

**ComEd Historical and Forecasted
Summer Peaks
(System Net Hourly Load - MW)**

<u>Year</u>	<u>Actual</u>	<u>Weather Adjusted</u>	<u>Date & Time</u>
1990	17,272	17,272	9/6 4-5 p.m.
1991	17,733	17,600	7/22 3-4 p.m.
1992	15,994	17,600	8/10 4-5 p.m.
1993	17,771	17,900	8/27 3-4 p.m.
1994	17,928	18,250	7/5 3-4 p.m.
1995	19,212	18,700	8/14 3-4 p.m.
1996	18,916	19,300	8/7 3-4 p.m.
1997	18,497	19,500	7/14 2-3 p.m.
1998	19,012	19,700	6/25 3-4 p.m.
1999	21,243	20,350	7/30 2-3 p.m.
2000	20,143	21,000	8/15 3-4 p.m.
2001	21,547	21,400	8/9 3-4 p.m.
2002	21,804	21,800	8/1 3-4 p.m.
2003	22,054	22,075	8/21 3-4 p.m.
2004	19,794	22,200	8/3 3-4 p.m. (1)
Forecasted Peaks:			
2005		22,700	
2006		23,150	
2007		23,600	
2008		24,050	
2009		24,475	

(1) ComEd entered PJM on May 1, 2004. Zone loads after that date represent PJM methodology, which differs from the previous years.

Load Forecasting
February 10, 2005