CHICAGO

ComEd Appendix A

OUTAGE ID	START DATE TIME	DATE TIME RESTORED	OUTAGE DURATION (MIN)	CIRCUIT	WARD AFFECTED	NUMBER OF CUSTOMERS AFFECTED	EQUIPMENT INVOLVED	RESTORATION AND REMEDIATION
758921	8/4/2008 19:39	8/5/2008 09:59	859	W3123	NULL	1	POLE	REPAIRED OVERHEAD MATERIAL
758176	8/4/2008 19:44	8/5/2008 11:00	915	G612	WARD19	1	CABLE-AERIAL	REPLACED OVERHEAD MATERIAL
758026	8/4/2008 20:03	8/5/2008 06:30	626	D5015	WARD13	39	PHASE WIRE (ALL VOLTAGES)	CLOSED SUBSTATION BREAKER
758217	8/4/2008 20:06	8/5/2008 04:10	483	Z10432	WARD13	515	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
759738	8/4/2008 20:07	8/6/2008 16:50	2,683	Z30741	WARD23	122	FUSE	REPLACED FUSE
757871	8/4/2008 20:08	8/4/2008 21:53	106	315X142	WARD41	204	PHASE WIRE (ALL VOLTAGES)	CLOSED SWITCH/DISCONNECT/LT
		8/4/2008 22:30	142		WARD41	941		
759856	8/4/2008 20:09	8/6/2008 16:30	2,660	310Y348	WARD28	151	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
758628	8/4/2008 20:10	8/5/2008 21:24	1,514	W2018	NULL	1	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
758631	8/4/2008 20:10	8/5/2008 00:40	270	W2018	NULL	1	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
759519	8/4/2008 20:11	8/6/2008 15:10	2,579	Z10430	WARD18	22	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
760060	8/4/2008 20:12	8/6/2008 21:50	2,978	X3937	WARD45	118	FUSE	CHANGED SIZE
758771	8/4/2008 20:12	8/5/2008 23:01	1,608	380X349	WARD31	81	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
757994	8/4/2008 20:13	8/5/2008 03:00	407	X3965	WARD38	91	FUSE	CLOSED FUSE
		8/5/2008 03:00	407		WARD45	1727		
761651	8/4/2008 20:13	8/4/2008 23:21	188	X4855	WARD36	1246	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
761574	8/4/2008 20:14	8/5/2008 01:58	344	Y1951	WARD3	43	CABLE	TEMPORARY SWITCHING
		8/5/2008 01:58	344		WARD11	117		
		8/5/2008 01:58	344		WARD20	61		
758537	8/4/2008 20:14	8/4/2008 21:45	91	X5456	WARD32	22	POLE	TEMPORARY SWITCHING
		8/5/2008 01:06	292		WARD32	176		
		8/5/2008 11:35	921		WARD32	1		
		8/5/2008 14:38	1,104		WARD32	4		
758213	8/4/2008 20:14	8/5/2008 10:46	872	Y3832	WARD27	1063	FUSE	CHANGED SIZE
761605	8/4/2008 20:14	8/5/2008 01:47	332	380X342	WARD30	285	PHASE WIRE (ALL VOLTAGES)	CLOSED SUBSTATION BREAKER
758216	8/4/2008 20:15	8/5/2008 11:40	924	X3939X	WARD39	2114	FUSE	REPLACED FUSE
		8/5/2008 11:40	924		WARD45	111		
759248	8/4/2008 20:16	8/6/2008 11:22	2,346	X11032	WARD39	187	FUSE	REPLACED FUSE
757879	8/4/2008 20:16	8/4/2008 23:19	183	Z1415	WARD15	773	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
		8/4/2008 23:19	183		WARD17	729		
		8/4/2008 23:19	183		WARD18	973		
758272	8/4/2008 20:16	8/5/2008 01:20	303	Z10440	WARD13	328	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE
		8/5/2008 01:20	303		WARD18	124		
758645	8/4/2008 20:17	8/5/2008 20:10	1,432	Y13062	WARD24	2012	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
758910	8/4/2008 20:17	8/6/2008 01:55	1,777	X5375	WARD30	516	FUSE	REPLACED FUSE
		8/6/2008 01:55	1,777		WARD35	320		
757914	8/4/2008 20:19	8/4/2008 21:38	79	X5334	WARD46	779	PHASE WIRE (ALL VOLTAGES)	TREE REMOVED
		8/4/2008 21:50	91		WARD40	273		
		8/4/2008 21:50	91		WARD47	1327		
758282	8/4/2008 20:19	8/5/2008 00:40	260	X3251	WARD37	558	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
		8/5/2008 01:58	338		NULL	18		
		8/5/2008 01:58	338		WARD29	414		
		8/5/2008 01:58	338		WARD37	976		
758397	8/4/2008 20:19	8/5/2008 12:10	950	Z13746	WARD16	1	FUSE	REPAIRED OVERHEAD MATERIAL
758976	8/4/2008 20:19	8/6/2008 05:48	2,008	Y3879	WARD37	213	PHASE WIRE (ALL VOLTAGES)	REPLACED OVERHEAD MATERIAL
758255	8/4/2008 20:21	8/4/2008 21:41	80	X8446	WARD40	27	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE
		8/4/2008 21:58	97		WARD40	1671		
		8/4/2008 22:29	128		WARD40	1		
		8/4/2008 22:29	128		WARD47	417		
		8/4/2008 22:29	128		WARD50	1		
760004	8/4/2008 20:21	8/6/2008 20:00	2,859	X7149	WARD41	89	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE
758031	8/4/2008 20:21	8/5/2008 04:57	516	D5001	WARD23	59	FUSE	REPLACED FUSE
758571	8/4/2008 20:22	8/5/2008 12:51	990	X7134	NULL	49	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
		8/5/2008 12:51	990		WARD41	237		
		8/5/2008 15:10	1,128		WARD41	110		
		8/5/2008 15:10	1,128		WARD45	130		
		8/5/2008 15:30	1,148		WARD45	147		
		8/5/2008 18:10	1,308		WARD45	654		
		8/5/2008 18:50	1,348		WARD45	108		
759996	8/4/2008 20:22	8/6/2008 21:00	2,918	Z13750	WARD20	61	FUSE	REPLACED FUSE
758318	8/4/2008 20:22	8/5/2008 12:45	982	Z8936	WARD19	80	FUSE	REPAIRED OVERHEAD MATERIAL
758624	8/4/2008 20:22	8/5/2008 20:17	1,435	X4072	WARD32	448	FUSE	REPAIRED OVERHEAD MATERIAL
757925	8/4/2008 20:23	8/4/2008 23:56	213	G651	WARD9	5	PHASE WIRE (ALL VOLTAGES)	TEMPORARY SWITCHING
		8/5/2008 01:30	307		NULL	1		
		8/5/2008 01:30	307		WARD9	110		
758241	8/4/2008 20:23	8/5/2008 12:17	954	Z8936	WARD19	42	FUSE	REPLACED FUSE
758566	8/4/2008 20:23	8/5/2008 16:45	1,221	X4048	WARD1	221	FUSE	REPLACED FUSE
		8/5/2008 16:45	1,221		WARD32	247		
758422	8/4/2008 20:23	8/5/2008 15:45	1,161	F961	NULL	10	PHASE WIRE (ALL VOLTAGES)	TREE REMOVED
759526	8/4/2008 20:24	8/6/2008 15:31	2,587	X5341	WARD44	304	FUSE	REPAIRED OVERHEAD MATERIAL
		8/6/2008 15:31	2,587		WARD47	108		
758476	8/4/2008 20:24	8/5/2008 16:45	1,221	Z8936	WARD19	148	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
761680	8/4/2008 20:25	8/5/2008 17:10	1,245	Z4347	WARD34	3	PHASE WIRE (ALL VOLTAGES)	TEMPORARY SWITCHING
760686	8/4/2008 20:25	8/7/2008 14:36	3,971	X5471	WARD43	36	CABLE-AERIAL	REPAIRED OVERHEAD MATERIAL
759963	8/4/2008 20:25	8/6/2008 20:26	2,880	Y2557	WARD28	274	PHASE WIRE (ALL VOLTAGES)	CLOSED FUSE
760312	8/4/2008 20:25	8/6/2008 23:09	3,043	750Y41	WARD30	1	PHASE WIRE (ALL VOLTAGES)	REPLACED OVERHEAD MATERIAL
759844	8/4/2008 20:26	8/6/2008 18:32	2,766	X1434	WARD44	240	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE

CHICAGO

ComEd Appendix A

OUTAGE ID	START DATE TIME	DATE TIME RESTORED	OUTAGE DURATION (MIN)	CIRCUIT	WARD AFFECTED	NUMBER OF CUSTOMERS AFFECTED	EQUIPMENT INVOLVED	RESTORATION AND REMEDIATION
758810	8/4/2008 20:26	8/5/2008 23:02	1,596	X5452	WARD32	264	FUSE	REPLACED FUSE
		8/5/2008 23:02	1,596		WARD43	242		
759827	8/4/2008 20:26	8/6/2008 18:57	2,791	Z1406	WARD18	36	TRANSFORMER-OVHD	REPLACED TRANSFORMER
759283	8/4/2008 20:27	8/6/2008 10:20	2,273	300X057	WARD47	81	FUSE	REPLACED FUSE
760332	8/4/2008 20:27	8/7/2008 07:12	3,525	Z4332	WARD9	120	FUSE	REPLACED FUSE
758564	8/4/2008 20:27	8/5/2008 16:45	1,217	X4048	WARD1	16	FUSE	REPLACED FUSE
		8/5/2008 16:45	1,217		WARD32	68		
758456	8/4/2008 20:27	8/5/2008 16:25	1,197	X3935	WARD45	83	CUTOUT	REPLACED CUTOUT
758995	8/4/2008 20:27	8/6/2008 06:00	2,012	Z4332	WARD9	21	PHASE WIRE (ALL VOLTAGES)	CLOSED FUSE
761663	8/4/2008 20:28	8/4/2008 21:53	85	X7137	WARD41	1146	PHASE WIRE (ALL VOLTAGES)	TEMPORARY SWITCHING
759764	8/4/2008 20:28	8/6/2008 14:45	2,537	X5466	WARD43	325	FUSE	REPLACED FUSE
761656	8/4/2008 20:29	8/4/2008 20:56	27	Y8268	WARD27	1	PHASE WIRE (ALL VOLTAGES)	TEMPORARY SWITCHING
		8/4/2008 20:56	27		WARD42	156		
		8/4/2008 20:56	27		WARD43	792		
759563	8/4/2008 20:29	8/6/2008 16:08	2,618	301X042	WARD30	120	CUTOUT	REPLACED CUTOUT
758030	8/4/2008 20:29	8/5/2008 05:00	510	Z15093	WARD7	221	CABLE	TEMPORARY SWITCHING
		8/5/2008 05:00	510		WARD8	378		
		8/5/2008 06:01	571		WARD8	676		
		8/5/2008 06:50	620		WARD10	325		
759059	8/4/2008 20:30	8/5/2008 21:30	1,500	X3252	WARD30	536	FUSE	REPLACED FUSE
		8/5/2008 21:30	1,500		WARD31	427		
759017	8/4/2008 20:30	8/6/2008 03:00	1,830	X8463	WARD48	265	FUSE	REPLACED FUSE
		8/6/2008 06:10	2,020		WARD46	71		
		8/6/2008 06:10	2,020		WARD48	53		
759220	8/4/2008 20:30	8/6/2008 11:38	2,347	687X47	WARD41	108	FUSE	REPLACED FUSE
760366	8/4/2008 20:31	8/7/2008 09:30	3,659	Y84048	WARD25	2	FUSE	REPLACED FUSE
759991	8/4/2008 20:31	8/6/2008 20:53	2,902	D5011	WARD23	77	FUSE	REPLACED FUSE
757930	8/4/2008 20:31	8/5/2008 01:51	320	X7131	NULL	7	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
		8/5/2008 01:51	320		WARD41	1024		
758038	8/4/2008 20:31	8/5/2008 05:35	544	X4033	WARD32	151	FUSE	REPLACED FUSE
759161	8/4/2008 20:31	8/6/2008 10:53	2,302	Y13062	WARD24	42	CABLE-AERIAL	REPAIRED OVERHEAD MATERIAL
760334	8/4/2008 20:32	8/6/2008 09:09	2,197	X4072	WARD32	42	FUSE	REPLACED FUSE
760033	8/4/2008 20:32	8/6/2008 21:15	2,923	Z6351	WARD23	262	SWITCH-LTD	CLOSED SWITCH/DISCONNECT/LT
760232	8/4/2008 20:32	8/7/2008 03:45	3,313	Y8269	WARD27	254	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
758894	8/4/2008 20:32	8/5/2008 22:36	1,563	Z15087	NULL	28	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
		8/5/2008 22:36	1,563		WARD7	852		
		8/5/2008 22:36	1,563		WARD10	386		
759796	8/4/2008 20:32	8/6/2008 18:26	2,753	X4865	WARD36	145	FUSE	REPLACED FUSE
758902	8/4/2008 20:33	8/5/2008 20:44	1,451	X4035	WARD32	30	FUSE	TREE REMOVED
		8/5/2008 21:06	1,473		WARD32	246		
759115	8/4/2008 20:33	8/6/2008 09:58	2,245	X3256	WARD30	74	CABLE-AERIAL	REPAIRED OVERHEAD MATERIAL
759578	8/4/2008 20:33	8/6/2008 15:17	2,563	310Y348	WARD28	50	FUSE	REPAIRED OVERHEAD MATERIAL
759198	8/4/2008 20:33	8/6/2008 11:25	2,331	X3964	WARD38	136	FUSE	REPAIRED OVERHEAD MATERIAL
761109	8/4/2008 20:34	8/7/2008 20:17	4,302	Y3081	WARD28	1	PHASE WIRE (ALL VOLTAGES)	REPLACED OVERHEAD MATERIAL
759140	8/4/2008 20:34	8/6/2008 09:20	2,205	X5356	WARD39	249	FUSE	REPLACED FUSE
760014	8/4/2008 20:34	8/6/2008 21:17	2,922	X7150	WARD41	9	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
760084	8/4/2008 20:34	8/5/2008 02:16	342	X7136	WARD41	1243	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
		8/5/2008 13:05	990		WARD41	199		
		8/6/2008 19:20	2,805		WARD41	52		
758314	8/4/2008 20:35	8/5/2008 13:24	1,009	Z5536	WARD10	736	PHASE WIRE (ALL VOLTAGES)	CLOSED SUBSTATION BREAKER
758709	8/4/2008 20:35	8/5/2008 21:43	1,508	X8438	WARD49	655	FUSE	REPAIRED OVERHEAD MATERIAL
759363	8/4/2008 20:36	8/6/2008 14:08	2,492	Y3847	WARD28	5	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
759097	8/4/2008 20:36	8/6/2008 09:05	2,189	X1439	WARD35	132	FUSE	REPLACED FUSE
758496	8/4/2008 20:39	8/5/2008 15:32	1,133	Z17434	WARD4	538	FUSE	REPLACED FUSE
761644	8/4/2008 20:39	8/4/2008 21:03	23	031X041	WARD29	471	PHASE WIRE (ALL VOLTAGES)	CLOSED SUBSTATION BREAKER
		8/4/2008 21:03	23		WARD30	225		
		8/4/2008 21:03	23		WARD37	69		
758700	8/4/2008 20:40	8/5/2008 19:50	1,390	X3946	WARD30	720	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
		8/5/2008 19:50	1,390		WARD31	264		
758308	8/4/2008 20:40	8/5/2008 13:41	1,021	Z15077	WARD7	50	PHASE WIRE (ALL VOLTAGES)	TREE REMOVED
		8/5/2008 13:41	1,021		WARD10	527		
758412	8/4/2008 20:44	8/5/2008 14:52	1,088	HARP36	WARD5	117	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
758195	8/4/2008 20:44	8/5/2008 10:32	828	X5459	WARD43	358	FUSE	REPLACED FUSE
760089	8/4/2008 20:44	8/6/2008 22:29	2,985	Z6346	WARD23	25	FUSE	REPLACED FUSE
759517	8/4/2008 20:44	8/6/2008 15:17	2,553	310Y348	WARD28	199	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
760049	8/4/2008 20:45	8/5/2008 18:00	1,274	X1438	WARD33	173	TRANSFORMER-OVHD	REPLACED TRANSFORMER
		8/6/2008 18:00	2,714		WARD33	39		
759125	8/4/2008 20:45	8/6/2008 08:50	2,164	Z3351	WARD18	80	FUSE	REPLACED FUSE
759594	8/4/2008 20:46	8/6/2008 16:15	2,608	Y3880	WARD27	31	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
		8/6/2008 16:15	2,608		WARD28	91		
760335	8/4/2008 20:46	8/7/2008 08:02	3,555	WILD041	WARD9	17	FUSE	REPLACED FUSE
762448	8/4/2008 20:47	8/6/2008 19:30	2,803	300X054	WARD40	99	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
758761	8/4/2008 20:47	8/5/2008 22:43	1,556	380X451	WARD31	1	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
761053	8/4/2008 20:47	8/7/2008 19:28	4,241	Y3873	WARD35	1	PHASE WIRE (ALL VOLTAGES)	TREE REMOVED
758002	8/4/2008 20:48	8/5/2008 04:58	490	Z11863	NULL	19	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
		8/5/2008 04:58	490		WARD21	2169		
759292	8/4/2008 20:48	8/6/2008 12:15	2,366	SCHG55	WARD7	98	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
759873	8/4/2008 20:49	8/6/2008 19:34	2,805	THRP49	WARD17	144	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL

CHICAGO

ComEd Appendix A

OUTAGE ID	START DATE TIME	DATE TIME RESTORED	OUTAGE DURATION (MIN)	CIRCUIT	WARD AFFECTED	NUMBER OF CUSTOMERS AFFECTED	EQUIPMENT INVOLVED	RESTORATION AND REMEDIATION
759584	8/4/2008 20:49	8/6/2008 16:00	2,591	Z8949	WARD19	16	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
759060	8/4/2008 20:49	8/6/2008 08:20	2,130	X7150	WARD41	43	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE
759104	8/4/2008 20:52	8/6/2008 09:40	2,208	Y8238	WARD32	46	FUSE	REPLACED FUSE
759755	8/4/2008 20:52	8/6/2008 17:41	2,689	X3247	WARD31	37	ARRESTER-PORCELAIN	REPLACED OVERHEAD MATERIAL
759304	8/4/2008 20:52	8/6/2008 12:50	2,398	X5346	WARD33	176	FUSE	REPLACED FUSE
758656	8/4/2008 20:52	8/5/2008 14:18	1,046	691X548	WARD32	266	FUSE	REPAIRED OVERHEAD MATERIAL
		8/5/2008 20:24	1,412		WARD32	45		
759506	8/4/2008 20:52	8/6/2008 15:23	2,551	626X49	WARD36	42	FUSE	REPLACED FUSE
760724	8/4/2008 20:52	8/6/2008 00:19	1,647	X3745	WARD36	554	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
759718	8/4/2008 20:52	8/6/2008 17:00	2,648	301X046	WARD38	22	FUSE	REPLACED FUSE
759041	8/4/2008 20:52	8/6/2008 07:30	2,077	032X041	WARD29	62	FUSE	REPLACED FUSE
759035	8/4/2008 20:53	8/6/2008 07:30	2,076	X3747	WARD36	64	TAP WIRE	REPLACED OVERHEAD MATERIAL
760222	8/4/2008 20:54	8/7/2008 02:48	3,234	SCHG241	WARD10	206	SWITCHGEAR	CLOSED SWITCH/DISCONNECT/LT
		8/7/2008 03:09	3,255		WARD10	36		
758539	8/4/2008 20:54	8/5/2008 18:44	1,309	Z8931	WARD19	22	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE
763516	8/4/2008 20:55	8/6/2008 19:00	2,765	Z8935	WARD19	32	FUSE	REPLACED FUSE
759691	8/4/2008 20:55	8/6/2008 17:06	2,651	X3934	WARD38	139	CROSS-ARM BRACE	REPLACED OVERHEAD MATERIAL
759037	8/4/2008 20:56	8/6/2008 07:30	2,074	X3747	WARD36	52	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
758697	8/4/2008 20:56	8/5/2008 21:10	1,454	X3966	WARD45	64	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
761370	8/4/2008 20:56	8/8/2008 05:05	4,809	X5383	WARD33	1	CABLE-AERIAL	REPLACED OVERHEAD MATERIAL
759178	8/4/2008 20:57	8/6/2008 10:30	2,253	X4040	WARD44	30	FUSE	REPLACED FUSE
759721	8/4/2008 20:57	8/6/2008 17:23	2,666	X7133	WARD41	14	TRANSFORMER-OVHD	REPLACED TRANSFORMER
759163	8/4/2008 20:57	8/6/2008 10:40	2,262	Z5541	WARD10	49	PHASE WIRE (ALL VOLTAGES)	CLOSED FUSE
758970	8/4/2008 20:58	8/5/2008 19:59	1,380	Y3840	WARD27	49	FUSE	REPLACED FUSE
		8/6/2008 05:45	1,966		WARD27	137		
760385	8/4/2008 20:59	8/7/2008 10:01	3,661	X5452	WARD32	63	AUTOMATIC SPLICE	REPAIRED OVERHEAD MATERIAL
759793	8/4/2008 21:01	8/6/2008 18:24	2,723	Z17441	WARD4	41	FUSE	REPLACED OVERHEAD MATERIAL
758544	8/4/2008 21:02	8/5/2008 18:50	1,308	Z11872	WARD6	200	FUSE	REPLACED FUSE
760921	8/4/2008 21:03	8/6/2008 21:00	2,876	X4865	WARD36	32	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
758219	8/4/2008 21:05	8/5/2008 11:45	880	Z6353	WARD14	21	CUTOUT	REPLACED FUSE
760050	8/4/2008 21:06	8/6/2008 21:44	2,918	Y3031	WARD28	87	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE
758670	8/4/2008 21:06	8/5/2008 19:20	1,333	Z3334	WARD18	186	PHASE WIRE (ALL VOLTAGES)	CLOSED FUSE
760911	8/4/2008 21:06	8/7/2008 17:13	4,086	310Y346	WARD28	19	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
759317	8/4/2008 21:07	8/6/2008 13:15	2,408	X4074	WARD26	82	PHASE WIRE (ALL VOLTAGES)	REPLACED OVERHEAD MATERIAL
		8/6/2008 13:15	2,408		WARD35	71		
758050	8/4/2008 21:09	8/5/2008 06:37	567	X4034	WARD32	3	FUSE	REPLACED FUSE
759472	8/4/2008 21:09	8/6/2008 14:47	2,497	310Y244	WARD28	57	FUSE	REPLACED FUSE
758725	8/4/2008 21:09	8/5/2008 21:00	1,430	310X246	WARD33	651	FUSE	REPAIRED OVERHEAD MATERIAL
761024	8/4/2008 21:11	8/7/2008 19:04	4,193	Y13058	WARD22	7	FUSE	REPLACED FUSE
759532	8/4/2008 21:11	8/6/2008 15:43	2,551	X3152	WARD36	1	CABLE-AERIAL	REPAIRED OVERHEAD MATERIAL
759183	8/4/2008 21:11	8/6/2008 10:30	2,238	X4040	WARD44	52	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE
759751	8/4/2008 21:13	8/4/2008 23:25	132	Z5541	WARD10	2	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
		8/5/2008 01:18	245		NULL	1		
		8/5/2008 01:18	245		WARD10	13		
		8/5/2008 23:25	1,572		WARD10	2		
760413	8/4/2008 21:13	8/7/2008 09:25	3,612	X3254	WARD31	65	FUSE	REPLACED FUSE
758720	8/4/2008 21:13	8/5/2008 20:46	1,412	X8454	WARD47	55	FUSE	REPLACED FUSE
		8/5/2008 20:57	1,423		WARD47	1040		
761083	8/4/2008 21:17	8/7/2008 19:15	4,198	Y3873	WARD26	34	TRANSFORMER-OVHD	REPLACED TRANSFORMER
758543	8/4/2008 21:17	8/5/2008 18:45	1,288	Y8273	WARD27	244	FUSE	REPLACED FUSE
		8/5/2008 18:45	1,288		WARD43	6		
759734	8/4/2008 21:20	8/6/2008 16:58	2,617	X4059	WARD44	1110	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE
759493	8/4/2008 21:24	8/6/2008 13:39	2,415	Y3880	WARD26	80	FUSE	REPLACED FUSE
		8/6/2008 13:39	2,415		WARD27	26		
760579	8/4/2008 21:24	8/7/2008 12:45	3,801	Z11863	WARD21	26	TRANSFORMER-OVHD	REPLACED TRANSFORMER
760485	8/4/2008 21:27	8/7/2008 10:45	3,678	GRDX30	WARD8	22	PHASE WIRE (ALL VOLTAGES)	REPLACED OVERHEAD MATERIAL
761379	8/4/2008 21:29	8/8/2008 04:55	4,765	X5365	WARD35	1	CABLE-AERIAL	REPLACED OVERHEAD MATERIAL
760497	8/4/2008 21:31	8/7/2008 11:48	3,737	Z4142	WARD9	1	CABLE-AERIAL	REPAIRED OVERHEAD MATERIAL
760414	8/4/2008 21:31	8/6/2008 22:12	2,921	X3134	WARD36	1	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
758380	8/4/2008 21:32	8/5/2008 14:40	1,027	Z15091	WARD5	706	FUSE	REPLACED FUSE
		8/5/2008 14:40	1,027		WARD8	386		
760674	8/4/2008 21:38	8/6/2008 03:00	1,762	X8463	WARD48	128	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
		8/6/2008 06:10	1,952		WARD46	37		
		8/6/2008 06:10	1,952		WARD48	83		
760944	8/4/2008 21:42	8/7/2008 17:43	4,081	Z3334	WARD18	1	CABLE-AERIAL	REPAIRED OVERHEAD MATERIAL
758000	8/4/2008 21:42	8/5/2008 04:58	435	Z11863	WARD21	115	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
759312	8/4/2008 21:44	8/6/2008 12:45	2,341	Z4133	WARD9	1	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
760491	8/4/2008 21:44	8/7/2008 10:45	3,660	Z8940	WARD34	18	TRANSFORMER-OVHD	REPLACED TRANSFORMER
761998	8/4/2008 21:45	8/5/2008 23:00	1,514	603X44	WARD38	1	CABLE-AERIAL	REPLACED OVERHEAD MATERIAL
761313	8/4/2008 21:45	8/6/2008 19:11	2,725	C298	WARD41	1	TRANSFORMER-OVHD	REPLACED TRANSFORMER
761039	8/4/2008 21:45	8/7/2008 19:10	4,164	310Y245	WARD29	51	CUTOUT	CLOSED CUTOUT
758311	8/4/2008 21:47	8/5/2008 12:43	895	Y3076	WARD27	3	PHASE WIRE (ALL VOLTAGES)	REPLACED OVERHEAD MATERIAL
		8/5/2008 12:43	895		WARD28	153		
759598	8/4/2008 22:00	8/6/2008 16:00	2,519	Z8949	WARD19	13	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE
759031	8/4/2008 22:09	8/6/2008 07:40	2,011	X7152	WARD38	1	TERMINATION	REPAIRED UNDERGROUND MATERIAL
759881	8/4/2008 22:11	8/5/2008 14:15	964	Y13059	WARD24	164	TRANSFORMER-OVHD	REPLACED TRANSFORMER
		8/6/2008 19:45	2,734		WARD24	15		
758948	8/4/2008 22:11	8/6/2008 02:52	1,721	793Y31	WARD37	438	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL

CHICAGO

ComEd Appendix A

OUTAGE ID	START DATE TIME	DATE TIME RESTORED	OUTAGE DURATION (MIN)	CIRCUIT	WARD AFFECTED	NUMBER OF CUSTOMERS AFFECTED	EQUIPMENT INVOLVED	RESTORATION AND REMEDIATION
760258	8/4/2008 22:12	8/7/2008 02:45	3,152	Z8931	WARD21	1	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
761084	8/4/2008 22:16	8/7/2008 19:00	4,123	300X051	WARD47	43	TRANSFORMER-OVHD	REPLACED TRANSFORMER
760015	8/4/2008 22:19	8/6/2008 21:19	2,819	Z3349	WARD16	42	FUSE	REPLACED FUSE
760781	8/4/2008 22:29	8/7/2008 15:47	3,917	Y3859	WARD1	42	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
761095	8/4/2008 22:31	8/7/2008 20:09	4,178	310X352	WARD33	74	TRANSFORMER-OVHD	REPLACED TRANSFORMER
759551	8/4/2008 22:39	8/6/2008 11:31	2,212	X3947	WARD38	34	PHASE WIRE (ALL VOLTAGES)	CLOSED RECLOSER-LINE
761226	8/4/2008 22:46	8/7/2008 22:30	4,303	Z13785	WARD6	38	TRANSFORMER-OVHD	REPLACED TRANSFORMER
758703	8/4/2008 22:48	8/5/2008 21:39	1,371	X3960	WARD30	1	PHASE WIRE (ALL VOLTAGES)	REPLACED OVERHEAD MATERIAL
758446	8/4/2008 23:02	8/5/2008 16:26	1,043	X3935	WARD45	21	CUTOUT	REPLACED CUTOUT
758436	8/4/2008 23:03	8/5/2008 11:05	722	C298	WARD41	175	PHASE WIRE (ALL VOLTAGES)	TEMPORARY SWITCHING
		8/5/2008 12:20	796		WARD41	92		
		8/5/2008 15:50	1,006		WARD41	13		
758233	8/4/2008 23:05	8/5/2008 11:28	743	Z11884	WARD6	65	FUSE	REPLACED FUSE
		8/5/2008 11:28	743		WARD8	85		
761566	8/4/2008 23:06	8/4/2008 23:18	12	X7144	WARD41	1029	PHASE WIRE (ALL VOLTAGES)	TEMPORARY SWITCHING
		8/4/2008 23:18	12		WARD45	939		
759182	8/4/2008 23:07	8/6/2008 10:30	2,122	X4040	WARD44	36	FUSE	REPLACED FUSE
758881	8/4/2008 23:09	8/6/2008 02:03	1,613	687X049	WARD45	43	FUSE	CLOSED SWITCH/DISCONNECT/LT
760388	8/4/2008 23:09	8/7/2008 10:01	3,531	X9158	WARD50	136	FUSE	REPLACED FUSE
761491	8/4/2008 23:10	8/5/2008 00:18	68	626X49	WARD36	367	PHASE WIRE (ALL VOLTAGES)	TEMPORARY SWITCHING
760211	8/4/2008 23:11	8/7/2008 02:50	3,099	313X247	WARD46	49	CABLE-AERIAL	REPAIRED OVERHEAD MATERIAL
758776	8/4/2008 23:11	8/5/2008 16:20	1,029	X7144	WARD45	301	FUSE	REPLACED FUSE
758351	8/4/2008 23:11	8/5/2008 11:30	738	X3933	WARD45	344	FUSE	REPLACED FUSE
		8/5/2008 14:24	913		WARD45	36		
759322	8/4/2008 23:14	8/6/2008 10:00	2,085	X5376	WARD33	231	FUSE	REPLACED FUSE
759605	8/4/2008 23:14	8/6/2008 16:38	2,483	Y3880	WARD28	35	FUSE	REPLACED FUSE
759309	8/4/2008 23:15	8/6/2008 12:26	2,231	X3133	WARD38	473	PHASE WIRE (ALL VOLTAGES)	REPLACED OVERHEAD MATERIAL
760038	8/4/2008 23:15	8/6/2008 20:26	2,710	687X044	WARD45	23	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE
761455	8/4/2008 23:17	8/8/2008 10:37	4,999	X3937	WARD45	1	CABLE-AERIAL	REPAIRED OVERHEAD MATERIAL
761447	8/4/2008 23:18	8/4/2008 23:48	30	Y71447	NULL	37	PHASE WIRE (ALL VOLTAGES)	CLOSED SUBSTATION BREAKER
		8/4/2008 23:48	30		WARD2	827		
		8/4/2008 23:48	30		WARD25	1275		
757956	8/4/2008 23:19	8/5/2008 00:36	77	X3936	WARD31	638	PHASE WIRE (ALL VOLTAGES)	REPLACED OVERHEAD MATERIAL
		8/5/2008 00:51	92		WARD31	752		
		8/5/2008 00:51	92		WARD38	462		
		8/5/2008 00:52	94		WARD30	144		
		8/5/2008 00:52	94		WARD38	488		
		8/5/2008 03:24	246		WARD30	4		
		8/5/2008 03:24	246		WARD31	338		
		8/5/2008 03:24	246		WARD38	2		
759890	8/4/2008 23:19	8/6/2008 19:14	2,635	X3978	WARD45	37	FUSE	REPLACED FUSE
760772	8/4/2008 23:20	8/7/2008 15:00	3,819	X3941	WARD30	1	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
761247	8/4/2008 23:25	8/7/2008 00:26	2,940	X3978	WARD45	19	FUSE	REPAIRED TRANSFORMER
758284	8/4/2008 23:27	8/5/2008 01:46	139	674X45	WARD31	496	CABLE	TEMPORARY SWITCHING
761453	8/4/2008 23:28	8/4/2008 23:39	11	Y1977	NULL	2	PHASE WIRE (ALL VOLTAGES)	TEMPORARY SWITCHING
		8/4/2008 23:39	11		WARD25	1369		
758848	8/4/2008 23:28	8/6/2008 00:57	1,528	X3966	WARD45	81	FUSE	CLOSED FUSE
761457	8/4/2008 23:29	8/4/2008 23:49	20	Y71461	WARD2	210	PHASE WIRE (ALL VOLTAGES)	TEMPORARY SWITCHING
		8/4/2008 23:49	20		WARD28	221		
758362	8/4/2008 23:30	8/5/2008 13:20	829	Y3837	WARD26	107	PHASE WIRE (ALL VOLTAGES)	REPLACED OVERHEAD MATERIAL
		8/5/2008 13:20	829		WARD27	779		
762473	8/4/2008 23:30	8/5/2008 11:15	704	Y3078	WARD29	1187	FUSE	REPLACED FUSE
758961	8/4/2008 23:31	8/6/2008 04:45	1,754	G6086	NULL	2	PHASE WIRE (ALL VOLTAGES)	TREE REMOVED
759120	8/4/2008 23:31	8/6/2008 00:30	1,499	300X046	WARD47	331	CABLE-AERIAL	REPAIRED OVERHEAD MATERIAL
		8/6/2008 01:45	1,574		WARD47	73		
762475	8/4/2008 23:31	8/5/2008 08:41	550	X7148	WARD45	413	FUSE	REPLACED FUSE
		8/5/2008 09:10	579		WARD45	220		
759457	8/4/2008 23:31	8/6/2008 14:42	2,351	X5365	WARD35	141	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE
760784	8/4/2008 23:31	8/6/2008 01:34	1,562	X1439	WARD1	266	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
		8/6/2008 01:34	1,562		WARD35	183		
761417	8/4/2008 23:31	8/5/2008 00:13	41	Y3850	WARD26	1943	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
		8/5/2008 00:13	41		WARD37	14		
758270	8/4/2008 23:32	8/5/2008 02:24	172	Z1411	WARD18	1471	PHASE WIRE (ALL VOLTAGES)	CLOSED SUBSTATION BREAKER
761016	8/4/2008 23:32	8/6/2008 20:07	2,675	X3747	WARD36	47	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
761458	8/4/2008 23:36	8/5/2008 00:10	34	381X049	WARD1	556	PHASE WIRE (ALL VOLTAGES)	TEMPORARY SWITCHING
761426	8/4/2008 23:37	8/5/2008 00:05	27	Y3833	WARD2	1	AUTOMATIC SPLICE	REPAIRED OVERHEAD MATERIAL
		8/5/2008 00:05	27		WARD26	271		
		8/5/2008 00:05	27		WARD27	618		
		8/5/2008 00:05	27		WARD42	13		
761427	8/4/2008 23:39	8/5/2008 06:00	381	Y71455	NULL	39	PHASE WIRE (ALL VOLTAGES)	TEMPORARY SWITCHING
		8/5/2008 06:00	381		WARD2	266		
		8/5/2008 06:00	381		WARD24	2		
		8/5/2008 06:00	381		WARD28	437		
758943	8/4/2008 23:44	8/5/2008 10:05	621	Z1408	WARD15	1721	PHASE WIRE (ALL VOLTAGES)	TEMPORARY SWITCHING
		8/5/2008 10:37	653		WARD15	164		
		8/5/2008 19:30	1,186		WARD17	114		
760906	8/4/2008 23:44	8/6/2008 00:30	1,485	300X046	WARD47	198	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
		8/6/2008 01:45	1,560		WARD47	60		

CHICAGO

OUTAGE ID	START DATE TIME	DATE TIME RESTORED	OUTAGE DURATION (MIN)	CIRCUIT	WARD AFFECTED	NUMBER OF CUSTOMERS AFFECTED	EQUIPMENT INVOLVED	RESTORATION AND REMEDIATION
759988	8/4/2008 23:44	8/6/2008 18:55	2,590	X3745	WARD36	297	FUSE	CLOSED FUSE
761436	8/4/2008 23:44	8/5/2008 02:21	156	Y1943	WARD25	389	PHASE WIRE (ALL VOLTAGES)	OTHER NO FURTHER DETAIL
759715	8/4/2008 23:44	8/6/2008 17:14	2,489	X5356	WARD45	38	FUSE	REPLACED FUSE
760275	8/4/2008 23:45	8/7/2008 05:45	3,240	X3236	WARD37	101	POLE	REPLACED FUSE
758277	8/4/2008 23:45	8/5/2008 06:13	388	X3141	WARD30	814	PHASE WIRE (ALL VOLTAGES)	TEMPORARY SWITCHING
		8/5/2008 06:13	388		WARD31	837		
759593	8/4/2008 23:45	8/6/2008 16:20	2,435	368X045	WARD45	13	FUSE	REPLACED FUSE
760915	8/4/2008 23:45	8/5/2008 18:50	1,145	MFLD251	WARD16	195	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
758869	8/4/2008 23:45	8/6/2008 01:30	1,545	DRXL042	WARD6	140	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
757961	8/4/2008 23:45	8/5/2008 02:15	150	Z11869	WARD21	1268	PHASE WIRE (ALL VOLTAGES)	CLOSED SUBSTATION BREAKER
		8/5/2008 03:14	209		WARD17	57		
		8/5/2008 03:14	209		WARD21	1309		
758850	8/4/2008 23:45	8/6/2008 00:57	1,512	X3966	WARD45	46	FUSE	CLOSED FUSE
762294	8/4/2008 23:45	8/5/2008 12:40	775	X3249	WARD29	99	FUSE	REPLACED FUSE
		8/5/2008 12:40	775		WARD37	738		
759710	8/4/2008 23:45	8/6/2008 17:04	2,479	X3134	WARD36	151	FUSE	REPAIRED OVERHEAD MATERIAL
758959	8/4/2008 23:45	8/6/2008 04:29	1,724	Y13056	WARD12	370	PHASE WIRE (ALL VOLTAGES)	CLOSED FUSE
760252	8/4/2008 23:46	8/7/2008 03:40	3,113	ARCH044	WARD23	95	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
759070	8/4/2008 23:48	8/5/2008 18:50	1,142	MFLD251	WARD16	325	PHASE WIRE (ALL VOLTAGES)	CLOSED FUSE
758205	8/4/2008 23:48	8/5/2008 01:12	84	X4855	WARD36	1111	PHASE WIRE (ALL VOLTAGES)	TEMPORARY SWITCHING
758181	8/4/2008 23:48	8/5/2008 04:16	268	798Y45	WARD27	25	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
		8/5/2008 10:25	636		WARD27	9		
761420	8/4/2008 23:49	8/5/2008 11:03	674	Y3477	WARD27	1	PHASE WIRE (ALL VOLTAGES)	TEMPORARY SWITCHING
		8/5/2008 11:03	674		WARD42	1		
758688	8/4/2008 23:50	8/5/2008 17:45	1,075	Y13080	WARD22	485	PHASE WIRE (ALL VOLTAGES)	CLOSED CUTOUT
761207	8/4/2008 23:50	8/5/2008 23:57	1,446	X3966	WARD45	576	TRANSFORMER-OVHD	REPLACED TRANSFORMER
		8/7/2008 22:15	4,224		WARD45	39		
761413	8/4/2008 23:51	8/5/2008 01:55	124	Y71437	WARD2	474	PHASE WIRE (ALL VOLTAGES)	TEMPORARY SWITCHING
		8/5/2008 01:55	124		WARD25	130		
761021	8/4/2008 23:53	8/6/2008 14:23	2,310	X3964	WARD38	42	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
761402	8/4/2008 23:53	8/5/2008 00:15	22	761Y240	WARD42	100	PHASE WIRE (ALL VOLTAGES)	TEMPORARY SWITCHING
760208	8/4/2008 23:54	8/6/2008 20:38	2,684	Z15031	WARD8	290	PHASE WIRE (ALL VOLTAGES)	CLOSED FUSE
		8/7/2008 01:35	2,981		WARD8	18		
761400	8/4/2008 23:55	8/5/2008 18:16	1,101	28TH243	WARD22	660	PHASE WIRE (ALL VOLTAGES)	TEMPORARY SWITCHING
758857	8/4/2008 23:55	8/5/2008 23:30	1,415	Y2534	NULL	1	CABLE	TEMPORARY SWITCHING
		8/5/2008 23:30	1,415		WARD12	9		
		8/6/2008 00:45	1,490		WARD12	167		
		8/6/2008 00:52	1,497		WARD12	1		
758312	8/4/2008 23:57	8/5/2008 13:45	827	Z5535	WARD10	1	CABLE-AERIAL	REPAIRED OVERHEAD MATERIAL
763435	8/4/2008 23:57	8/7/2008 15:13	3,795	X11038	WARD39	9	PHASE WIRE (ALL VOLTAGES)	REPLACED OVERHEAD MATERIAL
		8/7/2008 15:37	3,819		WARD39	6		
760850	8/4/2008 23:57	8/7/2008 16:43	3,885	793Y45	WARD28	50	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
759974	8/4/2008 23:58	8/6/2008 04:40	1,721	Y1977	NULL	2	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
		8/6/2008 04:40	1,721		WARD25	24		
		8/6/2008 20:30	2,671		WARD25	9		
761229	8/4/2008 23:58	8/6/2008 19:54	2,635	X3152	WARD36	21	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE
758378	8/4/2008 23:59	8/5/2008 13:39	820	Y13047	WARD22	1089	PHASE WIRE (ALL VOLTAGES)	CLOSED FUSE
758875	8/4/2008 23:59	8/6/2008 01:30	1,531	DRXL042	WARD6	282	SWITCH-LOADBRK	CLOSED SWITCH/DISCONNECT/LT
761041	8/4/2008 23:59	8/7/2008 19:08	4,028	039X159	WARD38	1	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
760087	8/4/2008 23:59	8/6/2008 22:26	2,786	Y2566	WARD11	20	POLE	REPLACED EQUIPMENT
760733	8/5/2008 00:00	8/6/2008 11:30	2,130	Z74134	WARD11	148	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
		8/6/2008 12:58	2,219		WARD11	44		
758534	8/5/2008 00:00	8/5/2008 17:24	1,043	Y1955	WARD2	1	SWITCH-AIRBREAK	CLOSED SWITCH/DISCONNECT/LT
		8/5/2008 17:24	1,043		WARD25	800		
758215	8/5/2008 00:00	8/5/2008 11:50	709	X3932	WARD38	1	CABLE-AERIAL	TREE TRIMMED
759748	8/5/2008 00:00	8/6/2008 17:10	2,469	Z15071	WARD7	80	TRANSFORMER-OVHD	REPLACED TRANSFORMER
760037	8/5/2008 00:01	8/6/2008 21:32	2,731	X3947	WARD38	5	PHASE WIRE (ALL VOLTAGES)	REPLACED OVERHEAD MATERIAL
		8/6/2008 21:32	2,731		WARD45	116		
759092	8/5/2008 00:01	8/5/2008 23:40	1,418	27TH450	WARD2	121	CABLE	TEMPORARY SWITCHING
		8/5/2008 23:40	1,418		WARD3	121		
		8/5/2008 23:40	1,418		WARD4	11		
760278	8/5/2008 00:02	8/5/2008 22:50	1,368	Z13778	WARD5	254	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
		8/6/2008 03:55	1,673		WARD5	197		
		8/7/2008 23:00	4,258		WARD5	7		
759201	8/5/2008 00:02	8/6/2008 11:20	2,118	Y13056	WARD12	112	FUSE	REPLACED FUSE
761697	8/5/2008 00:02	8/5/2008 16:55	1,013	Y71434	WARD25	32	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
758666	8/5/2008 00:02	8/5/2008 19:15	1,153	Z4342	WARD34	678	PHASE WIRE (ALL VOLTAGES)	CLOSED FUSE
760282	8/5/2008 00:03	8/6/2008 20:21	2,658	Z13762	WARD6	57	TRANSFORMER-OVHD	REPLACED TRANSFORMER
758048	8/5/2008 00:03	8/5/2008 06:37	393	X4034	WARD32	1	FUSE	REPLACED FUSE
760848	8/5/2008 00:04	8/5/2008 22:10	1,326	HYPK345	WARD4	1125	PHASE WIRE (ALL VOLTAGES)	TEMPORARY SWITCHING
760094	8/5/2008 00:04	8/6/2008 19:20	2,595	56TH143	WARD3	13	FUSE	REPLACED FUSE
760822	8/5/2008 00:04	8/5/2008 08:02	477	365Y247	WARD25	123	PHASE WIRE (ALL VOLTAGES)	CLOSED RECLOSER-SUBSTATION
		8/5/2008 08:02	477		WARD28	236		
760836	8/5/2008 00:06	8/5/2008 00:40	34	Y2534	NULL	1	PHASE WIRE (ALL VOLTAGES)	TEMPORARY SWITCHING
		8/5/2008 00:40	34		WARD12	178		
759358	8/5/2008 00:06	8/5/2008 06:59	413	D131	NULL	1	PHASE WIRE (ALL VOLTAGES)	TEMPORARY SWITCHING
759495	8/5/2008 00:07	8/6/2008 15:15	2,348	X11036	WARD45	10	FUSE	REPLACED FUSE
760549	8/5/2008 00:08	8/7/2008 12:00	3,591	Y84047	WARD11	37	TRANSFORMER-OVHD	REPLACED TRANSFORMER

CHICAGO

ComEd Appendix A

OUTAGE ID	START DATE TIME	DATE TIME RESTORED	OUTAGE DURATION (MIN)	CIRCUIT	WARD AFFECTED	NUMBER OF CUSTOMERS AFFECTED	EQUIPMENT INVOLVED	RESTORATION AND REMEDIATION
760800	8/5/2008 00:08	8/5/2008 16:55	1,006	Y71434	WARD25	223	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
759843	8/5/2008 00:08	8/6/2008 19:15	2,586	GRDX358	WARD8	45	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE
760790	8/5/2008 00:10	8/7/2008 14:16	3,726	Y2566	WARD11	26	FUSE	REPLACED FUSE
759958	8/5/2008 00:10	8/6/2008 20:35	2,665	Z6351	WARD23	30	FUSE	REPLACED FUSE
761701	8/5/2008 00:13	8/5/2008 18:30	1,097	X3976	WARD38	22	PHASE WIRE (ALL VOLTAGES)	TREE TRIMMED
761286	8/5/2008 00:15	8/8/2008 01:08	4,372	X1433	WARD33	1	CABLE-AERIAL	REPLACED OVERHEAD MATERIAL
758305	8/5/2008 00:15	8/5/2008 13:14	778	MFLD252	WARD12	209	FUSE	REPAIRED OVERHEAD MATERIAL
		8/5/2008 13:14	778		WARD20	56		
759993	8/5/2008 00:15	8/6/2008 20:19	2,643	031X046	WARD29	19	FUSE	REPLACED FUSE
760997	8/5/2008 00:16	8/7/2008 18:13	3,956	380X141	WARD31	1	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
759583	8/5/2008 00:16	8/5/2008 05:33	317	Z13755	WARD4	1	FUSE	REPLACED FUSE
		8/5/2008 10:10	594		WARD5	1		
		8/5/2008 12:35	738		WARD20	315		
		8/6/2008 11:18	2,101		WARD20	107		
760645	8/5/2008 00:17	8/5/2008 01:10	53	Y3038	WARD29	781	PHASE WIRE (ALL VOLTAGES)	TEMPORARY SWITCHING
758363	8/5/2008 00:17	8/5/2008 14:40	863	Z13778	WARD8	240	FUSE	REPLACED FUSE
759153	8/5/2008 00:17	8/5/2008 21:35	1,278	Y2556	WARD2	29	PHASE WIRE (ALL VOLTAGES)	TREE REMOVED
		8/5/2008 21:35	1,278		WARD28	155		
758169	8/5/2008 00:19	8/5/2008 10:25	606	Z6353	WARD23	72	FUSE	REPLACED FUSE
760624	8/5/2008 00:19	8/7/2008 13:47	3,688	Y3854	WARD32	19	TAP WIRE	REPAIRED OVERHEAD MATERIAL
760240	8/5/2008 00:19	8/7/2008 04:10	3,110	Z15061	WARD7	137	FUSE	REPLACED FUSE
760293	8/5/2008 00:20	8/7/2008 00:33	2,893	GRDX358	WARD8	126	FUSE	REPLACED FUSE
759294	8/5/2008 00:21	8/6/2008 12:30	2,169	381X047	WARD32	1	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
760716	8/5/2008 00:23	8/7/2008 14:15	3,712	Z10443	WARD13	28	TRANSFORMER-OVHD	REPLACED TRANSFORMER
760100	8/5/2008 00:23	8/6/2008 22:31	2,768	MFLD145	WARD16	114	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
760300	8/5/2008 00:23	8/7/2008 06:20	3,236	WNPK45	WARD7	101	TRANSFORMER-OVHD	REPLACED TRANSFORMER
758491	8/5/2008 00:24	8/5/2008 17:25	1,021	62ND46	WARD5	268	CABLE-AERIAL	REPLACED FUSE
		8/5/2008 17:25	1,021		WARD20	82		
758520	8/5/2008 00:24	8/5/2008 17:43	1,039	Z6352	WARD12	174	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE
		8/5/2008 17:43	1,039		WARD20	141		
759513	8/5/2008 00:24	8/6/2008 15:00	2,315	Z8949	WARD19	24	TRANSFORMER-OVHD	REPLACED TRANSFORMER
758762	8/5/2008 00:24	8/5/2008 20:47	1,222	Y84047	WARD11	36	TRANSFORMER-OVHD	CLOSED FUSE
760152	8/5/2008 00:24	8/6/2008 23:55	2,850	Z6332	WARD14	35	FUSE	REPLACED FUSE
760545	8/5/2008 00:26	8/6/2008 10:16	2,030	X3934	WARD38	1	CABLE-AERIAL	DISCONNECT OVERHEAD MATERIAL
759998	8/5/2008 00:27	8/6/2008 12:00	2,132	Z15087	WARD7	80	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
		8/6/2008 12:00	2,132		WARD10	32		
760140	8/5/2008 00:27	8/6/2008 23:55	2,847	750Y45	WARD26	38	TRANSFORMER-OVHD	REPLACED TRANSFORMER
759488	8/5/2008 00:27	8/5/2008 14:33	845	Z13731	WARD5	470	CABLE	TEMPORARY SWITCHING
		8/5/2008 14:33	845		WARD20	133		
		8/5/2008 17:42	1,034		WARD5	100		
		8/5/2008 17:42	1,034		WARD20	80		
758470	8/5/2008 00:28	8/5/2008 17:02	994	Z13746	WARD17	1	CABLE-AERIAL	REPAIRED OVERHEAD MATERIAL
759365	8/5/2008 00:30	8/6/2008 13:55	2,245	Z15073	WARD7	223	PHASE WIRE (ALL VOLTAGES)	REPLACED OVERHEAD MATERIAL
		8/6/2008 13:55	2,245		WARD8	15		
759979	8/5/2008 00:30	8/6/2008 20:44	2,653	Z11884	WARD8	31	CABLE-AERIAL	REPLACED OVERHEAD MATERIAL
759487	8/5/2008 00:31	8/5/2008 20:42	1,211	GRDX44	WARD6	155	CABLE	TEMPORARY SWITCHING
		8/5/2008 21:45	1,274		WARD8	354		
		8/5/2008 22:47	1,336		WARD6	279		
760092	8/5/2008 00:33	8/6/2008 20:20	2,627	GRDX254	WARD5	155	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE
759872	8/5/2008 00:33	8/6/2008 19:19	2,565	Z15092	WARD8	2	FUSE	REPLACED FUSE
		8/6/2008 19:19	2,565		WARD9	112		
761224	8/5/2008 00:34	8/6/2008 19:17	2,562	X4858	WARD36	21	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE
760570	8/5/2008 00:35	8/5/2008 09:04	509	Z13761	WARD3	14	PHASE WIRE (ALL VOLTAGES)	TEMPORARY SWITCHING
		8/5/2008 09:04	509		WARD16	2409		
		8/5/2008 09:04	509		WARD20	509		
759356	8/5/2008 00:35	8/6/2008 13:58	2,242	Z83432	WARD7	133	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE
760539	8/5/2008 00:44	8/7/2008 12:15	3,570	798Y32	WARD2	29	PHASE WIRE (ALL VOLTAGES)	REPLACED OVERHEAD MATERIAL
759787	8/5/2008 00:45	8/6/2008 18:20	2,494	GRDX256	WARD8	67	CABLE-AERIAL	REPAIRED EQUIPMENT
760025	8/5/2008 00:46	8/6/2008 21:26	2,680	Z15063	WARD10	210	FUSE	REPLACED FUSE
760585	8/5/2008 00:46	8/7/2008 11:43	3,536	Y2547	WARD24	7	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
759969	8/5/2008 00:47	8/6/2008 20:37	2,630	BURN543	WARD8	18	CABLE-AERIAL	REPAIRED OVERHEAD MATERIAL
760503	8/5/2008 00:48	8/7/2008 11:10	3,501	Y2571	WARD3	76	CABLE-AERIAL	REPLACED OVERHEAD MATERIAL
		8/7/2008 11:10	3,501		WARD20	73		
758091	8/5/2008 00:50	8/5/2008 08:01	431	62ND46	WARD20	76	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
760395	8/5/2008 00:50	8/6/2008 01:10	1,460	X1432	WARD32	1	FUSE	REPLACED FUSE
761014	8/5/2008 00:54	8/7/2008 18:51	3,956	SCHG249	WARD7	1	CABLE-AERIAL	REPLACED OVERHEAD MATERIAL
758286	8/5/2008 00:58	8/5/2008 11:30	632	Z4331	WARD34	87	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
760162	8/5/2008 01:00	8/5/2008 06:37	336	Y1945	WARD11	435	CABLE	TEMPORARY SWITCHING
		8/5/2008 06:43	343		WARD11	490		
		8/6/2008 15:47	2,327		WARD3	2		
		8/6/2008 15:47	2,327		WARD11	449		
		8/6/2008 15:53	2,332		WARD11	374		
		8/6/2008 16:23	2,363		WARD11	453		
		8/7/2008 00:45	2,864		WARD3	1		
		8/7/2008 00:45	2,864		WARD11	201		
761177	8/5/2008 01:01	8/7/2008 20:30	4,049	X3932	WARD38	1	CROSS-ARM	REPLACED OVERHEAD MATERIAL
758368	8/5/2008 01:09	8/5/2008 14:15	785	Z15074	WARD10	1	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
758021	8/5/2008 01:18	8/5/2008 05:39	261	X5456	WARD32	1	PHASE WIRE (ALL VOLTAGES)	REPLACED OVERHEAD MATERIAL

CHICAGO

ComEd Appendix A

OUTAGE ID	START DATE TIME	DATE TIME RESTORED	OUTAGE DURATION (MIN)	CIRCUIT	WARD AFFECTED	NUMBER OF CUSTOMERS AFFECTED	EQUIPMENT INVOLVED	RESTORATION AND REMEDIATION
761317	8/5/2008 01:21	8/8/2008 02:08	4,367	300X057	WARD47	1	CABLE-AERIAL	TREE REMOVED
759603	8/5/2008 01:23	8/6/2008 16:36	2,352	Y2559	WARD24	178	TAP WIRE	REPAIRED OVERHEAD MATERIAL
759250	8/5/2008 01:26	8/6/2008 11:55	2,069	Y13052	WARD22	69	CABLE-AERIAL	REPAIRED OVERHEAD MATERIAL
758209	8/5/2008 01:30	8/5/2008 10:55	565	Z1407	WARD17	720	PHASE WIRE (ALL VOLTAGES)	CLOSED FUSE
760607	8/5/2008 01:35	8/7/2008 13:15	3,580	Z15091	WARD8	1	CABLE-AERIAL	REPLACED OVERHEAD MATERIAL
760083	8/5/2008 01:37	8/6/2008 22:21	2,684	D5012	WARD23	43	CUTOUT	REPLACED CUTOUT
758143	8/5/2008 01:48	8/5/2008 09:30	461	X3939X	WARD38	1	CABLE-AERIAL	REPAIRED OVERHEAD MATERIAL
758542	8/5/2008 01:57	8/5/2008 13:00	663	G651	WARD9	51	TAP WIRE	REPAIRED OVERHEAD MATERIAL
760952	8/5/2008 02:16	8/7/2008 17:41	3,805	X8450	WARD48	28	TRANSFORMER-OVHD	REPLACED TRANSFORMER
758114	8/5/2008 02:44	8/5/2008 08:25	340	Z5538	WARD10	1327	CABLE	TEMPORARY SWITCHING
		8/5/2008 08:40	356		WARD10	344		
760168	8/5/2008 02:46	8/5/2008 17:11	864	G612	WARD19	257	PHASE WIRE (ALL VOLTAGES)	TEMPORARY SWITCHING
761276	8/5/2008 02:59	8/6/2008 19:20	2,421	X7136	WARD41	14	PHASE WIRE (ALL VOLTAGES)	REPLACED OVERHEAD MATERIAL
761810	8/5/2008 03:02	8/8/2008 19:23	5,301	311X141	WARD45	1	CABLE-AERIAL	REPAIRED OVERHEAD MATERIAL
759994	8/5/2008 03:23	8/6/2008 20:55	2,492	Z10443	WARD13	54	FUSE	REPLACED FUSE
761123	8/5/2008 04:27	8/7/2008 20:36	3,848	THRP49	WARD17	1	CABLE-AERIAL	REPAIRED OVERHEAD MATERIAL
758029	8/5/2008 04:43	8/5/2008 06:13	90	X3135	WARD30	911	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
759466	8/5/2008 04:47	8/6/2008 14:23	2,015	X3964	WARD38	78	FUSE	REPLACED FUSE
760091	8/5/2008 04:59	8/6/2008 20:38	2,378	Z15031	WARD8	255	FUSE	CLOSED FUSE
760742	8/5/2008 05:08	8/7/2008 15:05	3,477	Z5541	WARD10	1	FUSE	REPAIRED OVERHEAD MATERIAL
758610	8/5/2008 05:31	8/5/2008 19:31	839	Y8274	WARD27	2	FUSE	REPLACED FUSE
		8/5/2008 19:31	839		WARD32	26		
759898	8/5/2008 05:35	8/6/2008 19:54	2,298	Z3348	WARD18	40	FUSE	REPLACED FUSE
758384	8/5/2008 05:40	8/5/2008 14:45	545	X3235	WARD30	1	FUSE	TREE REMOVED
760597	8/5/2008 05:42	8/7/2008 13:22	3,339	56TH142	WARD3	15	CABLE-AERIAL	REPAIRED OTHER
761268	8/5/2008 05:42	8/6/2008 21:02	2,359	X7131	WARD41	17	PHASE WIRE (ALL VOLTAGES)	REPLACED CUTOUT
758309	8/5/2008 05:42	8/5/2008 13:14	451	MFLD252	WARD12	80	FUSE	REPLACED FUSE
760694	8/5/2008 05:54	8/7/2008 14:38	3,404	679X151	WARD32	1	AUTOMATIC SPLICE	REPAIRED OVERHEAD MATERIAL
760476	8/5/2008 05:57	8/7/2008 11:33	3,216	X5365	WARD35	48	TRANSFORMER-OVHD	REPLACED TRANSFORMER
761064	8/5/2008 05:57	8/7/2008 19:35	3,698	X3251	WARD37	19	FUSE	REPLACED FUSE
760311	8/5/2008 05:57	8/7/2008 06:40	2,922	Y13062	WARD24	8	FUSE	REPLACED FUSE
761058	8/5/2008 06:01	8/7/2008 19:31	3,689	WILD041	WARD9	1	CABLE-AERIAL	REPLACED OVERHEAD MATERIAL
759128	8/5/2008 06:05	8/6/2008 10:25	1,700	315X142	WARD41	13	FUSE	REPLACED OVERHEAD MATERIAL
759520	8/5/2008 06:08	8/6/2008 15:20	1,993	X5438	WARD43	302	FUSE	REPLACED FUSE
760403	8/5/2008 06:10	8/5/2008 15:26	556	X4852	WARD36	64	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
760450	8/5/2008 06:10	8/7/2008 11:10	3,179	Y3871	WARD27	1	TIE WIRE	REPAIRED OVERHEAD MATERIAL
760253	8/5/2008 06:11	8/7/2008 04:30	2,779	Z11863	WARD21	20	TRANSFORMER-OVHD	CHANGED SIZE
760908	8/5/2008 06:11	8/7/2008 17:10	3,539	Y3083	WARD29	22	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
759174	8/5/2008 06:11	8/6/2008 10:30	1,698	X4040	WARD44	99	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE
760660	8/5/2008 06:15	8/7/2008 10:29	3,133	GRDX44	WARD6	171	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
		8/7/2008 10:43	3,147		WARD6	263		
		8/7/2008 10:43	3,147		WARD8	331		
759482	8/5/2008 06:20	8/6/2008 13:45	1,885	Y71455	WARD2	52	TIE WIRE	REPAIRED OVERHEAD MATERIAL
761389	8/5/2008 06:35	8/8/2008 07:03	4,348	Z13778	WARD5	1	POLE	REPLACED OVERHEAD MATERIAL
759192	8/5/2008 06:46	8/6/2008 10:35	1,669	PERS043	WARD11	39	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
760466	8/5/2008 06:48	8/7/2008 10:45	3,117	X1432	WARD32	1	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
760949	8/5/2008 06:48	8/7/2008 17:48	3,539	Z15071	WARD7	1	NEUTRAL WIRE	REPAIRED OVERHEAD MATERIAL
761659	8/5/2008 06:57	8/8/2008 15:20	4,823	Y3859	WARD1	3	CABLE	TEMPORARY GENERATOR
759545	8/5/2008 07:01	8/6/2008 15:30	1,948	THRP45	WARD17	79	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
758766	8/5/2008 07:14	8/5/2008 22:55	941	Y84060	WARD11	466	TRANSFORMER-OVHD	REPLACED TRANSFORMER
760791	8/5/2008 07:18	8/5/2008 22:50	932	X3251	WARD29	188	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
		8/5/2008 22:50	932		WARD37	162		
760714	8/5/2008 07:21	8/7/2008 14:50	3,329	310Y142	WARD28	1	METER ENTRANCE	REPAIRED OVERHEAD MATERIAL
760746	8/5/2008 07:22	8/7/2008 15:15	3,353	Y3853	WARD27	3	FUSE	REPLACED FUSE
760434	8/5/2008 07:26	8/7/2008 10:10	3,044	Z15071	WARD10	1	FUSE	REPLACED FUSE
761321	8/5/2008 07:26	8/7/2008 17:25	3,478	X3253	WARD26	1	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
760458	8/5/2008 07:26	8/7/2008 10:00	3,033	Y3878	WARD1	8	TRANSFORMER-OVHD	REPLACED TRANSFORMER
760105	8/5/2008 07:36	8/6/2008 22:40	2,344	Z15087	WARD7	125	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE
760480	8/5/2008 07:37	8/7/2008 11:20	3,102	GRDX256	WARD8	23	FUSE	REPLACED FUSE
761163	8/5/2008 07:38	8/7/2008 21:13	3,694	Z15091	WARD7	1	CABLE-AERIAL	REPAIRED OVERHEAD MATERIAL
760711	8/5/2008 07:44	8/7/2008 14:48	3,304	Z5541	WARD10	2	FUSE	REPLACED FUSE
761308	8/5/2008 07:48	8/8/2008 01:30	3,942	X3251	WARD37	15	TRANSFORMER-OVHD	REPLACED TRANSFORMER
759917	8/5/2008 07:51	8/6/2008 20:07	2,176	Z83432	WARD5	31	CABLE-AERIAL	REPLACED OVERHEAD MATERIAL
759423	8/5/2008 07:51	8/6/2008 13:32	1,780	BURN543	WARD8	29	TRANSFORMER-OVHD	REPLACED OVERHEAD MATERIAL
760926	8/5/2008 07:54	8/7/2008 16:20	3,386	G651	WARD9	11	TRANSFORMER-OVHD	REPLACED TRANSFORMER
760803	8/5/2008 07:58	8/7/2008 16:07	3,368	Y8274	WARD32	4	TRANSFORMER-OVHD	REPLACED TRANSFORMER
759204	8/5/2008 08:01	8/6/2008 10:45	1,604	X3962	WARD38	164	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
760425	8/5/2008 08:10	8/7/2008 10:41	3,030	X3251	WARD37	5	TRANSFORMER-OVHD	REPLACED TRANSFORMER
759692	8/5/2008 08:11	8/6/2008 17:08	1,977	X3949	WARD31	12	CUTOUT	REPLACED CUTOUT
761158	8/5/2008 08:11	8/7/2008 21:09	3,657	Z13750	WARD6	1	CABLE-AERIAL	TREE TRIMMED
761178	8/5/2008 08:14	8/7/2008 21:26	3,672	Z30741	WARD23	1	CABLE-AERIAL	REPAIRED OVERHEAD MATERIAL
758389	8/5/2008 08:16	8/5/2008 14:55	398	Y3871	WARD27	1	CABLE-AERIAL	INSTALL OVERHEAD MATERIAL
760718	8/5/2008 08:17	8/7/2008 14:54	3,276	793Y42	WARD37	1	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
761366	8/5/2008 08:20	8/8/2008 04:48	4,107	X5347	WARD33	1	CABLE-AERIAL	REPLACED OVERHEAD MATERIAL
761230	8/5/2008 08:23	8/7/2008 22:42	3,738	Y84056	WARD11	1	TRANSFORMER-OVHD	REPLACED TRANSFORMER
760741	8/5/2008 08:24	8/7/2008 15:09	3,285	Y3832	WARD27	1	PHASE WIRE (ALL VOLTAGES)	REPLACED OVERHEAD MATERIAL
761149	8/5/2008 08:25	8/7/2008 20:14	3,589	X3945	WARD45	22	GROUND WIRE	REPAIRED OVERHEAD MATERIAL
758684	8/5/2008 08:31	8/5/2008 21:20	769	Y3878	WARD1	60	TRANSFORMER-OVHD	REPLACED TRANSFORMER

CHICAGO

OUTAGE ID	START DATE TIME	DATE TIME RESTORED	OUTAGE DURATION (MIN)	CIRCUIT	WARD AFFECTED	NUMBER OF CUSTOMERS AFFECTED	EQUIPMENT INVOLVED	RESTORATION AND REMEDIATION
760754	8/5/2008 08:31	8/7/2008 15:15	3,283	Z10438	WARD13	1	FUSE	REPLACED FUSE
761002	8/5/2008 08:37	8/7/2008 18:43	3,486	Z15090	WARD8	1	CABLE-AERIAL	TREE REMOVED
760798	8/5/2008 08:41	8/7/2008 16:06	3,325	380X342	WARD30	1	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
760889	8/5/2008 08:47	8/7/2008 17:01	3,374	Y3076	WARD28	1	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
761079	8/5/2008 08:55	8/7/2008 10:04	2,948	Y3880	WARD28	42	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
760823	8/5/2008 08:57	8/7/2008 16:25	3,328	X5357	WARD39	1	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
759101	8/5/2008 09:00	8/6/2008 09:45	1,484	X3251	WARD29	4	TRANSFORMER-OVHD	REPLACED FUSE
759924	8/5/2008 09:01	8/6/2008 19:25	2,063	310X141	WARD33	82	FUSE	CLOSED FUSE
760263	8/5/2008 09:05	8/7/2008 04:42	2,617	Z4131	WARD34	8	TRANSFORMER-OVHD	REPLACED CUTOUT
761479	8/5/2008 09:08	8/8/2008 11:10	4,441	28TH347	WARD22	1	CABLE-AERIAL	REPAIRED OVERHEAD MATERIAL
760679	8/5/2008 09:10	8/7/2008 14:29	3,198	X3978	WARD45	22	CABLE-AERIAL	REPLACED OVERHEAD MATERIAL
761059	8/5/2008 09:11	8/7/2008 19:32	3,501	365Y450	WARD28	35	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
759501	8/5/2008 09:13	8/6/2008 15:00	1,786	Z4142	WARD9	1	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
760132	8/5/2008 09:15	8/6/2008 23:49	2,313	X1447	WARD47	1	FUSE	CLOSED FUSE
759768	8/5/2008 09:16	8/6/2008 17:59	1,962	EWNG043	WARD10	29	CABLE-AERIAL	REPAIRED OVERHEAD MATERIAL
761086	8/5/2008 09:20	8/7/2008 20:02	3,522	365Y452	WARD2	78	TRANSFORMER-OVHD	REPLACED TRANSFORMER
761112	8/5/2008 09:21	8/7/2008 20:05	3,523	X3946	WARD30	1	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
761165	8/5/2008 09:26	8/7/2008 20:30	3,544	031X042	WARD36	1	POLE	REPLACED OTHER
758672	8/5/2008 09:26	8/5/2008 10:31	64	Y3076	WARD29	39	PHASE WIRE (ALL VOLTAGES)	REPLACED OVERHEAD MATERIAL
761101	8/5/2008 09:28	8/7/2008 20:17	3,529	Z11863	WARD21	1	CABLE-AERIAL	REPAIRED OVERHEAD MATERIAL
760702	8/5/2008 09:36	8/7/2008 14:40	3,184	Z6352	WARD16	1	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
759864	8/5/2008 09:37	8/6/2008 19:25	2,027	Z9214	WARD5	158	CABLE-AERIAL	REPLACED OVERHEAD MATERIAL
761132	8/5/2008 09:39	8/7/2008 20:47	3,548	GRDX254	WARD5	1	CABLE-AERIAL	TREE REMOVED
761343	8/5/2008 09:39	8/8/2008 03:15	3,936	307X048	WARD50	1	FUSE	REPLACED FUSE
759984	8/5/2008 09:42	8/6/2008 20:47	2,105	Z6339	WARD23	36	FUSE	REPLACED FUSE
761164	8/5/2008 09:46	8/7/2008 21:13	3,566	X5373	WARD33	1	FUSE	REPLACED FUSE
759256	8/5/2008 09:51	8/6/2008 12:11	1,580	Z6344	WARD20	186	CABLE-AERIAL	REPAIRED OVERHEAD MATERIAL
761052	8/5/2008 09:51	8/7/2008 19:28	3,457	Z4337	WARD9	1	CABLE-AERIAL	REPLACED OVERHEAD MATERIAL
761440	8/5/2008 09:55	8/8/2008 10:05	4,329	Z13762	WARD8	1	CABLE-AERIAL	REPAIRED OVERHEAD MATERIAL
760389	8/5/2008 09:56	8/6/2008 18:28	1,951	111TH443	WARD19	2	TRANSFORMER-OVHD	REPLACED FUSE
758627	8/5/2008 09:59	8/5/2008 18:35	515	Z8942	WARD21	205	CABLE	DISCONNECT UNDERGROUND MATERIAL
761121	8/5/2008 10:05	8/6/2008 20:10	2,044	X3934	WARD38	31	TIE WIRE	REPAIRED OVERHEAD MATERIAL
760684	8/5/2008 10:09	8/7/2008 14:35	3,146	Z6352	WARD16	1	CABLE-AERIAL	REPLACED OVERHEAD MATERIAL
760980	8/5/2008 10:14	8/7/2008 18:26	3,371	MFLD251	WARD16	1	CABLE-AERIAL	REPAIRED OVERHEAD MATERIAL
760376	8/5/2008 10:19	8/5/2008 11:58	98	Y8246	WARD42	96	PHASE WIRE (ALL VOLTAGES)	CLOSED SUBSTATION BREAKER
760315	8/5/2008 10:26	8/6/2008 20:00	2,014	Y2571	WARD3	42	FUSE	REPLACED FUSE
758764	8/5/2008 10:31	8/5/2008 12:45	133	X4059	WARD44	1110	PHASE WIRE (ALL VOLTAGES)	TEMPORARY SWITCHING
759315	8/5/2008 10:38	8/6/2008 13:18	1,599	X5456	WARD32	1	FUSE	INSTALL FUSE
760655	8/5/2008 10:44	8/7/2008 13:55	3,070	PRAI32	WARD3	4	PHASE WIRE (ALL VOLTAGES)	REPLACED OVERHEAD MATERIAL
760757	8/5/2008 10:54	8/7/2008 15:24	3,150	Z11863	WARD21	1	CABLE-AERIAL	REPAIRED OVERHEAD MATERIAL
761169	8/5/2008 11:00	8/7/2008 21:17	3,497	EXCH045	WARD7	1	CABLE-AERIAL	REPAIRED OVERHEAD MATERIAL
761240	8/5/2008 11:15	8/7/2008 23:02	3,586	28TH347	WARD22	17	CABLE-AERIAL	TREE REMOVED
761325	8/5/2008 11:25	8/8/2008 02:27	3,782	Y84060	WARD11	504	FUSE	REPLACED FUSE
761251	8/5/2008 12:15	8/6/2008 21:29	1,993	X3937	WARD45	18	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
760977	8/5/2008 12:21	8/7/2008 18:20	3,238	310Y142	WARD28	22	PHASE WIRE (ALL VOLTAGES)	REPLACED OVERHEAD MATERIAL
758727	8/5/2008 12:38	8/5/2008 22:11	572	Z1408	WARD15	228	CABLE-AERIAL	TREE REMOVED
760477	8/5/2008 12:39	8/7/2008 11:34	2,815	793Y45	WARD28	1	TAP WIRE	REPAIRED OVERHEAD MATERIAL
759490	8/5/2008 12:50	8/6/2008 15:13	1,583	Y13065	WARD24	62	FUSE	REPAIRED OVERHEAD MATERIAL
760440	8/5/2008 13:01	8/6/2008 08:30	1,170	Y13043	WARD12	335	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
		8/6/2008 08:30	1,170		WARD25	102		
		8/6/2008 08:30	1,170		WARD28	611		
760375	8/5/2008 13:24	8/5/2008 19:55	391	Y8238	WARD32	1	FUSE	REPLACED FUSE
759875	8/5/2008 13:43	8/6/2008 19:11	1,767	Y3873	WARD26	113	PHASE WIRE (ALL VOLTAGES)	REPLACED OVERHEAD MATERIAL
		8/6/2008 19:11	1,767		WARD35	95		
759333	8/5/2008 13:48	8/6/2008 13:00	1,391	Z4134	WARD34	1	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
760755	8/5/2008 13:50	8/7/2008 15:24	2,974	Y13080	WARD28	1	METER ENTRANCE	REPAIRED OVERHEAD MATERIAL
758912	8/5/2008 13:56	8/6/2008 02:07	731	W2020	NULL	1	PHASE WIRE (ALL VOLTAGES)	TEMPORARY SWITCHING
760528	8/5/2008 14:01	8/7/2008 12:18	2,777	Z6342	WARD16	1	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
758669	8/5/2008 14:05	8/5/2008 16:31	145	Y71434	WARD25	223	FUSE	REPLACED FUSE
760858	8/5/2008 14:08	8/6/2008 04:43	875	C298	WARD41	1	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE
761116	8/5/2008 14:08	8/7/2008 20:30	3,262	GRDX254	WARD5	1	CABLE-AERIAL	REPLACED OTHER
758577	8/5/2008 14:12	8/5/2008 18:48	276	380X440	WARD31	1	PHASE WIRE (ALL VOLTAGES)	REPLACED OVERHEAD MATERIAL
760043	8/5/2008 14:26	8/6/2008 18:23	1,677	X3249	WARD37	114	POLE	REPAIRED OVERHEAD MATERIAL
759604	8/5/2008 14:29	8/6/2008 16:02	1,532	X7134	NULL	16	CUTOUT	REPLACED FUSE OR CUTOUT
		8/6/2008 16:02	1,532		WARD41	39		
761264	8/5/2008 15:07	8/7/2008 19:29	3,141	X4031	WARD44	97	ALLEY-ARM	REPLACED OVERHEAD MATERIAL
		8/8/2008 00:15	3,427		WARD44	156		
759648	8/5/2008 15:10	8/6/2008 17:01	1,550	X3933	WARD45	31	PHASE WIRE (ALL VOLTAGES)	REPLACED OVERHEAD MATERIAL
761062	8/5/2008 15:24	8/7/2008 19:36	3,132	Y2531	WARD12	1	CABLE-AERIAL	REPAIRED OVERHEAD MATERIAL
758416	8/5/2008 15:31	8/5/2008 15:44	13	F126	WARD5	1	SUBSTATION BREAKER	TREE REMOVED
760109	8/5/2008 15:38	8/6/2008 19:40	1,681	Y13047	WARD22	69	ARRESTER-PORCELAIN	REPAIRED OVERHEAD MATERIAL
760082	8/5/2008 15:41	8/6/2008 18:00	1,579	Z1408	WARD15	29	CUTOUT	REPLACED CUTOUT
761781	8/5/2008 15:49	8/8/2008 18:16	4,467	Z8942	WARD19	1	CABLE-AERIAL	REPLACED OVERHEAD MATERIAL
761144	8/5/2008 15:51	8/7/2008 21:02	3,191	Z8940	WARD34	1	CABLE-AERIAL	REPLACED OVERHEAD MATERIAL
761636	8/5/2008 16:01	8/8/2008 14:53	4,251	HYPK348	WARD5	1	TRANSFORMER-OVHD	REPLACED TRANSFORMER

CHICAGO

ComEd Appendix A

OUTAGE ID	START DATE TIME	DATE TIME RESTORED	OUTAGE DURATION (MIN)	CIRCUIT	WARD AFFECTED	NUMBER OF CUSTOMERS AFFECTED	EQUIPMENT INVOLVED	RESTORATION AND REMEDIATION
761138	8/5/2008 16:13	8/7/2008 17:00	2,927	MFLD252	NULL	1	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE
		8/7/2008 17:00	2,927		WARD3	88		
		8/7/2008 17:00	2,927		WARD12	183		
		8/7/2008 17:00	2,927		WARD20	7		
759770	8/5/2008 16:18	8/6/2008 17:35	1,517	X7148	WARD45	44	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
761520	8/5/2008 16:32	8/8/2008 12:20	4,068	28TH347	WARD22	1	CABLE-AERIAL	REPLACED OVERHEAD MATERIAL
760153	8/5/2008 16:33	8/7/2008 00:33	1,919	Z11863	WARD21	1	CABLE-AERIAL	REPAIRED OVERHEAD MATERIAL
759450	8/5/2008 16:34	8/6/2008 14:52	1,338	X3933	WARD45	18	FUSE	REPLACED FUSE
760003	8/5/2008 16:50	8/6/2008 20:56	1,686	X3932	WARD38	15	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
761356	8/5/2008 16:55	8/8/2008 03:15	3,499	X5383	WARD35	26	TIE WIRE	REPAIRED OVERHEAD MATERIAL
760463	8/5/2008 16:57	8/7/2008 10:40	2,503	Y2557	WARD28	38	FUSE	REPLACED FUSE
760157	8/5/2008 17:02	8/7/2008 00:39	1,896	Z15079	WARD7	1	PHASE WIRE (ALL VOLTAGES)	OTHER NO FURTHER DETAIL
760367	8/5/2008 17:40	8/6/2008 22:06	1,706	X3949	WARD38	3	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
760993	8/5/2008 17:50	8/7/2008 18:38	2,927	Z4141	WARD9	1	CABLE-AERIAL	REPLACED OVERHEAD MATERIAL
758826	8/5/2008 18:17	8/5/2008 20:10	113	Z6352	WARD20	99	PHASE WIRE (ALL VOLTAGES)	CLOSED FUSE
758804	8/5/2008 18:19	8/5/2008 20:50	151	Z6352	WARD12	249	PHASE WIRE (ALL VOLTAGES)	CLOSED FUSE
		8/5/2008 20:50	151		WARD20	86		
761940	8/5/2008 18:50	8/8/2008 12:39	3,949	Z4336	WARD9	1	PHASE WIRE (ALL VOLTAGES)	DISCONNECT OVERHEAD MATERIAL
760029	8/5/2008 19:04	8/6/2008 21:22	1,577	032X041	WARD29	15	TRANSFORMER-OVHD	REPLACED TRANSFORMER
761533	8/5/2008 19:07	8/8/2008 11:50	3,883	Z13790	WARD6	1	CABLE-AERIAL	REPAIRED OVERHEAD MATERIAL
760020	8/5/2008 19:22	8/6/2008 21:24	1,561	62ND46	WARD5	100	CABLE-AERIAL	REPLACED OVERHEAD MATERIAL
760877	8/5/2008 19:32	8/7/2008 16:58	2,725	X3937	WARD45	1	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
759909	8/5/2008 19:35	8/6/2008 17:07	1,291	X5368	WARD35	118	CUTOUT	REPAIRED EQUIPMENT
758809	8/5/2008 19:45	8/5/2008 20:50	65	Z6352	WARD12	53	FUSE	CLOSED FUSE
758759	8/5/2008 20:30	8/5/2008 22:33	123	D5014	WARD23	1104	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
760457	8/5/2008 20:41	8/7/2008 11:00	2,299	Z8942	WARD21	39	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
760920	8/5/2008 20:49	8/6/2008 18:00	1,270	X1438	WARD33	173	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
761140	8/5/2008 21:00	8/7/2008 18:45	2,744	X3937	WARD45	1	PHASE WIRE (ALL VOLTAGES)	REPAIRED EQUIPMENT
760273	8/5/2008 21:05	8/7/2008 05:28	1,943	Z4342	WARD34	66	FUSE	REPLACED FUSE
760777	8/5/2008 21:26	8/7/2008 11:15	2,269	Y13062	WARD24	31	CABLE-AERIAL	REPAIRED OVERHEAD MATERIAL
760128	8/5/2008 22:01	8/6/2008 22:38	1,477	X5359	WARD39	391	FUSE	REPLACED FUSE
761271	8/5/2008 22:34	8/6/2008 19:59	1,285	X3147	WARD29	14	TIE WIRE	REPAIRED OVERHEAD MATERIAL
760432	8/5/2008 22:42	8/7/2008 10:47	2,164	310Y149	WARD28	151	FUSE	REPLACED FUSE
760863	8/5/2008 23:05	8/7/2008 16:50	2,505	X3976	WARD38	1	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
760618	8/5/2008 23:14	8/5/2008 23:40	26	27TH347X	WARD2	3	SUBSTATION BREAKER	CLOSED SUBSTATION BREAKER
		8/5/2008 23:40	26		WARD3	43		
761179	8/5/2008 23:28	8/7/2008 21:26	2,758	X1468	WARD47	68	TRANSFORMER-OVHD	REPAIRED OVERHEAD MATERIAL
758907	8/6/2008 01:14	8/6/2008 02:15	60	28TH245	WARD22	341	SUBSTATION BREAKER	CLOSED SUBSTATION BREAKER
759244	8/6/2008 04:32	8/6/2008 12:30	478	Y13065	WARD24	383	FUSE	REPLACED FUSE
		8/6/2008 12:30	478		WARD28	312		
759973	8/6/2008 04:39	8/6/2008 20:30	951	Y1977	WARD25	57	FUSE	CLOSED FUSE
759577	8/6/2008 04:52	8/6/2008 05:52	60	X3939X	WARD39	64	PHASE WIRE (ALL VOLTAGES)	REPLACED OVERHEAD MATERIAL
759110	8/6/2008 04:56	8/6/2008 09:20	264	X3740	WARD36	279	FUSE	REPLACED FUSE
759622	8/6/2008 05:27	8/6/2008 16:49	682	X3256	WARD30	82	FUSE	REPAIRED OVERHEAD MATERIAL
759190	8/6/2008 05:27	8/6/2008 11:22	354	X3258	WARD26	664	TAP WIRE	REPAIRED OVERHEAD MATERIAL
759617	8/6/2008 05:56	8/6/2008 16:37	641	X3745	WARD36	120	FUSE	REPLACED OVERHEAD MATERIAL
759475	8/6/2008 06:11	8/6/2008 13:20	429	380X349	WARD31	81	FUSE	REPLACED FUSE
759961	8/6/2008 06:35	8/6/2008 20:30	834	Z13778	WARD5	21	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE
759987	8/6/2008 06:57	8/6/2008 20:48	831	Z13778	WARD5	49	CABLE-AERIAL	REPLACED OVERHEAD MATERIAL
761236	8/6/2008 06:57	8/7/2008 22:49	2,392	G651	WARD9	1	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
760543	8/6/2008 07:12	8/7/2008 12:31	1,758	674X42	WARD45	43	TAP WIRE	REPAIRED OVERHEAD MATERIAL
759985	8/6/2008 07:25	8/6/2008 20:00	755	Z13778	WARD5	22	TRANSFORMER-OVHD	REPAIRED OTHER
760421	8/6/2008 07:27	8/7/2008 10:39	1,632	X7134	WARD45	1	CABLE-AERIAL	REPLACED OVERHEAD MATERIAL
760830	8/6/2008 07:47	8/7/2008 16:05	1,938	HYPK31	WARD4	29	CABLE-AERIAL	REPAIRED OVERHEAD MATERIAL
761681	8/6/2008 07:48	8/8/2008 15:52	3,364	WNPK47	WARD7	75	PHASE WIRE (ALL VOLTAGES)	REPLACED OVERHEAD MATERIAL
761473	8/6/2008 07:53	8/8/2008 11:11	3,078	Z15087	WARD7	1	CABLE-AERIAL	REPAIRED OVERHEAD MATERIAL
759732	8/6/2008 08:02	8/6/2008 16:52	530	X7147	WARD41	1	ATO	CLOSED SWITCH/DISCONNECT/LT
760827	8/6/2008 08:09	8/7/2008 16:28	1,938	603X52	WARD39	1	NEUTRAL WIRE	REPAIRED OVERHEAD MATERIAL
759208	8/6/2008 08:15	8/6/2008 11:33	198	X3947	WARD38	422	PHASE WIRE (ALL VOLTAGES)	CLOSED RECLOSER-LINE
760287	8/6/2008 08:24	8/6/2008 08:25	1	Z15087	WARD7	199	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
760786	8/6/2008 08:24	8/7/2008 12:45	1,701	Y3855	WARD37	1	FUSE	REPLACED FUSE
761558	8/6/2008 08:30	8/6/2008 12:30	239	Y13065	WARD24	38	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
760732	8/6/2008 08:33	8/7/2008 15:07	1,834	X3946	WARD30	24	FUSE	REPLACED FUSE
759500	8/6/2008 08:41	8/6/2008 09:30	49	Z6343	WARD14	1	CABLE	TEMPORARY SWITCHING
		8/6/2008 10:00	79		WARD23	236		
		8/6/2008 10:58	137		WARD23	3		
		8/6/2008 11:50	189		WARD23	4		
760928	8/6/2008 08:43	8/7/2008 17:05	1,942	X3939X	WARD39	46	CUTOUT	REPLACED CUTOUT
760866	8/6/2008 08:47	8/7/2008 16:52	1,925	X3976	WARD38	1	PHASE WIRE (ALL VOLTAGES)	REPLACED OVERHEAD MATERIAL
759369	8/6/2008 08:48	8/6/2008 14:10	322	D131	NULL	1	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE
760453	8/6/2008 08:54	8/7/2008 07:07	1,333	X4035	WARD32	62	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE
759267	8/6/2008 09:04	8/6/2008 12:05	180	SCHG249	WARD10	1	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
760276	8/6/2008 09:12	8/7/2008 06:30	1,277	Z13778	WARD5	26	PHASE WIRE (ALL VOLTAGES)	REPAIRED OTHER
761485	8/6/2008 09:27	8/8/2008 11:10	2,983	X5359	WARD39	35	TRANSFORMER-OVHD	REPLACED TRANSFORMER
760759	8/6/2008 09:36	8/7/2008 15:10	1,774	X3939X	WARD39	1	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
760499	8/6/2008 10:02	8/7/2008 11:48	1,546	793Y42	WARD37	1	TAP WIRE	REPLACED OVERHEAD MATERIAL
760961	8/6/2008 10:03	8/7/2008 17:45	1,902	307X048	WARD50	82	FUSE	CLOSED FUSE
761315	8/6/2008 10:06	8/8/2008 02:04	2,398	Y2544	WARD12	1	TRANSFORMER-PADMOUNT	REPAIRED TRANSFORMER

CHICAGO

ComEd Appendix A

OUTAGE ID	START DATE TIME	DATE TIME RESTORED	OUTAGE DURATION (MIN)	CIRCUIT	WARD AFFECTED	NUMBER OF CUSTOMERS AFFECTED	EQUIPMENT INVOLVED	RESTORATION AND REMEDIATION
760774	8/6/2008 10:11	8/7/2008 15:10	1,739	X3252	WARD30	2	TRANSFORMER-OVHD	REPLACED TRANSFORMER
760832	8/6/2008 10:15	8/7/2008 16:30	1,814	X5357	WARD39	1	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
761406	8/6/2008 10:23	8/8/2008 08:18	2,755	Z13778	WARD5	1	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
759817	8/6/2008 10:24	8/6/2008 18:44	499	G612	WARD19	14	FUSE	REPLACED FUSE
760064	8/6/2008 10:35	8/6/2008 20:40	605	031X045	WARD36	147	PHASE WIRE (ALL VOLTAGES)	CLOSED FUSE
761126	8/6/2008 10:54	8/7/2008 20:38	2,024	Z15093	WARD10	1	CABLE-AERIAL	REPLACED OVERHEAD MATERIAL
761344	8/6/2008 11:17	8/7/2008 15:10	1,673	G651	WARD9	58	FUSE	CLOSED FUSE
762469	8/6/2008 11:18	8/6/2008 12:05	48	Z15091	WARD5	616	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
		8/6/2008 16:10	292		WARD8	341		
759978	8/6/2008 11:22	8/6/2008 20:17	535	X4033	WARD43	149	FUSE	CLOSED FUSE
760728	8/6/2008 11:24	8/7/2008 15:04	1,659	X7138	WARD41	33	TRANSFORMER-OVHD	REPLACED TRANSFORMER
761369	8/6/2008 11:34	8/8/2008 04:57	2,482	X5383	WARD33	10	CABLE-AERIAL	REPLACED OVERHEAD MATERIAL
761048	8/6/2008 11:38	8/7/2008 19:18	1,900	038Y147	WARD32	1	PHASE WIRE (ALL VOLTAGES)	REPLACED OVERHEAD MATERIAL
760974	8/6/2008 11:50	8/7/2008 18:16	1,825	Y2559	WARD24	1	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
759351	8/6/2008 12:18	8/6/2008 13:20	62	Y3847	WARD28	39	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
761050	8/6/2008 12:37	8/7/2008 19:24	1,846	Y84036	WARD11	1	FUSE	REPLACED FUSE
760892	8/6/2008 12:55	8/7/2008 14:30	1,534	Y13065	WARD24	1	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
760894	8/6/2008 13:11	8/7/2008 17:06	1,674	Y13065	WARD24	1	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
759847	8/6/2008 13:17	8/6/2008 19:14	356	Z6344	WARD12	1	FUSE	REPLACED FUSE
759476	8/6/2008 13:19	8/6/2008 14:58	98	Y3858	WARD27	43	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
760567	8/6/2008 13:20	8/7/2008 12:50	1,409	X4868	WARD41	15	FUSE	REPLACED FUSE
761071	8/6/2008 13:32	8/7/2008 19:46	1,814	X1439	WARD35	49	CABLE-AERIAL	REPLACED OVERHEAD MATERIAL
760901	8/6/2008 13:44	8/7/2008 17:09	1,645	Y2543	WARD24	1	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
760982	8/6/2008 13:56	8/7/2008 17:15	1,639	X1439	WARD1	72	FUSE	REPLACED FUSE
760865	8/6/2008 14:00	8/6/2008 16:54	173	301X046	WARD38	37	PHASE WIRE (ALL VOLTAGES)	REPLACED OVERHEAD MATERIAL
761537	8/6/2008 14:14	8/8/2008 11:25	2,711	Z8940	WARD34	1	CABLE-AERIAL	REPLACED OVERHEAD MATERIAL
760561	8/6/2008 14:18	8/7/2008 12:45	1,347	X3740	WARD36	1	TAP WIRE	REPAIRED OVERHEAD MATERIAL
761096	8/6/2008 14:21	8/7/2008 20:11	1,790	Z8948	WARD21	37	CABLE-AERIAL	REPAIRED OVERHEAD MATERIAL
759928	8/6/2008 14:33	8/6/2008 20:13	340	MQPK52	WARD15	45	CABLE-AERIAL	OTHER NO FURTHER DETAIL
761131	8/6/2008 14:53	8/7/2008 17:44	1,611	039X159	WARD38	27	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE
760614	8/6/2008 15:04	8/7/2008 13:36	1,352	Y13059	WARD24	21	CABLE-AERIAL	REPAIRED OVERHEAD MATERIAL
760304	8/6/2008 15:18	8/7/2008 05:14	836	380X349	WARD31	81	FUSE	REPLACED FUSE
761968	8/6/2008 15:31	8/8/2008 19:18	3,107	GRDX361	WARD8	1	PHASE WIRE (ALL VOLTAGES)	REPLACED OVERHEAD MATERIAL
760842	8/6/2008 15:31	8/7/2008 16:38	1,506	X3247	WARD31	52	FUSE	REPLACED FUSE
760519	8/6/2008 15:34	8/7/2008 12:08	1,233	X3964	WARD38	67	TAP WIRE	REPAIRED OVERHEAD MATERIAL
760692	8/6/2008 15:35	8/7/2008 14:36	1,380	X3978	WARD38	1	FUSE	REPAIRED OVERHEAD MATERIAL
760508	8/6/2008 15:54	8/7/2008 10:50	1,136	310Y348	WARD28	151	CABLE-AERIAL	REPLACED OVERHEAD MATERIAL
761914	8/6/2008 16:01	8/7/2008 18:11	1,570	C298	WARD41	1	PHASE WIRE (ALL VOLTAGES)	REPLACED OVERHEAD MATERIAL
760810	8/6/2008 16:08	8/7/2008 16:13	1,445	310Y244	WARD28	38	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
760763	8/6/2008 16:09	8/7/2008 15:30	1,400	Y3873	WARD26	1	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
760161	8/6/2008 16:11	8/6/2008 18:58	167	Z83432	WARD7	133	PHASE WIRE (ALL VOLTAGES)	TREE REMOVED
760871	8/6/2008 16:25	8/7/2008 16:55	1,470	X7134	WARD45	1	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
760942	8/6/2008 16:31	8/7/2008 17:38	1,506	Z13784	WARD6	14	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
759631	8/6/2008 16:32	8/6/2008 16:38	6	312X45	WARD44	128	SUBSTATION BREAKER	CLOSED SUBSTATION BREAKER
		8/6/2008 16:38	6		WARD46	243		
760492	8/6/2008 16:39	8/7/2008 11:30	1,131	X7134	WARD41	20	CUTOUT	REPLACED CUTOUT
761800	8/6/2008 16:49	8/8/2008 19:07	3,018	GRDX44	WARD8	58	PHASE WIRE (ALL VOLTAGES)	REPLACED OVERHEAD MATERIAL
760805	8/6/2008 17:03	8/7/2008 16:09	1,386	X3147	WARD29	31	FUSE	REPLACED FUSE
760483	8/6/2008 17:06	8/7/2008 11:41	1,114	X3744	WARD36	1	AUTOMATIC SPLICE	REPAIRED OVERHEAD MATERIAL
761693	8/6/2008 17:26	8/8/2008 16:17	2,811	Y13065	WARD28	1	CABLE-AERIAL	REPAIRED OVERHEAD MATERIAL
761125	8/6/2008 17:39	8/7/2008 20:36	1,616	Z1415	WARD17	1	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
761925	8/6/2008 17:46	8/7/2008 18:28	1,481	X11036	WARD45	1	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
761794	8/6/2008 18:05	8/8/2008 18:00	2,875	X3974	WARD38	22	CABLE-AERIAL	REPLACED OVERHEAD MATERIAL
760841	8/6/2008 18:21	8/7/2008 16:35	1,334	X3247	WARD31	77	FUSE	REPLACED FUSE
762449	8/6/2008 18:30	8/6/2008 19:30	60	300X054	WARD40	49	FUSE	CLOSED FUSE
760816	8/6/2008 18:49	8/7/2008 15:50	1,261	Y3847	WARD28	5	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
760323	8/6/2008 18:49	8/6/2008 18:59	10	X7136	WARD41	1229	ARRESTER-PORCELAIN	CLOSED SUBSTATION BREAKER
761706	8/6/2008 19:12	8/7/2008 18:34	1,401	Y2549	WARD12	1	FUSE	REPLACED FUSE
760443	8/6/2008 19:18	8/7/2008 11:03	944	Y3077	WARD29	1	AUTOMATIC SPLICE	REPAIRED OVERHEAD MATERIAL
760573	8/6/2008 19:19	8/7/2008 12:53	1,054	X4858	WARD36	21	TRANSFORMER-OVHD	REPLACED TRANSFORMER
760103	8/6/2008 19:28	8/6/2008 22:51	203	Z13761	WARD16	68	FUSE	REPLACED FUSE
		8/6/2008 22:51	203		WARD20	41		
761926	8/6/2008 19:46	8/7/2008 18:40	1,374	X11036	WARD41	1	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
760506	8/6/2008 20:44	8/7/2008 11:53	909	Y2557	WARD28	1	TIE WIRE	REPAIRED OVERHEAD MATERIAL
760523	8/6/2008 20:57	8/7/2008 12:14	917	X4871	WARD36	334	FUSE	REPAIRED OVERHEAD MATERIAL
760171	8/6/2008 22:38	8/7/2008 01:15	156	GRDX254	WARD5	1	CABLE-AERIAL	REPAIRED OVERHEAD MATERIAL
761469	8/6/2008 22:48	8/8/2008 11:15	2,187	674X48	WARD38	1	CABLE-AERIAL	REPLACED OVERHEAD MATERIAL
760400	8/6/2008 22:55	8/7/2008 10:28	692	X7136	WARD41	1	AUTOMATIC SPLICE	REPAIRED OVERHEAD MATERIAL
760186	8/6/2008 23:07	8/7/2008 02:05	178	GRDX254	WARD5	1	CABLE-AERIAL	REPAIRED OVERHEAD MATERIAL
760259	8/6/2008 23:14	8/7/2008 04:35	321	X5359	WARD39	264	SWITCH-LOADBRK	CLOSED SWITCH/DISCONNECT/LT
761924	8/6/2008 23:18	8/8/2008 14:00	2,322	X3949	WARD45	1	CABLE-AERIAL	REPAIRED OVERHEAD MATERIAL
761789	8/6/2008 23:27	8/8/2008 18:46	2,598	Z8942	WARD21	1	CABLE-AERIAL	REPLACED OVERHEAD MATERIAL
761674	8/6/2008 23:35	8/8/2008 13:30	2,275	X5368	WARD35	48	TRANSFORMER-OVHD	REPLACED TRANSFORMER
761762	8/7/2008 01:31	8/8/2008 11:32	2,040	Y2557	WARD28	4	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
760522	8/7/2008 03:40	8/7/2008 12:00	499	Z4142	WARD9	15	CABLE-AERIAL	REPAIRED OVERHEAD MATERIAL
760518	8/7/2008 04:47	8/7/2008 11:50	423	Z13761	WARD16	25	ARRESTER-POLYMER	REPLACED OVERHEAD MATERIAL
760302	8/7/2008 06:04	8/7/2008 06:41	37	X4064	WARD44	5	CABLE	TEMPORARY SWITCHING
761381	8/7/2008 06:04	8/7/2008 16:14	610	X5359	WARD39	120	FUSE	REPLACED FUSE

CHICAGO

OUTAGE ID	START DATE TIME	DATE TIME RESTORED	OUTAGE DURATION (MIN)	CIRCUIT	WARD AFFECTED	NUMBER OF CUSTOMERS AFFECTED	EQUIPMENT INVOLVED	RESTORATION AND REMEDIATION
760594	8/7/2008 06:30	8/7/2008 12:20	349	Z13762	WARD6	57	TRANSFORMER-OVHD	REPLACED TRANSFORMER
761106	8/7/2008 07:19	8/7/2008 20:21	782	X3934	WARD38	1	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
761847	8/7/2008 08:03	8/8/2008 12:26	1,702	X7151	WARD41	10	BUSHING-PRIMARY	REPLACED TRANSFORMER
		8/8/2008 20:20	2,176		WARD41	10		
761572	8/7/2008 08:10	8/8/2008 13:27	1,757	X1438	WARD33	48	TRANSFORMER-OVHD	REPLACED TRANSFORMER
760821	8/7/2008 08:29	8/7/2008 14:02	332	687X46	WARD45	1	TRANSFORMER-PADMOUNT	REPLACED TRANSFORMER
761799	8/7/2008 08:53	8/8/2008 17:15	1,942	Y71449	WARD2	1	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
761416	8/7/2008 09:07	8/8/2008 08:30	1,403	Y13052	WARD22	1	CABLE-AERIAL	REPAIRED OVERHEAD MATERIAL
761360	8/7/2008 09:16	8/8/2008 04:28	1,152	28TH246	WARD22	1	CABLE-AERIAL	REPLACED OVERHEAD MATERIAL
761730	8/7/2008 09:17	8/8/2008 16:55	1,898	Y3035	WARD27	1	CABLE-AERIAL	REPLACED OVERHEAD MATERIAL
761234	8/7/2008 09:41	8/7/2008 22:47	785	BURN444	WARD6	1	CABLE-AERIAL	REPLACED OVERHEAD MATERIAL
761534	8/7/2008 09:49	8/8/2008 12:26	1,597	Y71434	WARD25	17	TRANSFORMER-OVHD	REPLACED TRANSFORMER
761650	8/7/2008 09:51	8/8/2008 15:22	1,770	674X57	WARD38	1	CABLE-AERIAL	REPAIRED OVERHEAD MATERIAL
760628	8/7/2008 10:00	8/7/2008 12:45	165	X9158	WARD50	21	TRANSFORMER-OVHD	REPLACED TRANSFORMER
760563	8/7/2008 10:03	8/7/2008 12:47	164	311X141	WARD41	1	CABLE-AERIAL	REPAIRED OVERHEAD MATERIAL
761478	8/7/2008 10:04	8/8/2008 11:28	1,524	Z6344	WARD20	1	CABLE-AERIAL	REPAIRED EQUIPMENT
761927	8/7/2008 10:20	8/9/2008 02:30	2,409	X3939X	WARD39	1	TRANSFORMER-OVHD	REPLACED TRANSFORMER
760571	8/7/2008 10:29	8/7/2008 10:43	14	GRDX30	WARD6	209	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
761093	8/7/2008 11:09	8/7/2008 20:05	536	X1458	WARD26	1	PHASE WIRE (ALL VOLTAGES)	INSTALL OVERHEAD MATERIAL
760897	8/7/2008 11:14	8/7/2008 17:07	353	X11036	WARD45	1	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
760929	8/7/2008 11:42	8/7/2008 17:31	349	C298	WARD41	1	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
761007	8/7/2008 11:44	8/7/2008 18:15	390	Z8940	WARD34	25	FUSE	REPLACED FUSE
760715	8/7/2008 11:57	8/7/2008 14:51	173	687X46	WARD45	1	CONNECTOR-BOLTED	REPAIRED OVERHEAD MATERIAL
761532	8/7/2008 12:14	8/8/2008 12:30	1,455	X3740	WARD36	3	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
761898	8/7/2008 12:16	8/8/2008 13:05	1,488	Z4142	WARD9	15	TRANSFORMER-OVHD	REPLACED TRANSFORMER
761868	8/7/2008 12:26	8/8/2008 22:00	2,014	793Y42	WARD37	1	PHASE WIRE (ALL VOLTAGES)	REPLACED OVERHEAD MATERIAL
761470	8/7/2008 12:28	8/8/2008 10:45	1,337	JUST041	WARD18	1	CABLE-AERIAL	REPLACED OVERHEAD MATERIAL
761431	8/7/2008 12:35	8/7/2008 22:30	595	X1432	WARD32	45	PHASE WIRE (ALL VOLTAGES)	REPLACED OVERHEAD MATERIAL
761948	8/7/2008 13:15	8/9/2008 05:50	2,435	Z6346	WARD23	1	TRANSFORMER-OVHD	REPLACED TRANSFORMER
761687	8/7/2008 13:22	8/8/2008 15:30	1,568	X5347	WARD33	1	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
761802	8/7/2008 13:31	8/8/2008 19:09	1,777	X5456	WARD32	1	SWITCH-SINGLE PHASE	REPAIRED OVERHEAD MATERIAL
761559	8/7/2008 13:39	8/8/2008 13:18	1,419	X4864	WARD36	1	CABLE-AERIAL	TREE REMOVED
761340	8/7/2008 13:46	8/8/2008 03:11	806	X3237	WARD37	38	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
761806	8/7/2008 13:48	8/8/2008 17:40	1,672	X5471	WARD43	1	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
761798	8/7/2008 13:55	8/8/2008 18:56	1,741	X5439	WARD43	1	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
761808	8/7/2008 14:02	8/8/2008 19:21	1,759	Y3078	WARD29	1	FUSE	REPLACED FUSE
761696	8/7/2008 14:12	8/8/2008 16:15	1,562	Z15074	WARD7	1	CABLE-AERIAL	REPAIRED OVERHEAD MATERIAL
761284	8/7/2008 14:20	8/8/2008 01:00	640	X3980	WARD45	155	FUSE	CLOSED SWITCH/DISCONNECT/LT
761891	8/7/2008 14:27	8/8/2008 12:00	1,292	X7131	WARD41	23	TRANSFORMER-OVHD	REPLACED TRANSFORMER
761728	8/7/2008 15:13	8/8/2008 16:52	1,539	031X042	WARD36	1	CABLE-AERIAL	REPAIRED OVERHEAD MATERIAL
761105	8/7/2008 16:05	8/7/2008 20:19	253	X4033	WARD43	1	CABLE-AERIAL	REPLACED OVERHEAD MATERIAL
761811	8/7/2008 16:06	8/8/2008 18:00	1,554	X3946	WARD30	24	TRANSFORMER-OVHD	REPLACED TRANSFORMER
761831	8/7/2008 16:13	8/8/2008 20:43	1,709	310Y142	WARD28	1	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
763724	8/7/2008 16:49	8/8/2008 15:55	1,386	Z4141	WARD9	35	FUSE	REPLACED FUSE
761807	8/7/2008 16:49	8/8/2008 19:00	1,570	X3137	WARD36	1	CABLE-AERIAL	REPLACED OVERHEAD MATERIAL
761921	8/7/2008 17:05	8/7/2008 19:46	160	56TH446	WARD3	1	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
761699	8/7/2008 17:16	8/8/2008 16:27	1,391	28TH243	WARD22	1	CABLE-AERIAL	REPLACED OVERHEAD MATERIAL
761182	8/7/2008 18:02	8/7/2008 21:04	182	Y2568	WARD11	1	CONNECTOR-WEDGE	REPAIRED OVERHEAD MATERIAL
		8/7/2008 21:27	204		WARD11	1		
761291	8/7/2008 18:02	8/8/2008 01:29	446	MFLD250	WARD20	29	CONNECTOR-WEDGE	REPAIRED OVERHEAD MATERIAL
761608	8/7/2008 18:13	8/7/2008 21:30	196	X7131	WARD41	20	TRANSFORMER-OVHD	REPLACED TRANSFORMER
761784	8/7/2008 18:36	8/8/2008 18:34	1,437	X3254	WARD31	1	POLE	REPAIRED OVERHEAD MATERIAL
763638	8/7/2008 18:38	8/8/2008 18:11	1,412	X4044	WARD43	1	PHASE WIRE (ALL VOLTAGES)	REPLACED OVERHEAD MATERIAL
761066	8/7/2008 18:51	8/7/2008 19:12	21	X8442	WARD46	520	SWITCH-LOADBRK	CLOSED SWITCH/DISCONNECT/LT
761218	8/7/2008 19:11	8/7/2008 22:26	195	301X056	WARD31	1	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
761731	8/7/2008 20:02	8/8/2008 16:55	1,253	674X57	WARD38	1	CABLE-AERIAL	REPAIRED OVERHEAD MATERIAL
761352	8/7/2008 21:44	8/8/2008 03:30	345	GRDX257	WARD8	1	FUSE	REPLACED FUSE
761838	8/7/2008 22:30	8/8/2008 20:56	1,346	380X453	WARD26	1	ALLEY-ARM	REPAIRED OVERHEAD MATERIAL
761796	8/7/2008 22:40	8/8/2008 18:40	1,199	X8442	WARD46	1	CABLE-AERIAL	REPAIRED OVERHEAD MATERIAL
761312	8/8/2008 01:04	8/8/2008 01:36	31	Y71434	WARD25	223	FUSE	REPLACED FUSE
761324	8/8/2008 02:11	8/8/2008 02:18	8	X5453	WARD27	8	SUBSTATION BREAKER	CLOSED SUBSTATION BREAKER
		8/8/2008 02:18	8		WARD43	1093		
		8/8/2008 05:58	227		WARD43	23		
761779	8/8/2008 05:52	8/8/2008 18:20	748	Y3077	WARD29	1	NEUTRAL WIRE	REPAIRED OVERHEAD MATERIAL

NORTHERN

OUTAGE ID	START DATE TIME	DATE TIME RESTORED	OUTAGE DURATION (MIN)	CIRCUIT	TOWN AFFECTED	NUMBER OF CUSTOMERS AFFECTED	EQUIPMENT INVOLVED	RESTORATION AND REMEDIATION
759714	8/4/2008 19:59	8/4/2008 23:43	224	L7831	CHICAGO	1	PHASE WIRE (ALL VOLTAGES)	TEMPORARY SWITCHING
		8/4/2008 23:43	224		CHICAGO	7		
759727	8/4/2008 20:02	8/4/2008 23:51	229	L4653	CHICAGO	1	PHASE WIRE (ALL VOLTAGES)	CLOSED SUBSTATION BREAKER
		8/4/2008 23:51	229		CHICAGO	7		
757946	8/5/2008 00:57	8/5/2008 03:02	125	W3512	CHICAGO	1	PHASE WIRE (ALL VOLTAGES)	CLOSED SWITCH/DISCONNECT/LT