REGION_NAME	OUTAGE_ID	START_DATETIME	DATETIME_RSTD	DURATION _MINUTES	AS_BUILT _FEEDER _LINE	TOWN NAME	PREM _COUNT	EQUIPMENT_INVOLVED	RESTORATION_MEDIATION
NORTHWEST	689332	8/23/2007 22:35	8/24/2007 0:43	127.1	R8874	ROCKFORD TWP	36	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHWEST	689332	8/23/2007 22:35	8/24/2007 0:43	127.1	R8874	ROSCOE TWP	1	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHWEST	689764	8/23/2007 22:36	8/24/2007 16:00	1043.7	H446	EAST GROVE TWP	1	TRANSFORMER-OVHD	REPLACED TRANSFORMER
NORTHWEST	689943	8/23/2007 22:36	8/24/2007 11:35	778.6	W744	HANOVER PARK	28	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHWEST	689943	8/23/2007 22:36	8/24/2007 21:00	1343.6	W744	HANOVER PARK	53	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
SOUTHERN	691867	8/23/2007 22:37	8/26/2007 20:15	4177.9	F3571	TINLEY PARK	1	CABLE-AERIAL	REPAIRED OVERHEAD MATERIAL
NORTHERN	689367	8/23/2007 22:38	8/24/2007 1:35	176.8	C773	SKOKIE	16	FUSE	DISCONNECT OVERHEAD MATERIAL
NORTHWEST	689802	8/23/2007 22:38	8/24/2007 18:16	1177.4	W744	HANOVER PARK	22	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHERN	695430	8/23/2007 22:40	8/23/2007 22:50	10	L12054	WHEATON	102	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHERN	695430	8/23/2007 22:40	8/23/2007 22:50	10	L12054	GLEN ELLYN	16	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHERN	695430	8/23/2007 22:40	8/23/2007 23:05	25	L12054	WHEATON	1020	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHERN	695430	8/23/2007 22:40	8/24/2007 16:58	1098	L12054	ADDISON TWP	28	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHERN	695430	8/23/2007 22:40	8/24/2007 16:58	1098	L12054	ADDISON	1599	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHERN	695430	8/23/2007 22:40	8/24/2007 16:58	1098	L12054	BENSENVILLE	1	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
CHICAGO	689568	8/23/2007 22:43	8/24/2007 12:29	825.2	X7145	WARD41	307	FUSE	REPLACED FUSE
SOUTHERN	698983	8/23/2007 22:44	8/23/2007 23:05	20.3	S375	STREATOR	16	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE
NORTHERN	691899	8/23/2007 22:46	8/26/2007 21:00	4213.2	C7215	NORTHFIELD TWP	1	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHWEST	689386	8/23/2007 22:50	8/24/2007 4:20	329.7	H385	LORAINE TWP	5	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHWEST	689386	8/23/2007 22:50	8/24/2007 4:20	329.7	H385	YORKTOWN TWP	6	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHERN	691221	8/23/2007 22:51	8/26/2007 11:45	3653.3	D0506	RIVER FOREST	11	PHASE WIRE (ALL VOLTAGES)	REPAIRED EQUIPMENT
CHICAGO	690394	8/23/2007 22:59	8/25/2007 12:30	2250.6	X3137	WARD36	61	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE
SOUTHERN	689751	8/23/2007 23:00	8/24/2007 17:10	1089.3	G6194	OAK FOREST	1	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHERN	690323	8/23/2007 23:00	8/25/2007 10:43	2142.3	W743X	SCHAUMBURG	22	FUSE	REPLACED FUSE
NORTHERN	690323	8/23/2007 23:00	8/25/2007 10:43	2142.3	W743X	SCHAUMBURG TWP	1	FUSE	REPLACED FUSE
NORTHERN	691593	8/23/2007 23:00	8/26/2007 11:45	3644.3	D0506	RIVER FOREST	1	PHASE WIRE (ALL VOLTAGES)	INSTALL OVERHEAD MATERIAL
SOUTHERN	690207	8/23/2007 23:02	8/24/2007 3:18	255.7	F3586	RICH TWP	49	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
SOUTHERN	690207	8/23/2007 23:02	8/24/2007 3:18	255.7	F3586	FLOSSMOOR	1	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
SOUTHERN	690207	8/23/2007 23:02	8/24/2007 3:18	255.7	F3586	TINLEY PARK	1	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
SOUTHERN	690207	8/23/2007 23:02	8/24/2007 3:18	255.7	F3586	COUNTRY CLUB HILLS	516	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
SOUTHERN	690207	8/23/2007 23:02	8/24/2007 3:18	255.7	F3586	CRETE	1	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
SOUTHERN	690207	8/23/2007 23:02	8/24/2007 3:18	255.7	F3586	MATTESON	531	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
SOUTHERN	690207	8/23/2007 23:02	8/24/2007 3:18	255.7	F3586	CHICAGO HEIGHTS	2	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
SOUTHERN	690207	8/23/2007 23:02	8/24/2007 3:18	255.7	F3586	UNIVERSITY PARK	1	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
SOUTHERN	690207	8/23/2007 23:02	8/24/2007 3:18	255.7	F3586	OLYMPIA FIELDS	68	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHERN	690987	8/23/2007 23:02	8/24/2007 7:14	491.2	E6820	ARLINGTON HEIGHTS	431	PHASE WIRE (ALL VOLTAGES)	TEMPORARY SWITCHING
NORTHERN	690987	8/23/2007 23:02	8/24/2007 8:01	538.2	E6820	ARLINGTON HEIGHTS	572	PHASE WIRE (ALL VOLTAGES)	TEMPORARY SWITCHING
NORTHERN	690987	8/23/2007 23:02	8/24/2007 14:00	897.2	E6820	ROLLING MDWS	2	PHASE WIRE (ALL VOLTAGES)	TEMPORARY SWITCHING
NORTHERN	690987	8/23/2007 23:02	8/24/2007 14:00	897.2	E6820	ARLINGTON HEIGHTS	98	PHASE WIRE (ALL VOLTAGES)	TEMPORARY SWITCHING
NORTHERN	691030	8/23/2007 23:02	8/26/2007 5:10	3247.1	E521	MOUNT PROSPECT	43	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHERN	690841	8/23/2007 23:03	8/24/2007 15:58	1014.3	W523	LOMBARD	81	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHERN	690841	8/23/2007 23:03	8/24/2007 15:58	1014.3	W523	VILLA PARK	55	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHERN	690841	8/23/2007 23:03	8/24/2007 18:00	1136.1	W523	LOMBARD	46	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHWEST	689333	8/23/2007 23:04	8/24/2007 0:43	98.6	R8874	ROCKFORD	1	SWITCH-LTD	CLOSED SWITCH/DISCONNECT/LT
NORTHWEST	689333	8/23/2007 23:04	8/24/2007 0:43	98.6	R8874	ROSCOE TWP	106	SWITCH-LTD	CLOSED SWITCH/DISCONNECT/LT
NORTHWEST	689333	8/23/2007 23:04	8/24/2007 0:43	98.6	R8874	ROCKFORD TWP	522	SWITCH-LTD	CLOSED SWITCH/DISCONNECT/LT
NORTHWEST	689333	8/23/2007 23:04	8/24/2007 0:43	98.6	R8874	CALEDONIA-P GROVE	1	SWITCH-LTD	CLOSED SWITCH/DISCONNECT/LT
NORTHWEST	689333	8/23/2007 23:04	8/24/2007 0:43	98.6	R8874	SHIRLAND RURAL	1	SWITCH-LTD	CLOSED SWITCH/DISCONNECT/LT
NORTHWEST	689333	8/23/2007 23:04	8/24/2007 0:43	98.6	R8874	ROSCOE	764	SWITCH-LTD	CLOSED SWITCH/DISCONNECT/LT

REGION_NAME	OUTAGE_ID	START_DATETIME	DATETIME_RSTD	DURATION _MINUTES	AS_BUILT _FEEDER _LINE	TOWN NAME	PREM _COUNT	EQUIPMENT_INVOLVED	RESTORATION_MEDIATION
SOUTHERN	689721	8/23/2007 23:04	8/24/2007 16:00	1015.5	J3691	JOLIET	35	PHASE WIRE (ALL VOLTAGES)	TEMPORARY SWITCHING
SOUTHERN	691057	8/23/2007 23:04	8/24/2007 4:42	338	G1997	ORLAND TWP	9	CUTOUT	REPLACED CUTOUT
SOUTHERN	691057	8/23/2007 23:04	8/24/2007 4:42	338	G1997	CRESTWOOD	1	CUTOUT	REPLACED CUTOUT
SOUTHERN	691057	8/23/2007 23:04	8/24/2007 4:42	338	G1997	THORNTON TWP	1	CUTOUT	REPLACED CUTOUT
SOUTHERN	691057	8/23/2007 23:04	8/24/2007 4:42	338	G1997	TINLEY PARK	1073	CUTOUT	REPLACED CUTOUT
SOUTHERN	691057	8/23/2007 23:04	8/24/2007 5:20	376	G1997	TINLEY PARK	11	CUTOUT	REPLACED CUTOUT
NORTHWEST	689344	8/23/2007 23:08	8/24/2007 1:15	126.3	B155	FRANKLIN TWP	19	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE
CHICAGO	691733	8/23/2007 23:08	8/26/2007 19:00	4071.4	X8442	WARD46	108	TIE WIRE	REPAIRED OVERHEAD MATERIAL
NORTHWEST	689342	8/23/2007 23:11	8/24/2007 1:40	148.9	H366	PROPHETSTOWN TWP	29	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE
NORTHWEST	689342	8/23/2007 23:11	8/24/2007 1:40	148.9	H366	YORKTOWN TWP	4	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE
NORTHWEST	689342	8/23/2007 23:11	8/24/2007 1:40	148.9	H366	TAMPICO TWP	2	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE
NORTHERN	690885	8/23/2007 23:11	8/26/2007 1:29	3018	W4563	ELMHURST	1	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHERN	691944	8/23/2007 23:11	8/26/2007 23:24	4332.7	C1212	NORTHFIELD	12	TRANSFORMER-OVHD	REPLACED OVERHEAD MATERIAL
NORTHERN	691990	8/23/2007 23:11	8/25/2007 15:30	2419.6	C211	SKOKIE	399	PHASE WIRE (ALL VOLTAGES)	TREE REMOVED
NORTHERN	691990	8/23/2007 23:11	8/25/2007 15:30	2419.6	C211	GLENVIEW	170	PHASE WIRE (ALL VOLTAGES)	TREE REMOVED
SOUTHERN	691582	8/23/2007 23:13	8/26/2007 17:15	3961.9	J195	LOCKPORT	7	FUSE	REPLACED FUSE
NORTHWEST	689426	8/23/2007 23:14	8/24/2007 6:20	425.6	E6025	DUNDEE TWP	171	PHASE WIRE (ALL VOLTAGES)	TREE TRIMMED
NORTHWEST	689426	8/23/2007 23:14	8/24/2007 6:20	425.6	E6025	CARPENTERSVILLE	4	PHASE WIRE (ALL VOLTAGES)	TREE TRIMMED
NORTHERN	690982	8/23/2007 23:14	8/25/2007 12:55	2260.2	C496	WILMETTE	104	TRANSFORMER-3:1	REPLACED TRANSFORMER
SOUTHERN	691558	8/23/2007 23:14	8/26/2007 17:00	3945.6	J185	LOCKPORT TWP	7	TRANSFORMER-OVHD	REPLACED TRANSFORMER
SOUTHERN	691558	8/23/2007 23:14	8/26/2007 17:00	3945.6	J185	LOCKPORT	2	TRANSFORMER-OVHD	REPLACED TRANSFORMER
SOUTHERN	689409	8/23/2007 23:15	8/24/2007 5:15	359.8	W3605	HINSDALE	19	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
SOUTHERN	689409	8/23/2007 23:15	8/24/2007 5:15	359.8	W3605	BURR RIDGE	1	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHERN	689897	8/23/2007 23:15	8/24/2007 20:05	1249.4	D991	FRANKLIN PARK	17	FUSE	REPLACED FUSE
SOUTHERN	690853	8/23/2007 23:16	8/25/2007 23:45	2908.3	G6190	POSEN	2	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE
SOUTHERN	690853	8/23/2007 23:16	8/25/2007 23:45	2908.3	G6190	CRESTWOOD	1	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE
SOUTHERN	690853	8/23/2007 23:16	8/25/2007 23:45	2908.3	G6190	ROBBINS	3	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE
SOUTHERN	690853	8/23/2007 23:16	8/25/2007 23:45	2908.3	G6190	BLUE ISLAND	219	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE
SOUTHERN	690853	8/23/2007 23:16	8/25/2007 23:45	2908.3	G6190	CALUMET PARK	1	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE
NORTHERN	692324	8/23/2007 23:16	8/27/2007 11:43	5066.6	C296	SKOKIE	17	FUSE	REPLACED CUTOUT
SOUTHERN	690412	8/23/2007 23:18	8/25/2007 13:05	2266.3	G4377	MARKHAM	38	FUSE	REPLACED FUSE
NORTHERN	700458	8/23/2007 23:24	8/26/2007 15:00	3815.3	C1510	DES PLAINES	8	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE
NORTHERN	690476	8/23/2007 23:26	8/25/2007 15:35	2409	W2013	MILTON TWP	10	FUSE	REPAIRED OVERHEAD MATERIAL
CHICAGO	690854	8/23/2007 23:26	8/25/2007 23:40	2894	Z5544	WARD10	2	FUSE	REPLACED FUSE
CHICAGO	690346	8/23/2007 23:27	8/25/2007 6:21	1854	Z1408	WARD15	35	TRANSFORMER-OVHD	REPLACED TRANSFORMER
NORTHWEST	689779	8/23/2007 23:30	8/24/2007 16:30	1019.5	W391	ST CHARLES TWP	5	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE
NORTHERN	690996	8/23/2007 23:30	8/25/2007 17:00	2489.7	D142	PROVISO TWP	10	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE
NORTHERN	691455	8/23/2007 23:30	8/24/2007 16:35	1025	W432	ELMHURST	1	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHERN	691455	8/23/2007 23:30	8/25/2007 1:00	1529.4	W432	ELMHURST	73	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHERN	695447	8/23/2007 23:31	8/23/2007 23:56	25	L6467	BELLWOOD	2	PHASE WIRE (ALL VOLTAGES)	TEMPORARY SWITCHING
NORTHERN	695447	8/23/2007 23:31	8/23/2007 23:56	25	L6467	RIVER GROVE	1	PHASE WIRE (ALL VOLTAGES)	TEMPORARY SWITCHING
NORTHERN	695447	8/23/2007 23:31	8/23/2007 23:56	25	L6467	MELROSE PARK	8	PHASE WIRE (ALL VOLTAGES)	TEMPORARY SWITCHING
CHICAGO	689431	8/23/2007 23:34	8/24/2007 7:54	499.5	Z11871	WARD17	53	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE
CHICAGO	689431	8/23/2007 23:34	8/24/2007 7:54	499.5	Z11871	WARD21	164	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE
NORTHWEST	695409	8/23/2007 23:35	8/24/2007 2:29	174	W1001	DUNDEE TWP	1	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHWEST	695409	8/23/2007 23:35	8/24/2007 2:29	174	W1001	VALLEY VIEW	11	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHWEST	695409	8/23/2007 23:35	8/24/2007 2:29	174	W1001	SOUTH ELGIN	1	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHWEST	695409	8/23/2007 23:35	8/24/2007 2:29	174	W1001	BARTLETT	4	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL

REGION_NAME	OUTAGE_ID	START_DATETIME	DATETIME_RSTD	DURATION _MINUTES	AS_BUILT _FEEDER _LINE	TOWN NAME	PREM _COUNT	EQUIPMENT_INVOLVED	RESTORATION_MEDIATION
NORTHWEST	695409	8/23/2007 23:35	8/24/2007 2:29	174	W1001	ST CHARLES TWP	827	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHWEST	695409	8/23/2007 23:35	8/24/2007 2:29	174	W1001	ST CHARLES	8	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHWEST	695409	8/23/2007 23:35	8/24/2007 2:29	174	W1001	WAYNE	90	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
SOUTHERN	689765	8/23/2007 23:36	8/24/2007 2:34	178	J5683	JOLIET	141	PHASE WIRE (ALL VOLTAGES)	TEMPORARY SWITCHING
SOUTHERN	689765	8/23/2007 23:36	8/24/2007 14:17	881	J5683	JOLIET	2	PHASE WIRE (ALL VOLTAGES)	TEMPORARY SWITCHING
SOUTHERN	689765	8/23/2007 23:36	8/24/2007 16:25	1009	J5683	JOLIET	213	PHASE WIRE (ALL VOLTAGES)	TEMPORARY SWITCHING
SOUTHERN	689765	8/23/2007 23:36	8/24/2007 17:13	1057	J5683	TROY TWP	1	PHASE WIRE (ALL VOLTAGES)	TEMPORARY SWITCHING
SOUTHERN	689765	8/23/2007 23:36	8/24/2007 17:13	1057	J5683	JOLIET	567	PHASE WIRE (ALL VOLTAGES)	TEMPORARY SWITCHING
SOUTHERN	695398	8/23/2007 23:36	8/24/2007 7:50	494	F321	STEGER	762	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
SOUTHERN	690364	8/23/2007 23:37	8/25/2007 12:46	2228.6	G6586	DOLTON	48	PHASE WIRE (ALL VOLTAGES)	TREE REMOVED
NORTHWEST	694345	8/23/2007 23:37	8/24/2007 2:45	187.5	E595	DUNDEE TWP	69	PHASE WIRE (ALL VOLTAGES)	REPLACED OVERHEAD MATERIAL
SOUTHERN	689455	8/23/2007 23:38	8/24/2007 7:00	441.1	K7092	BOURBONNAIS	373	PHASE WIRE (ALL VOLTAGES)	CLOSED FUSE
SOUTHERN	689455	8/23/2007 23:38	8/24/2007 9:30	591.1	K7092	BOURBONNAIS	559	PHASE WIRE (ALL VOLTAGES)	CLOSED FUSE
NORTHERN	691065	8/23/2007 23:41	8/26/2007 8:05	3383.1	C161	MOUNT PROSPECT	69	PHASE WIRE (ALL VOLTAGES)	CLOSED FUSE
SOUTHERN	690058	8/23/2007 23:42	8/24/2007 11:30	707.6	J686	GARFIELD TWP	13	CUTOUT	REPLACED CUTOUT
SOUTHERN	690058	8/23/2007 23:42	8/24/2007 11:30	707.6	J686	COAL CITY	15	CUTOUT	REPLACED CUTOUT
SOUTHERN	690058	8/23/2007 23:42	8/24/2007 11:30	707.6	J686	GOOSE LAKE TWP	24	CUTOUT	REPLACED CUTOUT
SOUTHERN	690058	8/23/2007 23:42	8/24/2007 11:30	707.6	J686	BRACEVILLE TWP	15	CUTOUT	REPLACED CUTOUT
SOUTHERN	690058	8/23/2007 23:42	8/24/2007 11:30	707.6	J686	MAZON TWP	31	CUTOUT	REPLACED CUTOUT
SOUTHERN	690058	8/23/2007 23:42	8/24/2007 11:30	707.6	J686	MAINE TWP	89	CUTOUT	REPLACED CUTOUT
SOUTHERN	689684	8/23/2007 23:43	8/24/2007 15:30	946.4	K505	MOMENCE	14	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE
SOUTHERN	689349	8/23/2007 23:44	8/24/2007 2:00	135.2	S211	RICHLAND TWP	5	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE
NORTHWEST	690069	8/23/2007 23:45	8/24/2007 16:19	993.2	W392	CAMPTON TWP	89	FUSE	REPLACED OVERHEAD MATERIAL
NORTHWEST	690069	8/23/2007 23:45	8/24/2007 16:19	993.2	W392	ST CHARLES TWP	2	FUSE	REPLACED OVERHEAD MATERIAL
SOUTHERN	690580	8/23/2007 23:45	8/25/2007 18:00	2534.5	J7472	NEW LENOX TWP	5	FUSE	REPLACED FUSE
NORTHERN	691322	8/23/2007 23:45	8/26/2007 13:20	3694.1	C525	GOLF	1	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
SOUTHERN	690145	8/23/2007 23:47	8/25/2007 2:20	1592.9	J4085	FRANKFORT TWP	1	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE
SOUTHERN	690145	8/23/2007 23:47	8/25/2007 2:20	1592.9	J4085	FRANKFORT	61	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE
SOUTHERN	689705	8/23/2007 23:48	8/24/2007 16:00	971.8	J1683	MOKENA	1	FUSE	REPLACED FUSE
SOUTHERN	689705	8/23/2007 23:48	8/24/2007 16:00	971.8	J1683	LOCKPORT	91	FUSE	REPLACED FUSE
SOUTHERN	689705	8/23/2007 23:48	8/24/2007 16:00	971.8	J1683	HOMER TWP	11	FUSE	REPLACED FUSE
SOUTHERN	690114	8/23/2007 23:49	8/25/2007 2:20	1590.2	J686	FELIX TWP	27	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
SOUTHERN	690114	8/23/2007 23:49	8/25/2007 2:20	1590.2	J686	GOOSE LAKE TWP	56	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
SOUTHERN	690114	8/23/2007 23:49	8/25/2007 2:20	1590.2	J686	COAL CITY	2	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
SOUTHERN	690114	8/23/2007 23:49	8/25/2007 2:20	1590.2	J686	CARBON HILL	19	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
SOUTHERN	690114	8/23/2007 23:49	8/25/2007 2:20	1590.2	J686	WAUPONSEE TWP	21	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHERN	691332	8/23/2007 23:50	8/26/2007 13:20	3689.1	C525	GOLF	14	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHERN	691392	8/23/2007 23:54	8/26/2007 14:22	3748	W3515	BENSENVILLE	97	TIE WIRE	REPAIRED OVERHEAD MATERIAL
SOUTHERN	689612	8/23/2007 23:57	8/24/2007 14:13	855.8	F457	CRETE	1	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHWEST	689644	8/23/2007 23:57	8/24/2007 2:38	160	E6027	CARPENTERSVILLE	59	FUSE	REPAIRED OVERHEAD MATERIAL
NORTHWEST	689644	8/23/2007 23:57	8/24/2007 14:59	901.5	E6027	CARPENTERSVILLE	23	FUSE	REPAIRED OVERHEAD MATERIAL
SOUTHERN	689587	8/24/2007 0:00	8/24/2007 2:55	175	K405	BOURBONNAIS	71	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
SOUTHERN	689587	8/24/2007 0:00	8/24/2007 2:55	175	K405	MANTENO TWP	129	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
SOUTHERN	689587	8/24/2007 0:00	8/24/2007 2:55	175	K405	WILTON TWP	40	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
SOUTHERN	689587	8/24/2007 0:00	8/24/2007 2:55	175	K405	MANTENO	368	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
SOUTHERN	689587	8/24/2007 0:00	8/24/2007 2:55	175	K405	PEOTONE TWP	132	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
SOUTHERN	689587	8/24/2007 0:00	8/24/2007 2:55	175	K405	BRADLEY	1	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
SOUTHERN	689587	8/24/2007 0:00	8/24/2007 2:55	175	K405	ROCKVILLE TWP	66	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL

REGION_NAME	OUTAGE_ID	START_DATETIME	DATETIME_RSTD	DURATION _MINUTES	AS_BUILT _FEEDER _LINE	TOWN NAME	PREM _COUNT	EQUIPMENT_INVOLVED	RESTORATION_MEDIATION
SOUTHERN	689587	8/24/2007 0:00	8/24/2007 2:55	175	K405	BOURBONNAIS TWP	18	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHERN	691179	8/24/2007 0:02	8/26/2007 9:20	3437.5	W3522	BENSENVILLE	22	PHASE WIRE (ALL VOLTAGES)	CLOSED FUSE
SOUTHERN	691388	8/24/2007 0:02	8/25/2007 21:15	2712.4	G6976	HOMETOWN	28	FUSE	REPLACED FUSE
NORTHWEST	689343	8/24/2007 0:03	8/24/2007 0:30	26.3	H537	SANDWICH	1	FUSE	REPLACED FUSE
NORTHWEST	689343	8/24/2007 0:03	8/24/2007 0:30	26.3	H537	LAKE HOLIDAY	466	FUSE	REPLACED FUSE
NORTHWEST	689343	8/24/2007 0:03	8/24/2007 0:30	26.3	H537	NORTHVILLE TWP	1	FUSE	REPLACED FUSE
NORTHERN	689411	8/24/2007 0:04	8/24/2007 4:23	258.9	C143	LAKE BLUFF	60	PHASE WIRE (ALL VOLTAGES)	TREE REMOVED
NORTHERN	689411	8/24/2007 0:04	8/24/2007 4:23	258.9	C143	LAKE FOREST	25	PHASE WIRE (ALL VOLTAGES)	TREE REMOVED
NORTHERN	689411	8/24/2007 0:04	8/24/2007 6:02	357.9	C143	LAKE FOREST	82	PHASE WIRE (ALL VOLTAGES)	TREE REMOVED
NORTHERN	689411	8/24/2007 0:04	8/24/2007 6:02	357.9	C143	LAKE BLUFF	56	PHASE WIRE (ALL VOLTAGES)	TREE REMOVED
SOUTHERN	690206	8/24/2007 0:04	8/24/2007 0:13	9.1	F4782	EAST HAZELCREST	1	SUBSTATION BREAKER	REPAIRED OVERHEAD MATERIAL
SOUTHERN	690206	8/24/2007 0:04	8/24/2007 0:13	9.1	F4782	LANSING	645	SUBSTATION BREAKER	REPAIRED OVERHEAD MATERIAL
NORTHERN	690216	8/24/2007 0:06	8/24/2007 22:15	1328.7	C4715	EVANSTON	163	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE
NORTHWEST	689377	8/24/2007 0:07	8/24/2007 3:50	222.5	H651	PLANO	73	FUSE	REPLACED FUSE
NORTHWEST	689377	8/24/2007 0:07	8/24/2007 3:50	222.5	H651	DEKALB	1	FUSE	REPLACED FUSE
NORTHWEST	689377	8/24/2007 0:07	8/24/2007 3:50	222.5	H651	LITTLE ROCK	1	FUSE	REPLACED FUSE
NORTHWEST	689377	8/24/2007 0:07	8/24/2007 3:50	222.5	H651	LITTLE ROCK TWP	15	FUSE	REPLACED FUSE
NORTHERN	691191	8/24/2007 0:12	8/26/2007 11:15	3542	D783	FRANKLIN PARK	12	FUSE	REPLACED FUSE
SOUTHERN	690302	8/24/2007 0:14	8/25/2007 10:40	2065.8	G4377	HAZELCREST	46	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE
SOUTHERN	690302	8/24/2007 0:14	8/25/2007 10:40	2065.8	G4377	EAST HAZELCREST	3	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE
SOUTHERN	691633	8/24/2007 0:16	8/26/2007 18:43	3986.5	J245	KENDALL TWP	1	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
SOUTHERN	690858	8/24/2007 0:18	8/26/2007 0:20	2881.5	J245	BIG GROVE TWP	1	FUSE	REPLACED FUSE
CHICAGO	690343	8/24/2007 0:20	8/24/2007 3:31	190.5	Z8946	WARD19	20	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
CHICAGO	690343	8/24/2007 0:20	8/24/2007 3:54	213.5	Z8946	WARD19	18	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
CHICAGO	690343	8/24/2007 0:20	8/25/2007 12:16	2155.6	Z8946	WARD19	19	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHERN	691012	8/24/2007 0:20	8/25/2007 16:00	2379.6	D22	OAK PARK	30	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHWEST	689385	8/24/2007 0:21	8/24/2007 4:10	228.5	B275	SCOTT TWP	20	PHASE WIRE (ALL VOLTAGES)	TREE REMOVED
SOUTHERN	690493	8/24/2007 0:21	8/25/2007 15:30	2348.9	J245	KENDALL TWP	1	FUSE	REPLACED FUSE
NORTHERN	691748	8/24/2007 0:22	8/26/2007 19:56	4053.2	D4903	NORTHLAKE	2	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHWEST	690070	8/24/2007 0:24	8/24/2007 17:15	1010.8	W111	PLATO TWP	2	PHASE WIRE (ALL VOLTAGES)	TREE REMOVED
CHICAGO	690036	8/24/2007 0:26	8/24/2007 23:15	1369	Y2573	WARD11	65	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE
NORTHERN	691074	8/24/2007 0:28	8/26/2007 8:05	3336.1	W0110	WOOD DALE	26	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE
CHICAGO	691706	8/24/2007 0:28	8/25/2007 10:13	2024.4	307X050	WARD50	55	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE
NORTHERN	691600	8/24/2007 0:30	8/26/2007 18:22	3952.4	W4566	ELMHURST	36	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHERN	691246	8/24/2007 0:31	8/26/2007 11:25	3533	C758	EVANSTON	35	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHERN	689680	8/24/2007 0:32	8/24/2007 6:50	377.7	W7415	SCHAUMBURG	21	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHERN	689680	8/24/2007 0:32	8/24/2007 6:50	377.7	W7415	SCHAUMBURG TWP	51	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
SOUTHERN	691212	8/24/2007 0:32	8/26/2007 11:50	3557.9	K155	WESLEY TWP	1	FUSE	REPLACED FUSE
NORTHWEST	689624	8/24/2007 0:35	8/24/2007 13:10	754.6	W111	CAMPTON TWP	26	TRANSFORMER-PADMOUNT	TEMPORARY SWITCHING
NORTHWEST	689624	8/24/2007 0:35	8/24/2007 14:00	804.6	W111	CAMPTON TWP	1	TRANSFORMER-PADMOUNT	TEMPORARY SWITCHING
SOUTHERN	691291	8/24/2007 0:35	8/25/2007 5:05	1709.6	G4081	PALOS TWP	13	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE
SOUTHERN	691291	8/24/2007 0:35	8/26/2007 13:45	3669.6	G4081	PALOS TWP	4	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE
SOUTHERN	689541	8/24/2007 0:37	8/24/2007 10:45	607.4	W456Y	WESTMONT	7	FUSE	REPLACED FUSE
SOUTHERN	689541	8/24/2007 0:37	8/24/2007 10:45	607.4	W456Y	DOWNERS GROVE TWP	5	FUSE	REPLACED FUSE
CHICAGO	689932	8/24/2007 0:37	8/24/2007 20:00	1162.1	X5356	WARD45	331	TAP WIRE	REPAIRED OVERHEAD MATERIAL
SOUTHERN	691832	8/24/2007 0:38	8/24/2007 22:00	1281.1	G6186	CRESTWOOD	8	PHASE WIRE (ALL VOLTAGES)	INSTALL OVERHEAD MATERIAL
SOUTHERN	691832	8/24/2007 0:38	8/26/2007 21:10	4111.1	G6186	CRESTWOOD	13	PHASE WIRE (ALL VOLTAGES)	INSTALL OVERHEAD MATERIAL
NORTHERN	691066	8/24/2007 0:50	8/26/2007 7:12	3261.4	E685	ARLINGTON HEIGHTS	19	FUSE	REPLACED FUSE

REGION_NAME	OUTAGE_ID	START_DATETIME	DATETIME_RSTD	DURATION _MINUTES	AS_BUILT _FEEDER _LINE	TOWN NAME	PREM _COUNT	EQUIPMENT_INVOLVED	RESTORATION_MEDIATION
NORTHERN	691617	8/24/2007 0:50	8/26/2007 18:35	3945.1	C7221	MAINE TWP	31	FUSE	REPLACED FUSE
NORTHERN	690927	8/24/2007 0:56	8/24/2007 21:00	1204	W431	ELMHURST	2	PHASE WIRE (ALL VOLTAGES)	TREE REMOVED
SOUTHERN	691112	8/24/2007 1:36	8/26/2007 9:55	3378.2	G654	SOUTH HOLLAND	30	PHASE WIRE (ALL VOLTAGES)	TREE REMOVED
NORTHERN	690880	8/24/2007 1:37	8/26/2007 0:39	2821.3	E502	BARRINGTON HILLS	1	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHERN	690880	8/24/2007 1:37	8/26/2007 0:40	2822.3	E502	FOX RIVER GR	4	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHERN	690880	8/24/2007 1:37	8/26/2007 0:40	2822.3	E502	ALGONQUIN TWP	25	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHERN	690880	8/24/2007 1:37	8/26/2007 1:02	2844.7	E502	ALGONQUIN TWP	14	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
CHICAGO	689551	8/24/2007 1:38	8/24/2007 7:15	336.7	365Y452	WARD2	17	CABLE	TEMPORARY SWITCHING
CHICAGO	689551	8/24/2007 1:38	8/24/2007 7:43	365.6	365Y452	WARD27	2	CABLE	TEMPORARY SWITCHING
CHICAGO	689551	8/24/2007 1:38	8/24/2007 7:43	365.6	365Y452	WARD2	56	CABLE	TEMPORARY SWITCHING
CHICAGO	689551	8/24/2007 1:38	8/24/2007 8:00	381.8	365Y452	WARD2	158	CABLE	TEMPORARY SWITCHING
CHICAGO	689551	8/24/2007 1:38	8/24/2007 8:00	381.8	365Y452	WARD1	295	CABLE	TEMPORARY SWITCHING
CHICAGO	689551	8/24/2007 1:38	8/24/2007 8:00	381.8	365Y452	WARD27	18	CABLE	TEMPORARY SWITCHING
CHICAGO	689551	8/24/2007 1:38	8/24/2007 8:00	381.7	365Y452	WARD2	5	CABLE	TEMPORARY SWITCHING
CHICAGO	689551	8/24/2007 1:38	8/24/2007 8:00	381.8	365Y452	WARD26	74	CABLE	TEMPORARY SWITCHING
SOUTHERN	690205	8/24/2007 1:38	8/24/2007 11:10	571.6	F5382	UNIVERSITY PARK	8	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
SOUTHERN	690205	8/24/2007 1:38	8/24/2007 11:10	571.6	F5382	MONEE	1	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
SOUTHERN	690205	8/24/2007 1:38	8/24/2007 11:10	571.6	F5382	MONEE TWP	17	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
CHICAGO	689483	8/24/2007 1:40	8/24/2007 10:35	534.8	X5379	WARD47	423	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHERN	691409	8/24/2007 1:41	8/26/2007 15:34	3712.3	C8811	SKOKIE	36	FUSE	REPLACED FUSE
NORTHERN	691982	8/24/2007 1:42	8/24/2007 18:19	997	E5211	ARLINGTON HEIGHTS	719	PHASE WIRE (ALL VOLTAGES)	CLOSED SUBSTATION BREAKER
NORTHERN	691982	8/24/2007 1:42	8/24/2007 18:19	997	E5211	ROLLING MDWS	1	PHASE WIRE (ALL VOLTAGES)	CLOSED SUBSTATION BREAKER
NORTHERN	691982	8/24/2007 1:42	8/24/2007 18:19	997	E5211	NORTHFIELD TWP	1	PHASE WIRE (ALL VOLTAGES)	CLOSED SUBSTATION BREAKER
NORTHERN	690924	8/24/2007 1:43	8/25/2007 23:04	2720.8	W442	ELMHURST	35	CROSS-ARM	REPLACED OTHER
SOUTHERN	699312	8/24/2007 1:43	8/25/2007 17:45	2401.5	G6587	DOLTON	48	FUSE	REPLACED FUSE
NORTHERN	692293	8/24/2007 1:44	8/27/2007 11:38	4914	C564	WILMETTE	19	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
CHICAGO	691766	8/24/2007 1:45	8/26/2007 19:47	3961.9	X7150	WARD41	10	FUSE	REPLACED FUSE
NORTHERN	691434	8/24/2007 1:56	8/26/2007 15:45	3709	C1730	GLENVIEW	1	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
CHICAGO	689462	8/24/2007 1:58	8/24/2007 8:59	420.5	Z6351	WARD13	197	PHASE WIRE (ALL VOLTAGES)	REPLACED OVERHEAD MATERIAL
CHICAGO	689668	8/24/2007 1:58	8/24/2007 15:26	807.9	Z4145	WARD34	98	FUSE	REPLACED FUSE
SOUTHERN	689965	8/24/2007 1:59	8/24/2007 12:45	645.5	J765	MARSEILLES	27	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE
SOUTHERN	689965	8/24/2007 1:59	8/24/2007 12:45	645.5	J765	BROOKFIELD TWP	246	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE
SOUTHERN	689965	8/24/2007 1:59	8/24/2007 12:45	645.5	J765	SENECA	33	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE
SOUTHERN	689965	8/24/2007 1:59	8/24/2007 12:45	645.5	J765	MANLIUS TWP	5	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE
NORTHERN	690801	8/24/2007 1:59	8/25/2007 22:00	2640.3	318X443	OAK PARK	36	PHASE WIRE (ALL VOLTAGES)	INSTALL OVERHEAD MATERIAL
SOUTHERN	689463	8/24/2007 2:00	8/24/2007 9:07	427	G6588	DOLTON	1	PHASE WIRE (ALL VOLTAGES)	TEMPORARY SWITCHING
SOUTHERN	689463	8/24/2007 2:00	8/24/2007 9:07	427	G6588	CALUMET CITY	1766	PHASE WIRE (ALL VOLTAGES)	TEMPORARY SWITCHING
SOUTHERN	690590	8/24/2007 2:00	8/25/2007 18:23	2422.9	G612	ROBBINS	19	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
SOUTHERN	691350	8/24/2007 2:07	8/26/2007 9:14	3306.4	J4403	CHANNAHON	1	PHASE WIRE (ALL VOLTAGES)	DISCONNECT OVERHEAD MATERIAL
NORTHERN	690677	8/24/2007 2:08	8/25/2007 13:00	2091.4	C4617	MAINE TWP	1	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHERN	690677	8/24/2007 2:08	8/25/2007 13:00	2091.4	C4617	DES PLAINES	404	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
SOUTHERN	689452	8/24/2007 2:10	8/24/2007 8:30	379.9	W6128	BOLINGBROOK	122	CABLE	TEMPORARY SWITCHING
NORTHERN	695265	8/24/2007 2:10	8/24/2007 7:40	330	W5209	ADDISON	606	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHERN	695265	8/24/2007 2:10	8/24/2007 9:04	414	W5209	ADDISON	44	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHERN	695265	8/24/2007 2:10	8/24/2007 9:04	414	W5209	OAKBROOK	1	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHERN	695265	8/24/2007 2:10	8/24/2007 9:04	414	W5209	ELMHURST	216	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHERN	695265	8/24/2007 2:10	8/24/2007 9:04	414	W5209	ADDISON TWP	8	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHERN	695265	8/24/2007 2:10	8/24/2007 9:30	440	W5209	VILLA PARK	19	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL

REGION_NAME	OUTAGE_ID	START_DATETIME	DATETIME_RSTD	DURATION _MINUTES	AS_BUILT _FEEDER _LINE	TOWN NAME	PREM _COUNT	EQUIPMENT_INVOLVED	RESTORATION_MEDIATION
NORTHERN	695265	8/24/2007 2:10	8/24/2007 9:30	440	W5209	ADDISON TWP	26	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHERN	695265	8/24/2007 2:10	8/24/2007 9:30	440	W5209	ELMHURST	745	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHERN	695265	8/24/2007 2:10	8/24/2007 9:30	440	W5209	ADDISON	493	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHERN	695265	8/24/2007 2:10	8/24/2007 11:25	555	W5209	VILLA PARK	49	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHERN	695265	8/24/2007 2:10	8/24/2007 11:25	555	W5209	ADDISON	14	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHERN	695265	8/24/2007 2:10	8/24/2007 11:25	555	W5209	ADDISON TWP	10	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHERN	695265	8/24/2007 2:10	8/24/2007 15:00	770	W5209	VILLA PARK	1	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHERN	695265	8/24/2007 2:10	8/24/2007 15:00	770	W5209	ADDISON TWP	84	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHERN	695265	8/24/2007 2:10	8/24/2007 15:00	770	W5209	LOMBARD	5	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHERN	695265	8/24/2007 2:10	8/24/2007 19:00	1010	W5209	YORK TWP	42	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHERN	695265	8/24/2007 2:10	8/24/2007 19:00	1010	W5209	ADDISON TWP	3	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHERN	695265	8/24/2007 2:10	8/24/2007 19:00	1010	W5209	VILLA PARK	467	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHERN	689995	8/24/2007 2:11	8/24/2007 20:00	1069	D31	FOREST PARK	5	PHASE WIRE (ALL VOLTAGES)	CLOSED SUBSTATION BREAKER
NORTHERN	689995	8/24/2007 2:11	8/24/2007 20:00	1069	D31	RIVER FOREST	228	PHASE WIRE (ALL VOLTAGES)	CLOSED SUBSTATION BREAKER
NORTHWEST	689441	8/24/2007 2:14	8/24/2007 6:30	255.1	H1702	NELSON-PALMYRA TWP	14	ARRESTER-PORCELAIN	DISCONNECT OVERHEAD MATERIAL
NORTHERN	690684	8/24/2007 2:14	8/25/2007 20:18	2523.2	D134	CICERO	1	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
SOUTHERN	691777	8/24/2007 2:14	8/24/2007 6:28	254.2	G7683	CALUMET PARK	1	PHASE WIRE (ALL VOLTAGES)	TEMPORARY SWITCHING
SOUTHERN	691777	8/24/2007 2:14	8/24/2007 6:28	254.2	G7683	RIVERDALE	5	PHASE WIRE (ALL VOLTAGES)	TEMPORARY SWITCHING
SOUTHERN	691777	8/24/2007 2:14	8/24/2007 6:28	254.2	G7683	THORNTON TWP	2	PHASE WIRE (ALL VOLTAGES)	TEMPORARY SWITCHING
SOUTHERN	691777	8/24/2007 2:14	8/24/2007 7:30	316	G7683	RIVERDALE	18	PHASE WIRE (ALL VOLTAGES)	TEMPORARY SWITCHING
SOUTHERN	691777	8/24/2007 2:14	8/24/2007 7:30	316	G7683	CALUMET PARK	2	PHASE WIRE (ALL VOLTAGES)	TEMPORARY SWITCHING
SOUTHERN	691777	8/24/2007 2:14	8/24/2007 7:30	316	G7683	BLUE ISLAND	16	PHASE WIRE (ALL VOLTAGES)	TEMPORARY SWITCHING
SOUTHERN	691777	8/24/2007 2:14	8/24/2007 9:10	416	G7683	BLUE ISLAND	4	PHASE WIRE (ALL VOLTAGES)	TEMPORARY SWITCHING
SOUTHERN	691777	8/24/2007 2:14	8/24/2007 9:10	416	G7683	CALUMET PARK	321	PHASE WIRE (ALL VOLTAGES)	TEMPORARY SWITCHING
SOUTHERN	691777	8/24/2007 2:14	8/24/2007 9:19	425	G7683	CALUMET PARK	620	PHASE WIRE (ALL VOLTAGES)	TEMPORARY SWITCHING
SOUTHERN	691777	8/24/2007 2:14	8/24/2007 9:19	425	G7683	BLUE ISLAND	3	PHASE WIRE (ALL VOLTAGES)	TEMPORARY SWITCHING
SOUTHERN	691777	8/24/2007 2:14	8/24/2007 10:22	488	G7683	CALUMET PARK	547	PHASE WIRE (ALL VOLTAGES)	TEMPORARY SWITCHING
SOUTHERN	691777	8/24/2007 2:14	8/26/2007 11:46	3452	G7683	CALUMET PARK	48	PHASE WIRE (ALL VOLTAGES)	TEMPORARY SWITCHING
SOUTHERN	691777	8/24/2007 2:14	8/26/2007 13:05	3531	G7683	CALUMET PARK	22	PHASE WIRE (ALL VOLTAGES)	TEMPORARY SWITCHING
SOUTHERN	689773	8/24/2007 2:15	8/24/2007 4:26	131	G651	RIVERDALE	459	PHASE WIRE (ALL VOLTAGES)	TEMPORARY SWITCHING
SOUTHERN	689773	8/24/2007 2:15	8/24/2007 16:12	837	G651	RIVERDALE	656	PHASE WIRE (ALL VOLTAGES)	TEMPORARY SWITCHING
SOUTHERN	691444	8/24/2007 2:17	8/26/2007 16:04	3706.3	F492	BLOOM TWP	1	PHASE WIRE (ALL VOLTAGES)	REPLACED OVERHEAD MATERIAL
SOUTHERN	690562	8/24/2007 2:19	8/25/2007 17:44	2364.8	G6591	SOUTH HOLLAND	30	FUSE	REPLACED CUTOUT
NORTHERN	691810	8/24/2007 2:19	8/25/2007 21:08	2568.2	C132	NORTHBROOK	12	PHASE WIRE (ALL VOLTAGES)	TREE REMOVED
SOUTHERN	689519	8/24/2007 2:20	8/24/2007 11:32	551.1	F522	CHICAGO HEIGHTS	145	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
SOUTHERN	689519	8/24/2007 2:20	8/24/2007 11:32	551.1	F522	FLOSSMOOR	70	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHERN	691816	8/24/2007 2:20	8/26/2007 16:45	3744.2	E024	PALATINE	46	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHERN	691816	8/24/2007 2:20	8/26/2007 16:45	3744.2	E024	PALATINE TWP	9	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
SOUTHERN	691845	8/24/2007 2:21	8/24/2007 17:00	878.7	G6075	ALSIP	35	CABLE	TEMPORARY SWITCHING
SOUTHERN	691845	8/24/2007 2:21	8/26/2007 12:40	3498.7	G6075	ALSIP	6	CABLE	TEMPORARY SWITCHING
SOUTHERN	691845	8/24/2007 2:21	8/26/2007 13:10	3528.7	G6075	ALSIP	29	CABLE	TEMPORARY SWITCHING
SOUTHERN	691845	8/24/2007 2:21	8/26/2007 17:00	3758.7	G6075	ALSIP	6	CABLE	TEMPORARY SWITCHING
NORTHERN	691059	8/24/2007 2:22	8/26/2007 7:00	3158	E688	ARLINGTON HEIGHTS	37	FUSE	REPLACED FUSE
SOUTHERN	689447	8/24/2007 2:23	8/24/2007 4:50	146.4	S675	MAZON TWP	18	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE
SOUTHERN	691321	8/24/2007 2:23	8/26/2007 13:20	3537	G4072	PALOS PARK	4	PHASE WIRE (ALL VOLTAGES)	REPAIRED EQUIPMENT
NORTHERN	692202	8/24/2007 2:23	8/27/2007 10:01	4777.5	C1730	GLENVIEW	41	FUSE	REPAIRED OVERHEAD MATERIAL
CHICAGO	690560	8/24/2007 2:24	8/25/2007 13:15	2090.1	032X041	WARD29	80	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE
SOUTHERN	691559	8/24/2007 2:24	8/26/2007 16:45	3740.7	G617	ALSIP	42	CABLE	TEMPORARY JUMPER TO RESTORE

REGION_NAME	OUTAGE_ID	START_DATETIME	DATETIME_RSTD	DURATION_MINUTES	AS_BUILT_FEEDER_LINE	TOWN NAME	PREM_COUNT	EQUIPMENT_INVOLVED	RESTORATION_MEDIATION
SOUTHERN	689920	8/24/2007 2:25	8/24/2007 6:40	254.6	D3427	LYONS TWP	1	FUSE	REPLACED FUSE
SOUTHERN	689920	8/24/2007 2:25	8/24/2007 6:40	254.6	D3427	WESTERN SPRINGS	86	FUSE	REPLACED FUSE
NORTHERN	690305	8/24/2007 2:28	8/25/2007 10:30	1921.9	C1511	DES PLAINES	1	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
CHICAGO	689648	8/24/2007 2:33	8/24/2007 14:18	705	Z15058	WARD7	62	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE
SOUTHERN	690287	8/24/2007 2:35	8/25/2007 9:40	1865	J885	JOLIET	26	FUSE	REPLACED FUSE
NORTHERN	690672	8/24/2007 2:37	8/25/2007 20:00	2483	Y3079	OAK PARK	1	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
CHICAGO	690015	8/24/2007 2:39	8/24/2007 11:50	551	DRXL042	WARD6	391	CABLE-AERIAL	REPAIRED OVERHEAD MATERIAL
NORTHWEST	689383	8/24/2007 2:40	8/24/2007 3:50	69.3	B8304Y	CORTLAND TWP	2	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE
NORTHWEST	689383	8/24/2007 2:40	8/24/2007 3:50	69.3	B8304Y	CORTLAND	168	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE
NORTHWEST	689486	8/24/2007 2:41	8/24/2007 10:00	438.5	H496	ASHTON	7	TRANSFORMER-OVHD	REPLACED TRANSFORMER
CHICAGO	689872	8/24/2007 2:41	8/24/2007 19:20	998	X3933	WARD45	1012	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE
SOUTHERN	691756	8/24/2007 2:41	8/26/2007 19:20	3878.8	G6093	WORTH	1	CABLE-AERIAL	REPAIRED OVERHEAD MATERIAL
NORTHERN	690230	8/24/2007 2:42	8/24/2007 3:25	42.6	C527	MORTON GROVE	51	SUBSTATION BREAKER	TEMPORARY SWITCHING
NORTHERN	690402	8/24/2007 2:42	8/25/2007 13:49	2106.8	E3311	BARRINGTON	45	FUSE	REPLACED FUSE
NORTHERN	691707	8/24/2007 2:42	8/26/2007 15:00	3617.6	C1736	MOUNT PROSPECT	64	PHASE WIRE (ALL VOLTAGES)	CLOSED FUSE
CHICAGO	690385	8/24/2007 2:43	8/25/2007 10:00	1876.9	X3747	WARD36	115	PHASE WIRE (ALL VOLTAGES)	TREE REMOVED
CHICAGO	692033	8/24/2007 2:43	8/24/2007 10:45	481.4	Z10442	WARD13	40	PHASE WIRE (ALL VOLTAGES)	REPLACED OVERHEAD MATERIAL
NORTHERN	689830	8/24/2007 2:44	8/24/2007 18:48	963.9	D46	OAK PARK	13	PHASE WIRE (ALL VOLTAGES)	INSTALL OVERHEAD MATERIAL
NORTHERN	691286	8/24/2007 2:44	8/26/2007 13:55	3550.7	C584	NORTHFIELD	138	FUSE	REPLACED FUSE
NORTHWEST	690079	8/24/2007 2:45	8/24/2007 11:00	494.4	W7020	ELGIN	50	TRANSFORMER-OVHD	TEMPORARY SWITCHING
CHICAGO	690017	8/24/2007 2:46	8/24/2007 23:23	1236.5	WNPK41	WARD8	48	TRANSFORMER-OVHD	REPLACED TRANSFORMER
SOUTHERN	689513	8/24/2007 2:47	8/24/2007 11:05	497.8	G144	PALOS HILLS	26	CUTOUT	CLOSED FUSE
NORTHERN	692042	8/24/2007 2:47	8/26/2007 10:36	3348.8	D308	OAK PARK	13	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
SOUTHERN	689586	8/24/2007 2:48	8/24/2007 12:30	581.9	J7481	MANHATTAN TWP	17	FUSE	REPLACED FUSE
SOUTHERN	689586	8/24/2007 2:48	8/24/2007 12:30	581.9	J7481	NEW LENOX TWP	60	FUSE	REPLACED FUSE
SOUTHERN	689586	8/24/2007 2:48	8/24/2007 12:30	581.9	J7481	NEW LENOX	99	FUSE	REPLACED FUSE
SOUTHERN	690407	8/24/2007 2:48	8/24/2007 6:07	199	J697	REED TWP	12	PHASE WIRE (ALL VOLTAGES)	TEMPORARY SWITCHING
SOUTHERN	690407	8/24/2007 2:48	8/24/2007 6:07	199	J697	ESSEX	1	PHASE WIRE (ALL VOLTAGES)	TEMPORARY SWITCHING
SOUTHERN	690407	8/24/2007 2:48	8/24/2007 6:07	199	J697	CUSTER TWP	493	PHASE WIRE (ALL VOLTAGES)	TEMPORARY SWITCHING
SOUTHERN	690407	8/24/2007 2:48	8/24/2007 6:07	199	J697	WESLEY TWP	6	PHASE WIRE (ALL VOLTAGES)	TEMPORARY SWITCHING
SOUTHERN	690407	8/24/2007 2:48	8/24/2007 6:07	199	J697	MORRIS	1	PHASE WIRE (ALL VOLTAGES)	TEMPORARY SWITCHING
SOUTHERN	690407	8/24/2007 2:48	8/24/2007 6:07	199	J697	ESSEX TWP	9	PHASE WIRE (ALL VOLTAGES)	TEMPORARY SWITCHING
SOUTHERN	690407	8/24/2007 2:48	8/24/2007 6:07	199	J697	BRAIDWOOD	659	PHASE WIRE (ALL VOLTAGES)	TEMPORARY SWITCHING
SOUTHERN	690407	8/24/2007 2:48	8/24/2007 6:07	199	J697	SALINA TWP	3	PHASE WIRE (ALL VOLTAGES)	TEMPORARY SWITCHING
SOUTHERN	690407	8/24/2007 2:48	8/24/2007 6:07	199	J697	WILMINGTON	2	PHASE WIRE (ALL VOLTAGES)	TEMPORARY SWITCHING
SOUTHERN	690407	8/24/2007 2:48	8/24/2007 6:07	199	J697	CUSTER PARK	61	PHASE WIRE (ALL VOLTAGES)	TEMPORARY SWITCHING
SOUTHERN	690407	8/24/2007 2:48	8/24/2007 6:07	199	J697	DIAMOND	1	PHASE WIRE (ALL VOLTAGES)	TEMPORARY SWITCHING
SOUTHERN	690407	8/24/2007 2:48	8/24/2007 20:30	1062	J697	CUSTER TWP	58	PHASE WIRE (ALL VOLTAGES)	TEMPORARY SWITCHING
SOUTHERN	690407	8/24/2007 2:48	8/25/2007 13:45	2097	J697	CUSTER TWP	1	PHASE WIRE (ALL VOLTAGES)	TEMPORARY SWITCHING
CHICAGO	689674	8/24/2007 2:49	8/24/2007 15:40	770.4	X3731	WARD36	21	FUSE	REPLACED FUSE
NORTHERN	691534	8/24/2007 2:49	8/25/2007 18:58	2409	C4615	DES PLAINES	82	FUSE	REPLACED FUSE
CHICAGO	690157	8/24/2007 2:50	8/25/2007 3:40	1489.8	X3932	WARD31	189	FUSE	REPLACED FUSE
CHICAGO	689986	8/24/2007 2:52	8/24/2007 18:02	910	Z4332	WARD9	15	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHERN	690915	8/24/2007 2:54	8/26/2007 2:10	2835.3	E501	BARRINGTON HILLS	4	FUSE	REPLACED FUSE
NORTHERN	690925	8/24/2007 2:54	8/24/2007 2:58	4	W3521	ELMHURST	76	PHASE WIRE (ALL VOLTAGES)	TEMPORARY SWITCHING
NORTHERN	690925	8/24/2007 2:54	8/26/2007 1:15	2781.3	W3521	ELMHURST	78	PHASE WIRE (ALL VOLTAGES)	TEMPORARY SWITCHING
NORTHERN	692472	8/24/2007 2:54	8/27/2007 14:30	5015.3	W7406Y	ROSELLE	4	TRANSFORMER-OVHD	REPLACED TRANSFORMER
NORTHERN	690296	8/24/2007 2:55	8/24/2007 21:00	1084.2	C835	EVANSTON	137	CROSS-ARM	REPAIRED EQUIPMENT

REGION_NAME	OUTAGE_ID	START_DATETIME	DATETIME_RSTD	DURATION _MINUTES	AS_BUILT _FEEDER _LINE	TOWN NAME	PREM _COUNT	EQUIPMENT_INVOLVED	RESTORATION_MEDIATION
NORTHERN	690296	8/24/2007 2:55	8/24/2007 21:00	1084.2	C835	WILMETTE	111	CROSS-ARM	REPAIRED EQUIPMENT
SOUTHERN	689800	8/24/2007 2:58	8/24/2007 18:00	901.7	G6074	OAK LAWN	74	FUSE	REPLACED FUSE
NORTHERN	690641	8/24/2007 2:58	8/25/2007 18:54	2396.2	C4616	PARK RIDGE	35	ALLEY-ARM	REPLACED OVERHEAD MATERIAL
SOUTHERN	691166	8/24/2007 2:58	8/26/2007 11:00	3361.6	K155	ROCKVILLE TWP	1	TRANSFORMER-OVHD	REPLACED TRANSFORMER
CHICAGO	689387	8/24/2007 2:59	8/24/2007 3:55	55.8	JUST044	WARD21	305	SUBSTATION BREAKER	REPAIRED OVERHEAD MATERIAL
CHICAGO	689387	8/24/2007 2:59	8/24/2007 4:18	78.5	JUST044	WARD21	173	SUBSTATION BREAKER	REPAIRED OVERHEAD MATERIAL
CHICAGO	690351	8/24/2007 2:59	8/24/2007 7:06	246.3	G6976	WARD18	674	PHASE WIRE (ALL VOLTAGES)	TEMPORARY SWITCHING
SOUTHERN	690351	8/24/2007 2:59	8/24/2007 7:06	246.3	G6976	HOMETOWN	84	PHASE WIRE (ALL VOLTAGES)	TEMPORARY SWITCHING
SOUTHERN	690351	8/24/2007 2:59	8/24/2007 7:06	246.3	G6976	EVERGREEN PARK	1	PHASE WIRE (ALL VOLTAGES)	TEMPORARY SWITCHING
SOUTHERN	690351	8/24/2007 2:59	8/24/2007 7:10	250.3	G6976	WORTH TWP	3	PHASE WIRE (ALL VOLTAGES)	TEMPORARY SWITCHING
SOUTHERN	690351	8/24/2007 2:59	8/24/2007 7:10	250.3	G6976	HOMETOWN	1372	PHASE WIRE (ALL VOLTAGES)	TEMPORARY SWITCHING
SOUTHERN	690351	8/24/2007 2:59	8/24/2007 7:10	250.3	G6976	OAK LAWN	243	PHASE WIRE (ALL VOLTAGES)	TEMPORARY SWITCHING
SOUTHERN	690351	8/24/2007 2:59	8/25/2007 12:06	1986.3	G6976	HOMETOWN	200	PHASE WIRE (ALL VOLTAGES)	TEMPORARY SWITCHING
SOUTHERN	690351	8/24/2007 2:59	8/25/2007 12:06	1986.3	G6976	CRESTWOOD	1	PHASE WIRE (ALL VOLTAGES)	TEMPORARY SWITCHING
NORTHERN	691103	8/24/2007 2:59	8/26/2007 10:04	3304.4	C661	EVANSTON	55	FUSE	CLOSED FUSE
NORTHERN	691247	8/24/2007 2:59	8/26/2007 12:20	3440.3	W2025	MILTON TWP	2	FUSE	REPLACED FUSE
NORTHERN	691673	8/24/2007 3:00	8/25/2007 9:40	1840.4	E5214	ARLINGTON HEIGHTS	56	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHERN	691673	8/24/2007 3:00	8/26/2007 19:16	3855.9	E5214	ARLINGTON HEIGHTS	71	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
SOUTHERN	689480	8/24/2007 3:01	8/24/2007 10:05	423.4	K197	MANTENO	78	PHASE WIRE (ALL VOLTAGES)	REPLACED CUTOUT
SOUTHERN	690118	8/24/2007 3:01	8/25/2007 2:00	1378.5	J686	COAL CITY	66	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE
SOUTHERN	691095	8/24/2007 3:01	8/26/2007 9:15	3253.8	G7683	HARVEY	30	FUSE	REPLACED FUSE
CHICAGO	689742	8/24/2007 3:02	8/24/2007 16:57	834	X7140	WARD41	19	FUSE	REPLACED FUSE
SOUTHERN	690203	8/24/2007 3:03	8/24/2007 13:45	641.6	F225	CALUMET CITY	1	CABLE	TEMPORARY SWITCHING
SOUTHERN	690203	8/24/2007 3:03	8/24/2007 13:45	641.6	F225	CHICAGO HEIGHTS	244	CABLE	TEMPORARY SWITCHING
CHICAGO	690018	8/24/2007 3:04	8/24/2007 23:20	1215.8	Y3851	WARD27	209	FUSE	REPLACED FUSE
NORTHERN	692126	8/24/2007 3:04	8/27/2007 5:56	4491	E0612	SCHAUMBURG	1	CABLE	REPAIRED UNDERGROUND MATERIAL
NORTHERN	692126	8/24/2007 3:04	8/27/2007 5:56	4491	E0612	ELK GROVE VIL	74	CABLE	REPAIRED UNDERGROUND MATERIAL
CHICAGO	690133	8/24/2007 3:05	8/25/2007 2:50	1424.8	X8454	WARD47	602	FUSE	REPLACED FUSE
SOUTHERN	690422	8/24/2007 3:05	8/25/2007 14:00	2094.8	F577	STEGER	85	CROSS-ARM	REPAIRED OVERHEAD MATERIAL
SOUTHERN	690422	8/24/2007 3:05	8/25/2007 14:00	2094.8	F577	SO CHICAGO HEIGHTS	31	CROSS-ARM	REPAIRED OVERHEAD MATERIAL
NORTHERN	691918	8/24/2007 3:05	8/26/2007 14:00	3534.9	C7215	GLENVIEW	3	FUSE	REPLACED FUSE
NORTHERN	691918	8/24/2007 3:05	8/26/2007 14:00	3534.9	C7215	NORTHFIELD TWP	5	FUSE	REPLACED FUSE
CHICAGO	689555	8/24/2007 3:06	8/24/2007 12:15	548.3	Y3040	WARD22	233	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
CHICAGO	689419	8/24/2007 3:08	8/24/2007 6:18	189.4	Z11869	WARD21	238	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE
SOUTHERN	689476	8/24/2007 3:08	8/24/2007 9:40	391.6	W6120	BOLINGBROOK	38	FUSE	REPLACED FUSE
NORTHWEST	689557	8/24/2007 3:08	8/24/2007 11:42	513.3	W7013	ELGIN	71	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE
CHICAGO	689469	8/24/2007 3:10	8/24/2007 9:44	393.3	Z11870	WARD21	92	PHASE WIRE (ALL VOLTAGES)	REPLACED OVERHEAD MATERIAL
NORTHWEST	690090	8/24/2007 3:10	8/25/2007 1:05	1315	W185	KENDALL TWP	2	PHASE WIRE (ALL VOLTAGES)	TREE TRIMMED
SOUTHERN	689474	8/24/2007 3:11	8/24/2007 9:00	348.6	K395	ST ANNE TWP	11	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE
SOUTHERN	689474	8/24/2007 3:11	8/24/2007 9:00	348.6	K395	SUN RIVER TERRACE	30	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE
SOUTHERN	689474	8/24/2007 3:11	8/24/2007 9:00	348.6	K395	GANEER TWP	131	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE
SOUTHERN	689474	8/24/2007 3:11	8/24/2007 9:00	348.6	K395	ST ANNE	3	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE
SOUTHERN	689474	8/24/2007 3:11	8/24/2007 9:00	348.6	K395	BOURBONNAIS TWP	7	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE
SOUTHERN	689474	8/24/2007 3:11	8/24/2007 9:00	348.6	K395	AROMA TWP	242	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE
SOUTHERN	689474	8/24/2007 3:11	8/24/2007 9:00	348.6	K395	KANKAKEE	1	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE
SOUTHERN	689474	8/24/2007 3:11	8/24/2007 9:00	348.6	K395	KANKAKEE TWP	7	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE
SOUTHERN	689474	8/24/2007 3:11	8/24/2007 10:05	413.6	K395	AROMA TWP	5	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE
SOUTHERN	689474	8/24/2007 3:11	8/24/2007 10:05	413.6	K395	KANKAKEE TWP	107	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE

REGION_NAME	OUTAGE_ID	START_DATETIME	DATETIME_RSTD	DURATION _MINUTES	AS_BUILT _FEEDER _LINE	TOWN NAME	PREM _COUNT	EQUIPMENT_INVOLVED	RESTORATION_MEDIATION
SOUTHERN	690636	8/24/2007 3:13	8/25/2007 18:00	2326.5	J0623	NEW LENOX	38	FUSE	REPLACED FUSE
SOUTHERN	690636	8/24/2007 3:13	8/25/2007 18:00	2326.5	J0623	NEW LENOX TWP	4	FUSE	REPLACED FUSE
SOUTHERN	689405	8/24/2007 3:14	8/24/2007 5:45	150.2	K7082	BOURBONNAIS TWP	19	CUTOUT	REPLACED CUTOUT
NORTHERN	692587	8/24/2007 3:15	8/27/2007 15:45	5070	W0105	ADDISON TWP	1	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE
NORTHERN	692587	8/24/2007 3:15	8/27/2007 15:45	5070	W0105	WOOD DALE	12	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE
CHICAGO	690389	8/24/2007 3:16	8/24/2007 6:30	193.1	X4855	WARD36	1576	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHERN	690389	8/24/2007 3:16	8/24/2007 6:30	193.1	X4855	ELMWOOD PARK	412	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHERN	690389	8/24/2007 3:16	8/24/2007 6:30	193.1	X4855	RIVER GROVE	3	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHERN	691763	8/24/2007 3:16	8/26/2007 19:30	3853.2	E0220	PALATINE TWP	13	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
SOUTHERN	690510	8/24/2007 3:20	8/25/2007 16:05	2204.2	G4384	THORNTON	29	FUSE	REPLACED FUSE
SOUTHERN	690646	8/24/2007 3:20	8/25/2007 18:00	2319.9	F295	PARK FOREST	36	FUSE	REPAIRED OVERHEAD MATERIAL
CHICAGO	689942	8/24/2007 3:23	8/24/2007 13:00	577	Z4342	WARD34	31	TRANSFORMER-OVHD	REPLACED FUSE
NORTHERN	691960	8/24/2007 3:23	8/26/2007 18:30	3786.2	C461	MAINE TWP	114	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
SOUTHERN	691406	8/24/2007 3:31	8/26/2007 14:35	3543.9	J4085	FRANKFORT	8	TRANSFORMER-OVHD	REPLACED TRANSFORMER
CHICAGO	692037	8/24/2007 3:31	8/24/2007 3:55	23.6	JUST043	WARD21	675	SUBSTATION BREAKER	REPAIRED EQUIPMENT
CHICAGO	692037	8/24/2007 3:31	8/24/2007 3:55	23.6	JUST043	WARD18	466	SUBSTATION BREAKER	REPAIRED EQUIPMENT
SOUTHERN	689449	8/24/2007 3:46	8/24/2007 8:20	273.2	W034	LISLE	14	FUSE	REPLACED FUSE
SOUTHERN	689449	8/24/2007 3:46	8/24/2007 8:20	273.2	W034	LISLE TWP	143	FUSE	REPLACED FUSE
NORTHERN	695356	8/24/2007 3:55	8/24/2007 3:57	2	D7901	WARD41	3	SUBSTATION BREAKER	CLOSED SUBSTATION BREAKER
SOUTHERN	690460	8/24/2007 3:57	8/25/2007 15:00	2102.1	F528	FORD HEIGHTS	41	PHASE WIRE (ALL VOLTAGES)	REPLACED OVERHEAD MATERIAL
SOUTHERN	689402	8/24/2007 4:09	8/24/2007 4:49	39.7	D162	LYONS TWP	9	FUSE	REPLACED FUSE
NORTHWEST	689410	8/24/2007 4:12	8/24/2007 5:26	73.6	B951	DEKALB	362	ARRESTER-POLYMER	DISCONNECT OVERHEAD MATERIAL
NORTHWEST	689410	8/24/2007 4:12	8/24/2007 5:26	73.6	B951	DEKALB TWP	78	ARRESTER-POLYMER	DISCONNECT OVERHEAD MATERIAL
NORTHWEST	689410	8/24/2007 4:12	8/24/2007 5:26	73.6	B951	AFTON TWP	64	ARRESTER-POLYMER	DISCONNECT OVERHEAD MATERIAL
NORTHWEST	689574	8/24/2007 4:12	8/24/2007 10:35	382.8	W9202	OSWEGO TWP	533	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHWEST	689574	8/24/2007 4:12	8/24/2007 10:35	382.8	W9202	MONTGOMERY	4	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
SOUTHERN	690012	8/24/2007 4:12	8/24/2007 11:33	440.6	G6585	PHOENIX	95	FUSE	REPLACED FUSE
SOUTHERN	690420	8/24/2007 4:12	8/25/2007 14:26	2053.2	J4082	FRANKFORT TWP	1	FUSE	REPLACED FUSE
NORTHERN	691631	8/24/2007 4:12	8/26/2007 18:15	3722.9	C725	NILES	178	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHERN	691631	8/24/2007 4:12	8/26/2007 18:15	3722.9	C725	GLENVIEW	305	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHERN	691631	8/24/2007 4:12	8/26/2007 18:15	3722.9	C725	MORTON GROVE	6	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHERN	691631	8/24/2007 4:12	8/26/2007 18:15	3722.9	C725	MAINE TWP	661	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
CHICAGO	691631	8/24/2007 4:12	8/26/2007 18:15	3722.9	C725	WARD	9	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHWEST	689882	8/24/2007 4:13	8/24/2007 13:15	542	W9202	OSWEGO TWP	22	CABLE	TEMPORARY SWITCHING
NORTHWEST	689882	8/24/2007 4:13	8/24/2007 14:05	592	W9202	OSWEGO TWP	26	CABLE	TEMPORARY SWITCHING
SOUTHERN	690405	8/24/2007 4:13	8/25/2007 12:15	1921.7	G4074	ORLAND PARK	32	CABLE	TEMPORARY SWITCHING
SOUTHERN	690405	8/24/2007 4:13	8/25/2007 12:40	1946.7	G4074	PALOS TWP	1	CABLE	TEMPORARY SWITCHING
SOUTHERN	690405	8/24/2007 4:13	8/25/2007 12:40	1946.7	G4074	ORLAND PARK	54	CABLE	TEMPORARY SWITCHING
SOUTHERN	691788	8/24/2007 4:13	8/26/2007 20:45	3871.2	G145	HICKORY HILLS	10	TRANSFORMER-OVHD	REPLACED TRANSFORMER
SOUTHERN	691924	8/24/2007 4:15	8/26/2007 17:00	3644.3	F575	CHICAGO HEIGHTS	55	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
SOUTHERN	689470	8/24/2007 4:16	8/24/2007 9:45	328.7	W0303	LISLE TWP	1	TAP WIRE	REPAIRED OVERHEAD MATERIAL
SOUTHERN	689470	8/24/2007 4:16	8/24/2007 9:45	328.7	W0303	LISLE	227	TAP WIRE	REPAIRED OVERHEAD MATERIAL
NORTHWEST	689517	8/24/2007 4:16	8/24/2007 5:30	73.3	B116	POPLAR GROVE	3	BUSHING-PRIMARY	REPLACED UNDERGROUND MATERIAL
NORTHWEST	689517	8/24/2007 4:16	8/24/2007 5:30	73.3	B116	CALEDONIA-P GROVE	114	BUSHING-PRIMARY	REPLACED UNDERGROUND MATERIAL
NORTHWEST	689517	8/24/2007 4:16	8/24/2007 5:45	88.3	B116	CALEDONIA-P GROVE	3	BUSHING-PRIMARY	REPLACED UNDERGROUND MATERIAL
NORTHWEST	689517	8/24/2007 4:16	8/24/2007 11:00	403.3	B116	CALEDONIA-P GROVE	2	BUSHING-PRIMARY	REPLACED UNDERGROUND MATERIAL
NORTHWEST	689675	8/24/2007 4:16	8/24/2007 15:35	678.6	W6310	STREAMWOOD	51	PHASE WIRE (ALL VOLTAGES)	TREE REMOVED
CHICAGO	689824	8/24/2007 4:17	8/24/2007 18:11	833.5	Z8934	WARD34	24	NEUTRAL WIRE	REPLACED FUSE

REGION_NAME	OUTAGE_ID	START_DATETIME	DATETIME_RSTD	DURATION_MINUTES	AS_BUILT_FEEDER	TOWN NAME	PREM_COUNT	EQUIPMENT_INVOLVED	RESTORATION_MEDIATION
SOUTHERN	689905	8/24/2007 4:17	8/24/2007 10:30	373	J765	NORMAN TWP	2	FUSE	REPLACED FUSE
SOUTHERN	689905	8/24/2007 4:17	8/24/2007 10:30	373	J765	VIENNA TWP	19	FUSE	REPLACED FUSE
SOUTHERN	689857	8/24/2007 4:18	8/24/2007 18:15	836.4	J3691	JOLIET	24	FUSE	REPLACED FUSE
CHICAGO	690152	8/24/2007 4:18	8/24/2007 22:32	1094.5	691X547	WARD1	79	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
CHICAGO	690152	8/24/2007 4:18	8/24/2007 22:32	1094.5	691X547	WARD32	205	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
CHICAGO	690152	8/24/2007 4:18	8/24/2007 23:20	1142.4	691X547	WARD32	316	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
CHICAGO	690152	8/24/2007 4:18	8/24/2007 23:20	1142.4	691X547	WARD1	179	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
SOUTHERN	690515	8/24/2007 4:18	8/25/2007 16:22	2163.8	J3685	JOLIET	61	FUSE	REPLACED FUSE
NORTHERN	690932	8/24/2007 4:18	8/26/2007 0:48	2669.5	C554	PARK RIDGE	14	FUSE	REPLACED FUSE
NORTHWEST	689428	8/24/2007 4:19	8/24/2007 7:10	170.4	H535	SOMO-SAND TWP	12	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE
SOUTHERN	689561	8/24/2007 4:19	8/24/2007 10:30	370.8	G56	PHOENIX	139	FUSE	REPLACED FUSE
NORTHERN	690718	8/24/2007 4:19	8/25/2007 20:00	2380.1	D128	CICERO	27	TRANSFORMER-OVHD	REPLACED TRANSFORMER
CHICAGO	689623	8/24/2007 4:20	8/24/2007 13:30	550	Y2532	WARD11	7	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE
SOUTHERN	691497	8/24/2007 4:22	8/26/2007 16:00	3577.9	G428	WORTH TWP	6	TRANSFORMER-OVHD	REPLACED TRANSFORMER
SOUTHERN	691497	8/24/2007 4:22	8/26/2007 16:00	3577.9	G428	OAK LAWN	9	TRANSFORMER-OVHD	REPLACED TRANSFORMER
NORTHERN	690408	8/24/2007 4:23	8/25/2007 14:01	2017.7	C7212	PARK RIDGE	51	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
SOUTHERN	690766	8/24/2007 4:23	8/25/2007 18:00	2256.1	G284	MARKHAM	22	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
SOUTHERN	689399	8/24/2007 4:25	8/24/2007 5:35	70	J3679	CRESTHILL	500	SUBSTATION BREAKER	CLOSED SUBSTATION BREAKER
SOUTHERN	689399	8/24/2007 4:25	8/24/2007 5:35	70	J3679	LOCKPORT	3	SUBSTATION BREAKER	CLOSED SUBSTATION BREAKER
SOUTHERN	689399	8/24/2007 4:25	8/24/2007 5:35	70	J3679	LOCKPORT TWP	63	SUBSTATION BREAKER	CLOSED SUBSTATION BREAKER
SOUTHERN	689399	8/24/2007 4:25	8/24/2007 5:35	70	J3679	ROMEOVILLE	29	SUBSTATION BREAKER	CLOSED SUBSTATION BREAKER
SOUTHERN	689399	8/24/2007 4:25	8/24/2007 5:35	70	J3679	JOLIET	5	SUBSTATION BREAKER	CLOSED SUBSTATION BREAKER
SOUTHERN	689642	8/24/2007 4:25	8/24/2007 13:45	559.7	S206	WENONA	53	PHASE WIRE (ALL VOLTAGES)	CLOSED RECLOSER-LINE
SOUTHERN	689642	8/24/2007 4:25	8/24/2007 13:45	559.7	S206	GROVELAND TWP	4	PHASE WIRE (ALL VOLTAGES)	CLOSED RECLOSER-LINE
SOUTHERN	689642	8/24/2007 4:25	8/24/2007 13:45	559.7	S206	BENNINGTON TWP	9	PHASE WIRE (ALL VOLTAGES)	CLOSED RECLOSER-LINE
SOUTHERN	689642	8/24/2007 4:25	8/24/2007 13:45	559.7	S206	TOLUCA	3	PHASE WIRE (ALL VOLTAGES)	CLOSED RECLOSER-LINE
SOUTHERN	689642	8/24/2007 4:25	8/24/2007 13:45	559.7	S206	OSAGE TWP	2	PHASE WIRE (ALL VOLTAGES)	CLOSED RECLOSER-LINE
SOUTHERN	689642	8/24/2007 4:25	8/24/2007 13:45	559.7	S206	EVANS TWP	23	PHASE WIRE (ALL VOLTAGES)	CLOSED RECLOSER-LINE
SOUTHERN	689642	8/24/2007 4:25	8/24/2007 13:45	559.7	S206	RUTLAND	3	PHASE WIRE (ALL VOLTAGES)	CLOSED RECLOSER-LINE
SOUTHERN	689642	8/24/2007 4:25	8/24/2007 14:55	630.1	S206	EVANS TWP	1	PHASE WIRE (ALL VOLTAGES)	CLOSED RECLOSER-LINE
NORTHWEST	689985	8/24/2007 4:25	8/24/2007 20:10	944.5	R8883	MACHESNEY PARK	1	CABLE	TEMPORARY JUMPER TO RESTORE
NORTHERN	690573	8/24/2007 4:25	8/25/2007 17:00	2194.6	X3148	OAK PARK	50	PHASE WIRE (ALL VOLTAGES)	INSTALL OVERHEAD MATERIAL
NORTHERN	692172	8/24/2007 4:26	8/25/2007 17:22	2215.3	C801	NORTHFIELD TWP	76	FUSE	REPAIRED OVERHEAD MATERIAL
NORTHERN	692172	8/24/2007 4:26	8/25/2007 17:22	2215.3	C801	GLENVIEW	123	FUSE	REPAIRED OVERHEAD MATERIAL
NORTHERN	692172	8/24/2007 4:26	8/25/2007 20:31	2405.1	C801	MAINE TWP	1	FUSE	REPAIRED OVERHEAD MATERIAL
NORTHERN	692172	8/24/2007 4:26	8/25/2007 20:31	2405.1	C801	NORTHFIELD TWP	129	FUSE	REPAIRED OVERHEAD MATERIAL
NORTHERN	692172	8/24/2007 4:26	8/25/2007 20:31	2405.1	C801	GLENVIEW	145	FUSE	REPAIRED OVERHEAD MATERIAL
NORTHERN	692172	8/24/2007 4:26	8/26/2007 3:45	2838.3	C801	GLENVIEW	10	FUSE	REPAIRED OVERHEAD MATERIAL
NORTHERN	692172	8/24/2007 4:26	8/26/2007 3:45	2838.3	C801	NORTHFIELD TWP	9	FUSE	REPAIRED OVERHEAD MATERIAL
NORTHERN	692172	8/24/2007 4:26	8/27/2007 8:48	4581.6	C801	NORTHFIELD TWP	36	FUSE	REPAIRED OVERHEAD MATERIAL
NORTHERN	692172	8/24/2007 4:26	8/27/2007 8:48	4581.6	C801	GLENVIEW	167	FUSE	REPAIRED OVERHEAD MATERIAL
NORTHWEST	689439	8/24/2007 4:27	8/24/2007 7:05	157.9	B646	FRANKLIN GROVE	26	FUSE	REPLACED FUSE
NORTHWEST	689439	8/24/2007 4:27	8/24/2007 7:05	157.9	B646	TAYLOR-NCH-CHIN TWP	2	FUSE	REPLACED FUSE
NORTHWEST	689439	8/24/2007 4:27	8/24/2007 7:05	157.9	B646	LAFAYETTE-ASHTN TWP	2	FUSE	REPLACED FUSE
SOUTHERN	689855	8/24/2007 4:28	8/24/2007 18:45	856.8	J3691	JOLIET	33	FUSE	REPLACED FUSE
CHICAGO	690286	8/24/2007 4:28	8/24/2007 18:50	861.2	Z17439	WARD4	78	TRANSFORMER-OVHD	TEMPORARY GENERATOR
SOUTHERN	689562	8/24/2007 4:30	8/24/2007 12:35	484.2	W419	DOWNERS GROVE	40	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
SOUTHERN	689562	8/24/2007 4:30	8/24/2007 12:49	498.3	W419	DOWNERS GROVE	13	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL

REGION_NAME	OUTAGE_ID	START_DATETIME	DATETIME_RSTD	DURATION_MINUTES	AS_BUILT_FEEDER_LINE	TOWN NAME	PREM_COUNT	EQUIPMENT_INVOLVED	RESTORATION_MEDIATION
SOUTHERN	690025	8/24/2007 4:30	8/24/2007 23:07	1117	J3674	JOLIET	145	FUSE	REPLACED FUSE
SOUTHERN	690025	8/24/2007 4:30	8/24/2007 23:07	1117	J3674	CRESTHILL	1	FUSE	REPLACED FUSE
NORTHERN	691779	8/24/2007 4:30	8/26/2007 19:20	3769.3	C1212	NORTHFIELD	1	FUSE	REPLACED FUSE
NORTHERN	691779	8/24/2007 4:30	8/26/2007 19:20	3769.3	C1212	GLENVIEW	21	FUSE	REPLACED FUSE
CHICAGO	692043	8/24/2007 4:31	8/24/2007 11:49	437.1	Y2566	WARD11	147	ARRESTER-PORCELAIN	DISCONNECT OVERHEAD MATERIAL
SOUTHERN	689539	8/24/2007 4:32	8/24/2007 10:35	362.5	K7082	BOURBONNAIS TWP	43	PHASE WIRE (ALL VOLTAGES)	TREE REMOVED
SOUTHERN	689873	8/24/2007 4:32	8/24/2007 11:15	402.8	S365	VIENNA TWP	10	FUSE	REPLACED FUSE
SOUTHERN	689873	8/24/2007 4:32	8/24/2007 11:15	402.8	S365	STREATOR	1	FUSE	REPLACED FUSE
SOUTHERN	690331	8/24/2007 4:34	8/25/2007 11:30	1856	F5271	HOMEWOOD	51	PHASE WIRE (ALL VOLTAGES)	TREE REMOVED
NORTHWEST	689464	8/24/2007 4:35	8/24/2007 9:15	279.7	W109	AURORA	15	FUSE	REPLACED FUSE
SOUTHERN	689956	8/24/2007 4:35	8/24/2007 14:30	594.7	J4403	CHANNAHON	57	CABLE	TEMPORARY SWITCHING
SOUTHERN	689935	8/24/2007 4:36	8/24/2007 19:00	863.3	S675	MAZON	13	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE
SOUTHERN	689935	8/24/2007 4:36	8/24/2007 19:00	863.3	S675	MAZON TWP	18	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE
SOUTHERN	689964	8/24/2007 4:37	8/24/2007 9:40	302.1	J5673	JOLIET	371	TAP WIRE	REPLACED OVERHEAD MATERIAL
SOUTHERN	689964	8/24/2007 4:37	8/24/2007 9:40	302.1	J5673	SHOREWOOD	1	TAP WIRE	REPLACED OVERHEAD MATERIAL
SOUTHERN	689964	8/24/2007 4:37	8/24/2007 9:40	302.1	J5673	JOLIET TWP	2	TAP WIRE	REPLACED OVERHEAD MATERIAL
SOUTHERN	690146	8/24/2007 4:38	8/25/2007 3:25	1366.2	J926	LEMONT	104	FUSE	REPLACED FUSE
NORTHWEST	691152	8/24/2007 4:40	8/24/2007 14:42	601.6	B905	SYCAMORE TWP	1	FUSE	REPLACED FUSE
SOUTHERN	689532	8/24/2007 4:41	8/24/2007 11:28	406	W613	WOODRIDGE	7	CUTOUT	REPAIRED OVERHEAD MATERIAL
NORTHWEST	689682	8/24/2007 4:41	8/24/2007 15:30	648.4	H526	ADAMS TWP	1	FUSE	REPLACED FUSE
NORTHERN	692729	8/24/2007 4:41	8/27/2007 18:22	5140.4	E529	DES PLAINES	1	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
SOUTHERN	690059	8/24/2007 4:42	8/25/2007 0:05	1162.7	G091	RIVERDALE	75	PHASE WIRE (ALL VOLTAGES)	TREE REMOVED
SOUTHERN	691316	8/24/2007 4:42	8/26/2007 13:50	3427.2	G1973	ORLAND PARK	78	CUTOUT	REPLACED CUTOUT
SOUTHERN	691234	8/24/2007 4:43	8/26/2007 11:50	3306.1	G4082	ORLAND PARK	11	FUSE	REPLACED FUSE
SOUTHERN	691469	8/24/2007 4:43	8/25/2007 18:30	2266	J167	JOLIET	45	FUSE	REPLACED FUSE
SOUTHERN	691469	8/24/2007 4:43	8/26/2007 16:26	3582	J167	JOLIET	21	FUSE	REPLACED FUSE
SOUTHERN	689427	8/24/2007 4:44	8/24/2007 6:45	120.5	W530	WESTERN SPRINGS	1	FUSE	REPLACED FUSE
SOUTHERN	689427	8/24/2007 4:44	8/24/2007 6:45	120.5	W530	HINSDALE	50	FUSE	REPLACED FUSE
NORTHWEST	690076	8/24/2007 4:44	8/24/2007 11:45	420	W7715	ST CHARLES TWP	51	FUSE	CLOSED FUSE
NORTHWEST	690076	8/24/2007 4:44	8/24/2007 11:45	420	W7715	CAMPTON TWP	14	FUSE	CLOSED FUSE
SOUTHERN	689929	8/24/2007 4:45	8/24/2007 21:04	978.1	J235	SARATOGA TWP	4	FUSE	REPLACED FUSE
SOUTHERN	703371	8/24/2007 4:46	8/24/2007 14:42	595.5	S475	BRACEVILLE TWP	1	FUSE	CLOSED FUSE
SOUTHERN	703371	8/24/2007 4:46	8/24/2007 14:42	595.5	S475	MAINE TWP	1	FUSE	CLOSED FUSE
NORTHWEST	689397	8/24/2007 4:48	8/24/2007 5:15	26.3	B162	BURLINGTON TWP	14	ARRESTER-PORCELAIN	REPLACED OVERHEAD MATERIAL
NORTHWEST	689397	8/24/2007 4:48	8/24/2007 5:15	26.3	B162	HAMPSHIRE TWP	21	ARRESTER-PORCELAIN	REPLACED OVERHEAD MATERIAL
NORTHWEST	689737	8/24/2007 4:48	8/24/2007 17:02	733.1	W7020	ELGIN	17	FUSE	REPAIRED OVERHEAD MATERIAL
CHICAGO	690294	8/24/2007 4:48	8/25/2007 8:42	1674.6	Z30602	WARD23	52	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHERN	690294	8/24/2007 4:48	8/25/2007 8:42	1674.6	Z30602	FORESTVIEW	1	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHERN	690294	8/24/2007 4:48	8/25/2007 8:42	1674.6	Z30602	STICKNEY TWP	13	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
SOUTHERN	690352	8/24/2007 4:48	8/25/2007 12:00	1871.8	J875	LEMONT	2	FUSE	REPLACED FUSE
NORTHERN	692546	8/24/2007 4:48	8/27/2007 15:36	4967.4	C7222	GLENVIEW	65	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
SOUTHERN	689479	8/24/2007 4:49	8/24/2007 10:00	310.8	J765	VIENNA TWP	11	FUSE	REPLACED FUSE
SOUTHERN	690304	8/24/2007 4:50	8/25/2007 10:30	1779.2	J696	BRAIDWOOD	5	FUSE	TREE REMOVED
NORTHERN	691512	8/24/2007 4:51	8/26/2007 17:08	3616.8	E521	MOUNT PROSPECT	8	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHERN	691537	8/24/2007 4:52	8/26/2007 13:30	3397.8	W525	LOMBARD	21	FUSE	REPLACED FUSE
NORTHWEST	689740	8/24/2007 4:53	8/24/2007 16:55	721.8	B162	BURLINGTON TWP	50	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE
NORTHERN	690938	8/24/2007 4:53	8/24/2007 16:00	667	W301	WHEATON	1801	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHERN	690938	8/24/2007 4:53	8/24/2007 16:00	667	W301	MILTON TWP	2	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL

REGION_NAME	OUTAGE_ID	START_DATETIME	DATETIME_RSTD	DURATION _MINUTES	AS_BUILT _FEEDER _LINE	TOWN NAME	PREM _COUNT	EQUIPMENT_INVOLVED	RESTORATION_MEDIATION
NORTHERN	692789	8/24/2007 4:54	8/27/2007 18:37	5142.8	C7222	GLENVIEW	9	PHASE WIRE (ALL VOLTAGES)	REPLACED OVERHEAD MATERIAL
SOUTHERN	692941	8/24/2007 4:54	8/27/2007 20:50	5276	G6586	CALUMET CITY	1	CROSS-ARM	REPLACED OVERHEAD MATERIAL
SOUTHERN	690127	8/24/2007 4:55	8/25/2007 2:00	1264.7	G617	ALSIP	11	TRANSFORMER-PADMOUNT	TEMPORARY SWITCHING
SOUTHERN	690127	8/24/2007 4:55	8/25/2007 2:25	1289.7	G617	CRESTWOOD	1	TRANSFORMER-PADMOUNT	TEMPORARY SWITCHING
SOUTHERN	690127	8/24/2007 4:55	8/25/2007 2:25	1289.7	G617	ALSIP	113	TRANSFORMER-PADMOUNT	TEMPORARY SWITCHING
SOUTHERN	691230	8/24/2007 4:55	8/26/2007 12:15	3319.4	G4381	HARVEY	35	POLE	REPLACED EQUIPMENT
NORTHWEST	689553	8/24/2007 4:57	8/24/2007 5:00	3	W152	BATAVIA TWP	1	POLE	REPAIRED OVERHEAD MATERIAL
SOUTHERN	691304	8/24/2007 4:58	8/26/2007 12:56	3357.5	G101	CALUMET CITY	45	PHASE WIRE (ALL VOLTAGES)	REPAIRED EQUIPMENT
NORTHWEST	690397	8/24/2007 4:59	8/25/2007 13:30	1950.6	W125	LITTLE ROCK TWP	3	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHWEST	690599	8/24/2007 4:59	8/24/2007 20:25	925.4	W7937	WAYNE	4	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHWEST	690599	8/24/2007 4:59	8/25/2007 18:21	2241.4	W7937	WAYNE	1	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
SOUTHERN	691263	8/24/2007 4:59	8/26/2007 11:45	3285.4	G091	RIVERDALE	8	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE
NORTHERN	692476	8/24/2007 4:59	8/27/2007 12:45	4785.2	C1723	WHEELING	9	FUSE	REPLACED FUSE
NORTHERN	692476	8/24/2007 4:59	8/27/2007 12:45	4785.2	C1723	WHEELING TWP	2	FUSE	REPLACED FUSE
SOUTHERN	692714	8/24/2007 5:00	8/27/2007 17:00	5039.8	J696	BRAIDWOOD	1	POLE	REPLACED OVERHEAD MATERIAL
CHICAGO	689700	8/24/2007 5:01	8/24/2007 13:05	484	G6089	WARD19	59	PHASE WIRE (ALL VOLTAGES)	REPLACED OVERHEAD MATERIAL
SOUTHERN	690172	8/24/2007 5:01	8/25/2007 4:50	1428.2	G211	WORTH	70	FUSE	REPLACED FUSE
CHICAGO	690488	8/24/2007 5:01	8/25/2007 15:40	2078.1	Y3842	WARD1	105	FUSE	REPLACED FUSE
NORTHWEST	689433	8/24/2007 5:03	8/24/2007 7:50	166.9	H675	AMBOY	58	FUSE	REPLACED FUSE
NORTHERN	691207	8/24/2007 5:03	8/26/2007 12:00	3296.4	C82	SKOKIE	37	TRANSFORMER-OVHD	REPLACED OVERHEAD MATERIAL
NORTHERN	689766	8/24/2007 5:04	8/24/2007 16:45	700.9	C487	DEERFIELD	56	FUSE	REPLACED FUSE
SOUTHERN	689767	8/24/2007 5:04	8/24/2007 15:30	626	W3605	HINSDALE	17	CABLE	TEMPORARY JUMPER TO RESTORE
CHICAGO	690337	8/24/2007 5:04	8/25/2007 12:01	1856.8	X7145	WARD41	64	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE
SOUTHERN	698785	8/24/2007 5:05	8/26/2007 1:00	2634.7	J1184	ROMEOVILLE	35	CUTOUT	REPLACED CUTOUT
SOUTHERN	698785	8/24/2007 5:05	8/26/2007 3:00	2754.7	J1184	ROMEOVILLE	31	CUTOUT	REPLACED CUTOUT
SOUTHERN	689538	8/24/2007 5:06	8/24/2007 11:35	388.1	K7082	BOURBONNAIS TWP	42	PHASE WIRE (ALL VOLTAGES)	TREE REMOVED
SOUTHERN	689538	8/24/2007 5:06	8/24/2007 11:35	388.1	K7082	UNIVERSITY PARK	1	PHASE WIRE (ALL VOLTAGES)	TREE REMOVED
NORTHWEST	689703	8/24/2007 5:06	8/24/2007 14:00	533.4	W7421	BARTLETT	13	PHASE WIRE (ALL VOLTAGES)	REPLACED OVERHEAD MATERIAL
SOUTHERN	689712	8/24/2007 5:06	8/24/2007 16:15	668.5	G616	MIDLOTHIAN	48	FUSE	REPLACED FUSE
NORTHERN	692640	8/24/2007 5:06	8/27/2007 16:42	5015.2	E0225	INVERNESS	6	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE
NORTHERN	692640	8/24/2007 5:06	8/27/2007 16:42	5015.2	E0225	PALATINE TWP	1	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE
CHICAGO	689522	8/24/2007 5:07	8/24/2007 9:30	263	Z1407	WARD17	246	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE
CHICAGO	689653	8/24/2007 5:08	8/24/2007 13:40	511.5	687X045	WARD45	11	FUSE	REPLACED FUSE
SOUTHERN	689887	8/24/2007 5:08	8/24/2007 20:00	892	S716	PONTIAC TWP	19	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE
SOUTHERN	689889	8/24/2007 5:08	8/24/2007 9:00	231.4	W598	WOODRIDGE	15	CABLE	TEMPORARY JUMPER TO RESTORE
SOUTHERN	689889	8/24/2007 5:08	8/24/2007 18:20	791.4	W598	WOODRIDGE	6	CABLE	TEMPORARY JUMPER TO RESTORE
NORTHERN	691556	8/24/2007 5:08	8/26/2007 17:46	3637.6	C138Y	NORTHBROOK	35	FUSE	REPLACED FUSE
NORTHERN	692495	8/24/2007 5:08	8/27/2007 15:00	4911.8	W550	LOMBARD	28	FUSE	REPLACED FUSE
SOUTHERN	690270	8/24/2007 5:09	8/25/2007 8:15	1625.1	J3312	SARATOGA TWP	51	FUSE	REPLACED FUSE
SOUTHERN	690270	8/24/2007 5:09	8/25/2007 8:15	1625.1	J3312	MORRIS	3	FUSE	REPLACED FUSE
SOUTHERN	690306	8/24/2007 5:09	8/25/2007 10:45	1775.2	F365	CRETE TWP	40	FUSE	REPLACED FUSE
SOUTHERN	690306	8/24/2007 5:09	8/25/2007 10:45	1775.2	F365	CRETE	1	FUSE	REPLACED FUSE
SOUTHERN	690635	8/24/2007 5:09	8/25/2007 18:45	2255.2	J0613	FRANKFORT TWP	11	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE
SOUTHERN	690635	8/24/2007 5:09	8/25/2007 18:45	2255.2	J0613	NEW LENOX	1	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE
SOUTHERN	690635	8/24/2007 5:09	8/25/2007 18:45	2255.2	J0613	MOKENA	3	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE
SOUTHERN	690635	8/24/2007 5:09	8/25/2007 18:45	2255.2	J0613	MILLER TWP	1	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE
SOUTHERN	690635	8/24/2007 5:09	8/25/2007 18:45	2255.2	J0613	NEW LENOX TWP	92	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE
SOUTHERN	690635	8/24/2007 5:09	8/25/2007 18:45	2255.2	J0613	MARLEY	25	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE

REGION_NAME	OUTAGE_ID	START_DATETIME	DATETIME_RSTD	DURATION _MINUTES	AS_BUILT _FEEDER _LINE	TOWN NAME	PREM _COUNT	EQUIPMENT_INVOLVED	RESTORATION_MEDIATION
NORTHERN	691923	8/24/2007 5:09	8/26/2007 23:01	3951.8	D861	BERKELEY	4	TRANSFORMER-OVHD	REPLACED TRANSFORMER
CHICAGO	689983	8/24/2007 5:10	8/24/2007 22:24	1033.1	Z13733	WARD3	61	TRANSFORMER-OVHD	REPLACED TRANSFORMER
SOUTHERN	690553	8/24/2007 5:11	8/25/2007 17:00	2148.4	G995	PALOS HEIGHTS	39	FUSE	REPLACED FUSE
NORTHERN	691144	8/24/2007 5:11	8/25/2007 5:30	1458.2	W9518	MILTON TWP	82	ARRESTER-PORCELAIN	REPLACED CUTOUT
NORTHERN	691144	8/24/2007 5:11	8/25/2007 5:30	1458.2	W9518	WHEATON	1	ARRESTER-PORCELAIN	REPLACED CUTOUT
NORTHERN	691144	8/24/2007 5:11	8/26/2007 11:14	3242.5	W9518	MILTON TWP	10	ARRESTER-PORCELAIN	REPLACED CUTOUT
NORTHERN	693178	8/24/2007 5:11	8/28/2007 7:30	5898.3	W2024	CAROL STREAM	1	CABLE	REPAIRED UNDERGROUND MATERIAL
SOUTHERN	690391	8/24/2007 5:12	8/25/2007 13:39	1947	J846	JOLIET	10	FUSE	REPLACED FUSE
CHICAGO	691153	8/24/2007 5:13	8/26/2007 11:00	3226.2	Y2547	WARD24	45	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHERN	691398	8/24/2007 5:13	8/26/2007 15:26	3492.1	W9518	MILTON TWP	14	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHERN	691635	8/24/2007 5:13	8/26/2007 18:44	3690.1	W9518	MILTON TWP	12	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHERN	690251	8/24/2007 5:14	8/24/2007 20:47	932.8	C586	WHEELING TWP	1	PHASE WIRE (ALL VOLTAGES)	TREE REMOVED
NORTHERN	690251	8/24/2007 5:14	8/24/2007 20:47	932.8	C586	GLENVIEW	456	PHASE WIRE (ALL VOLTAGES)	TREE REMOVED
SOUTHERN	691904	8/24/2007 5:14	8/26/2007 22:00	3885	G6181	MARKHAM	15	FUSE	REPAIRED OVERHEAD MATERIAL
SOUTHERN	699794	8/24/2007 5:14	8/24/2007 19:34	859.9	S355	NEWTOWN TWP	4	FUSE	REPLACED FUSE
NORTHWEST	689601	8/24/2007 5:15	8/24/2007 10:25	309.8	W561	AURORA TWP	19	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHWEST	689601	8/24/2007 5:15	8/24/2007 10:25	309.8	W561	AURORA	10	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
SOUTHERN	689637	8/24/2007 5:15	8/24/2007 14:00	524.5	K505	MOMENCE	31	PHASE WIRE (ALL VOLTAGES)	TREE REMOVED
NORTHERN	690653	8/24/2007 5:15	8/25/2007 19:29	2293.2	D28	OAK PARK	88	FUSE	REPLACED FUSE
NORTHERN	691133	8/24/2007 5:15	8/26/2007 10:58	3222.8	C4616	PARK RIDGE	41	FUSE	REPLACED FUSE
SOUTHERN	690360	8/24/2007 5:16	8/25/2007 12:20	1863.7	G6083	CHICAGO RIDGE	67	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHERN	691794	8/24/2007 5:16	8/26/2007 19:58	3761.3	E024	PALATINE	177	CROSS-ARM	REPLACED OVERHEAD MATERIAL
NORTHERN	689457	8/24/2007 5:17	8/24/2007 9:00	222.3	C096	LONG GROVE	24	CABLE	TEMPORARY SWITCHING
SOUTHERN	690075	8/24/2007 5:17	8/25/2007 0:55	1177.2	J4405	CHANNAHON	11	FUSE	REPLACED FUSE
SOUTHERN	690075	8/24/2007 5:17	8/25/2007 0:55	1177.2	J4405	MINOOKA	7	FUSE	REPLACED FUSE
SOUTHERN	689422	8/24/2007 5:18	8/24/2007 6:30	71.6	S475	GARFIELD TWP	10	FUSE	REPLACED FUSE
SOUTHERN	689422	8/24/2007 5:18	8/24/2007 6:30	71.6	S475	GREENFIELD TWP	1	FUSE	REPLACED FUSE
NORTHWEST	689407	8/24/2007 5:19	8/24/2007 5:50	30.8	W9201	AURORA TWP	26	FUSE	REPLACED FUSE
NORTHWEST	689407	8/24/2007 5:19	8/24/2007 5:50	30.8	W9201	MONTGOMERY	22	FUSE	REPLACED FUSE
SOUTHERN	690218	8/24/2007 5:19	8/25/2007 5:15	1435.6	J4085	FRANKFORT	8	CABLE	TEMPORARY SWITCHING
SOUTHERN	690218	8/24/2007 5:19	8/25/2007 5:40	1460.6	J4085	FRANKFORT	8	CABLE	TEMPORARY SWITCHING
NORTHERN	690513	8/24/2007 5:19	8/25/2007 14:30	1990.8	E024	PALATINE	63	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE
NORTHERN	692105	8/24/2007 5:19	8/27/2007 4:30	4270.2	W602	LOMBARD	58	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE
NORTHWEST	689608	8/24/2007 5:20	8/24/2007 14:00	519.1	W7415	HANOVER PARK	311	PHASE WIRE (ALL VOLTAGES)	TREE REMOVED
NORTHERN	690424	8/24/2007 5:20	8/25/2007 14:27	1986.8	W9521	CAROL STREAM	32	FUSE	REPLACED FUSE
NORTHERN	690631	8/24/2007 5:20	8/25/2007 18:59	2258.2	W6211	ROSELLE	39	FUSE	CLOSED FUSE
NORTHERN	691785	8/24/2007 5:20	8/26/2007 18:30	3669.1	E0220	DEER PARK	48	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
SOUTHERN	689418	8/24/2007 5:21	8/24/2007 6:20	59	J3680	JOLIET	442	ARRESTER-PORCELAIN	TEMPORARY SWITCHING
NORTHWEST	689794	8/24/2007 5:21	8/24/2007 17:52	750.9	W9232	OSWEGO TWP	1	FUSE	REPLACED FUSE
SOUTHERN	689860	8/24/2007 5:21	8/24/2007 17:45	743.1	G53	HARVEY	227	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHERN	692816	8/24/2007 5:21	8/27/2007 19:35	5173.4	W656X	ITASCA	16	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHERN	691135	8/24/2007 5:22	8/26/2007 10:15	3172.4	C8512	SKOKIE	41	FUSE	REPLACED FUSE
SOUTHERN	691315	8/24/2007 5:22	8/26/2007 14:10	3408	G6190	ROBBINS	12	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
SOUTHERN	690439	8/24/2007 5:23	8/25/2007 14:40	1996.8	J245	LISBON TWP	6	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
SOUTHERN	690887	8/24/2007 5:23	8/24/2007 7:40	137	J1674	PALOS TWP	2	PHASE WIRE (ALL VOLTAGES)	TEMPORARY SWITCHING
SOUTHERN	690887	8/24/2007 5:23	8/24/2007 7:40	137	J1674	LEMONT	11	PHASE WIRE (ALL VOLTAGES)	TEMPORARY SWITCHING
SOUTHERN	690887	8/24/2007 5:23	8/24/2007 7:40	137	J1674	LEMONT TWP	463	PHASE WIRE (ALL VOLTAGES)	TEMPORARY SWITCHING
SOUTHERN	690887	8/24/2007 5:23	8/24/2007 7:40	137	J1674	HOMER TWP	6	PHASE WIRE (ALL VOLTAGES)	TEMPORARY SWITCHING

REGION_NAME	OUTAGE_ID	START_DATETIME	DATETIME_RSTD	DURATION _MINUTES	AS_BUILT _FEEDER _LINE	TOWN NAME	PREM _COUNT	EQUIPMENT_INVOLVED	RESTORATION_MEDIATION
SOUTHERN	690887	8/24/2007 5:23	8/24/2007 8:44	201	J1674	LEMONT TWP	3	PHASE WIRE (ALL VOLTAGES)	TEMPORARY SWITCHING
SOUTHERN	690887	8/24/2007 5:23	8/24/2007 8:44	201	J1674	PALOS PARK	1	PHASE WIRE (ALL VOLTAGES)	TEMPORARY SWITCHING
SOUTHERN	690887	8/24/2007 5:23	8/24/2007 8:44	201	J1674	LEMONT	1	PHASE WIRE (ALL VOLTAGES)	TEMPORARY SWITCHING
SOUTHERN	690887	8/24/2007 5:23	8/24/2007 11:00	337	J1674	PALOS TWP	47	PHASE WIRE (ALL VOLTAGES)	TEMPORARY SWITCHING
SOUTHERN	690887	8/24/2007 5:23	8/24/2007 11:00	337	J1674	PALOS PARK	136	PHASE WIRE (ALL VOLTAGES)	TEMPORARY SWITCHING
SOUTHERN	690887	8/24/2007 5:23	8/24/2007 11:00	337	J1674	LEMONT TWP	1	PHASE WIRE (ALL VOLTAGES)	TEMPORARY SWITCHING
SOUTHERN	690887	8/24/2007 5:23	8/24/2007 11:00	337	J1674	ORLAND PARK	1	PHASE WIRE (ALL VOLTAGES)	TEMPORARY SWITCHING
SOUTHERN	690887	8/24/2007 5:23	8/24/2007 11:00	337	J1674	PALOS HEIGHTS	2	PHASE WIRE (ALL VOLTAGES)	TEMPORARY SWITCHING
NORTHERN	690534	8/24/2007 5:24	8/25/2007 17:05	2140.4	C316	WILMETTE	32	FUSE	REPAIRED OVERHEAD MATERIAL
SOUTHERN	690518	8/24/2007 5:25	8/25/2007 16:00	2074.4	F176	PEOTONE	30	CABLE	TEMPORARY SWITCHING
CHICAGO	690986	8/24/2007 5:25	8/26/2007 4:08	2802.9	X8451	WARD47	1	PHASE WIRE (ALL VOLTAGES)	TEMPORARY JUMPER TO RESTORE
NORTHERN	691219	8/24/2007 5:25	8/26/2007 12:15	3289.8	C536	EVANSTON	34	PHASE WIRE (ALL VOLTAGES)	REPLACED TRANSFORMER
NORTHERN	692409	8/24/2007 5:25	8/26/2007 12:30	3304.9	E5219	DES PLAINES	59	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHERN	690761	8/24/2007 5:26	8/25/2007 21:33	2406.4	C1711	PROSPECT HEIGHTS	29	FUSE	REPLACED FUSE
CHICAGO	692041	8/24/2007 5:26	8/24/2007 11:53	386.5	Y2566	WARD11	9	ARRESTER-PORCELAIN	CLOSED FUSE
NORTHWEST	689438	8/24/2007 5:28	8/24/2007 8:05	156.5	H1702	SOUTH DIXON TWP	3	FUSE	REPLACED FUSE
NORTHERN	691755	8/24/2007 5:28	8/26/2007 20:27	3778.2	D6419	RIVER FOREST	12	PHASE WIRE (ALL VOLTAGES)	REPLACED OVERHEAD MATERIAL
SOUTHERN	689676	8/24/2007 5:29	8/24/2007 15:45	615.5	F465	BLOOM TWP	18	PHASE WIRE (ALL VOLTAGES)	TEMPORARY SWITCHING
SOUTHERN	689676	8/24/2007 5:29	8/24/2007 15:45	615.5	F465	LANSING	461	PHASE WIRE (ALL VOLTAGES)	TEMPORARY SWITCHING
SOUTHERN	689676	8/24/2007 5:29	8/24/2007 15:45	615.5	F465	CHICAGO HEIGHTS	1	PHASE WIRE (ALL VOLTAGES)	TEMPORARY SWITCHING
SOUTHERN	689676	8/24/2007 5:29	8/24/2007 15:45	615.5	F465	LYNWOOD	164	PHASE WIRE (ALL VOLTAGES)	TEMPORARY SWITCHING
CHICAGO	689955	8/24/2007 5:29	8/24/2007 20:55	925.1	62ND46	WARD20	39	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE
CHICAGO	689955	8/24/2007 5:29	8/24/2007 20:55	925.1	62ND46	WARD5	51	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE
NORTHERN	691860	8/24/2007 5:29	8/25/2007 15:00	2010.1	D991	RIVER GROVE	23	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHERN	691860	8/24/2007 5:29	8/25/2007 15:00	2010.1	D991	FRANKLIN PARK	25	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHWEST	690158	8/24/2007 5:30	8/25/2007 3:30	1319.3	W7415	HANOVER PARK	9	POLE	REPLACED OVERHEAD MATERIAL
SOUTHERN	692536	8/24/2007 5:31	8/27/2007 10:15	4603.4	F365	CRETE TWP	1	TRANSFORMER-OVHD	REPAIRED TRANSFORMER
CHICAGO	690134	8/24/2007 5:32	8/24/2007 18:32	779.6	X7140	WARD41	46	FUSE	REPLACED FUSE
SOUTHERN	689695	8/24/2007 5:33	8/24/2007 15:59	625.5	W5911	LISLE TWP	1	METER	INSTALL RE-INSTALL METER
NORTHERN	691097	8/24/2007 5:33	8/26/2007 9:50	3136.9	X7153	PARK RIDGE	46	FUSE	REPLACED FUSE
NORTHERN	692075	8/24/2007 5:33	8/27/2007 3:26	4192.9	C1212	NORTHBROOK	1	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
SOUTHERN	690441	8/24/2007 5:34	8/25/2007 7:40	1565.6	J135	WAUPONSEE TWP	5	FUSE	REPLACED FUSE
SOUTHERN	690441	8/24/2007 5:34	8/25/2007 10:25	1731.4	J135	WAUPONSEE TWP	3	FUSE	REPLACED FUSE
SOUTHERN	690441	8/24/2007 5:34	8/25/2007 14:15	1960.6	J135	WAUPONSEE TWP	4	FUSE	REPLACED FUSE
NORTHERN	691068	8/24/2007 5:34	8/24/2007 14:21	527.6	W9507	MILTON TWP	665	POLE	REPLACED OVERHEAD MATERIAL
NORTHERN	691068	8/24/2007 5:34	8/24/2007 14:21	527.6	W9507	BLOOMINGDALE TWP	19	POLE	REPLACED OVERHEAD MATERIAL
NORTHERN	691068	8/24/2007 5:34	8/24/2007 14:21	527.6	W9507	WHEATON	5	POLE	REPLACED OVERHEAD MATERIAL
NORTHERN	691068	8/24/2007 5:34	8/24/2007 14:21	527.6	W9507	WINFIELD TWP	2	POLE	REPLACED OVERHEAD MATERIAL
NORTHERN	691068	8/24/2007 5:34	8/24/2007 14:21	527.6	W9507	WINFIELD	428	POLE	REPLACED OVERHEAD MATERIAL
NORTHERN	691068	8/24/2007 5:34	8/24/2007 14:21	527.6	W9507	CAROL STREAM	441	POLE	REPLACED OVERHEAD MATERIAL
SOUTHERN	690456	8/24/2007 5:35	8/25/2007 13:30	1914.1	F596	UNIVERSITY PARK	1	FUSE	REPLACED FUSE
CHICAGO	690523	8/24/2007 5:35	8/25/2007 16:50	2114.8	Z11871	WARD21	1	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHERN	691921	8/24/2007 5:35	8/25/2007 19:00	2244.4	X7153	PARK RIDGE	519	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHERN	691941	8/24/2007 5:35	8/26/2007 21:30	3834.3	C1212	NORTHFIELD	15	FUSE	REPLACED FUSE
SOUTHERN	689534	8/24/2007 5:36	8/24/2007 10:30	294	J4082	FRANKFORT	29	TAP WIRE	REPAIRED OVERHEAD MATERIAL
SOUTHERN	689534	8/24/2007 5:36	8/24/2007 10:30	294	J4082	FRANKFORT TWP	20	TAP WIRE	REPAIRED OVERHEAD MATERIAL
SOUTHERN	689567	8/24/2007 5:37	8/24/2007 12:00	382.6	K195	UNIVERSITY PARK	1	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE
SOUTHERN	689567	8/24/2007 5:37	8/24/2007 12:00	382.6	K195	MANTENO	28	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE

REGION_NAME	OUTAGE_ID	START_DATETIME	DATETIME_RSTD	DURATION _MINUTES	AS_BUILT _FEEDER _LINE	TOWN NAME	PREM _COUNT	EQUIPMENT_INVOLVED	RESTORATION_MEDIATION
SOUTHERN	689567	8/24/2007 5:37	8/24/2007 12:00	382.6	K195	MANTENO TWP	24	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE
NORTHERN	690347	8/24/2007 5:38	8/25/2007 12:10	1831.1	E331	CUBA TWP	80	FUSE	REPLACED FUSE
NORTHERN	691412	8/24/2007 5:38	8/26/2007 15:00	3441.1	W689	WOOD DALE	16	TRANSFORMER-OVHD	REPLACED TRANSFORMER
NORTHERN	692415	8/24/2007 5:38	8/27/2007 13:00	4761.3	W310	WEST CHICAGO	1	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHERN	692415	8/24/2007 5:38	8/27/2007 13:00	4761.3	W310	WHEATON	22	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
SOUTHERN	689487	8/24/2007 5:39	8/24/2007 10:15	275.9	W3605	HINSDALE	1	FUSE	REPLACED FUSE
SOUTHERN	689487	8/24/2007 5:39	8/24/2007 10:15	275.9	W3605	DOWNERS GROVE TWP	90	FUSE	REPLACED FUSE
NORTHWEST	689808	8/24/2007 5:39	8/24/2007 17:35	715.7	W1001	WAYNE	3	FUSE	REPLACED FUSE
NORTHWEST	689808	8/24/2007 5:39	8/24/2007 17:35	715.7	W1001	BARTLETT	4	FUSE	REPLACED FUSE
NORTHERN	690601	8/24/2007 5:39	8/25/2007 18:00	2180.6	D593	CICERO	19	FUSE	REPLACED FUSE
NORTHWEST	689591	8/24/2007 5:40	8/24/2007 12:50	429.6	W638	STREAMWOOD	53	PHASE WIRE (ALL VOLTAGES)	TREE REMOVED
NORTHERN	692656	8/24/2007 5:41	8/27/2007 12:29	4727.7	E3313	BARRINGTON HILLS	1	BUSHING-PRIMARY	REPLACED OVERHEAD MATERIAL
NORTHWEST	689631	8/24/2007 5:42	8/24/2007 13:55	492.6	E6021	EAST DUNDEE	42	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
SOUTHERN	689650	8/24/2007 5:43	8/24/2007 14:50	546.7	G6028	SOUTH HOLLAND	26	FUSE	REPLACED FUSE
SOUTHERN	690487	8/24/2007 5:43	8/25/2007 12:15	1831	J5163	FRANKFORT TWP	6	FUSE	REPLACED FUSE
SOUTHERN	690487	8/24/2007 5:43	8/25/2007 12:15	1831	J5163	FRANKFORT	1	FUSE	REPLACED FUSE
SOUTHERN	690487	8/24/2007 5:43	8/25/2007 13:30	1906	J5163	FRANKFORT TWP	18	FUSE	REPLACED FUSE
NORTHERN	692504	8/24/2007 5:43	8/27/2007 14:33	4849.6	C132	NORTHBROOK	20	CABLE	TEMPORARY SWITCHING
NORTHWEST	689593	8/24/2007 5:44	8/24/2007 13:00	436	B961	HAMPSHIRE TWP	1	TRANSFORMER-OVHD	REPLACED TRANSFORMER
SOUTHERN	689896	8/24/2007 5:44	8/24/2007 20:15	870.6	J4074	FRANKFORT	69	FUSE	REPLACED FUSE
SOUTHERN	691462	8/24/2007 5:44	8/26/2007 15:50	3485.3	G767	MARKHAM	6	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE
NORTHERN	699804	8/24/2007 5:44	8/24/2007 22:46	1021.3	C80	SKOKIE	8	FUSE	REPLACED FUSE
SOUTHERN	691040	8/24/2007 5:45	8/26/2007 6:06	2900.2	J656	MILLER TWP	3	FUSE	REPLACED FUSE
SOUTHERN	690519	8/24/2007 5:46	8/25/2007 16:02	2055.7	F465	LANSING	84	PHASE WIRE (ALL VOLTAGES)	REPLACED OVERHEAD MATERIAL
NORTHERN	692635	8/24/2007 5:46	8/27/2007 15:00	4873.9	C583	GLENVIEW	37	PHASE WIRE (ALL VOLTAGES)	TREE REMOVED
NORTHWEST	690332	8/24/2007 5:47	8/24/2007 12:00	372.6	H526	EARL TWP	20	TRANSFORMER-OVHD	REPLACED TRANSFORMER
NORTHWEST	690332	8/24/2007 5:47	8/25/2007 11:00	1752.6	H526	EARL TWP	1	TRANSFORMER-OVHD	REPLACED TRANSFORMER
SOUTHERN	691347	8/24/2007 5:47	8/26/2007 11:00	3193	G091	RIVERDALE	10	TRANSFORMER-OVHD	REPLACED TRANSFORMER
SOUTHERN	689498	8/24/2007 5:48	8/24/2007 9:55	246.5	G6188	OAK FOREST	152	FUSE	REPLACED FUSE
NORTHERN	691882	8/24/2007 5:48	8/26/2007 22:23	3874.1	E707	ARLINGTON HEIGHTS	15	FUSE	REPLACED FUSE
NORTHWEST	690089	8/24/2007 5:49	8/24/2007 23:00	1031	W178	SUGAR GROVE TWP	1	FUSE	REPLACED FUSE
CHICAGO	690472	8/24/2007 5:50	8/25/2007 14:50	1979.6	C8511X	WARD50	41	TRANSFORMER-OVHD	REPLACED TRANSFORMER
NORTHERN	692697	8/24/2007 5:50	8/27/2007 18:02	5051.5	C7212	MAINE TWP	7	TRANSFORMER-OVHD	REPLACED TRANSFORMER
NORTHERN	689879	8/24/2007 5:51	8/24/2007 19:30	818.8	W556	GLEN ELLYN	25	FUSE	REPLACED FUSE
SOUTHERN	689924	8/24/2007 5:51	8/24/2007 20:45	893.3	K195	SUMNER TWP	29	FUSE	DISCONNECT OVERHEAD MATERIAL
NORTHERN	695278	8/24/2007 5:51	8/24/2007 21:50	959.1	E5215X	MOUNT PROSPECT	13	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHERN	695278	8/24/2007 5:51	8/24/2007 23:04	1033.2	E5215X	MOUNT PROSPECT	60	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHERN	695278	8/24/2007 5:51	8/24/2007 23:04	1033.2	E5215X	ARLINGTON HEIGHTS	26	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHERN	695278	8/24/2007 5:51	8/26/2007 3:02	2712	E5215X	ARLINGTON HEIGHTS	65	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHERN	695278	8/24/2007 5:51	8/26/2007 3:02	2712	E5215X	NORTHFIELD TWP	1	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHERN	695278	8/24/2007 5:51	8/26/2007 11:35	3224	E5215X	ARLINGTON HEIGHTS	626	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHERN	695278	8/24/2007 5:51	8/26/2007 11:35	3224	E5215X	NORTHFIELD TWP	1	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHERN	695278	8/24/2007 5:51	8/26/2007 12:30	3279	E5215X	ARLINGTON HEIGHTS	28	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHERN	695278	8/24/2007 5:51	8/26/2007 12:49	3298	E5215X	ARLINGTON HEIGHTS	339	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHERN	695278	8/24/2007 5:51	8/26/2007 13:30	3339	E5215X	ARLINGTON HEIGHTS	33	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHWEST	689493	8/24/2007 5:52	8/24/2007 9:17	205	E6023X	DUNDEE TWP	14	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE
NORTHWEST	689493	8/24/2007 5:52	8/24/2007 9:17	205	E6023X	WEST DUNDEE	2	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE
SOUTHERN	689576	8/24/2007 5:52	8/24/2007 13:00	427.9	G6029	SOUTH HOLLAND	1	FUSE	REPLACED FUSE

REGION_NAME	OUTAGE_ID	START_DATETIME	DATETIME_RSTD	DURATION_MINUTES	AS_BUILT_FEEDER_LINE	TOWN NAME	PREM_COUNT	EQUIPMENT_INVOLVED	RESTORATION_MEDIATION
SOUTHERN	689576	8/24/2007 5:52	8/24/2007 13:00	427.9	G6029	PHOENIX	79	FUSE	REPLACED FUSE
SOUTHERN	691310	8/24/2007 5:52	8/26/2007 13:17	3324.1	G1986X	ORLAND PARK	12	CABLE	TEMPORARY SWITCHING
SOUTHERN	691310	8/24/2007 5:52	8/26/2007 13:24	3331.1	G1986X	ORLAND PARK	15	CABLE	TEMPORARY SWITCHING
SOUTHERN	691310	8/24/2007 5:52	8/26/2007 14:00	3367.1	G1986X	ORLAND PARK	14	CABLE	TEMPORARY SWITCHING
SOUTHERN	691718	8/24/2007 5:52	8/24/2007 19:50	838	K187	MOMENCE TWP	13	POLE	REPAIRED OVERHEAD MATERIAL
SOUTHERN	691718	8/24/2007 5:52	8/26/2007 16:10	3498	K187	MOMENCE TWP	11	POLE	REPAIRED OVERHEAD MATERIAL
SOUTHERN	692585	8/24/2007 5:52	8/27/2007 16:16	4943.5	F574	STEGER	1	GUY WIRE	REPLACED OVERHEAD MATERIAL
CHICAGO	689801	8/24/2007 5:53	8/24/2007 18:12	739	Z6346	WARD23	50	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE
NORTHWEST	690004	8/24/2007 5:53	8/24/2007 21:30	936.7	B171	GENOA TWP	1	FUSE	REPLACED FUSE
NORTHERN	690632	8/24/2007 5:53	8/25/2007 18:35	2201.3	X4867	NORRIDGE	6	FUSE	REPLACED FUSE
SOUTHERN	691235	8/24/2007 5:54	8/26/2007 11:30	3215.5	J0613	NEW LENOX TWP	9	TRANSFORMER-OVHD	REPLACED TRANSFORMER
CHICAGO	692092	8/24/2007 5:54	8/27/2007 3:44	4189.2	Y3880	WARD28	1	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
CHICAGO	690325	8/24/2007 5:55	8/25/2007 11:46	1790.5	X7145	WARD41	83	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE
NORTHERN	690793	8/24/2007 5:55	8/25/2007 19:45	2269.3	C2917	NILES	1	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
SOUTHERN	691320	8/24/2007 5:55	8/26/2007 13:20	3324.2	G4072	PALOS PARK	5	PHASE WIRE (ALL VOLTAGES)	REPAIRED EQUIPMENT
NORTHERN	692373	8/24/2007 5:55	8/27/2007 13:05	4749.4	E815	NORTHFIELD TWP	1	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHERN	692373	8/24/2007 5:55	8/27/2007 13:05	4749.4	E815	ARLINGTON HEIGHTS	39	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHWEST	689919	8/24/2007 5:57	8/24/2007 16:00	602.8	B7570	DEKALB	37	SWITCHGEAR	REPAIRED UNDERGROUND MATERIAL
NORTHWEST	689919	8/24/2007 5:57	8/24/2007 17:21	684.2	B7570	DEKALB	62	SWITCHGEAR	REPAIRED UNDERGROUND MATERIAL
NORTHWEST	689919	8/24/2007 5:57	8/24/2007 20:40	882.8	B7570	DEKALB	125	SWITCHGEAR	REPAIRED UNDERGROUND MATERIAL
SOUTHERN	689977	8/24/2007 5:57	8/24/2007 21:40	942.9	S675	GOOD FARM TWP	1	FUSE	REPLACED FUSE
SOUTHERN	689977	8/24/2007 5:57	8/24/2007 21:40	942.9	S675	MAZON TWP	22	FUSE	REPLACED FUSE
SOUTHERN	689977	8/24/2007 5:57	8/24/2007 21:40	942.9	S675	WAUPONSEE TWP	1	FUSE	REPLACED FUSE
SOUTHERN	690696	8/24/2007 5:57	8/25/2007 16:50	2093	G6085	ALSIP	46	CABLE	REPAIRED UNDERGROUND MATERIAL
SOUTHERN	690696	8/24/2007 5:57	8/25/2007 19:15	2238	G6085	ALSIP	13	CABLE	REPAIRED UNDERGROUND MATERIAL
SOUTHERN	691587	8/24/2007 5:57	8/26/2007 17:34	3576.4	G148	WORTH	4	FUSE	REPLACED FUSE
CHICAGO	690551	8/24/2007 5:58	8/25/2007 17:35	2136.5	28TH246	WARD22	19	TRANSFORMER-OVHD	REPLACED TRANSFORMER
NORTHERN	690768	8/24/2007 5:58	8/25/2007 21:30	2371.5	X4871	NORRIDGE	1	CONNECTOR-COMP. FULL TSN.	REPLACED OVERHEAD MATERIAL
SOUTHERN	689572	8/24/2007 5:59	8/24/2007 12:15	375.2	K395	BOURBONNAIS TWP	1	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE
SOUTHERN	689572	8/24/2007 5:59	8/24/2007 12:15	375.2	K395	GANEER TWP	29	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE
SOUTHERN	689604	8/24/2007 5:59	8/24/2007 12:20	380.4	J5673	JOLIET	182	FUSE	TREE REMOVED
SOUTHERN	690117	8/24/2007 5:59	8/25/2007 2:16	1216.6	F572	FLOSSMOOR	166	TRANSFORMER-3:1	DISCONNECT EQUIPMENT
SOUTHERN	690117	8/24/2007 5:59	8/25/2007 2:16	1216.6	F572	BLOOM TWP	106	TRANSFORMER-3:1	DISCONNECT EQUIPMENT
SOUTHERN	690117	8/24/2007 5:59	8/25/2007 2:16	1216.6	F572	OLYMPIA FIELDS	703	TRANSFORMER-3:1	DISCONNECT EQUIPMENT
SOUTHERN	690117	8/24/2007 5:59	8/25/2007 2:16	1216.6	F572	PARK FOREST	22	TRANSFORMER-3:1	DISCONNECT EQUIPMENT
SOUTHERN	690117	8/24/2007 5:59	8/25/2007 2:16	1216.6	F572	CHICAGO HEIGHTS	427	TRANSFORMER-3:1	DISCONNECT EQUIPMENT
SOUTHERN	690117	8/24/2007 5:59	8/25/2007 2:16	1216.6	F572	RICH TWP	24	TRANSFORMER-3:1	DISCONNECT EQUIPMENT
SOUTHERN	690117	8/24/2007 5:59	8/25/2007 2:28	1228.6	F572	CHICAGO HEIGHTS	4	TRANSFORMER-3:1	DISCONNECT EQUIPMENT
SOUTHERN	690117	8/24/2007 5:59	8/25/2007 2:28	1228.6	F572	PARK FOREST	159	TRANSFORMER-3:1	DISCONNECT EQUIPMENT
CHICAGO	690273	8/24/2007 5:59	8/25/2007 8:50	1610.1	Y3833	WARD26	68	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE
SOUTHERN	690563	8/24/2007 5:59	8/25/2007 16:45	2085.9	J3681	CRESTHILL	72	CABLE	TEMPORARY SWITCHING
SOUTHERN	690669	8/24/2007 5:59	8/25/2007 19:30	2250.4	G1989	ORLAND PARK	22	FUSE	REPLACED FUSE
NORTHERN	689497	8/24/2007 6:01	8/24/2007 10:55	293.8	D0502	OAK PARK	23	FUSE	REPLACED FUSE
NORTHERN	689530	8/24/2007 6:02	8/24/2007 11:22	319.4	C046Y	LINCOLNSHIRE	9	CUTOUT	REPLACED OVERHEAD MATERIAL
NORTHWEST	689780	8/24/2007 6:02	8/24/2007 16:45	643	W8123	NAPERVILLE TWP	7	CABLE	TEMPORARY SWITCHING
NORTHWEST	689780	8/24/2007 6:02	8/24/2007 17:00	658	W8123	NAPERVILLE TWP	12	CABLE	TEMPORARY SWITCHING
NORTHWEST	689974	8/24/2007 6:02	8/24/2007 21:30	927.8	W392	CAMPTON TWP	3	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
CHICAGO	691120	8/24/2007 6:02	8/26/2007 9:45	3102.3	310X352	WARD33	73	TRANSFORMER-OVHD	REPLACED FUSE

REGION_NAME	OUTAGE_ID	START_DATETIME	DATETIME_RSTD	DURATION _MINUTES	AS_BUILT _FEEDER _LINE	TOWN NAME	PREM _COUNT	EQUIPMENT_INVOLVED	RESTORATION_MEDIATION
NORTHERN	691761	8/24/2007 6:03	8/25/2007 14:07	1923.4	W434	ELMHURST	33	PHASE WIRE (ALL VOLTAGES)	TEMPORARY SWITCHING
NORTHERN	691761	8/24/2007 6:03	8/26/2007 20:25	3741.4	W434	ELMHURST	32	PHASE WIRE (ALL VOLTAGES)	TEMPORARY SWITCHING
NORTHERN	691843	8/24/2007 6:03	8/26/2007 21:44	3820.7	D6414	HILLSIDE	17	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
SOUTHERN	701616	8/24/2007 6:03	8/24/2007 17:10	666.4	S195	TONICA	2	TRANSFORMER-OVHD	CLOSED FUSE
SOUTHERN	691084	8/24/2007 6:04	8/26/2007 9:00	3055.2	K187	MOMENCE TWP	1	CUTOUT	REPLACED CUTOUT
NORTHERN	691891	8/24/2007 6:04	8/26/2007 22:35	3870.9	E707	ARLINGTON HEIGHTS	15	FUSE	REPLACED FUSE
NORTHERN	689527	8/24/2007 6:05	8/24/2007 9:21	195.3	E4809	VERNON TWP	1	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE
SOUTHERN	690027	8/24/2007 6:05	8/24/2007 23:00	1014.4	F175	WILL TWP	1	FUSE	REPLACED FUSE
NORTHERN	692311	8/24/2007 6:05	8/27/2007 11:45	4659.6	E2007	SCHAUMBURG TWP	1	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHERN	689725	8/24/2007 6:06	8/24/2007 16:05	598.5	W7410	WAYNE TWP	54	PHASE WIRE (ALL VOLTAGES)	REPLACED OVERHEAD MATERIAL
NORTHWEST	690527	8/24/2007 6:06	8/25/2007 12:56	1849.4	W259	RUTLAND TWP	1	PHASE WIRE (ALL VOLTAGES)	TREE REMOVED
CHICAGO	690588	8/24/2007 6:06	8/25/2007 18:00	2153.5	X3251	WARD37	96	FUSE	REPAIRED OVERHEAD MATERIAL
NORTHERN	690650	8/24/2007 6:06	8/25/2007 19:18	2232	E339	NORTH BARRINGTON	3	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHERN	691854	8/24/2007 6:06	8/26/2007 13:01	3295	E023	PALATINE	28	CABLE	TEMPORARY SWITCHING
NORTHWEST	689981	8/24/2007 6:07	8/24/2007 20:47	879.6	W351	ELGIN	26	ELBOW	TEMPORARY SWITCHING
NORTHWEST	689981	8/24/2007 6:07	8/24/2007 20:47	879.6	W351	ELGIN TWP	2	ELBOW	TEMPORARY SWITCHING
CHICAGO	691187	8/24/2007 6:08	8/26/2007 11:15	3186.3	798Y45	WARD27	8	FUSE	REPLACED FUSE
NORTHWEST	689549	8/24/2007 6:09	8/24/2007 12:00	350.1	R8482	ROCKFORD	2	TRANSFORMER-OVHD	REPLACED TRANSFORMER
NORTHWEST	689550	8/24/2007 6:09	8/24/2007 11:00	290.9	W196	BLACKBERRY TWP	18	CABLE	TEMPORARY SWITCHING
NORTHWEST	689550	8/24/2007 6:09	8/24/2007 11:05	295.9	W196	BLACKBERRY TWP	3	CABLE	TEMPORARY SWITCHING
SOUTHERN	689743	8/24/2007 6:09	8/24/2007 16:50	640.7	W3601	DOWNERS GROVE TWP	1	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHWEST	689437	8/24/2007 6:10	8/24/2007 7:35	84.8	H1782	GR DETOUR-DIXON TWP	4	FUSE	REPLACED FUSE
NORTHWEST	689546	8/24/2007 6:10	8/24/2007 8:45	154.3	H322	ERIE-PORTLAND TWP	20	PHASE WIRE (ALL VOLTAGES)	REPLACED OVERHEAD MATERIAL
NORTHWEST	689546	8/24/2007 6:10	8/24/2007 11:00	289.3	H322	ERIE-PORTLAND TWP	3	PHASE WIRE (ALL VOLTAGES)	REPLACED OVERHEAD MATERIAL
NORTHWEST	689669	8/24/2007 6:11	8/24/2007 15:25	553.3	W633	HANOVER TWP	3	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE
NORTHERN	689948	8/24/2007 6:11	8/24/2007 21:15	903.3	C627	GLENCOE	18	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
SOUTHERN	690153	8/24/2007 6:11	8/25/2007 2:50	1238.1	J4973	DIAMOND	9	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE
SOUTHERN	691552	8/24/2007 6:11	8/25/2007 3:45	1293.1	G4373	HAZELCREST	116	PHASE WIRE (ALL VOLTAGES)	DISCONNECT OVERHEAD MATERIAL
SOUTHERN	691552	8/24/2007 6:11	8/26/2007 17:15	3543.1	G4373	HAZELCREST	14	PHASE WIRE (ALL VOLTAGES)	DISCONNECT OVERHEAD MATERIAL
SOUTHERN	690019	8/24/2007 6:12	8/24/2007 17:20	667.7	K7072	BOURBONNAIS TWP	21	PHASE WIRE (ALL VOLTAGES)	REPLACED TRANSFORMER
SOUTHERN	690019	8/24/2007 6:12	8/24/2007 21:00	887.7	K7072	BOURBONNAIS TWP	9	PHASE WIRE (ALL VOLTAGES)	REPLACED TRANSFORMER
NORTHWEST	690034	8/24/2007 6:13	8/24/2007 23:42	1048.5	W748	HANOVER PARK	1	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
SOUTHERN	690377	8/24/2007 6:13	8/25/2007 12:35	1821.4	S276	DEER PARK TWP	7	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHERN	691075	8/24/2007 6:13	8/25/2007 16:30	2056.4	C7225	GLENVIEW	14	POLE	TREE REMOVED
NORTHERN	693975	8/24/2007 6:13	8/28/2007 22:00	6706.6	C2917	NILES	1	FUSE/CUTOUT	REPAIRED UNDERGROUND MATERIAL
SOUTHERN	700456	8/24/2007 6:13	8/26/2007 18:30	3616.7	J3985	JOLIET	2	FUSE	REPLACED FUSE
NORTHWEST	689716	8/24/2007 6:14	8/24/2007 16:00	585.7	B646	LAFAYETTE-ASHTN TWP	1	TRANSFORMER-OVHD	REPLACED TRANSFORMER
SOUTHERN	689894	8/24/2007 6:14	8/24/2007 20:15	841	J1684	HOMER TWP	5	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
CHICAGO	689543	8/24/2007 6:15	8/24/2007 11:35	319.1	Z83432	WARD5	21	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE
CHICAGO	689543	8/24/2007 6:15	8/24/2007 11:35	319.1	Z83432	WARD7	43	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE
SOUTHERN	689869	8/24/2007 6:15	8/24/2007 12:55	399.4	G148	PALOS HILLS	10	FUSE	REPLACED FUSE
SOUTHERN	689869	8/24/2007 6:15	8/24/2007 12:56	400.4	G148	PALOS HILLS	1	FUSE	REPLACED FUSE
NORTHERN	691160	8/24/2007 6:15	8/26/2007 11:32	3196.2	C133	DEERFIELD	35	FUSE	REPLACED FUSE
NORTHWEST	689488	8/24/2007 6:16	8/24/2007 7:45	88.6	H147	NORTHVILLE TWP	2	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE
CHICAGO	689934	8/24/2007 6:16	8/24/2007 17:00	644	Z13746	WARD17	51	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE
SOUTHERN	690536	8/24/2007 6:17	8/25/2007 16:33	2055.8	F5381	MONEE TWP	8	FUSE	TREE REMOVED
SOUTHERN	690652	8/24/2007 6:17	8/25/2007 19:24	2226.9	G4376	EAST HAZELCREST	47	CABLE-AERIAL	REPAIRED OVERHEAD MATERIAL
SOUTHERN	691050	8/24/2007 6:17	8/24/2007 14:00	462.6	G148	PALOS HILLS	1	FUSE	REPLACED FUSE

REGION_NAME	OUTAGE_ID	START_DATETIME	DATETIME_RSTD	DURATION_MINUTES	AS_BUILT_FEEDER_LINE	TOWN NAME	PREM_COUNT	EQUIPMENT_INVOLVED	RESTORATION_MEDIATION
CHICAGO	692045	8/24/2007 6:17	8/24/2007 18:02	704.7	Z4332	WARD9	30	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHWEST	689804	8/24/2007 6:18	8/24/2007 18:15	716.3	W258	HAMPSHIRE	1	FUSE	REPLACED FUSE
NORTHWEST	689804	8/24/2007 6:18	8/24/2007 18:15	716.3	W258	HAMPSHIRE TWP	10	FUSE	REPLACED FUSE
NORTHERN	691198	8/24/2007 6:18	8/26/2007 11:30	3191.7	C536	EVANSTON	61	PHASE WIRE (ALL VOLTAGES)	REPLACED OVERHEAD MATERIAL
SOUTHERN	691461	8/24/2007 6:18	8/26/2007 15:57	3458.2	G4083	WORTH TWP	8	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE
SOUTHERN	689772	8/24/2007 6:19	8/24/2007 17:01	641.6	G657	SOUTH HOLLAND	131	FUSE	CLOSED FUSE
NORTHWEST	690077	8/24/2007 6:19	8/24/2007 18:50	750.1	W7703	ST CHARLES TWP	2	FUSE	REPLACED FUSE
SOUTHERN	689580	8/24/2007 6:20	8/24/2007 12:15	354.3	W4101	DOWNERS GROVE TWP	9	FUSE	REPLACED FUSE
SOUTHERN	689831	8/24/2007 6:20	8/24/2007 18:48	747.5	F458	CRETE TWP	75	FUSE	REPLACED FUSE
NORTHERN	689926	8/24/2007 6:21	8/24/2007 21:01	879.3	C723	MORTON GROVE	143	FUSE	REPLACED FUSE
SOUTHERN	689719	8/24/2007 6:22	8/24/2007 16:30	607.1	S211	RICHLAND TWP	8	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE
CHICAGO	689819	8/24/2007 6:22	8/24/2007 18:43	740.7	X7140	WARD41	19	FUSE	REPLACED FUSE
NORTHWEST	689748	8/24/2007 6:23	8/24/2007 16:50	626.5	W240	WEST DUNDEE	12	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHERN	691614	8/24/2007 6:23	8/25/2007 22:30	2407	W572	GLEN ELLYN	4	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHERN	691614	8/24/2007 6:23	8/25/2007 22:30	2407	W572	MILTON TWP	31	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHWEST	702184	8/24/2007 6:23	8/24/2007 16:30	606.8	W9208	OSWEGO TWP	1	TAP WIRE	REPAIRED OVERHEAD MATERIAL
CHICAGO	690758	8/24/2007 6:24	8/25/2007 19:50	2245.4	X5362	WARD47	88	PHASE WIRE (ALL VOLTAGES)	TEMPORARY SWITCHING
SOUTHERN	691308	8/24/2007 6:24	8/26/2007 14:23	3358.8	J8783	LOCKPORT TWP	16	POLE	REPAIRED OTHER
NORTHERN	691681	8/24/2007 6:24	8/26/2007 19:05	3640.1	C1711	PROSPECT HEIGHTS	8	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
CHICAGO	691725	8/24/2007 6:24	8/26/2007 19:59	3694.4	THRP34	WARD17	1	CABLE-AERIAL	REPLACED OVERHEAD MATERIAL
SOUTHERN	689878	8/24/2007 6:25	8/24/2007 19:45	799.3	W455Y	YORK TWP	1	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
SOUTHERN	689878	8/24/2007 6:25	8/24/2007 19:45	799.3	W455Y	DOWNERS GROVE	24	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHERN	692908	8/24/2007 6:25	8/27/2007 19:20	5094.8	C416	EVANSTON	18	POLE	REPLACED OVERHEAD MATERIAL
NORTHERN	691438	8/24/2007 6:27	8/26/2007 9:11	3043.7	C7213	MAINE TWP	27	FUSE	REPAIRED OVERHEAD MATERIAL
SOUTHERN	689592	8/24/2007 6:28	8/24/2007 13:00	391.3	K325	AROMA TWP	1	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE
SOUTHERN	689592	8/24/2007 6:28	8/24/2007 13:00	391.3	K325	AROMA PARK	30	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE
SOUTHERN	689649	8/24/2007 6:28	8/24/2007 14:45	496.5	K5773	AROMA TWP	11	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE
SOUTHERN	689728	8/24/2007 6:28	8/24/2007 16:45	616.5	G6186	BREMEN TWP	1	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
SOUTHERN	689906	8/24/2007 6:28	8/24/2007 20:00	811.4	S276	LOWELL	1	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
SOUTHERN	689906	8/24/2007 6:28	8/24/2007 20:00	811.4	S276	VERMILLION TWP	25	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
SOUTHERN	689906	8/24/2007 6:28	8/24/2007 20:00	811.4	S276	TONICA	1	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
SOUTHERN	690333	8/24/2007 6:28	8/25/2007 11:35	1746.1	F467	LANSING	27	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE
NORTHERN	690769	8/24/2007 6:28	8/25/2007 19:00	2191.9	C7213	GLENVIEW	30	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE
NORTHERN	690991	8/24/2007 6:28	8/24/2007 11:54	326.2	W9502	WINFIELD TWP	46	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHERN	690991	8/24/2007 6:28	8/24/2007 11:54	326.2	W9502	CAROL STREAM	188	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHERN	690991	8/24/2007 6:28	8/24/2007 11:54	326.2	W9502	BLOOMINGDALE TWP	7	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHERN	690991	8/24/2007 6:28	8/24/2007 11:54	326.2	W9502	WAYNE TWP	39	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHERN	693128	8/24/2007 6:28	8/28/2007 3:50	5601.3	W4570	YORK TWP	5	TRANSFORMER-OVHD	CHANGED SIZE
SOUTHERN	689771	8/24/2007 6:29	8/24/2007 16:30	600.4	J165	JOLIET	16	FUSE	REPLACED FUSE
SOUTHERN	689799	8/24/2007 6:29	8/24/2007 18:22	712.3	G6185	CRESTWOOD	1	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
SOUTHERN	690043	8/24/2007 6:29	8/24/2007 22:30	960.3	K5781	KANKAKEE TWP	1	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE
SOUTHERN	690043	8/24/2007 6:29	8/24/2007 22:30	960.3	K5781	OTTO TWP	18	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE
SOUTHERN	690043	8/24/2007 6:29	8/25/2007 0:00	1050.3	K5781	OTTO TWP	6	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE
SOUTHERN	690043	8/24/2007 6:29	8/25/2007 0:00	1050.3	K5781	KANKAKEE TWP	1	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE
NORTHWEST	689435	8/24/2007 6:30	8/24/2007 7:00	29.9	B526	MARYLND-LEAF RVR TP	2	FUSE	REPLACED FUSE
SOUTHERN	689564	8/24/2007 6:30	8/24/2007 11:30	299.5	K187	MOMENCE TWP	6	CABLE	TEMPORARY SWITCHING
SOUTHERN	689564	8/24/2007 6:30	8/24/2007 12:15	344.5	K187	MOMENCE TWP	4	CABLE	TEMPORARY SWITCHING
NORTHWEST	690008	8/24/2007 6:30	8/24/2007 22:30	960	B162	BURLINGTON TWP	1	CROSS-ARM	REPAIRED OVERHEAD MATERIAL

REGION_NAME	OUTAGE_ID	START_DATETIME	DATETIME_RSTD	DURATION _MINUTES	AS_BUILT _FEEDER _LINE	TOWN NAME	PREM _COUNT	EQUIPMENT_INVOLVED	RESTORATION_MEDIATION
NORTHWEST	690008	8/24/2007 6:30	8/24/2007 22:30	960	B162	BURLINGTON	10	CROSS-ARM	REPAIRED OVERHEAD MATERIAL
NORTHERN	691345	8/24/2007 6:31	8/26/2007 13:48	3316.6	W0109	ITASCA	16	FUSE	REPLACED FUSE
NORTHWEST	689432	8/24/2007 6:32	8/24/2007 7:28	55.1	W162	DUNDEE TWP	2	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE
NORTHWEST	689456	8/24/2007 6:32	8/24/2007 8:45	132.9	H445	OHIO TWP	1	FUSE	REPLACED FUSE
SOUTHERN	690129	8/24/2007 6:32	8/25/2007 2:50	1217.9	K5777	LIMESTONE TWP	5	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE
NORTHERN	691226	8/24/2007 6:32	8/26/2007 11:45	3192.5	D0506	RIVER FOREST	14	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
SOUTHERN	690547	8/24/2007 6:33	8/25/2007 16:30	2036.2	J4082	FRANKFORT TWP	5	FUSE	REPLACED FUSE
SOUTHERN	690547	8/24/2007 6:33	8/25/2007 16:30	2036.2	J4082	MOKENA	14	FUSE	REPLACED FUSE
SOUTHERN	692097	8/24/2007 6:33	8/25/2007 18:20	2147	J4971	WILMINGTON TWP	11	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
SOUTHERN	692097	8/24/2007 6:33	8/25/2007 18:20	2147	J4971	WILMINGTON	32	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
SOUTHERN	692097	8/24/2007 6:33	8/27/2007 3:35	4142.9	J4971	CUSTER TWP	2	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHERN	700193	8/24/2007 6:33	8/25/2007 12:24	1790.1	W9514	MILTON TWP	6	FUSE	TREE REMOVED
SOUTHERN	703303	8/24/2007 6:33	8/24/2007 19:15	761	J765	SENECA	4	TRANSFORMER-OVHD	REPLACED TRANSFORMER
SOUTHERN	690261	8/24/2007 6:34	8/25/2007 8:30	1555.1	K5781	OTTO TWP	2	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE
SOUTHERN	690905	8/24/2007 6:34	8/25/2007 13:10	1835.9	G1978X	ORLAND PARK	1	CABLE	REPAIRED UNDERGROUND MATERIAL
SOUTHERN	690905	8/24/2007 6:34	8/25/2007 20:30	2275.9	G1978X	ORLAND PARK	1	CABLE	REPAIRED UNDERGROUND MATERIAL
NORTHWEST	689460	8/24/2007 6:35	8/24/2007 9:30	175	E286	DUNDEE TWP	34	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE
NORTHWEST	689813	8/24/2007 6:35	8/24/2007 18:30	714.2	B7583	DEKALB	13	FUSE	REPLACED FUSE
SOUTHERN	689839	8/24/2007 6:35	8/24/2007 18:50	735	J0613	LOCKPORT TWP	1	TAP WIRE	INSTALL OVERHEAD MATERIAL
SOUTHERN	690132	8/24/2007 6:35	8/25/2007 3:00	1224.1	K455	AROMA TWP	3	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE
SOUTHERN	690621	8/24/2007 6:35	8/25/2007 17:30	2094.6	K155	WESLEY TWP	9	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
SOUTHERN	690735	8/24/2007 6:35	8/25/2007 19:30	2214.3	G6195	ALSIP	13	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
SOUTHERN	691266	8/24/2007 6:35	8/24/2007 20:45	849.3	J0613	NEW LENOX TWP	34	PHASE WIRE (ALL VOLTAGES)	REPLACED OVERHEAD MATERIAL
SOUTHERN	691266	8/24/2007 6:35	8/26/2007 0:00	2484.3	J0613	NEW LENOX TWP	16	PHASE WIRE (ALL VOLTAGES)	REPLACED OVERHEAD MATERIAL
NORTHERN	689638	8/24/2007 6:37	8/24/2007 14:00	442.1	C161	MOUNT PROSPECT	27	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHERN	690612	8/24/2007 6:37	8/25/2007 17:35	2097.2	W2013	BLOOMINGDALE TWP	15	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHERN	690612	8/24/2007 6:37	8/25/2007 17:35	2097.2	W2013	GLENDALE HEIGHTS	2	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
SOUTHERN	689475	8/24/2007 6:38	8/24/2007 9:30	171.8	J585	MANHATTAN TWP	12	PHASE WIRE (ALL VOLTAGES)	OTHER NO FURTHER DETAIL
SOUTHERN	689475	8/24/2007 6:38	8/24/2007 9:30	171.8	J585	WILTON TWP	7	PHASE WIRE (ALL VOLTAGES)	OTHER NO FURTHER DETAIL
NORTHWEST	689750	8/24/2007 6:38	8/24/2007 17:00	621.9	W391	ST CHARLES TWP	29	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE
SOUTHERN	689898	8/24/2007 6:38	8/24/2007 20:25	826.1	W032	LISLE TWP	1	POLE TOP EXTENSION	REPAIRED OVERHEAD MATERIAL
NORTHERN	690804	8/24/2007 6:38	8/25/2007 21:50	2351.3	W572	WEST CHICAGO	1	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHERN	690804	8/24/2007 6:38	8/25/2007 21:50	2351.3	W572	GLEN ELLYN	776	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHERN	690804	8/24/2007 6:38	8/25/2007 21:50	2351.3	W572	MILTON TWP	31	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHERN	691061	8/24/2007 6:38	8/25/2007 15:45	1986.1	W653	ROSELLE	3	PHASE WIRE (ALL VOLTAGES)	CLOSED FUSE
NORTHERN	691061	8/24/2007 6:38	8/25/2007 15:45	1986.1	W653	BLOOMINGDALE TWP	29	PHASE WIRE (ALL VOLTAGES)	CLOSED FUSE
SOUTHERN	689496	8/24/2007 6:39	8/24/2007 9:00	140.4	W3605	BURR RIDGE	1	FUSE	REPLACED FUSE
SOUTHERN	689496	8/24/2007 6:39	8/24/2007 9:00	140.4	W3605	HINSDALE	19	FUSE	REPLACED FUSE
NORTHERN	690998	8/24/2007 6:39	8/24/2007 11:25	285.4	C9814Y	ROSEMONT	25	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHERN	690998	8/24/2007 6:39	8/24/2007 11:25	285.4	C9814Y	PARK RIDGE	1	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHERN	690998	8/24/2007 6:39	8/24/2007 11:25	285.4	C9814Y	DES PLAINES	251	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHERN	690998	8/24/2007 6:39	8/25/2007 0:25	1066.4	C9814Y	ROSEMONT	1	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHERN	690998	8/24/2007 6:39	8/25/2007 2:49	1209.4	C9814Y	DES PLAINES	9	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
SOUTHERN	700457	8/24/2007 6:39	8/25/2007 14:00	1880.2	J765	ERIENNA TWP	2	TRANSFORMER-OVHD	REPLACED TRANSFORMER
SOUTHERN	689545	8/24/2007 6:40	8/24/2007 11:57	316.5	D41	LA GRANGE	11	FUSE	REPLACED FUSE
SOUTHERN	689545	8/24/2007 6:40	8/24/2007 11:57	316.5	D41	BOLINGBROOK	1	FUSE	REPLACED FUSE
NORTHERN	689702	8/24/2007 6:40	8/24/2007 13:48	428	C0913	ELA TWP	9	PHASE WIRE (ALL VOLTAGES)	CLOSED FUSE
NORTHERN	689702	8/24/2007 6:40	8/24/2007 13:48	428	C0913	LONG GROVE	1	PHASE WIRE (ALL VOLTAGES)	CLOSED FUSE

REGION_NAME	OUTAGE_ID	START_DATETIME	DATETIME_RSTD	DURATION_MINUTES	AS_BUILT_FEEDER_LINE	TOWN NAME	PREM_COUNT	EQUIPMENT_INVOLVED	RESTORATION_MEDIATION
NORTHWEST	690063	8/24/2007 6:40	8/24/2007 18:42	722.8	E3518	EAST DUNDEE	4	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHWEST	690063	8/24/2007 6:40	8/24/2007 22:20	940	E3518	EAST DUNDEE	7	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHWEST	690063	8/24/2007 6:40	8/24/2007 22:20	940	E3518	ELGIN	1	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHWEST	690063	8/24/2007 6:40	8/24/2007 22:20	940	E3518	DUNDEE TWP	29	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHWEST	690063	8/24/2007 6:40	8/25/2007 0:40	1080	E3518	DUNDEE TWP	1	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
SOUTHERN	690657	8/24/2007 6:40	8/25/2007 19:15	2194.8	F4782	LANSING	10	CUTOUT	REPLACED CUTOUT
CHICAGO	690072	8/24/2007 6:41	8/25/2007 23:57	2475.5	Z8947	WARD19	10	PHASE WIRE (ALL VOLTAGES)	TREE REMOVED
SOUTHERN	691822	8/24/2007 6:44	8/26/2007 20:00	3675.2	J325	WILMINGTON	2	POLE	REPLACED OVERHEAD MATERIAL
SOUTHERN	691822	8/24/2007 6:44	8/26/2007 20:00	3675.2	J325	WESLEY TWP	9	POLE	REPLACED OVERHEAD MATERIAL
NORTHERN	692834	8/24/2007 6:44	8/27/2007 19:46	5101.7	W656X	ITASCA	1	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
SOUTHERN	691285	8/24/2007 6:45	8/26/2007 13:50	3304.9	G6185	MIDLOTHIAN	18	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE
SOUTHERN	691647	8/24/2007 6:45	8/26/2007 18:15	3569.5	G6190	CRESTWOOD	1	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHWEST	690531	8/24/2007 6:46	8/25/2007 16:56	2049.6	E6022	EAST DUNDEE	13	PHASE WIRE (ALL VOLTAGES)	TREE REMOVED
SOUTHERN	691586	8/24/2007 6:46	8/26/2007 17:30	3523.8	F3582	COUNTRY CLUB HILLS	63	FUSE	REPLACED FUSE
SOUTHERN	689661	8/24/2007 6:47	8/24/2007 15:17	509.4	J696	BRACEVILLE	1	FUSE	CLOSED FUSE
SOUTHERN	690371	8/24/2007 6:47	8/25/2007 13:00	1812.2	G614	BREMEN TWP	7	FUSE	REPLACED FUSE
SOUTHERN	690371	8/24/2007 6:47	8/25/2007 13:00	1812.2	G614	CRESTWOOD	22	FUSE	REPLACED FUSE
NORTHERN	690670	8/24/2007 6:47	8/25/2007 19:40	2212.4	C423	WILMETTE	1	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
SOUTHERN	690978	8/24/2007 6:47	8/26/2007 3:25	2677	L0953	CHANNAHON TWP	1	FUSE	REPLACED FUSE
SOUTHERN	691078	8/24/2007 6:47	8/26/2007 8:00	2952.4	J176	TROY TWP	7	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE
NORTHWEST	689471	8/24/2007 6:48	8/24/2007 9:55	186.6	H393	MERIDEN TWP	2	FUSE	REPLACED FUSE
NORTHWEST	689495	8/24/2007 6:48	8/24/2007 10:44	235.4	B465	JORDON TWP	1	FUSE	REPLACED FUSE
NORTHWEST	689809	8/24/2007 6:48	8/24/2007 18:05	676.5	W258	PLATO TWP	2	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHERN	690368	8/24/2007 6:48	8/25/2007 12:51	1802.7	D4911	BERKELEY	1	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHERN	690578	8/24/2007 6:48	8/25/2007 18:01	2112.6	E3313	BARRINGTON HILLS	10	FUSE	CLOSED FUSE
SOUTHERN	690598	8/24/2007 6:48	8/25/2007 18:10	2121.6	G6190	ROBBINS	30	FUSE	REPLACED FUSE
SOUTHERN	690795	8/24/2007 6:48	8/25/2007 20:30	2261.4	G583	CALUMET CITY	35	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHERN	691080	8/24/2007 6:48	8/25/2007 18:00	2111.5	E0217	ROLLING MDWS	8	FUSE	REPLACED FUSE
SOUTHERN	690307	8/24/2007 6:49	8/25/2007 10:50	1680.1	K187	MOMENCE TWP	1	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE
SOUTHERN	691381	8/24/2007 6:49	8/26/2007 14:20	3330.2	G645	BLUE ISLAND	21	PHASE WIRE (ALL VOLTAGES)	INSTALL OVERHEAD MATERIAL
SOUTHERN	690185	8/24/2007 6:50	8/25/2007 4:00	1269.7	G4081	PALOS PARK	15	FUSE	REPLACED FUSE
SOUTHERN	690185	8/24/2007 6:50	8/25/2007 4:00	1269.7	G4081	PALOS TWP	14	FUSE	REPLACED FUSE
SOUTHERN	691239	8/24/2007 6:50	8/26/2007 12:45	3234.1	F576	MONEE TWP	3	FUSE	REPLACED FUSE
SOUTHERN	690674	8/24/2007 6:51	8/25/2007 19:30	2198.4	F295	PARK FOREST	25	CONNECTOR-BOLTED	REPLACED OTHER
NORTHERN	691893	8/24/2007 6:51	8/26/2007 19:00	3608.4	C427	WILMETTE	59	FUSE	REPLACED FUSE
NORTHERN	692119	8/24/2007 6:51	8/27/2007 5:00	4208.3	W0116	WOOD DALE	1	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHERN	692717	8/24/2007 6:51	8/27/2007 16:00	4868.3	C554	PARK RIDGE	34	FUSE	REPLACED FUSE
SOUTHERN	689448	8/24/2007 6:52	8/24/2007 8:30	97.2	J245	BIG GROVE TWP	3	FUSE	REPLACED FUSE
SOUTHERN	689448	8/24/2007 6:52	8/24/2007 8:30	97.2	J245	LISBON	2	FUSE	REPLACED FUSE
SOUTHERN	689972	8/24/2007 6:53	8/24/2007 18:20	686.6	S675	MAZON TWP	6	FUSE	REPLACED FUSE
SOUTHERN	689972	8/24/2007 6:53	8/24/2007 18:20	686.6	S675	GOOD FARM TWP	1	FUSE	REPLACED FUSE
SOUTHERN	690530	8/24/2007 6:53	8/25/2007 16:30	2016.6	W6130	WHEATLAND TWP	7	FUSE	REPLACED FUSE
SOUTHERN	690668	8/24/2007 6:53	8/25/2007 19:52	2218.2	F5283	FLOSSMOOR	9	CROSS ARM	REPLACED OVERHEAD MATERIAL
NORTHERN	692479	8/24/2007 6:53	8/27/2007 13:54	4740.9	C1220	GLENVIEW	28	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
SOUTHERN	689823	8/24/2007 6:54	8/24/2007 16:40	586	S675	MAZON TWP	1	FUSE	REPLACED FUSE
NORTHWEST	690170	8/24/2007 6:54	8/25/2007 5:00	1325.4	W6310	STREAMWOOD	67	POLE	REPAIRED OVERHEAD MATERIAL
CHICAGO	692062	8/24/2007 6:54	8/24/2007 21:28	874	111TH244	WARD19	152	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE
SOUTHERN	689609	8/24/2007 6:55	8/24/2007 13:37	401.8	W8010	DOWNERS GROVE	1	FUSE	REPLACED FUSE

REGION_NAME	OUTAGE_ID	START_DATETIME	DATETIME_RSTD	DURATION _MINUTES	AS_BUILT _FEEDER _LINE	TOWN NAME	PREM _COUNT	EQUIPMENT_INVOLVED	RESTORATION_MEDIATION
CHICAGO	690700	8/24/2007 6:55	8/25/2007 20:20	2244.2	Z11869	WARD21	39	TRANSFORMER-OVHD	REPLACED TRANSFORMER
NORTHERN	690846	8/24/2007 6:57	8/25/2007 13:30	1832.2	E5213Y	ELK GROVE VIL	11	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
SOUTHERN	691138	8/24/2007 6:57	8/26/2007 11:07	3129.2	J135	WAUPONSEE TWP	1	FUSE	REPLACED FUSE
NORTHERN	691519	8/24/2007 6:57	8/26/2007 17:15	3497.8	E521	MOUNT PROSPECT	13	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
SOUTHERN	691774	8/24/2007 6:58	8/26/2007 20:10	3671	G335	DOLTON	1	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHERN	695280	8/24/2007 6:58	8/24/2007 23:25	987	W356	WINFIELD TWP	11	PHASE WIRE (ALL VOLTAGES)	OTHER NO FURTHER DETAIL
NORTHERN	695280	8/24/2007 6:58	8/24/2007 23:25	987	W356	WEST CHICAGO	2	PHASE WIRE (ALL VOLTAGES)	OTHER NO FURTHER DETAIL
NORTHERN	691751	8/24/2007 7:00	8/25/2007 20:20	2239.1	E1423	HOFFMAN ESTATES	9	TAP WIRE	REPAIRED OVERHEAD MATERIAL
NORTHWEST	690006	8/24/2007 7:01	8/24/2007 19:50	768.4	W6905	SUGAR GROVE	4	CABLE	TEMPORARY SWITCHING
NORTHWEST	690006	8/24/2007 7:01	8/24/2007 19:50	768.4	W6905	SUGAR GROVE TWP	1	CABLE	TEMPORARY SWITCHING
NORTHERN	690222	8/24/2007 7:01	8/24/2007 22:00	898.8	C424	WILMETTE	63	PHASE WIRE (ALL VOLTAGES)	TREE REMOVED
NORTHWEST	689537	8/24/2007 7:02	8/24/2007 11:35	273	B905	VIRGIL TWP	2	FUSE	REPAIRED OVERHEAD MATERIAL
NORTHWEST	689768	8/24/2007 7:02	8/24/2007 17:24	621.4	W6310	STREAMWOOD	10	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHERN	691000	8/24/2007 7:02	8/25/2007 2:56	1194.4	W423	ELMHURST	139	PHASE WIRE (ALL VOLTAGES)	TREE REMOVED
NORTHERN	691615	8/24/2007 7:02	8/26/2007 12:00	3177.5	C1514	DES PLAINES	11	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE
SOUTHERN	689735	8/24/2007 7:03	8/24/2007 15:15	491.6	K325	AROMA TWP	7	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE
CHICAGO	690131	8/24/2007 7:03	8/25/2007 2:10	1147	Y2566	WARD11	26	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE
CHICAGO	690311	8/24/2007 7:03	8/25/2007 10:45	1662	Z8934	WARD34	1	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
SOUTHERN	689854	8/24/2007 7:05	8/24/2007 19:20	735	J3691	JOLIET	16	FUSE	REPLACED FUSE
SOUTHERN	691852	8/24/2007 7:05	8/26/2007 20:55	3709.5	F365	CRETE TWP	1	FUSE	REPLACED FUSE
SOUTHERN	690274	8/24/2007 7:06	8/25/2007 9:20	1573.9	J3311	MORRIS	13	FUSE	REPLACED FUSE
NORTHWEST	689741	8/24/2007 7:07	8/24/2007 11:55	287.5	H125	ALTO TWP	5	FUSE	REPLACED FUSE
SOUTHERN	689745	8/24/2007 7:07	8/24/2007 17:02	594.1	D291	LYONS TWP	1	CABLE AERIAL	REPAIRED OVERHEAD MATERIAL
NORTHERN	690746	8/24/2007 7:07	8/25/2007 18:15	2107.9	D514	STICKNEY	18	PHASE WIRE (ALL VOLTAGES)	TEMPORARY JUMPER TO RESTORE
CHICAGO	691703	8/24/2007 7:07	8/24/2007 17:30	622.8	315X646	WARD41	26	PHASE WIRE (ALL VOLTAGES)	TREE REMOVED
NORTHERN	691712	8/24/2007 7:09	8/26/2007 19:49	3639.4	D3301	RIVER GROVE	11	CABLE AERIAL	REPLACED OVERHEAD MATERIAL
NORTHWEST	689595	8/24/2007 7:10	8/24/2007 13:00	350	H537	LAKE HOLIDAY	12	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE
SOUTHERN	689654	8/24/2007 7:10	8/24/2007 14:15	424.1	K5773	OTTO TWP	3	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE
SOUTHERN	690593	8/24/2007 7:10	8/25/2007 18:05	2094.3	F5383	MONEE	22	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE
SOUTHERN	690593	8/24/2007 7:10	8/25/2007 18:05	2094.3	F5383	MONEE TWP	5	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE
SOUTHERN	690593	8/24/2007 7:10	8/25/2007 18:05	2094.3	F5383	LANSING	1	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE
SOUTHERN	691373	8/24/2007 7:10	8/26/2007 14:20	3309.7	G645	BLUE ISLAND	7	PHASE WIRE (ALL VOLTAGES)	INSTALL OVERHEAD MATERIAL
NORTHERN	691327	8/24/2007 7:11	8/26/2007 13:20	3248.8	C525	GOLF	8	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
SOUTHERN	690602	8/24/2007 7:13	8/25/2007 18:22	2108.4	F5283	HOMEWOOD	10	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE
NORTHERN	691186	8/24/2007 7:13	8/26/2007 11:29	3135.2	C536	EVANSTON	32	PHASE WIRE (ALL VOLTAGES)	REPLACED OVERHEAD MATERIAL
SOUTHERN	700201	8/24/2007 7:13	8/25/2007 15:58	1964.1	S675	WAUPONSEE TWP	2	FUSE	REPLACED FUSE
NORTHWEST	689788	8/24/2007 7:16	8/24/2007 17:40	623.3	W5618	NAPERVILLE TWP	1	TAP WIRE	REPAIRED OTHER
NORTHWEST	689788	8/24/2007 7:16	8/24/2007 17:40	623.3	W5618	AURORA	14	TAP WIRE	REPAIRED OTHER
NORTHERN	690461	8/24/2007 7:17	8/25/2007 13:30	1812.5	E5213Y	ELK GROVE VIL	1	TAP WIRE	REPAIRED OVERHEAD MATERIAL
SOUTHERN	689829	8/24/2007 7:21	8/24/2007 19:04	702.3	G616	MIDLOTHIAN	1	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHERN	690581	8/24/2007 7:21	8/25/2007 13:30	1808.6	C225	LINCOLNWOOD	1	CABLE-AERIAL	REPAIRED OVERHEAD MATERIAL
SOUTHERN	694336	8/24/2007 7:22	8/24/2007 20:00	757.2	K7084	BRADLEY	4	FUSE	REPLACED FUSE
CHICAGO	695285	8/24/2007 7:22	8/24/2007 8:28	66	Y1940	WARD2	400	PHASE WIRE (ALL VOLTAGES)	OTHER NO FURTHER DETAIL
CHICAGO	695285	8/24/2007 7:22	8/24/2007 8:28	66	Y1940	WARD3	2	PHASE WIRE (ALL VOLTAGES)	OTHER NO FURTHER DETAIL
SOUTHERN	690159	8/24/2007 7:23	8/25/2007 1:06	1062.1	S385	BRUCE TWP	1	FUSE	REPLACED FUSE
CHICAGO	692034	8/24/2007 7:23	8/27/2007 0:45	3921.1	X5351	WARD47	1	PHASE WIRE (ALL VOLTAGES)	INSTALL OVERHEAD MATERIAL
SOUTHERN	690245	8/24/2007 7:24	8/24/2007 21:20	836	J5141	MOKENA	63	CROSS-ARM	REPAIRED OVERHEAD MATERIAL
SOUTHERN	690245	8/24/2007 7:24	8/24/2007 21:20	836	J5141	FRANKFORT TWP	47	CROSS-ARM	REPAIRED OVERHEAD MATERIAL

REGION_NAME	OUTAGE_ID	START_DATETIME	DATETIME_RSTD	DURATION _MINUTES	AS_BUILT _FEEDER _LINE	TOWN NAME	PREM _COUNT	EQUIPMENT_INVOLVED	RESTORATION_MEDIATION
SOUTHERN	691037	8/24/2007 7:24	8/26/2007 5:40	2775.6	J696	BRACEVILLE TWP	1	FUSE	REPLACED FUSE
SOUTHERN	691037	8/24/2007 7:24	8/26/2007 5:40	2775.6	J696	BRAIDWOOD	1	FUSE	REPLACED FUSE
SOUTHERN	689784	8/24/2007 7:27	8/24/2007 17:30	602.9	S206	MINONK TWP	1	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE
SOUTHERN	689784	8/24/2007 7:27	8/24/2007 17:30	602.9	S206	GROVELAND TWP	6	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE
CHICAGO	689915	8/24/2007 7:27	8/24/2007 18:00	632.7	Z11869	WARD21	34	TRANSFORMER-OVHD	REPLACED TRANSFORMER
SOUTHERN	691126	8/24/2007 7:27	8/26/2007 10:30	3062	F596	RICH TWP	1	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
SOUTHERN	696698	8/24/2007 7:27	8/24/2007 17:45	617.6	K505	MOMENCE	1	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
CHICAGO	689782	8/24/2007 7:28	8/24/2007 15:40	491.9	Z11884	WARD8	44	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE
SOUTHERN	689933	8/24/2007 7:28	8/24/2007 18:05	636.5	S628	DWIGHT	1	FUSE	REPLACED FUSE
SOUTHERN	689933	8/24/2007 7:28	8/24/2007 18:05	636.5	S628	DWIGHT TWP	4	FUSE	REPLACED FUSE
CHICAGO	691874	8/24/2007 7:28	8/26/2007 22:11	3762.3	318X142	WARD29	47	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHERN	692654	8/24/2007 7:28	8/27/2007 16:27	4858.6	C124	NORTHFIELD	2	PHASE WIRE (ALL VOLTAGES)	REPLACED OVERHEAD MATERIAL
SOUTHERN	692148	8/24/2007 7:29	8/27/2007 6:00	4230.2	F126	STEGER	3	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
SOUTHERN	692148	8/24/2007 7:29	8/27/2007 6:00	4230.2	F126	CRETE	9	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
SOUTHERN	692148	8/24/2007 7:29	8/27/2007 6:00	4230.2	F126	CRETE TWP	5	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHERN	691894	8/24/2007 7:30	8/26/2007 17:30	3479.1	C587	WILMETTE	57	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHERN	690434	8/24/2007 7:32	8/25/2007 13:36	1803.7	C1711	PROSPECT HEIGHTS	1	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
SOUTHERN	691150	8/24/2007 7:32	8/26/2007 11:20	3107.6	G404	WORTH	1	TAP WIRE	REPAIRED OVERHEAD MATERIAL
SOUTHERN	691361	8/24/2007 7:32	8/26/2007 9:15	2982.8	G141	PALOS HILLS	1	CABLE	TEMPORARY SWITCHING
SOUTHERN	691361	8/24/2007 7:32	8/26/2007 11:36	3123.8	G141	PALOS HILLS	25	CABLE	TEMPORARY SWITCHING
NORTHERN	690429	8/24/2007 7:33	8/25/2007 14:32	1858.8	C464	DES PLAINES	1	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
SOUTHERN	691717	8/24/2007 7:33	8/26/2007 19:53	3619.6	J3675	JOLIET	1	CABLE-AERIAL	REPAIRED OVERHEAD MATERIAL
NORTHERN	690169	8/24/2007 7:34	8/25/2007 4:55	1280.3	C348	HIGHLAND PARK	14	PHASE WIRE (ALL VOLTAGES)	CLOSED OTHER
SOUTHERN	690293	8/24/2007 7:34	8/25/2007 10:21	1606.3	F522	CHICAGO HEIGHTS	1	FUSE	REPAIRED OVERHEAD MATERIAL
NORTHERN	693053	8/24/2007 7:37	8/26/2007 2:01	2543.8	W341	VILLA PARK	9	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHERN	693053	8/24/2007 7:37	8/27/2007 17:30	4912.8	W341	VILLA PARK	12	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHWEST	689620	8/24/2007 7:38	8/24/2007 14:15	396.5	W2002	CAMPTON TWP	21	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHERN	691890	8/24/2007 7:38	8/26/2007 22:30	3771.6	W2018	GLENDALE HEIGHTS	179	POLE	REPLACED OVERHEAD MATERIAL
NORTHERN	691890	8/24/2007 7:38	8/26/2007 22:30	3771.6	W2018	MILTON TWP	14	POLE	REPLACED OVERHEAD MATERIAL
NORTHERN	691890	8/24/2007 7:38	8/26/2007 22:30	3771.6	W2018	GLEN ELLYN	1	POLE	REPLACED OVERHEAD MATERIAL
NORTHWEST	689762	8/24/2007 7:39	8/24/2007 9:50	130.8	H595	PAW PAW TWP	1	FUSE	REPLACED FUSE
CHICAGO	689816	8/24/2007 7:39	8/24/2007 18:37	657.8	X7140	WARD41	16	FUSE	REPLACED FUSE
NORTHWEST	689901	8/24/2007 7:39	8/24/2007 20:30	770.1	B2301	GENOA TWP	1	FUSE	REPLACED FUSE
NORTHWEST	690174	8/24/2007 7:39	8/25/2007 5:05	1286	W9203	OSWEGO TWP	1	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
SOUTHERN	691580	8/24/2007 7:39	8/26/2007 15:30	3350.5	J195	LOCKPORT	6	FUSE	REPLACED FUSE
SOUTHERN	691661	8/24/2007 7:39	8/26/2007 18:35	3535.9	J7473	JOLIET TWP	1	DEAD END	REPAIRED OVERHEAD MATERIAL
NORTHERN	690626	8/24/2007 7:41	8/25/2007 18:51	2109.3	E4804	LAKE ZURICH	14	FUSE	REPLACED FUSE
SOUTHERN	689491	8/24/2007 7:43	8/24/2007 10:30	166.7	S375	STREATOR	47	FUSE	CLOSED FUSE
SOUTHERN	689729	8/24/2007 7:43	8/24/2007 16:45	541.7	W3603	HINSDALE	9	TRANSFORMER-OVHD	REPLACED TRANSFORMER
CHICAGO	691193	8/24/2007 7:43	8/26/2007 11:57	3134	X3978	WARD45	44	TRANSFORMER-NETWORK	REPLACED TRANSFORMER
NORTHERN	692732	8/24/2007 7:43	8/26/2007 18:15	3511.3	C564	WILMETTE	39	PHASE WIRE (ALL VOLTAGES)	REPLACED OVERHEAD MATERIAL
NORTHERN	692901	8/24/2007 7:45	8/27/2007 18:57	4991.1	C316	WILMETTE	9	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHWEST	689482	8/24/2007 7:48	8/24/2007 9:59	130.9	H495	FLAGG TWP	1	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
SOUTHERN	692356	8/24/2007 7:48	8/27/2007 12:40	4611.9	J1679	HOMER TWP	1	TRANSFORMER-OVHD	REPLACED TRANSFORMER
NORTHWEST	689925	8/24/2007 7:49	8/24/2007 18:43	653.9	W6905	SUGAR GROVE	1	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE
NORTHERN	690418	8/24/2007 7:49	8/25/2007 13:19	1769.5	E5213Y	ELK GROVE VIL	1	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
SOUTHERN	690683	8/24/2007 7:49	8/25/2007 20:17	2187.8	J245	LISBON TWP	4	PHASE WIRE (ALL VOLTAGES)	REPLACED OVERHEAD MATERIAL
SOUTHERN	690683	8/24/2007 7:49	8/25/2007 20:17	2187.8	J245	KENDALL TWP	6	PHASE WIRE (ALL VOLTAGES)	REPLACED OVERHEAD MATERIAL

REGION_NAME	OUTAGE_ID	START_DATETIME	DATETIME_RSTD	DURATION _MINUTES	AS_BUILT _FEEDER _LINE	TOWN NAME	PREM _COUNT	EQUIPMENT_INVOLVED	RESTORATION_MEDIATION
SOUTHERN	690744	8/24/2007 7:50	8/25/2007 14:00	1809.4	F3588	TINLEY PARK	15	FUSE	REPLACED FUSE
SOUTHERN	690744	8/24/2007 7:50	8/25/2007 20:00	2169.4	F3588	TINLEY PARK	3	FUSE	REPLACED FUSE
NORTHERN	689866	8/24/2007 7:52	8/24/2007 16:38	525.8	A282	GRANT TWP	1	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHERN	689866	8/24/2007 7:52	8/24/2007 16:38	525.8	A282	INGLESIDE	1	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
CHICAGO	690734	8/24/2007 7:52	8/25/2007 20:57	2224.8	Z3351	WARD13	24	CABLE-AERIAL	REPAIRED OVERHEAD MATERIAL
NORTHWEST	690762	8/24/2007 7:53	8/25/2007 12:30	1716.1	W2002	CAMPTON TWP	1	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHERN	691002	8/24/2007 7:53	8/25/2007 14:50	1856.4	E5223Y	DES PLAINES	382	NEUTRAL WIRE	REPAIRED OVERHEAD MATERIAL
NORTHERN	691002	8/24/2007 7:53	8/25/2007 14:50	1856.4	E5223Y	MOUNT PROSPECT	926	NEUTRAL WIRE	REPAIRED OVERHEAD MATERIAL
SOUTHERN	691859	8/24/2007 7:54	8/26/2007 21:30	3695.3	G4377	MARKHAM	8	CABLE-AERIAL	REPAIRED OVERHEAD MATERIAL
NORTHERN	689514	8/24/2007 7:55	8/24/2007 11:02	186.2	E4001	LAKE BARRINGTON	3	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE
NORTHWEST	689514	8/24/2007 7:55	8/24/2007 11:02	186.2	E4001	CARY	23	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE
NORTHWEST	689514	8/24/2007 7:55	8/24/2007 11:02	186.2	E4001	WOODSTOCK	1	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE
NORTHERN	689514	8/24/2007 7:55	8/24/2007 11:02	186.2	E4001	FOX RIVER GR	156	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE
NORTHWEST	689514	8/24/2007 7:55	8/24/2007 11:02	186.2	E4001	CUBA TWP	111	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE
NORTHERN	689514	8/24/2007 7:55	8/24/2007 11:02	186.2	E4001	BARRINGTON HILLS	12	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE
NORTHWEST	689514	8/24/2007 7:55	8/24/2007 11:02	186.2	E4001	ALGONQUIN TWP	309	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE
NORTHERN	689514	8/24/2007 7:55	8/24/2007 11:02	186.2	E4001	ALGONQUIN TWP	10	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE
NORTHERN	691145	8/24/2007 7:55	8/26/2007 11:05	3069.5	C314	NORTHFIELD	1	POLE	REPAIRED OVERHEAD MATERIAL
SOUTHERN	690280	8/24/2007 7:57	8/25/2007 7:45	1427.4	J167	JOLIET	13	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE
SOUTHERN	690464	8/24/2007 7:58	8/25/2007 15:00	1861.9	J245	LISBON TWP	7	FUSE	REPLACED FUSE
NORTHERN	692376	8/24/2007 7:58	8/27/2007 12:10	4571.3	C7214	MORTON GROVE	8	FUSE	TREE REMOVED
SOUTHERN	689581	8/24/2007 8:00	8/24/2007 13:00	299.2	K206	MANTENO	12	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE
CHICAGO	690817	8/24/2007 8:00	8/25/2007 23:01	2341	Y13047	WARD22	41	TRANSFORMER-OVHD	REPLACED TRANSFORMER
NORTHERN	692932	8/24/2007 8:00	8/27/2007 13:50	4669.8	C316	WILMETTE	5	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
SOUTHERN	690584	8/24/2007 8:08	8/24/2007 18:08	599.5	W3607	DARIEN	1	CABLE	REPAIRED UNDERGROUND MATERIAL
NORTHERN	693032	8/24/2007 8:08	8/27/2007 23:10	5221.9	C8814	SKOKIE	16	PHASE WIRE (ALL VOLTAGES)	REPLACED OVERHEAD MATERIAL
CHICAGO	691154	8/24/2007 8:10	8/26/2007 11:00	3049	X5457	WARD26	82	PHASE WIRE (ALL VOLTAGES)	REPLACED OVERHEAD MATERIAL
CHICAGO	691088	8/24/2007 8:12	8/26/2007 9:38	2965.9	Z11870	WARD21	1	PHASE WIRE (ALL VOLTAGES)	REPLACED OVERHEAD MATERIAL
CHICAGO	691379	8/24/2007 8:12	8/26/2007 15:17	3304.9	L9066	WARD43	16	CABLE-AERIAL	REPAIRED OVERHEAD MATERIAL
NORTHERN	691791	8/24/2007 8:12	8/26/2007 20:45	3633	C7215	NORTHFIELD TWP	8	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHWEST	690055	8/24/2007 8:13	8/24/2007 19:00	647	W744	HANOVER PARK	94	PHASE WIRE (ALL VOLTAGES)	TREE REMOVED
CHICAGO	690917	8/24/2007 8:15	8/26/2007 2:32	2536.5	X8457	WARD47	1	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
SOUTHERN	689664	8/24/2007 8:16	8/24/2007 11:45	208.6	J155	MANHATTAN TWP	5	POLE	TEMPORARY SWITCHING
SOUTHERN	689664	8/24/2007 8:16	8/24/2007 11:45	208.6	J155	JACKSON TWP	19	POLE	TEMPORARY SWITCHING
SOUTHERN	689664	8/24/2007 8:16	8/24/2007 11:45	208.6	J155	ELWOOD	1	POLE	TEMPORARY SWITCHING
SOUTHERN	690074	8/24/2007 8:16	8/25/2007 0:30	973.2	S475	GARFIELD TWP	1	CUTOUT	REPLACED CUTOUT
SOUTHERN	691260	8/24/2007 8:16	8/26/2007 11:20	3063.5	G091	DOLTON	15	FUSE	REPLACED FUSE
CHICAGO	692147	8/24/2007 8:16	8/26/2007 16:39	3382.7	304X048	WARD50	8	CROSS-ARM	REPAIRED OVERHEAD MATERIAL
CHICAGO	691692	8/24/2007 8:17	8/25/2007 8:26	1448.4	300X056	WARD47	1	PHASE WIRE (ALL VOLTAGES)	REPLACED OVERHEAD MATERIAL
NORTHWEST	689734	8/24/2007 8:18	8/24/2007 16:54	515.2	H526	ADAMS TWP	1	FUSE	REPLACED FUSE
SOUTHERN	690687	8/24/2007 8:18	8/25/2007 20:00	2141	G6588	THORNTON TWP	9	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE
SOUTHERN	690687	8/24/2007 8:18	8/25/2007 20:00	2141	G6588	CALUMET CITY	1	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE
SOUTHERN	691366	8/24/2007 8:18	8/26/2007 15:02	3283.2	G4072	PALOS PARK	3	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
SOUTHERN	691274	8/24/2007 8:20	8/26/2007 12:30	3129.2	J7473	JACKSON TWP	5	CUTOUT	REPLACED EQUIPMENT
SOUTHERN	690505	8/24/2007 8:21	8/25/2007 15:18	1856.8	F962	CHICAGO HEIGHTS	65	CROSS-ARM BRACE	REPLACED OTHER
NORTHERN	690753	8/24/2007 8:22	8/25/2007 21:05	2202.1	D515	LYONS	34	FUSE	REPLACED FUSE
NORTHWEST	689770	8/24/2007 8:24	8/24/2007 15:30	425.5	W9201	MONTGOMERY	20	FUSE	REPLACED FUSE
NORTHWEST	689770	8/24/2007 8:24	8/24/2007 15:30	425.5	W9201	AURORA TWP	26	FUSE	REPLACED FUSE

REGION_NAME	OUTAGE_ID	START_DATETIME	DATETIME_RSTD	DURATION_MINUTES	AS_BUILT_FEEDER_LINE	TOWN NAME	PREM_COUNT	EQUIPMENT_INVOLVED	RESTORATION_MEDIATION
SOUTHERN	689605	8/24/2007 8:25	8/24/2007 12:20	234.9	J5673	JOLIET	200	FUSE	TREE REMOVED
NORTHERN	693102	8/24/2007 8:25	8/28/2007 3:02	5436.5	E525Y	MOUNT PROSPECT	57	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
SOUTHERN	691280	8/24/2007 8:26	8/26/2007 13:15	3169	G6190	ROBBINS	12	FUSE	REPLACED CUTOUT
SOUTHERN	691525	8/24/2007 8:26	8/26/2007 10:27	3000.2	F175	WILL TWP	1	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
SOUTHERN	691815	8/24/2007 8:27	8/26/2007 21:00	3632.5	G888	HOMETOWN	14	TRANSFORMER-OVHD	REPLACED TRANSFORMER
NORTHERN	693031	8/24/2007 8:28	8/27/2007 23:26	5217.5	C1713	WHEELING	16	CABLE	TEMPORARY SWITCHING
NORTHWEST	689494	8/24/2007 8:35	8/24/2007 10:25	109.9	H149	SOMO-SAND TWP	1	FUSE	REPLACED FUSE
SOUTHERN	692508	8/24/2007 8:35	8/27/2007 9:55	4399.3	J585	WILTON TWP	1	TRANSFORMER-OVHD	REPLACED TRANSFORMER
SOUTHERN	689713	8/24/2007 8:36	8/24/2007 15:40	423.7	F575	CHICAGO HEIGHTS	1091	TAP WIRE	REPAIRED OVERHEAD MATERIAL
SOUTHERN	689713	8/24/2007 8:36	8/24/2007 15:40	423.7	F575	LANSING	1	TAP WIRE	REPAIRED OVERHEAD MATERIAL
SOUTHERN	689713	8/24/2007 8:36	8/24/2007 15:40	423.7	F575	OLYMPIA FIELDS	1	TAP WIRE	REPAIRED OVERHEAD MATERIAL
SOUTHERN	689713	8/24/2007 8:36	8/24/2007 15:40	423.7	F575	PARK FOREST	11	TAP WIRE	REPAIRED OVERHEAD MATERIAL
SOUTHERN	691049	8/24/2007 8:36	8/26/2007 6:00	2723.4	J335	MORRIS	7	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE
NORTHERN	691911	8/24/2007 8:37	8/26/2007 22:53	3735.7	E520Y	MOUNT PROSPECT	6	FUSE	REPLACED FUSE
NORTHWEST	689781	8/24/2007 8:39	8/24/2007 17:50	551	W6310	STREAMWOOD	1	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
SOUTHERN	691447	8/24/2007 8:40	8/26/2007 16:00	3319	F3578	HAZELCREST	9	TRANSFORMER-OVHD	REPLACED TRANSFORMER
CHICAGO	690147	8/24/2007 8:42	8/25/2007 3:01	1099	Z1407	WARD17	21	TRANSFORMER-OVHD	REPLACED CUTOUT
SOUTHERN	690349	8/24/2007 8:42	8/25/2007 11:30	1607.6	K187	MOMENCE TWP	10	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE
SOUTHERN	691476	8/24/2007 8:44	8/26/2007 15:45	3301	G6984	EVERGREEN PARK	11	TRANSFORMER-OVHD	REPLACED TRANSFORMER
SOUTHERN	689822	8/24/2007 8:45	8/24/2007 18:40	594.6	J1674	HOMER TWP	1	FUSE	REPLACED FUSE
SOUTHERN	689822	8/24/2007 8:45	8/24/2007 18:40	594.6	J1674	LEMONT TWP	20	FUSE	REPLACED FUSE
NORTHWEST	689923	8/24/2007 8:45	8/24/2007 20:36	710.8	W161	AURORA TWP	1	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
SOUTHERN	691108	8/24/2007 8:50	8/25/2007 10:40	1549.2	J697	DIAMOND	1	PHASE WIRE (ALL VOLTAGES)	TEMPORARY SWITCHING
SOUTHERN	691108	8/24/2007 8:50	8/25/2007 10:40	1549.2	J697	WESLEY TWP	4	PHASE WIRE (ALL VOLTAGES)	TEMPORARY SWITCHING
SOUTHERN	691108	8/24/2007 8:50	8/25/2007 10:40	1549.2	J697	CUSTER TWP	182	PHASE WIRE (ALL VOLTAGES)	TEMPORARY SWITCHING
SOUTHERN	691108	8/24/2007 8:50	8/25/2007 10:40	1549.2	J697	SALINA TWP	3	PHASE WIRE (ALL VOLTAGES)	TEMPORARY SWITCHING
SOUTHERN	691108	8/24/2007 8:50	8/25/2007 10:40	1549.2	J697	ESSEX TWP	3	PHASE WIRE (ALL VOLTAGES)	TEMPORARY SWITCHING
SOUTHERN	691108	8/24/2007 8:50	8/25/2007 10:40	1549.2	J697	CUSTER PARK	19	PHASE WIRE (ALL VOLTAGES)	TEMPORARY SWITCHING
NORTHERN	692609	8/24/2007 8:50	8/27/2007 16:10	4759.1	C75	WILMETTE	1	PHASE WIRE (ALL VOLTAGES)	REPLACED OVERHEAD MATERIAL
NORTHERN	690483	8/24/2007 8:51	8/25/2007 14:50	1798.3	E5223Y	MOUNT PROSPECT	12	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
SOUTHERN	690741	8/24/2007 8:53	8/25/2007 21:19	2185.8	J3687	TROY TWP	1	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHERN	692403	8/24/2007 8:53	8/27/2007 12:30	4536.7	C895	WILMETTE	16	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE
NORTHERN	692462	8/24/2007 8:53	8/27/2007 14:32	4658.6	D152	BROADVIEW	15	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
SOUTHERN	690517	8/24/2007 8:54	8/25/2007 16:20	1885.6	J815	JOLIET	24	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHERN	691522	8/24/2007 8:54	8/26/2007 16:17	3322.6	D4910	BELLWOOD	1	CONNECTOR-COMP. FULL TSN.	REPLACED EQUIPMENT
NORTHERN	691664	8/24/2007 8:54	8/26/2007 19:11	3496.7	C587	WILMETTE	82	POLE	REPLACED OTHER
NORTHERN	691747	8/24/2007 8:56	8/24/2007 13:00	244	C801	GLENVIEW	222	FUSE	REPLACED OVERHEAD MATERIAL
NORTHERN	691747	8/24/2007 8:56	8/24/2007 13:00	244	C801	MAINE TWP	24	FUSE	REPLACED OVERHEAD MATERIAL
NORTHWEST	689473	8/24/2007 9:01	8/24/2007 9:39	37.9	H445	OHIO TWP	5	FUSE	REPLACED FUSE
SOUTHERN	690262	8/24/2007 9:04	8/25/2007 7:15	1330.7	J5141	FRANKFORT TWP	44	FUSE	REPLACED FUSE
SOUTHERN	690262	8/24/2007 9:04	8/25/2007 7:15	1330.7	J5141	MOKENA	26	FUSE	REPLACED FUSE
NORTHWEST	689803	8/24/2007 9:06	8/24/2007 17:45	518.6	W391	ST CHARLES TWP	7	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE
NORTHWEST	689967	8/24/2007 9:06	8/24/2007 21:40	753.3	B905	VIRGIL TWP	1	FUSE	REPLACED FUSE
SOUTHERN	689461	8/24/2007 9:08	8/24/2007 9:27	18.6	J4971	CUSTER TWP	9	PHASE WIRE (ALL VOLTAGES)	TEMPORARY SWITCHING
SOUTHERN	689461	8/24/2007 9:08	8/24/2007 9:27	18.6	J4971	REED TWP	1	PHASE WIRE (ALL VOLTAGES)	TEMPORARY SWITCHING
SOUTHERN	689461	8/24/2007 9:08	8/24/2007 9:27	18.6	J4971	BRAIDWOOD	111	PHASE WIRE (ALL VOLTAGES)	TEMPORARY SWITCHING
SOUTHERN	689461	8/24/2007 9:08	8/24/2007 9:27	18.6	J4971	WILMINGTON TWP	198	PHASE WIRE (ALL VOLTAGES)	TEMPORARY SWITCHING
SOUTHERN	689461	8/24/2007 9:08	8/24/2007 9:27	18.6	J4971	WILMINGTON	435	PHASE WIRE (ALL VOLTAGES)	TEMPORARY SWITCHING

REGION_NAME	OUTAGE_ID	START_DATETIME	DATETIME_RSTD	DURATION_MINUTES	AS_BUILT_FEEDER_LINE	TOWN NAME	PREM_COUNT	EQUIPMENT_INVOLVED	RESTORATION_MEDIATION
NORTHERN	692327	8/24/2007 9:08	8/27/2007 11:45	4476.5	E2007	SCHAUMBURG TWP	1	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
SOUTHERN	690050	8/24/2007 9:16	8/24/2007 23:15	838.2	S255	GRAND RAPIDS TWP	1	FUSE	REPLACED FUSE
SOUTHERN	690356	8/24/2007 9:19	8/25/2007 11:25	1565.1	F125	SAUK VILLAGE	16	FUSE	INSTALL FUSE
NORTHERN	691945	8/24/2007 9:20	8/25/2007 19:30	2049.3	C587	WILMETTE	300	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHERN	691945	8/24/2007 9:20	8/26/2007 19:00	3459.3	C587	WILMETTE	271	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHERN	691597	8/24/2007 9:21	8/26/2007 14:55	3213.5	C165X	MOUNT PROSPECT	1	FUSE	REPAIRED OVERHEAD MATERIAL
NORTHERN	691597	8/24/2007 9:21	8/26/2007 14:55	3213.5	C165X	WHEELING TWP	14	FUSE	REPAIRED OVERHEAD MATERIAL
SOUTHERN	689910	8/24/2007 9:23	8/24/2007 19:00	576.1	S355	NEWTOWN TWP	19	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHERN	689884	8/24/2007 9:25	8/24/2007 19:40	614.7	W556	GLEN ELLYN	34	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE
NORTHERN	690779	8/24/2007 9:27	8/25/2007 19:45	2057.1	C2917	NILES	1	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
CHICAGO	689868	8/24/2007 9:29	8/24/2007 20:05	635.3	X4076	WARD44	135	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHWEST	689465	8/24/2007 9:30	8/24/2007 9:48	18	W7014	ELGIN	424	SWITCH-LOADBRK	REPAIRED OVERHEAD MATERIAL
NORTHWEST	689465	8/24/2007 9:30	8/24/2007 9:48	18	W7014	ELGIN TWP	262	SWITCH-LOADBRK	REPAIRED OVERHEAD MATERIAL
NORTHWEST	689465	8/24/2007 9:30	8/24/2007 9:48	18	W7014	BARTLETT	1	SWITCH-LOADBRK	REPAIRED OVERHEAD MATERIAL
NORTHWEST	689465	8/24/2007 9:30	8/24/2007 9:48	18	W7014	RUTLAND TWP	1	SWITCH-LOADBRK	REPAIRED OVERHEAD MATERIAL
NORTHERN	691942	8/24/2007 9:31	8/25/2007 20:08	2076.8	E1423	HOFFMAN ESTATES	22	PHASE WIRE (ALL VOLTAGES)	REPLACED OVERHEAD MATERIAL
NORTHWEST	690124	8/24/2007 9:32	8/25/2007 2:30	1017.2	W108	AURORA	1	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE
SOUTHERN	690366	8/24/2007 9:42	8/25/2007 12:10	1587.4	J4971	WILMINGTON	14	FUSE	REPLACED FUSE
SOUTHERN	690855	8/24/2007 9:45	8/25/2007 23:40	2274.7	G6586	DOLTON	18	CABLE-AERIAL	REPAIRED OVERHEAD MATERIAL
NORTHERN	692151	8/24/2007 9:45	8/26/2007 12:00	3014.1	C169	DES PLAINES	2	CABLE	TEMPORARY GENERATOR
NORTHERN	691949	8/24/2007 9:46	8/26/2007 20:04	3497.6	E525Y	MOUNT PROSPECT	44	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
SOUTHERN	691705	8/24/2007 9:48	8/26/2007 19:00	3431.6	K7078	BRADLEY	1	CABLE	TEMPORARY JUMPER TO RESTORE
NORTHERN	690732	8/24/2007 9:53	8/25/2007 20:30	2076.9	E520Y	MOUNT PROSPECT	13	PHASE WIRE (ALL VOLTAGES)	TEMPORARY SWITCHING
SOUTHERN	700447	8/24/2007 9:59	8/26/2007 18:40	3400	J1683	HOMER TWP	2	FUSE	REPLACED FUSE
NORTHWEST	698850	8/24/2007 10:00	8/24/2007 14:15	254.8	W9201	MONTGOMERY	2	FUSE	REPLACED FUSE
SOUTHERN	689806	8/24/2007 10:04	8/24/2007 17:45	460.1	J5141	MOKENA	98	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHWEST	689570	8/24/2007 10:05	8/24/2007 12:10	124.8	H661	LITTLE ROCK TWP	1	CABLE	TEMPORARY SWITCHING
NORTHWEST	689922	8/24/2007 10:06	8/24/2007 19:00	534	W191	BRISTOL TWP	15	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE
NORTHWEST	689575	8/24/2007 10:10	8/24/2007 10:35	25	W9202	LITTLE ROCK TWP	2	CUTOUT	REPAIRED OVERHEAD MATERIAL
NORTHWEST	689575	8/24/2007 10:10	8/24/2007 10:35	25	W9202	MONTGOMERY	6	CUTOUT	REPAIRED OVERHEAD MATERIAL
NORTHWEST	689575	8/24/2007 10:10	8/24/2007 10:35	25	W9202	OSWEGO TWP	858	CUTOUT	REPAIRED OVERHEAD MATERIAL
CHICAGO	690435	8/24/2007 10:11	8/25/2007 14:01	1669.4	D5001	WARD23	4	TRANSFORMER-OVHD	REPLACED TRANSFORMER
SOUTHERN	691348	8/24/2007 10:11	8/25/2007 19:00	1968.3	F5376	UNIVERSITY PARK	7	CABLE	TEMPORARY SWITCHING
SOUTHERN	691348	8/24/2007 10:11	8/26/2007 11:30	2958.3	F5376	UNIVERSITY PARK	15	CABLE	TEMPORARY SWITCHING
SOUTHERN	691348	8/24/2007 10:11	8/26/2007 12:00	2988.3	F5376	UNIVERSITY PARK	2	CABLE	TEMPORARY SWITCHING
CHICAGO	692071	8/24/2007 10:13	8/25/2007 11:50	1537	WSTN145	WARD16	11	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHERN	691453	8/24/2007 10:14	8/25/2007 10:30	1456.3	D578	FOREST PARK	1	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHERN	691453	8/24/2007 10:14	8/25/2007 10:30	1456.3	D578	RIVER FOREST	98	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHERN	691453	8/24/2007 10:14	8/26/2007 0:55	2320.8	D578	RIVER FOREST	240	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHERN	691453	8/24/2007 10:14	8/26/2007 1:05	2331.3	D578	RIVER FOREST	130	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHERN	691453	8/24/2007 10:14	8/26/2007 1:05	2331.3	D578	FOREST PARK	1	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHERN	691453	8/24/2007 10:14	8/26/2007 15:48	3213.4	D578	RIVER FOREST	48	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHERN	691453	8/24/2007 10:14	8/26/2007 16:06	3232.1	D578	RIVER FOREST	247	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHWEST	689573	8/24/2007 10:15	8/24/2007 12:10	114.9	H661	LITTLE ROCK TWP	14	CABLE	TEMPORARY SWITCHING
SOUTHERN	690328	8/24/2007 10:17	8/25/2007 11:20	1502.4	K346	SALINA TWP	1	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE
SOUTHERN	690565	8/24/2007 10:19	8/25/2007 17:00	1840.4	G651	RIVERDALE	1	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHWEST	690048	8/24/2007 10:20	8/24/2007 12:00	100	B7505	DEKALB	1	TRANSFORMER-PADMOUNT	REPLACED TRANSFORMER
CHICAGO	690706	8/24/2007 10:20	8/25/2007 20:41	2061	Z6347	WARD13	38	TRANSFORMER-OVHD	REPLACED TRANSFORMER

REGION_NAME	OUTAGE_ID	START_DATETIME	DATETIME_RSTD	DURATION _MINUTES	AS_BUILT _FEEDER _LINE	TOWN NAME	PREM _COUNT	EQUIPMENT_INVOLVED	RESTORATION_MEDIATION
NORTHERN	692265	8/24/2007 10:21	8/27/2007 11:20	4378.5	C82	SKOKIE	1	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHWEST	689665	8/24/2007 10:22	8/24/2007 15:29	306.7	E6027	CARPENTERSVILLE	1	NEUTRAL WIRE	REPAIRED OVERHEAD MATERIAL
NORTHWEST	689714	8/24/2007 10:22	8/24/2007 16:05	342.6	W7936	BARTLETT	107	PHASE WIRE (ALL VOLTAGES)	TREE REMOVED
NORTHWEST	689714	8/24/2007 10:22	8/24/2007 16:05	342.6	W7936	SOUTH ELGIN	1	PHASE WIRE (ALL VOLTAGES)	TREE REMOVED
SOUTHERN	690173	8/24/2007 10:22	8/25/2007 5:10	1127.8	K425	KANKAKEE	4	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE
NORTHERN	690628	8/24/2007 10:23	8/25/2007 18:30	1926.1	W5203	VILLA PARK	100	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
SOUTHERN	689844	8/24/2007 10:24	8/24/2007 18:50	505.7	K7076	BOURBONNAIS TWP	10	CUTOUT	REPLACED CUTOUT
SOUTHERN	689844	8/24/2007 10:24	8/24/2007 18:50	505.7	K7076	BRADLEY	11	CUTOUT	REPLACED CUTOUT
CHICAGO	690228	8/24/2007 10:24	8/25/2007 7:20	1256	Z11870	WARD21	25	TRANSFORMER-OVHD	REPLACED TRANSFORMER
SOUTHERN	690537	8/24/2007 10:24	8/25/2007 14:20	1675.3	F295	PARK FOREST	5	CROSS-ARM	REPLACED OVERHEAD MATERIAL
SOUTHERN	691115	8/24/2007 10:24	8/26/2007 10:19	2874.7	J5112	MOKENA	1	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHERN	691674	8/24/2007 10:24	8/25/2007 4:30	1086	E6818	ARLINGTON HEIGHTS	54	CABLE	TEMPORARY SWITCHING
NORTHERN	691674	8/24/2007 10:24	8/25/2007 11:15	1491	E6818	ARLINGTON HEIGHTS	326	CABLE	TEMPORARY SWITCHING
NORTHERN	691674	8/24/2007 10:24	8/26/2007 19:15	3411	E6818	ARLINGTON HEIGHTS	18	CABLE	TEMPORARY SWITCHING
SOUTHERN	689529	8/24/2007 10:27	8/24/2007 11:30	62.9	K395	YELLOWHEAD TWP	2	SWITCH-LOADBRK	REPAIRED OVERHEAD MATERIAL
SOUTHERN	689529	8/24/2007 10:27	8/24/2007 11:30	62.9	K395	GANEER TWP	100	SWITCH-LOADBRK	REPAIRED OVERHEAD MATERIAL
SOUTHERN	689529	8/24/2007 10:27	8/24/2007 11:30	62.9	K395	MOMENCE	44	SWITCH-LOADBRK	REPAIRED OVERHEAD MATERIAL
SOUTHERN	689529	8/24/2007 10:27	8/24/2007 11:30	62.9	K395	MOMENCE TWP	6	SWITCH-LOADBRK	REPAIRED OVERHEAD MATERIAL
SOUTHERN	689529	8/24/2007 10:27	8/24/2007 11:30	62.9	K395	SUMNER TWP	13	SWITCH-LOADBRK	REPAIRED OVERHEAD MATERIAL
NORTHERN	691209	8/24/2007 10:28	8/26/2007 12:00	2971.4	C536	EVANSTON	38	PHASE WIRE (ALL VOLTAGES)	REPLACED OVERHEAD MATERIAL
SOUTHERN	690567	8/24/2007 10:29	8/25/2007 15:50	1760.5	G589	CALUMET CITY	50	PHASE WIRE (ALL VOLTAGES)	REPLACED OVERHEAD MATERIAL
SOUTHERN	690743	8/24/2007 10:29	8/25/2007 20:04	2014.4	F525	CHICAGO HEIGHTS	1	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
SOUTHERN	690807	8/24/2007 10:31	8/25/2007 17:15	1843	G6588	CALUMET CITY	167	CABLE	TEMPORARY SWITCHING
SOUTHERN	690807	8/24/2007 10:31	8/25/2007 17:30	1858	G6588	CALUMET CITY	65	CABLE	TEMPORARY SWITCHING
NORTHERN	690564	8/24/2007 10:36	8/25/2007 15:30	1733.4	D6412	WESTCHESTER	12	TRANSFORMER-OVHD	REPLACED TRANSFORMER
SOUTHERN	689697	8/24/2007 10:37	8/24/2007 16:00	322.7	S206	EVANS TWP	1	FUSE	CLOSED FUSE
NORTHERN	691919	8/24/2007 10:40	8/26/2007 13:30	3049.6	C7215	GLENVIEW	3	FUSE	REPLACED FUSE
NORTHERN	691919	8/24/2007 10:40	8/26/2007 13:30	3049.6	C7215	NORTHFIELD TWP	6	FUSE	REPLACED FUSE
NORTHWEST	689524	8/24/2007 10:41	8/24/2007 11:10	28.4	B465	MILLEDGEVILLE	11	FUSE	REPLACED FUSE
SOUTHERN	690663	8/24/2007 10:42	8/25/2007 19:15	1952.1	F3577	COUNTRY CLUB HILLS	13	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE
NORTHERN	691888	8/24/2007 10:42	8/26/2007 19:00	3377.1	C858	NORTHFIELD TWP	13	FUSE	REPLACED FUSE
NORTHERN	691616	8/24/2007 10:43	8/26/2007 18:36	3352.1	E520Y	MOUNT PROSPECT	1	PHASE WIRE (ALL VOLTAGES)	REPLACED OVERHEAD MATERIAL
SOUTHERN	689571	8/24/2007 10:44	8/24/2007 12:30	105.1	F525	CHICAGO HEIGHTS	19	CUTOUT	REPLACED CUTOUT
SOUTHERN	689571	8/24/2007 10:44	8/24/2007 12:30	105.1	F525	HOLBROOK	2	CUTOUT	REPLACED CUTOUT
SOUTHERN	690818	8/24/2007 10:44	8/25/2007 16:08	1763.2	L14964	WESLEY TWP	1	POLE	REPAIRED OVERHEAD MATERIAL
SOUTHERN	691041	8/24/2007 10:44	8/26/2007 5:56	2592	J4971	WILMINGTON	3	FUSE	REPLACED FUSE
SOUTHERN	690300	8/24/2007 10:46	8/25/2007 10:30	1423.1	K188	MOMENCE TWP	1	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE
SOUTHERN	691125	8/24/2007 10:47	8/26/2007 10:47	2879.9	K155	WESLEY TWP	1	FUSE	REPLACED FUSE
SOUTHERN	689518	8/24/2007 10:48	8/24/2007 11:32	44.4	F522	CHICAGO HEIGHTS	127	SUBSTATION BREAKER	REPAIRED OVERHEAD MATERIAL
SOUTHERN	690168	8/24/2007 10:50	8/25/2007 4:40	1069.2	W3614X	HINSDALE	1	CABLE	TEMPORARY JUMPER TO RESTORE
NORTHERN	692846	8/24/2007 10:51	8/27/2007 18:17	4766	C124	NORTHFIELD	6	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
CHICAGO	689711	8/24/2007 10:53	8/24/2007 13:31	158	Z8934	WARD34	34	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
CHICAGO	689711	8/24/2007 10:53	8/24/2007 13:31	158	Z8934	WARD9	191	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
CHICAGO	689711	8/24/2007 10:53	8/24/2007 15:36	283	Z8934	WARD9	66	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHERN	691403	8/24/2007 10:56	8/26/2007 15:00	3123.4	C435	EVANSTON	37	FUSE	REPAIRED OVERHEAD MATERIAL
NORTHERN	691917	8/24/2007 10:57	8/26/2007 22:57	3599.6	E707	ARLINGTON HEIGHTS	10	FUSE	REPLACED FUSE
NORTHERN	690839	8/24/2007 10:58	8/24/2007 11:36	37.8	W365	WINFIELD	1	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHERN	690839	8/24/2007 10:58	8/24/2007 13:50	171.8	W365	WINFIELD	32	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL

REGION_NAME	OUTAGE_ID	START_DATETIME	DATETIME_RSTD	DURATION_MINUTES	AS_BUILT_FEEDER	TOWN NAME	PREM_COUNT	EQUIPMENT_INVOLVED	RESTORATION_MEDIATION
NORTHERN	690839	8/24/2007 10:58	8/24/2007 13:50	171.8	W365	MILTON TWP	23	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHERN	690839	8/24/2007 10:58	8/24/2007 15:20	261.8	W365	WINFIELD	162	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHERN	690839	8/24/2007 10:58	8/24/2007 16:15	316.8	W365	WINFIELD	108	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHERN	690839	8/24/2007 10:58	8/24/2007 16:15	316.8	W365	WHEATON	31	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHERN	690839	8/24/2007 10:58	8/24/2007 16:15	316.8	W365	MILTON TWP	1	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHERN	690839	8/24/2007 10:58	8/26/2007 0:00	2221.8	W365	WINFIELD	245	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHERN	690839	8/24/2007 10:58	8/26/2007 0:00	2221.8	W365	MILTON TWP	2	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHERN	690839	8/24/2007 10:58	8/26/2007 0:00	2221.8	W365	WINFIELD TWP	1	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
CHICAGO	691256	8/24/2007 10:59	8/26/2007 12:55	2995.6	X4074	WARD35	33	CABLE-AERIAL	REPLACED OVERHEAD MATERIAL
NORTHERN	692756	8/24/2007 11:00	8/27/2007 18:30	4769.5	C496	WILMETTE	12	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
SOUTHERN	702902	8/24/2007 11:00	8/27/2007 14:15	4514.8	F165	BEECHER	1	FUSE	REPLACED FUSE
SOUTHERN	702902	8/24/2007 11:00	8/27/2007 14:15	4514.8	F165	WILL TWP	1	FUSE	REPLACED FUSE
SOUTHERN	691636	8/24/2007 11:02	8/26/2007 18:43	3341	G6028	HARVEY	1	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
SOUTHERN	692431	8/24/2007 11:02	8/27/2007 13:30	4468	F576	CRETE TWP	2	PHASE WIRE (ALL VOLTAGES)	TEMPORARY SWITCHING
SOUTHERN	692431	8/24/2007 11:02	8/27/2007 13:30	4468	F576	CRETE	2	PHASE WIRE (ALL VOLTAGES)	TEMPORARY SWITCHING
NORTHERN	692619	8/24/2007 11:02	8/27/2007 15:15	4572.3	C729	MAINE TWP	1	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHERN	691418	8/24/2007 11:03	8/26/2007 15:00	3116.7	C172	WHEELING	18	PHASE WIRE (ALL VOLTAGES)	CLOSED FUSE
NORTHERN	691418	8/24/2007 11:03	8/26/2007 15:00	3116.7	C172	WHEELING TWP	1	PHASE WIRE (ALL VOLTAGES)	CLOSED FUSE
NORTHERN	690724	8/24/2007 11:04	8/25/2007 16:31	1767	D6415	MAYWOOD	23	FUSE	REPLACED FUSE
NORTHERN	692893	8/24/2007 11:04	8/27/2007 17:28	4703.3	C316	WILMETTE	14	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHWEST	690656	8/24/2007 11:05	8/25/2007 18:15	1869.4	E6022	EAST DUNDEE	9	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
SOUTHERN	691163	8/24/2007 11:06	8/26/2007 11:00	2873.7	J177	CHANNAHON	12	FUSE	REPLACED FUSE
SOUTHERN	691710	8/24/2007 11:06	8/26/2007 19:45	3398.9	J8783	LOCKPORT TWP	1	TRANSFORMER-PADMOUNT	REPAIRED OTHER
NORTHWEST	689579	8/24/2007 11:07	8/24/2007 12:25	77.1	R8473	ROCKFORD	1	FUSE	REPLACED FUSE
NORTHERN	690796	8/24/2007 11:07	8/25/2007 17:58	1850.5	W6219	BLOOMINGDALE	1	PHASE WIRE (ALL VOLTAGES)	REPLACED OVERHEAD MATERIAL
NORTHERN	689848	8/24/2007 11:09	8/24/2007 19:00	470.1	C1218	NORTHBROOK	98	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHERN	690791	8/24/2007 11:09	8/25/2007 22:08	2098.1	W9514	MILTON TWP	7	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHWEST	689797	8/24/2007 11:11	8/24/2007 17:59	407.4	H406	WALNUT TWP	2	TRANSFORMER-OVHD	REPLACED TRANSFORMER
CHICAGO	692047	8/24/2007 11:11	8/25/2007 13:25	1573.8	Z8942	WARD21	1	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
SOUTHERN	690165	8/24/2007 11:13	8/24/2007 14:30	196.7	K7082	ROCKVILLE TWP	1	CABLE	REPAIRED UNDERGROUND MATERIAL
SOUTHERN	690165	8/24/2007 11:13	8/25/2007 4:15	1021.7	K7082	BOURBONNAIS TWP	4	CABLE	REPAIRED UNDERGROUND MATERIAL
NORTHERN	691922	8/24/2007 11:13	8/26/2007 23:01	3587.9	E707	ARLINGTON HEIGHTS	13	FUSE	REPLACED FUSE
SOUTHERN	698626	8/24/2007 11:14	8/24/2007 14:30	195.8	W387	DOWNERS GROVE TWP	2	FUSE	REPLACED FUSE
SOUTHERN	690345	8/24/2007 11:15	8/25/2007 12:20	1504.8	G282	MARKHAM	1	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
SOUTHERN	692154	8/24/2007 11:15	8/27/2007 6:50	4054.4	J165	JOLIET	1	PHASE WIRE (ALL VOLTAGES)	TREE TRIMMED
SOUTHERN	691094	8/24/2007 11:17	8/26/2007 9:43	2785.7	J7485	NEW LENOX	1	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHERN	692015	8/24/2007 11:17	8/26/2007 9:15	2757.6	D346	CICERO	14	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE
NORTHWEST	703451	8/24/2007 11:20	8/24/2007 19:19	478.1	H537	LAKE HOLIDAY	9	FUSE	REPLACED FUSE
NORTHWEST	690005	8/24/2007 11:21	8/24/2007 18:37	435.2	W9201	AURORA TWP	2	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE
SOUTHERN	690266	8/24/2007 11:21	8/25/2007 8:30	1268.8	K346	LIMESTONE TWP	1	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE
NORTHERN	690648	8/24/2007 11:25	8/25/2007 18:15	1849	W2012	LOMBARD	1	PHASE WIRE (ALL VOLTAGES)	REPLACED OVERHEAD MATERIAL
NORTHERN	691142	8/24/2007 11:25	8/26/2007 11:05	2860	C314	NEW TRIER TWP	1	POLE	REPAIRED OVERHEAD MATERIAL
SOUTHERN	689739	8/24/2007 11:26	8/24/2007 16:15	288.1	W4101	DOWNERS GROVE TWP	46	FUSE	REPLACED FUSE
NORTHWEST	690010	8/24/2007 11:26	8/24/2007 23:03	696.2	W560	AURORA	1	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHERN	690358	8/24/2007 11:26	8/25/2007 12:36	1509.7	W9514	GLENDALE HEIGHTS	1	PHASE WIRE (ALL VOLTAGES)	TREE REMOVED
NORTHERN	691299	8/24/2007 11:29	8/26/2007 13:50	3020.7	C723	MORTON GROVE	12	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE
NORTHERN	692394	8/24/2007 11:29	8/24/2007 23:00	690.9	W5202	ADDISON	16	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHERN	692394	8/24/2007 11:29	8/24/2007 23:00	690.9	W5202	VILLA PARK	129	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL

REGION_NAME	OUTAGE_ID	START_DATETIME	DATETIME_RSTD	DURATION_MINUTES	AS_BUILT_FEEDER_LINE	TOWN NAME	PREM_COUNT	EQUIPMENT_INVOLVED	RESTORATION_MEDIATION
NORTHERN	692394	8/24/2007 11:29	8/24/2007 23:00	690.9	W5202	ELMHURST	22	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHERN	692394	8/24/2007 11:29	8/24/2007 23:00	690.9	W5202	YORK TWP	1	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHERN	692394	8/24/2007 11:29	8/24/2007 23:00	690.9	W5202	ADDISON TWP	4	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHERN	692394	8/24/2007 11:29	8/25/2007 4:50	1040.9	W5202	ADDISON	45	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHERN	692394	8/24/2007 11:29	8/25/2007 4:50	1040.9	W5202	ADDISON TWP	3	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHERN	692394	8/24/2007 11:29	8/25/2007 4:50	1040.9	W5202	VILLA PARK	19	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHERN	692394	8/24/2007 11:29	8/27/2007 13:33	4444.9	W5202	VILLA PARK	13	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
SOUTHERN	689747	8/24/2007 11:32	8/24/2007 16:20	287.3	L1863	FRANKFORT TWP	1	PHASE WIRE (ALL VOLTAGES)	TEMPORARY SWITCHING
NORTHERN	692607	8/24/2007 11:34	8/27/2007 13:35	4440.7	C726X	MORTON GROVE	12	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
SOUTHERN	690014	8/24/2007 11:39	8/24/2007 18:10	390.8	S211	HOPE TWP	1	FUSE	REPLACED FUSE
NORTHWEST	690002	8/24/2007 11:40	8/24/2007 21:30	589.9	B171	GENOA TWP	1	FUSE	REPLACED FUSE
SOUTHERN	689951	8/24/2007 11:42	8/24/2007 21:00	557.8	J5141	FRANKFORT TWP	4	FUSE	REPLACED FUSE
SOUTHERN	690314	8/24/2007 11:42	8/25/2007 10:50	1387.7	J5141	MOKENA	62	FUSE	REPLACED FUSE
NORTHERN	690739	8/24/2007 11:42	8/25/2007 21:10	2007.9	D8100	BROADVIEW	77	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHERN	693043	8/24/2007 11:42	8/27/2007 23:43	5040.4	E0220	DEER PARK	1	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHERN	691184	8/24/2007 11:43	8/26/2007 11:45	2881.7	E725	FOX RIVER GR	1	PHASE WIRE (ALL VOLTAGES)	REPLACED OVERHEAD MATERIAL
SOUTHERN	691087	8/24/2007 11:46	8/26/2007 9:34	2747.9	J5163	FRANKFORT TWP	1	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
SOUTHERN	690265	8/24/2007 11:47	8/25/2007 8:40	1252.8	J585	MANHATTAN TWP	5	FUSE	REPLACED FUSE
CHICAGO	691464	8/24/2007 11:47	8/26/2007 15:40	3112.8	X1432	WARD32	1	CABLE-AERIAL	REPLACED OVERHEAD MATERIAL
SOUTHERN	691739	8/24/2007 11:47	8/26/2007 19:40	3352.8	J325	WILMINGTON	5	PHASE WIRE (ALL VOLTAGES)	REPLACED OVERHEAD MATERIAL
CHICAGO	691866	8/24/2007 11:47	8/26/2007 22:03	3495.6	X3249	WARD37	1	CABLE-AERIAL	REPLACED OVERHEAD MATERIAL
NORTHERN	692424	8/24/2007 11:47	8/25/2007 21:18	2010.7	D8100	BROADVIEW	16	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHERN	692424	8/24/2007 11:47	8/27/2007 13:40	4432.2	D8100	BROADVIEW	45	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHERN	693047	8/24/2007 11:47	8/27/2007 22:00	4932.8	W5205	ADDISON	1	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
CHICAGO	689849	8/24/2007 11:49	8/24/2007 18:50	420.7	Y4573	WARD2	1	PHASE WIRE (ALL VOLTAGES)	CLOSED FUSE
NORTHERN	691604	8/24/2007 11:49	8/26/2007 18:24	3274.1	E0222	PALATINE	1	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
SOUTHERN	690370	8/24/2007 11:50	8/25/2007 12:45	1494.7	J166	JOLIET	13	FUSE	CLOSED FUSE
CHICAGO	691122	8/24/2007 11:50	8/26/2007 10:36	2806	Z3331	WARD13	1	CABLE-AERIAL	REPAIRED OVERHEAD MATERIAL
SOUTHERN	691419	8/24/2007 11:51	8/26/2007 15:43	3111.6	G658	DOLTON	1	PHASE WIRE (ALL VOLTAGES)	REPLACED OVERHEAD MATERIAL
NORTHWEST	689883	8/24/2007 11:52	8/24/2007 20:13	500.5	B255	MONROE TWP	1	FUSE	REPLACED FUSE
NORTHERN	690538	8/24/2007 11:55	8/25/2007 12:21	1465.1	W9502	WINFIELD TWP	24	CROSS-ARM	TEMPORARY SWITCHING
NORTHERN	690538	8/24/2007 11:55	8/25/2007 17:12	1756.2	W9502	WINFIELD TWP	9	CROSS-ARM	TEMPORARY SWITCHING
NORTHERN	690468	8/24/2007 11:56	8/25/2007 14:50	1613.5	E5223Y	MOUNT PROSPECT	22	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHERN	691440	8/24/2007 11:56	8/26/2007 15:58	3121.1	C1713	WHEELING	22	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
SOUTHERN	690329	8/24/2007 11:57	8/25/2007 11:50	1433	G6185	TINLEY PARK	1	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
SOUTHERN	691699	8/24/2007 11:58	8/26/2007 19:37	3338.2	G4378	SOUTH HOLLAND	1	CABLE-AERIAL	INSTALL OVERHEAD MATERIAL
NORTHWEST	689847	8/24/2007 12:01	8/24/2007 19:20	438.3	B2302	MARENGO	14	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
CHICAGO	692048	8/24/2007 12:01	8/25/2007 9:19	1277.4	Z4341	WARD9	1	METER	REPLACED OTHER
NORTHERN	691986	8/24/2007 12:02	8/25/2007 0:17	734.4	E0210	ARLINGTON HEIGHTS	1	PHASE WIRE (ALL VOLTAGES)	CLOSED SWITCH/DISCONNECT/LT
NORTHERN	691986	8/24/2007 12:02	8/25/2007 0:17	734.4	E0210	PALATINE TWP	3	PHASE WIRE (ALL VOLTAGES)	CLOSED SWITCH/DISCONNECT/LT
NORTHERN	691986	8/24/2007 12:02	8/25/2007 0:17	734.4	E0210	PALATINE	75	PHASE WIRE (ALL VOLTAGES)	CLOSED SWITCH/DISCONNECT/LT
NORTHERN	691986	8/24/2007 12:02	8/25/2007 0:17	734.4	E0210	HOFFMAN ESTATES	16	PHASE WIRE (ALL VOLTAGES)	CLOSED SWITCH/DISCONNECT/LT
NORTHERN	691986	8/24/2007 12:02	8/25/2007 0:17	734.4	E0210	INVERNESS	627	PHASE WIRE (ALL VOLTAGES)	CLOSED SWITCH/DISCONNECT/LT
SOUTHERN	692509	8/24/2007 12:04	8/27/2007 14:51	4486.2	L7343	CRETE TWP	1	NEUTRAL WIRE	REPLACED OVERHEAD MATERIAL
SOUTHERN	690716	8/24/2007 12:05	8/25/2007 18:00	1794.2	G615	ALSIP	76	CABLE	TEMPORARY SWITCHING
NORTHERN	691171	8/24/2007 12:08	8/26/2007 11:25	2836.4	W689	ADDISON TWP	9	FUSE	REPLACED FUSE
SOUTHERN	690474	8/24/2007 12:09	8/25/2007 14:00	1550.7	J7474	JOLIET	8	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE
NORTHERN	690042	8/24/2007 12:10	8/24/2007 23:57	706.8	E523	MOUNT PROSPECT	99	CABLE-AERIAL	REPAIRED OVERHEAD MATERIAL

REGION_NAME	OUTAGE_ID	START_DATETIME	DATETIME_RSTD	DURATION _MINUTES	AS_BUILT _FEEDER _LINE	TOWN NAME	PREM _COUNT	EQUIPMENT_INVOLVED	RESTORATION_MEDIATION
SOUTHERN	691540	8/24/2007 12:11	8/26/2007 13:30	2958.6	G137	HARVEY	24	FUSE	REPAIRED OVERHEAD MATERIAL
NORTHWEST	689616	8/24/2007 12:12	8/24/2007 14:00	107	W240	CARPENTERSVILLE	51	SWITCH-LOADBRK	REPAIRED OVERHEAD MATERIAL
NORTHWEST	689616	8/24/2007 12:12	8/24/2007 14:00	107	W240	WEST DUNDEE	67	SWITCH-LOADBRK	REPAIRED OVERHEAD MATERIAL
SOUTHERN	690566	8/24/2007 12:13	8/25/2007 17:20	1746	J7474	JOLIET TWP	16	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHERN	690038	8/24/2007 12:14	8/24/2007 23:49	695	E523	MOUNT PROSPECT	72	CABLE-AERIAL	REPAIRED OVERHEAD MATERIAL
NORTHERN	690845	8/24/2007 12:15	8/25/2007 13:30	1514.7	E5213Y	ELK GROVE VIL	1	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHERN	691031	8/24/2007 12:16	8/26/2007 4:45	2428.4	E501	BARRINGTON HILLS	7	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHERN	690039	8/24/2007 12:17	8/24/2007 23:52	694.2	E523	MOUNT PROSPECT	14	CABLE-AERIAL	REPAIRED OVERHEAD MATERIAL
NORTHERN	690040	8/24/2007 12:19	8/24/2007 23:54	694.1	E523	MOUNT PROSPECT	30	CABLE-AERIAL	REPAIRED OVERHEAD MATERIAL
SOUTHERN	690339	8/24/2007 12:25	8/24/2007 12:26	1	K235	KANKAKEE	1	PHASE WIRE (ALL VOLTAGES)	DISCONNECT OVERHEAD MATERIAL
NORTHWEST	689863	8/24/2007 12:26	8/24/2007 19:50	444	W240	EAST DUNDEE	13	FUSE	REPLACED FUSE
SOUTHERN	689679	8/24/2007 12:27	8/24/2007 12:45	17.4	J155	JACKSON TWP	16	POLE	TEMPORARY SWITCHING
NORTHWEST	689970	8/24/2007 12:27	8/24/2007 21:52	564.6	W7702	ELGIN TWP	2	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE
CHICAGO	691596	8/24/2007 12:27	8/26/2007 17:30	3182.1	X1458	WARD35	165	PHASE WIRE (ALL VOLTAGES)	TREE REMOVED
NORTHERN	691848	8/24/2007 12:27	8/26/2007 21:47	3439.7	D119	BELLWOOD	1	PHASE WIRE (ALL VOLTAGES)	REPLACED OVERHEAD MATERIAL
SOUTHERN	692959	8/24/2007 12:28	8/27/2007 21:23	4854.5	F5273	CHICAGO HEIGHTS	5	CABLE	TEMPORARY JUMPER TO RESTORE
CHICAGO	690372	8/24/2007 12:32	8/25/2007 12:00	1407.5	Z15079	WARD6	1	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
NORTHERN	699801	8/24/2007 12:32	8/25/2007 4:35	962.6	E5223Y	DES PLAINES	2	FUSE	REPLACED FUSE
SOUTHERN	691176	8/24/2007 12:33	8/26/2007 11:41	2827.9	J3675	JOLIET	1	PHASE WIRE (ALL VOLTAGES)	REPLACED OVERHEAD MATERIAL
NORTHERN	690219	8/24/2007 12:34	8/24/2007 13:34	59.4	C7224	PARK RIDGE	404	CABLE	TEMPORARY SWITCHING
NORTHERN	690219	8/24/2007 12:34	8/24/2007 13:34	59.4	C7224	MAINE TWP	26	CABLE	TEMPORARY SWITCHING
NORTHERN	690219	8/24/2007 12:34	8/24/2007 13:34	59.4	C7224	GLENVIEW	1	CABLE	TEMPORARY SWITCHING
NORTHERN	690219	8/24/2007 12:34	8/24/2007 13:34	59.4	C7224	NILES	1211	CABLE	TEMPORARY SWITCHING
NORTHERN	690219	8/24/2007 12:34	8/24/2007 14:00	85.1	C7224	NILES	38	CABLE	TEMPORARY SWITCHING
NORTHERN	690219	8/24/2007 12:34	8/24/2007 14:00	85.1	C7224	PARK RIDGE	219	CABLE	TEMPORARY SWITCHING
NORTHERN	690219	8/24/2007 12:34	8/24/2007 14:50	135.1	C7224	PARK RIDGE	880	CABLE	TEMPORARY SWITCHING
CHICAGO	689614	8/24/2007 12:37	8/24/2007 12:56	18.8	Z8931	WARD19	366	CABLE	TEMPORARY SWITCHING
CHICAGO	689614	8/24/2007 12:37	8/24/2007 13:27	50.2	Z8931	WARD21	732	CABLE	TEMPORARY SWITCHING
CHICAGO	689614	8/24/2007 12:37	8/24/2007 13:27	50.2	Z8931	WARD19	289	CABLE	TEMPORARY SWITCHING
CHICAGO	689614	8/24/2007 12:37	8/24/2007 13:27	49.8	Z8931	WARD19	131	CABLE	TEMPORARY SWITCHING
CHICAGO	689614	8/24/2007 12:37	8/24/2007 13:38	60.8	Z8931	WARD21	227	CABLE	TEMPORARY SWITCHING
CHICAGO	689614	8/24/2007 12:37	8/24/2007 13:51	73.8	Z8931	WARD21	491	CABLE	TEMPORARY SWITCHING
SOUTHERN	690078	8/24/2007 12:37	8/25/2007 0:45	727.9	K395	BOURBONNAIS TWP	6	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE
CHICAGO	690549	8/24/2007 12:37	8/25/2007 17:16	1718.6	Y1954	WARD25	80	PHASE WIRE (ALL VOLTAGES)	REPLACED FUSE
CHICAGO	690021	8/24/2007 12:41	8/24/2007 23:31	649.6	Z13766	WARD16	49	FUSE	REPLACED FUSE
NORTHERN	691929	8/24/2007 12:41	8/26/2007 23:10	3508.2	E2007	SCHAUMBURG TWP	2	FUSE	REPLACED FUSE
SOUTHERN	690013	8/24/2007 12:42	8/24/2007 23:00	617.1	J696	BRACEVILLE	1	CUTOUT	REPLACED CUTOUT
SOUTHERN	690068	8/24/2007 12:43	8/25/2007 0:20	696.1	K395	GANEER TWP	10	FUSE	REPLACED CUTOUT
SOUTHERN	690204	8/24/2007 12:44	8/25/2007 6:50	1086	K346	LIMESTONE TWP	1	FUSE	REPLACED FUSE
SOUTHERN	691689	8/24/2007 12:44	8/26/2007 19:15	3270.6	G281	MARKHAM	1	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL
SOUTHERN	698992	8/24/2007 12:44	8/24/2007 13:40	56	K187	MOMENCE	8	CUTOUT	REPLACED CUTOUT
NORTHERN	690046	8/24/2007 12:46	8/25/2007 0:02	675.1	E523	MOUNT PROSPECT	56	CABLE-AERIAL	REPAIRED OVERHEAD MATERIAL
CHICAGO	691180	8/24/2007 12:49	8/26/2007 11:48	2818.5	Z15073	WARD7	1	CABLE-AERIAL	REPAIRED OTHER
NORTHERN	690033	8/24/2007 12:51	8/24/2007 23:44	652.3	E523	MOUNT PROSPECT	1	CABLE-AERIAL	REPAIRED OVERHEAD MATERIAL
NORTHERN	700094	8/24/2007 12:51	8/25/2007 13:59	1507.2	D3411	LA GRANGE PARK	6	FUSE	REPLACED FUSE
SOUTHERN	690365	8/24/2007 12:54	8/25/2007 11:40	1365.5	K7083	BOURBONNAIS TWP	1	TRANSFORMER-PADMOUNT	CHANGED SIZE
SOUTHERN	690365	8/24/2007 12:54	8/25/2007 11:40	1365.5	K7083	BOURBONNAIS	2	TRANSFORMER-PADMOUNT	CHANGED SIZE
NORTHERN	691178	8/24/2007 12:54	8/26/2007 11:43	2808.4	D0502	OAK PARK	1	PHASE WIRE (ALL VOLTAGES)	REPAIRED OVERHEAD MATERIAL