

**OFFICIAL FILE**

I.C.C. DOCKET NO. 09-0206

ComEd Exhibit No. H

Witness \_\_\_\_\_

Date 6/9/09 Reporter DJ

COMED EXHIBIT H



Field Order Number **22228003** Date/Time **5/1/2007 9:06:01 AM** Completed Date: **5/1/2007 9:05:58 AM**

Dispatched Date: **5/1/2007 12:26:31 AM** On Site **5/1/2007 8:32:48 AM** Technician: **Santiago, W - 273**

Address: **505 N LAKE-SHORE DR 1101 CHICAGO**

Meter Number: **999756536** Kwh Reading: **36511** Meter Size: **047**

Meter Type: **I60S1** Number of Revs:  WHR Meter Revs Found: **10**

As Found Reading 1 Heavy  Found Unmetered: **n** Found Foreign Amps   
As Found Reading 2 Heavy:  Average Acc. Found: **099.75** Found Foreign Load Y/N **n**

As found % Light 1: **099.72** As Found % Light 2: **099.78** As Found Reading 1 L:

As found % Heavy 1: **099.80** As found % Heavy 2: **099.70** As Found Reading 2 L:

Found Heavy not Rec:  Found as Left: **Y**

**Issuance Remarks:**  
\* ICC INQ \* MR WEB APPT FOR 5/01/07 AM .. Pls test meter and check for foreign load. Call 312-399-6986 when headed to the stop or enroute. Be specific with details. Thanks

**Completion Remarks:**  
mtr test completed