C-first Desktop

File Edit Objects Views Options Window Help

Service Orders - TAYLOR, VALENTINA 1175 RICHMOND ST

PendingOrders | Initiate Detail | Initiate Basic | Scheduling | AcctTransfer | ServiceCharges

RemarksHistory | AppDetail | FinaBillInfo | OrderErrors | AuditDetails | Completion

Order Type: EMERGENCY Order Status: POSTED Order State: POSTED

No of Stops: 2 Sched Date: 11/05/2009 Sched Time: DAY 30 Arrival Date: 11/05/2009 Compl Date: 11/05/2009

Additional SO Completion

Original Order Type	EMERGENCY
Original Work Type	EMERGENCY INSIDE
Original Order Reason	NO GAS
Original Appliance Type	CENTRAL HEATING PLAN

Premise Checks			
HOUSE PIPE OK	Yes	No	N/A
OUTSIDE WALL OK	Yes	No	N/A
COMPANY SERVICE OK	Yes	No	N/A

How Found: B-BOX/RISER OFF

Action Taken: TURNED METER ON

Violation	Comments
OTHER (SEE REMARKS)	INSTALL EXTRA FRESH AIR OPENINGS
RELIEF VALVE HAS NO ACTIVE DRAIN	CONNECT DRAIN PIPE TO ACTIVE DRAIN

Insert | Delete | OK | Cancel

Ready

Page 1 Sec 1 1/1 At 1" Ln 1 Col 1 REC TRK EXT OVR

Start | Inbox - Micro... | C-first Desktop | Untitled - Me... | Completion R... | Document1 - ... | 9:01 AM Wednesday

Respondent's EX 6 I

OFFICIAL FILE

I.C.C. DOCKET NO. 09-0408

Respondent's Exhibit No. 6 I

Witness Barragan

Date 12-9-09 Reporter AC