

ComEd EX 1

A



Field Order Number **555431021** Date/Time **6/3/2009 11:16:28 AM** Completed Date: **6/3/2009 11:16:28 AM**
 Dispatched Date: **6/3/2009 5:28:13 AM** On Site **6/3/2009 10:45:12 AM** Technician: **Ceja, Raymond - 93**

Address: **27135 S LA-GRANGE RD GREEN GARDEN TWP**
 Unit :

Meter Number: **141410097** Kwh Reading: **38893** Meter Size: **047**
 Meter Type: **CY1S** Number of Revs: WHR Meter Revs Found: **10**

As Found Reading 1 Heavy **100.38** Found Unmetered: **N** Found Foreign Amps
 As Found Reading 2 Heavy: **100.35** Average Acc. Found: **100.37** Found Foreign Load Y/N **N**

As found % Light 1: **099.73** As Found % Light 2: **099.80** As Found Reading 1 L: **099.73**
 As found % Heavy 1: **100.38** As found % Heavy 2: **100.35** As Found Reading 2 L: **099.80**
 Found Heavy not Rec: Found as Left:

OFFICIAL FILE

ICC Docket No. 09-0331
 Exhibit No. 14
 Witness Res.
 Date 11-23-09 Reporter J-G.

Issuance Remarks:
 CHECKED METER, SEAL, WIRING, RUNS UNDER LOAD
 PERFORMED BREAKER CHECK
 UNABLE TO SATISFY CUST. ON HIGH BILL COMPLAINT. CUST WOULD
 LIKE TRANS. AND SERVICE WIRE FROM POLE TO HOUSE CHECKED
 ALSO HAVE MTR TESTED FOR ACCURACY.

Completion Remarks:
 COMP. MTR FIED TEST. SEE RESULTS ON MTR TESTED WITHIN
 ICC AND COMPANY LIMITS