

OFFICIAL FILE



UNITED STATES
DEPARTMENT OF LABOR

I.C.C. DOCKET NO. 10-0262

ALL DOI

COMED Exhibit No. 12

Occupational Safety & Health Administration

Witness Weaver

A to Z Index | En Español | Contact Us

OSHA Home

Date 6/10/10 Reporter JP

RSS Feeds Print This Page

Inspection: 313847915 - Jozef Kaminski DbA J.K. Construction

Inspection Information - Office: Chicago North		
Nr: 313847915	Report ID:0524200	Open Date: 10/14/2009
Jozef Kaminski DbA J.K. Construction 1708 W. Crescent Ave. Park Ridge, IL 60068 Union Status: NonUnion SIC: 1761/Roofing, Siding, and Sheet Metal Work NAICS: 238170/Siding Contractors Mailing: 7000 Niles Ter., Niles, IL 60714		
Inspection Type: Unprog Rel Scope: Partial Ownership: Private Safety/Health: Safety Emphasis: S:Residential Constr,S:Electrical	Advanced Notice: N Close Conference: 10/16/2009 Close Case: 01/14/2010	
Optional Information: Type	ID	Value
	N	16 SINGFAM
	N	1 313847881
Related Activity: Type	ID	Safety Health
	Referral 201269727	Yes

	Violation Summary					
	Serious	Willful	Repeat	Other	Unclass	Total
Initial Violations	1					1
Current Violations	1					1
Initial Penalty	1500					1500
Current Penalty	750					750
FTA Amount						

Violation Items										
#	ID	Type	Standard	Issuance	Abate	Curr\$	Init\$	Fta\$	Contest	LastEvent
1.	01001A	Serious	19260020 B02	10/19/2009	10/23/2009	\$750	\$1500	\$0		I - Informal Settlement
2.	01001B	Serious	19260416 A01	10/19/2009	10/23/2009	\$0	\$0	\$0		-
3.	01001C	Serious	19260416 A03	10/19/2009	10/23/2009	\$0	\$0	\$0		-



UNITED STATES
DEPARTMENT OF LABOR

Occupational Safety & Health Administration

All DOL

[A to Z Index](#) | [En Español](#) | [Contact Us](#)

[OSHA Home](#)

[RSS Feeds](#) [Print This Page](#)

Inspection: 313847907 - Turbacz Construction, Inc.

Inspection Information - Office: Chicago North			
Nr: 313847907	Report ID:0524200	Open Date: 10/14/2009	
Turbacz Construction, Inc. 1708 W. Crescent Ave. Park Ridge, IL 60068		Union Status: NonUnion	
SIC: 1761/Roofing, Siding, and Sheet Metal Work NAICS: 238160/Roofing Contractors Mailing: 7673 W Forest Preserve Dr., Chicago, IL 60634			
Inspection Type: Unprog Rel Scope: Partial Ownership: Private Safety/Health: Safety Emphasis: S:Electrical,S:Residential Constr		Advanced Notice: N Close Conference: 10/16/2009 Close Case: 11/17/2009	
Optional Information: Type	ID	Value	
N	1	313847881	
N	16	SINGFAM	
Related Activity: Type	ID	Safety	Health
Referral 201269727 Yes			

	Violation Summary					
	Serious	Willful	Repeat	Other	Unclass	Total
Initial Violations	1					1
Current Violations	1					1
Initial Penalty	1500					1500
Current Penalty	750					750
FTA Amount						

Violation Items										
#	ID	Type	Standard	Issuance	Abate	Curr\$	Init\$	Fta\$	Contest	LastEvent
1.	01001A	Serious	19260020 B02	10/19/2009	10/23/2009	\$750	\$1500	\$0		I - Informal Settlement
2.	01001B	Serious	19260416 A01	10/19/2009	10/23/2009	\$0	\$0	\$0		-
3.	01001C	Serious	19260416 A03	10/19/2009	10/23/2009	\$0	\$0	\$0		-

[Freedom of Information Act](#) | [Privacy & Security Statement](#) | [Disclaimers](#) | [Customer Survey](#) | [Important Web Site Notices](#) | [Internal](#)

U.S. Department of Labor | Occupational Safety & Health Administration | 200 Constitution Ave., NW, Washington, DC 20210



UNITED STATES
DEPARTMENT OF LABOR
Occupational Safety & Health Administration

ALL DOL

[A to Z Index](#) | [En Español](#) | [Contact Us](#)

[OSHA Home](#)

[RSS Feeds](#) [Print This Page](#)

Inspection: 313847899 - Roman Master Services, Inc.

Inspection Information - Office: Chicago North			
Nr: 313847899	Report ID:0524200	Open Date: 10/14/2009	
Roman Master Services, Inc. 1708 W. Crescent Ave. Park Ridge, IL 60068 SIC: 1751/Carpentry Work NAICS: 238130/Framing Contractors Mailing: 3254 N. Natchez, Chicago, IL 60634		Union Status: NonUnion	
Inspection Type: Unprog Rel Scope: Partial Ownership: Private Safety/Health: Safety Emphasis: S:Electrical,S:Residential Constr		Advanced Notice: N Close Conference: 10/16/2009 Close Case: 11/17/2009	
Optional Information: Type	ID	Value	
N	16	SINGFAM	
N	1	313847881	
Related Activity: Type	ID	Safety	Health
Referral 201269727 Yes			

	Violation Summary					
	Serious	Willful	Repeat	Other	Unclass	Total
Initial Violations	1					1
Current Violations	1					1
Initial Penalty	1500					1500
Current Penalty	750					750
FTA Amount						

Violation Items										
#	ID	Type	Standard	Issuance	Abate	Curr\$	Init\$	Fta\$	Contest	LastEvent
1.	01001A	Serious	19260020 B02	10/19/2009	10/23/2009	\$750	\$1500	\$0		I - Informal Settlement
2.	01001B	Serious	19260416 A01	10/19/2009	10/23/2009	\$0	\$0	\$0		-
3.	01001C	Serious	19260416 A03	10/19/2009	10/23/2009	\$0	\$0	\$0		-

[Freedom of Information Act](#) | [Privacy & Security Statement](#) | [Disclaimers](#) | [Customer Survey](#) | [Important Web Site Notices](#) | [Internal](#)

U.S. Department of Labor | Occupational Safety & Health Administration | 200 Constitution Ave., NW, Washington, DC 20210



UNITED STATES
DEPARTMENT OF LABOR

Occupational Safety & Health Administration

ALL DOL

[A to Z Index](#) | [En Español](#) | [Contact Us](#)

[OSHA Home](#)

[RSS Feeds](#) [Print This Page](#)

[Regulations \(Standards - 29 CFR\) - Table of Contents](#)

• Part Number:	1926
• Part Title:	Safety and Health Regulations for Construction
• Subpart:	K
• Subpart Title:	Electrical
• Standard Number:	<u>1926.416</u>
• Title:	General requirements.
• Applicable Standards:	<u>1910.333</u> ; <u>1910.334</u>

1926.416(a)

Protection of employees -

1926.416(a)(1)

No employer shall permit an employee to work in such proximity to any part of an electric power circuit that the employee could contact that electric power circuit in the course of work, unless the employee is protected against electric shock by deenergizing the circuit and ground it or by guarding it effectively by insulation or other means.

1926.416(a)(2)

In work areas where the exact location of underground electric powerlines is unknown, employees using jack-hammers, bars, or other hand tools which may contact a line shall be provided with insulated protective gloves.

1926.416(a)(3)

Before work is begun the employer shall ascertain by inquiry or direct observation, or by instruments, whether any part of an energized electric power circuit, exposed or concealed, is so located that the performance of the work may bring any person, tool, or machine into physical or electrical contact with the electric power circuit. The employer shall post and maintain proper warning signs where such a circuit exists. The employer shall advise employees of the location of such lines, the hazards involved, and the protective measures to be taken.

..1926.416(b)

1926.416(b)

Passageways and open spaces -

1926.416(b)(1)

Barriers or other means of guarding shall be provided to ensure that workspace for electrical equipment will not be used as a passageway during periods when energized parts of electrical equipment are exposed.

1926.416(b)(2)

Working spaces, walkways, and similar locations shall be kept clear of cords so as not to create a hazard to employees.

1926.416(c)

Load ratings. In existing installations, no changes in circuit protection shall be made to increase the load in excess of the load rating of the circuit wiring.

1926.416(d)

Fuses. When fuses are installed or removed with one or both terminals energized, special tools insulated for the voltage shall be used.

1926.416(e)

Cords and cables.

1926.416(e)(1)

Worn or frayed electric cords or cables shall not be used.

1926.416(e)(2)

Extension cords shall not be fastened with staples, hung from nails, or suspended by wire.

[58 FR 35179, June 30, 1993; 61 FR 9227, March 7, 1996; 61 FR 41738, August 12, 1996]

◀ [Next Standard \(1926.417\)](#)

◀ [Regulations \(Standards - 29 CFR\) - Table of Contents](#)

[Freedom of Information Act](#) | [Privacy & Security Statement](#) | [Disclaimers](#) | [Customer Survey](#) | [Important Web Site Notices](#) | [Interna](#)

U.S. Department of Labor | Occupational Safety & Health Administration | 200 Constitution Ave., NW, Washington, DC 20210
Telephone: 800-321-OSHA (6742) | TTY: 877-889-5627

www.OSHA.gov
