

Com Ed Offer of Proof Ex. 1

Account Number 02844-25001	Field Order # N/A	AMS Meter No W140384879 {DJLS6R 08}
Service Address 1919 S. Butterfield Rd.		CIMS Meter No 140384879
Town Mundelien	Name on Account Rexam Medical Packaging	

**SYSTEM METER TEST REPORT**

Inventoried Location TIAD 13	Tester ID T. Rumsey	Test Board type & NO. WECO 2150 # 73		
<table border="1"> <tr> <td>Calibration Check</td> <td>N</td> </tr> </table>	Calibration Check	N	DATE 9/24/2009	Meter Reading Er 000001
Calibration Check	N			

	1ST Run	2ND Run	Average
F.L.	99.96	99.95	99.95
P.F.	99.99	99.98	99.98
L.L.	99.95	99.94	99.94

**SYSTEM METER REMARKS**

**Customer Complaint Test.** A 10/5/2 test was conducted. Weighted Average test results = 99.95%. A long diagnostic register read was also conducted. A scaling factor of 6 was found which translates to A CPR of 4. The correct scaling factor is 2 which translates to a CPR of 12. The long diagnostic read is contained in 140384.doc the scaling factor can be found on page 4 under the heading Load Profile Defenition. The meter will be held on Shelf TIAD 13 in the tamper room for 1 year.

Tampering Yes  No

**OFFICIAL FILE**

I.C.C. DOCKET NO. 11-0033  
 Com Ed Exhibit No. 1  
 Witness Rumsey  
 Date 5/2/12 Reporter P.W.