



Docket No. 12-0484
ComEd Ex. 2.1

PJM Load Management

PJM State & Member Training
August, 2012
Version 8



Three Product Types available beginning in the 2014/2015 DY

Requirement	Limited DR	Extended Summer DR	Annual DR
Availability	Any weekday, other than NERC holidays, during June – Sept. period of DY	Any day during June-October period and following May of DY	Any day during DY (unless on an approved maintenance outage during Oct. - April)
Maximum Number of Interruptions	10 interruptions	Unlimited	Unlimited
Hours of Day Required to Respond <i>(Hours in EPT)</i>	12:00 PM – 8:00 PM	10:00 AM – 10:00 PM	Jun – Oct. and following May: 10 AM – 10 PM Nov. – April: 6 AM- 9 PM
Maximum Duration of Interruption	6 Hours	10 Hours	10 Hours
Notification	Must be able to reduce load when requested by PJM All Call system within 2 hours of notification, without additional approvals required		
Registration in eLRS	Must register sites in Emergency Load Response Program in Load Response System (eLRS)		
Event Compliance	Must provide customer-specific compliance and verification information within 45 days after the end of month in which PJM-initiated LM event occurred.		
Test Compliance	In absence of the PJM-initiated LM event, CSP must test load management resources and provide customer-specific compliance and verification information.		