

ICC Docket No. 13-0552

**Commonwealth Edison Company's Response to
Illinois Commerce Commission ("STAFF") Data Requests
EPS 2.01 – 2.06
Date Received: November 1, 2013
Date Served: November 8, 2013**

REQUEST NO. EPS 2.04:

Please describe in detail ComEd's current meter replacement policy.

RESPONSE:

ComEd replaces meters due to a number of operational and regulated triggers. The more common triggers include but are not limited to:

- Requirements as described in Il. Administrative Code Part 410 that include:
 - Periodic exchanges of interval data recorders
 - Random samples used in accuracy testing
 - Group of meters associated with a failed vintage random test

- Meter Failure (stopped, slow, damaged, etc.)
 - Customer reported
 - Employee reported

- Change in tariff requirements (e.g., competitive declaration)

- Customer request for RRTP (or a RES request for an interval data recording meter)

- Customer service upgrade (e.g. many villages require A 60 amp or 100 amp service upgrade to 200 amp on the sale of a home)