PDM Ex. 8.15 – DR Channon-ICC 1.03

Docket No. 12-0598 – (Rehearing)
Response to Channon Trust's
First Set of Data Requests to ICC Staff
Response Date: November 7, 2013

ICC Person Responsible:	Greg Rockrohr
Title:	Senior Electrical Engineer, Safety & Reliability Division
Business Address:	Illinois Commerce Commission 527 East Capitol Avenue Springfield, IL 62701
Telephone:	217/524-0695

REQUEST Channon-ICC 1.03:

Please identify the reasons and criteria used to select the Option 1 and Option 2 proposed substation sites on Staff's alternative route from Pawnee to Mt. Zion through the Kincaid substation.

RESPONSE:

Mr. Rockrohr identified the Option 1 and Option 2 substation sites because this area was previously identified by the Village of Mt. Zion as a potential substation site, and because of his own belief that these sites are close enough to the Decatur area to provide adequate voltage supply, even under contingency conditions. In addition, use of either site would provide the ability to use the Mt. Zion to Kansas segment route alternatives that have already been submitted in this docket.