

Kankakee Water Division

Section 285.325 (c)

285.325 (c)

Peak day and peak hour (if available) water flows for the last three years.

Kankakee Water Division

	<u>Peak Day</u>
July 20, 2011	17.667 MG
June 15, 2012	16.010 MG
August 20, 2013	15.625 MG

	<u>Peak Hour Day</u>
July 20, 2011 (11pm - 12am)	744,000 GPH
June 15, 2012 (11am - 12pm)	764,000 GPH
August 20, 2013 (10pm - 11pm)	722,000 GPH