Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
131660838	D36002	06/15/2013	16:18	06/15/2013	17:17	1	59	59	Overhead equipment	Fuse	Repair		I
131660849	Y55505	06/15/2013	16:31	06/15/2013	18:30	6	714	119	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
131660868	S18535	06/15/2013	16:53	06/15/2013	19:57	1	184	184	Substation equipment	Regulator	Patrol/Test/Inspect		VI
131660879	H06135	06/15/2013	17:04	06/15/2013	18:10	1	66	66	Overhead equipment	Overhead Service			IV
131660902	301051	06/15/2013	17:19	06/15/2013	18:35	1	76	76	Weather	Fuse	Repair		VI
131660911	B19002	06/15/2013	17:25	06/15/2013	19:16	1	111	111	Unknown	Fuse	Repair	Replace - Same Size	I
131660711	K11376	06/15/2013	18:36	06/15/2013	19:16	1	40	40	Tree related-tree contact	Overhead Service	Repair	Repair	V
131661047	334004	06/15/2013	18:43	06/15/2013	20:00	1	77	77	Public	Overhead Service	Repair		VI
131661151	V50001	06/15/2013	19:18	06/16/2013	5:25	101	61307	607	Tree related-tree broken	Tree			II
131661190	U16500	06/15/2013	19:20	06/15/2013	20:34	335	24790	74	Tree related-tree broken	Tree	Remove	Remove	II
131661156	V41533	06/15/2013	19:24	06/16/2013	1:10	94	32524	346	Tree related-tree broken	Overhead Primary	Repair		II
131661489	V49541	06/15/2013	19:27	06/16/2013	11:18	41	38991	951	Tree related-tree broken	Pole			II
131661477	V49541	06/15/2013	19:28	06/16/2013	11:15	37	35039	947	Tree related-tree broken	Pole		Replace - Same Size	II
131661191	V40556	06/15/2013	19:29	06/16/2013	12:21	9	9108	1012	Tree related-tree broken	Tree		Cut in Clear	II
131661189		06/15/2013	19:32	06/15/2013	20:34	1	62	62	Tree related-tree broken				II
131661296	V41568	06/15/2013	19:33	06/16/2013	3:30	1	477	477	Tree related-tree broken	Overhead Service			II
131670073	V36001	06/15/2013	19:37	06/15/2013	22:30	71	12283	173	Tree related-tree broken	Tree	Cut in Clear		II
131661209	K01239	06/15/2013	19:39	06/15/2013	21:11	8	736	92	Animal related	Transformer Fuse	Replace - Same Size		VI
131661219	V31001	06/15/2013	19:41	06/15/2013	23:40	1	239	239	Tree related-tree broken	Overhead Primary		Repair	II
131661266	V69546	06/15/2013	19:44	06/16/2013	3:06	44	19448	442	Tree related-tree broken	Crossarm	Replace - Same Size	Replace - Same Size	II
131661323	U59001	06/15/2013	19:53	06/16/2013	0:27	235	64390	274	Overhead equipment	Recloser	Switch/Reset		II
131661336	P72318	06/15/2013	19:54	06/15/2013	21:55	42	5082	121	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	V
131661503	U10525	06/15/2013	19:54	06/16/2013	0:27	69	18837	273	Overhead equipment	Recloser	Switch/Reset		II
131661457	V69558	06/15/2013	19:57	06/15/2013	22:57	14	2520	180	Weather	Fuse	Replace - Same Size		II
131661311		06/15/2013	19:59	06/15/2013	20:34	1	35	35	Tree related-tree broken				II
131661297	V28597	06/15/2013	20:01	06/16/2013	4:18	1	497	497	Tree related-tree broken	Overhead Service		Repair	II
131661351	K62102	06/15/2013	20:13	06/15/2013	23:22	1	189	189	Tree related-tree contact	Overhead Secondary	Repair	No Work Required	II
131661356	V35003	06/15/2013	20:15	06/16/2013	4:49	2	1028	514	Tree related-tree broken	Overhead Service	Replace - Same Size	Replace - Same Size	II
131661379	K62102	06/15/2013	20:23	06/15/2013	22:30	1	127	127	Weather	Transformer Fuse	Replace - Same Size		II
131661407	U68003	06/15/2013	20:28	06/16/2013	1:50	10	3220	322	Weather	Fuse	Replace - Same Size		II
131661401	R06209	06/15/2013	20:29	06/16/2013	2:00	4	1324	331	Weather	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	II
131661399	C37002	06/15/2013	20:29	06/15/2013	22:02	1	93	93	Animal related	Fuse	Replace - Same Size	No Work Required	III
131661415	J58381	06/15/2013	20:32	06/15/2013	21:57	1	85	85	Overhead equipment	Fuse			III
131661417	V39002	06/15/2013	20:33	06/16/2013	6:00	1	567	567	Tree related-tree broken	Transformer Fuse	Replace - Same Size		II
131661545	V21548	06/15/2013	20:45	06/15/2013	23:40	60	10500	175	Weather	Fuse	Replace - Same Size		II
131661490	M37191	06/15/2013	20:47	06/16/2013	5:27	1	520	520	Weather	Overhead Transformer	Replace - Same Size	Replace - Same Size	I
131661504	P74911	06/15/2013	20:49	06/15/2013	22:32	1	103	103	Substation equipment	Substation Misc.	Patrol/Test/Inspect	Replace - Same Size	VI
131661506	V92542	06/15/2013	20:50	06/16/2013	5:50	3	1620	540	Tree related-tree broken	Fuse	Replace - Same Size	Patrol/Test/Inspect	II
131662443	H11340	06/15/2013	20:51	06/16/2013	1:45	23	6762	294	Overhead equipment	Recloser	Switch/Reset	Switch/Reset	V
131662078	309139	06/15/2013	20:54	06/16/2013	3:50	13	5408	416	Tree related-tree broken	Overhead Secondary	Cut in Clear	Repair	V
131661659	310124	06/15/2013	20:54	06/16/2013	1:35	18	5058	281	Weather	Overhead Primary	Repair		V
131661548	340101	06/15/2013	20:56	06/16/2013	0:34	1	218	218	Tree related-tree contact	Overhead Transformer	Switch/Reset		V
131661697	M05368	06/15/2013	20:56	06/16/2013	3:55	14	5866	419	Overhead equipment	Lightning Arrestor	Repair	Repair	V
131661551	P47120	06/15/2013	20:57	06/15/2013	23:35	6	948	158	Overhead equipment	Overhead Transformer	Switch/Reset		I
131661550	J15302	06/15/2013	20:57	06/15/2013	22:12	1	75	75	Animal related	Transformer Fuse	Replace - Same Size	Replace - Same Size	I
131661603	327155	06/15/2013	20:57	06/15/2013	23:18	29	4089	141	Tree related-tree contact	Fuse	Replace - Same Size		V
131661586	340101	06/15/2013	20:57	06/15/2013	22:27	21	1890	90	Tree related-tree contact	Fuse			V
131661561	V41568	06/15/2013	20:59	06/16/2013	2:10	1	311	311	Overhead equipment				II
131661645	K52401	06/15/2013	20:59	06/16/2013	0:40	1893	418353	221	Tree related-tree broken	Tree			V
131662050	M05361	06/15/2013	21:00	06/16/2013	2:25	52	16900	325	Weather	Fuse	Replace - Same Size		V
131661577	339160	06/15/2013	21:01	06/15/2013	23:09	6	768	128	Overhead equipment	Overhead Transformer	Switch/Reset	No Work Required	V
131661669	346002	06/15/2013	21:05	06/16/2013	1:10	5	1225	245	Tree related-tree contact	Fuse	Replace - Same Size		VI
131661633	M81403	06/15/2013	21:06	06/15/2013	23:45	18	2862	159	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	V
131662393	342001	06/15/2013	21:07	06/15/2013	23:11	43	5332	124	Overhead equipment	Fuse	Switch/Reset		VI
131661670		06/15/2013	21:11	06/16/2013	0:24	1	193	193	Tree related-tree contact				V
131661672	R04409	06/15/2013	21:12	06/16/2013	4:26	1	434	434	Weather	Overhead Transformer	Replace - Same Size		V

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
131661857	342001	06/15/2013	21:14	06/16/2013	13:37	37	36371	983	Tree related-tree broken	Tree	Patrol/Test/Inspect	Repair	VI
131661705	P05825	06/15/2013	21:20	06/16/2013	0:20	1	180	180	Overhead equipment	Transformer Fuse	Replace - Same Size		V
131670105	A85001	06/15/2013	21:22	06/16/2013	13:00	43	40334	938	Tree related-tree contact	Overhead Primary	Cut in Clear	Repair	I
131661879	A85001	06/15/2013	21:22	06/16/2013	0:12	60	10200	170	Tree related-tree broken	Overhead Primary	Cut in Clear	Repair	I
131661849	P54827	06/15/2013	21:24	06/16/2013	1:42	35	9030	258	Tree related-tree broken	Overhead Primary			V
131661832	309143	06/15/2013	21:26	06/16/2013	0:23	1	177	177	Tree related-tree broken	Overhead Service	Repair	No Work Required	V
131661920	M73330	06/15/2013	21:26	06/15/2013	22:54	55	4840	88	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	V
131661875	309142	06/15/2013	21:32	06/16/2013	2:28	1	296	296	Tree related-tree contact	Overhead Service	Move	Repair	V
131662414	B38002	06/15/2013	21:32	06/15/2013	23:40	343	43904	128	Tree related-tree broken	Overhead Primary	Repair		I
131661876	R28870	06/15/2013	21:33	06/16/2013	3:30	7	2499	357	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	V
131661915	M05360	06/15/2013	21:37	06/16/2013	1:40	109	26487	243	Weather	Overhead Primary	Patrol/Test/Inspect	Tie/Tighten	V
131670355	Q32170	06/15/2013	21:39	06/16/2013	11:37	1425	1194150	838	Overhead equipment	Pole	Replace - Urgent		I
131661912	A85001	06/15/2013	21:40	06/16/2013	0:12	8	1216	152	Tree related-tree broken				I
131661967	A91002	06/15/2013	21:44	06/16/2013	0:24	46	7360	160	Weather	Fuse	Replace - Same Size		I
131661935	K52421	06/15/2013	21:45	06/16/2013	6:38	1	533	533	Weather				V
131662019	B77002	06/15/2013	21:46	06/16/2013	1:52	92	22632	246	Tree related-tree broken	Overhead Primary	Repair	Repair	I
131662433	B19001	06/15/2013	21:50	06/16/2013	4:37	8	3256	407	Unknown	Fuse	Replace - Same Size		I
131661968	B73002	06/15/2013	21:50	06/16/2013	6:12	11	5522	502	Overhead equipment	Fuse	Repair		I
131662116	P47BUS69	06/15/2013	21:51	06/15/2013	23:35	1493	155272	104	Overhead equipment				I
131662005	Y07576	06/15/2013	22:01	06/16/2013	3:30	1	329	329	Underground equipment	Underground Primary		Repair	IV
131662001	K46388	06/15/2013	22:01	06/16/2013	6:19	1	498	498	Weather	Overhead Service		No Work Required	V
131662016	327155	06/15/2013	22:02	06/15/2013	23:18	1	76	76	Tree related-tree broken	Fuse	Replace - Same Size		V
131662025	N60181	06/15/2013	22:05	06/15/2013	23:37	2	184	92	Weather	Overhead Transformer	Repair		I
131662032	L74191	06/15/2013	22:06	06/16/2013	1:13	1	187	187	Tree related-tree broken	Tree			IV
131662018	P05825	06/15/2013	22:10	06/16/2013	0:02	1	112	112	Overhead equipment	Tree			V
131662072	J20931	06/15/2013	22:12	06/15/2013	23:00	210	10080	48	Overhead equipment	Jumper	Repair		VI
131662068	L23145	06/15/2013	22:17	06/15/2013	23:53	1	96	96	Weather	Transformer Fuse	Replace - Same Size		III
131662081	X20001	06/15/2013	22:21	06/16/2013	0:50	5	745	149	Overhead equipment	Fuse	Replace - Same Size		IV
131662082	B28006	06/15/2013	22:22	06/16/2013	1:23	1	181	181	Overhead equipment	Overhead Transformer	Repair	Replace - Same Size	I
131670057	Q32171	06/15/2013	22:23	06/16/2013	11:37	548	435112	794	Overhead equipment	Pole	Replace - Urgent		I
131662178	Q91141	06/15/2013	22:24	06/15/2013	23:32	818	55624	68	Overhead equipment	Pole	Switch/Reset		I
131662275	Q91175	06/15/2013	22:24	06/15/2013	23:32	795	54060	68	Overhead equipment	Pole	Switch/Reset		I
131662364	X20001	06/15/2013	22:26	06/16/2013	0:50	16	2304	144	Overhead equipment	Fuse	Replace - Same Size		IV
131662193	K91117	06/15/2013	22:30	06/16/2013	4:23	6	2118	353	Weather	Overhead Transformer	Patrol/Test/Inspect	Replace - Urgent	III
131661692	309139	06/15/2013	22:30	06/16/2013	1:50	72	14400	200	Tree related-tree broken	Overhead Primary	Cut in Clear		V
131662224	B82002	06/15/2013	22:32	06/16/2013	1:44	1	192	192	Overhead equipment	Overhead Primary	Repair		I
131662262	J01118	06/15/2013	22:35	06/16/2013	0:57	1	142	142	Tree related-tree contact	Overhead Service	Repair	Repair	I
131662283	K89144	06/15/2013	22:35	06/16/2013	0:01	119	10234	86	Weather	Fuse			III
131662451	B77003	06/15/2013	22:37	06/15/2013	22:59	8	176	22	Overhead equipment	Crossarm	Replace - Same Size		I
131662303	X57003	06/15/2013	22:39	06/16/2013	0:11	2	184	92	Tree related-tree broken	Tree	Remove		IV
131670070	Q47833	06/15/2013	22:39	06/16/2013	1:35	3	528	176	Weather	Transformer Fuse	Repair	Repair	V
131662315	H10843	06/15/2013	22:39	06/16/2013	0:35	15	1740	116	Weather	Fuse	Replace - Same Size		V
131662317	N67309	06/15/2013	22:41	06/16/2013	1:23	4	648	162	Tree related-tree contact	Overhead Transformer	No Work Required		I
131662353	B82002	06/15/2013	22:43	06/16/2013	1:44	4	724	181	Overhead equipment	Overhead Primary	Repair		I
131662332	B82002	06/15/2013	22:44	06/16/2013	1:44	1	180	180	Overhead equipment	Overhead Primary	Repair		I
131662346	K94224	06/15/2013	22:48	06/16/2013	5:02	1	374	374	Tree related-tree contact	Overhead Secondary	Patrol/Test/Inspect	Repair	III
131662365	K43385	06/15/2013	22:55	06/16/2013	2:45	1	230	230	Weather	Overhead Service	Patrol/Test/Inspect	No Work Required	V
131662368	U78001	06/15/2013	22:57	06/16/2013	2:10	1	193	193	Tree related-tree broken	Overhead Service	Repair		II
131662369	Y01524	06/15/2013	22:58	06/16/2013	2:00	1	182	182	Tree related-tree contact	Overhead Secondary	Patrol/Test/Inspect		IV
131670059	Q47833	06/15/2013	23:02	06/16/2013	0:37	19	1805	95	Overhead equipment	Crossarm			V
131662378	B10001	06/15/2013	23:03	06/16/2013	1:27	1	144	144	Overhead equipment	Disconnect Switch	Replace - Same Size		I
131670164	G50001	06/15/2013	23:10	06/16/2013	7:35	14	7070	505	Overhead equipment	Pole		Replace - Same Size	IV
131662401	K28183	06/15/2013	23:13	06/16/2013	3:43	1	270	270	Weather	Overhead Transformer	Patrol/Test/Inspect	Replace - Urgent	III
131662437	G50001	06/15/2013	23:13	06/16/2013	2:20	52	9724	187	Overhead equipment	Pole	Replace - Same Size	Replace - Same Size	IV
131662412	342001	06/15/2013	23:20	06/15/2013	23:46	1	26	26	Tree related-tree broken	Overhead Service	Repair		VI
131662416	P26280	06/15/2013	23:21	06/16/2013	2:54	1	213	213	Animal related	Fuse	Patrol/Test/Inspect		I

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
131662419	Y13044	06/15/2013	23:22	06/16/2013	2:45	1	203	203	Tree related-tree broken	Overhead Service	Repair		IV
131662426	K75311	06/15/2013	23:28	06/16/2013	0:30	1	62	62	Tree related-tree broken	Overhead Service	Cut in Clear	No Work Required	IV
131662427	P54827	06/15/2013	23:29	06/16/2013	1:44	3	405	135	Tree related-tree broken	Overhead Secondary	Repair		V
131670009	K65221	06/15/2013	23:42	06/16/2013	2:59	8	1576	197	Tree related-tree contact	Fuse			III
131662452	R53391	06/15/2013	23:43	06/16/2013	10:13	1	630	630	Underground equipment	Underground Service		Repair	V
131662461	X24536	06/15/2013	23:48	06/16/2013	1:40	142	15904	112	Tree related-tree broken	Fuse	Replace - Same Size		IV
131662456	M37191	06/15/2013	23:49	06/16/2013	2:02	1	133	133	Overhead equipment	Overhead Transformer	Replace - Same Size	Replace - Same Size	I
131662459	X35501	06/15/2013	23:53	06/16/2013	1:30	11	1067	97	Tree related-tree broken	Overhead Primary	Repair		IV
131662330	J63172	06/16/2013	0:06	06/16/2013	3:15	1	189	189	Overhead equipment	Overhead Secondary			III
131670017	N18210	06/16/2013	0:11	06/16/2013	7:00	7	2863	409	Underground equipment	Underground Primary			III
131670026	L24122	06/16/2013	0:16	06/16/2013	4:20	1	244	244	Weather	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	III
131670034	B82001	06/16/2013	0:20	06/16/2013	10:30	1	610	610	Underground equipment	Underground Primary	Patrol/Test/Inspect		I
131670207	B45005	06/16/2013	0:20	06/16/2013	15:17	19	17043	897	Tree related-tree broken	Overhead Primary	Repair		I
131670041	B45005	06/16/2013	0:20	06/16/2013	4:00	95	20900	220	Tree related-tree contact	Overhead Primary		Repair	I
131670052	J47175	06/16/2013	0:20	06/16/2013	2:18	611	72098	118	Overhead equipment	Other			III
131670061	N05172	06/16/2013	0:32	06/16/2013	4:30	1	238	238	Tree related-tree broken	Overhead Service	Repair		I
131670062	309139	06/16/2013	0:34	06/16/2013	1:50	1	76	76	Tree related-tree broken				V
131670170	D87001	06/16/2013	0:39	06/16/2013	19:05	17	18802	1106	Tree related-tree broken	Pole	Patrol/Test/Inspect	Replace - Urgent	I
131670098	L43154	06/16/2013	0:46	06/16/2013	5:08	106	27772	262	Tree related-tree contact	Overhead Primary			I
131670302	A91001	06/16/2013	0:57	06/16/2013	8:45	4	1872	468	Underground equipment	Underground Transformer		Repair	I
131670103	A91001	06/16/2013	0:57	06/16/2013	6:30	101	33633	333	Underground equipment	Underground Primary		Repair	I
131670196	C70004	06/16/2013	1:12	06/16/2013	9:40	8	4064	508	Underground equipment	Underground Primary			III
131670132	C70004	06/16/2013	1:19	06/16/2013	4:08	202	34138	169	Underground equipment	Underground Primary			III
131670229	B21004	06/16/2013	1:44	06/16/2013	13:37	3	2139	713	Underground equipment	Underground Transformer	Repair	Repair	I
131670184	B21004	06/16/2013	1:49	06/16/2013	4:19	4	600	150	Underground equipment	Underground Transformer	Replace - Same Size	Replace - Same Size	I
131670185	B21004	06/16/2013	1:51	06/16/2013	4:30	33	5247	159	Underground equipment	Underground Transformer	Repair		I
131670151	B25002	06/16/2013	1:52	06/16/2013	7:30	1	338	338	Overhead equipment	Pole	Replace - Same Size	Repair	I
131670153	L68111	06/16/2013	1:56	06/16/2013	2:08	1	12	12	Tree related-tree contact	Overhead Service			IV
131670180	D66001	06/16/2013	3:08	06/16/2013	4:37	1	89	89	Overhead equipment	Fuse			IV
131670181	K27150	06/16/2013	3:08	06/16/2013	5:47	1	159	159	Tree related-tree broken	Overhead Service	Repair	Repair	VI
131670187	S62521	06/16/2013	3:13	06/16/2013	6:30	15	2955	197	Underground equipment	Underground Primary	Repair	Repair	VI
131670192	M05361	06/16/2013	3:59	06/16/2013	6:28	4	596	149	Tree related-tree contact	Disconnect Switch	Replace - Same Size	Replace - Same Size	V
131670214	Y91500	06/16/2013	4:21	06/16/2013	6:15	54	6156	114	Overhead equipment	Jumper	Repair		IV
131670232	J01118	06/16/2013	5:47	06/16/2013	11:14	1	327	327	Overhead equipment	Overhead Service	Repair		I
131670278	Y37593	06/16/2013	6:22	06/16/2013	8:30	33	4224	128	Underground equipment	Fuse	Replace - Same Size	Repair	IV
131670262	K31124	06/16/2013	6:24	06/16/2013	9:20	39	6864	176	Animal related	Overhead Transformer	Repair		I
131670274	D69003	06/16/2013	6:31	06/16/2013	7:20	34	1666	49	Animal related	Fuse	Replace - Same Size		I
131670281	N50331	06/16/2013	6:32	06/16/2013	7:18	13	598	46	Weather	Fuse	Replace - Same Size	No Work Required	II
131670284	J01118	06/16/2013	6:48	06/16/2013	12:02	1	314	314	Overhead equipment	Overhead Service	Repair		I
131670292	Z19547	06/16/2013	6:53	06/16/2013	7:47	1	54	54	Animal related	Transformer Fuse	Replace - Same Size		IV
131670301	Q15844	06/16/2013	7:03	06/16/2013	7:54	1	51	51	Animal related	Transformer Fuse	Replace - Same Size		V
131670318	Q06131	06/16/2013	7:10	06/16/2013	8:04	77	4158	54	Overhead equipment	Fuse			IV
131670328	Q93522	06/16/2013	7:23	06/16/2013	11:22	5	1195	239	Tree related-tree contact	Overhead Service	Patrol/Test/Inspect		I
131670334	H22347	06/16/2013	7:24	06/16/2013	8:39	1	75	75	Animal related	Transformer Fuse	Replace - Same Size	Replace - Same Size	V
131670345	Q34360	06/16/2013	7:26	06/16/2013	9:15	24	2616	109	Animal related	Fuse	Replace - Same Size	Replace - Same Size	I
131670381	P52305	06/16/2013	7:35	06/16/2013	9:55	6	840	140	Animal related	Fuse	Replace - Same Size		IV
131670350	Y69553	06/16/2013	7:36	06/16/2013	12:00	1	264	264	Tree related-tree broken	Tree	Remove	Repair	IV
131670466	K76547	06/16/2013	7:37	06/16/2013	10:05	1043	154364	148	Substation equipment	Substation Breaker	Switch/Reset		IV
131670361	M05360	06/16/2013	7:50	06/16/2013	9:50	1	120	120	Weather	Fuse	Replace - Same Size	Replace - Same Size	V
131670364	Y35515	06/16/2013	7:55	06/16/2013	9:00	6	390	65	Animal related	Fuse	Replace - Same Size		IV
131670368	M05360	06/16/2013	7:57	06/16/2013	9:40	1	103	103	Weather	Fuse	Replace - Same Size	Replace - Same Size	V
131670453	B73002	06/16/2013	7:57	06/16/2013	10:34	11	1727	157	Weather	Disconnect Switch		Replace - Same Size	I
131670375	B00004	06/16/2013	8:03	06/16/2013	13:06	1	303	303	Overhead equipment	Disconnect Switch	Replace - Urgent		I
131670379	P07179	06/16/2013	8:04	06/16/2013	12:25	1	261	261	Overhead equipment	Overhead Transformer	Replace - Same Size	Replace - Same Size	I
131670388	K08909	06/16/2013	8:04	06/16/2013	10:16	39	5148	132	Animal related	Fuse	Replace - Same Size	No Work Required	VI
131670386	L35283	06/16/2013	8:08	06/16/2013	11:13	1	185	185	Tree related-tree broken	Overhead Service	Repair		III

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
131670390	M40116	06/16/2013	8:11	06/16/2013	10:17	1	126	126	Weather	Fuse	Replace - Same Size		I
131670446	Q24313	06/16/2013	8:16	06/16/2013	10:10	9	1026	114	Weather	Transformer Fuse	Replace - Same Size		VI
131670419	P47169	06/16/2013	8:26	06/16/2013	9:10	46	2024	44	Animal related	Overhead Transformer	Switch/Reset		I
131670412	Y97512	06/16/2013	8:27	06/16/2013	10:55	7	1036	148	Tree related-tree broken	Overhead Secondary	Repair	Repair	IV
131670417	D88001	06/16/2013	8:29	06/16/2013	9:09	1	40	40	Weather	Fuse	Replace - Same Size		I
131670422	M45212	06/16/2013	8:33	06/16/2013	11:59	1	206	206	Animal related	Transformer Fuse			IV
131670425	Q06131	06/16/2013	8:36	06/16/2013	11:47	1	191	191	Tree related-tree contact	Transformer Fuse	Replace - Same Size	No Work Required	IV
131670437	N93260	06/16/2013	8:40	06/16/2013	10:44	2	248	124	Overhead equipment	Fuse			III
131670436	K36151	06/16/2013	8:40	06/16/2013	9:28	1	48	48	Animal related	Transformer Fuse	Repair		III
131670450	P77233	06/16/2013	8:47	06/16/2013	11:44	3	531	177	Animal related	Transformer Fuse	Replace - Same Size		VI
131670468	R84148	06/16/2013	9:02	06/16/2013	10:16	1	74	74	Overhead equipment	Overhead Service	No Work Required		I
131670483	Q06141	06/16/2013	9:19	06/16/2013	12:10	2	342	171	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
131670487	U19534	06/16/2013	9:27	06/16/2013	12:39	1	192	192	Animal related	Transformer Fuse	Replace - Same Size		II
131670493	T29561	06/16/2013	9:33	06/16/2013	10:45	6	432	72	Animal related	Transformer Fuse			VI
131670499	M18131	06/16/2013	9:45	06/16/2013	12:54	1	189	189	Overhead equipment	Overhead Transformer	Replace - Same Size		III
131670502		06/16/2013	9:48	06/16/2013	10:44	1	56	56	Animal related	Fuse		Repair	III
131670516	M09143	06/16/2013	9:49	06/16/2013	10:45	6	336	56	Animal related	Fuse	Replace - Same Size	Repair	VI
131670506	303006	06/16/2013	9:49	06/16/2013	16:05	1	376	376	Overhead equipment	Tree	Trim	Replace - New Size	VI
131670508	P18104	06/16/2013	9:50	06/16/2013	10:55	1	65	65	Animal related	Transformer Fuse			IV
131670513	J58380	06/16/2013	9:52	06/16/2013	11:13	1	81	81	Animal related	Fuse		Repair	III
131670649	B80004	06/16/2013	10:03	06/16/2013	13:15	3	576	192	Weather	Fuse	Replace - Same Size		I
131670600	A97002	06/16/2013	10:10	06/16/2013	11:11	2	122	61	Animal related	Underground Transformer	Replace - Same Size		I
131670534	T06505	06/16/2013	10:10	06/16/2013	10:50	1	40	40	Animal related	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
131670604	R05186	06/16/2013	10:40	06/16/2013	13:10	7	1050	150	Overhead equipment	Fuse	Patrol/Test/Inspect	No Work Required	I
131670574	Q91175	06/16/2013	10:42	06/16/2013	12:48	1	126	126	Overhead equipment	Overhead Service	No Work Required		I
131670577	K76545	06/16/2013	10:47	06/16/2013	11:25	49	1862	38	Animal related	Fuse	Replace - Same Size		IV
131670583	Q21423	06/16/2013	10:50	06/16/2013	13:04	1	134	134	Animal related	Transformer Fuse	Replace - Same Size		VI
131670587	J05138	06/16/2013	10:54	06/16/2013	13:24	1	150	150	Overhead equipment	Overhead Service	No Work Required		I
131670611	V19001	06/16/2013	11:22	06/16/2013	14:23	1	181	181	Tree related-tree contact	Other			II
131670613	U35511	06/16/2013	11:29	06/16/2013	13:23	2	228	114	Animal related	Transformer Fuse	Replace - Same Size		II
131670626	Y82590	06/16/2013	11:42	06/16/2013	13:30	4	432	108	Animal related	Transformer Fuse	Replace - Same Size		IV
131670629	M40116	06/16/2013	11:47	06/16/2013	14:00	1	133	133	Overhead equipment	Overhead Transformer	Replace - Same Size	Replace - Same Size	I
131670639	L86175	06/16/2013	11:57	06/16/2013	12:01	1	4	4	Tree related-tree contact	Overhead Service			IV
131670642	J83138	06/16/2013	12:00	06/16/2013	13:52	1	112	112	Overhead equipment	Transformer Fuse	Replace - Same Size		VI
131670650	N15849	06/16/2013	12:04	06/16/2013	14:45	1	161	161	Tree related-tree broken	Tree	Patrol/Test/Inspect	Remove	V
131670665	Q32170	06/16/2013	12:21	06/16/2013	14:10	1	109	109	Tree related-tree contact	Overhead Service	Replace - New Size	Repair	I
131670676	K43386	06/16/2013	12:45	06/16/2013	14:34	1	109	109	Animal related	Transformer Fuse	Replace - Same Size	Replace - Same Size	V
131670684	K65221	06/16/2013	13:00	06/16/2013	14:45	1	105	105	Animal related	Fuse			III
131670755	M61302	06/16/2013	13:22	06/16/2013	15:15	1	113	113	Tree related-tree contact	Overhead Secondary	Repair	Repair	V
131670759	K01241	06/16/2013	13:30	06/16/2013	20:22	6	2472	412	Underground equipment	Underground Transformer	Replace - Same Size	Replace - Urgent	VI
131670761	V77543	06/16/2013	13:32	06/16/2013	15:20	1	108	108	Weather	Transformer Fuse	Replace - Same Size		II
131670772	U11531	06/16/2013	13:47	06/16/2013	15:12	1	85	85	Overhead equipment	Overhead Primary	Repair	Repair	II
131670774	V45526	06/16/2013	13:48	06/16/2013	16:20	1	152	152	Overhead equipment	Overhead Service	Repair		II
131670775	K62102	06/16/2013	13:52	06/16/2013	15:52	1	120	120	Weather	Overhead Transformer	Replace - Same Size	No Work Required	II
131670828	K30205	06/16/2013	15:08	06/16/2013	16:04	1	56	56	Animal related	Fuse			III
131670829	V74506	06/16/2013	15:09	06/16/2013	16:07	1	58	58	Animal related	Fuse	Replace - Same Size		II
131670831	Y50002	06/16/2013	15:11	06/16/2013	16:15	1	64	64	Tree related-tree contact	Overhead Service			IV
131670850	X30506	06/16/2013	15:43	06/16/2013	17:30	1	107	107	Tree related-tree contact	Overhead Service	Repair		IV
131670864	B80002	06/16/2013	15:55	06/16/2013	16:50	1	55	55	Overhead equipment	Connector	Replace - Same Size		I
131670872	308003	06/16/2013	16:05	06/16/2013	21:00	1	295	295	Tree related-tree contact	Tree	Patrol/Test/Inspect		VI
131670893	T15571	06/16/2013	16:30	06/16/2013	18:01	8	728	91	Overhead equipment	Overhead Primary	Repair		VI
131670890	Y48001	06/16/2013	16:31	06/16/2013	17:12	1	41	41	Tree related-tree contact	Overhead Service	Disconnect	Disconnect	IV
131670897	D31016	06/16/2013	16:37	06/16/2013	17:30	1	53	53	Overhead equipment	Connector	Replace - Same Size		III
131670899	M05360	06/16/2013	16:39	06/16/2013	17:39	1	60	60	Animal related	Transformer Fuse	Replace - Same Size	Replace - Same Size	V
131670901	B73002	06/16/2013	16:44	06/16/2013	19:45	1	181	181	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Repair	I
131670904	J06167	06/16/2013	16:48	06/16/2013	18:44	1	116	116	Animal related	Overhead Transformer	Switch/Reset		I

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
131670905	P62138	06/16/2013	16:49	06/16/2013	20:30	1	221	221	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Repair	VI
131670910	R06209	06/16/2013	17:03	06/16/2013	18:50	1	107	107	Underground equipment	Underground Secondary	Replace - New Size	No Work Required	II
131670911	C37002	06/16/2013	17:09	06/16/2013	17:59	1	50	50	Overhead equipment	Fuse	Replace - Same Size		III
131670915	L62928	06/16/2013	17:16	06/16/2013	19:03	1	107	107	Overhead equipment	Overhead Secondary	Repair		VI
131670922	X96543	06/16/2013	17:32	06/16/2013	19:00	1	88	88	Public	Overhead Service	Replace - Same Size		IV
131670942	K89144	06/16/2013	18:18	06/16/2013	21:11	4	692	173	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - Urgent	III
131670951	Q28141	06/16/2013	18:33	06/16/2013	19:45	1	72	72	Animal related	Fuse	Replace - Same Size		VI
131670966	V41533	06/16/2013	19:00	06/16/2013	20:50	1	110	110	Overhead equipment	Overhead Service	Repair		II
131670964	S21529	06/16/2013	19:00	06/16/2013	20:16	1	76	76	Animal related	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
131670972	Q23258	06/16/2013	19:00	06/16/2013	20:15	44	3300	75	Overhead equipment	Fuse	Replace - Same Size		VI
131671063	D87001	06/16/2013	20:02	06/16/2013	21:27	5	425	85	Overhead equipment	Pole	Replace - Same Size		I
131671005	Q82906	06/16/2013	20:11	06/16/2013	22:09	1	118	118	Overhead equipment	Overhead Service	Repair		VI
131671039	H02256	06/16/2013	20:35	06/16/2013	21:40	1	65	65	Overhead equipment	Fuse			III
131671055	K52401	06/16/2013	20:56	06/17/2013	4:48	44	20768	472	Underground equipment	Underground Primary	Repair	Repair	V
131671060	A85001	06/16/2013	21:07	06/16/2013	22:45	16	1568	98	Overhead equipment	Jumper	Move		I
131671072	Z33507	06/16/2013	21:32	06/16/2013	22:42	1	70	70	Overhead equipment	Disconnect Switch	Repair	Replace - Same Size	IV
131671160	340100	06/16/2013	23:03	06/17/2013	0:28	1	85	85	Tree related-tree broken	Overhead Secondary			V
131671172	K95204	06/16/2013	23:34	06/17/2013	1:10	1	96	96	Unknown	Transformer Fuse	Replace - Same Size		III
131680128	J79305	06/17/2013	2:52	06/17/2013	4:06	1	74	74	Animal related	Fuse	Replace - Same Size		I
131681949	C00001	06/17/2013	4:12	06/17/2013	12:00	2	936	468	Underground equipment	Underground Primary	Patrol/Test/Inspect	Patrol/Test/Inspect	I
131681801	D36003	06/17/2013	4:29	06/17/2013	10:40	6	2226	371	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
131681784	D36003	06/17/2013	4:29	06/17/2013	6:03	43	4042	94	Underground equipment	Underground Primary	Patrol/Test/Inspect		I
131681790	U16500	06/17/2013	4:58	06/17/2013	6:24	3	258	86	Overhead equipment	Pole	Replace - Same Size	Replace - Same Size	II
131681798	K80381	06/17/2013	5:40	06/17/2013	7:40	33	3960	120	Underground equipment	Underground Primary	Switch/Reset	Repair	IV
131681806	R04409	06/17/2013	5:58	06/17/2013	7:00	1	62	62	Animal related	Fuse	Replace - Same Size	Replace - Same Size	V
131681812	N48109	06/17/2013	6:05	06/17/2013	7:00	1	55	55	Overhead equipment	Fuse	Replace - Same Size	No Work Required	II
131681826	Q24313	06/17/2013	6:20	06/17/2013	8:09	1	109	109	Animal related	Transformer Fuse	Replace - Same Size	Patrol/Test/Inspect	VI
131681829	Q32171	06/17/2013	6:22	06/17/2013	8:21	3	357	119	Tree related-tree broken	Overhead Primary			I
131681837	S04545	06/17/2013	6:30	06/17/2013	8:22	23	2576	112	Overhead equipment	Jumper	Patrol/Test/Inspect	Repair	VI
131681840	A97006	06/17/2013	6:35	06/17/2013	8:24	1	109	109	Weather	Lightning Arrestor	Patrol/Test/Inspect	Replace - Same Size	I
131681855	B45005	06/17/2013	6:46	06/17/2013	7:15	1	29	29	Underground equipment	Underground Primary	Repair	Replace - Same Size	I
131681861	L50214	06/17/2013	6:56	06/17/2013	7:53	1	57	57	Animal related	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
131681862	P05825	06/17/2013	6:58	06/17/2013	8:20	1	82	82	Weather	Transformer Fuse	Replace - Same Size		V
131681899		06/17/2013	7:13	06/17/2013	7:53	1	40	40	Weather	Transformer Fuse	Replace - Same Size		III
131681910	Y11556	06/17/2013	7:14	06/17/2013	8:20	34	2244	66	Overhead equipment	Overhead Primary	Raise		IV
131681928	B62004	06/17/2013	7:18	06/17/2013	13:29	1	371	371	Animal related	Fuse	Replace - Same Size		I
131681994	Q18245	06/17/2013	7:38	06/17/2013	8:30	1	52	52	Animal related	Fuse	Replace - Same Size		VI
131682002	N35852	06/17/2013	7:41	06/17/2013	8:46	1	65	65	Animal related	Transformer Fuse	Replace - Same Size		V
131682535	A45002	06/17/2013	7:48	06/17/2013	10:24	68	10608	156	Underground equipment	Underground Primary	Switch/Reset	Switch/Reset	I
131682054	S42579	06/17/2013	7:56	06/17/2013	8:35	5	195	39	Animal related	Transformer Fuse	Repair	Replace - Same Size	VI
131682153	L46811	06/17/2013	8:12	06/17/2013	9:13	232	14152	61	Animal related	Substation Breaker	Replace - Same Size	No Work Required	V
131682139	L46810	06/17/2013	8:13	06/17/2013	9:30	732	56364	77	Animal related	Recloser	Patrol/Test/Inspect	Repair	V
131682189	Q71846	06/17/2013	8:25	06/17/2013	9:31	1	66	66	Animal related			No Work Required	V
131682261	J99128	06/17/2013	8:34	06/17/2013	9:45	81	5751	71	Overhead equipment	Overhead Primary		Repair	VI
131682268	Y11556	06/17/2013	8:40	06/17/2013	9:26	1	46	46	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	IV
131682316	P12290	06/17/2013	8:51	06/17/2013	9:35	3	132	44	Overhead equipment	Fuse	Replace - Same Size		V
131682318	S88502	06/17/2013	8:52	06/17/2013	11:03	1	131	131	Animal related	Fuse	Replace - Same Size		VI
131682348	Q85162	06/17/2013	8:58	06/17/2013	9:45	1	47	47	Animal related	Fuse	Repair	Repair	VI
131682401	J80806	06/17/2013	9:08	06/17/2013	12:30	1	202	202	Overhead equipment	Fuse	Repair	Repair	V
131682426	T04513	06/17/2013	9:13	06/17/2013	9:54	1	41	41	Animal related	Transformer Fuse	Repair	Replace - Same Size	VI
131682470	Y96564	06/17/2013	9:20	06/17/2013	10:12	1	52	52	Overhead equipment	Connector	Repair		IV
131682469	S47576	06/17/2013	9:20	06/17/2013	9:48	2	56	28	Overhead equipment	Fuse	Replace - Same Size		VI
131682484	K46388	06/17/2013	9:23	06/17/2013	9:48	1	25	25	Animal related	Fuse	Replace - Same Size		V
131682770	U42001	06/17/2013	9:30	06/17/2013	10:39	4	276	69	Overhead equipment	Disconnect Switch	Repair		II
131682717	L95110	06/17/2013	10:10	06/17/2013	10:35	1	25	25	Animal related	Fuse	Replace - Same Size		III
131682931	P57107	06/17/2013	10:46	06/17/2013	11:29	1	43	43	Animal related	Fuse	Repair	Replace - Same Size	VI

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
131682991	J39391	06/17/2013	10:57	06/17/2013	12:21	1	84	84	Overhead equipment	Disconnect Switch		Repair	III
131682997	L46810	06/17/2013	10:59	06/17/2013	11:03	1	4	4	Animal related			No Work Required	V
131683069		06/17/2013	11:10	06/17/2013	11:30	1	20	20	Other	Other	Patrol/Test/Inspect	Repair	VI
131683357	A81001	06/17/2013	11:38	06/17/2013	19:10	2	904	452	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
131683230	L81141	06/17/2013	11:39	06/17/2013	13:00	1	81	81	Tree related-tree contact	Overhead Secondary			IV
131683313	M05368	06/17/2013	11:53	06/17/2013	12:14	1	21	21	Jurisdictional	Meter	Reconnect	Advise Customer	V
131683729	C40002	06/17/2013	12:16	06/17/2013	13:45	130	11570	89	Underground equipment	Underground Primary	Replace - Same Size		I
131683599	L23145	06/17/2013	12:45	06/17/2013	16:51	1	246	246	Overhead equipment	Overhead Primary	Repair		III
131683625	B80004	06/17/2013	12:50	06/17/2013	13:00	1	10	10	Overhead equipment	Connector	Patrol/Test/Inspect	Replace - New Size	I
131683800	K71821	06/17/2013	13:00	06/17/2013	14:12	8	576	72	Underground equipment	Underground Primary	Switch/Reset	Replace - Same Size	IV
131683685	M04364	06/17/2013	13:02	06/17/2013	14:01	1	59	59	Overhead equipment	Fuse	Replace - Same Size		V
131683713	Q32171	06/17/2013	13:06	06/17/2013	13:24	1	18	18	Overhead equipment	Overhead Primary	Repair	Repair	I
131683776	332003	06/17/2013	13:16	06/17/2013	14:06	10	500	50	Overhead equipment	Fuse	Repair		VI
131683806	L00133	06/17/2013	13:20	06/17/2013	18:50	1	330	330	Underground equipment	Underground Primary	Repair		III
131683922	Q32171	06/17/2013	13:40	06/17/2013	14:07	1	27	27	Overhead equipment	Overhead Primary	Repair		I
131683925	T06505	06/17/2013	13:41	06/17/2013	15:07	3	258	86	Tree related-tree broken	Overhead Service	Replace - Same Size		VI
131683949	S47576	06/17/2013	13:46	06/17/2013	14:14	1	28	28	Overhead equipment	Fuse	Replace - Same Size		VI
131684018	K71821	06/17/2013	13:59	06/17/2013	14:12	1	13	13	Underground equipment				IV
131684033	J39392	06/17/2013	14:01	06/17/2013	15:06	1	65	65	Animal related	Transformer Fuse		Replace - Same Size	III
131684135	S42579	06/17/2013	14:21	06/17/2013	15:11	1	50	50	Other				VI
131684154	Q82906	06/17/2013	14:22	06/17/2013	18:15	43	10019	233	Tree related-tree broken	Overhead Primary	Repair	Repair	VI
131684837	M09143	06/17/2013	14:26	06/17/2013	17:16	7	1190	170	Overhead equipment	Overhead Primary	Replace - Same Size	Repair	VI
131684160	L59923	06/17/2013	14:26	06/17/2013	16:14	2	216	108	Tree related-tree broken	Overhead Secondary	Repair		VI
131684174	X57001	06/17/2013	14:28	06/17/2013	16:20	1	112	112	Overhead equipment	Disconnect Switch	Replace - New Size	Replace - New Size	IV
131684176	L59929	06/17/2013	14:28	06/17/2013	16:57	1	149	149	Weather	Fuse	Replace - Same Size		VI
131684217	U14528	06/17/2013	14:35	06/17/2013	18:43	1	248	248	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - New Size	II
131685676	F03003	06/17/2013	14:38	06/17/2013	19:04	4	1064	266	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	III
131684256	T08502	06/17/2013	14:40	06/17/2013	15:58	2	156	78	Overhead equipment	Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
131684309	S47589	06/17/2013	14:46	06/17/2013	15:40	1	54	54	Overhead equipment	Overhead Service	Repair		VI
131686000	R08910	06/17/2013	14:47	06/18/2013	2:49	1	722	722	Tree related-tree broken	Pole		Replace - Same Size	VI
131684721	R08910	06/17/2013	14:47	06/17/2013	19:00	41	10373	253	Tree related-tree broken	Pole	Replace - New Size		VI
131684457	J20931	06/17/2013	14:51	06/17/2013	16:14	16	1328	83	Weather	Pole	Repair		VI
131684361	J61115	06/17/2013	14:52	06/17/2013	15:37	1	45	45	Tree related-tree contact	Other			III
131684680	P72320	06/17/2013	15:18	06/17/2013	20:12	1	294	294	Tree related-tree broken	Overhead Service	Repair		V
131684704	M09143	06/17/2013	15:18	06/17/2013	16:34	1	76	76	Overhead equipment	Fuse	Replace - Same Size	Repair	VI
131684762	J84145	06/17/2013	15:27	06/17/2013	18:57	10	2100	210	Tree related-tree broken				VI
131685298	Q63835	06/17/2013	15:31	06/17/2013	20:42	282	87702	311	Overhead equipment	Pole	Patrol/Test/Inspect	Replace - New Size	V
131684886	Q63835	06/17/2013	15:31	06/17/2013	16:47	277	21052	76	Overhead equipment	Pole	Switch/Reset	Replace - Same Size	V
131684959	R53416	06/17/2013	15:33	06/17/2013	20:15	33	9306	282	Tree related-tree broken	Overhead Primary	Patrol/Test/Inspect	Repair	V
131684988	303007	06/17/2013	15:34	06/17/2013	16:43	22	1518	69	Weather	Fuse	Replace - Same Size		VI
131685600	R04407	06/17/2013	15:35	06/17/2013	20:09	301	82474	274	Tree related-tree contact	Overhead Primary	Patrol/Test/Inspect	Repair	V
131684933	R04407	06/17/2013	15:35	06/17/2013	18:13	646	102068	158	Overhead equipment	Overhead Primary	Switch/Reset		V
131684970	R53416	06/17/2013	15:35	06/17/2013	20:57	44	14168	322	Weather	Fuse	Replace - Same Size		V
131684875	303007	06/17/2013	15:36	06/17/2013	16:43	1	67	67	Weather	Fuse	Replace - Same Size		VI
131686616	R53391	06/17/2013	15:38	06/17/2013	18:50	150	28800	192	Overhead equipment	Overhead Primary	Switch/Reset		V
131684931	R93350	06/17/2013	15:40	06/17/2013	16:54	1	74	74	Tree related-tree broken	Tree	Patrol/Test/Inspect	Replace - Same Size	V
131684943	303006	06/17/2013	15:40	06/17/2013	17:45	4	500	125	Weather	Overhead Transformer	Cut in Clear	Replace - New Size	VI
131684951	R04409	06/17/2013	15:40	06/17/2013	17:54	24	3216	134	Weather	Fuse	Replace - Same Size		V
131685673	K43383	06/17/2013	15:41	06/18/2013	3:22	7	4907	701	Tree related-tree contact	Overhead Primary		Repair	V
131684968	K46388	06/17/2013	15:41	06/17/2013	16:55	345	25530	74	Weather	Disconnect Switch	Switch/Reset	Switch/Reset	V
131685432	R78300	06/17/2013	15:45	06/17/2013	17:48	8	984	123	Tree related-tree broken	Tree	Remove		V
131685006	R01153	06/17/2013	15:46	06/17/2013	16:24	1	38	38	Overhead equipment	Overhead Service			III
131685008	R53391	06/17/2013	15:46	06/17/2013	23:37	16	7536	471	Tree related-tree broken	Overhead Primary	Patrol/Test/Inspect	Repair	V
131685047	M78325	06/17/2013	15:51	06/18/2013	0:06	5	2475	495	Weather	Overhead Transformer	Patrol/Test/Inspect	Repair	V
131685054	K43383	06/17/2013	15:51	06/17/2013	17:45	34	3876	114	Weather	Overhead Primary		Repair	V
131685077	K46388	06/17/2013	15:53	06/17/2013	19:35	74	16428	222	Weather	Lightning Arrestor	Patrol/Test/Inspect	Replace - Same Size	V

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
131685109	R04412	06/17/2013	15:58	06/17/2013	18:43	1	165	165	Weather	Fuse	Replace - Same Size		V
131685142	K52401	06/17/2013	16:01	06/17/2013	18:36	1	155	155	Tree related-tree broken	Overhead Service	Repair	Repair	V
131685162	309139	06/17/2013	16:05	06/17/2013	21:40	1	335	335	Tree related-tree broken	Overhead Service	Reconnect		V
131685384	R49263	06/17/2013	16:06	06/17/2013	20:15	158	39342	249	Overhead equipment	Overhead Primary		Repair	VI
131685345	R73841	06/17/2013	16:08	06/17/2013	20:07	49	11711	239	Weather				V
131685215	B57003	06/17/2013	16:10	06/18/2013	6:15	1	845	845	Public	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	I
131685214	A80001	06/17/2013	16:10	06/17/2013	19:28	1	198	198	Overhead equipment	Overhead Transformer	Repair	Repair	I
131685212	P42229	06/17/2013	16:10	06/17/2013	17:42	1	92	92	Weather	Fuse	Switch/Reset		VI
131685343	K95204	06/17/2013	16:30	06/17/2013	17:11	1	41	41	Overhead equipment	Transformer Fuse	Replace - Same Size		III
131685352	B62004	06/17/2013	16:33	06/17/2013	23:00	1	387	387	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
131685379	342003	06/17/2013	16:40	06/17/2013	18:20	2	200	100	Tree related-tree contact	Overhead Transformer	Patrol/Test/Inspect		VI
131685395	S47537	06/17/2013	16:44	06/17/2013	19:11	2	294	147	Overhead equipment	Disconnect Switch	Replace - Same Size		VI
131685473	V04716	06/17/2013	16:45	06/17/2013	16:54	2985	26865	9	Overhead equipment				II
131685416	UE2001	06/17/2013	16:48	06/17/2013	20:30	1	222	222	Overhead equipment	Crossarm	Patrol/Test/Inspect	Repair	V
131685439	X69555	06/17/2013	16:52	06/17/2013	17:47	1	55	55	Weather	Fuse	Repair		IV
131685429	X88507	06/17/2013	16:52	06/17/2013	19:50	5	890	178	Public	Overhead Transformer	Replace - Same Size	Replace - Same Size	IV
131685438	Q63835	06/17/2013	16:53	06/17/2013	20:10	1	197	197	Weather	Transformer Fuse	Replace - Same Size	No Work Required	V
131685457	D48001	06/17/2013	16:57	06/17/2013	19:00	1	123	123	Animal related	Transformer Fuse	Replace - Same Size		I
131685461	306003	06/17/2013	16:58	06/17/2013	20:13	1	195	195	Overhead equipment	Overhead Primary	Repair		VI
131685557	K52401	06/17/2013	17:17	06/17/2013	18:13	1	56	56	Weather				V
131685568	K52400	06/17/2013	17:20	06/17/2013	19:56	2	312	156	Weather	Fuse	Replace - Same Size		V
131685444	M04365	06/17/2013	17:29	06/17/2013	17:50	1	21	21	Tree related-tree broken	Tree	Cut in Clear		V
131685620	D88001	06/17/2013	17:31	06/17/2013	19:26	1	115	115	Animal related	Transformer Fuse	Replace - Same Size		I
131685622	R93351	06/17/2013	17:31	06/17/2013	19:59	1	148	148	Weather	Fuse	Patrol/Test/Inspect		V
131685634		06/17/2013	17:38	06/17/2013	20:30	1	172	172	Public	Underground Service	Repair	Repair	II
131685651	M09143	06/17/2013	17:46	06/17/2013	19:18	1	92	92	Overhead equipment	Overhead Primary	Replace - Same Size	Repair	VI
131685956	M49424	06/17/2013	18:04	06/18/2013	3:48	1	584	584	Tree related-tree broken	Overhead Primary	Patrol/Test/Inspect		V
131685989	L73160	06/17/2013	18:15	06/17/2013	19:09	1	54	54	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
131686527	M49411	06/17/2013	18:23	06/17/2013	19:30	1	67	67	Tree related-tree contact	Overhead Service	Repair		V
131686576		06/17/2013	18:36	06/18/2013	5:05	1	629	629	Weather	Overhead Primary	Patrol/Test/Inspect	Repair	V
131685342	K46388	06/17/2013	18:38	06/18/2013	3:40	14	7588	542	Tree related-tree broken	Pole	Replace - Same Size	Replace - Same Size	V
131686593	S61531	06/17/2013	18:39	06/17/2013	20:00	1	81	81	Overhead equipment	Transformer Fuse	Replace - Same Size		VI
131686611	Q32171	06/17/2013	18:43	06/17/2013	19:19	1	36	36	Overhead equipment	Overhead Primary	Repair	Repair	I
131686617	P60170	06/17/2013	18:47	06/17/2013	19:36	1	49	49	Jurisdictional				VI
131686620	P60170	06/17/2013	18:48	06/17/2013	19:23	1	35	35	Other				VI
131686644	K01238	06/17/2013	18:58	06/17/2013	20:35	1	97	97	Underground equipment	Connector	Tie/Tighten		VI
131686674	J85161	06/17/2013	18:59	06/17/2013	20:07	217	14756	68	Overhead equipment	Recloser	Switch/Reset		VI
131686740	M05368	06/17/2013	19:30	06/17/2013	20:22	1	52	52	Weather	Fuse	Replace - Same Size		V
131686743	B71002	06/17/2013	19:32	06/17/2013	22:35	1	183	183	Overhead equipment	Overhead Service		Repair	I
131686846	L53341	06/17/2013	19:40	06/17/2013	21:05	5456	463760	85	Overhead equipment				VI
131687015	P60161	06/17/2013	19:55	06/18/2013	1:15	84	26880	320	Underground equipment	Underground Primary		Repair	VI
131687033	Q24310	06/17/2013	20:07	06/17/2013	21:05	1	58	58	Overhead equipment			Repair	VI
131687049	Q27186	06/17/2013	20:15	06/17/2013	21:32	1	77	77	Weather	Fuse	Replace - Same Size		VI
131687056	R73841	06/17/2013	20:18	06/17/2013	21:45	1	87	87	Weather	Fuse	Replace - Same Size	No Work Required	V
131687081	K09863	06/17/2013	20:42	06/17/2013	23:54	2	384	192	Overhead equipment	Overhead Transformer	Replace - Same Size	Repair	V
131687125	X02546	06/17/2013	21:16	06/17/2013	22:00	1	44	44	Weather	Fuse	Repair		IV
131687278	M53312	06/17/2013	22:31	06/17/2013	23:04	11	363	33	Weather	Fuse	Repair		V
131687308	Q63835	06/17/2013	23:34	06/18/2013	0:45	1	71	71	Animal related	Transformer Fuse	Replace - Same Size	No Work Required	V
131687314	E05002	06/17/2013	23:39	06/18/2013	4:49	83	25730	310	Underground equipment	Underground Primary			IV
131690110		06/18/2013	0:08	06/18/2013	3:00	1	172	172	Overhead equipment	Overhead Transformer	Repair	Replace - Same Size	IV
131690121	K35308	06/18/2013	0:48	06/18/2013	3:00	1	132	132	Other	Fuse	Replace - Same Size		III
131690274	V58507	06/18/2013	2:22	06/18/2013	6:20	1	238	238	Overhead equipment	Overhead Transformer	Replace - Same Size	Replace - Same Size	II
131691871	J01119	06/18/2013	3:31	06/18/2013	5:40	1	129	129	Overhead equipment	Underground Primary	Repair	Repair	I
131691880	345002	06/18/2013	4:25	06/18/2013	8:49	1	264	264	Overhead equipment	Overhead Transformer	Advise Customer	Replace - Same Size	VI
131691886	345002	06/18/2013	4:39	06/18/2013	8:50	12	3012	251	Overhead equipment	Overhead Transformer	Advise Customer	Replace - Same Size	VI
131691906	J88163	06/18/2013	6:03	06/18/2013	18:45	1	762	762	Overhead equipment	Overhead Secondary			VI

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
131691917	M05360	06/18/2013	6:15	06/18/2013	7:33	1	78	78	Overhead equipment	Fuse			V
131691921	K17119	06/18/2013	6:18	06/18/2013	6:56	1	38	38	Overhead equipment	Fuse	Repair	Repair	VI
131691926	X77543	06/18/2013	6:21	06/18/2013	7:25	19	1216	64	Animal related	Fuse	Replace - Same Size		IV
131691928	X77543	06/18/2013	6:28	06/18/2013	7:25	3	171	57	Animal related	Fuse	Replace - Same Size		IV
131691941	J34377	06/18/2013	6:42	06/18/2013	7:56	6	444	74	Animal related	Fuse	Replace - Same Size		V
131691976	M47802	06/18/2013	7:11	06/18/2013	9:00	1	109	109	Overhead equipment	Overhead Service			V
131692036	B61001	06/18/2013	7:11	06/18/2013	8:20	23	1587	69	Overhead equipment	Fuse	Replace - Same Size		I
131691985	R58961	06/18/2013	7:12	06/18/2013	8:34	66	5412	82	Animal related	Fuse	Replace - Same Size	Replace - Same Size	IV
131691992	L17104	06/18/2013	7:14	06/18/2013	8:20	1	66	66	Animal related	Fuse	Replace - Same Size		III
131692000	S86580	06/18/2013	7:17	06/18/2013	8:10	1	53	53	Animal related	Fuse	Replace - Same Size		VI
131692067	B93003	06/18/2013	7:37	06/18/2013	10:33	1	176	176	Overhead equipment	Connector	Replace - Same Size	No Work Required	I
131692089	J63172	06/18/2013	7:43	06/18/2013	8:15	9	288	32	Animal related	Transformer Fuse	Repair	Repair	III
131692104	U68581	06/18/2013	7:46	06/18/2013	9:47	1	121	121	Tree related-tree contact	Tree			II
131692120	305130	06/18/2013	7:51	06/18/2013	10:16	1	145	145	Weather	Fuse	Replace - Same Size		V
131692129	S88503	06/18/2013	7:54	06/18/2013	11:06	6	1152	192	Animal related	Disconnect Switch	Patrol/Test/Inspect	Replace - Same Size	VI
131692170	Y51506	06/18/2013	8:05	06/18/2013	9:40	1	95	95	Animal related	Transformer Fuse			IV
131692223	X29002	06/18/2013	8:20	06/18/2013	11:30	1	190	190	Tree related-tree broken	Overhead Service	Repair	Replace - Same Size	IV
131692239	K09863	06/18/2013	8:25	06/18/2013	9:08	1	43	43	Animal related				V
131692315	K27153	06/18/2013	8:38	06/18/2013	8:52	178	2492	14	Other	Recloser	Switch/Reset	No Work Required	VI
131692331	J87120	06/18/2013	8:42	06/18/2013	9:25	1	43	43	Animal related	Transformer Fuse	Replace - Same Size		VI
131692365	T15570	06/18/2013	8:47	06/18/2013	14:00	1	313	313	Underground equipment	Underground Secondary			VI
131692420	K30204	06/18/2013	8:56	06/18/2013	9:58	57	3534	62	Animal related	Fuse	Replace - Same Size		III
131692432	B81003	06/18/2013	9:01	06/18/2013	9:48	1	47	47	Animal related	Transformer Fuse	Replace - Same Size	No Work Required	I
131692471	X96543	06/18/2013	9:10	06/18/2013	9:51	1	41	41	Unknown	Overhead Primary			IV
131692498	K32916	06/18/2013	9:15	06/18/2013	11:06	1	111	111	Tree related-tree contact	Tree			VI
131692501	S84535	06/18/2013	9:16	06/18/2013	10:45	1	89	89	Tree related-tree broken	Overhead Service	Repair	Replace - Same Size	VI
131692552	U39541	06/18/2013	9:29	06/18/2013	10:34	1	65	65	Animal related	Fuse	Replace - Same Size		II
131692598	B81002	06/18/2013	9:36	06/18/2013	14:34	1	298	298	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	I
131692680	Q27185	06/18/2013	9:51	06/18/2013	10:37	1	46	46	Weather	Fuse	Replace - Same Size		VI
131692766	P42229	06/18/2013	10:08	06/18/2013	12:18	1	130	130	Animal related	Fuse	Replace - Same Size		VI
131692777	M25144	06/18/2013	10:10	06/18/2013	12:25	1	135	135	Public				IV
131692779	T06505	06/18/2013	10:10	06/18/2013	10:48	1	38	38	Tree related-tree broken	Overhead Service	Cut in Clear		VI
131692796	Y55004	06/18/2013	10:14	06/18/2013	11:53	1	99	99	Tree related-tree contact	Overhead Service	Repair		IV
131692806	Q18244	06/18/2013	10:17	06/18/2013	11:08	1	51	51	Animal related	Fuse	Replace - Same Size		VI
131692810	S79510	06/18/2013	10:18	06/18/2013	11:49	1	91	91	Overhead equipment	Transformer Fuse	Repair	Replace - Same Size	VI
131692828	B57001	06/18/2013	10:21	06/18/2013	11:26	1	65	65	Animal related	Fuse	Patrol/Test/Inspect	Replace - New Size	I
131692849	R06212	06/18/2013	10:26	06/18/2013	11:20	1	54	54	Animal related	Transformer Fuse	Replace - Same Size		II
131692903	B68003	06/18/2013	10:38	06/18/2013	12:54	1	136	136	Jurisdictional	Overhead Primary	Repair	No Work Required	III
131692928	B68003	06/18/2013	10:44	06/18/2013	12:54	1	130	130	Tree related-tree contact	Other	Patrol/Test/Inspect	Patrol/Test/Inspect	III
131692989	L59929	06/18/2013	10:51	06/18/2013	11:57	1	66	66	Weather	Transformer Fuse	Replace - Same Size		VI
131693030	R05186	06/18/2013	10:59	06/18/2013	11:43	1	44	44	Animal related	Overhead Transformer	Switch/Reset		I
131693069	T06505	06/18/2013	11:05	06/18/2013	13:59	1	174	174	Tree related-tree broken	Overhead Service	Repair	Repair	VI
131693110	M05361	06/18/2013	11:13	06/18/2013	11:39	1	26	26	Jurisdictional				V
131693181	T06505	06/18/2013	11:28	06/18/2013	12:10	1	42	42	Tree related-tree broken	Fuse	Replace - Same Size	Replace - Same Size	VI
131693196	H01190	06/18/2013	11:32	06/18/2013	13:48	1	136	136	Overhead equipment	Jumper	Repair		III
131693315	R58942	06/18/2013	12:05	06/18/2013	14:23	1	138	138	Tree related-tree broken	Overhead Service	Repair		IV
131693346	L12127	06/18/2013	12:11	06/18/2013	13:21	8	560	70	Animal related	Fuse	Replace - Same Size		III
131693390	J07173	06/18/2013	12:21	06/18/2013	16:27	1	246	246	Public	Underground Service	Repair	Repair	I
131693445	K52401	06/18/2013	12:30	06/18/2013	14:41	1	131	131	Weather	Fuse	Replace - Same Size	Replace - Same Size	V
131693503	L95209	06/18/2013	12:39	06/18/2013	14:20	1	101	101	Overhead equipment	Fuse	Replace - Same Size		III
131694141	R49263	06/18/2013	13:15	06/18/2013	17:00	2	450	225	Overhead equipment	Overhead Transformer		Patrol/Test/Inspect	VI
131693674	J06168	06/18/2013	13:21	06/18/2013	17:43	1	262	262	Overhead equipment	Overhead Transformer	Replace - Same Size	Replace - Same Size	I
131693766	V17539	06/18/2013	13:38	06/18/2013	15:01	6	498	83	Underground equipment	Underground Primary			II
131693932	P47123	06/18/2013	14:09	06/18/2013	15:20	1	71	71	Overhead equipment	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	I
131694068	R41131	06/18/2013	14:13	06/18/2013	15:50	23	2231	97	Overhead equipment				VI
131693997	P69175	06/18/2013	14:20	06/18/2013	15:16	835	46760	56	Tree related-tree contact	Overhead Primary		Repair	III

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
131694036	R41131	06/18/2013	14:26	06/18/2013	15:50	11	924	84	Overhead equipment				VI
131694122	Q36410	06/18/2013	14:44	06/18/2013	15:06	1	22	22	Animal related	Fuse	Replace - Same Size	Replace - Same Size	I
131694146	C65001	06/18/2013	14:47	06/18/2013	15:54	60	4020	67	Public	Underground Primary	Patrol/Test/Inspect	Repair	III
131694162	J84123	06/18/2013	14:49	06/18/2013	18:40	30	6930	231	Tree related-tree contact	Tree	Patrol/Test/Inspect	Remove	VI
131694232	L79157	06/18/2013	15:04	06/18/2013	17:01	1	117	117	Public	Underground Transformer			IV
131694265	S83533	06/18/2013	15:11	06/18/2013	18:09	1	178	178	Overhead equipment	Overhead Transformer	Repair	Replace - Same Size	VI
131694387	P69175	06/18/2013	15:40	06/18/2013	16:16	1	36	36	Overhead equipment	Overhead Transformer	Switch/Reset		III
131694475	Y61004	06/18/2013	16:14	06/18/2013	17:20	1	66	66	Tree related-tree broken	Overhead Service			IV
131694499	P42229	06/18/2013	16:22	06/18/2013	16:56	12	408	34	Animal related	Fuse			VI
131694557	X96739	06/18/2013	16:24	06/18/2013	16:35	2024	22264	11	Unknown				IV
131694562	S43511	06/18/2013	16:35	06/18/2013	17:32	1	57	57	Animal related	Transformer Fuse	Replace - Same Size	No Work Required	VI
131694563	P42230	06/18/2013	16:36	06/18/2013	17:01	1	25	25	Animal related	Fuse			VI
131694641	J84146	06/18/2013	17:10	06/18/2013	17:34	6	144	24	Animal related	Transformer Fuse	Replace - Same Size		VI
131694695	P69175	06/18/2013	17:17	06/18/2013	18:50	3	279	93	Overhead equipment	Overhead Primary	Repair		III
131694665	R34921	06/18/2013	17:22	06/18/2013	18:24	1	62	62	Animal related	Fuse	Replace - Same Size		VI
131694679	D67001	06/18/2013	17:28	06/18/2013	22:04	1	276	276	Underground equipment	Underground Transformer			IV
131694698	K28183	06/18/2013	17:45	06/18/2013	19:38	1	113	113	Overhead equipment	Transformer Fuse	Replace - Same Size		III
131694777	U04571	06/18/2013	18:01	06/18/2013	20:45	48	7872	164	Overhead equipment	Fuse	Replace - Same Size		II
131694716	S88551	06/18/2013	18:03	06/18/2013	19:22	1	79	79	Overhead equipment	Overhead Service	Patrol/Test/Inspect	Repair	VI
131694823	L50217	06/18/2013	18:09	06/18/2013	23:20	1	311	311	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	VI
131694881	K55398	06/18/2013	18:13	06/18/2013	21:00	11	1837	167	Overhead equipment				V
131695250	H07106	06/18/2013	18:44	06/18/2013	19:37	1	53	53	Weather	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	IV
131695277	J84123	06/18/2013	19:13	06/19/2013	1:30	2	754	377	Overhead equipment	Overhead Transformer	Disconnect	Replace - Same Size	VI
131695268	R59417	06/18/2013	19:20	06/18/2013	20:45	1	85	85	Tree related-tree contact	Overhead Service	Repair	No Work Required	IV
131695303	U86001	06/18/2013	19:29	06/18/2013	21:56	276	40572	147	Substation equipment	Substation Misc.	Switch/Reset		II
131695317	347001	06/18/2013	19:57	06/18/2013	21:00	4	252	63	Overhead equipment	Transformer Fuse	Replace - Same Size		VI
131695319	V65549	06/18/2013	19:59	06/19/2013	6:00	5	3005	601	Underground equipment	Underground Secondary	Repair	Repair	II
131695333	M48815	06/18/2013	20:15	06/18/2013	21:20	1	65	65	Tree related-tree broken	Overhead Service			V
131695373		06/18/2013	21:18	06/18/2013	22:50	1	92	92	Animal related	Fuse	Replace - Same Size		II
131695360	S50542	06/18/2013	21:35	06/18/2013	23:11	1	96	96	Other	Meter	Cover		VI
131695416	N61011	06/18/2013	22:23	06/19/2013	5:21	1	418	418	Overhead equipment	Disconnect Switch	Patrol/Test/Inspect	Replace - Same Size	IV
131695417	R04412	06/18/2013	22:32	06/18/2013	23:29	1	57	57	Animal related	Fuse	Replace - Same Size		V
131695418	J14142	06/18/2013	22:33	06/18/2013	23:21	1	48	48	Overhead equipment	Transformer Fuse	Repair		VI
131695440	J87101	06/18/2013	23:03	06/19/2013	0:15	28	2016	72	Overhead equipment	Disconnect Switch			VI
131695443	S28552	06/18/2013	23:08	06/19/2013	2:30	15	3030	202	Tree related-tree broken	Overhead Primary	Patrol/Test/Inspect	Repair	VI
131695438	J87101	06/18/2013	23:12	06/19/2013	0:18	1	66	66	Overhead equipment				VI
131701674	S95571	06/18/2013	23:59	06/19/2013	4:25	5	1330	266	Overhead equipment	Underground Primary			VI
131701675	S95571	06/18/2013	23:59	06/19/2013	5:55	14	4984	356	Underground equipment	Underground Primary			VI
131700133	D28123	06/19/2013	0:05	06/19/2013	6:07	3	1086	362	Underground equipment	Underground Primary	Patrol/Test/Inspect	Replace - Urgent	I
131700394	B21004	06/19/2013	1:16	06/19/2013	6:49	4	1332	333	Underground equipment	Underground Primary	Repair	Repair	I
131700144	B21004	06/19/2013	1:16	06/19/2013	3:10	93	10602	114	Underground equipment	Underground Primary	Patrol/Test/Inspect	Replace - Urgent	I
131700209	311003	06/19/2013	2:16	06/19/2013	3:45	4	356	89	Overhead equipment	Overhead Transformer	Switch/Reset		VI
131701739	P69174	06/19/2013	2:16	06/19/2013	7:38	25	8050	322	Underground equipment	Underground Primary			III
131701673	Y51505	06/19/2013	3:44	06/19/2013	4:58	1	74	74	Weather	Transformer Fuse	Replace - Same Size		IV
131701679	V83505	06/19/2013	4:40	06/19/2013	6:30	1	110	110	Animal related	Transformer Fuse	Replace - Same Size		II
131701684	V20502	06/19/2013	5:27	06/19/2013	7:14	1	107	107	Overhead equipment				II
131701710	L93133	06/19/2013	6:21	06/19/2013	6:53	12	384	32	Animal related	Transformer Fuse			VI
131701717	J63172	06/19/2013	6:32	06/19/2013	7:30	2	116	58	Tree related-tree broken	Overhead Service	Repair	Repair	III
131701726	D88002	06/19/2013	6:44	06/19/2013	9:08	1	144	144	Animal related	Lightning Arrestor	Patrol/Test/Inspect	Replace - Same Size	I
131701750	S61575	06/19/2013	7:04	06/19/2013	7:57	1	53	53	Animal related	Transformer Fuse	Replace - Same Size		VI
131701830	A85002	06/19/2013	7:26	06/19/2013	10:50	180	36720	204	Overhead equipment	Overhead Primary	Patrol/Test/Inspect	Repair	I
131701837	D35003	06/19/2013	7:34	06/19/2013	9:05	1	91	91	Overhead equipment	Fuse	Replace - Same Size		I
131701893	A17021	06/19/2013	7:50	06/19/2013	9:41	1	111	111	Overhead equipment	Overhead Service			I
131701925	J01118	06/19/2013	8:04	06/19/2013	11:25	1	201	201	Overhead equipment	Overhead Service	No Work Required		I
131701935	Z51551	06/19/2013	8:07	06/19/2013	9:25	1	78	78	Weather	Transformer Fuse			IV
131701952	R04412	06/19/2013	8:13	06/19/2013	11:48	1	215	215	Weather	Overhead Transformer	Replace - Same Size	Replace - Same Size	V

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
131701967	N67309	06/19/2013	8:16	06/19/2013	9:25	1	69	69	Overhead equipment	Jumper	Replace - New Size		I
131701987	D96001	06/19/2013	8:20	06/19/2013	13:44	1	324	324	Underground equipment	Underground Service	Patrol/Test/Inspect	Repair	I
131702032	N50333	06/19/2013	8:20	06/19/2013	9:54	5	470	94	Overhead equipment	Overhead Primary	Repair		II
131702016	K09809	06/19/2013	8:26	06/19/2013	10:06	1	100	100	Overhead equipment	Connector	Replace - Same Size	Repair	V
131702048		06/19/2013	8:32	06/19/2013	10:06	1	94	94	Overhead equipment	Connector	Replace - Same Size	Repair	V
131702071	Y54591	06/19/2013	8:36	06/19/2013	13:17	1	281	281	Underground equipment	Underground Primary	Repair	Repair	IV
131702202	V65549	06/19/2013	9:09	06/19/2013	11:15	1	126	126	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	II
131702216	R68900	06/19/2013	9:12	06/19/2013	10:44	1	92	92	Overhead equipment	Other	Patrol/Test/Inspect	No Work Required	I
131702293	X68506	06/19/2013	9:33	06/19/2013	13:25	1	232	232	Tree related-tree contact	Tree	Trim		IV
131702311	P69173	06/19/2013	9:39	06/19/2013	11:02	1	83	83	Animal related	Transformer Fuse	Replace - Same Size		III
131702352	J87150	06/19/2013	9:48	06/19/2013	10:26	1	38	38	Animal related	Transformer Fuse	Replace - Same Size		VI
131702412	S64501	06/19/2013	10:07	06/19/2013	10:29	1	22	22	Overhead equipment				VI
131702413	J07135	06/19/2013	10:08	06/19/2013	10:44	1	36	36	Overhead equipment	Fuse	Replace - Same Size		I
131702427	S64501	06/19/2013	10:11	06/19/2013	10:28	1	17	17	Overhead equipment				VI
131702426	S64501	06/19/2013	10:11	06/19/2013	10:27	1	16	16	Overhead equipment				VI
131702456	L24122	06/19/2013	10:14	06/19/2013	14:12	37	8806	238	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	III
131702449	U99593	06/19/2013	10:16	06/19/2013	11:08	1	52	52	Animal related	Transformer Fuse	Repair		II
131702457	K28180	06/19/2013	10:17	06/19/2013	11:54	1	97	97	Overhead equipment	Transformer Fuse	Replace - Same Size		III
131702682	K27122	06/19/2013	10:32	06/19/2013	12:09	24	2328	97	Public	Overhead Primary	Patrol/Test/Inspect	Repair	VI
131702964	M09143	06/19/2013	11:30	06/19/2013	12:12	1	42	42	Overhead equipment	Transformer Fuse	Replace - Same Size	No Work Required	VI
131702990	Q18245	06/19/2013	11:37	06/19/2013	13:21	1	104	104	Overhead equipment	Meter			VI
131703001	X86543	06/19/2013	11:39	06/19/2013	13:09	1	90	90	Unknown	Transformer Fuse	Replace - Same Size		IV
131703059	P05825	06/19/2013	11:56	06/19/2013	12:45	1	49	49	Weather	Transformer Fuse	Replace - Same Size		V
131703120		06/19/2013	12:14	06/19/2013	13:23	1	69	69	Animal related	Fuse	Replace - Same Size	No Work Required	I
131703217	Q18245	06/19/2013	12:39	06/19/2013	14:24	17	1785	105	Underground equipment	Underground Primary	Switch/Reset	Repair	VI
131703187	Q32170	06/19/2013	12:40	06/19/2013	13:15	1	35	35	Animal related	Transformer Fuse	Replace - Same Size	Repair	I
131703240	D70003	06/19/2013	12:49	06/19/2013	15:45	9	1584	176	Underground equipment	Underground Primary	Patrol/Test/Inspect	Patrol/Test/Inspect	I
131703357	T41540	06/19/2013	13:21	06/19/2013	16:20	5	895	179	Underground equipment	Underground Primary			IV
131703508	Q32171	06/19/2013	13:58	06/19/2013	14:40	1	42	42	Weather	Fuse	Replace - Same Size	Replace - Same Size	I
131703570	J76804	06/19/2013	14:12	06/19/2013	15:11	1	59	59	Animal related	Overhead Transformer	Repair	Repair	V
131703595	R39934	06/19/2013	14:19	06/19/2013	16:42	1	143	143	Overhead equipment	Fuse	Replace - Same Size		VI
131703614	L00134	06/19/2013	14:23	06/19/2013	15:41	37	2886	78	Underground equipment	Underground Primary	Switch/Reset	Repair	III
131703790	B38001	06/19/2013	15:06	06/19/2013	18:10	16	2944	184	Overhead equipment	Crossarm	Replace - New Size	Replace - New Size	I
131703804	S62523	06/19/2013	15:15	06/19/2013	16:30	1	75	75	Overhead equipment	Overhead Service	Repair		VI
131703832	D96002	06/19/2013	15:22	06/19/2013	17:13	1	111	111	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	I
131703879	K27153	06/19/2013	15:22	06/19/2013	16:45	3	249	83	Overhead equipment	Fuse	Repair		VI
131703948	J01118	06/19/2013	15:34	06/19/2013	16:37	504	31752	63	Overhead equipment	Overhead Primary		Repair	I
131703955	L50214	06/19/2013	15:50	06/19/2013	17:16	9	774	86	Animal related	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
131704048	K65221	06/19/2013	16:23	06/19/2013	20:41	1	258	258	Overhead equipment	Overhead Transformer			III
131704083	S49549	06/19/2013	16:37	06/19/2013	20:30	1	233	233	Underground equipment	Meter	Repair		VI
131704112	J01118	06/19/2013	16:50	06/19/2013	17:03	1	13	13	Overhead equipment	Overhead Service	No Work Required		I
131704144	P42229	06/19/2013	17:08	06/20/2013	6:27	1	799	799	Overhead equipment	Crossarm		Replace - Same Size	VI
131704154	E10002	06/19/2013	17:15	06/19/2013	18:44	1	89	89	Overhead equipment	Overhead Service	Repair		III
131704185	S61529	06/19/2013	17:33	06/19/2013	18:43	1	70	70	Other	Overhead Service	Advise Customer		VI
131704202	307001	06/19/2013	17:42	06/19/2013	18:32	34	1700	50	Other	Fuse	Replace - Same Size		VI
131704518		06/19/2013	18:02	06/19/2013	18:18	3008	48128	16	Jurisdictional				I
131704531	B57002	06/19/2013	18:08	06/19/2013	19:17	1180	81420	69	Animal related	Animal Guard			I
131704523	B57001	06/19/2013	18:13	06/19/2013	19:15	1	62	62	Overhead equipment	Recloser	Patrol/Test/Inspect	Replace - Same Size	I
131704533		06/19/2013	18:14	06/19/2013	19:26	1	72	72	Animal related				I
131704540	N03296	06/19/2013	18:17	06/19/2013	21:33	5	980	196	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	V
131704544	B57001	06/19/2013	18:24	06/19/2013	19:36	2	144	72	Overhead equipment	Recloser	Patrol/Test/Inspect	Replace - Same Size	I
131704899	R73841	06/19/2013	18:28	06/19/2013	20:53	1	145	145	Overhead equipment	Fuse	Replace - Same Size		V
131704918	B68004	06/19/2013	18:40	06/19/2013	19:30	1	50	50	Overhead equipment	Overhead Service	Repair		III
131704942	Z10500	06/19/2013	19:12	06/19/2013	20:00	1	48	48	Unknown	Fuse	Repair		IV
131705101	R93351	06/19/2013	19:30	06/19/2013	23:13	24	5352	223	Overhead equipment	Overhead Primary	Cut in Clear	Repair	V
131704971	A17025	06/19/2013	19:37	06/19/2013	20:45	1	68	68	Overhead equipment	Overhead Service	Repair		I

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
131704984	X83533	06/19/2013	19:59	06/20/2013	13:00	1	1021	1021	Public	Overhead Secondary		Install	IV
131705091		06/19/2013	20:08	06/19/2013	20:43	3008	105280	35	Substation equipment				I
131705105	L00134	06/19/2013	20:37	06/19/2013	23:01	1	144	144	Underground equipment	Underground Primary	Repair		III
131705110	343001	06/19/2013	20:44	06/19/2013	22:18	1	94	94	Overhead equipment	Fuse	Replace - Same Size		VI
131705125	L71170	06/19/2013	20:48	06/19/2013	22:20	1	92	92	Animal related	Transformer Fuse	Replace - Same Size		IV
131705155	X88510	06/19/2013	21:00	06/19/2013	23:15	1	135	135	Animal related	Transformer Fuse	Replace - Same Size		IV
131705284	N54213	06/19/2013	22:13	06/19/2013	23:10	2	114	57	Animal related	Overhead Transformer	Repair		II
131705295	R23334	06/19/2013	22:55	06/20/2013	0:08	1	73	73	Underground equipment	Underground Service	Patrol/Test/Inspect	Repair	V
131705311	Q28141	06/19/2013	23:24	06/20/2013	1:09	1	105	105	Overhead equipment	Fuse	Replace - Same Size		VI
131710094	M09143	06/20/2013	0:02	06/20/2013	5:26	1	324	324	Overhead equipment	Overhead Transformer	Replace - Same Size	Repair	VI
131710224	N48104	06/20/2013	1:28	06/20/2013	5:40	187	47124	252	Overhead equipment	Overhead Primary	Repair		II
131712752	Q01282	06/20/2013	5:38	06/20/2013	6:31	99	5247	53	Animal related	Fuse	Repair	Repair	III
131712787	N70330	06/20/2013	6:33	06/20/2013	7:18	1	45	45	Animal related	Fuse	Replace - Same Size		I
131712788	T17581	06/20/2013	6:34	06/20/2013	7:20	1	46	46	Animal related	Fuse	Replace - Same Size	No Work Required	VI
131712862	R48165	06/20/2013	7:16	06/20/2013	8:22	1	66	66	Overhead equipment	Overhead Service			IV
131712880	X34530	06/20/2013	7:16	06/20/2013	8:50	136	12784	94	Animal related	Fuse	Replace - Same Size		IV
131713060	Q32170	06/20/2013	7:26	06/20/2013	8:40	6	444	74	Animal related	Fuse	Replace - Same Size	Repair	I
131712893	Z10501	06/20/2013	7:26	06/20/2013	10:04	1	158	158	Tree related-tree broken	Transformer Fuse			IV
131712935	334003	06/20/2013	7:45	06/20/2013	13:55	1	370	370	Public	Pole	Patrol/Test/Inspect	Replace - New Size	VI
131712940	X24536	06/20/2013	7:46	06/20/2013	8:30	1	44	44	Overhead equipment	Overhead Service			IV
131712963	M19222	06/20/2013	7:54	06/20/2013	9:30	1	96	96	Overhead equipment	Transformer Fuse	Repair	Repair	VI
131713065	Q32171	06/20/2013	8:16	06/20/2013	9:25	1	69	69	Overhead equipment	Transformer Fuse	Replace - Same Size	Repair	I
131713098	Q69926	06/20/2013	8:26	06/20/2013	9:51	1	85	85	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	VI
131713110	S30518	06/20/2013	8:27	06/20/2013	9:55	1	88	88	Unknown	Fuse	Replace - Same Size		VI
131713164	P77233	06/20/2013	8:41	06/20/2013	9:08	1	27	27	Overhead equipment	Fuse	Replace - Same Size		VI
131713205	J20931	06/20/2013	8:53	06/20/2013	14:00	1	307	307	Underground equipment	Underground Service	Advise Customer	Cut in Clear	VI
131713280	R48167	06/20/2013	9:11	06/20/2013	9:59	1	48	48	Animal related	Transformer Fuse			IV
131713307	N22296	06/20/2013	9:17	06/20/2013	10:25	1	68	68	Overhead equipment	Transformer Fuse	Repair	Repair	VI
131713930	P57108	06/20/2013	9:31	06/20/2013	12:43	2	384	192	Underground equipment	Underground Primary	Repair	Repair	VI
131713423	P57108	06/20/2013	9:31	06/20/2013	12:46	6	1170	195	Public	Underground Primary	Repair	Repair	VI
131713405	R05115	06/20/2013	9:35	06/20/2013	10:09	1	34	34	Overhead equipment				I
131713424	M21134	06/20/2013	9:38	06/20/2013	10:09	1	31	31	Overhead equipment	Fuse	Repair	Repair	VI
131713429	R05115	06/20/2013	9:39	06/20/2013	10:24	1	45	45	Animal related	Overhead Transformer	Switch/Reset		I
131713506	N94182	06/20/2013	9:53	06/20/2013	11:06	1	73	73	Animal related	Transformer Fuse	Replace - Same Size		I
131713507	V49541	06/20/2013	9:53	06/20/2013	16:04	1	371	371	Overhead equipment	Overhead Transformer		Replace - Same Size	II
131713523	E10003	06/20/2013	9:56	06/20/2013	11:00	1	64	64	Overhead equipment	Tree	Trim	Repair	III
131713534	U11531	06/20/2013	9:59	06/20/2013	11:24	1	85	85	Animal related	Transformer Fuse	Replace - Same Size		II
131713635	M42107	06/20/2013	10:15	06/20/2013	10:48	1	33	33	Overhead equipment	Overhead Service	Repair		I
131713645	L59929	06/20/2013	10:17	06/20/2013	11:02	1	45	45	Animal related	Transformer Fuse	Replace - Same Size		VI
131713669	C52002	06/20/2013	10:19	06/20/2013	10:56	4	148	37	Overhead equipment	Fuse	Replace - Same Size		III
131713677	A97006	06/20/2013	10:22	06/20/2013	12:45	1	143	143	Underground equipment	Underground Transformer	Patrol/Test/Inspect	Repair	I
131713699	Q06132	06/20/2013	10:26	06/20/2013	11:20	7	378	54	Tree related-tree contact	Tree		Trim	IV
131713789	M37192	06/20/2013	10:39	06/20/2013	11:04	1	25	25	Overhead equipment	Overhead Service	No Work Required		I
131713796	M37192	06/20/2013	10:40	06/20/2013	11:10	1	30	30	Overhead equipment				I
131713795	M37192	06/20/2013	10:40	06/20/2013	11:07	1	27	27	Overhead equipment	Overhead Service	No Work Required		I
131713856	T22507	06/20/2013	10:50	06/20/2013	11:30	1	40	40	Other				VI
131713885	Q32171	06/20/2013	10:57	06/20/2013	11:30	1	33	33	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	I
131713920	B93003	06/20/2013	11:05	06/20/2013	11:59	1	54	54	Overhead equipment	Overhead Service	Repair		I
131713996	Q82907	06/20/2013	11:20	06/20/2013	17:25	1	365	365	Tree related-tree broken	Tree	Cut in Clear	Repair	VI
131714144	D55002	06/20/2013	11:52	06/20/2013	13:35	1	103	103	Overhead equipment	Connector	Repair	Replace - Same Size	I
131714143	N22295	06/20/2013	11:52	06/20/2013	13:17	1	85	85	Overhead equipment	Transformer Fuse			VI
131714312	S53542	06/20/2013	12:25	06/20/2013	14:49	6	864	144	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	VI
131714464	D33143	06/20/2013	13:01	06/20/2013	14:17	1	76	76	Public	Overhead Service	Replace - Same Size		I
131714533	L71171	06/20/2013	13:08	06/20/2013	15:24	37	5032	136	Underground equipment	Underground Primary			IV
131715822	J87150	06/20/2013	13:10	06/20/2013	21:55	4	2100	525	Underground equipment	Underground Primary	Replace - Same Size		VI
131715793	J87150	06/20/2013	13:10	06/20/2013	14:40	5	450	90	Underground equipment	Underground Primary			VI

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
131714517	J87150	06/20/2013	13:11	06/20/2013	14:40	2	178	89	Underground equipment	Underground Primary	Switch/Reset	Replace - Same Size	VI
131714654	L00134	06/20/2013	13:34	06/20/2013	14:02	1	28	28	Animal related	Transformer Fuse	Replace - Same Size		III
131714748	S95571	06/20/2013	13:35	06/20/2013	15:20	20	2100	105	Public				VI
131715387	S95571	06/20/2013	13:38	06/20/2013	15:20	125	12750	102	Public				VI
131715144	S95571	06/20/2013	13:42	06/20/2013	17:20	5	1090	218	Public				VI
131714787	D35002	06/20/2013	13:43	06/20/2013	15:59	26	3536	136	Overhead equipment	Overhead Primary	Tie/Tighten	Repair	I
131715065	R23331	06/20/2013	14:02	06/20/2013	14:17	1904	28560	15	Substation equipment				V
131715050	U29001	06/20/2013	14:20	06/20/2013	17:13	1	173	173	Other	Customer Equipment	Advise Customer		II
131715099	V28597	06/20/2013	14:27	06/20/2013	16:10	1	103	103	Overhead equipment	Overhead Service	Patrol/Test/Inspect	Repair	II
131715212	J86118	06/20/2013	14:50	06/20/2013	15:55	1	65	65	Tree related-tree broken	Tree			VI
131716168	B71002	06/20/2013	14:51	06/20/2013	21:41	4	1640	410	Underground equipment	Underground Primary	Repair	Repair	I
131715240	B71002	06/20/2013	14:51	06/20/2013	18:00	119	22491	189	Underground equipment	Underground Primary	Repair	Repair	I
131715303	U39541	06/20/2013	15:05	06/20/2013	15:37	1	32	32	Overhead equipment				II
131715454	D70001	06/20/2013	15:37	06/20/2013	19:30	33	7689	233	Overhead equipment	Fuse	Repair		I
131715536	M09143	06/20/2013	15:56	06/20/2013	21:26	2	660	330	Underground equipment	Underground Secondary	Replace - Same Size	Repair	VI
131715858	M04364	06/20/2013	15:56	06/20/2013	20:11	13	3315	255	Overhead equipment	Disconnect Switch			V
131715542	S30518	06/20/2013	15:58	06/20/2013	17:01	1	63	63	Overhead equipment	Overhead Service	Patrol/Test/Inspect	Repair	VI
131715556	M07236	06/20/2013	16:03	06/20/2013	19:00	1	177	177	Public	Pole	Patrol/Test/Inspect	Replace - Urgent	III
131715595	D66004	06/20/2013	16:06	06/21/2013	3:56	8	5680	710	Underground equipment	Underground Primary		Repair	IV
131715573	M05362	06/20/2013	16:07	06/20/2013	17:11	1	64	64	Overhead equipment				V
131715698	J63173	06/20/2013	16:55	06/20/2013	17:10	1	15	15	Public	Underground Secondary	Repair		III
131716497	J87150	06/20/2013	17:32	06/20/2013	21:55	5	1315	263	Underground equipment	Underground Primary		Replace - Same Size	VI
131715799	J87150	06/20/2013	17:32	06/20/2013	18:25	12	636	53	Underground equipment	Underground Primary			VI
131715796	R60551	06/20/2013	17:41	06/20/2013	18:30	1	49	49	Overhead equipment	Fuse	Replace - Same Size	No Work Required	IV
131716676	P60161	06/20/2013	17:46	06/21/2013	2:10	6	3024	504	Underground equipment	Underground Primary	Repair		VI
131715832	P60161	06/20/2013	17:46	06/20/2013	22:21	45	12375	275	Underground equipment	Underground Primary		Repair	VI
131716062	Q27185	06/20/2013	18:05	06/20/2013	20:11	1	126	126	Tree related-tree contact	Fuse	Replace - Same Size		VI
131716147	L23145	06/20/2013	18:17	06/20/2013	21:15	1	178	178	Overhead equipment	Overhead Transformer	Replace - Same Size		III
131716154	B73003	06/20/2013	18:24	06/20/2013	21:30	20	3720	186	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Repair	I
131716371	L68111	06/20/2013	18:29	06/20/2013	20:30	1	121	121	Overhead equipment	Overhead Service	Cut in Clear		IV
131716495	Q04411	06/20/2013	18:45	06/20/2013	20:49	29	3596	124	Underground equipment	Underground Primary			III
131716499	J89125	06/20/2013	18:50	06/20/2013	20:01	7	497	71	Public	Transformer Fuse	Replace - Same Size		VI
131716516	F03003	06/20/2013	19:12	06/20/2013	20:23	1	71	71	Tree related-tree broken	Overhead Service	Cut in Clear	No Work Required	III
131716542	J88163	06/20/2013	19:45	06/20/2013	20:33	1	48	48	Overhead equipment	Overhead Transformer	Replace - Same Size		VI
131716550	J56341	06/20/2013	19:45	06/20/2013	21:12	19	1653	87	Animal related	Overhead Transformer			III
131716548	Q32171	06/20/2013	19:50	06/20/2013	23:06	1	196	196	Tree related-tree broken	Overhead Primary	Repair	Repair	I
131716650	L81141	06/20/2013	19:57	06/20/2013	22:30	5	765	153	Tree related-tree broken	Overhead Primary	Repair	Repair	IV
131716567	P12290	06/20/2013	20:22	06/24/2013	9:02	5	25400	5080	Weather	Customer Equipment	Patrol/Test/Inspect		V
131716684	D16003	06/20/2013	20:46	06/21/2013	5:10	8	4032	504	Underground equipment	Underground Primary	Repair	Repair	I
131716585	D16003	06/20/2013	20:46	06/20/2013	22:55	78	10062	129	Underground equipment	Underground Primary		Repair	I
131716588	S61575	06/20/2013	20:53	06/21/2013	5:09	2	992	496	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	VI
131716678	R02120	06/20/2013	22:39	06/21/2013	1:23	1	164	164	Overhead equipment	Overhead Service	Repair		VI
131716682	342003	06/20/2013	22:48	06/21/2013	0:10	1	82	82	Overhead equipment	Fuse	Replace - Same Size		VI
131716687	L12126	06/20/2013	22:53	06/21/2013	1:30	129	20253	157	Underground equipment	Underground Primary		Repair	III
131720097	U97528	06/21/2013	0:41	06/21/2013	4:50	1	249	249	Underground equipment	Underground Primary		Repair	II
131720103	X37001	06/21/2013	1:29	06/21/2013	8:45	1	436	436	Underground equipment	Underground Secondary	Repair		IV
131720137	P26280	06/21/2013	2:10	06/21/2013	4:00	8	880	110	Tree related-tree broken				I
131720212	P26280	06/21/2013	2:37	06/21/2013	6:22	12	2700	225	Tree related-tree broken	Overhead Primary	Patrol/Test/Inspect	Repair	I
131723504	J47178	06/21/2013	5:11	06/21/2013	8:08	35	6195	177	Underground equipment	Underground Primary	Repair	Repair	III
131723435	U97528	06/21/2013	5:20	06/21/2013	8:09	9	1521	169	Overhead equipment	Overhead Transformer	Replace - Same Size		II
131723437	R49275	06/21/2013	5:23	06/21/2013	6:42	1	79	79	Overhead equipment	Transformer Fuse		Patrol/Test/Inspect	VI
131723458	J30201	06/21/2013	6:29	06/21/2013	7:30	1	61	61	Animal related	Transformer Fuse		Patrol/Test/Inspect	VI
131723470	B27009	06/21/2013	6:31	06/21/2013	8:14	68	7004	103	Unknown	Fuse			I
131723469	D81003	06/21/2013	6:32	06/21/2013	7:48	57	4332	76	Animal related	Disconnect Switch			I
131723503	A85001	06/21/2013	7:03	06/21/2013	13:32	1	389	389	Underground equipment	Underground Primary			I
131723512	J89126	06/21/2013	7:06	06/21/2013	7:36	1	30	30	Overhead equipment	Fuse	Replace - Same Size		VI

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
131723537	Y98518	06/21/2013	7:13	06/21/2013	8:10	1	57	57	Unknown	Fuse	Replace - Same Size		IV
131723580	E05002	06/21/2013	7:22	06/21/2013	9:35	51	6783	133	Underground equipment	Underground Primary	Switch/Reset	Repair	IV
131723594	P52305	06/21/2013	7:32	06/21/2013	14:10	1	398	398	Underground equipment	Underground Service	Repair		IV
131723972	M05362	06/21/2013	7:43	06/21/2013	7:48	422	2110	5	Overhead equipment	Regulator			V
131723653	B68001	06/21/2013	7:54	06/21/2013	8:31	1	37	37	Animal related	Other	Replace - Same Size	Patrol/Test/Inspect	III
131723691	K57212	06/21/2013	8:11	06/21/2013	10:36	2	290	145	Animal related	Animal Guard	Install	Replace - Same Size	VI
131723791	S61531	06/21/2013	8:44	06/21/2013	9:08	1	24	24	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	VI
131723789	K43386	06/21/2013	8:45	06/21/2013	9:23	1	38	38	Animal related	Fuse	Replace - Same Size		V
131723824	Y55594	06/21/2013	8:52	06/21/2013	10:55	1	123	123	Animal related	Lightning Arrestor	Replace - Same Size		IV
131723912	S88503	06/21/2013	9:04	06/21/2013	10:35	62	5642	91	Unknown	Fuse			VI
131724049	J99141	06/21/2013	9:07	06/21/2013	12:43	19	4104	216	Underground equipment	Underground Primary	Patrol/Test/Inspect	Patrol/Test/Inspect	VI
131724046	Q04411	06/21/2013	9:25	06/21/2013	10:15	11	550	50	Overhead equipment	Fuse	Repair	Repair	III
131724474	L68113	06/21/2013	11:25	06/21/2013	11:45	6	120	20	Overhead equipment	Fuse	Replace - Same Size		IV
131724484	D36003	06/21/2013	11:28	06/21/2013	12:28	1	60	60	Animal related	Transformer Fuse	Replace - Same Size		I
131724504	V28597	06/21/2013	11:33	06/21/2013	12:30	1	57	57	Overhead equipment	Overhead Service			II
131724528	R08910	06/21/2013	11:39	06/21/2013	12:14	1	35	35	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	VI
131724611	J85161	06/21/2013	12:03	06/21/2013	14:01	3	354	118	Animal related	Fuse		Replace - Same Size	VI
131724662	J12166	06/21/2013	12:18	06/21/2013	14:10	1	112	112	Tree related-tree broken	Overhead Service	Repair		III
131724701	Z30584	06/21/2013	12:28	06/21/2013	12:55	6	162	27	Overhead equipment	Transformer Fuse	Replace - Same Size	No Work Required	IV
131724712	Y54002	06/21/2013	12:32	06/21/2013	13:20	1	48	48	Overhead equipment	Connector	Replace - Same Size		IV
131725233	N05170	06/21/2013	12:47	06/21/2013	15:44	6	1062	177	Overhead equipment	Fuse	Replace - Same Size	No Work Required	I
131724799	Z29579	06/21/2013	12:49	06/21/2013	14:47	1	118	118	Overhead equipment	Disconnect Switch		Replace - Same Size	IV
131724812	R50910	06/21/2013	12:52	06/21/2013	16:28	1	216	216	Weather	Overhead Transformer		Replace - Same Size	I
131724856	D35003	06/21/2013	13:02	06/21/2013	14:22	1	80	80	Weather	Disconnect Switch	Replace - Same Size		I
131724916	D35003	06/21/2013	13:11	06/21/2013	14:53	1	102	102	Weather	Disconnect Switch	Replace - Same Size		I
131725447		06/21/2013	13:14	06/21/2013	14:22	571	38828	68	Weather				I
131725308		06/21/2013	13:14	06/21/2013	14:22	604	41072	68	Weather				I
131724986	B93001	06/21/2013	13:14	06/21/2013	14:52	655	64190	98	Overhead equipment	Disconnect Switch	Replace - Same Size		I
131725039	P26BUS	06/21/2013	13:14	06/21/2013	13:51	3115	115255	37	Weather				I
131724934	B44002	06/21/2013	13:16	06/21/2013	13:50	26	884	34	Overhead equipment	Overhead Transformer	Replace - Same Size		I
131725085	M40131	06/21/2013	13:33	06/21/2013	19:02	17	5593	329	Tree related-tree broken	Overhead Transformer		Replace - Same Size	I
131725136	R60551	06/21/2013	13:39	06/21/2013	15:20	1	101	101	Underground equipment	Underground Service	Replace - Same Size	Repair	IV
131725975	D01002	06/21/2013	13:55	06/21/2013	15:52	8	936	117	Overhead equipment	Disconnect Switch	Replace - Same Size		I
131725225	B19002	06/21/2013	13:55	06/21/2013	19:45	2	700	350	Tree related-tree broken	Tree	Patrol/Test/Inspect		I
131725224	S53542	06/21/2013	14:01	06/21/2013	15:25	2	168	84	Overhead equipment	Overhead Primary	Repair		VI
131725243	B65001	06/21/2013	14:04	06/21/2013	18:20	1	256	256	Tree related-tree broken	Overhead Service	Repair		I
131726781	B45005	06/21/2013	14:04	06/21/2013	20:25	18	6858	381	Overhead equipment	Overhead Primary	Patrol/Test/Inspect	Repair	I
131725271	B45005	06/21/2013	14:04	06/21/2013	16:29	95	13775	145	Overhead equipment	Overhead Primary			I
131725258	B77003	06/21/2013	14:05	06/21/2013	16:43	2	316	158	Overhead equipment	Fuse	Replace - Same Size		I
131725285	A26006	06/21/2013	14:05	06/21/2013	17:35	64	13440	210	Tree related-tree broken	Overhead Primary			I
131725268	D16003	06/21/2013	14:06	06/22/2013	11:43	2	2594	1297	Tree related-tree broken	Tree	Patrol/Test/Inspect	Repair	I
131725401	B19002	06/21/2013	14:07	06/21/2013	16:43	45	7020	156	Tree related-tree broken	Fuse	Replace - Same Size	No Work Required	I
131725291	A56013	06/21/2013	14:08	06/21/2013	15:15	1	67	67	Tree related-tree contact	Overhead Service	Repair		I
131725812	B65001	06/21/2013	14:08	06/22/2013	0:45	30	19110	637	Tree related-tree broken	Overhead Primary		Repair	I
131725319	D72001	06/21/2013	14:11	06/21/2013	20:28	1	377	377	Tree related-tree broken	Overhead Service	Tie/Tighten		I
131725378	B08003	06/21/2013	14:11	06/21/2013	18:48	79	21883	277	Overhead equipment	Fuse	Replace - Same Size		I
131725321		06/21/2013	14:12	06/21/2013	20:31	1	379	379	Tree related-tree broken				I
131725389	B77003	06/21/2013	14:13	06/21/2013	16:45	19	2888	152	Overhead equipment	Overhead Primary	Patrol/Test/Inspect		I
131725336	B19001	06/21/2013	14:14	06/22/2013	2:30	1	736	736	Tree related-tree broken	Pole	Replace - Same Size		I
131725352	A56013	06/21/2013	14:18	06/21/2013	19:37	1	319	319	Tree related-tree broken	Overhead Service	Repair	Repair	I
131725811	D28124	06/21/2013	14:22	06/21/2013	17:30	3	564	188	Overhead equipment	Overhead Primary	Patrol/Test/Inspect	Repair	I
131726001	A17025	06/21/2013	14:23	06/21/2013	17:27	262	48208	184	Tree related-tree broken	Fuse	Replace - Same Size	No Work Required	I
131725422	A36001	06/21/2013	14:25	06/21/2013	15:23	12	696	58	Overhead equipment	Fuse	Replace - Same Size		I
131726896	D92002	06/21/2013	14:25	06/21/2013	18:43	13	3354	258	Tree related-tree broken	Overhead Primary			I
131725468	D88001	06/21/2013	14:26	06/21/2013	17:08	29	4698	162	Overhead equipment	Fuse	Repair	Replace - Same Size	I
131725941	B58002	06/21/2013	14:29	06/21/2013	17:35	132	24552	186	Tree related-tree contact	Overhead Primary	Repair	No Work Required	I

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
131726723	M40117	06/21/2013	14:31	06/21/2013	18:28	1	237	237	Overhead equipment	Overhead Transformer	Replace - Same Size	Replace - Same Size	I
131725890	A50002	06/21/2013	14:38	06/21/2013	15:59	14	1134	81	Overhead equipment	Overhead Primary	Repair	Replace - Same Size	I
131725396	A42005	06/21/2013	14:41	06/22/2013	3:43	1	782	782	Tree related-tree broken				I
131725883	N93260	06/21/2013	14:42	06/21/2013	20:53	127	47117	371	Weather	Pole			III
131725842	K31120	06/21/2013	14:43	06/21/2013	17:23	1	160	160	Overhead equipment	Overhead Transformer	Repair	Repair	I
131726026	P49183	06/21/2013	14:45	06/21/2013	15:32	9	423	47	Overhead equipment	Fuse	Patrol/Test/Inspect	Replace - Same Size	I
131725879	J46182	06/21/2013	14:45	06/21/2013	19:59	3	942	314	Tree related-tree broken	Tree			III
131725900	B93003	06/21/2013	14:47	06/21/2013	16:33	1	106	106	Overhead equipment	Fuse	Replace - Same Size		I
131725934	B08003	06/21/2013	14:49	06/21/2013	17:45	136	23936	176	Overhead equipment	Fuse	Replace - Same Size		I
131726096	N18211	06/21/2013	14:49	06/21/2013	15:55	798	52668	66	Weather	Recloser	Switch/Reset		III
131725980	B73002	06/21/2013	14:57	06/21/2013	21:20	9	3447	383	Tree related-tree broken	Overhead Primary	Patrol/Test/Inspect		I
131725978	B58001	06/21/2013	14:57	06/21/2013	17:54	1	177	177	Weather	Fuse	Replace - Same Size	No Work Required	I
131726015	U37579	06/21/2013	15:02	06/21/2013	15:32	19	570	30	Public	Fuse	Replace - Same Size		II
131726034	A85001	06/21/2013	15:03	06/21/2013	17:10	23	2921	127	Weather	Fuse	Replace - Same Size		I
131726028	B58001	06/21/2013	15:05	06/21/2013	17:45	1	160	160	Weather	Fuse	Replace - Same Size	No Work Required	I
131726870	C10001	06/21/2013	15:10	06/21/2013	19:36	2	532	266	Tree related-tree broken	Overhead Primary	Cut in Clear	Repair	III
131726118	C10001	06/21/2013	15:10	06/21/2013	16:23	17	1241	73	Tree related-tree broken	Overhead Primary	Cut in Clear		III
131726081	A56015	06/21/2013	15:13	06/21/2013	16:10	1	57	57	Tree related-tree contact	Overhead Service		Repair	I
131726097		06/21/2013	15:17	06/21/2013	16:05	1	48	48	Overhead equipment	Fuse	Repair	Replace - Same Size	I
131726103	D88001	06/21/2013	15:19	06/21/2013	19:13	11	2574	234	Overhead equipment	Crossarm	Repair	Replace - Same Size	I
131726848	A45002	06/21/2013	15:20	06/21/2013	18:40	64	12800	200	Tree related-tree contact	Overhead Primary	Remove		I
131726709	A85002	06/21/2013	15:20	06/21/2013	21:10	12	4200	350	Tree related-tree broken	Overhead Primary	Patrol/Test/Inspect	Repair	I
131726130	Q21423	06/21/2013	15:22	06/21/2013	15:43	4	84	21	Underground equipment	Underground Secondary		Repair	VI
131726146	J61114	06/21/2013	15:24	06/21/2013	16:14	88	4400	50	Weather	Overhead Primary		Repair	III
131726150	D16004	06/21/2013	15:26	06/22/2013	5:12	1	826	826	Tree related-tree broken	Overhead Primary	Patrol/Test/Inspect	Repair	I
131726158	Y84526	06/21/2013	15:26	06/21/2013	16:55	28	2492	89	Weather				IV
131726187	A85001	06/21/2013	15:31	06/21/2013	18:06	8	1240	155	Weather	Lightning Arrestor	Disconnect	Replace - Same Size	I
131726168	B93003	06/21/2013	15:31	06/21/2013	17:42	1	131	131	Overhead equipment	Other	Patrol/Test/Inspect		I
131726865	K35308	06/21/2013	15:31	06/21/2013	17:30	1	119	119	Overhead equipment	Fuse	Replace - Same Size		III
131726196	D72003	06/21/2013	15:38	06/21/2013	20:19	1	281	281	Tree related-tree broken	Tree	Patrol/Test/Inspect	Repair	I
131726206	U99515	06/21/2013	15:42	06/21/2013	16:45	1	63	63	Weather	Transformer Fuse	Repair		II
131726224	L43154	06/21/2013	15:46	06/21/2013	19:05	1	199	199	Tree related-tree broken	Overhead Secondary	Repair	Repair	I
131726604	B44002	06/21/2013	15:49	06/21/2013	17:41	1	112	112	Tree related-tree broken	Overhead Service	No Work Required	No Work Required	I
131726634	K19118	06/21/2013	15:53	06/21/2013	18:43	1	170	170	Public	Overhead Service	Repair	Repair	VI
131726648	D41003	06/21/2013	15:58	06/21/2013	19:41	1	223	223	Overhead equipment	Overhead Service	Replace - Same Size		I
131726645	B58001	06/21/2013	15:58	06/21/2013	17:39	5	505	101	Weather	Fuse	Replace - Same Size	No Work Required	I
131726653	B44002	06/21/2013	15:59	06/21/2013	18:00	1	121	121	Tree related-tree broken	Overhead Service	Repair		I
131726664	U06524	06/21/2013	16:02	06/21/2013	18:20	5	690	138	Weather	Transformer Fuse	Repair		II
131726756	D36003	06/21/2013	16:08	06/21/2013	19:54	32	7232	226	Overhead equipment	Overhead Primary			I
131726697	T06538	06/21/2013	16:12	06/21/2013	17:17	1	65	65	Unknown	Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
131726701	C50003	06/21/2013	16:14	06/21/2013	17:06	1	52	52	Overhead equipment	Fuse	Replace - Same Size	Repair	III
131726732	L86175	06/21/2013	16:17	06/22/2013	2:18	91	54691	601	Tree related-tree broken				IV
131726719		06/21/2013	16:19	06/21/2013	17:00	1	41	41	Unknown	Fuse	Repair		IV
131726728	D31018	06/21/2013	16:20	06/21/2013	18:23	1	123	123	Overhead equipment	Fuse	Replace - Same Size	Repair	III
131727543	L86175	06/21/2013	16:23	06/22/2013	2:18	11	6545	595	Tree related-tree broken	Tree	Remove		IV
131726985	L86175	06/21/2013	16:23	06/22/2013	2:18	51	30345	595	Tree related-tree broken				IV
131726833	D87001	06/21/2013	16:25	06/22/2013	1:41	3	1668	556	Underground equipment	Underground Primary	Repair	Replace - Same Size	I
131726747	N72240	06/21/2013	16:26	06/21/2013	17:57	1	91	91	Weather	Fuse	Replace - Same Size		III
131726757	A36002	06/21/2013	16:28	06/21/2013	17:27	1	59	59	Overhead equipment	Fuse	Replace - Same Size		I
131726926	D90002	06/21/2013	16:29	06/21/2013	17:39	3	210	70	Overhead equipment	Fuse	Replace - Same Size	Repair	III
131726993	L86176	06/21/2013	16:30	06/21/2013	17:45	273	20475	75	Overhead equipment	Overhead Primary	Switch/Reset		IV
131726936	L86176	06/21/2013	16:30	06/21/2013	20:15	66	14850	225	Overhead equipment	Overhead Primary	Patrol/Test/Inspect	Repair	IV
131726796	B58001	06/21/2013	16:38	06/21/2013	17:39	1	61	61	Weather	Fuse	Replace - Same Size	No Work Required	I
131726800	U62510	06/21/2013	16:40	06/21/2013	17:15	1	35	35	Weather	Fuse	Replace - Same Size	Replace - Same Size	II
131726999	U62510	06/21/2013	16:45	06/21/2013	17:50	18	1170	65	Weather	Disconnect Switch	Repair		II
131726834	N93260	06/21/2013	16:47	06/21/2013	17:15	1	28	28	Weather	Fuse			III

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
131726832	L23146	06/21/2013	16:47	06/21/2013	17:20	9	297	33	Tree related-tree broken	Overhead Service	Patrol/Test/Inspect	Repair	III
131726851	R50910	06/21/2013	16:52	06/21/2013	18:30	1	98	98	Weather	Transformer Fuse	Replace - Same Size		I
131726215	P98190	06/21/2013	16:52	06/21/2013	20:00	10	1880	188	Tree related-tree broken				III
131726915	R48166	06/21/2013	17:00	06/21/2013	18:44	324	33696	104	Tree related-tree broken	Tree			IV
131726909	V59001	06/21/2013	17:06	06/21/2013	17:46	1	40	40	Animal related	Transformer Fuse	Replace - Same Size		II
131726919	P52305	06/21/2013	17:10	06/21/2013	18:39	1	89	89	Tree related-tree contact	Transformer Fuse			IV
131726941	D28124	06/21/2013	17:22	06/21/2013	18:03	1	41	41	Overhead equipment	Overhead Primary	Patrol/Test/Inspect		I
131726928	L86175	06/21/2013	17:26	06/21/2013	17:55	25	725	29	Overhead equipment	Overhead Primary		Repair	IV
131726955	D93001	06/21/2013	17:29	06/21/2013	18:44	1	75	75	Overhead equipment	Pole	Patrol/Test/Inspect	Repair	IV
131726923	L86175	06/21/2013	17:29	06/21/2013	17:55	40	1040	26	Overhead equipment	Overhead Primary		Repair	IV
131726951	B58001	06/21/2013	17:30	06/21/2013	18:27	1	57	57	Overhead equipment	Transformer Fuse	Replace - Same Size	No Work Required	I
131726964	Z04002	06/21/2013	17:32	06/21/2013	20:00	1	148	148	Tree related-tree contact	Tree	Trim		IV
131726970	F03004	06/21/2013	17:34	06/21/2013	19:07	1	93	93	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	III
131726974	H06135	06/21/2013	17:36	06/22/2013	1:07	1	451	451	Overhead equipment	Overhead Transformer			IV
131726996	R23332	06/21/2013	17:46	06/21/2013	18:59	1	73	73	Underground equipment	Pedestal	Repair		V
131727000	M07236	06/21/2013	17:47	06/21/2013	19:35	1	108	108	Weather	Fuse	Replace - Same Size		III
131727121	Y61003	06/21/2013	18:04	06/21/2013	20:57	10	1730	173	Tree related-tree broken	Overhead Primary	Repair		IV
131727127	Q74148	06/21/2013	18:05	06/21/2013	23:40	1	335	335	Weather	Fuse			IV
131727128	S09520	06/21/2013	18:05	06/21/2013	19:06	1	61	61	Other	Overhead Service			VI
131727131	X39542	06/21/2013	18:07	06/21/2013	22:14	2	494	247	Overhead equipment	Overhead Transformer	Replace - Same Size	Repair	IV
131727135	K65221	06/21/2013	18:09	06/21/2013	19:04	1	55	55	Weather	Other			III
131727572	L79180	06/21/2013	18:21	06/21/2013	19:44	337	27971	83	Overhead equipment	Jumper	Repair		IV
131727426	Y05002	06/21/2013	18:23	06/21/2013	19:45	4	328	82	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
131727490	Y66557	06/21/2013	18:24	06/21/2013	22:00	33	7128	216	Tree related-tree broken	Overhead Service	Replace - New Size	Replace - Same Size	IV
131727508	B65004	06/21/2013	18:35	06/21/2013	23:09	1	274	274	Tree related-tree broken	Overhead Service			I
131727518	D55002	06/21/2013	18:46	06/21/2013	22:06	1	200	200	Tree related-tree broken	Overhead Service			I
131727522	312114	06/21/2013	18:46	06/21/2013	20:56	1	130	130	Tree related-tree contact	Overhead Service	Repair		V
131727551	U06524	06/21/2013	18:58	06/21/2013	22:40	313	69486	222	Weather	Fuse	Replace - Same Size		II
131727554	N78243	06/21/2013	19:04	06/21/2013	19:39	15	525	35	Overhead equipment	Overhead Service	Repair		I
131727557	A85001	06/21/2013	19:06	06/21/2013	19:42	1	36	36	Weather	Fuse	Replace - Same Size		I
131727559	Q74148	06/21/2013	19:08	06/22/2013	2:32	1	444	444	Weather	Overhead Transformer			IV
131727582	B08003	06/21/2013	19:16	06/21/2013	21:05	79	8611	109	Overhead equipment	Overhead Primary	No Work Required		I
131727583	B73001	06/21/2013	19:22	06/22/2013	0:25	1	303	303	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Repair	I
131727606	D93001	06/21/2013	19:41	06/21/2013	20:44	47	2961	63	Unknown	Fuse	Patrol/Test/Inspect	Replace - Same Size	IV
131727612	X86546	06/21/2013	19:53	06/21/2013	21:56	2	246	123	Weather	Customer Equipment			IV
131727614	R05115	06/21/2013	19:57	06/21/2013	21:30	1	93	93	Overhead equipment	Connector	Repair	Tie/Tighten	I
131727634	R84148	06/21/2013	20:21	06/21/2013	21:30	5	345	69	Unknown	Fuse	Patrol/Test/Inspect	Replace - Same Size	I
131727643	B08003	06/21/2013	20:46	06/21/2013	21:21	1	35	35	Overhead equipment	Overhead Service	Tie/Tighten		I
131727651	B93002	06/21/2013	20:57	06/22/2013	5:52	1	535	535	Underground equipment	Underground Primary	Repair	Replace - Same Size	I
131727649	K82202	06/21/2013	20:57	06/21/2013	22:27	1	90	90	Tree related-tree broken	Overhead Service			III
131727655	K30204	06/21/2013	21:00	06/21/2013	22:15	1	75	75	Weather	Fuse	Replace - Same Size		III
131727796	F22001	06/21/2013	21:07	06/21/2013	22:49	6	612	102	Underground equipment	Underground Primary	Switch/Reset		IV
131727661	F22001	06/21/2013	21:07	06/22/2013	0:35	25	5200	208	Underground equipment	Underground Primary		Repair	IV
131727670	U62521	06/21/2013	21:15	06/22/2013	2:45	7	2310	330	Weather	Overhead Transformer	Replace - Same Size		II
131727674	B19001	06/21/2013	21:19	06/21/2013	23:20	1	121	121	Tree related-tree broken	Tree	Remove	No Work Required	I
131727754		06/21/2013	21:46	06/21/2013	22:25	1	39	39	Public	Overhead Service	Disconnect		VI
131727762	307001	06/21/2013	21:59	06/21/2013	23:20	1	81	81	Tree related-tree broken	Overhead Service		Repair	VI
131727763	G30001	06/21/2013	22:00	06/22/2013	0:52	1	172	172	Weather	Transformer Fuse		Repair	III
131725054	B93003	06/21/2013	22:08	06/22/2013	6:07	1	479	479	Overhead equipment	Pole	Patrol/Test/Inspect	Repair	I
131727776	R68903	06/21/2013	22:31	06/22/2013	0:05	1	94	94	Weather	Lightning Arrestor	Replace - Same Size	No Work Required	I
131727802	U06551	06/21/2013	23:18	06/22/2013	3:22	1	244	244	Weather	Transformer Fuse	Replace - Same Size		II
131730018	D36003	06/22/2013	0:26	06/22/2013	2:39	1	133	133	Tree related-tree contact	Overhead Service			I
131730052	Q06141	06/22/2013	2:46	06/22/2013	7:20	15	4110	274	Underground equipment	Underground Primary		Switch/Reset	IV
131730036	311001	06/22/2013	3:06	06/22/2013	4:07	11	671	61	Overhead equipment	Fuse	Replace - Same Size		VI
131730051	B80003	06/22/2013	4:41	06/22/2013	9:06	1	265	265	Tree related-tree broken	Overhead Service	Patrol/Test/Inspect	Repair	I
131730053	R59412	06/22/2013	5:01	06/22/2013	8:49	11	2508	228	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	IV

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
131730063	M42107	06/22/2013	5:42	06/22/2013	7:50	19	2432	128	Animal related	Transformer Fuse	Replace - Same Size	Replace - Same Size	I
131730067	M78324	06/22/2013	6:01	06/22/2013	7:18	9	693	77	Overhead equipment	Transformer Fuse	Replace - Same Size		V
131730070	Q06132	06/22/2013	6:12	06/22/2013	8:28	8	1088	136	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	IV
131730076	J75271	06/22/2013	6:30	06/22/2013	8:26	1	116	116	Tree related-tree contact	Fuse			IV
131730082	K30205	06/22/2013	6:31	06/22/2013	7:40	28	1932	69	Unknown	Fuse	Replace - Same Size		III
131730085	Q15844	06/22/2013	6:42	06/22/2013	8:25	50	5150	103	Animal related	Fuse	Replace - Same Size		V
131730091	P98192	06/22/2013	6:52	06/22/2013	7:39	19	893	47	Animal related	Fuse			III
131730092	M37191	06/22/2013	6:59	06/22/2013	8:15	9	684	76	Animal related	Transformer Fuse	Replace - Same Size	Replace - Same Size	I
131730101	C10001	06/22/2013	7:04	06/22/2013	10:57	4	932	233	Weather	Other	Patrol/Test/Inspect	Patrol/Test/Inspect	III
131730108	L68111	06/22/2013	7:07	06/22/2013	7:55	53	2544	48	Overhead equipment	Fuse			IV
131730109	U32579	06/22/2013	7:24	06/22/2013	8:04	9	360	40	Overhead equipment	Transformer Fuse	Repair	Repair	II
131730126	K39153	06/22/2013	7:38	06/22/2013	12:27	1	289	289	Underground equipment	Underground Primary			III
131730135	U32579	06/22/2013	7:53	06/22/2013	8:07	1	14	14	Overhead equipment	Transformer Fuse	Repair	Repair	II
131730162	Q93522	06/22/2013	8:15	06/22/2013	9:15	1	60	60	Weather	Fuse	Replace - Same Size	No Work Required	I
131730203	D31015	06/22/2013	8:58	06/22/2013	10:39	1	101	101	Weather	Other	Patrol/Test/Inspect	Patrol/Test/Inspect	III
131730212	Q95247	06/22/2013	9:07	06/22/2013	10:25	1	78	78	Overhead equipment				VI
131730216	N03298	06/22/2013	9:13	06/22/2013	10:55	1	102	102	Overhead equipment	Overhead Service	Replace - Same Size	Repair	V
131730234	R07382	06/22/2013	9:34	06/22/2013	9:55	1	21	21	Animal related	Fuse	Replace - Same Size	Replace - Same Size	I
131730244		06/22/2013	9:49	06/22/2013	10:46	1	57	57	Overhead equipment	Overhead Primary			IV
131730267	D92002	06/22/2013	10:18	06/22/2013	11:20	1	62	62	Overhead equipment	Overhead Service	Repair	No Work Required	I
131730540	A80001	06/22/2013	10:38	06/22/2013	15:17	10	2790	279	Overhead equipment				I
131730300	U32594	06/22/2013	10:39	06/22/2013	11:31	1	52	52	Tree related-tree broken	Overhead Service	Repair	Repair	II
131730311	302002	06/22/2013	10:53	06/22/2013	11:50	1	57	57	Overhead equipment	Connector	Replace - Same Size		VI
131730317	P47125	06/22/2013	10:54	06/22/2013	12:32	1	98	98	Overhead equipment	Connector	Replace - Same Size	Patrol/Test/Inspect	I
131730667		06/22/2013	10:54	06/22/2013	12:54	668	80160	120	Animal related				I
131730432	A12035	06/22/2013	10:54	06/22/2013	11:54	810	48600	60	Animal related				I
131730462	A91003	06/22/2013	10:54	06/22/2013	11:10	827	13232	16	Animal related	Substation Misc.	Switch/Reset		I
131730521	X75571	06/22/2013	10:58	06/22/2013	12:39	601	60701	101	Weather	Recloser	Switch/Reset		IV
131730455	X75571	06/22/2013	11:11	06/22/2013	15:54	1	283	283	Tree related-tree broken	Overhead Service	Cut in Clear		IV
131730488	D67001	06/22/2013	11:23	06/22/2013	14:00	19	2983	157	Underground equipment	Underground Primary	Repair		IV
131730538	X73002	06/22/2013	11:28	06/22/2013	15:25	48	11376	237	Weather	Fuse	Replace - Same Size		IV
131730492	B79003	06/22/2013	11:29	06/22/2013	13:32	1	123	123	Overhead equipment	Connector	Repair	No Work Required	I
131730843	X75512	06/22/2013	11:31	06/22/2013	13:35	92	11408	124	Tree related-tree broken	Fuse	Replace - Same Size		IV
131730508	R04407	06/22/2013	11:33	06/22/2013	15:40	44	10868	247	Underground equipment	Underground Primary	Patrol/Test/Inspect	Replace - Same Size	V
131730510	X73002	06/22/2013	11:35	06/22/2013	19:08	1	453	453	Overhead equipment	Overhead Transformer	Replace - Same Size	Repair	IV
131730541	X73002	06/22/2013	11:41	06/22/2013	15:59	19	4902	258	Overhead equipment	Overhead Transformer	Replace - Same Size	Repair	IV
131730663	K52401	06/22/2013	11:55	06/22/2013	12:34	4	156	39	Underground equipment	Underground Secondary	Patrol/Test/Inspect	Repair	V
131730587	X73003	06/22/2013	11:59	06/22/2013	16:51	1	292	292	Tree related-tree broken	Overhead Service	Repair		IV
131730590	RT1001	06/22/2013	12:03	06/22/2013	12:59	1	56	56	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	IV
131730607	Y39515	06/22/2013	12:10	06/22/2013	13:48	1	98	98	Tree related-tree broken	Overhead Service	Raise		IV
131730655	B65004	06/22/2013	12:21	06/22/2013	14:44	1	143	143	Tree related-tree broken	Overhead Service	No Work Required		I
131730659	X73002	06/22/2013	12:21	06/22/2013	17:20	9	2691	299	Tree related-tree broken	Overhead Secondary	Repair		IV
131730728	Y39521	06/22/2013	12:26	06/22/2013	12:57	6	186	31	Overhead equipment	Overhead Primary	Repair		IV
131730732	S01559	06/22/2013	12:33	06/22/2013	14:03	1	90	90	Overhead equipment	Jumper	Repair	Replace - Same Size	VI
131730735	306003	06/22/2013	12:34	06/22/2013	13:41	11	737	67	Underground equipment	Underground Transformer	Patrol/Test/Inspect	Replace - Same Size	VI
131730742	P69173	06/22/2013	12:37	06/22/2013	15:24	1	167	167	Overhead equipment	Overhead Service			III
131730753	K76546	06/22/2013	12:37	06/22/2013	19:20	52	20956	403	Tree related-tree broken	Pole	Patrol/Test/Inspect	Repair	IV
131730795	K69117	06/22/2013	12:40	06/22/2013	19:50	22	9460	430	Tree related-tree contact	Tree		Trim	IV
131732040	K80386	06/22/2013	12:42	06/22/2013	18:19	141	47517	337	Overhead equipment	Overhead Primary	Cut in Clear	Repair	IV
131730764	K79212	06/22/2013	12:43	06/23/2013	3:38	2	1790	895	Tree related-tree broken	Tree		Trim	IV
131730781	Y59519	06/22/2013	12:46	06/22/2013	15:38	1	172	172	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
131730838	K69112	06/22/2013	12:46	06/22/2013	16:46	57	13680	240	Overhead equipment				IV
131730788	X73001	06/22/2013	12:47	06/22/2013	18:46	3	1077	359	Tree related-tree broken	Overhead Secondary	Repair		IV
131730785	K71811	06/22/2013	12:47	06/22/2013	20:11	7	3108	444	Weather	Fuse	Replace - Same Size		IV
131730782	H07106	06/22/2013	12:47	06/22/2013	19:34	1	407	407	Weather				IV
131731174	K79213	06/22/2013	12:47	06/23/2013	2:11	10	8040	804	Tree related-tree broken	Pole	Patrol/Test/Inspect	Replace - Same Size	IV

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
131730793	R60552	06/22/2013	12:48	06/23/2013	1:25	1	757	757	Weather	Fuse	Replace - Same Size		IV
131730798	K71812	06/22/2013	12:49	06/22/2013	17:32	6	1698	283	Tree related-tree broken	Overhead Service			IV
131730812	F22001	06/22/2013	12:51	06/22/2013	14:38	17	1819	107	Weather				IV
131730806	310123	06/22/2013	12:52	06/22/2013	12:54	6	12	2	Overhead equipment	Customer Equipment	Advise Customer		V
131730875	P05825	06/22/2013	13:13	06/22/2013	17:20	1	247	247	Weather	Overhead Primary			V
131730908	313134	06/22/2013	13:16	06/22/2013	13:38	9	198	22	Overhead equipment	Overhead Transformer	Switch/Reset		V
131730928	Z04001	06/22/2013	13:16	06/22/2013	16:05	245	41405	169	Weather	Recloser	Patrol/Test/Inspect	Switch/Reset	IV
131730884	Z04520	06/22/2013	13:17	06/22/2013	17:55	1	278	278	Tree related-tree broken	Overhead Service	Repair		IV
131730888	Z20542	06/22/2013	13:19	06/22/2013	16:36	1	197	197	Weather	Lightning Arrestor	Replace - Same Size		IV
131730893	N67309	06/22/2013	13:20	06/22/2013	14:35	1	75	75	Animal related	Fuse	Replace - Same Size		I
131730897	D93001	06/22/2013	13:23	06/22/2013	17:45	7	1834	262	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	IV
131730899	H10843	06/22/2013	13:23	06/22/2013	15:30	1	127	127	Weather	Pole	Repair		V
131730904	Z04520	06/22/2013	13:27	06/22/2013	21:50	1	503	503	Overhead equipment	Overhead Transformer	Replace - Same Size	Replace - Same Size	IV
131730918	J75271	06/22/2013	13:28	06/22/2013	17:07	8	1752	219	Overhead equipment	Lightning Arrestor	Cut in Clear	Replace - Same Size	IV
131732355	Z11506	06/22/2013	13:28	06/22/2013	20:25	12	5004	417	Overhead equipment	Overhead Transformer	Replace - Same Size		IV
131730929	M05360	06/22/2013	13:30	06/22/2013	16:41	105	20055	191	Weather	Lightning Arrestor	Replace - Same Size		V
131730948	R28871	06/22/2013	13:36	06/22/2013	15:57	77	10857	141	Tree related-tree broken	Fuse	Remove	Replace - Same Size	V
131730942	K69112	06/22/2013	13:37	06/22/2013	16:48	45	8595	191	Overhead equipment	Fuse	Replace - Same Size	No Work Required	IV
131730943	J08207	06/22/2013	13:38	06/22/2013	16:10	1	152	152	Overhead equipment	Fuse	Patrol/Test/Inspect	Replace - New Size	I
131731111	X73003	06/22/2013	13:45	06/22/2013	16:19	54	8316	154	Tree related-tree broken	Overhead Service	Repair		IV
131730977	B28004	06/22/2013	13:48	06/22/2013	14:48	1	60	60	Overhead equipment	Connector	Repair	No Work Required	I
131731167	Q24313	06/22/2013	13:48	06/22/2013	15:07	105	8295	79	Overhead equipment	Fuse			VI
131730985	V19001	06/22/2013	13:49	06/22/2013	14:38	1	49	49	Overhead equipment	Overhead Secondary	Tie/Tighten		II
131731004	Y97514	06/22/2013	13:50	06/22/2013	15:20	58	5220	90	Weather	Fuse	Replace - Same Size		IV
131731173	Q23258	06/22/2013	13:51	06/22/2013	14:59	45	3060	68	Weather	Fuse			VI
131731053	X29548	06/22/2013	13:54	06/22/2013	15:54	1	120	120	Tree related-tree broken	Overhead Service	Repair	Replace - Same Size	IV
131731055	Y79006	06/22/2013	13:55	06/22/2013	18:45	6	1740	290	Overhead equipment	Overhead Primary	Repair	Replace - Same Size	IV
131731198	J75271	06/22/2013	14:17	06/22/2013	18:29	2	504	252	Weather	Fuse			IV
131740191	R04412	06/22/2013	14:17	06/22/2013	18:11	53	12402	234	Overhead equipment	Pole	Replace - Same Size		V
131731293	R04412	06/22/2013	14:17	06/23/2013	12:03	196	255976	1306	Tree related-tree broken	Pole	Patrol/Test/Inspect	Patrol/Test/Inspect	V
131731203	M31203	06/22/2013	14:18	06/22/2013	15:15	1	57	57	Overhead equipment	Fuse	Replace - Same Size		I
131732337	Z11536	06/22/2013	14:19	06/22/2013	16:00	77	7777	101	Weather	Fuse	Replace - Same Size	No Work Required	IV
131731211	K69112	06/22/2013	14:20	06/22/2013	19:30	1	310	310	Weather	Fuse			IV
131731288	K80382	06/22/2013	14:23	06/22/2013	18:51	62	16616	268	Tree related-tree contact	Fuse	Replace - Same Size	Trim	IV
131731738	61078	06/22/2013	14:24	06/22/2013	18:20	2220	523920	236	Unknown				VI
131731245	K69112	06/22/2013	14:25	06/22/2013	19:35	1	310	310	Weather	Fuse			IV
131731279	L74191	06/22/2013	14:27	06/22/2013	15:26	6	354	59	Animal related	Transformer Fuse	Replace - Same Size	No Work Required	IV
131731480	R04412	06/22/2013	14:28	06/22/2013	16:57	64	9536	149	Tree related-tree contact	Pole	Patrol/Test/Inspect	Replace - Same Size	V
131731316	Y45503	06/22/2013	14:29	06/22/2013	19:40	1	311	311	Weather	Overhead Transformer	Replace - Same Size	Replace - Same Size	IV
131731957	N35852	06/22/2013	14:29	06/22/2013	16:47	18	2484	138	Weather	Fuse	Replace - Same Size		V
131731660	303001	06/22/2013	14:30	06/23/2013	0:40	69	42090	610	Tree related-tree broken	Tree	Patrol/Test/Inspect	Remove	VI
131733001	303001	06/22/2013	14:31	06/23/2013	2:45	324	237816	734	Overhead equipment	Overhead Primary	Patrol/Test/Inspect	Replace - Same Size	VI
131731364	303001	06/22/2013	14:31	06/23/2013	8:25	45	48330	1074	Tree related-tree broken	Overhead Primary	Patrol/Test/Inspect		VI
131731327	P19395	06/22/2013	14:31	06/23/2013	2:00	16	11024	689	Overhead equipment				V
131731537	302004	06/22/2013	14:32	06/23/2013	6:05	19	17727	933	Overhead equipment	Overhead Primary	Patrol/Test/Inspect	Repair	VI
131731433	338003	06/22/2013	14:32	06/22/2013	19:08	175	48300	276	Weather	Overhead Primary			VI
131731388	303001	06/22/2013	14:35	06/23/2013	4:25	35	29050	830	Tree related-tree broken	Tree	Trim		VI
131731434	346001	06/22/2013	14:37	06/23/2013	2:48	1	731	731	Tree related-tree contact	Other			VI
131731426	341003	06/22/2013	14:37	06/22/2013	22:23	1	466	466	Tree related-tree contact	Other			VI
131731408	338003	06/22/2013	14:37	06/23/2013	4:00	1	803	803	Overhead equipment	Tree	Trim		VI
131732088	61079	06/22/2013	14:37	06/22/2013	17:00	3466	495638	143	Unknown				VI
131733204	302003	06/22/2013	14:37	06/22/2013	21:15	66	26268	398	Weather				VI
131731414	338002	06/22/2013	14:37	06/22/2013	14:40	115	345	3	Tree related-tree broken				VI
131731488	M22812	06/22/2013	14:40	06/22/2013	16:47	1	127	127	Weather	Meter	Patrol/Test/Inspect		V
131732829	303006	06/22/2013	14:40	06/23/2013	0:34	499	296406	594	Overhead equipment	Overhead Secondary	Patrol/Test/Inspect		VI
131731494	K71811	06/22/2013	14:42	06/22/2013	22:54	1	492	492	Tree related-tree broken				IV

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
131732459	P19395	06/22/2013	14:42	06/22/2013	19:06	2	528	264	Weather	Fuse	Patrol/Test/Inspect	Replace - Same Size	V
131732547	M81404	06/22/2013	14:42	06/22/2013	20:45	196	71148	363	Tree related-tree broken	Tree	Patrol/Test/Inspect	Remove	V
131731689	M81404	06/22/2013	14:42	06/22/2013	17:25	299	48737	163	Tree related-tree broken	Tree	Patrol/Test/Inspect	Remove	V
131731682	M22812	06/22/2013	14:43	06/22/2013	16:14	5	455	91	Weather	Overhead Transformer			V
131731512	341003	06/22/2013	14:43	06/22/2013	21:55	1	432	432	Tree related-tree contact	Other			VI
131731511	341002	06/22/2013	14:43	06/22/2013	22:11	1	448	448	Tree related-tree contact	Other			VI
131731569	303007	06/22/2013	14:43	06/23/2013	3:33	23	17710	770	Tree related-tree broken	Overhead Primary	Repair	Repair	VI
131731558		06/22/2013	14:44	06/23/2013	4:30	2	1652	826	Weather	Insulator	Patrol/Test/Inspect	Replace - Same Size	VI
131731547	338003	06/22/2013	14:44	06/22/2013	19:08	2	528	264	Overhead equipment				VI
131731617	303004	06/22/2013	14:45	06/23/2013	7:30	30	30150	1005	Tree related-tree broken	Overhead Primary	Patrol/Test/Inspect	Repair	VI
131731581	347001	06/22/2013	14:46	06/23/2013	1:34	1	648	648	Tree related-tree broken	Overhead Transformer	Switch/Reset		VI
131733164	T41540	06/22/2013	14:47	06/22/2013	21:15	5	1940	388	Underground equipment	Underground Primary	Repair	Repair	IV
131732196	324001	06/22/2013	14:47	06/22/2013	20:35	53	18444	348	Overhead equipment	Fuse	Replace - Same Size		VI
131731840	R04409	06/22/2013	14:47	06/23/2013	0:15	10	5680	568	Tree related-tree contact	Pole	Patrol/Test/Inspect	Replace - Same Size	V
131731681	T41540	06/22/2013	14:47	06/22/2013	19:51	26	7904	304	Underground equipment	Underground Primary	Repair	Repair	IV
131731604	334003	06/22/2013	14:50	06/23/2013	7:35	8	8040	1005	Overhead equipment	Tree	Trim		VI
131731602		06/22/2013	14:50	06/23/2013	2:50	1	720	720	Tree related-tree contact	Other			VI
131731627	303001	06/22/2013	14:52	06/23/2013	7:08	1	976	976	Tree related-tree broken	Tree	Trim		VI
131731664	374052	06/22/2013	14:56	06/23/2013	0:45	1	589	589	Tree related-tree contact	Other			VI
131731650	303005	06/22/2013	14:56	06/23/2013	3:27	3	2253	751	Weather	Transformer Fuse	Replace - Same Size		VI
131733249	303006	06/22/2013	14:59	06/23/2013	6:30	36	33516	931	Tree related-tree broken	Tree	Patrol/Test/Inspect	Remove	VI
131731687	H10843	06/22/2013	15:00	06/22/2013	16:09	1	69	69	Weather	Transformer Fuse	Replace - Same Size		V
131731841	N03296	06/22/2013	15:01	06/22/2013	17:23	26	3692	142	Weather	Fuse	Replace - Same Size	Replace - Same Size	V
131731703	X12526	06/22/2013	15:02	06/22/2013	19:42	1	280	280	Overhead equipment	Overhead Transformer		Patrol/Test/Inspect	IV
131731708	303001	06/22/2013	15:03	06/23/2013	5:19	1	856	856	Overhead equipment	Overhead Service		Reconnect	VI
131731724	Q18244	06/22/2013	15:04	06/22/2013	16:13	1	69	69	Animal related	Transformer Fuse			VI
131732577	M83408	06/22/2013	15:04	06/22/2013	17:57	28	4844	173	Weather	Fuse	Replace - Same Size	Replace - Same Size	V
131732385	P19395	06/22/2013	15:07	06/22/2013	18:16	3	567	189	Weather	Fuse	Patrol/Test/Inspect	Replace - Same Size	V
131731985	351001	06/22/2013	15:07	06/23/2013	6:55	36	34128	948	Tree related-tree broken				VI
131732472	Q24313	06/22/2013	15:09	06/22/2013	16:57	105	11340	108	Weather				VI
131732030	K43386	06/22/2013	15:11	06/22/2013	16:48	15	1455	97	Weather	Fuse	Replace - Same Size	Replace - Same Size	V
131731887	M73330	06/22/2013	15:12	06/22/2013	18:29	9	1773	197	Weather	Fuse	Replace - Same Size	Replace - Same Size	V
131731923	333002	06/22/2013	15:13	06/23/2013	5:00	1	827	827	Overhead equipment	Overhead Primary	Replace - Same Size	Replace - Same Size	VI
131731916	349002	06/22/2013	15:13	06/22/2013	23:26	1	493	493	Weather	Fuse	Replace - Same Size		VI
131731924	349002	06/22/2013	15:13	06/22/2013	23:20	10	4870	487	Weather	Fuse	Replace - Same Size		VI
131732099	M15375	06/22/2013	15:13	06/22/2013	17:43	20	3000	150	Weather	Fuse	Replace - Same Size	Replace - Same Size	V
131731932	M22812	06/22/2013	15:14	06/22/2013	16:15	1	61	61	Overhead equipment	Overhead Transformer		Replace - Same Size	V
131731984	F10002	06/22/2013	15:15	06/22/2013	19:33	49	12642	258	Tree related-tree broken	Overhead Primary		Repair	III
131732046	K11376	06/22/2013	15:15	06/22/2013	16:44	771	68619	89	Weather	Recloser	Switch/Reset		V
131731948	346002	06/22/2013	15:16	06/22/2013	22:10	1	414	414	Overhead equipment	Other			VI
131731960	346004	06/22/2013	15:17	06/22/2013	20:30	1	313	313	Overhead equipment				VI
131731977	K52401	06/22/2013	15:19	06/22/2013	19:08	4	916	229	Weather	Fuse	Replace - Same Size		V
131732151	346002	06/22/2013	15:19	06/22/2013	20:40	104	33384	321	Tree related-tree broken	Tree	Cut in Clear		VI
131732599	346003	06/22/2013	15:19	06/23/2013	1:45	37	23162	626	Overhead equipment	Overhead Primary	Patrol/Test/Inspect	Repair	VI
131732382	J80807	06/22/2013	15:19	06/22/2013	19:20	40	9640	241	Weather	Fuse	Patrol/Test/Inspect		V
131732083	J80807	06/22/2013	15:19	06/22/2013	19:33	37	9398	254	Weather				V
131732021		06/22/2013	15:20	06/23/2013	1:52	1	632	632	Tree related-tree contact	Other			VI
131732298	337001	06/22/2013	15:20	06/22/2013	21:23	11	3993	363	Weather	Pole	Patrol/Test/Inspect	Replace - Same Size	VI
131732037	X57525	06/22/2013	15:21	06/22/2013	18:31	3	570	190	Overhead equipment	Disconnect Switch	Replace - Same Size		IV
131732175	X57525	06/22/2013	15:23	06/22/2013	17:25	48	5856	122	Overhead equipment	Substation Breaker	Switch/Reset		IV
131732069	334004	06/22/2013	15:25	06/22/2013	20:52	1	327	327	Tree related-tree broken	Overhead Service	Cut in Clear		VI
131732068	T23528	06/22/2013	15:25	06/22/2013	17:10	1	105	105	Other	Underground Service	Repair		VI
131732396	J80807	06/22/2013	15:27	06/22/2013	18:30	5	915	183	Weather	Fuse	Patrol/Test/Inspect		V
131732081	J86118	06/22/2013	15:27	06/23/2013	1:17	1	590	590	Tree related-tree broken	Overhead Service	Repair		VI
131732107	E10003	06/22/2013	15:31	06/22/2013	18:42	1	191	191	Weather	Other	Patrol/Test/Inspect	Patrol/Test/Inspect	III
131732114	338006	06/22/2013	15:32	06/23/2013	2:39	1	667	667	Tree related-tree contact	Other			VI

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
131732144	D28124	06/22/2013	15:38	06/22/2013	18:30	1	172	172	Overhead equipment	Overhead Transformer	Replace - Same Size		I
131732143	L50215	06/22/2013	15:38	06/23/2013	7:48	1	970	970	Tree related-tree broken	Fuse	Replace - Same Size	Remove	VI
131732195	L93149	06/22/2013	15:40	06/22/2013	19:34	62	14508	234	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	VI
131732222	338005	06/22/2013	15:44	06/23/2013	3:08	1	684	684	Tree related-tree broken	Overhead Transformer	Replace - Same Size	Replace - Same Size	VI
131732216	K15205	06/22/2013	15:44	06/23/2013	2:41	1	657	657	Weather	Tree	Trim	Replace - Same Size	VI
131732261	K17119	06/22/2013	15:47	06/22/2013	16:53	1	66	66	Overhead equipment	Overhead Service	Repair	Repair	VI
131732284	L74191	06/22/2013	15:49	06/22/2013	15:56	1	7	7	Animal related	Transformer Fuse	Replace - Same Size	No Work Required	IV
131732291	L93135	06/22/2013	15:51	06/22/2013	22:12	6	2286	381	Weather	Fuse	Replace - Same Size		VI
131732402	342003	06/22/2013	15:52	06/23/2013	9:50	7	7546	1078	Tree related-tree broken	Pole	Replace - Same Size	Replace - Same Size	VI
131732331	J86118	06/22/2013	15:56	06/22/2013	22:12	1	376	376	Tree related-tree contact	Tree		Replace - Same Size	VI
131732363	L93132	06/22/2013	15:56	06/22/2013	17:20	55	4620	84	Weather	Fuse			VI
131732368	L71171	06/22/2013	16:02	06/22/2013	17:00	1	58	58	Overhead equipment	Transformer Fuse	Replace - Same Size	No Work Required	IV
131732367	P82291	06/22/2013	16:02	06/22/2013	22:06	1	364	364	Tree related-tree contact	Fuse	Switch/Reset		VI
131732372	J74125	06/22/2013	16:04	06/22/2013	17:01	1	57	57	Animal related	Fuse	Repair	Repair	VI
131732392	Q95248	06/22/2013	16:07	06/23/2013	7:53	9	8514	946	Weather	Overhead Transformer		Replace - Same Size	VI
131732784	P19395	06/22/2013	16:08	06/22/2013	20:41	9	2457	273	Weather	Fuse	Patrol/Test/Inspect	Replace - Same Size	V
131733302	A17022	06/22/2013	16:12	06/23/2013	15:13	1	1381	1381	Substation equipment	Substation Transformer	Replace - Same Size		I
131732578	A17022	06/22/2013	16:12	06/22/2013	18:04	2	224	112	Overhead equipment	Substation Breaker	Switch/Reset		I
131732406	Y12559	06/22/2013	16:12	06/22/2013	17:00	1	48	48	Weather	Fuse	Replace - Same Size	No Work Required	IV
131732408	303006	06/22/2013	16:12	06/23/2013	4:26	1	734	734	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Repair	VI
131732423	J83138	06/22/2013	16:13	06/22/2013	21:06	22	6446	293	Weather	Fuse		Replace - Same Size	VI
131732416	303007	06/22/2013	16:14	06/23/2013	4:45	1	751	751	Weather	Overhead Transformer	Switch/Reset		VI
131732420	J34356	06/22/2013	16:15	06/23/2013	1:12	1	537	537	Weather	Overhead Transformer		Replace - Same Size	V
131732428	R04409	06/22/2013	16:18	06/22/2013	18:02	1	104	104	Overhead equipment			Replace - Same Size	V
131732433	A85002	06/22/2013	16:19	06/23/2013	6:35	1	856	856	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
131732778	303002	06/22/2013	16:20	06/23/2013	5:00	2	1520	760	Tree related-tree broken	Tree		Remove	VI
131732440	P82291	06/22/2013	16:21	06/23/2013	13:00	1	1239	1239	Tree related-tree broken	Tree	Trim	Replace - Same Size	VI
131732438	374069	06/22/2013	16:21	06/23/2013	1:07	1	526	526	Tree related-tree contact	Other			VI
131732437	Q23256	06/22/2013	16:21	06/23/2013	2:33	5	3060	612	Tree related-tree contact	Fuse		Patrol/Test/Inspect	VI
131732445	R49261	06/22/2013	16:22	06/22/2013	20:27	1	245	245	Weather	Fuse	Replace - Same Size	Patrol/Test/Inspect	VI
131732446	R53391	06/22/2013	16:23	06/22/2013	18:34	3	393	131	Weather	Fuse	Replace - Same Size		V
131732448	303004	06/22/2013	16:23	06/23/2013	0:43	1	500	500	Weather	Transformer Fuse	Replace - Same Size		VI
131732456	J89126	06/22/2013	16:27	06/23/2013	0:05	1	458	458	Weather	Overhead Transformer	Replace - Same Size		VI
131732463	Q18244	06/22/2013	16:28	06/23/2013	3:39	1	671	671	Weather	Transformer Fuse			VI
131732471	L93135	06/22/2013	16:30	06/22/2013	22:10	1	340	340	Weather	Fuse	Replace - Same Size		VI
131732469	J86118	06/22/2013	16:30	06/22/2013	22:12	1	342	342	Tree related-tree contact	Tree		Replace - Same Size	VI
131732474	J34377	06/22/2013	16:31	06/22/2013	21:18	1	287	287	Weather				V
131732476	338007	06/22/2013	16:32	06/23/2013	2:57	1	625	625	Tree related-tree contact	Other			VI
131732655	M05360	06/22/2013	16:32	06/22/2013	19:08	499	77844	156	Weather	Recloser			V
131732479	303007	06/22/2013	16:34	06/23/2013	1:42	13	7124	548	Weather	Overhead Transformer	Switch/Reset		VI
131732488		06/22/2013	16:36	06/23/2013	1:25	1	529	529	Overhead equipment	Other			VI
131732492	V92555	06/22/2013	16:37	06/22/2013	17:40	2	126	63	Animal related	Transformer Fuse	Replace - Same Size	Patrol/Test/Inspect	II
131732508	X77543	06/22/2013	16:43	06/22/2013	18:45	1	122	122	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
131732511	M26161	06/22/2013	16:45	06/22/2013	17:57	1	72	72	Weather	Fuse			III
131732515	Y36541	06/22/2013	16:45	06/22/2013	17:35	1	50	50	Weather	Fuse	Replace - Same Size		IV
131732519	L50215	06/22/2013	16:46	06/23/2013	2:03	3	1671	557	Weather	Fuse		Replace - Same Size	VI
131740042	Q95247	06/22/2013	16:49	06/23/2013	4:15	4	2744	686	Tree related-tree contact	Overhead Primary	Patrol/Test/Inspect	Replace - Same Size	VI
131732527	H07106	06/22/2013	16:50	06/22/2013	19:14	1	144	144	Weather	Fuse	Repair	Repair	IV
131732530	J83138	06/22/2013	16:51	06/22/2013	20:56	4	980	245	Weather	Fuse		Replace - Same Size	VI
131732535		06/22/2013	16:52	06/23/2013	10:21	1	1049	1049	Tree related-tree broken	Tree		Remove	VI
131733223	Q24312	06/22/2013	16:59	06/22/2013	23:06	2	734	367	Weather	Fuse	Replace - Same Size	Patrol/Test/Inspect	VI
131732556	342003	06/22/2013	17:00	06/23/2013	8:22	1	922	922	Tree related-tree broken	Tree		Remove	VI
131732564	Q24313	06/22/2013	17:02	06/22/2013	17:48	1	46	46	Weather	Fuse			VI
131732584	Y12559	06/22/2013	17:06	06/22/2013	17:19	1	13	13	Weather	Fuse	Replace - Same Size	No Work Required	IV
131732590	303001	06/22/2013	17:08	06/23/2013	3:00	1	592	592	Overhead equipment	Tree	Trim		VI
131733186	332002	06/22/2013	17:10	06/23/2013	2:45	23	13225	575	Overhead equipment	Fuse	Replace - Same Size		VI

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
131732600	K15207	06/22/2013	17:12	06/23/2013	1:26	1	494	494	Overhead equipment	Overhead Service	Repair		VI
131732611	L74191	06/22/2013	17:17	06/22/2013	19:43	1	146	146	Tree related-tree broken	Overhead Service	Repair	No Work Required	IV
131732688	P77233	06/22/2013	17:17	06/22/2013	23:26	6	2214	369	Weather	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	VI
131732639	P25150	06/22/2013	17:23	06/22/2013	18:24	1	61	61	Weather	Fuse			III
131732641	L46811	06/22/2013	17:25	06/22/2013	18:32	1	67	67	Weather	Fuse	Replace - Same Size	No Work Required	V
131732661	334004	06/22/2013	17:30	06/23/2013	0:32	1	422	422	Tree related-tree contact	Other			VI
131733316	303005	06/22/2013	17:44	06/23/2013	5:45	8	5768	721	Tree related-tree broken	Tree	Trim	Repair	VI
131732698	P62138	06/22/2013	17:46	06/22/2013	18:31	1	45	45	Overhead equipment	Fuse	Repair	Replace - Same Size	VI
131732703	332001	06/22/2013	17:47	06/23/2013	1:22	1	455	455	Tree related-tree contact	Other			VI
131732974	P49180	06/22/2013	17:53	06/22/2013	20:00	72	9144	127	Tree related-tree broken	Overhead Primary	Repair	Patrol/Test/Inspect	I
131733005	J34377	06/22/2013	17:55	06/22/2013	21:12	113	22261	197	Weather	Lightning Arrestor	Replace - Same Size		V
131732742	R49263	06/22/2013	17:57	06/22/2013	19:51	1	114	114	Weather	Fuse	Replace - Same Size	Patrol/Test/Inspect	VI
131732745	303005	06/22/2013	18:00	06/23/2013	1:00	1	420	420	Tree related-tree broken	Tree		Remove	VI
131732747	J99128	06/22/2013	18:01	06/23/2013	1:49	1	468	468	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	VI
131732751	B80004	06/22/2013	18:04	06/22/2013	21:00	1	176	176	Overhead equipment	Fuse	Replace - Same Size		I
131732775		06/22/2013	18:08	06/23/2013	2:05	1	477	477	Tree related-tree contact	Other			VI
131732774	338003	06/22/2013	18:08	06/22/2013	19:26	1	78	78	Tree related-tree broken	Overhead Primary		Repair	VI
131732887	R34921	06/22/2013	18:14	06/23/2013	4:10	33	19668	596	Weather	Overhead Primary	Cut in Clear	Repair	VI
131732791	Y26580	06/22/2013	18:16	06/22/2013	19:10	1	54	54	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
131733006	M78322	06/22/2013	18:16	06/22/2013	20:09	29	3277	113	Weather	Transformer Fuse	Repair		V
131732798	K32915	06/22/2013	18:18	06/22/2013	19:59	1	101	101	Weather	Fuse			VI
131732810	M83408	06/22/2013	18:24	06/22/2013	20:40	1	136	136	Weather	Fuse	Replace - Same Size	Replace - Same Size	V
131733049	61078	06/22/2013	18:29	06/22/2013	19:40	1688	119848	71	Substation equipment				VI
131732816	346002	06/22/2013	18:29	06/22/2013	22:00	27	5697	211	Overhead equipment	Fuse	Replace - Same Size		VI
131732943	N03296	06/22/2013	18:30	06/23/2013	3:39	5	2745	549	Weather	Overhead Transformer	Replace - Same Size	Replace - Same Size	V
131732853	X73001	06/22/2013	18:39	06/22/2013	19:34	1	55	55	Tree related-tree broken	Overhead Service	Repair		IV
131732876	D72001	06/22/2013	18:41	06/22/2013	20:09	1	88	88	Tree related-tree broken	Overhead Service	No Work Required		I
131732929	B80004	06/22/2013	18:46	06/22/2013	21:00	1	134	134	Overhead equipment	Fuse	Replace - Same Size		I
131732931	L93149	06/22/2013	18:46	06/22/2013	18:56	21	210	10	Weather	Fuse			VI
131732936	K79223	06/22/2013	18:47	06/23/2013	1:00	1	373	373	Tree related-tree broken	Overhead Service	Replace - Same Size	Replace - Same Size	IV
131732938	338005	06/22/2013	18:48	06/23/2013	1:55	1	427	427	Overhead equipment	Other			VI
131732940	Z04520	06/22/2013	18:49	06/22/2013	21:49	1	180	180	Overhead equipment	Overhead Transformer	Replace - New Size		IV
131732957	Q10702	06/22/2013	18:52	06/23/2013	4:43	1	591	591	Weather	Overhead Transformer			V
131732984	334003	06/22/2013	18:59	06/23/2013	9:41	11	9702	882	Overhead equipment	Overhead Primary	Patrol/Test/Inspect	Repair	VI
131733023	J18268	06/22/2013	19:22	06/22/2013	21:11	1	109	109	Animal related	Transformer Fuse	Replace - Same Size	Patrol/Test/Inspect	VI
131733040	338003	06/22/2013	19:23	06/23/2013	1:55	53	20776	392	Tree related-tree broken	Tree	Patrol/Test/Inspect	Remove	VI
131733038	341001	06/22/2013	19:26	06/23/2013	5:49	1	623	623	Tree related-tree broken	Tree	Trim		VI
131733042	S22594	06/22/2013	19:29	06/22/2013	21:34	1	125	125	Overhead equipment	Disconnect Switch	Replace - Same Size		VI
131733064	Z41528	06/22/2013	19:46	06/22/2013	21:25	1	99	99	Tree related-tree broken	Tree	Remove		IV
131733062	X52537	06/22/2013	19:46	06/22/2013	21:15	1	89	89	Weather	Transformer Fuse	Replace - Same Size		IV
131733074	K27150	06/22/2013	19:50	06/22/2013	22:23	27	4131	153	Overhead equipment	Overhead Primary	Repair	Repair	VI
131733071	308003	06/22/2013	19:51	06/23/2013	2:32	1	401	401	Tree related-tree contact	Other			VI
131733162	M05360	06/22/2013	19:57	06/23/2013	2:25	1	388	388	Weather	Overhead Transformer	Replace - Same Size		V
131733171	338003	06/22/2013	20:00	06/23/2013	2:00	1	360	360	Overhead equipment	Tree	Trim		VI
131733169	308003	06/22/2013	20:00	06/23/2013	2:20	1	380	380	Tree related-tree contact	Other			VI
131733166	K15205	06/22/2013	20:00	06/23/2013	3:34	1	454	454	Tree related-tree broken	Tree	Trim	Trim	VI
131733200	K15205	06/22/2013	20:37	06/22/2013	23:28	1	171	171	Weather	Fuse		Replace - Same Size	VI
131733202	Q24312	06/22/2013	20:38	06/22/2013	23:07	1	149	149	Weather	Fuse	Replace - Same Size	Patrol/Test/Inspect	VI
131733205	K69117	06/22/2013	20:40	06/23/2013	2:10	1	330	330	Tree related-tree broken	Overhead Service	Repair	Replace - Same Size	IV
131733220	R73447	06/22/2013	21:00	06/22/2013	22:00	2	120	60	Unknown				V
131733232	303001	06/22/2013	21:10	06/23/2013	4:55	1	465	465	Tree related-tree broken	Overhead Secondary			VI
131733244	J97113	06/22/2013	21:15	06/22/2013	23:27	48	6336	132	Tree related-tree broken	Overhead Secondary			VI
131733248	HB6283	06/22/2013	21:24	06/23/2013	8:12	30	19440	648	Weather	Underground Primary	Patrol/Test/Inspect		VI
131733252	L93133	06/22/2013	21:31	06/23/2013	9:05	1	694	694	Weather	Tree			VI
131733261	Y39515	06/22/2013	21:42	06/22/2013	23:35	1	113	113	Overhead equipment	Fuse	Replace - Same Size		IV
131733266	M83408	06/22/2013	21:49	06/23/2013	5:24	3	1365	455	Weather	Overhead Transformer	Patrol/Test/Inspect		V

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
131733277	F10002	06/22/2013	22:03	06/23/2013	1:51	1	228	228	Overhead equipment	Transformer Fuse		Repair	III
131733293	Q95247	06/22/2013	22:24	06/23/2013	0:58	1	154	154	Overhead equipment				VI
131733310	J75271	06/22/2013	23:26	06/23/2013	3:18	1	232	232	Overhead equipment	Jumper	Repair		IV
131740006	308001	06/23/2013	0:05	06/23/2013	2:15	1	130	130	Tree related-tree contact	Other			VI
131740070	303006	06/23/2013	0:57	06/23/2013	9:30	7	3591	513	Overhead equipment				VI
131740053	303006	06/23/2013	0:57	06/23/2013	3:30	242	37026	153	Tree related-tree broken	Overhead Primary	Patrol/Test/Inspect	Repair	VI
131740031	L93133	06/23/2013	1:00	06/23/2013	10:32	1	572	572	Tree related-tree broken	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
131740049	R49261	06/23/2013	1:19	06/23/2013	5:51	50	13600	272	Underground equipment	Fuse		Patrol/Test/Inspect	VI
131740058	332002	06/23/2013	2:50	06/23/2013	9:48	16	6688	418	Weather	Overhead Transformer	Cut in Clear		VI
131740065	P77233	06/23/2013	3:36	06/23/2013	6:04	1	148	148	Weather	Fuse		Replace - Same Size	VI
131740066	L70125	06/23/2013	3:38	06/23/2013	4:54	1	76	76	Overhead equipment	Transformer Fuse	Replace - Same Size	No Work Required	IV
131740067	Y41559	06/23/2013	3:43	06/23/2013	6:00	1	137	137	Tree related-tree broken	Tree			IV
131740074	K69112	06/23/2013	4:09	06/23/2013	5:30	36	2916	81	Animal related	Fuse	Replace - Same Size		IV
131740082	C52002	06/23/2013	5:12	06/23/2013	7:26	1	134	134	Tree related-tree broken	Overhead Service	Patrol/Test/Inspect	Repair	III
131740084	L81141	06/23/2013	5:15	06/23/2013	6:10	1	55	55	Overhead equipment	Transformer Fuse	Replace - Same Size	No Work Required	IV
131740085	J86118	06/23/2013	5:25	06/23/2013	6:26	1	61	61	Tree related-tree broken	Overhead Service	Patrol/Test/Inspect	Repair	VI
131740094	HB6251	06/23/2013	5:55	06/23/2013	7:16	1	81	81	Weather	Overhead Primary	Patrol/Test/Inspect	Repair	VI
131740096	S20555	06/23/2013	6:02	06/23/2013	7:15	1	73	73	Animal related	Fuse	Replace - Same Size	No Work Required	VI
131740100	L93135	06/23/2013	6:02	06/23/2013	7:07	10	650	65	Tree related-tree broken	Fuse	Replace - Same Size		VI
131740103	M09144	06/23/2013	6:20	06/23/2013	7:54	1	94	94	Animal related	Fuse	Replace - Same Size	Repair	VI
131740125	A97001	06/23/2013	6:43	06/23/2013	7:35	160	8320	52	Animal related	Fuse	Replace - Same Size		I
131740134	R09225	06/23/2013	7:02	06/23/2013	7:59	1	57	57	Animal related	Transformer Fuse		Repair	III
131740140	351001	06/23/2013	7:09	06/23/2013	8:24	7	525	75	Overhead equipment	Overhead Primary	Repair	Repair	VI
131740143	J86118	06/23/2013	7:12	06/23/2013	11:35	10	2630	263	Tree related-tree contact	Overhead Primary	Patrol/Test/Inspect	Repair	VI
131740149	K32915	06/23/2013	7:15	06/23/2013	8:36	3	243	81	Animal related	Fuse			VI
131740148	Q67938	06/23/2013	7:15	06/23/2013	8:55	1	100	100	Weather	Fuse	Repair		VI
131740170	B62003	06/23/2013	7:21	06/23/2013	8:10	5	245	49	Animal related	Fuse	Replace - Same Size		I
131740171	F10002	06/23/2013	7:30	06/23/2013	9:00	1	90	90	Overhead equipment	Fuse	Replace - Same Size		III
131740172	S34527	06/23/2013	7:31	06/23/2013	8:52	1	81	81	Animal related	Overhead Transformer	Switch/Reset		VI
131740173	T05539	06/23/2013	7:33	06/23/2013	7:57	1	24	24	Animal related	Transformer Fuse			VI
131740174	R48166	06/23/2013	7:34	06/23/2013	8:50	1	76	76	Overhead equipment	Disconnect Switch	Replace - Same Size	No Work Required	IV
131740178	R16511	06/23/2013	7:37	06/23/2013	9:10	1	93	93	Animal related	Transformer Fuse	Replace - Same Size	No Work Required	I
131740212	P05826	06/23/2013	7:52	06/23/2013	9:58	7	882	126	Weather	Lightning Arrestor	Replace - Same Size		V
131740192	V37509	06/23/2013	7:55	06/23/2013	9:13	1	78	78	Animal related	Transformer Fuse	Replace - Same Size		II
131740205	S88503	06/23/2013	8:05	06/23/2013	9:18	44	3212	73	Animal related	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
131740218	M05360	06/23/2013	8:08	06/23/2013	9:07	39	2301	59	Tree related-tree broken	Tree	Remove	Remove	V
131740210	Q16867	06/23/2013	8:14	06/23/2013	10:13	1	119	119	Tree related-tree broken	Overhead Service	Repair		V
131740216	303004	06/23/2013	8:20	06/23/2013	9:28	1	68	68	Overhead equipment	Overhead Transformer	Switch/Reset		VI
131740220	P19395	06/23/2013	8:28	06/23/2013	10:31	1	123	123	Overhead equipment	Transformer Fuse	Repair		V
131740229	L93133	06/23/2013	8:37	06/23/2013	10:19	1	102	102	Tree related-tree broken	Fuse	Replace - Same Size		VI
131740241	J46180	06/23/2013	8:38	06/23/2013	12:25	23	5221	227	Animal related	Overhead Primary		Repair	III
131740311	Y01524	06/23/2013	8:39	06/23/2013	10:46	4	508	127	Overhead equipment	Lightning Arrestor	Cut in Clear	Repair	IV
131740264	Y01524	06/23/2013	8:39	06/23/2013	10:11	8	736	92	Overhead equipment	Lightning Arrestor		Replace - Same Size	IV
131740268	F03003	06/23/2013	8:40	06/23/2013	9:49	4	276	69	Animal related	Fuse	Replace - Same Size		III
131740238	J34356	06/23/2013	8:44	06/23/2013	9:31	1	47	47	Weather	Transformer Fuse	Replace - Same Size	Replace - Same Size	V
131740243	U12540	06/23/2013	8:48	06/23/2013	9:54	2	132	66	Animal related	Fuse	Replace - Same Size		II
131740251	U73583	06/23/2013	9:02	06/23/2013	10:30	1	88	88	Tree related-tree contact	Tree	Trim		II
131740253	S92559	06/23/2013	9:04	06/23/2013	10:32	1	88	88	Overhead equipment	Overhead Service	Tie/Tighten	Advise Customer	VI
131740269	B46001	06/23/2013	9:26	06/23/2013	10:07	1	41	41	Overhead equipment	Connector	Replace - Same Size		I
131740278	R02121	06/23/2013	9:39	06/23/2013	11:00	1	81	81	Overhead equipment	Fuse	Repair		VI
131740316	P20930	06/23/2013	10:16	06/23/2013	14:36	1	260	260	Animal related	Fuse		Patrol/Test/Inspect	VI
131740334	T23528	06/23/2013	10:36	06/23/2013	11:33	1	57	57	Animal related	Fuse	Replace - Same Size		VI
131740337	K08909	06/23/2013	10:39	06/23/2013	11:24	1	45	45	Animal related	Transformer Fuse			VI
131740369	S61531	06/23/2013	11:11	06/23/2013	12:52	28	2828	101	Animal related	Disconnect Switch	Replace - Same Size	Replace - Same Size	VI
131740374	303001	06/23/2013	11:20	06/23/2013	13:00	1	100	100	Tree related-tree contact	Tree	Trim		VI
131740376	R28870	06/23/2013	11:24	06/23/2013	11:50	8	208	26	Animal related	Transformer Fuse	Replace - Same Size		V

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
131740386	P54828	06/23/2013	11:30	06/23/2013	12:57	18	1566	87	Overhead equipment	Fuse	Replace - Same Size		V
131740406	M78325	06/23/2013	11:50	06/23/2013	12:46	3	168	56	Animal related	Transformer Fuse	Replace - Same Size	Replace - Same Size	V
131740411	K69117	06/23/2013	11:54	06/23/2013	13:05	1	71	71	Tree related-tree broken	Overhead Service			IV
131740435	L99392	06/23/2013	12:23	06/23/2013	16:30	1	247	247	Weather	Fuse	Replace - Same Size		V
131740442	V76001	06/23/2013	12:28	06/23/2013	14:01	1	93	93	Overhead equipment	Connector	Repair		II
131740444	P19395	06/23/2013	12:31	06/23/2013	18:45	1	374	374	Weather	Overhead Transformer		Replace - Same Size	V
131740450	J88166	06/23/2013	12:34	06/23/2013	15:29	39	6825	175	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	VI
131740471	X75573	06/23/2013	12:48	06/23/2013	13:46	16	928	58	Overhead equipment	Fuse	Repair		IV
131740660	P83710	06/23/2013	12:59	06/23/2013	15:00	3	363	121	Overhead equipment	Fuse	Replace - Same Size	No Work Required	I
131740631	V69546	06/23/2013	13:34	06/23/2013	15:02	1	88	88	Overhead equipment	Transformer Fuse	Replace - Same Size		II
131740635	L99392	06/23/2013	13:37	06/23/2013	16:17	1	160	160	Weather	Fuse	Replace - Same Size	Replace - Same Size	V
131740652	L46810	06/23/2013	13:55	06/23/2013	14:55	1	60	60	Overhead equipment	Meter	Replace - Same Size	No Work Required	V
131740655	X62032	06/23/2013	14:01	06/23/2013	15:08	3	201	67	Weather	Transformer Fuse	Replace - Same Size		IV
131740665	J08205	06/23/2013	14:08	06/23/2013	17:34	1	206	206	Weather	Transformer Fuse	Replace - Same Size		I
131740698	P47120	06/23/2013	14:10	06/23/2013	15:27	332	25564	77	Animal related	Recloser	Replace - Same Size		I
131740687	J08207	06/23/2013	14:16	06/23/2013	18:56	1	280	280	Weather	Overhead Transformer	Replace - Same Size	Replace - Same Size	I
131740693	P44324	06/23/2013	14:19	06/23/2013	15:46	1	87	87	Weather	Fuse	Replace - Same Size		I
131740700	P18103	06/23/2013	14:21	06/23/2013	16:20	1	119	119	Weather	Transformer Fuse			IV
131740719	N60181	06/23/2013	14:43	06/23/2013	15:30	1	47	47	Overhead equipment	Transformer Fuse	Replace - Same Size	Patrol/Test/Inspect	I
131740722	Y37010	06/23/2013	14:47	06/23/2013	15:55	9	612	68	Tree related-tree broken	Overhead Secondary	Repair		IV
131740727	T06504	06/23/2013	14:47	06/23/2013	17:20	33	5049	153	Tree related-tree broken	Overhead Primary	Repair		VI
131740724	T08502	06/23/2013	14:49	06/23/2013	20:44	3	1065	355	Tree related-tree broken	Overhead Service	Patrol/Test/Inspect	Repair	VI
131740757	S28552	06/23/2013	15:17	06/23/2013	16:30	1	73	73	Weather	Transformer Fuse	Replace - Same Size	Replace - Same Size	VI
131740794	U39541	06/23/2013	15:25	06/23/2013	21:13	29	10092	348	Tree related-tree broken	Overhead Primary	Repair		II
131740773		06/23/2013	15:29	06/23/2013	16:19	1	50	50	Unknown	Transformer Fuse	Replace - Same Size		III
131740778	B25001	06/23/2013	15:31	06/23/2013	23:25	2	948	474	Weather	Overhead Transformer	Repair		I
131740800	A73002	06/23/2013	15:39	06/23/2013	23:17	1	458	458	Weather	Disconnect Switch	Replace - Same Size		I
131740940	D16001	06/23/2013	15:44	06/23/2013	18:28	705	115620	164	Underground equipment	Underground Primary	Switch/Reset	Repair	I
131740944	D16002	06/23/2013	15:44	06/23/2013	18:56	835	160320	192	Underground equipment	Underground Primary	Switch/Reset	Repair	I
131740817	V23001	06/23/2013	15:45	06/23/2013	18:00	31	4185	135	Tree related-tree broken	Overhead Primary	Repair		II
131740907	B77001	06/23/2013	15:48	06/23/2013	23:50	220	106040	482	Unknown	Fuse	Patrol/Test/Inspect		I
131740845	B44002	06/23/2013	15:50	06/23/2013	21:45	1	355	355	Tree related-tree broken	Overhead Service	Patrol/Test/Inspect	Repair	I
131750190	A42005	06/23/2013	15:50	06/24/2013	1:49	139	83261	599	Weather				I
131741052	D36002	06/23/2013	15:53	06/24/2013	0:25	42	21504	512	Overhead equipment	Overhead Primary	Patrol/Test/Inspect		I
131740911	B77001	06/23/2013	15:54	06/23/2013	21:06	1	312	312	Tree related-tree broken	Overhead Service	Replace - Same Size		I
131740948	V23592	06/23/2013	15:54	06/23/2013	19:40	12	2712	226	Weather	Fuse	Replace - Same Size		II
131740995	B44002	06/23/2013	15:58	06/24/2013	13:39	47	61147	1301	Tree related-tree broken	Overhead Primary		Repair	I
131743663	B08003	06/23/2013	15:59	06/24/2013	2:53	6	3924	654	Tree related-tree contact	Overhead Primary	Repair		I
131741080	B44002	06/23/2013	16:00	06/23/2013	19:22	57	11514	202	Unknown	Fuse	Replace - Same Size		I
131740921	B44002	06/23/2013	16:00	06/24/2013	11:24	41	47724	1164	Tree related-tree broken	Pole	Replace - Same Size		I
131743082	B44002	06/23/2013	16:01	06/24/2013	6:25	132	114048	864	Tree related-tree broken	Overhead Primary	Repair		I
131741193	D35002	06/23/2013	16:01	06/23/2013	19:29	24	4992	208	Overhead equipment	Fuse	Repair	Replace - New Size	I
131743547	D36001	06/23/2013	16:04	06/23/2013	22:35	113	44183	391	Overhead equipment	Overhead Primary	Repair		I
131741252	B28006	06/23/2013	16:08	06/23/2013	22:22	176	65824	374	Tree related-tree broken	Overhead Primary	Patrol/Test/Inspect	Repair	I
131741006	D81001	06/23/2013	16:09	06/23/2013	20:00	37	8547	231	Overhead equipment	Disconnect Switch	Replace - Same Size		I
131741009	B77003	06/23/2013	16:10	06/24/2013	0:45	1	515	515	Tree related-tree broken	Overhead Service	Patrol/Test/Inspect	Repair	I
131845185	D36001	06/23/2013	16:10	06/23/2013	21:47	113	38081	337	Overhead equipment	Overhead Primary	Repair		I
131742117	B93003	06/23/2013	16:12	06/24/2013	6:27	2	1710	855	Overhead equipment	Overhead Transformer	Replace - Same Size		I
131741045	D36002	06/23/2013	16:14	06/24/2013	0:40	1	506	506	Tree related-tree broken	Overhead Service	Repair		I
131741137	B93003	06/23/2013	16:14	06/23/2013	18:05	12	1332	111	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	I
131741047	T06504	06/23/2013	16:15	06/23/2013	19:55	1	220	220	Weather	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
131741106	D33142	06/23/2013	16:15	06/23/2013	22:48	14	5502	393	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect		I
131741054	D35002	06/23/2013	16:16	06/23/2013	17:30	1	74	74	Tree related-tree broken	Overhead Service	Repair		I
131740969	D81001	06/23/2013	16:17	06/23/2013	21:42	1	325	325	Tree related-tree broken	Overhead Service	Repair		I
131741099	B44002	06/23/2013	16:17	06/24/2013	12:05	21	24948	1188	Tree related-tree broken	Overhead Primary	Patrol/Test/Inspect	Repair	I
131740774	T09530	06/23/2013	16:18	06/23/2013	18:30	1	132	132	Tree related-tree broken	Overhead Primary	Patrol/Test/Inspect	Repair	VI

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
131741067	S21529	06/23/2013	16:21	06/23/2013	17:50	1	89	89	Overhead equipment	Transformer Fuse	Replace - Same Size	Replace - Same Size	VI
131741091	B93002	06/23/2013	16:22	06/24/2013	1:45	20	11260	563	Overhead equipment	Tree	Patrol/Test/Inspect	Remove	I
131741079	B93002	06/23/2013	16:23	06/24/2013	4:15	1	712	712	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	I
131741089	K76541	06/23/2013	16:25	06/23/2013	17:57	1	92	92	Tree related-tree broken	Overhead Service	Reconnect		IV
131741098	A24002	06/23/2013	16:26	06/23/2013	19:37	1	191	191	Overhead equipment	Pole			I
131741103	B21003	06/23/2013	16:27	06/23/2013	18:25	1	118	118	Overhead equipment	Overhead Primary	Cut in Clear		I
131741109	B44002	06/23/2013	16:27	06/24/2013	1:53	18	10188	566	Overhead equipment	Fuse	Replace - Same Size		I
131741110	N05172	06/23/2013	16:29	06/23/2013	19:20	1	171	171	Weather	Overhead Transformer	Replace - Same Size	Replace - Urgent	I
131741114	D35003	06/23/2013	16:31	06/23/2013	20:16	1	225	225	Unknown	Fuse	Repair		I
131741117	S43501	06/23/2013	16:32	06/23/2013	19:47	1	195	195	Overhead equipment	Overhead Transformer	Replace - Same Size	Replace - Same Size	VI
131741118	P73160	06/23/2013	16:33	06/23/2013	18:15	1	102	102	Weather	Fuse	Replace - Same Size		VI
131741126	U35511	06/23/2013	16:33	06/23/2013	18:35	15	1830	122	Tree related-tree broken	Disconnect Switch	Replace - Same Size		II
131741386	D35003	06/23/2013	16:42	06/23/2013	20:11	10	2090	209	Overhead equipment	Fuse	Repair		I
131741135	U14528	06/23/2013	16:42	06/23/2013	18:13	63	5733	91	Overhead equipment	Overhead Primary	Repair		II
131741141	K31120	06/23/2013	16:44	06/23/2013	18:00	1	76	76	Weather	Transformer Fuse	Replace - Same Size		I
131741153	U35511	06/23/2013	16:44	06/23/2013	19:40	24	4224	176	Tree related-tree broken	Overhead Primary	No Work Required		II
131741146	Q14392	06/23/2013	16:45	06/23/2013	22:01	1	316	316	Weather	Underground Connector	Replace - Same Size	Repair	I
131741097	B08003	06/23/2013	16:47	06/23/2013	22:50	34	12342	363	Overhead equipment	Overhead Primary		Repair	I
131741166	K07320	06/23/2013	16:50	06/23/2013	17:39	6	294	49	Animal related	Fuse	Replace - Same Size		I
131741179	B44001	06/23/2013	16:55	06/24/2013	9:35	1	1000	1000	Tree related-tree broken	Tree	Patrol/Test/Inspect	Repair	I
131741302	R95520	06/23/2013	16:55	06/23/2013	20:22	889	184023	207	Weather	Switchgear	Switch/Reset	No Work Required	I
131742767	M78325	06/23/2013	16:57	06/23/2013	20:00	252	46116	183	Overhead equipment	Pole			V
131741251	M78325	06/23/2013	16:57	06/23/2013	19:25	797	117956	148	Weather	Disconnect Switch	Patrol/Test/Inspect	Patrol/Test/Inspect	V
131741381	V03562	06/23/2013	17:01	06/23/2013	21:00	155	37045	239	Overhead equipment	Recloser	Repair		II
131741334	D81001	06/23/2013	17:03	06/23/2013	19:28	39	5655	145	Tree related-tree broken	Tree	Remove		I
131742676	R68903	06/23/2013	17:07	06/23/2013	20:30	41	8323	203	Weather	Transformer Fuse	Replace - Same Size		I
131741293		06/23/2013	17:12	06/23/2013	18:10	1	58	58	Weather	Transformer Fuse	Replace - New Size		IV
131741299	D33142	06/23/2013	17:13	06/24/2013	0:19	4	1704	426	Overhead equipment	Transformer Fuse	Replace - Same Size	Patrol/Test/Inspect	I
131741311	V95586	06/23/2013	17:15	06/23/2013	23:44	1	389	389	Tree related-tree broken	Overhead Secondary	Repair		II
131741340	V25513	06/23/2013	17:21	06/23/2013	19:40	1	139	139	Weather	Overhead Transformer			II
131741347	Y31589	06/23/2013	17:23	06/23/2013	18:25	1	62	62	Unknown	Fuse	Repair		IV
131742954	V03734	06/23/2013	17:26	06/23/2013	20:07	1	161	161	Weather	Other	Patrol/Test/Inspect		II
131741615	P14421	06/23/2013	17:31	06/23/2013	18:40	3627	250263	69	Overhead equipment				V
131741409	S43511	06/23/2013	17:34	06/23/2013	18:35	3	183	61	Overhead equipment	Transformer Fuse	Replace - Same Size		VI
131741443	D81001	06/23/2013	17:36	06/23/2013	21:09	1	213	213	Tree related-tree broken	Overhead Service	Repair		I
131741676	V03734	06/23/2013	17:36	06/23/2013	19:40	941	116684	124	Overhead equipment				II
131741584	L23146	06/23/2013	17:41	06/23/2013	19:45	1	124	124	Tree related-tree broken	Overhead Service			III
131741630	M81402	06/23/2013	17:44	06/23/2013	23:14	1	330	330	Tree related-tree broken	Overhead Service	Patrol/Test/Inspect	Repair	V
131741667	U84587	06/23/2013	17:46	06/23/2013	19:06	1	80	80	Transmission outage	Underground Primary			II
131741647	M81404	06/23/2013	17:46	06/24/2013	2:34	1	528	528	Tree related-tree broken	Overhead Service	Repair	Repair	V
131755386	M78325	06/23/2013	17:47	06/24/2013	15:45	54	71172	1318	Weather	Pole			V
131742168	H24471	06/23/2013	17:48	06/23/2013	18:40	2680	139360	52	Overhead equipment				V
131742180	K66320	06/23/2013	17:48	06/23/2013	18:30	4757	199794	42	Overhead equipment				V
131743577	M81405	06/23/2013	17:48	06/23/2013	23:15	48	15696	327	Overhead equipment	Crossarm			V
131750242	M78325	06/23/2013	17:51	06/24/2013	12:56	48	54960	1145	Weather	Pole			V
131741740	M81405	06/23/2013	17:52	06/23/2013	21:57	1	245	245	Tree related-tree contact	Overhead Service	Cut in Clear		V
131743020	61072	06/23/2013	18:07	06/23/2013	21:52	3440	774000	225	Unknown				VI
131742150	L90359	06/23/2013	18:08	06/23/2013	23:00	2	584	292	Weather	Fuse	Replace - Same Size	No Work Required	V
131742207	342004	06/23/2013	18:09	06/24/2013	9:30	14	12894	921	Tree related-tree broken	Tree	Patrol/Test/Inspect		VI
131743257	Q10702	06/23/2013	18:10	06/23/2013	20:10	129	15480	120	Weather				V
131742784	M05368	06/23/2013	18:14	06/23/2013	20:47	189	28917	153	Weather	Fuse	Replace - Same Size		V
131742606	61075	06/23/2013	18:17	06/24/2013	1:42	2368	1053760	445	Tree related-tree broken				VI
131743327	342001	06/23/2013	18:17	06/24/2013	9:20	20	18060	903	Tree related-tree broken	Overhead Secondary	Patrol/Test/Inspect		VI
131742224	K43386	06/23/2013	18:17	06/23/2013	22:24	68	16796	247	Weather	Fuse	Patrol/Test/Inspect	Replace - Same Size	V
131742298	K46422	06/23/2013	18:17	06/23/2013	23:17	81	24300	300	Weather				V
131742231	L90359	06/23/2013	18:18	06/23/2013	23:00	1	282	282	Weather	Fuse	Replace - Same Size		V

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
131742242	342001	06/23/2013	18:20	06/24/2013	6:56	1	756	756	Overhead equipment	Overhead Service		Repair	VI
131742257	K55397	06/23/2013	18:20	06/24/2013	1:25	100	42500	425	Tree related-tree broken	Overhead Primary			V
131742264	Y06573	06/23/2013	18:23	06/23/2013	19:40	1	77	77	Animal related	Animal Guard	Replace - New Size		IV
131742295	342001	06/23/2013	18:25	06/24/2013	6:57	1	752	752	Tree related-tree broken	Tree	Patrol/Test/Inspect	Remove	VI
131742310	334001	06/23/2013	18:26	06/24/2013	3:27	1	541	541	Tree related-tree contact	Overhead Service			VI
131742309	332002	06/23/2013	18:26	06/24/2013	3:49	1	563	563	Tree related-tree contact	Other			VI
131742338	B77003	06/23/2013	18:27	06/24/2013	3:38	1	551	551	Overhead equipment	Fuse	Patrol/Test/Inspect	Replace - Same Size	I
131742336	H10843	06/23/2013	18:27	06/23/2013	19:56	1	89	89	Weather	Fuse	Replace - Same Size		V
131742358	IP9009	06/23/2013	18:27	06/24/2013	6:00	38	26334	693	Overhead equipment	Overhead Secondary		Repair	VI
131742425	R04412	06/23/2013	18:29	06/23/2013	19:31	20	1240	62	Weather				V
131742384	N50331	06/23/2013	18:30	06/23/2013	19:53	1	83	83	Tree related-tree broken	Overhead Service	Repair		II
131743613	R23334	06/23/2013	18:30	06/23/2013	23:34	3	912	304	Weather	Fuse	Replace - Same Size		V
131742382	M81402	06/23/2013	18:30	06/24/2013	0:57	1	387	387	Tree related-tree broken	Tree	Trim	Trim	V
131742407	H19877	06/23/2013	18:32	06/23/2013	19:00	1	28	28	Weather	Overhead Service	Advise Customer	No Work Required	V
131742468	R04412	06/23/2013	18:32	06/23/2013	19:35	21	1323	63	Weather	Fuse	Replace - Same Size		V
131742416	K11376	06/23/2013	18:33	06/23/2013	23:04	9	2439	271	Tree related-tree broken	Fuse	Replace - Same Size	Replace - Same Size	V
131742437	X29547	06/23/2013	18:34	06/23/2013	19:30	1	56	56	Animal related	Fuse	Replace - Same Size		IV
131742480	R04412	06/23/2013	18:34	06/23/2013	19:31	20	1140	57	Weather				V
131742584	N86225	06/23/2013	18:35	06/24/2013	0:50	23	8625	375	Tree related-tree broken	Fuse	Replace - Same Size	Patrol/Test/Inspect	VI
131743228	337003	06/23/2013	18:36	06/24/2013	6:40	5	3620	724	Tree related-tree broken	Tree	Trim		VI
131742473	J76804	06/23/2013	18:37	06/23/2013	21:21	2	328	164	Weather	Transformer Fuse	Remove	Replace - Same Size	V
131742514	347001	06/23/2013	18:37	06/24/2013	8:20	25	20575	823	Weather	Overhead Transformer		Replace - Same Size	VI
131742478	B44001	06/23/2013	18:38	06/24/2013	9:00	1	862	862	Tree related-tree broken	Overhead Service	Replace - Same Size		I
131743310	341002	06/23/2013	18:39	06/24/2013	4:15	22	12672	576	Overhead equipment	Transformer Fuse			VI
131743153	K11376	06/23/2013	18:40	06/24/2013	0:15	81	27135	335	Weather	Other			V
131742351	K05253	06/23/2013	18:42	06/23/2013	20:52	1	130	130	Tree related-tree broken	Overhead Service			VI
131742531	303007	06/23/2013	18:44	06/24/2013	3:41	12	6444	537	Tree related-tree contact	Overhead Secondary		Repair	VI
131742550	P72320	06/23/2013	18:46	06/23/2013	20:00	1	74	74	Weather				V
131742602	K52401	06/23/2013	18:48	06/23/2013	23:32	15	4260	284	Tree related-tree contact	Overhead Primary	Patrol/Test/Inspect	Repair	V
131742601	J87119	06/23/2013	18:51	06/23/2013	22:18	1	207	207	Tree related-tree broken	Overhead Service	Repair		VI
131742634	Q21293	06/23/2013	18:54	06/24/2013	2:18	1	444	444	Underground equipment	Switchgear	Patrol/Test/Inspect	Patrol/Test/Inspect	VI
131742679	J83140	06/23/2013	19:00	06/24/2013	1:23	3	1149	383	Weather	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
131743169	61071	06/23/2013	19:02	06/24/2013	1:42	3688	1475200	400	Overhead equipment				VI
131741694	M81402	06/23/2013	19:06	06/24/2013	2:25	1	439	439	Tree related-tree broken	Overhead Service	Repair		V
131742729	342003	06/23/2013	19:06	06/24/2013	6:49	15	10545	703	Tree related-tree contact	Overhead Primary			VI
131742740	B57002	06/23/2013	19:09	06/23/2013	20:44	1	95	95	Tree related-tree broken	Overhead Service	Repair		I
131742738	R68900	06/23/2013	19:09	06/23/2013	21:10	1	121	121	Weather	Fuse	Replace - Same Size		I
131742742	303004	06/23/2013	19:09	06/24/2013	5:45	1	636	636	Tree related-tree broken	Overhead Service			VI
131742751	J18268	06/23/2013	19:12	06/24/2013	2:30	1	438	438	Tree related-tree broken	Tree	Trim	Replace - Same Size	VI
131742757	311001	06/23/2013	19:13	06/24/2013	4:57	5	2920	584	Weather	Fuse	Replace - Same Size		VI
131742768	J18268	06/23/2013	19:15	06/23/2013	22:09	1	174	174	Weather	Transformer Fuse	Replace - Same Size		VI
131742838	335003	06/23/2013	19:17	06/24/2013	5:42	1	625	625	Tree related-tree broken	Overhead Service			VI
131750155	J86118	06/23/2013	19:19	06/24/2013	7:12	23	16399	713	Tree related-tree contact	Overhead Secondary	Patrol/Test/Inspect	Repair	VI
131742817	R71286	06/23/2013	19:20	06/24/2013	12:15	5	5075	1015	Overhead equipment	Overhead Primary			VI
131742810	306003	06/23/2013	19:22	06/24/2013	5:40	1	618	618	Overhead equipment	Connector	Repair		VI
131742805	J89125	06/23/2013	19:22	06/23/2013	23:59	1	277	277	Tree related-tree broken	Overhead Service	Repair	Reconnect	VI
131742822	K46388	06/23/2013	19:24	06/23/2013	23:18	1	234	234	Weather	Pole	Patrol/Test/Inspect	Replace - Same Size	V
131743484	R94269	06/23/2013	19:25	06/23/2013	23:55	6	1620	270	Weather	Fuse	Replace - Same Size		VI
131743039	J83138	06/23/2013	19:25	06/23/2013	23:38	14	3542	253	Weather	Fuse	Patrol/Test/Inspect	Repair	VI
131742831	Q36410	06/23/2013	19:27	06/23/2013	22:26	1	179	179	Tree related-tree broken	Overhead Service	Replace - New Size	Repair	I
131742928	P42229	06/23/2013	19:27	06/23/2013	23:32	188	46060	245	Weather	Fuse	Patrol/Test/Inspect		VI
131742837	P82291	06/23/2013	19:28	06/24/2013	7:23	1	715	715	Weather	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
131742896	Q82907	06/23/2013	19:29	06/24/2013	2:09	14	5600	400	Weather	Transformer Fuse	Replace - Same Size		VI
131742855	Q36410	06/23/2013	19:31	06/23/2013	22:24	1	173	173	Tree related-tree broken	Overhead Service	Replace - Same Size	Repair	I
131742877	Q69926	06/23/2013	19:33	06/23/2013	22:42	35	6615	189	Tree related-tree broken	Fuse	Replace - Same Size	Patrol/Test/Inspect	VI
131742881	J89126	06/23/2013	19:35	06/24/2013	5:46	1	611	611	Weather	Overhead Transformer	Replace - Same Size	Replace - Same Size	VI

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
131743137		06/23/2013	19:35	06/23/2013	19:55	82	1640	20	Unknown				V
131743388	M81402	06/23/2013	19:35	06/23/2013	21:52	1179	161523	137	Unknown				V
131742939	335002	06/23/2013	19:38	06/24/2013	10:40	5	4510	902	Overhead equipment	Tree	Trim		VI
131743001	Q69926	06/23/2013	19:42	06/24/2013	2:42	1	420	420	Tree related-tree broken	Overhead Transformer		Trim	VI
131743280	M78325	06/23/2013	19:42	06/23/2013	21:45	16	1968	123	Weather	Fuse	Replace - Same Size		V
131750099	345002	06/23/2013	19:44	06/24/2013	7:04	2	1360	680	Tree related-tree broken	Overhead Service			VI
131743042	Q95247	06/23/2013	19:44	06/24/2013	0:02	1	258	258	Weather	Fuse			VI
131743078		06/23/2013	19:48	06/24/2013	2:39	1	411	411	Weather	Transformer Fuse	Replace - Same Size		I
131743358	K32916	06/23/2013	19:49	06/23/2013	21:50	5	605	121	Tree related-tree broken	Tree			VI
131743105	K46388	06/23/2013	19:51	06/23/2013	22:45	1	174	174	Tree related-tree broken	Overhead Service	Repair		V
131743256	K32915	06/23/2013	19:54	06/23/2013	21:05	5	355	71	Tree related-tree broken	Overhead Transformer			VI
131742714	K11376	06/23/2013	19:54	06/24/2013	5:44	39	23010	590	Weather	Pole	Patrol/Test/Inspect	Patrol/Test/Inspect	V
131743172	Q18244	06/23/2013	19:55	06/23/2013	23:00	19	3515	185	Weather	Fuse			VI
131743275	P20930	06/23/2013	19:59	06/24/2013	2:35	36	14256	396	Overhead equipment	Fuse	Replace - Same Size	Repair	VI
131743174	B77003	06/23/2013	20:01	06/24/2013	3:44	1	463	463	Tree related-tree broken	Overhead Service	Patrol/Test/Inspect	Repair	I
131743207	R10901	06/23/2013	20:02	06/23/2013	21:30	1	88	88	Tree related-tree broken	Tree	Cut in Clear	Repair	VI
131743210	K69117	06/23/2013	20:03	06/23/2013	20:19	1	16	16	Tree related-tree broken	Overhead Service			IV
131750101	H00163	06/23/2013	20:08	06/24/2013	0:35	22	5874	267	Underground equipment				III
131743283	M81402	06/23/2013	20:15	06/23/2013	22:10	1	115	115	Tree related-tree contact	Other			V
131743285		06/23/2013	20:16	06/24/2013	1:59	1	343	343	Weather				VI
131743292	A24002	06/23/2013	20:17	06/23/2013	20:31	1	14	14	Overhead equipment	Pole			I
131741677	M78325	06/23/2013	20:17	06/24/2013	4:35	75	37350	498	Weather	Pole	Patrol/Test/Inspect	Replace - New Size	V
131743307		06/23/2013	20:21	06/24/2013	12:52	1	991	991	Tree related-tree contact	Tree	Trim		VI
131743316	325008	06/23/2013	20:24	06/24/2013	3:30	1	426	426	Weather				VI
131743575	J20931	06/23/2013	20:27	06/23/2013	23:16	13	2197	169	Weather	Overhead Primary			VI
131743324	R02121	06/23/2013	20:29	06/23/2013	21:35	1	66	66	Overhead equipment	Fuse	Repair		VI
131743343	A24002	06/23/2013	20:34	06/23/2013	20:39	1	5	5	Overhead equipment	Pole			I
131743408	Q64919	06/23/2013	20:34	06/23/2013	23:58	5	1020	204	Weather	Fuse	Repair		VI
131743342	Q64919	06/23/2013	20:34	06/23/2013	22:20	1	106	106	Weather	Customer Equipment	Cut in Clear		VI
131743350		06/23/2013	20:35	06/23/2013	23:37	1	182	182	Tree related-tree broken	Overhead Service	Repair	Repair	VI
131743353	349001	06/23/2013	20:36	06/24/2013	1:45	1	309	309	Overhead equipment				VI
131743385	J86108	06/23/2013	20:40	06/24/2013	7:04	24	14976	624	Tree related-tree contact	Tree		Trim	VI
131743376	K69117	06/23/2013	20:41	06/23/2013	21:20	1	39	39	Tree related-tree broken	Overhead Service			IV
131743381	346003	06/23/2013	20:43	06/24/2013	2:10	15	4905	327	Tree related-tree contact	Overhead Primary			VI
131743627	S24598	06/23/2013	20:50	06/24/2013	4:45	131	62225	475	Tree related-tree broken	Crossarm	Replace - Same Size	Replace - Same Size	VI
131743578	S24598	06/23/2013	20:50	06/23/2013	22:55	342	42750	125	Tree related-tree broken	Crossarm	Patrol/Test/Inspect	Replace - Same Size	VI
131743397	A24002	06/23/2013	20:51	06/23/2013	21:12	1	21	21	Overhead equipment	Pole			I
131743460	S24597	06/23/2013	20:51	06/23/2013	22:55	350	43400	124	Tree related-tree broken				VI
131743451	Q67938	06/23/2013	20:59	06/23/2013	23:21	1	142	142	Tree related-tree broken	Overhead Service	Repair		VI
131743464	Q37370	06/23/2013	21:02	06/24/2013	1:16	1	254	254	Tree related-tree broken	Overhead Primary	Tie/Tighten	Repair	I
131743462	K67924	06/23/2013	21:02	06/24/2013	1:08	1	246	246	Weather	Fuse	Replace - Same Size		VI
131743698	Q37370	06/23/2013	21:11	06/24/2013	1:14	3	729	243	Tree related-tree broken	Overhead Primary	Tie/Tighten	Repair	I
131743491	R94269	06/23/2013	21:11	06/24/2013	3:55	6	2424	404	Overhead equipment	Fuse	Replace - Same Size		VI
131743528	R95520	06/23/2013	21:16	06/24/2013	0:24	56	10528	188	Weather	Fuse	Replace - Same Size	No Work Required	I
131742610	D36001	06/23/2013	21:17	06/23/2013	21:23	1112	6672	6	Overhead equipment	Overhead Primary	Patrol/Test/Inspect		I
131743499	S66578	06/23/2013	21:19	06/23/2013	22:55	2	192	96	Tree related-tree broken	Overhead Service	Cut in Clear	Cut in Clear	VI
131743514	K11376	06/23/2013	21:23	06/24/2013	0:30	1	187	187	Weather	Overhead Transformer		Replace - Same Size	V
131743526	R95520	06/23/2013	21:27	06/24/2013	1:09	1	222	222	Weather	Transformer Fuse	Replace - Same Size	No Work Required	I
131743678	R95520	06/23/2013	21:30	06/24/2013	0:28	6	1068	178	Weather	Fuse	Replace - Same Size	No Work Required	I
131743537	J83140	06/23/2013	21:33	06/24/2013	0:51	1	198	198	Tree related-tree broken	Overhead Service	Patrol/Test/Inspect	Repair	VI
131743542	J99121	06/23/2013	21:38	06/24/2013	4:45	1	427	427	Tree related-tree broken	Overhead Service	Patrol/Test/Inspect	Repair	VI
131743548	311001	06/23/2013	21:40	06/24/2013	4:57	1	437	437	Overhead equipment	Fuse			VI
131743606	325004	06/23/2013	21:57	06/24/2013	4:09	40	14880	372	Transmission outage				VI
131743583	Q82906	06/23/2013	22:09	06/24/2013	5:35	1	446	446	Tree related-tree broken	Tree			VI
131743600	325004	06/23/2013	22:18	06/24/2013	3:30	1	312	312	Weather				VI
131743631	M81405	06/23/2013	22:35	06/24/2013	2:58	3	789	263	Tree related-tree broken	Tree	Trim	Trim	V

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
131743660	J87150	06/23/2013	22:51	06/24/2013	14:53	14	13468	962	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	VI
131750192	B28006	06/23/2013	22:55	06/24/2013	2:25	44	9240	210	Weather	Jumper	Repair		I
131743674	D33142	06/23/2013	23:04	06/24/2013	7:00	5	2380	476	Overhead equipment	Overhead Transformer	Replace - Same Size		I
131752875	B77003	06/23/2013	23:10	06/24/2013	3:40	89	24030	270	Tree related-tree broken	Tree	Patrol/Test/Inspect		I
131743692	P82291	06/23/2013	23:12	06/24/2013	1:26	1	134	134	Weather	Transformer Fuse	Replace - Same Size		VI
131743699	S88503	06/23/2013	23:27	06/24/2013	4:20	1	293	293	Underground equipment	Underground Primary	Repair	Repair	VI
131743701	K31120	06/23/2013	23:33	06/24/2013	5:42	1	369	369	Tree related-tree broken	Overhead Primary	Repair	Repair	I
131750113	X66582	06/23/2013	23:35	06/24/2013	5:44	66	24354	369	Tree related-tree broken	Overhead Primary	Remove		IV
131743884	Q09377	06/23/2013	23:45	06/24/2013	3:30	5056	1137600	225	Unknown				III
131750094	J83138	06/24/2013	0:06	06/24/2013	0:39	1	33	33	Overhead equipment	Transformer Fuse	Replace - Same Size		VI
131752870	P49183	06/24/2013	0:36	06/24/2013	6:45	8	2952	369	Weather	Overhead Transformer	Replace - Same Size		I
131750125	P49183	06/24/2013	0:36	06/24/2013	3:29	87	15051	173	Weather	Fuse	Replace - Same Size		I
131750127	T08502	06/24/2013	0:45	06/24/2013	5:45	1	300	300	Weather	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	VI
131750156	R95520	06/24/2013	1:14	06/24/2013	5:10	6	1416	236	Tree related-tree broken	Overhead Primary		Repair	I
131750157	K35308	06/24/2013	1:15	06/24/2013	9:05	1	470	470	Overhead equipment	Fuse	Replace - Same Size		III
131750178	61075	06/24/2013	1:49	06/24/2013	2:55	1697	112002	66	Substation equipment				VI
131750174	M36189	06/24/2013	1:53	06/24/2013	4:23	1	150	150	Overhead equipment	Overhead Service	No Work Required		I
131750186	Q04411	06/24/2013	1:54	06/24/2013	9:34	40	18400	460	Underground equipment	Underground Primary	Cut in Clear	Repair	III
131752876	X48716	06/24/2013	2:10	06/24/2013	5:12	1014	184548	182	Tree related-tree broken				IV
131750191	J86118	06/24/2013	2:13	06/24/2013	9:46	1	453	453	Tree related-tree contact	Tree		Trim	VI
131754813	B19002	06/24/2013	2:17	06/24/2013	14:13	4	2864	716	Overhead equipment	Overhead Primary	Repair		I
131753354	B19002	06/24/2013	2:17	06/24/2013	8:25	110	40480	368	Tree related-tree broken	Tree	Remove		I
131750222	J08205	06/24/2013	2:28	06/24/2013	9:34	13	5538	426	Underground equipment	Underground Primary	Repair		I
131750237	R84148	06/24/2013	2:47	06/24/2013	4:05	9	702	78	Unknown	Fuse	Patrol/Test/Inspect	Replace - Same Size	I
131750234	B77003	06/24/2013	2:57	06/24/2013	5:39	1	162	162	Weather	Overhead Service	Repair	Patrol/Test/Inspect	I
131750235	D69008	06/24/2013	2:58	06/24/2013	15:23	1	745	745	Overhead equipment	Tree	Remove		I
131750239	J15302	06/24/2013	3:07	06/24/2013	4:32	1	85	85	Weather	Fuse	Replace - Same Size		I
131752860	J15302	06/24/2013	3:20	06/24/2013	5:37	8	1096	137	Tree related-tree broken	Fuse	Replace - Same Size		I
131752880	J79305	06/24/2013	3:20	06/24/2013	6:28	255	47940	188	Weather	Other	No Work Required	No Work Required	I
131752871	R84148	06/24/2013	3:29	06/24/2013	4:40	1	71	71	Overhead equipment	Fuse	Patrol/Test/Inspect	Replace - Same Size	I
131752882	D16002	06/24/2013	3:40	06/24/2013	14:21	1	641	641	Tree related-tree broken	Overhead Service	Repair		I
131753503	B82002	06/24/2013	3:47	06/24/2013	8:40	98	28714	293	Weather	Overhead Primary	Repair		I
131752887	C40002	06/24/2013	3:48	06/24/2013	10:25	5	1985	397	Overhead equipment				I
131753450	B82002	06/24/2013	3:52	06/24/2013	6:41	62	10478	169	Overhead equipment	Overhead Primary	Patrol/Test/Inspect		I
131752933	N70332	06/24/2013	3:55	06/24/2013	6:52	61	10797	177	Weather	Overhead Primary	Replace - Same Size		I
131752938	B82001	06/24/2013	4:02	06/24/2013	13:38	38	21888	576	Overhead equipment				I
131752954	A91003	06/24/2013	4:11	06/24/2013	6:02	84	9324	111	Weather	Fuse	Replace - Same Size		I
131753955	D32212	06/24/2013	4:12	06/24/2013	13:20	94	51512	548	Tree related-tree broken	Overhead Primary	Replace - Same Size		I
131753116	D32212	06/24/2013	4:12	06/24/2013	8:29	12	3084	257	Weather	Disconnect Switch	Replace - Same Size		I
131752971	D01002	06/24/2013	4:13	06/24/2013	9:20	17	5219	307	Overhead equipment	Fuse	Repair		I
131753165	L43154	06/24/2013	4:19	06/24/2013	6:35	58	7888	136	Weather	Fuse	Replace - Same Size		I
131753437	D32212	06/24/2013	4:25	06/24/2013	7:31	113	21018	186	Overhead equipment	Fuse	Repair		I
131752940	M26161	06/24/2013	4:28	06/24/2013	6:46	1	138	138	Underground equipment	Underground Primary			III
131753079	B21002	06/24/2013	4:29	06/24/2013	10:23	46	16284	354	Overhead equipment	Fuse	Replace - Same Size		I
131753736	D35003	06/24/2013	4:29	06/24/2013	15:33	35	23240	664	Tree related-tree broken	Overhead Primary	Patrol/Test/Inspect		I
131752952	B62003	06/24/2013	4:33	06/24/2013	9:29	25	7400	296	Weather	Fuse	Patrol/Test/Inspect	Replace - New Size	I
131753525	D01002	06/24/2013	4:36	06/24/2013	9:28	21	6132	292	Overhead equipment	Fuse	Repair		I
131753099	K07322	06/24/2013	4:41	06/24/2013	6:22	4	404	101	Weather	Lightning Arrestor	Replace - Same Size		I
131752967	K52400	06/24/2013	4:43	06/24/2013	5:29	1	46	46	Weather	Fuse	Replace - Same Size		V
131753121	N70330	06/24/2013	4:49	06/24/2013	7:24	57	8835	155	Weather	Overhead Primary	Reconnect		I
131752996	B76003	06/24/2013	4:50	06/24/2013	7:00	412	53560	130	Weather	Fuse	Replace - Same Size		I
131753641	B82001	06/24/2013	4:55	06/24/2013	13:37	8	4176	522	Overhead equipment				I
131752988	B27008	06/24/2013	4:55	06/24/2013	11:49	1	414	414	Tree related-tree contact	Tree			I
131753043	B62004	06/24/2013	4:56	06/24/2013	9:05	33	8217	249	Weather	Fuse	Replace - Same Size		I
131753603	B21002	06/24/2013	5:04	06/24/2013	9:15	72	18072	251	Tree related-tree broken	Fuse	Replace - Same Size		I
131753188	D39001	06/24/2013	5:05	06/24/2013	12:48	19	8797	463	Overhead equipment				I

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
131753097	D36002	06/24/2013	5:12	06/24/2013	11:30	8	3024	378	Overhead equipment				I
131755611	A68001	06/24/2013	5:21	06/24/2013	19:15	1	834	834	Overhead equipment	Overhead Transformer	Replace - Same Size	No Work Required	I
131755593	A68001	06/24/2013	5:21	06/24/2013	18:28	16	12592	787	Overhead equipment	Overhead Primary	Repair	Repair	I
131753103	A68001	06/24/2013	5:21	06/24/2013	12:00	58	23142	399	Overhead equipment	Other	No Work Required	No Work Required	I
131753553	A91004	06/24/2013	5:22	06/24/2013	10:07	19	5415	285	Overhead equipment				I
131753082	IP9009	06/24/2013	5:26	06/24/2013	7:05	1	99	99	Overhead equipment	Overhead Secondary	Repair	Repair	VI
131753468	D62074	06/24/2013	5:26	06/24/2013	8:11	3175	523875	165	Overhead equipment				I
131753127	Q80353	06/24/2013	5:31	06/24/2013	8:50	23	4577	199	Tree related-tree broken	Tree	Patrol/Test/Inspect	Remove	V
131753135	S84211	06/24/2013	5:45	06/24/2013	6:40	488	26840	55	Tree related-tree broken				VI
131753660	M07236	06/24/2013	5:47	06/24/2013	9:15	6	1248	208	Weather	Fuse	Replace - Same Size		III
131753170	B61001	06/24/2013	5:51	06/24/2013	10:31	1	280	280	Overhead equipment	Connector	Repair		I
131753168	N54213	06/24/2013	5:51	06/24/2013	8:00	10	1290	129	Animal related	Transformer Fuse	Replace - Same Size		II
131753625	B93002	06/24/2013	5:54	06/24/2013	11:37	373	127939	343	Overhead equipment	Disconnect Switch	Patrol/Test/Inspect	Replace - Same Size	I
131753280	N18210	06/24/2013	6:01	06/24/2013	7:52	24	2664	111	Weather	Fuse	Replace - Same Size		III
131753830	N18211	06/24/2013	6:02	06/24/2013	8:50	13	2184	168	Overhead equipment	Fuse			III
131754749	D28124	06/24/2013	6:10	06/24/2013	15:02	1	532	532	Tree related-tree broken	Tree	Patrol/Test/Inspect	Remove	I
131753364	D28124	06/24/2013	6:10	06/24/2013	11:13	36	10908	303	Tree related-tree contact	Overhead Primary	Patrol/Test/Inspect	Remove	I
131753293	B93002	06/24/2013	6:11	06/24/2013	12:16	1	365	365	Overhead equipment	Disconnect Switch	Patrol/Test/Inspect	Replace - Same Size	I
131753310	D55002	06/24/2013	6:15	06/24/2013	13:21	1	426	426	Tree related-tree broken	Tree	Cut in Clear		I
131753308	N67309	06/24/2013	6:15	06/24/2013	7:43	3	264	88	Tree related-tree contact	Fuse	Replace - Same Size		I
131753324	343006	06/24/2013	6:17	06/24/2013	9:00	1	163	163	Overhead equipment				VI
131753332	D90003	06/24/2013	6:19	06/24/2013	7:45	1	86	86	Tree related-tree broken	Tree		Repair	III
131753361	N18210	06/24/2013	6:25	06/24/2013	6:36	15	165	11	Weather	Fuse	Replace - Same Size		III
131753378	R84148	06/24/2013	6:27	06/24/2013	9:40	1	193	193	Overhead equipment	Overhead Transformer	Replace - Same Size	Replace - Same Size	I
131753405	Q14392	06/24/2013	6:34	06/24/2013	9:32	1	178	178	Weather	Overhead Transformer	Replace - Same Size		I
131753676	V03562	06/24/2013	6:34	06/24/2013	8:13	26	2574	99	Weather	Fuse	Replace - Same Size		II
131753474	K30205	06/24/2013	6:41	06/24/2013	8:16	2	190	95	Overhead equipment	Fuse			III
131753449		06/24/2013	6:45	06/24/2013	9:37	1	172	172	Overhead equipment	Fuse	Replace - Same Size		V
131753445	S32550	06/24/2013	6:45	06/24/2013	6:55	1	10	10	Other	Other			VI
131753465	M07235	06/24/2013	6:51	06/24/2013	10:00	1	189	189	Weather	Transformer Fuse	Replace - Same Size		III
131753486	N18211	06/24/2013	6:55	06/24/2013	9:27	1	152	152	Overhead equipment	Fuse			III
131753482	F03003	06/24/2013	6:56	06/24/2013	7:40	8	352	44	Animal related	Fuse	Replace - Same Size		III
131753487	P77233	06/24/2013	6:56	06/24/2013	7:58	1	62	62	Overhead equipment	Transformer Fuse			VI
131753499	N18211	06/24/2013	6:59	06/24/2013	9:07	1	128	128	Overhead equipment	Fuse			III
131753505		06/24/2013	7:00	06/24/2013	12:24	1	324	324	Overhead equipment	Disconnect Switch	Patrol/Test/Inspect	Replace - Same Size	I
131753502	D33142	06/24/2013	7:00	06/24/2013	10:57	4	948	237	Overhead equipment	Transformer Fuse	Replace - Same Size	Replace - Same Size	I
131753527	D28124	06/24/2013	7:06	06/24/2013	10:41	1	215	215	Tree related-tree contact				I
131753535	K78351	06/24/2013	7:08	06/24/2013	9:57	1	169	169	Underground equipment	Underground Transformer	Switch/Reset	Replace - Same Size	IV
131753567	P12290	06/24/2013	7:17	06/24/2013	12:09	1	292	292	Weather	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	V
131753575	N18211	06/24/2013	7:19	06/24/2013	8:43	1	84	84	Overhead equipment	Fuse			III
131753595	A91004	06/24/2013	7:23	06/24/2013	9:34	1	131	131	Weather				I
131753614	B44002	06/24/2013	7:28	06/24/2013	13:11	1	343	343	Weather				I
131753623	L93133	06/24/2013	7:31	06/24/2013	7:55	2	48	24	Overhead equipment	Jumper	Repair		VI
131753630	D89003	06/24/2013	7:34	06/24/2013	10:25	1	171	171	Animal related	Transformer Fuse	Replace - Same Size		I
131753631	J87119	06/24/2013	7:34	06/24/2013	11:28	1	234	234	Overhead equipment	Overhead Transformer	Cut in Clear	Replace - Same Size	VI
131753640	B77003	06/24/2013	7:35	06/24/2013	13:38	1	363	363	Weather				I
131753669	IP9009	06/24/2013	7:43	06/24/2013	10:00	1	137	137	Overhead equipment				VI
131753679	A91002	06/24/2013	7:45	06/24/2013	13:51	1	366	366	Overhead equipment				I
131753681	P12290	06/24/2013	7:46	06/24/2013	10:27	1	161	161	Weather	Fuse	Replace - Same Size	Replace - Same Size	V
131753692	B10002	06/24/2013	7:50	06/24/2013	8:22	1	32	32	Weather				I
131753701	D41002	06/24/2013	7:51	06/24/2013	13:47	84	29904	356	Weather				I
131753725	J34356	06/24/2013	7:56	06/24/2013	13:02	1	306	306	Overhead equipment	Overhead Transformer	Cut in Clear	Replace - Same Size	V
131753730	311001	06/24/2013	7:56	06/24/2013	9:35	1	99	99	Weather	Fuse	Repair	Repair	VI
131753742	Q32171	06/24/2013	7:58	06/24/2013	8:11	1	13	13	Tree related-tree broken	Overhead Primary	Repair	Repair	I
131753737	P39299	06/24/2013	7:58	06/24/2013	9:10	1	72	72	Weather	Recloser			VI
131753749	R68903	06/24/2013	7:59	06/24/2013	9:35	1	96	96	Weather	Transformer Fuse	Replace - Same Size		I

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
131753754		06/24/2013	8:00	06/24/2013	9:21	1	81	81	Animal related	Lightning Arrestor			IV
131753780	D93001	06/24/2013	8:03	06/24/2013	10:20	1	137	137	Weather	Fuse	Patrol/Test/Inspect	Replace - Same Size	IV
131753775	P57108	06/24/2013	8:04	06/24/2013	9:00	1	56	56	Overhead equipment	Fuse	Replace - Same Size		VI
131757391	J79304	06/24/2013	8:04	06/24/2013	18:59	874	572470	655	Overhead equipment	Overhead Transformer	Replace - Same Size		I
131753886	Q23258	06/24/2013	8:05	06/24/2013	9:31	8	688	86	Underground equipment	Underground Primary		Repair	VI
131753871	R50910	06/24/2013	8:05	06/24/2013	9:04	11	649	59	Weather	Fuse	Replace - Same Size		I
131754367	F03003	06/24/2013	8:06	06/24/2013	13:48	2	684	342	Underground equipment	Underground Primary			III
131753815	A26006	06/24/2013	8:11	06/24/2013	11:00	1	169	169	Tree related-tree broken	Overhead Service	Repair		I
131753814	Q27185	06/24/2013	8:11	06/24/2013	9:32	4	324	81	Animal related	Fuse	Replace - Same Size		VI
131753828	N18211	06/24/2013	8:13	06/24/2013	8:55	1	42	42	Overhead equipment	Fuse			III
131753836	N18211	06/24/2013	8:14	06/24/2013	8:47	1	33	33	Overhead equipment	Fuse			III
131753853	S86582	06/24/2013	8:18	06/24/2013	11:11	1	173	173	Overhead equipment	Crossarm		Replace - Same Size	VI
131753923	V23592	06/24/2013	8:30	06/24/2013	8:50	1	20	20	Weather	Fuse	Replace - Same Size		II
131753953	K35308	06/24/2013	8:33	06/24/2013	9:05	1	32	32	Overhead equipment	Fuse	Replace - Same Size		III
131753964	R48166	06/24/2013	8:34	06/24/2013	12:24	1	230	230	Tree related-tree broken	Pole	Replace - Same Size		IV
131755037	A91004	06/24/2013	8:35	06/24/2013	15:10	4	1580	395	Overhead equipment				I
131753974	K46388	06/24/2013	8:36	06/24/2013	10:30	1	114	114	Overhead equipment	Overhead Transformer	Cut in Clear	Replace - Same Size	V
131753984	P80145	06/24/2013	8:38	06/24/2013	12:15	1	217	217	Overhead equipment	Overhead Transformer	Replace - Same Size	Replace - Same Size	I
131753995	B45003	06/24/2013	8:40	06/24/2013	14:40	1	360	360	Tree related-tree broken	Overhead Service	Repair		I
131754005	V22555	06/24/2013	8:42	06/24/2013	12:44	1	242	242	Overhead equipment	Overhead Service	Repair		II
131754072	M45212	06/24/2013	8:43	06/24/2013	10:30	426	45582	107	Animal related	Overhead Primary	Repair		IV
131754023	HA5432	06/24/2013	8:46	06/24/2013	9:47	5	305	61	Animal related	Fuse	Replace - Same Size		V
131754068		06/24/2013	8:51	06/24/2013	9:37	1	46	46	Animal related				IV
131754086	D16002	06/24/2013	8:54	06/24/2013	16:34	1	460	460	Overhead equipment				I
131754125	D41003	06/24/2013	9:00	06/24/2013	11:05	1	125	125	Overhead equipment	Transformer Fuse	Replace - Same Size		I
131754213	Q34365	06/24/2013	9:07	06/24/2013	12:00	1	173	173	Public	Pole			I
131754164	B77002	06/24/2013	9:07	06/24/2013	13:45	1	278	278	Tree related-tree broken	Overhead Service	Repair		I
131754161	M42107	06/24/2013	9:07	06/24/2013	9:43	1	36	36	Overhead equipment				I
131754173	X73001	06/24/2013	9:09	06/24/2013	11:40	10	1510	151	Tree related-tree broken	Overhead Secondary			IV
131754193	334004	06/24/2013	9:13	06/24/2013	14:36	1	323	323	Overhead equipment				VI
131754210	U42001	06/24/2013	9:13	06/24/2013	11:17	53	6572	124	Tree related-tree broken	Disconnect Switch			II
131754446	K30205	06/24/2013	9:22	06/24/2013	10:26	2	128	64	Overhead equipment	Fuse			III
131754282		06/24/2013	9:28	06/24/2013	10:20	1	52	52	Weather	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	IV
131754332	N58144	06/24/2013	9:37	06/24/2013	10:26	1	49	49	Animal related	Fuse	Replace - Same Size		I
131755314	D01002	06/24/2013	9:40	06/24/2013	14:01	19	4959	261	Overhead equipment	Fuse	Repair		I
131754350	M81402	06/24/2013	9:45	06/24/2013	19:10	1	565	565	Overhead equipment	Overhead Service	Patrol/Test/Inspect	Replace - Same Size	V
131754381	A91003	06/24/2013	9:47	06/24/2013	11:38	1	111	111	Underground equipment	Underground Transformer	Replace - Same Size		I
131754370	N05170	06/24/2013	9:47	06/24/2013	10:58	1	71	71	Animal related	Fuse	Replace - Same Size		I
131754411	B10002	06/24/2013	9:53	06/24/2013	17:11	1	438	438	Overhead equipment	Overhead Transformer	Cut in Clear	Replace - Same Size	I
131754420	B61001	06/24/2013	9:54	06/24/2013	15:36	2	684	342	Overhead equipment	Underground Connector	Patrol/Test/Inspect	Replace - Same Size	I
131754719	K30205	06/24/2013	10:03	06/24/2013	13:00	19	3363	177	Overhead equipment	Overhead Primary			III
131754522	N18210	06/24/2013	10:12	06/24/2013	11:12	7	420	60	Weather	Fuse	Replace - Same Size		III
131755369	R07382	06/24/2013	10:36	06/24/2013	18:10	3	1362	454	Underground equipment	Underground Primary	Repair		I
131754718	R07382	06/24/2013	10:36	06/24/2013	12:43	24	3048	127	Underground equipment	Underground Primary	Switch/Reset		I
131754709	R94269	06/24/2013	10:41	06/24/2013	11:33	1	52	52	Weather	Transformer Fuse	Replace - Same Size		VI
131754770	D87001	06/24/2013	10:44	06/24/2013	16:27	74	25382	343	Overhead equipment	Overhead Primary			I
131754824	Q95247	06/24/2013	10:56	06/24/2013	12:17	1	81	81	Weather	Fuse	Replace - Same Size		VI
131754918	B44002	06/24/2013	11:13	06/24/2013	15:21	1	248	248	Overhead equipment				I
131754926	U04589	06/24/2013	11:15	06/24/2013	12:12	1	57	57	Animal related	Transformer Fuse	Replace - Same Size	Repair	II
131755005	B00005	06/24/2013	11:21	06/24/2013	13:08	81	8667	107	Public	Fuse	Replace - Same Size		I
131754977	J07173	06/24/2013	11:24	06/24/2013	12:15	1	51	51	Overhead equipment	Overhead Service	Tie/Tighten		I
131754993	K07322	06/24/2013	11:26	06/24/2013	12:24	1	58	58	Weather	Transformer Fuse	Replace - Same Size		I
131754999		06/24/2013	11:27	06/24/2013	13:10	1	103	103	Public	Pole	No Work Required		I
131755025	D28123	06/24/2013	11:31	06/24/2013	14:16	1	165	165	Weather	Lightning Arrestor	Replace - Same Size		I
131755076	V03562	06/24/2013	11:31	06/24/2013	13:30	26	3094	119	Overhead equipment	Fuse	Replace - Same Size		II
131755065	V17539	06/24/2013	11:42	06/24/2013	13:11	1	89	89	Animal related	Other			II

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
131755080	D36002	06/24/2013	11:44	06/24/2013	17:06	1	322	322	Underground equipment	Underground Transformer	Patrol/Test/Inspect	Replace - Same Size	I
131755084		06/24/2013	11:44	06/24/2013	12:50	1	66	66	Weather	Transformer Fuse	Replace - Same Size	Replace - Same Size	V
131755089	Q10702	06/24/2013	11:45	06/24/2013	15:33	1	228	228	Weather	Connector	Repair		V
131755163	D70001	06/24/2013	11:50	06/24/2013	14:05	14	1890	135	Underground equipment	Underground Primary	Repair	Repair	I
131755230	D69006	06/24/2013	12:21	06/24/2013	16:45	1	264	264	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect		I
131755970	B80004	06/24/2013	12:22	06/25/2013	5:30	2	2056	1028	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
131755250	B80004	06/24/2013	12:24	06/24/2013	16:10	15	3390	226	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
131755273	J20931	06/24/2013	12:30	06/24/2013	16:30	1	240	240	Overhead equipment	Overhead Transformer	Replace - Same Size	Replace - Same Size	VI
131755284	P47123	06/24/2013	12:32	06/24/2013	13:25	1	53	53	Tree related-tree contact	Overhead Service	Repair		I
131755414	B25002	06/24/2013	12:59	06/24/2013	13:30	1	31	31	Overhead equipment	Transformer Fuse	Replace - Same Size	No Work Required	I
131755440	R49263	06/24/2013	13:05	06/24/2013	14:08	1	63	63	Weather	Transformer Fuse		Patrol/Test/Inspect	VI
131755478	Q82907	06/24/2013	13:10	06/24/2013	20:20	2	860	430	Overhead equipment	Pole	Replace - Same Size	Replace - Same Size	VI
131755506	N70330	06/24/2013	13:18	06/24/2013	15:18	1	120	120	Overhead equipment	Transformer Fuse	Replace - Same Size	Replace - Same Size	I
131756279	D36002	06/24/2013	13:21	06/24/2013	18:00	24	6696	279	Underground equipment				I
131755595	P19395	06/24/2013	13:33	06/24/2013	16:25	1	172	172	Overhead equipment	Overhead Primary	Repair	Repair	V
131755619	K89143	06/24/2013	13:39	06/24/2013	14:18	1	39	39	Animal related	Fuse	Replace - Same Size		III
131755628	K43385	06/24/2013	13:41	06/24/2013	14:36	1	55	55	Tree related-tree broken	Overhead Service	Patrol/Test/Inspect	Repair	V
131755637	V58507	06/24/2013	13:43	06/24/2013	15:05	1	82	82	Overhead equipment	Disconnect Switch	Repair		II
131755751	B82002	06/24/2013	14:06	06/24/2013	15:40	1	94	94	Weather	Fuse	Replace - Same Size		I
131755768	T09559	06/24/2013	14:09	06/24/2013	15:20	1	71	71	Overhead equipment	Overhead Service	Raise		VI
131755880	N67311	06/24/2013	14:20	06/24/2013	19:03	18	5094	283	Overhead equipment				I
131755873	R41131	06/24/2013	14:25	06/24/2013	15:35	1	70	70	Overhead equipment	Fuse	Repair		VI
131755882	D81001	06/24/2013	14:26	06/24/2013	18:15	1	229	229	Tree related-tree broken	Tree	Remove		I
131755884	Q24312	06/24/2013	14:26	06/24/2013	15:35	2	138	69	Tree related-tree broken	Fuse	Replace - Same Size		VI
131755909	A56013	06/24/2013	14:31	06/24/2013	14:59	1	28	28	Overhead equipment	Disconnect Switch	Replace - Same Size		I
131755968		06/24/2013	14:39	06/24/2013	16:40	1	121	121	Overhead equipment	Connector	Repair	No Work Required	I
131755987	D32211	06/24/2013	14:40	06/24/2013	19:29	1	289	289	Tree related-tree broken	Tree	Trim		I
131756002	U02597	06/24/2013	14:43	06/24/2013	15:23	1	40	40	Weather	Transformer Fuse	Replace - Same Size		II
131756073	Q24312	06/24/2013	14:55	06/24/2013	15:34	1	39	39	Tree related-tree broken	Fuse	Replace - Same Size		VI
131756083	B76003	06/24/2013	14:58	06/24/2013	15:35	1	37	37	Overhead equipment	Transformer Fuse	Replace - Same Size		I
131756101	Y05001	06/24/2013	15:05	06/24/2013	18:03	1	178	178	Overhead equipment	Overhead Transformer	Replace - Same Size	Replace - Same Size	IV
131756163	V99562	06/24/2013	15:13	06/24/2013	22:28	2	870	435	Tree related-tree broken	Pole	Replace - Same Size		II
131756206	V99562	06/24/2013	15:13	06/24/2013	17:35	137	19454	142	Tree related-tree broken	Fuse	Replace - Same Size		II
131756471	W03570	06/24/2013	15:18	06/24/2013	18:30	10	1920	192	Weather	Fuse	Replace - Same Size		II
131756182	R05186	06/24/2013	15:19	06/24/2013	21:10	1	351	351	Animal related	Transformer Fuse	Replace - Same Size		I
131756257	P80145	06/24/2013	15:23	06/24/2013	17:55	35	5320	152	Overhead equipment	Fuse	Patrol/Test/Inspect	Replace - Same Size	I
131756230	M25143	06/24/2013	15:27	06/24/2013	17:37	1	130	130	Tree related-tree contact	Tree	Remove		IV
131756301	P47169	06/24/2013	15:49	06/24/2013	17:09	1	80	80	Tree related-tree contact	Tree			I
131756303	B19002	06/24/2013	15:50	06/24/2013	21:00	2	620	310	Overhead equipment	Overhead Primary		Replace - Urgent	I
131756311	K35308	06/24/2013	15:51	06/24/2013	17:15	1	84	84	Other	Fuse	Repair		III
131757068	P47120	06/24/2013	15:53	06/24/2013	21:20	7	2289	327	Tree related-tree broken	Fuse	Patrol/Test/Inspect	Replace - Same Size	I
131756336	D92002	06/24/2013	15:56	06/24/2013	17:25	1	89	89	Tree related-tree contact	Overhead Service	Replace - Same Size		I
131756353	J07173	06/24/2013	16:01	06/24/2013	20:05	7	1708	244	Overhead equipment	Overhead Transformer	Switch/Reset		I
131756839	M41182	06/24/2013	16:04	06/24/2013	17:45	109	11009	101	Tree related-tree broken	Tree	Cut in Clear		I
131756373	P77233	06/24/2013	16:05	06/24/2013	17:56	1	111	111	Overhead equipment	Fuse	Replace - Same Size		VI
131756374	M31203	06/24/2013	16:06	06/24/2013	20:58	1	292	292	Tree related-tree broken	Overhead Service	Repair		I
131756577	J15303	06/24/2013	16:06	06/24/2013	18:00	400	45600	114	Weather	Pole	Replace - Same Size	Replace - Same Size	I
131756388	M41111	06/24/2013	16:06	06/24/2013	18:30	21	3024	144	Overhead equipment	Recloser	Switch/Reset		I
131756410	R05115	06/24/2013	16:06	06/24/2013	18:21	69	9315	135	Overhead equipment	Overhead Primary	Repair		I
131756404	M37191	06/24/2013	16:07	06/24/2013	20:09	13	3146	242	Overhead equipment	Overhead Primary	Tie/Tighten	No Work Required	I
131756393	M40131	06/24/2013	16:08	06/25/2013	2:20	2	1224	612	Tree related-tree broken	Pole	Replace - New Size	Replace - New Size	I
131756511	J06168	06/24/2013	16:08	06/24/2013	19:35	38	7866	207	Overhead equipment	Overhead Primary	Cut in Clear		I
131756435	K07320	06/24/2013	16:12	06/24/2013	19:53	8	1768	221	Weather	Fuse	Replace - Same Size		I
131756552	J15302	06/24/2013	16:12	06/24/2013	20:59	49	14063	287	Weather	Overhead Primary	Replace - Same Size		I
131756426	R05115	06/24/2013	16:13	06/24/2013	18:24	12	1572	131	Overhead equipment	Overhead Service	No Work Required		I
131756464	M31202	06/24/2013	16:15	06/24/2013	19:34	22	4378	199	Tree related-tree broken	Overhead Primary	Reconnect		I

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
131756499	J08205	06/24/2013	16:16	06/24/2013	22:07	54	18954	351	Tree related-tree broken	Overhead Primary	Cut in Clear		I
131756524	J08205	06/24/2013	16:17	06/24/2013	22:05	28	9744	348	Tree related-tree broken	Overhead Primary	Cut in Clear		I
131756448	R05115	06/24/2013	16:18	06/24/2013	21:14	13	3848	296	Overhead equipment	Tree	Remove		I
131756470	R33126	06/24/2013	16:21	06/24/2013	18:45	1	144	144	Tree related-tree broken	Fuse	Replace - Same Size	Replace - Same Size	I
131756483	M31202	06/24/2013	16:22	06/24/2013	19:32	41	7790	190	Tree related-tree broken	Overhead Primary	Reconnect		I
131756646	V21548	06/24/2013	16:23	06/24/2013	17:07	114	5016	44	Weather	Fuse	Replace - Same Size		II
131756516	J15303	06/24/2013	16:26	06/24/2013	18:54	1	148	148	Weather	Overhead Primary	Replace - Same Size	Replace - Same Size	I
131756621	J79305	06/24/2013	16:26	06/24/2013	23:14	82	33456	408	Tree related-tree broken	Overhead Primary	Replace - Same Size	Replace - Same Size	I
131756539	J15303	06/24/2013	16:28	06/24/2013	18:50	1	142	142	Weather	Overhead Primary	Replace - Same Size	Replace - Same Size	I
131756537	M37191	06/24/2013	16:29	06/24/2013	18:41	4	528	132	Overhead equipment	Overhead Primary	Repair		I
131756535	J15303	06/24/2013	16:29	06/24/2013	18:56	1	147	147	Weather	Overhead Primary	Replace - Same Size	Replace - Same Size	I
131756728	A80002	06/24/2013	16:29	06/24/2013	18:31	326	39772	122	Tree related-tree broken	Tree	Trim		I
131756576	342004	06/24/2013	16:30	06/24/2013	17:40	18	1260	70	Overhead equipment				VI
131756776	A80001	06/24/2013	16:30	06/24/2013	19:37	24	4488	187	Tree related-tree broken	Disconnect Switch	Replace - Same Size		I
131756545	J15303	06/24/2013	16:30	06/24/2013	18:48	39	5382	138	Weather	Overhead Primary	Replace - Same Size	Replace - Same Size	I
131756565	D32212	06/24/2013	16:32	06/24/2013	22:45	1	373	373	Overhead equipment	Overhead Transformer	Replace - Same Size		I
131756557	R05115	06/24/2013	16:32	06/24/2013	22:43	1	371	371	Tree related-tree broken	Overhead Service	Replace - New Size	No Work Required	I
131756558	Q63835	06/24/2013	16:32	06/24/2013	17:49	1	77	77	Weather	Transformer Fuse	Replace - Same Size	No Work Required	V
131756578	D87001	06/24/2013	16:35	06/24/2013	20:25	1	230	230	Weather	Transformer Fuse	Replace - Same Size		I
131756596	N67309	06/24/2013	16:37	06/25/2013	6:21	8	6592	824	Overhead equipment	Pole	Replace - Same Size		I
131756597	K35308	06/24/2013	16:37	06/24/2013	17:15	1	38	38	Other	Fuse	Repair		III
131756852	D01001	06/24/2013	16:37	06/24/2013	21:23	85	24310	286	Overhead equipment	Overhead Primary	Repair		I
131760632	N94180	06/24/2013	16:44	06/25/2013	2:52	9	5472	608	Unknown	Fuse	Repair		I
131756649	N60181	06/24/2013	16:44	06/24/2013	20:45	3	723	241	Overhead equipment	Overhead Transformer	Replace - Same Size	Patrol/Test/Inspect	I
131756648	J15303	06/24/2013	16:44	06/24/2013	18:00	1	76	76	Tree related-tree contact	Fuse	Replace - Same Size		I
131758262	N94180	06/24/2013	16:44	06/24/2013	23:24	481	192400	400	Overhead equipment	Pole	Repair	Repair	I
131756693	D41003	06/24/2013	16:45	06/25/2013	2:25	3	1740	580	Tree related-tree broken	Overhead Primary	Patrol/Test/Inspect	Repair	I
131756934	K31124	06/24/2013	16:46	06/25/2013	11:15	3	3327	1109	Tree related-tree broken	Tree	Cut in Clear		I
131756662	U99593	06/24/2013	16:46	06/24/2013	19:10	1	144	144	Weather	Overhead Transformer	Replace - Same Size	Replace - Same Size	II
131756823	K31124	06/24/2013	16:46	06/25/2013	7:14	447	387996	868	Weather	Pole	Repair		I
131756762	N05173	06/24/2013	16:48	06/24/2013	18:12	6	504	84	Tree related-tree broken	Fuse	Replace - Same Size		I
131756673	J15303	06/24/2013	16:48	06/24/2013	18:37	1	109	109	Tree related-tree contact	Overhead Service	Repair		I
131756761	N70332	06/24/2013	16:53	06/24/2013	22:27	16	5344	334	Overhead equipment	Overhead Primary	Repair		I
131756722	A17025	06/24/2013	16:54	06/24/2013	21:00	9	2214	246	Tree related-tree contact	Tree	Remove		I
131756721		06/24/2013	16:54	06/25/2013	9:51	1	1017	1017	Overhead equipment				I
131756743	B45005	06/24/2013	16:54	06/24/2013	19:16	34	4828	142	Tree related-tree broken	Tree	Remove		I
131756774	D70006	06/24/2013	16:55	06/24/2013	20:20	40	8200	205	Tree related-tree contact	Crossarm	Replace - Same Size		I
131758184	K31124	06/24/2013	16:55	06/24/2013	20:29	87	18618	214	Overhead equipment	Pole	Patrol/Test/Inspect	Replace - Same Size	I
131756747	D32212	06/24/2013	16:57	06/24/2013	19:03	1	126	126	Overhead equipment	Fuse	Repair	Replace - Same Size	I
131756751	339159	06/24/2013	16:57	06/24/2013	17:00	1	3	3	Overhead equipment	Fuse	Replace - Same Size		V
131758376	D16004	06/24/2013	16:57	06/24/2013	23:30	53	20829	393	Tree related-tree broken	Overhead Primary	Patrol/Test/Inspect		I
131756754	M40131	06/24/2013	16:58	06/25/2013	5:40	1	762	762	Tree related-tree broken	Overhead Transformer	Replace - Same Size	Repair	I
131756772	A56013	06/24/2013	16:59	06/24/2013	20:45	1	226	226	Tree related-tree broken	Overhead Service	Repair		I
131756777	B19002	06/24/2013	17:00	06/24/2013	17:57	1	57	57	Weather	Transformer Fuse	Replace - Same Size		I
131756794	B93001	06/24/2013	17:02	06/24/2013	17:57	1	55	55	Tree related-tree contact	Overhead Service	Disconnect		I
131756765	D55002	06/24/2013	17:02	06/24/2013	19:50	10	1680	168	Tree related-tree broken	Overhead Primary		Repair	I
131756889	R50910	06/24/2013	17:04	06/25/2013	4:47	156	109668	703	Weather				I
131756840	N05172	06/24/2013	17:05	06/24/2013	20:05	43	7740	180	Tree related-tree broken	Overhead Primary	Repair	Repair	I
131756827	N78244	06/24/2013	17:06	06/24/2013	19:19	1	133	133	Tree related-tree broken	Overhead Service	Replace - Same Size		I
131756837	V39001	06/24/2013	17:07	06/24/2013	18:47	5	500	100	Overhead equipment	Overhead Primary	Repair		II
131757940	R50910	06/24/2013	17:07	06/24/2013	23:45	26	10348	398	Weather	Pole	Repair		I
131756851	D55002	06/24/2013	17:09	06/24/2013	22:01	1	292	292	Tree related-tree broken	Overhead Service	Repair		I
131756860	D55002	06/24/2013	17:11	06/24/2013	18:25	1	74	74	Tree related-tree contact	Overhead Service	Repair		I
131756863	A29001	06/24/2013	17:11	06/24/2013	17:25	18	252	14	Tree related-tree contact	Overhead Secondary	Patrol/Test/Inspect	Tie/Tighten	I
131756898	B58001	06/24/2013	17:12	06/24/2013	18:38	125	10750	86	Tree related-tree contact	Fuse	Replace - Same Size		I
131756877	R95520	06/24/2013	17:13	06/25/2013	4:07	56	36624	654	Tree related-tree broken				I

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
131757058	Q34360	06/24/2013	17:14	06/24/2013	20:18	230	42320	184	Weather	Recloser	Patrol/Test/Inspect	Repair	I
131756895		06/24/2013	17:16	06/24/2013	20:06	1	170	170	Tree related-tree broken	Overhead Primary	Raise	Raise	I
131757015	Q93522	06/24/2013	17:16	06/24/2013	19:45	523	77927	149	Tree related-tree broken	Overhead Primary	Raise		I
131756907	K31124	06/24/2013	17:17	06/25/2013	6:18	1	781	781	Overhead equipment	Overhead Primary	Repair	Repair	I
131756976	R07381	06/24/2013	17:17	06/24/2013	21:55	57	15846	278	Overhead equipment	Overhead Primary	Repair		I
131756916	N60181	06/24/2013	17:19	06/24/2013	21:40	1	261	261	Overhead equipment	Overhead Service	No Work Required		I
131756915	D48001	06/24/2013	17:19	06/25/2013	2:10	1	531	531	Tree related-tree broken	Pole	Replace - New Size		I
131756929	J88163	06/24/2013	17:21	06/24/2013	20:45	1	204	204	Overhead equipment	Overhead Transformer		Replace - Same Size	VI
131756941	D32212	06/24/2013	17:22	06/24/2013	20:39	13	2561	197	Overhead equipment	Fuse	Replace - Same Size		I
131756942	R07382	06/24/2013	17:23	06/25/2013	6:30	2	1574	787	Tree related-tree broken	Overhead Transformer	Replace - Same Size	Repair	I
131756960	R07382	06/24/2013	17:26	06/25/2013	5:00	1	694	694	Tree related-tree broken	Tree	Remove		I
131757087	D01001	06/24/2013	17:26	06/24/2013	21:26	15	3600	240	Overhead equipment	Overhead Primary	Repair		I
131756975	R50910	06/24/2013	17:28	06/25/2013	0:30	1	422	422	Tree related-tree broken	Overhead Service	Cut in Clear	Replace - Same Size	I
131756972	P26284	06/24/2013	17:28	06/25/2013	1:34	1	486	486	Overhead equipment	Fuse	Replace - Same Size		I
131757037	B93003	06/24/2013	17:29	06/24/2013	19:28	46	5474	119	Overhead equipment	Fuse	Replace - Same Size		I
131756994	D31017	06/24/2013	17:30	06/24/2013	19:06	828	79488	96	Tree related-tree broken	Tree	Remove	Remove	III
131758083	N58144	06/24/2013	17:30	06/24/2013	21:00	12	2520	210	Tree related-tree broken	Fuse	Patrol/Test/Inspect	Replace - Same Size	I
131757004	D90002	06/24/2013	17:31	06/24/2013	20:00	89	13261	149	Tree related-tree broken	Overhead Primary	Repair		III
131757009	R33126	06/24/2013	17:34	06/24/2013	19:05	1	91	91	Tree related-tree contact	Fuse	Replace - Same Size	Repair	I
131757011	D31016	06/24/2013	17:34	06/24/2013	21:15	1	221	221	Tree related-tree broken	Overhead Service	Tie/Tighten	Reconnect	III
131757008	B21002	06/24/2013	17:34	06/24/2013	21:59	11	2915	265	Overhead equipment	Fuse	Repair	Replace - Same Size	I
131764233	N94180	06/24/2013	17:34	06/25/2013	7:37	22	18546	843	Overhead equipment	Pole	Patrol/Test/Inspect	Replace - Same Size	I
131757107	P83705	06/24/2013	17:37	06/25/2013	4:38	24	15864	661	Tree related-tree broken				I
131757036	D90002	06/24/2013	17:40	06/24/2013	23:19	1	339	339	Weather	Other	Patrol/Test/Inspect	Patrol/Test/Inspect	III
131757047	P83705	06/24/2013	17:42	06/25/2013	7:50	1	848	848	Overhead equipment	Overhead Transformer			I
131757050	Q91141	06/24/2013	17:43	06/25/2013	0:09	7	2702	386	Tree related-tree contact	Overhead Transformer	Switch/Reset	Tie/Tighten	I
131758278	N58144	06/24/2013	17:44	06/24/2013	23:30	7	2422	346	Animal related	Fuse	Patrol/Test/Inspect	Replace - Same Size	I
131757069	R95520	06/24/2013	17:45	06/25/2013	5:30	22	15510	705	Tree related-tree broken	Fuse	Replace - Same Size		I
131757079	R95520	06/24/2013	17:49	06/25/2013	5:20	1	691	691	Tree related-tree broken	Fuse		Replace - Same Size	I
131757866	D90002	06/24/2013	17:50	06/24/2013	20:44	3	522	174	Overhead equipment	Fuse	Replace - Same Size		III
131757083	C15002	06/24/2013	17:50	06/24/2013	18:29	1	39	39	Overhead equipment	Fuse	Replace - Same Size		III
131757926	D28123	06/24/2013	17:52	06/24/2013	23:00	5	1540	308	Overhead equipment	Overhead Primary	Patrol/Test/Inspect	Repair	I
131757101	D35003	06/24/2013	17:52	06/24/2013	23:16	12	3888	324	Weather	Overhead Primary	Repair		I
131757102	R16510	06/24/2013	17:53	06/24/2013	20:44	1	171	171	Weather	Fuse	Replace - Same Size		I
131757355	P83705	06/24/2013	17:55	06/25/2013	8:16	5	4305	861	Tree related-tree broken	Overhead Primary	Cut in Clear		I
131757120	L43154	06/24/2013	18:01	06/25/2013	8:16	1	855	855	Tree related-tree broken	Transformer Fuse		Repair	I
131757861	U06551	06/24/2013	18:01	06/24/2013	20:18	8	1096	137	Weather	Fuse	Replace - Same Size		II
131757144	R95520	06/24/2013	18:08	06/25/2013	5:30	1	682	682	Tree related-tree broken	Fuse	Repair		I
131757145	HB6281	06/24/2013	18:08	06/24/2013	19:02	1	54	54	Animal related	Transformer Fuse			VI
131757148	P80145	06/24/2013	18:10	06/24/2013	19:04	1	54	54	Overhead equipment	Transformer Fuse	Replace - Same Size		I
131757150	F10001	06/24/2013	18:11	06/24/2013	19:44	10	930	93	Overhead equipment	Disconnect Switch	Replace - Same Size	Repair	III
131757152	C65001	06/24/2013	18:12	06/24/2013	19:38	2	172	86	Overhead equipment	Overhead Service	Patrol/Test/Inspect	Repair	III
131757172	R07381	06/24/2013	18:14	06/24/2013	19:52	1	98	98	Overhead equipment	Overhead Primary		Repair	I
131757316	K30204	06/24/2013	18:18	06/24/2013	20:21	18	2214	123	Weather	Fuse	Replace - Same Size		III
131757302	D96002	06/24/2013	18:19	06/24/2013	23:00	1	281	281	Weather	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	I
131757317	B68003	06/24/2013	18:24	06/25/2013	2:43	1	499	499	Weather	Underground Primary	Patrol/Test/Inspect	Repair	III
131757318	D90004	06/24/2013	18:25	06/24/2013	22:29	1	244	244	Overhead equipment	Overhead Service	Repair		III
131757370	X77586	06/24/2013	18:33	06/24/2013	19:24	1	51	51	Tree related-tree broken	Transformer Fuse	Replace - Same Size		IV
131757374	D36002	06/24/2013	18:34	06/25/2013	0:12	1	338	338	Weather	Overhead Transformer	Replace - Same Size		I
131757378	J63172	06/24/2013	18:35	06/24/2013	19:57	1	82	82	Tree related-tree broken	Overhead Service			III
131757383	P83710	06/24/2013	18:37	06/25/2013	9:40	1	903	903	Overhead equipment				I
131757384	D48001	06/24/2013	18:38	06/25/2013	0:21	1	343	343	Weather	Overhead Transformer	Replace - New Size		I
131757390	P83705	06/24/2013	18:40	06/25/2013	4:38	1	598	598	Tree related-tree broken	Overhead Primary	Repair		I
131757979	Z61524	06/24/2013	18:42	06/24/2013	22:25	282	62886	223	Overhead equipment	Overhead Primary	Repair	Repair	IV
131758123	X75558	06/24/2013	18:46	06/24/2013	22:00	18	3492	194	Overhead equipment	Pole	Replace - New Size	Replace - New Size	IV
131757868	R99180	06/24/2013	18:51	06/24/2013	19:57	1	66	66	Weather	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	IV

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
131758145	Y60593	06/24/2013	18:51	06/24/2013	21:04	745	99085	133	Unknown				IV
131757881	M31202	06/24/2013	18:54	06/24/2013	19:59	1	65	65	Overhead equipment	Overhead Primary	Replace - Same Size	Replace - Same Size	I
131757929	R68903	06/24/2013	18:58	06/25/2013	11:23	1	985	985	Weather	Overhead Primary	Patrol/Test/Inspect	Repair	I
131757031	P26283	06/24/2013	18:58	06/25/2013	5:40	1	642	642	Tree related-tree broken	Overhead Service	Disconnect		I
131758031	J79304	06/24/2013	18:59	06/25/2013	2:17	874	382812	438	Tree related-tree broken	Crossarm	Replace - Same Size	Replace - Same Size	I
131757959	X73001	06/24/2013	19:00	06/25/2013	1:35	1	395	395	Tree related-tree broken	Overhead Service			IV
131757961	J12166	06/24/2013	19:01	06/24/2013	19:49	1	48	48	Animal related	Fuse	Replace - Same Size		III
131758334	J15303	06/24/2013	19:01	06/25/2013	2:15	15	6510	434	Weather	Overhead Primary	Replace - Same Size	Replace - Same Size	I
131758037	R58922	06/24/2013	19:01	06/24/2013	21:16	26	3510	135	Tree related-tree contact	Overhead Primary	Patrol/Test/Inspect	Repair	IV
131757981	X75571	06/24/2013	19:03	06/25/2013	0:29	1	326	326	Tree related-tree broken	Overhead Service	Repair		IV
131758011	Y59519	06/24/2013	19:09	06/24/2013	23:40	1	271	271	Tree related-tree broken	Overhead Service	Repair		IV
131758223	Q06142	06/24/2013	19:13	06/24/2013	20:22	34	2346	69	Weather	Overhead Primary	Repair	Repair	IV
131758050	Q06142	06/24/2013	19:13	06/25/2013	0:53	76	25840	340	Weather	Overhead Primary	Patrol/Test/Inspect	Repair	IV
131758098	D31017	06/24/2013	19:17	06/24/2013	20:22	66	4290	65	Overhead equipment	Fuse	Replace - Same Size	Repair	III
131758061	D31017	06/24/2013	19:18	06/25/2013	0:05	1	287	287	Tree related-tree broken	Overhead Service	Replace - Same Size	Repair	III
131758065	J12166	06/24/2013	19:19	06/24/2013	19:55	2	72	36	Animal related	Other			III
131758064	J12166	06/24/2013	19:19	06/24/2013	19:30	1	11	11	Animal related	Other			III
131758073	L79159	06/24/2013	19:21	06/24/2013	22:29	1	188	188	Tree related-tree contact	Overhead Service	Repair		IV
131758091	R95520	06/24/2013	19:25	06/25/2013	10:55	1	930	930	Weather				I
131758118	Y20522	06/24/2013	19:38	06/25/2013	2:12	1	394	394	Weather	Overhead Transformer	Replace - Same Size	Replace - Same Size	IV
131758124	R99180	06/24/2013	19:40	06/24/2013	21:39	2	238	119	Tree related-tree contact	Overhead Service	Repair		IV
131758323	R60552	06/24/2013	19:41	06/24/2013	22:00	2	278	139	Weather	Fuse	Replace - Same Size	No Work Required	IV
131758149	Y20522	06/24/2013	19:41	06/24/2013	21:24	11	1133	103	Weather	Fuse	Replace - Same Size		IV
131758135	B25002	06/24/2013	19:44	06/24/2013	23:18	1	214	214	Overhead equipment	Jumper	Repair	No Work Required	I
131758108	J15303	06/24/2013	19:45	06/25/2013	13:55	2	2180	1090	Weather	Pole	Replace - Urgent		I
131758144	M31202	06/24/2013	19:50	06/24/2013	19:53	1	3	3	Tree related-tree broken	Overhead Primary	Reconnect		I
131758194	M25143	06/24/2013	19:53	06/24/2013	23:15	7	1414	202	Weather	Fuse	Replace - Same Size		IV
131758199	Q93522	06/24/2013	19:53	06/25/2013	1:36	34	11662	343	Tree related-tree broken	Overhead Primary	Patrol/Test/Inspect	Repair	I
131758156	E05002	06/24/2013	19:54	06/24/2013	20:38	1	44	44	Weather				IV
131758175	Q93522	06/24/2013	19:55	06/24/2013	23:02	182	34034	187	Tree related-tree broken	Overhead Primary	Patrol/Test/Inspect	Repair	I
131758163	Y68581	06/24/2013	19:58	06/24/2013	21:52	1	114	114	Weather	Transformer Fuse	Replace - Same Size		IV
131758168	R95520	06/24/2013	20:00	06/25/2013	7:52	1	712	712	Tree related-tree broken	Fuse		Replace - Same Size	I
131758178	Z29579	06/24/2013	20:03	06/24/2013	21:25	1	82	82	Weather	Fuse	Replace - Same Size		IV
131758181	B93003	06/24/2013	20:05	06/24/2013	21:05	1	60	60	Animal related	Fuse	Replace - Same Size		I
131758186	N94182	06/24/2013	20:08	06/24/2013	23:35	1	207	207	Overhead equipment				I
131758192		06/24/2013	20:10	06/24/2013	23:37	1	207	207	Overhead equipment	Insulator	Repair		I
131758222	Q34366	06/24/2013	20:21	06/25/2013	4:20	7	3353	479	Weather	Overhead Transformer	Replace - Same Size	Repair	I
131758219	P18104	06/24/2013	20:21	06/24/2013	22:38	1	137	137	Tree related-tree contact	Overhead Secondary	Repair	No Work Required	IV
131758155	X75573	06/24/2013	20:23	06/25/2013	3:15	1	412	412	Tree related-tree broken	Overhead Service	Repair		IV
131758232	Y68581	06/24/2013	20:25	06/24/2013	22:54	1	149	149	Overhead equipment	Overhead Service	Repair		IV
131758258	K65221	06/24/2013	20:41	06/24/2013	22:11	1	90	90	Tree related-tree broken	Tree			III
131758267	R68900	06/24/2013	20:50	06/25/2013	6:50	1	600	600	Tree related-tree contact	Overhead Service	Cut in Clear		I
131758270	R60552	06/24/2013	20:52	06/24/2013	22:37	1	105	105	Weather	Fuse	Replace - Same Size	No Work Required	IV
131758276	N60181	06/24/2013	20:55	06/24/2013	23:00	1	125	125	Weather	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	I
131758274	Z05548	06/24/2013	20:55	06/25/2013	0:45	1	230	230	Weather	Overhead Transformer	Replace - Same Size	Replace - Same Size	IV
131758282	K31124	06/24/2013	20:59	06/25/2013	1:08	1	249	249	Tree related-tree broken	Overhead Service	Repair		I
131758290	L73156	06/24/2013	21:07	06/25/2013	0:35	1	208	208	Overhead equipment	Overhead Transformer	Replace - Same Size		IV
131758303	R07382	06/24/2013	21:17	06/25/2013	3:14	1	357	357	Overhead equipment	Overhead Service	Repair		I
131758304	R34920	06/24/2013	21:18	06/25/2013	3:43	1	385	385	Tree related-tree broken	Tree	Patrol/Test/Inspect	Repair	VI
131758308	R68903	06/24/2013	21:20	06/25/2013	1:58	1	278	278	Weather	Transformer Fuse	Replace - Same Size		I
131758313	J20931	06/24/2013	21:24	06/25/2013	0:15	1	171	171	Overhead equipment	Overhead Transformer	Replace - Same Size	Replace - Same Size	VI
131758315	D96002	06/24/2013	21:28	06/24/2013	23:58	1	150	150	Overhead equipment	Fuse	Replace - Same Size	No Work Required	I
131758329	B45003	06/24/2013	21:58	06/24/2013	22:33	1	35	35	Tree related-tree broken	Overhead Service	Repair		I
131758331	B68004	06/24/2013	22:00	06/25/2013	0:49	1	169	169	Tree related-tree contact	Overhead Service	Replace - Same Size	Repair	III
131758345		06/24/2013	22:18	06/25/2013	8:13	1	595	595	Tree related-tree broken	Recloser	Switch/Reset		I
131758364	D28124	06/24/2013	22:38	06/24/2013	23:27	1	49	49	Overhead equipment	Fuse	Repair		I

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
131764132	B21002	06/24/2013	23:23	06/25/2013	7:44	2	1002	501	Underground equipment	Underground Primary	Repair		I
131758391	B21002	06/24/2013	23:23	06/25/2013	3:25	64	15488	242	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
131760841	Q93522	06/24/2013	23:31	06/25/2013	4:14	20	5660	283	Overhead equipment	Fuse	Repair		I
131758405	C15002	06/24/2013	23:50	06/25/2013	3:25	1	215	215	Overhead equipment	Overhead Transformer	Replace - Same Size	Advise Customer	III
131760633	D35003	06/25/2013	0:24	06/25/2013	5:19	1	295	295	Underground equipment	Underground Transformer	Patrol/Test/Inspect	Replace - Same Size	I
131760642	D88001	06/25/2013	0:53	06/25/2013	2:20	9	783	87	Overhead equipment	Fuse	Replace - Same Size		I
131764153	R50910	06/25/2013	0:55	06/25/2013	6:54	26	9334	359	Weather	Pole	Replace - Same Size		I
131760662	H11340	06/25/2013	1:34	06/25/2013	2:33	2	118	59	Overhead equipment	Recloser	Switch/Reset		V
131760668	D35003	06/25/2013	2:02	06/25/2013	2:05	1	3	3	Unknown	Fuse	Repair		I
131760820	H11340	06/25/2013	2:28	06/25/2013	2:35	3	21	7	Overhead equipment	Recloser	Switch/Reset		V
131760833	K79212	06/25/2013	2:35	06/25/2013	5:12	4	628	157	Tree related-tree broken	Overhead Primary		Repair	IV
131764154	J08205	06/25/2013	4:47	06/25/2013	6:00	1	73	73	Weather	Overhead Transformer	Replace - Same Size		I
131764167	350104	06/25/2013	5:33	06/25/2013	8:10	22	3454	157	Underground equipment	Underground Primary	Switch/Reset	Repair	V
131764200	S55566	06/25/2013	6:19	06/25/2013	7:09	1	50	50	Animal related	Overhead Transformer	Switch/Reset		VI
131764215	J08205	06/25/2013	6:32	06/25/2013	10:01	1	209	209	Weather	Overhead Transformer	Replace - Same Size		I
131764220	L93135	06/25/2013	6:36	06/25/2013	9:02	4	584	146	Animal related	Transformer Fuse	Replace - Same Size		VI
131764235	K28180	06/25/2013	6:48	06/25/2013	8:45	4	468	117	Overhead equipment	Overhead Primary	Repair		III
131764243	C30001	06/25/2013	6:57	06/25/2013	12:38	1	341	341	Underground equipment	Underground Primary			III
131764247	C15002	06/25/2013	6:58	06/25/2013	7:46	1	48	48	Overhead equipment	Fuse	Replace - Same Size	No Work Required	III
131764252	C15002	06/25/2013	7:00	06/25/2013	7:46	1	46	46	Overhead equipment	Fuse	Replace - Same Size	No Work Required	III
131764295	P26283	06/25/2013	7:21	06/25/2013	7:54	1	33	33	Tree related-tree broken	Overhead Service	Disconnect	Reconnect	I
131764314	D90003	06/25/2013	7:29	06/25/2013	8:44	1	75	75	Overhead equipment	Other	Patrol/Test/Inspect	Patrol/Test/Inspect	III
131764394	K31124	06/25/2013	7:35	06/25/2013	9:30	7	805	115	Overhead equipment				I
131764334	K58213	06/25/2013	7:37	06/25/2013	8:47	1	70	70	Animal related	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
131765093	N94180	06/25/2013	7:39	06/25/2013	14:22	22	8866	403	Tree related-tree broken	Overhead Primary	Repair	Repair	I
131764368	K31124	06/25/2013	7:50	06/25/2013	13:23	1	333	333	Overhead equipment	Overhead Transformer	Replace - Same Size	Replace - Same Size	I
131764361	Z17503	06/25/2013	7:50	06/25/2013	8:42	1	52	52	Underground equipment	Underground Primary	Switch/Reset		IV
131764422	L23146	06/25/2013	8:06	06/25/2013	9:38	1	92	92	Overhead equipment	Overhead Service	Repair		III
131764443	K62102	06/25/2013	8:10	06/25/2013	9:18	1	68	68	Overhead equipment	Jumper	Repair		II
131764518	Z04520	06/25/2013	8:27	06/25/2013	10:15	1	108	108	Tree related-tree broken	Tree	Cut in Clear		IV
131764536	D87001	06/25/2013	8:30	06/25/2013	14:28	1	358	358	Underground equipment	Underground Service	Patrol/Test/Inspect	Repair	I
131764547	S36570	06/25/2013	8:34	06/25/2013	11:14	1	160	160	Unknown	Fuse	Replace - Same Size		VI
131764584	J88166	06/25/2013	8:44	06/25/2013	14:03	1	319	319	Public	Underground Service		Repair	VI
131764667	J83140	06/25/2013	9:00	06/25/2013	10:25	1	85	85	Overhead equipment	Overhead Secondary		Repair	VI
131764664	R02121	06/25/2013	9:00	06/25/2013	9:45	1	45	45	Overhead equipment	Fuse	Repair	Repair	VI
131764662	J83140	06/25/2013	9:00	06/25/2013	9:58	1	58	58	Tree related-tree broken	Overhead Service	Replace - Same Size		VI
131764697	Q21423	06/25/2013	9:04	06/25/2013	10:33	1	89	89	Public	Underground Service	Disconnect	Disconnect	VI
131764696	M20221	06/25/2013	9:04	06/25/2013	11:05	1	121	121	Overhead equipment	Fuse	Repair	Repair	VI
131764765	N78244	06/25/2013	9:17	06/25/2013	11:50	1	153	153	Tree related-tree broken	Overhead Primary			I
131764835	S47576	06/25/2013	9:28	06/25/2013	10:43	1	75	75	Overhead equipment	Fuse	Replace - Same Size		VI
131764863	D72001	06/25/2013	9:29	06/25/2013	11:57	20	2960	148	Overhead equipment	Overhead Primary	Repair		I
131764877	Q10702	06/25/2013	9:34	06/25/2013	10:30	1	56	56	Weather	Overhead Transformer	Replace - Same Size	Replace - Same Size	V
131765013	H11340	06/25/2013	9:54	06/25/2013	10:46	1	52	52	Animal related	Fuse	Replace - Same Size		V
131765463		06/25/2013	9:56	06/25/2013	11:18	1	82	82	Weather	Overhead Service			I
131765038	Q11516	06/25/2013	9:58	06/25/2013	10:23	11	275	25	Overhead equipment	Guy Wire	Replace - Same Size	Replace - Same Size	I
131765091	N60181	06/25/2013	10:06	06/25/2013	11:45	1	99	99	Overhead equipment				I
131765185	D55003	06/25/2013	10:24	06/25/2013	10:35	1	11	11	Overhead equipment	Overhead Service	Repair		I
131765282	R16510	06/25/2013	10:42	06/25/2013	12:13	1	91	91	Weather	Fuse	Replace - Same Size	Replace - Same Size	I
131765331	R16510	06/25/2013	10:51	06/25/2013	12:15	4	336	84	Weather	Fuse	Replace - Same Size	Replace - Same Size	I
131765342	D31016	06/25/2013	10:52	06/25/2013	12:01	1	69	69	Tree related-tree contact	Other	Patrol/Test/Inspect	Patrol/Test/Inspect	III
131765390	Q32171	06/25/2013	11:01	06/25/2013	13:30	1	149	149	Overhead equipment	Overhead Primary	Repair	Repair	I
131765399	S27599	06/25/2013	11:03	06/25/2013	12:50	1	107	107	Overhead equipment	Overhead Secondary	Repair	Replace - Same Size	VI
131765429	D35001	06/25/2013	11:06	06/25/2013	12:12	19	1254	66	Tree related-tree broken	Fuse	Replace - Same Size	No Work Required	I
131765431	J98104	06/25/2013	11:09	06/25/2013	13:14	1	125	125	Overhead equipment	Overhead Service		Repair	VI
131765359	N94180	06/25/2013	11:11	06/25/2013	13:10	468	55692	119	Overhead equipment	Pole	Replace - Same Size	Replace - Same Size	I
131765355	N94182	06/25/2013	11:11	06/25/2013	13:10	125	14875	119	Overhead equipment	Pole	Replace - Same Size	Replace - Same Size	I

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
131765493	307005	06/25/2013	11:23	06/25/2013	16:08	7	1995	285	Tree related-tree broken	Tree	Patrol/Test/Inspect	Remove	VI
131765557		06/25/2013	11:39	06/25/2013	13:28	1	109	109	Weather	Fuse	Replace - Same Size		I
131765593	K82202	06/25/2013	11:49	06/25/2013	15:14	1	205	205	Tree related-tree broken	Overhead Secondary			III
131765683	A85001	06/25/2013	12:13	06/25/2013	13:30	7	539	77	Unknown	Fuse	Replace - Same Size		I
131765711	A91004	06/25/2013	12:18	06/25/2013	14:17	4	476	119	Overhead equipment	Transformer Fuse	Replace - Same Size		I
131765723	V45526	06/25/2013	12:20	06/25/2013	14:11	1	111	111	Overhead equipment	Fuse	Patrol/Test/Inspect	Patrol/Test/Inspect	II
131765795	B21002	06/25/2013	12:36	06/25/2013	16:45	1	249	249	Underground equipment	Fuse		Repair	I
131765826	L24124	06/25/2013	12:45	06/25/2013	13:42	1	57	57	Tree related-tree broken	Overhead Service	Repair		III
131765844	Y34596	06/25/2013	12:50	06/25/2013	13:49	1	59	59	Unknown	Transformer Fuse	Replace - Same Size		IV
131764999	D35002	06/25/2013	13:24	06/25/2013	13:53	1	29	29	Tree related-tree broken	Overhead Service	Raise	Reconnect	I
131766075	R73838	06/25/2013	13:44	06/25/2013	14:20	1	36	36	Tree related-tree broken	Overhead Service	Repair		V
131766098	R99180	06/25/2013	13:51	06/25/2013	15:12	1	81	81	Weather	Overhead Transformer		Replace - Same Size	IV
131766113	303001	06/25/2013	13:54	06/25/2013	17:28	1	214	214	Tree related-tree broken	Overhead Service	Advise Customer	Replace - Same Size	VI
131766173	M40131	06/25/2013	14:01	06/25/2013	15:40	12	1188	99	Overhead equipment	Pole	Repair		I
131766251	L68114	06/25/2013	14:18	06/25/2013	14:50	9	288	32	Overhead equipment	Fuse			IV
131766142	J80806	06/25/2013	14:18	06/25/2013	14:59	7	287	41	Overhead equipment	Overhead Transformer		Replace - Same Size	V
131766428	B77003	06/25/2013	15:04	06/25/2013	16:00	1	56	56	Public	Underground Primary	Repair	Repair	I
131766466	N19371	06/25/2013	15:12	06/25/2013	18:53	6	1326	221	Other	Overhead Transformer	Patrol/Test/Inspect	Replace - New Size	V
131766495	C66001	06/25/2013	15:15	06/25/2013	18:11	104	18304	176	Weather				III
131767167	308004	06/25/2013	15:16	06/25/2013	19:11	1	235	235	Tree related-tree broken	Overhead Service	Replace - Same Size		VI
131766512	R48166	06/25/2013	15:18	06/25/2013	16:45	12	1044	87	Underground equipment	Underground Transformer	Replace - Same Size	Replace - Same Size	IV
131766503	D48003	06/25/2013	15:21	06/25/2013	19:26	1	245	245	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Repair	I
131766507	E10003	06/25/2013	15:22	06/25/2013	15:59	1	37	37	Overhead equipment	Fuse	Replace - Same Size	Repair	III
131766524	342002	06/25/2013	15:28	06/25/2013	18:02	5	770	154	Tree related-tree broken	Overhead Service	Replace - Same Size		VI
131766617	C30002	06/25/2013	15:32	06/25/2013	19:47	50	12750	255	Overhead equipment	Overhead Primary	Repair		III
131766560	V17539	06/25/2013	15:40	06/25/2013	17:02	1	82	82	Animal related	Other			II
131766569	Q85162	06/25/2013	15:43	06/25/2013	18:18	2	310	155	Overhead equipment	Overhead Transformer	Repair	Repair	VI
131766627	Y32002	06/25/2013	16:01	06/25/2013	16:48	6	282	47	Overhead equipment	Transformer Fuse	Repair	Replace - Same Size	IV
131766643	U55537	06/25/2013	16:05	06/25/2013	17:45	1	100	100	Weather	Transformer Fuse	Replace - Same Size	No Work Required	II
131766684	Q82907	06/25/2013	16:20	06/25/2013	21:48	1	328	328	Underground equipment	Underground Secondary	Repair	Repair	VI
131766685	B21002	06/25/2013	16:20	06/26/2013	0:13	11	5203	473	Overhead equipment	Overhead Transformer	Repair	Replace - Same Size	I
131766872	N90247	06/25/2013	16:21	06/25/2013	18:18	38	4446	117	Tree related-tree contact				III
131766700	U33586	06/25/2013	16:24	06/25/2013	17:45	1	81	81	Weather	Transformer Fuse	Repair	Repair	II
131766716	C40002	06/25/2013	16:24	06/25/2013	18:30	187	23562	126	Underground equipment	Underground Primary	Switch/Reset	Repair	I
131766726	N90246	06/25/2013	16:26	06/25/2013	17:35	6	414	69	Tree related-tree contact				III
131766878	G10002	06/25/2013	16:35	06/25/2013	17:45	4	280	70	Tree related-tree broken				I
131766753	G10001	06/25/2013	16:35	06/25/2013	18:00	7	595	85	Overhead equipment	Pole	Patrol/Test/Inspect	Replace - Same Size	I
131766805	B68002	06/25/2013	16:50	06/25/2013	18:52	33	4026	122	Weather	Other	Replace - Same Size	Patrol/Test/Inspect	III
131766806	G20002	06/25/2013	16:54	06/25/2013	18:10	28	2128	76	Overhead equipment	Pole	Replace - Same Size		III
131766807	N73121	06/25/2013	16:55	06/25/2013	22:50	1	355	355	Overhead equipment	Overhead Primary	Repair		IV
131766828	X75512	06/25/2013	16:57	06/25/2013	17:27	546	16380	30	Weather	Recloser	Switch/Reset		IV
131766843	R99180	06/25/2013	17:03	06/25/2013	21:13	1	250	250	Weather	Fuse	Replace - Same Size		IV
131766852	X75571	06/25/2013	17:04	06/25/2013	17:24	1	20	20	Weather	Recloser	Switch/Reset		IV
131766879	C30001	06/25/2013	17:12	06/25/2013	19:35	1	143	143	Overhead equipment	Other	No Work Required	No Work Required	III
131767081	P18103	06/25/2013	17:12	06/26/2013	6:45	5	4065	813	Tree related-tree broken				IV
131767753	P18104	06/25/2013	17:19	06/25/2013	17:55	21	756	36	Tree related-tree broken	Overhead Primary	Cut in Clear	Repair	IV
131766931	G10002	06/25/2013	17:23	06/25/2013	19:30	58	7366	127	Tree related-tree broken				I
131766924	E10003	06/25/2013	17:25	06/25/2013	20:20	1	175	175	Overhead equipment	Fuse	Replace - Same Size		III
131770148	P17108	06/25/2013	17:25	06/26/2013	3:28	78	47034	603	Overhead equipment	Overhead Primary			IV
131766944	D90002	06/25/2013	17:33	06/25/2013	21:36	1	243	243	Tree related-tree contact	Other	Patrol/Test/Inspect	Patrol/Test/Inspect	III
131766977	P17108	06/25/2013	17:35	06/26/2013	1:40	21	10185	485	Overhead equipment				IV
131766959	303005	06/25/2013	17:38	06/25/2013	19:00	1	82	82	Public	Overhead Service	Reconnect		VI
131766968	S19554	06/25/2013	17:40	06/25/2013	19:11	1	91	91	Other	Overhead Service	Patrol/Test/Inspect	No Work Required	VI
131766983	P18102	06/25/2013	17:44	06/25/2013	18:58	1	74	74	Tree related-tree contact	Overhead Service	Repair		IV
131766995	H07106	06/25/2013	17:48	06/25/2013	20:07	1	139	139	Weather	Fuse	Replace - Same Size		IV
131767869	M26164	06/25/2013	17:52	06/25/2013	19:31	1	99	99	Weather	Fuse	Replace - Same Size		III

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
131767857	M26164	06/25/2013	17:52	06/26/2013	1:03	2	862	431	Weather	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	III
131767177	J12166	06/25/2013	17:53	06/25/2013	18:43	586	29300	50	Overhead equipment	Overhead Primary	Repair		III
131767054	K39153	06/25/2013	17:55	06/25/2013	18:37	1	42	42	Weather	Fuse	Replace - Same Size		III
131767145	S86582	06/25/2013	17:57	06/25/2013	21:19	1	202	202	Tree related-tree contact	Tree			VI
131767173	D66001	06/25/2013	17:59	06/25/2013	20:12	4	532	133	Tree related-tree broken	Fuse	Replace - Same Size		IV
131767172	U99515	06/25/2013	18:00	06/25/2013	19:30	1	90	90	Weather	Disconnect Switch	Replace - Same Size		II
131767187	D66001	06/25/2013	18:05	06/25/2013	20:12	1	127	127	Tree related-tree broken				IV
131935141	P17107	06/25/2013	18:06	06/25/2013	21:08	1386	252252	182	Weather	Overhead Primary	Switch/Reset	Repair	IV
131767199	R99180	06/25/2013	18:07	06/26/2013	7:23	1	796	796	Weather	Overhead Transformer	Replace - Same Size		IV
131767202	K48384	06/25/2013	18:08	06/25/2013	21:08	4	720	180	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	V
131767282	K71822	06/25/2013	18:12	06/26/2013	0:25	93	34689	373	Tree related-tree broken	Fuse	Replace - Same Size	No Work Required	IV
131768262	J75271	06/25/2013	18:14	06/26/2013	11:04	41	41410	1010	Overhead equipment	Pole		Replace - New Size	IV
131767286	J75271	06/25/2013	18:15	06/26/2013	12:13	1	1078	1078	Weather	Transformer Fuse	Replace - Same Size		IV
131767372	K76543	06/25/2013	18:17	06/26/2013	7:00	142	108346	763	Tree related-tree contact	Pole	Replace - Same Size		IV
131767311	X75571	06/25/2013	18:19	06/25/2013	19:15	1	56	56	Overhead equipment	Overhead Service	Repair		IV
131767232	G10001	06/25/2013	18:20	06/26/2013	5:27	2	1334	667	Overhead equipment	Pole	Replace - New Size	Repair	I
131767325	K71811	06/25/2013	18:21	06/26/2013	14:26	15	18075	1205	Tree related-tree broken	Pole	Patrol/Test/Inspect	Repair	IV
131767651	K76542	06/25/2013	18:24	06/25/2013	20:55	129	19479	151	Weather	Fuse	Replace - Same Size		IV
131767843	K74166	06/25/2013	18:27	06/26/2013	2:09	42	19404	462	Tree related-tree broken	Fuse	Patrol/Test/Inspect	Replace - Same Size	IV
131767662	K74166	06/25/2013	18:29	06/26/2013	8:26	7	5859	837	Overhead equipment	Overhead Transformer	Replace - Same Size		IV
131767665	K74166	06/25/2013	18:30	06/26/2013	2:26	7	3332	476	Weather	Transformer Fuse		Switch/Reset	IV
131767677	Z04520	06/25/2013	18:34	06/25/2013	22:38	2	488	244	Tree related-tree broken	Overhead Service	Advise Customer		IV
131767961	K76542	06/25/2013	18:35	06/25/2013	20:27	80	8960	112	Weather	Overhead Primary	Repair	Remove	IV
131767683	Q06132	06/25/2013	18:36	06/26/2013	3:50	1	554	554	Tree related-tree broken	Tree	Patrol/Test/Inspect	Remove	IV
131767704	K71811	06/25/2013	18:38	06/25/2013	20:24	46	4876	106	Tree related-tree broken	Fuse	Replace - Same Size	No Work Required	IV
131767696	P69173	06/25/2013	18:38	06/25/2013	22:00	60	12120	202	Weather	Overhead Primary	Repair		III
131768219	P17108	06/25/2013	18:39	06/26/2013	6:05	2	1372	686	Weather	Lightning Arrestor		Replace - Same Size	IV
131768113	X38791	06/25/2013	18:40	06/25/2013	21:26	1	166	166	Overhead equipment	Pole	Replace - Same Size		IV
131767698	K75311	06/25/2013	18:40	06/26/2013	1:40	1	420	420	Tree related-tree broken	Overhead Service	Cut in Clear		IV
131768062	X38791	06/25/2013	18:40	06/25/2013	20:43	1337	164451	123	Overhead equipment				IV
131767711	X38791	06/25/2013	18:40	06/25/2013	22:35	552	129720	235	Overhead equipment				IV
131767715	E10001	06/25/2013	18:43	06/25/2013	20:20	1	97	97	Overhead equipment	Fuse	Replace - Same Size	Repair	III
131767719	Q06132	06/25/2013	18:43	06/26/2013	3:54	27	14877	551	Tree related-tree broken	Overhead Primary	Patrol/Test/Inspect	Trim	IV
131767712	V44504	06/25/2013	18:44	06/25/2013	22:30	1	226	226	Underground equipment	Underground Service	Repair	Repair	II
131767718	K89142	06/25/2013	18:46	06/26/2013	1:50	8	3392	424	Weather	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	III
131767767	V23592	06/25/2013	18:50	06/25/2013	20:35	12	1260	105	Overhead equipment	Lightning Arrestor	Patrol/Test/Inspect	Repair	II
131767738	Y28597	06/25/2013	18:51	06/26/2013	4:27	1	576	576	Tree related-tree broken	Overhead Service	Repair	Replace - Same Size	IV
131767740	Q06131	06/25/2013	18:52	06/25/2013	22:07	1	195	195	Tree related-tree broken	Overhead Service	Repair	No Work Required	IV
131767749	K76541	06/25/2013	18:54	06/26/2013	9:12	1	858	858	Tree related-tree broken	Overhead Service			IV
131767746	Y28597	06/25/2013	18:54	06/26/2013	4:25	10	5710	571	Tree related-tree broken	Overhead Primary	Repair	Replace - Same Size	IV
131767759	Y93002	06/25/2013	18:56	06/25/2013	20:00	66	4224	64	Overhead equipment	Fuse	Repair	Replace - Same Size	IV
131767827	P18104	06/25/2013	19:00	06/25/2013	21:22	470	66740	142	Tree related-tree contact				IV
131767778	K28183	06/25/2013	19:04	06/25/2013	22:29	1	205	205	Weather	Fuse	Replace - Same Size		III
131767786	R20501	06/25/2013	19:07	06/26/2013	3:25	1	498	498	Weather	Overhead Primary	Repair		IV
131767803	R48166	06/25/2013	19:08	06/25/2013	21:30	70	9940	142	Tree related-tree broken	Overhead Primary	Replace - Same Size		IV
131767824	M25144	06/25/2013	19:12	06/25/2013	22:17	1	185	185	Weather	Fuse	Replace - Same Size		IV
131767953	D67001	06/25/2013	19:17	06/25/2013	23:47	10	2700	270	Weather	Fuse	Replace - Same Size		IV
131767838	D66002	06/25/2013	19:18	06/25/2013	21:55	1	157	157	Weather	Lightning Arrestor	Replace - Same Size		IV
131767849	K79213	06/25/2013	19:22	06/25/2013	22:21	1	179	179	Tree related-tree broken	Overhead Service	Cut in Clear		IV
131767860	H07106	06/25/2013	19:27	06/25/2013	20:10	1	43	43	Weather	Fuse	Replace - Same Size		IV
131767864	V67001	06/25/2013	19:29	06/25/2013	20:47	1	78	78	Weather	Lightning Arrestor			II
131767872	L71171	06/25/2013	19:32	06/26/2013	0:45	1	313	313	Tree related-tree broken	Tree			IV
131767870	K79212	06/25/2013	19:32	06/26/2013	2:31	1	419	419	Tree related-tree broken	Overhead Service	Cut in Clear	No Work Required	IV
131767874	M26164	06/25/2013	19:35	06/25/2013	19:46	1	11	11	Weather	Transformer Fuse	Replace - Same Size		III
131767879	K69112	06/25/2013	19:38	06/26/2013	4:07	4	2036	509	Weather	Riser	Switch/Reset	Repair	IV
131767929	Y10011	06/25/2013	19:51	06/25/2013	21:40	11	1199	109	Weather	Fuse	Replace - Same Size		IV

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
131767909	L35282	06/25/2013	19:56	06/25/2013	23:10	2	388	194	Overhead equipment	Jumper	Repair		III
131767962	J75271	06/25/2013	20:12	06/26/2013	9:15	2	1566	783	Overhead equipment	Transformer Fuse		Repair	IV
131767970	X29002	06/25/2013	20:13	06/25/2013	21:19	1	66	66	Tree related-tree broken	Overhead Service	Repair		IV
131767972	Y97514	06/25/2013	20:14	06/26/2013	0:45	1	271	271	Weather	Lightning Arrestor	Replace - Same Size		IV
131767982	K71812	06/25/2013	20:23	06/26/2013	0:56	1	273	273	Overhead equipment	Overhead Service			IV
131767707	P17107	06/25/2013	20:24	06/25/2013	21:08	107	4708	44	Weather	Overhead Primary	Switch/Reset	Repair	IV
131767992	K28183	06/25/2013	20:29	06/25/2013	21:17	1	48	48	Weather	Overhead Transformer		Replace - Same Size	III
131767997	K76542	06/25/2013	20:29	06/25/2013	22:08	80	7920	99	Tree related-tree broken				IV
131768008	R01153	06/25/2013	20:29	06/25/2013	21:20	97	4947	51	Weather	Fuse			III
131767998	F22001	06/25/2013	20:32	06/26/2013	9:43	1	791	791	Weather	Connector	Repair		IV
131768024	J12166	06/25/2013	20:37	06/25/2013	21:30	52	2756	53	Overhead equipment	Fuse	Replace - Same Size		III
131768026	U01514	06/25/2013	20:39	06/25/2013	22:57	11	1518	138	Overhead equipment	Transformer Fuse	Replace - Same Size		II
131768041	D31016	06/25/2013	20:53	06/25/2013	21:37	1	44	44	Overhead equipment	Fuse	Replace - Same Size	Repair	III
131768044	J01118	06/25/2013	20:55	06/26/2013	4:00	1	425	425	Overhead equipment	Pole	Replace - Same Size	Replace - Same Size	I
131768042		06/25/2013	20:55	06/25/2013	22:02	1	67	67	Overhead equipment	Fuse	Replace - Same Size		I
131768046	R59412	06/25/2013	20:56	06/26/2013	3:30	1	394	394	Tree related-tree broken	Overhead Service	Patrol/Test/Inspect	Cut in Clear	IV
131768048	U01514	06/25/2013	20:57	06/26/2013	0:16	1	199	199	Tree related-tree broken	Overhead Service			II
131768055	Q32171	06/25/2013	21:06	06/25/2013	22:15	1	69	69	Overhead equipment	Overhead Primary	Cut in Clear		I
131768058	K76542	06/25/2013	21:07	06/26/2013	3:02	1	355	355	Weather	Transformer Fuse	Replace - Same Size	No Work Required	IV
131768085	J01118	06/25/2013	21:07	06/25/2013	23:45	11	1738	158	Tree related-tree broken	Overhead Primary	Repair		I
131768061	X81555	06/25/2013	21:11	06/26/2013	7:20	1	609	609	Weather	Fuse	Repair	Replace - Same Size	IV
131768070	J01118	06/25/2013	21:14	06/26/2013	0:01	1	167	167	Tree related-tree broken	Overhead Primary	Repair		I
131768068	U01514	06/25/2013	21:14	06/26/2013	2:25	1	311	311	Weather	Disconnect Switch	Raise		II
131768115	R01153	06/25/2013	21:34	06/25/2013	21:41	1	7	7	Weather	Fuse			III
131768142	K39156	06/25/2013	21:34	06/25/2013	23:16	90	9180	102	Weather	Fuse	Replace - Same Size		III
131768131	P18104	06/25/2013	21:34	06/25/2013	22:55	21	1701	81	Tree related-tree contact	Overhead Primary	Repair	Repair	IV
131768124	P18104	06/25/2013	21:35	06/26/2013	0:34	7	1253	179	Tree related-tree contact	Fuse	Replace - Same Size	No Work Required	IV
131768128	P18104	06/25/2013	21:40	06/25/2013	23:23	4	412	103	Weather				IV
131768135	K39154	06/25/2013	21:42	06/25/2013	22:42	1	60	60	Weather	Fuse	Replace - Same Size		III
131768151	P17108	06/25/2013	21:48	06/26/2013	2:59	14	4354	311	Weather	Fuse		Replace - Same Size	IV
131768154	B25002	06/25/2013	21:49	06/25/2013	23:54	15	1875	125	Tree related-tree broken	Tree	Remove		I
131768162	B25001	06/25/2013	21:54	06/25/2013	23:07	6	438	73	Overhead equipment	Fuse	Replace - Same Size	Patrol/Test/Inspect	I
131768172	B00005	06/25/2013	22:05	06/26/2013	1:38	33	7029	213	Weather	Fuse	Replace - Same Size		I
131768169		06/25/2013	22:07	06/25/2013	22:21	1	14	14	Overhead equipment	Other	No Work Required		IV
131768186	A91002	06/25/2013	22:10	06/25/2013	23:30	46	3680	80	Overhead equipment	Fuse	Replace - Same Size	No Work Required	I
131768176	D41003	06/25/2013	22:11	06/26/2013	0:27	1	136	136	Overhead equipment	Fuse	Replace - Same Size	No Work Required	I
131768182	Y01524	06/25/2013	22:14	06/25/2013	23:54	1	100	100	Tree related-tree broken	Tree	Patrol/Test/Inspect		IV
131768193	D41003	06/25/2013	22:18	06/26/2013	0:18	1	120	120	Overhead equipment	Fuse	Replace - Same Size	No Work Required	I
131768191	J01118	06/25/2013	22:18	06/26/2013	0:51	1	153	153	Weather	Transformer Fuse	Replace - Same Size		I
131770227	D01001	06/25/2013	22:29	06/26/2013	3:59	3	990	330	Overhead equipment	Overhead Primary	Repair		I
131768231	D01001	06/25/2013	22:29	06/26/2013	0:55	23	3358	146	Overhead equipment	Overhead Primary		Repair	I
131768227	G10002	06/25/2013	22:30	06/25/2013	23:10	37	1480	40	Weather	Fuse	Replace - Same Size		I
131768234	Y73504	06/25/2013	22:35	06/25/2013	23:15	1	40	40	Weather	Overhead Transformer		Replace - Same Size	IV
131768268	Z21564	06/25/2013	22:37	06/26/2013	0:15	7	686	98	Overhead equipment	Transformer Fuse	Repair	Replace - Same Size	IV
131768283	H07106	06/25/2013	22:41	06/26/2013	3:51	165	51150	310	Overhead equipment				IV
131768244	L42158	06/25/2013	22:43	06/26/2013	3:52	83	25647	309	Overhead equipment	Recloser	Switch/Reset		III
131770135	R99180	06/25/2013	22:43	06/26/2013	1:47	17	3128	184	Overhead equipment				IV
131773680	P52305	06/25/2013	22:48	06/26/2013	7:31	84	43932	523	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
131768265	K76542	06/25/2013	22:53	06/25/2013	23:21	1	28	28	Tree related-tree broken	Overhead Service	Cut in Clear	No Work Required	IV
131768273	Y54002	06/25/2013	23:05	06/26/2013	0:32	1	87	87	Tree related-tree contact	Overhead Service	Repair		IV
131768311	H07106	06/25/2013	23:06	06/26/2013	5:00	36	12744	354	Weather				IV
131768282	K76542	06/25/2013	23:14	06/26/2013	1:16	7	854	122	Tree related-tree broken	Fuse	Replace - Same Size	No Work Required	IV
131768297	B57002	06/25/2013	23:19	06/26/2013	0:25	46	3036	66	Animal related	Transformer Fuse	Replace - Same Size		I
131768290	P18103	06/25/2013	23:22	06/26/2013	6:22	1	420	420	Animal related	Transformer Fuse	Replace - Same Size		IV
131768291	Y73504	06/25/2013	23:24	06/26/2013	8:49	1	565	565	Weather	Overhead Transformer		Replace - Same Size	IV
131768293	H07106	06/25/2013	23:25	06/26/2013	5:37	5	1860	372	Weather	Fuse	Replace - Same Size		IV

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
131768300	D93002	06/25/2013	23:33	06/26/2013	7:26	6	2838	473	Weather	Fuse	Patrol/Test/Inspect	Replace - Same Size	IV
131768332	H00163	06/25/2013	23:34	06/26/2013	3:03	56	11704	209	Underground equipment	Underground Primary			III
131768343	Y97513	06/25/2013	23:34	06/26/2013	6:12	49	19502	398	Tree related-tree broken				IV
131768312	Y97512	06/25/2013	23:39	06/26/2013	3:10	1	211	211	Tree related-tree broken	Overhead Secondary	Repair		IV
131770193	X38792	06/25/2013	23:40	06/26/2013	1:43	1487	182901	123	Overhead equipment				IV
131768319	X38792	06/25/2013	23:40	06/26/2013	3:10	37	7770	210	Overhead equipment				IV
131768342	R66472	06/25/2013	23:51	06/26/2013	4:00	45	11205	249	Underground equipment	Underground Primary	Switch/Reset	Repair	IV
131768329	Z20542	06/25/2013	23:52	06/26/2013	5:15	1	323	323	Weather	Fuse	Replace - Same Size		IV
131770107	K62102	06/25/2013	23:53	06/26/2013	4:45	13	3796	292	Underground equipment	Underground Primary	Switch/Reset	Repair	II
131770090	Z20542	06/26/2013	0:03	06/26/2013	4:45	1	282	282	Weather	Fuse	Replace - Same Size		IV
131770097	K39156	06/26/2013	0:08	06/26/2013	4:30	1	262	262	Overhead equipment	Overhead Primary	Patrol/Test/Inspect	Repair	III
131770099	D93002	06/26/2013	0:09	06/26/2013	7:25	7	3052	436	Weather	Fuse	Patrol/Test/Inspect	Replace - Same Size	IV
131770111	J01118	06/26/2013	0:23	06/26/2013	1:10	1	47	47	Tree related-tree broken	Tree	Cut in Clear		I
131770134	Z20543	06/26/2013	0:27	06/26/2013	7:12	1	405	405	Weather	Fuse	Replace - Same Size		IV
131770131	Z05001	06/26/2013	0:43	06/26/2013	2:01	246	19188	78	Tree related-tree broken	Substation Breaker	Switch/Reset		IV
131770137	P18103	06/26/2013	0:56	06/26/2013	4:00	1	184	184	Weather	Transformer Fuse	Replace - Same Size		IV
131770136	Z06537	06/26/2013	0:56	06/26/2013	4:02	6	1116	186	Overhead equipment	Transformer Fuse	Replace - Same Size	Patrol/Test/Inspect	IV
131773572	D35002	06/26/2013	1:15	06/26/2013	10:49	9	5166	574	Underground equipment	Underground Primary	Repair	Repair	I
131770144	Z06537	06/26/2013	1:37	06/26/2013	9:35	1	478	478	Overhead equipment	Pole	Replace - New Size	Replace - New Size	IV
131770168	C30002	06/26/2013	1:49	06/26/2013	7:12	1	323	323	Overhead equipment	Overhead Transformer	Replace - Same Size		III
131770171	G10002	06/26/2013	1:56	06/26/2013	2:56	16	960	60	Weather	Fuse	Replace - Same Size		I
131773436	X09594	06/26/2013	2:00	06/26/2013	2:20	198	3960	20	Overhead equipment	Pole	Switch/Reset		IV
131770175	K76542	06/26/2013	2:07	06/26/2013	9:52	2	930	465	Overhead equipment	Overhead Transformer		Replace - Same Size	IV
131770142	D35002	06/26/2013	2:32	06/26/2013	5:30	22	3916	178	Underground equipment	Underground Primary	Repair		I
131773388	K75311	06/26/2013	2:45	06/26/2013	4:43	55	6490	118	Weather	Fuse			IV
131770238	N58144	06/26/2013	2:58	06/26/2013	4:29	1	91	91	Overhead equipment	Fuse	Patrol/Test/Inspect	Replace - Same Size	I
131770286	K05253	06/26/2013	3:19	06/26/2013	5:20	482	58322	121	Other				VI
131770273	M26164	06/26/2013	3:28	06/26/2013	5:00	40	3680	92	Underground equipment	Underground Primary		Repair	III
131770275		06/26/2013	3:35	06/26/2013	13:40	1	605	605	Overhead equipment	Pole		Replace - Same Size	VI
131770287	K79213	06/26/2013	3:53	06/26/2013	5:25	1	92	92	Overhead equipment	Overhead Service			IV
131770276	X09594	06/26/2013	4:10	06/26/2013	11:41	51	23001	451	Overhead equipment	Pole			IV
131773396	V82002	06/26/2013	4:14	06/26/2013	6:50	2	312	156	Weather	Transformer Fuse	Replace - Same Size		II
131773408	R60552	06/26/2013	4:22	06/26/2013	6:20	1	118	118	Weather	Lightning Arrestor	Replace - Same Size	No Work Required	IV
131773462	Y97512	06/26/2013	4:56	06/26/2013	6:36	9	900	100	Tree related-tree broken	Overhead Primary	Trim		IV
131773458	P52305	06/26/2013	5:00	06/26/2013	9:43	1	283	283	Weather	Overhead Transformer	Replace - Same Size		IV
131773464	X86546	06/26/2013	5:08	06/26/2013	6:40	1	92	92	Overhead equipment	Transformer Fuse			IV
131773465	X09557	06/26/2013	5:09	06/26/2013	7:35	1	146	146	Weather	Fuse	Repair	Replace - Same Size	IV
131773567	V23530	06/26/2013	5:10	06/26/2013	7:18	13	1664	128	Tree related-tree broken	Overhead Primary	Patrol/Test/Inspect	Repair	II
131774075	303007	06/26/2013	5:20	06/26/2013	10:30	329	101990	310	Overhead equipment	Pole	Patrol/Test/Inspect	Replace - Same Size	VI
131773490	D93002	06/26/2013	5:26	06/26/2013	7:54	1	148	148	Unknown	Transformer Fuse	Replace - Same Size		IV
131773496	303004	06/26/2013	5:29	06/26/2013	8:50	1	201	201	Public	Pole	Patrol/Test/Inspect	Replace - Same Size	VI
131773513	Y97514	06/26/2013	5:43	06/26/2013	7:48	1	125	125	Weather	Fuse	Replace - Same Size		IV
131773841	J75272	06/26/2013	5:45	06/26/2013	8:00	20	2700	135	Weather	Fuse	Replace - Same Size	No Work Required	IV
131773524	Q91175	06/26/2013	5:55	06/26/2013	7:30	1	95	95	Tree related-tree broken	Pole	Replace - Same Size	Replace - Same Size	I
131773529	J75271	06/26/2013	6:02	06/26/2013	11:04	1	302	302	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
131773549	U66515	06/26/2013	6:12	06/26/2013	7:40	1	88	88	Unknown	Fuse	Replace - Same Size		II
131773639	R93351	06/26/2013	6:22	06/26/2013	9:08	11	1826	166	Weather	Jumper	Repair		V
131773588	324002	06/26/2013	6:26	06/26/2013	8:15	1	109	109	Overhead equipment	Transformer Fuse	Replace - Same Size		VI
131773608	K09864	06/26/2013	6:26	06/26/2013	10:35	103	25647	249	Tree related-tree broken	Overhead Primary	Repair	Repair	V
131773554	H22346	06/26/2013	6:29	06/26/2013	11:39	1	310	310	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	V
131773617	J75271	06/26/2013	6:32	06/26/2013	8:13	1	101	101	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
131773619	P12290	06/26/2013	6:34	06/26/2013	10:28	1	234	234	Weather	Crossarm	Replace - Same Size	Replace - Same Size	V
131773620	R33126	06/26/2013	6:36	06/26/2013	10:08	1	212	212	Weather	Overhead Transformer	Replace - Same Size	Replace - Same Size	I
131773625		06/26/2013	6:37	06/26/2013	8:37	1	120	120	Weather	Fuse	Replace - Same Size		V
131773632	M36189	06/26/2013	6:38	06/26/2013	7:55	55	4235	77	Overhead equipment	Recloser	Switch/Reset		I
131773635	312111	06/26/2013	6:40	06/26/2013	10:18	1	218	218	Tree related-tree broken	Overhead Service		Repair	V

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
131773636	P52305	06/26/2013	6:41	06/26/2013	18:59	1	738	738	Underground equipment	Underground Primary		Repair	IV
131773643	R94269	06/26/2013	6:45	06/26/2013	8:19	1	94	94	Overhead equipment	Transformer Fuse	Replace - Same Size		VI
131773649	K01240	06/26/2013	6:47	06/26/2013	7:39	1	52	52	Weather				VI
131773651	K80388	06/26/2013	6:48	06/26/2013	17:55	2	1334	667	Weather	Overhead Transformer	Patrol/Test/Inspect	Repair	IV
131773662	312111	06/26/2013	6:49	06/26/2013	9:40	22	3762	171	Weather	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	V
131773663	L93135	06/26/2013	6:52	06/26/2013	7:48	1	56	56	Overhead equipment	Transformer Fuse	Repair	Repair	VI
131773670	X75573	06/26/2013	6:57	06/26/2013	10:20	1	203	203	Weather	Fuse	Replace - Same Size		IV
131773683	L99392	06/26/2013	6:57	06/26/2013	13:40	20	8060	403	Tree related-tree broken	Overhead Primary	Patrol/Test/Inspect	Patrol/Test/Inspect	V
131773673	D67001	06/26/2013	7:00	06/26/2013	9:18	1	138	138	Weather	Customer Equipment	Switch/Reset		IV
131773679	S14510	06/26/2013	7:03	06/26/2013	7:35	1	32	32	Animal related	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
131773705	Q63835	06/26/2013	7:09	06/26/2013	9:06	3	351	117	Tree related-tree broken	Overhead Service	Repair		V
131773724	K94223	06/26/2013	7:12	06/26/2013	8:17	1	65	65	Overhead equipment	Pole		Repair	III
131773731	A85001	06/26/2013	7:14	06/26/2013	14:06	1	412	412	Weather	Overhead Transformer	Replace - Same Size	Repair	I
131773787	P26281	06/26/2013	7:14	06/26/2013	8:20	17	1122	66	Animal related	Fuse	Repair		I
131773740	V82002	06/26/2013	7:15	06/26/2013	7:22	1	7	7	Weather				II
131773746	K91115	06/26/2013	7:18	06/26/2013	8:40	1	82	82	Tree related-tree contact	Overhead Service	Repair		III
131773791	Y97513	06/26/2013	7:31	06/26/2013	8:35	1	64	64	Weather	Transformer Fuse	Replace - Same Size		IV
131773790	K79213	06/26/2013	7:31	06/26/2013	12:38	1	307	307	Tree related-tree broken				IV
131773795	J80806	06/26/2013	7:31	06/26/2013	9:27	1	116	116	Overhead equipment	Overhead Primary	Repair	Repair	V
131774131	B93002	06/26/2013	7:35	06/26/2013	9:27	60	6720	112	Tree related-tree broken	Tree			I
131774057	B93002	06/26/2013	7:35	06/26/2013	11:00	42	8610	205	Tree related-tree broken	Tree	Cut in Clear		I
131773849	K80381	06/26/2013	7:45	06/26/2013	13:00	1	315	315	Weather	Transformer Fuse	Replace - Same Size		IV
131773859	P17107	06/26/2013	7:49	06/26/2013	12:02	1	253	253	Overhead equipment	Jumper	Tie/Tighten	No Work Required	IV
131773862	D35003	06/26/2013	7:50	06/26/2013	10:06	1	136	136	Overhead equipment	Overhead Primary	Repair		I
131773866	K35308	06/26/2013	7:52	06/26/2013	10:04	1	132	132	Overhead equipment	Fuse	Replace - Same Size		III
131773883	R49263	06/26/2013	7:55	06/26/2013	8:55	1	60	60	Weather	Lightning Arrestor	Replace - Same Size	Patrol/Test/Inspect	VI
131773889	K31124	06/26/2013	7:56	06/26/2013	8:49	1	53	53	Tree related-tree contact	Fuse	Replace - Same Size		I
131773972	X99701	06/26/2013	8:02	06/26/2013	10:11	2	258	129	Tree related-tree broken	Tree	Remove		IV
131774515	Q93522	06/26/2013	8:08	06/26/2013	9:43	4	380	95	Tree related-tree broken	Overhead Primary	Switch/Reset		I
131773933	U99593	06/26/2013	8:08	06/26/2013	9:58	1	110	110	Tree related-tree contact	Overhead Service	Repair		II
131773936	Q93522	06/26/2013	8:08	06/26/2013	13:09	22	6622	301	Tree related-tree broken	Tree	Cut in Clear		I
131773946	J01118	06/26/2013	8:10	07/01/2013	7:58	9	64692	7188	Tree related-tree broken	Tree		Remove	I
131773970	M36189	06/26/2013	8:11	06/26/2013	9:59	55	5940	108	Tree related-tree contact	Tree	Cut in Clear		I
131773962	P53341	06/26/2013	8:14	06/26/2013	11:00	1	166	166	Weather	Fuse	Patrol/Test/Inspect	Replace - Same Size	IV
131773993	P62138	06/26/2013	8:22	06/26/2013	10:13	1	111	111	Overhead equipment	Fuse	Replace - Same Size	No Work Required	VI
131774206	V82002	06/26/2013	8:23	06/26/2013	9:32	1	69	69	Weather	Fuse	Replace - Same Size		II
131774016	R60551	06/26/2013	8:27	06/26/2013	11:15	1	168	168	Overhead equipment	Overhead Transformer	Replace - Same Size	Repair	IV
131774628	N18211	06/26/2013	8:28	06/26/2013	10:57	634	94466	149	Overhead equipment	Pole	Switch/Reset		III
131774564	N18211	06/26/2013	8:28	06/26/2013	16:31	97	46851	483	Overhead equipment	Pole	Replace - Same Size		III
131774061	N18211	06/26/2013	8:28	06/26/2013	9:59	63	5733	91	Overhead equipment	Pole	Switch/Reset		III
131773977	R50910	06/26/2013	8:33	06/26/2013	12:35	7	1694	242	Tree related-tree broken	Overhead Primary	Repair	No Work Required	I
131774066	K75311	06/26/2013	8:34	06/26/2013	16:26	1	472	472	Tree related-tree broken	Overhead Service	Repair		IV
131774079		06/26/2013	8:37	06/26/2013	9:15	1	38	38	Tree related-tree broken	Overhead Service	Cut in Clear		III
131774076	R04413	06/26/2013	8:37	06/26/2013	9:27	1	50	50	Weather				V
131774093	J75271	06/26/2013	8:41	06/26/2013	14:30	1	349	349	Weather	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	IV
131774148	M07235	06/26/2013	8:43	06/26/2013	13:14	13	3523	271	Tree related-tree broken	Overhead Secondary		Repair	III
131774116	D55003	06/26/2013	8:47	06/26/2013	10:56	1	129	129	Tree related-tree contact	Overhead Service	Repair		I
131774142	P73182	06/26/2013	8:51	06/26/2013	10:41	1	110	110	Weather	Transformer Fuse			VI
131774173	X09557	06/26/2013	8:55	06/26/2013	13:30	1	275	275	Weather	Overhead Transformer	Replace - Same Size		IV
131774221	P26284	06/26/2013	9:06	06/26/2013	10:27	1	81	81	Tree related-tree contact	Overhead Service	Tie/Tighten	Repair	I
131774235	M07236	06/26/2013	9:07	06/26/2013	10:20	1	73	73	Tree related-tree contact	Fuse	Repair		III
131774243	J39392	06/26/2013	9:08	06/26/2013	11:54	1	166	166	Weather	Pole			III
131774246	X75571	06/26/2013	9:09	06/26/2013	11:53	1	164	164	Overhead equipment	Disconnect Switch	Replace - Same Size	Repair	IV
131774263	J86108	06/26/2013	9:13	06/26/2013	10:26	1	73	73	Overhead equipment	Fuse	Repair	Repair	VI
131774269	V45574	06/26/2013	9:16	06/26/2013	10:02	1	46	46	Overhead equipment	Transformer Fuse	Replace - Same Size		II
131774303	J75271	06/26/2013	9:24	06/26/2013	10:55	1	91	91	Overhead equipment	Transformer Fuse	Replace - Same Size	No Work Required	IV

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
131774336	K05253	06/26/2013	9:29	06/26/2013	9:52	1	23	23	Underground equipment	Underground Service	Patrol/Test/Inspect	Repair	VI
131774356	M07235	06/26/2013	9:32	06/26/2013	11:45	1	133	133	Other	Overhead Primary	Repair		III
131774383	U01514	06/26/2013	9:38	06/26/2013	10:15	1	37	37	Tree related-tree broken	Overhead Service	Cut in Clear	Cut in Clear	II
131774390	X09557	06/26/2013	9:39	06/26/2013	10:31	1	52	52	Overhead equipment	Fuse	No Work Required	No Work Required	IV
131774398	P52305	06/26/2013	9:41	06/26/2013	12:25	1	164	164	Overhead equipment	Overhead Transformer		Replace - Same Size	IV
131774418	N05172	06/26/2013	9:46	06/26/2013	12:34	1	168	168	Weather	Overhead Transformer	Replace - Same Size		I
131774425	H22346	06/26/2013	9:48	06/26/2013	11:30	1	102	102	Weather			No Work Required	V
131774526	Q01280	06/26/2013	9:52	06/26/2013	11:10	778	60684	78	Animal related	Substation Transformer	Switch/Reset		III
131774507	C50001	06/26/2013	9:56	06/28/2013	13:35	1	3099	3099	Underground equipment	Underground Service			III
131774511	U09557	06/26/2013	9:57	06/26/2013	10:45	7	336	48	Unknown	Fuse	Replace - Same Size		II
131775079	B38001	06/26/2013	10:16	06/26/2013	14:22	2	492	246	Weather	Overhead Transformer	Patrol/Test/Inspect	Repair	I
131774705	B38001	06/26/2013	10:16	06/26/2013	11:40	10	840	84	Overhead equipment	Fuse	Replace - Same Size	No Work Required	I
131774631	Q04411	06/26/2013	10:17	06/26/2013	11:08	1	51	51	Animal related	Other			III
131774714	Q27186	06/26/2013	10:34	06/26/2013	11:31	1	57	57	Weather	Fuse	Repair		VI
131774781	J83138	06/26/2013	10:49	06/26/2013	11:51	1	62	62	Overhead equipment	Transformer Fuse	Repair	Repair	VI
131774850	D01001	06/26/2013	11:00	06/26/2013	12:38	1	98	98	Overhead equipment	Fuse	Repair	Replace - New Size	I
131774864	K89143	06/26/2013	11:02	06/26/2013	11:28	1	26	26	Unknown	Fuse	Replace - Same Size		III
131774894	L95110	06/26/2013	11:08	06/26/2013	12:23	1	75	75	Tree related-tree contact	Tree	Trim		III
131774899	D32212	06/26/2013	11:09	06/26/2013	12:04	1	55	55	Overhead equipment	Fuse	Repair		I
131774949	J75271	06/26/2013	11:20	06/26/2013	15:45	1	265	265	Weather	Pole		Repair	IV
131775018	J75271	06/26/2013	11:21	06/26/2013	13:42	7	987	141	Weather	Fuse	Replace - Same Size		IV
131774986	S57502	06/26/2013	11:25	06/26/2013	19:21	1	476	476	Underground equipment	Underground Service	Repair	Replace - Same Size	VI
131774990	Y45504	06/26/2013	11:26	06/26/2013	14:12	1	166	166	Tree related-tree contact	Overhead Service	Repair	Replace - Same Size	IV
131775505	H11340	06/26/2013	11:27	06/26/2013	13:59	152	23104	152	Tree related-tree contact	Overhead Primary			V
131775004	Y23513	06/26/2013	11:28	06/26/2013	12:07	1	39	39	Overhead equipment	Fuse	Repair	Replace - Same Size	IV
131775017	M07236	06/26/2013	11:30	06/26/2013	13:42	1	132	132	Tree related-tree contact	Overhead Service	Repair		III
131775031	X34532	06/26/2013	11:31	06/26/2013	12:21	1	50	50	Weather	Disconnect Switch	Repair	Replace - Same Size	IV
131775103	Q04411	06/26/2013	11:44	06/26/2013	13:07	8	664	83	Animal related	Transformer Fuse			III
131775104	P82290	06/26/2013	11:44	06/26/2013	12:40	1	56	56	Weather	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
131775117	J14140	06/26/2013	11:47	06/26/2013	12:46	1	59	59	Weather	Fuse	Replace - Same Size		VI
131775710	D93001	06/26/2013	11:50	06/26/2013	15:05	2	390	195	Weather	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	IV
131775178	L86175	06/26/2013	12:00	06/26/2013	15:48	1	228	228	Underground equipment	Underground Service	Repair		IV
131775195	K91117	06/26/2013	12:01	06/26/2013	13:24	40	3320	83	Unknown	Fuse	Replace - Same Size		III
131775230	R07381	06/26/2013	12:11	06/26/2013	16:37	16	4256	266	Tree related-tree broken	Tree	Cut in Clear	Cut in Clear	I
131775241	M07236	06/26/2013	12:14	06/26/2013	13:45	1	91	91	Tree related-tree contact	Overhead Service	Repair		III
131775239	S60581	06/26/2013	12:14	06/26/2013	13:40	1	86	86	Other	Disconnect Switch	Patrol/Test/Inspect	Replace - Same Size	VI
131775253	B61001	06/26/2013	12:20	06/26/2013	14:02	1	102	102	Overhead equipment	Lightning Arrestor	Replace - Same Size	No Work Required	I
131775264	R33126	06/26/2013	12:22	06/26/2013	13:30	1	68	68	Weather	Transformer Fuse	Replace - Same Size	Replace - Same Size	I
131775294	L63936	06/26/2013	12:30	06/26/2013	13:24	1	54	54	Tree related-tree broken	Overhead Service	Repair		VI
131775300	Z19547	06/26/2013	12:31	06/26/2013	13:10	1	39	39	Weather	Transformer Fuse	Replace - Same Size		IV
131775309	L00133	06/26/2013	12:32	06/26/2013	14:30	2	236	118	Overhead equipment	Pole	Patrol/Test/Inspect	Repair	III
131775315	J75271	06/26/2013	12:34	06/26/2013	15:40	1	186	186	Weather	Overhead Transformer	Replace - Same Size		IV
131775327	J01118	06/26/2013	12:36	06/26/2013	18:48	1	372	372	Overhead equipment	Overhead Service	Cut in Clear	Repair	I
131775350	K79213	06/26/2013	12:37	06/26/2013	16:50	23	5819	253	Overhead equipment	Overhead Primary		Repair	IV
131775360	R50910	06/26/2013	12:41	06/26/2013	14:21	1	100	100	Overhead equipment	Other	Patrol/Test/Inspect	Repair	I
131775423	T05539	06/26/2013	12:54	06/26/2013	13:48	1	54	54	Overhead equipment	Transformer Fuse	Repair	Replace - Same Size	VI
131775432	K74166	06/26/2013	12:57	06/26/2013	15:29	1	152	152	Tree related-tree broken				IV
131775459	Y23513	06/26/2013	12:57	06/26/2013	15:45	153	25704	168	Overhead equipment	Fuse	Patrol/Test/Inspect	Replace - Same Size	IV
131775441	Q24311	06/26/2013	12:59	06/26/2013	14:28	1	89	89	Overhead equipment	Lightning Arrestor	Replace - Same Size		VI
131775469	H22346	06/26/2013	13:06	06/26/2013	15:25	1	139	139	Tree related-tree contact	Overhead Service	Repair	Advise Customer	V
131775514	D16001	06/26/2013	13:07	06/26/2013	19:19	18	6696	372	Tree related-tree broken	Overhead Primary	Patrol/Test/Inspect	Repair	I
131775491	L99392	06/26/2013	13:08	06/26/2013	14:00	1	52	52	Animal related	Fuse	Replace - Same Size		V
131775638	R59415	06/26/2013	13:37	06/26/2013	18:30	1	293	293	Tree related-tree broken	Overhead Service	Repair		IV
131775692	J34356	06/26/2013	13:50	06/26/2013	15:00	1	70	70	Weather	Meter	Replace - Same Size		V
131775731	D41003	06/26/2013	14:00	06/26/2013	16:27	1	147	147	Overhead equipment	Transformer Fuse	Replace - Same Size		I
131775801	H00163	06/26/2013	14:17	06/26/2013	15:26	1	69	69	Animal related	Other			III

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
131775821	E10001	06/26/2013	14:20	06/26/2013	16:20	1	120	120	Overhead equipment	Fuse	Replace - Same Size	Repair	III
131775819	R48166	06/26/2013	14:20	06/26/2013	17:36	1	196	196	Overhead equipment	Connector	Replace - Same Size		IV
131775774	J99127	06/26/2013	14:21	06/26/2013	15:28	2	134	67	Tree related-tree broken	Transformer Fuse	Replace - Same Size		VI
131775855	B27006	06/26/2013	14:27	06/26/2013	18:35	2	496	248	Weather	Disconnect Switch	Replace - Same Size		I
131776175	Z17503	06/26/2013	14:38	06/26/2013	16:20	5	510	102	Overhead equipment	Fuse	Replace - Same Size		IV
131775911	Z17503	06/26/2013	14:40	06/26/2013	16:20	18	1800	100	Overhead equipment	Overhead Primary	Repair	Repair	IV
131775961	D36003	06/26/2013	14:53	06/26/2013	15:25	1	32	32	Overhead equipment	Fuse	Repair		I
131775987	J08207	06/26/2013	14:59	06/26/2013	16:20	1	81	81	Unknown	Fuse	Replace - Same Size		I
131775988	M07235	06/26/2013	15:00	06/26/2013	15:34	1	34	34	Tree related-tree broken	Overhead Service	Repair		III
131776079	D53002	06/26/2013	15:25	06/26/2013	16:47	1	82	82	Tree related-tree broken	Overhead Service	Raise		I
131776133	Q11517	06/26/2013	15:40	06/26/2013	16:48	1	68	68	Weather	Fuse	Replace - Same Size		I
131776168	P18104	06/26/2013	15:42	06/26/2013	18:30	23	3864	168	Underground equipment	Underground Primary	Patrol/Test/Inspect	Patrol/Test/Inspect	IV
131776157	K07320	06/26/2013	15:46	06/26/2013	16:34	1	48	48	Overhead equipment	Transformer Fuse	Replace - Same Size	Replace - Same Size	I
131776172	U37579	06/26/2013	15:51	06/26/2013	16:39	1	48	48	Unknown	Transformer Fuse	Replace - Same Size		II
131777166	P57108	06/26/2013	16:10	06/26/2013	22:30	1	380	380	Tree related-tree broken	Overhead Transformer			VI
131778064	P57108	06/26/2013	16:10	06/26/2013	20:19	367	91383	249	Tree related-tree broken				VI
131776414	P57336	06/26/2013	16:14	06/26/2013	20:18	494	120536	244	Tree related-tree broken				VI
131776286	P57108	06/26/2013	16:15	06/26/2013	22:27	1	372	372	Weather	Overhead Secondary	Replace - Same Size		VI
131776349	P57108	06/26/2013	16:16	06/26/2013	22:40	10	3840	384	Tree related-tree broken	Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
131777422	X24536	06/26/2013	16:41	06/26/2013	18:15	7	658	94	Weather	Fuse			IV
131776730	J87119	06/26/2013	16:42	06/26/2013	17:12	56	1680	30	Overhead equipment	Fuse			VI
131776906	D36002	06/26/2013	16:58	06/26/2013	20:16	1	198	198	Tree related-tree broken	Overhead Service	Repair		I
131777064	335002	06/26/2013	16:58	06/27/2013	1:20	137	68774	502	Tree related-tree broken	Pole	Patrol/Test/Inspect	Replace - Same Size	VI
131777013	303004	06/26/2013	16:59	06/26/2013	23:40	16	6416	401	Tree related-tree broken	Overhead Primary	Advise Customer	Repair	VI
131776942	335002	06/26/2013	17:01	06/26/2013	18:00	3	177	59	Overhead equipment	Overhead Primary	Advise Customer		VI
131776959	303004	06/26/2013	17:03	06/27/2013	1:58	1	535	535	Tree related-tree broken				VI
131776963	342001	06/26/2013	17:04	06/27/2013	1:18	1	494	494	Tree related-tree broken				VI
131777085	M54314	06/26/2013	17:05	06/26/2013	18:20	507	38025	75	Tree related-tree broken	Tree	Remove		V
131777000	303004	06/26/2013	17:07	06/26/2013	20:01	7	1218	174	Overhead equipment	Overhead Transformer	Switch/Reset		VI
131777946	349002	06/26/2013	17:08	06/26/2013	19:02	37	4218	114	Tree related-tree broken	Fuse	Replace - Same Size		VI
131777092	303004	06/26/2013	17:14	06/27/2013	0:43	5	2245	449	Overhead equipment	Tree	Patrol/Test/Inspect	Repair	VI
131777123	307004	06/26/2013	17:17	06/26/2013	22:50	1	333	333	Tree related-tree broken	Overhead Service	Repair		VI
131777128	347001	06/26/2013	17:17	06/26/2013	18:20	16	1008	63	Overhead equipment	Overhead Transformer	Switch/Reset		VI
131777171	K52401	06/26/2013	17:23	06/26/2013	18:31	1	68	68	Weather	Fuse	Replace - Same Size		V
131777189	M53312	06/26/2013	17:26	06/26/2013	19:48	1	142	142	Tree related-tree broken	Tree	Remove		V
131777232	315109	06/26/2013	17:28	06/26/2013	19:08	29	2900	100	Tree related-tree broken	Overhead Primary	Patrol/Test/Inspect		V
131777233	HB6281	06/26/2013	17:32	06/26/2013	18:50	8	624	78	Weather	Fuse	Replace - Same Size		VI
131777409	K09863	06/26/2013	17:44	06/26/2013	18:39	2	110	55	Animal related	Transformer Fuse	Replace - Same Size	Repair	V
131778004	P77233	06/26/2013	17:59	06/26/2013	20:16	4	548	137	Tree related-tree broken	Tree			VI
131777495	N18211	06/26/2013	18:02	06/26/2013	19:39	1	97	97	Weather	Transformer Fuse	Replace - Same Size		III
131777498	338005	06/26/2013	18:03	06/26/2013	20:55	1	172	172	Overhead equipment	Fuse	Replace - Same Size		VI
131777508		06/26/2013	18:05	06/26/2013	18:28	1	23	23	Tree related-tree broken				V
131777537	Y28598	06/26/2013	18:13	06/26/2013	19:35	1	82	82	Tree related-tree broken	Overhead Service	Repair		IV
131777904	Y41002	06/26/2013	18:27	06/26/2013	19:41	3	222	74	Tree related-tree broken	Overhead Primary	Repair		IV
131777944	Q64919	06/26/2013	18:38	06/26/2013	19:35	12	684	57	Weather	Fuse	Repair		VI
131777954	R10925	06/26/2013	18:41	06/26/2013	23:36	8	2360	295	Tree related-tree broken	Pole		Replace - Same Size	VI
131778106	L59933	06/26/2013	18:44	06/26/2013	20:07	338	28054	83	Overhead equipment				VI
131777977	J14140	06/26/2013	18:47	06/26/2013	19:52	1	65	65	Weather	Fuse	Replace - Same Size		VI
131778034	K32916	06/26/2013	18:48	06/26/2013	22:17	5	1045	209	Tree related-tree broken	Overhead Primary			VI
131778006	L59929	06/26/2013	18:49	06/27/2013	0:37	4	1392	348	Tree related-tree broken	Crossarm			VI
131778254	J88163	06/26/2013	18:50	06/27/2013	1:26	3	1188	396	Overhead equipment	Pole	Patrol/Test/Inspect	Replace - New Size	VI
131778046	T14575	06/26/2013	18:51	06/27/2013	4:30	11	6369	579	Tree related-tree broken	Pole	Repair	Repair	VI
131778001	L62927	06/26/2013	18:52	06/26/2013	21:50	1	178	178	Tree related-tree broken	Tree	Cut in Clear	Repair	VI
131778008	R10903	06/26/2013	18:53	06/26/2013	19:10	1	17	17	Tree related-tree broken				VI
131778053		06/26/2013	19:08	06/27/2013	8:01	1	773	773	Tree related-tree broken			Trim	VI
131778052	Q82906	06/26/2013	19:08	06/26/2013	20:53	1	105	105	Overhead equipment	Fuse	Replace - Same Size		VI

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
131778056	H10843	06/26/2013	19:10	06/26/2013	22:52	1	222	222	Weather	Overhead Transformer	Replace - Same Size		V
131778060	R39934	06/26/2013	19:11	06/26/2013	21:30	1	139	139	Weather	Fuse	Repair		VI
131778059	T08502	06/26/2013	19:11	06/26/2013	22:15	1	184	184	Weather	Disconnect Switch	Patrol/Test/Inspect	Replace - Same Size	VI
131778068	S52515	06/26/2013	19:13	06/27/2013	0:30	44	13948	317	Tree related-tree broken	Overhead Primary	Patrol/Test/Inspect	Repair	VI
131778071	L59933	06/26/2013	19:15	06/26/2013	20:36	1	81	81	Overhead equipment	Overhead Primary	Repair	Repair	VI
131778426	R10903	06/26/2013	19:22	06/26/2013	23:19	36	8532	237	Overhead equipment	Pole	Replace - Same Size	Replace - Same Size	VI
131778096	K32916	06/26/2013	19:25	06/26/2013	20:27	1	62	62	Overhead equipment	Fuse	Replace - Same Size		VI
131778095	T12528	06/26/2013	19:25	06/27/2013	5:35	1	610	610	Public	Overhead Primary	Patrol/Test/Inspect	Repair	VI
131778105	R50910	06/26/2013	19:28	06/26/2013	20:22	1	54	54	Animal related	Transformer Fuse	Replace - Same Size		I
131778108	L59929	06/26/2013	19:28	06/26/2013	22:36	2	376	188	Overhead equipment	Overhead Service	Repair	Repair	VI
131778113	D36002	06/26/2013	19:30	06/27/2013	1:15	2	690	345	Tree related-tree contact	Tree			I
131778146	Z10501	06/26/2013	19:42	06/27/2013	2:44	2	844	422	Overhead equipment	Overhead Transformer	Replace - Same Size	Replace - Same Size	IV
131778157	T14575	06/26/2013	19:46	06/26/2013	20:35	31	1519	49	Tree related-tree broken	Overhead Primary	Patrol/Test/Inspect	Repair	VI
131778161	J84123	06/26/2013	19:49	06/26/2013	21:13	1	84	84	Weather	Transformer Fuse			VI
131778222	S27599	06/26/2013	19:57	06/27/2013	7:46	96	68064	709	Tree related-tree broken	Overhead Primary			VI
131778185	302001	06/26/2013	19:58	06/26/2013	21:50	1	112	112	Tree related-tree broken	Overhead Service	Disconnect		VI
131778187	S41562	06/26/2013	19:59	06/26/2013	20:52	1	53	53	Tree related-tree contact	Overhead Service	Advise Customer	Repair	VI
131778192	S43502	06/26/2013	20:00	06/26/2013	21:49	1	109	109	Other	Overhead Service	Patrol/Test/Inspect	Patrol/Test/Inspect	VI
131778196	Z10501	06/26/2013	20:04	06/27/2013	4:01	4	1908	477	Overhead equipment	Overhead Transformer			IV
131778199	X24536	06/26/2013	20:05	06/26/2013	21:30	1	85	85	Tree related-tree broken	Overhead Service			IV
131778202	S01726	06/26/2013	20:07	06/27/2013	9:48	2	1642	821	Other	Pole			VI
131778263	S21529	06/26/2013	20:08	06/26/2013	22:20	9	1188	132	Overhead equipment	Disconnect Switch	Replace - Same Size	No Work Required	VI
131778208	U06551	06/26/2013	20:10	06/26/2013	22:26	2	272	136	Weather	Transformer Fuse	Replace - Same Size		II
131778251	S01511	06/26/2013	20:16	06/26/2013	22:27	46	6026	131	Tree related-tree broken	Overhead Primary			VI
131778244	S27599	06/26/2013	20:24	06/27/2013	1:19	1	295	295	Tree related-tree contact	Overhead Service			VI
131778247		06/26/2013	20:25	06/27/2013	4:15	1	470	470	Weather	Disconnect Switch		Replace - Same Size	V
131778252	P57108	06/26/2013	20:26	06/26/2013	22:26	1	120	120	Tree related-tree contact	Overhead Secondary	Replace - Same Size		VI
131778253	S55534	06/26/2013	20:26	06/26/2013	22:49	12	1716	143	Overhead equipment	Transformer Fuse	Repair	Replace - Same Size	VI
131784110	S27599	06/26/2013	20:30	06/27/2013	8:25	17	12155	715	Tree related-tree contact	Overhead Primary			VI
131778387	B71002	06/26/2013	20:42	06/27/2013	2:21	1473	499347	339	Underground equipment	Underground Primary	Switch/Reset	Repair	I
131778315	303004	06/26/2013	20:44	06/27/2013	2:15	1	331	331	Tree related-tree broken				VI
131778364	R10903	06/26/2013	20:44	06/26/2013	21:14	13	390	30	Tree related-tree broken				VI
131778414	J20931	06/26/2013	21:10	06/26/2013	23:23	1	133	133	Weather	Lightning Arrestor		Patrol/Test/Inspect	VI
131778422	M78322	06/26/2013	21:16	06/27/2013	0:50	1	214	214	Overhead equipment				V
131778455	P57108	06/26/2013	21:35	06/27/2013	14:11	1	996	996	Tree related-tree broken	Overhead Service	Repair		VI
131778474	S27599	06/26/2013	21:55	06/27/2013	10:04	7	5103	729	Tree related-tree contact	Overhead Service			VI
131778475	337001	06/26/2013	21:56	06/27/2013	0:30	1	154	154	Tree related-tree broken	Overhead Service	Repair		VI
131778479	P42230	06/26/2013	21:58	06/27/2013	0:33	21	3255	155	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	VI
131778499	S61575	06/26/2013	22:19	06/26/2013	22:57	1	38	38	Overhead equipment	Transformer Fuse	Replace - New Size		VI
131778518	S47576	06/26/2013	22:22	06/27/2013	0:05	13	1339	103	Overhead equipment	Fuse	Replace - New Size		VI
131778503	A91004	06/26/2013	22:27	06/26/2013	23:37	1	70	70	Public	Pole			I
131778502	L59933	06/26/2013	22:27	06/27/2013	0:57	1	150	150	Tree related-tree broken	Overhead Service	Raise		VI
131778541	J20931	06/26/2013	23:39	06/27/2013	0:30	1	51	51	Weather	Fuse	Replace - Same Size	Patrol/Test/Inspect	VI
131778545	S28552	06/26/2013	23:49	06/27/2013	2:00	1	131	131	Underground equipment	Underground Transformer	Replace - Same Size	Replace - Same Size	VI
131780097	S27599	06/27/2013	0:30	06/27/2013	3:51	1	201	201	Tree related-tree contact	Overhead Service			VI
131780106	Q01281	06/27/2013	0:40	06/27/2013	5:13	14	3822	273	Unknown	Underground Primary			III
131780108	307001	06/27/2013	0:56	06/27/2013	6:20	1	324	324	Tree related-tree broken	Overhead Secondary	Advise Customer	Repair	VI
131780120	L42158	06/27/2013	1:40	06/27/2013	2:39	1	59	59	Unknown	Fuse	Replace - Same Size		III
131780124	S27599	06/27/2013	2:03	06/27/2013	10:40	1	517	517	Tree related-tree broken	Overhead Primary	Repair	Replace - Same Size	VI
131783546	L12128	06/27/2013	2:35	06/27/2013	5:48	98	18914	193	Animal related	Fuse	Replace - Same Size		III
131780190	K89141	06/27/2013	2:58	06/27/2013	6:37	23	5037	219	Underground equipment	Underground Primary	Repair	Repair	III
131780193	P54827	06/27/2013	3:08	06/27/2013	5:32	1	144	144	Overhead equipment	Overhead Service	Repair		V
131783561	HB6251	06/27/2013	4:41	06/27/2013	5:13	1	32	32	Underground equipment	Underground Service			VI
131783563	B71002	06/27/2013	4:45	06/27/2013	9:39	3	882	294	Underground equipment	Underground Service		Repair	I
131783566	U33509	06/27/2013	4:54	06/27/2013	6:01	1	67	67	Overhead equipment	Transformer Fuse	Replace - Same Size		II
131783842	R01153	06/27/2013	5:33	06/27/2013	6:47	27	1998	74	Underground equipment	Underground Primary	Switch/Reset		III

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
131783737	R01153	06/27/2013	5:33	06/27/2013	10:21	51	14688	288	Underground equipment	Underground Primary	Repair	Repair	III
131783796	L90359	06/27/2013	6:09	06/27/2013	8:41	53	8056	152	Animal related	Fuse	Patrol/Test/Inspect		V
131783788	Q18242	06/27/2013	6:12	06/27/2013	6:48	948	34128	36	Overhead equipment				VI
131783802	Q11516	06/27/2013	6:19	06/27/2013	9:25	1	186	186	Overhead equipment	Overhead Secondary	Repair	No Work Required	I
131783808	Q23256	06/27/2013	6:21	06/27/2013	6:50	1	29	29	Overhead equipment			No Work Required	VI
131784245	L59933	06/27/2013	6:51	06/27/2013	11:01	4	1000	250	Tree related-tree contact	Overhead Primary			VI
131783862	R99180	06/27/2013	7:00	06/27/2013	10:18	1	198	198	Weather	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	IV
131783864	V80506	06/27/2013	7:01	06/27/2013	8:15	5	370	74	Animal related	Transformer Fuse	Replace - Same Size		II
131783867	Q18242	06/27/2013	7:02	06/27/2013	7:10	1	8	8	Overhead equipment			No Work Required	VI
131783878	D72002	06/27/2013	7:05	06/27/2013	11:14	1	249	249	Underground equipment	Other		Repair	I
131783901	J20931	06/27/2013	7:14	06/27/2013	9:40	1	146	146	Overhead equipment	Overhead Transformer	Replace - Same Size	Replace - Same Size	VI
131783930		06/27/2013	7:22	06/27/2013	9:10	1	108	108	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	VI
131783961	P12290	06/27/2013	7:30	06/27/2013	9:10	3	300	100	Overhead equipment	Fuse	Replace - Same Size		V
131784006	B80004	06/27/2013	7:44	06/27/2013	9:02	13	1014	78	Underground equipment	Vault	Move	Replace - Same Size	I
131784079	C36002	06/27/2013	8:07	06/27/2013	8:55	1	48	48	Overhead equipment	Fuse	Replace - Same Size		III
131784138	N42856	06/27/2013	8:26	06/27/2013	9:44	1	78	78	Animal related	Transformer Fuse	Replace - Same Size	No Work Required	V
131784623	S27599	06/27/2013	8:35	06/27/2013	10:10	28	2660	95	Tree related-tree broken	Overhead Service			VI
131784208	D28124	06/27/2013	8:41	06/27/2013	10:30	1	109	109	Overhead equipment	Fuse	Replace - Same Size		I
131784224	D96001	06/27/2013	8:44	06/27/2013	9:51	1	67	67	Overhead equipment	Connector	Replace - Same Size	No Work Required	I
131784242	Q16867	06/27/2013	8:48	06/27/2013	9:45	1	57	57	Animal related	Fuse	Replace - Same Size		V
131784255	K74164	06/27/2013	8:51	06/27/2013	9:37	13	598	46	Other	Underground Transformer	Switch/Reset		IV
131784279	Y28598	06/27/2013	8:57	06/27/2013	10:35	1	98	98	Overhead equipment	Overhead Service	Repair	Repair	IV
131784301	B38002	06/27/2013	9:02	06/27/2013	13:31	1	269	269	Overhead equipment	Transformer Fuse	Replace - Same Size	No Work Required	I
131784314	Q16867	06/27/2013	9:03	06/27/2013	10:00	1	57	57	Animal related	Transformer Fuse	Replace - Same Size		V
131784343	332004	06/27/2013	9:10	06/27/2013	12:44	7	1498	214	Tree related-tree broken	Tree	Remove		VI
131784349		06/27/2013	9:11	06/27/2013	10:25	1	74	74	Weather	Fuse		Replace - Same Size	V
131784950	J12166	06/27/2013	9:23	06/27/2013	13:10	2	454	227	Overhead equipment	Overhead Transformer	Repair		III
131784946	J12166	06/27/2013	9:23	06/27/2013	11:18	1	115	115	Overhead equipment	Overhead Transformer	Replace - Same Size		III
131784420	M49410	06/27/2013	9:24	06/27/2013	13:32	1	248	248	Underground equipment	Underground Service		Repair	V
131784467	S66579	06/27/2013	9:37	06/27/2013	11:46	1	129	129	Overhead equipment	Transformer Fuse	Replace - Same Size	Replace - Same Size	VI
131784496	T08502	06/27/2013	9:42	06/27/2013	10:20	1	38	38	Overhead equipment	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
131784585	D96001	06/27/2013	9:59	06/27/2013	10:38	1	39	39	Animal related	Transformer Fuse	Replace - Same Size	No Work Required	I
131784654	S66578	06/27/2013	10:13	06/27/2013	11:19	1	66	66	Overhead equipment	Overhead Service	Repair		VI
131784733	M41113	06/27/2013	10:30	06/27/2013	11:13	1	43	43	Overhead equipment	Overhead Service	No Work Required		I
131784761	L17105	06/27/2013	10:38	06/27/2013	13:54	1	196	196	Overhead equipment	Overhead Service	Repair		III
131784824	S43511	06/27/2013	10:52	06/27/2013	11:33	1	41	41	Tree related-tree broken	Overhead Service	Replace - Same Size	No Work Required	VI
131784840	L12128	06/27/2013	10:56	06/27/2013	12:51	1	115	115	Animal related	Transformer Fuse	Replace - Same Size		III
131784901		06/27/2013	11:07	06/27/2013	15:00	1	233	233	Overhead equipment	Pole	Patrol/Test/Inspect	Replace - Same Size	VI
131784990	K57211	06/27/2013	11:23	06/27/2013	13:20	1	117	117	Animal related	Animal Guard	Install	Replace - Same Size	VI
131784988	K32932	06/27/2013	11:23	06/27/2013	12:55	1	92	92	Tree related-tree broken	Overhead Service	Repair		VI
131785043	P19395	06/27/2013	11:38	06/27/2013	13:22	4	416	104	Overhead equipment	Overhead Transformer		Replace - Same Size	V
131785119	D89001	06/27/2013	11:50	06/27/2013	12:50	21	1260	60	Overhead equipment	Fuse	Replace - Same Size		I
131785138	N05172	06/27/2013	11:57	07/01/2013	6:44	1	5447	5447	Weather	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	I
131785137	M40132	06/27/2013	11:57	06/27/2013	12:21	1	24	24	Overhead equipment	Overhead Service	No Work Required		I
131785282	P18104	06/27/2013	12:22	06/27/2013	13:29	6	402	67	Overhead equipment	Jumper	Repair		IV
131785287	S27599	06/27/2013	12:36	06/27/2013	13:45	1	69	69	Tree related-tree contact	Overhead Service	Repair		VI
131785301	Q06132	06/27/2013	12:42	06/27/2013	13:03	1	21	21	Animal related	Overhead Primary	Install	Replace - Same Size	IV
131785362	K74162	06/27/2013	12:58	06/27/2013	14:20	1	82	82	Weather	Transformer Fuse	Replace - Same Size		IV
131785367	K71810	06/27/2013	12:59	06/27/2013	15:35	1	156	156	Underground equipment	Underground Service	Patrol/Test/Inspect	Repair	IV
131785372	B57002	06/27/2013	13:01	06/27/2013	13:47	1	46	46	Overhead equipment	Connector	Patrol/Test/Inspect	Replace - New Size	I
131785376	M05360	06/27/2013	13:01	06/27/2013	13:53	1	52	52	Animal related	Transformer Fuse	Replace - Same Size		V
131785485	Q06142	06/27/2013	13:26	06/27/2013	15:02	1	96	96	Tree related-tree broken	Overhead Service	Repair	No Work Required	IV
131785545	R16511	06/27/2013	13:38	06/27/2013	14:07	21	609	29	Overhead equipment	Overhead Transformer	Switch/Reset		I
131785592	K74164	06/27/2013	13:53	06/27/2013	14:15	8	176	22	Overhead equipment	Transformer Fuse	Replace - Same Size	No Work Required	IV
131785659		06/27/2013	14:06	06/27/2013	19:00	1	294	294	Overhead equipment	Overhead Transformer		Replace - Same Size	V
131785658	M78322	06/27/2013	14:06	06/27/2013	21:29	1	443	443	Overhead equipment	Pole	Replace - Same Size		V

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
131785676	J71129	06/27/2013	14:10	06/27/2013	15:46	1	96	96	Weather	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	I
131785784	K67912	06/27/2013	14:35	06/27/2013	15:44	1	69	69	Weather	Fuse	Replace - Same Size	Patrol/Test/Inspect	VI
131785938	S61575	06/27/2013	14:44	06/27/2013	15:29	9	405	45	Overhead equipment	Fuse	Replace - Same Size		VI
131785880	K11376	06/27/2013	14:59	06/27/2013	19:30	1	271	271	Overhead equipment	Fuse		Replace - Same Size	V
131785968	X29003	06/27/2013	15:22	06/27/2013	15:53	18	558	31	Overhead equipment	Disconnect Switch	Replace - New Size		IV
131786012	B08003	06/27/2013	15:35	06/27/2013	17:40	1	125	125	Overhead equipment	Overhead Service	Repair		I
131786081	Q74149	06/27/2013	15:57	06/27/2013	18:55	2	356	178	Animal related	Fuse	Replace - Same Size		IV
131786104	L35283	06/27/2013	16:04	06/27/2013	16:50	1	46	46	Overhead equipment	Connector	Replace - Same Size		III
131786207	M54292	06/27/2013	16:27	06/27/2013	21:07	7	1960	280	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	V
131786174	329148	06/27/2013	16:31	06/27/2013	17:20	1	49	49	Jurisdictional	Meter	Patrol/Test/Inspect		V
131786274	E05002	06/27/2013	17:01	06/27/2013	18:00	232	13688	59	Overhead equipment	Fuse	Replace - Same Size		IV
131786235	J87150	06/27/2013	17:02	06/27/2013	18:09	23	1541	67	Underground equipment	Underground Primary			VI
131786299	R07381	06/27/2013	17:34	06/27/2013	19:23	5	545	109	Overhead equipment	Connector	Replace - Same Size	Repair	I
131786459	B38001	06/27/2013	17:54	06/27/2013	21:40	1	226	226	Tree related-tree broken	Fuse	Replace - Same Size		I
131786925	K79212	06/27/2013	18:36	06/27/2013	20:09	791	73563	93	Tree related-tree broken				IV
131786848	X24536	06/27/2013	18:42	06/27/2013	19:48	1	66	66	Unknown	Transformer Fuse			IV
131786885	B21004	06/27/2013	19:08	06/27/2013	23:00	66	15312	232	Underground equipment	Underground Primary	Repair	Replace - Same Size	I
131786941	340101	06/27/2013	19:38	06/27/2013	19:42	35	140	4	Overhead equipment	Fuse	Replace - Same Size		V
131786948	D39002	06/27/2013	19:47	06/27/2013	23:59	1	252	252	Overhead equipment	Fuse	Replace - Same Size		I
131786970		06/27/2013	20:15	06/27/2013	22:30	1	135	135	Overhead equipment	Overhead Transformer	Replace - Same Size	Replace - Same Size	V
131786972	K01239	06/27/2013	20:18	06/27/2013	20:59	10	410	41	Animal related	Fuse	Replace - Same Size		VI
131786975	K79212	06/27/2013	20:23	06/27/2013	20:27	1	4	4	Tree related-tree broken				IV
131787101	P98191	06/27/2013	20:33	06/28/2013	0:35	96	23232	242	Underground equipment	Underground Primary			III
131786997	P98191	06/27/2013	20:33	06/27/2013	22:46	273	36309	133	Underground equipment	Underground Primary	Switch/Reset		III
131787003	K79212	06/27/2013	20:54	06/27/2013	21:05	1	11	11	Tree related-tree broken				IV
131787039	B93002	06/27/2013	21:17	06/28/2013	6:59	1	582	582	Overhead equipment	Connector	Replace - Same Size		I
131787052	M81403	06/27/2013	21:26	06/27/2013	23:36	36	4680	130	Underground equipment	Underground Primary	Patrol/Test/Inspect		V
131790122	A49001	06/27/2013	21:35	06/28/2013	0:54	1	199	199	Underground equipment	Underground Primary	Switch/Reset		I
131787096	A49001	06/27/2013	21:35	06/28/2013	6:04	5	2545	509	Overhead equipment	Fuse	Repair	Replace - Same Size	I
131787062	Y66557	06/27/2013	21:54	06/27/2013	22:38	1	44	44	Overhead equipment	Overhead Service			IV
131787087	U62510	06/27/2013	22:41	06/28/2013	0:10	1	89	89	Overhead equipment	Transformer Fuse	Replace - Same Size		II
131790129	J56341	06/28/2013	1:12	06/28/2013	3:06	10	1140	114	Underground equipment	Underground Primary			III
131790273	M54314	06/28/2013	2:04	06/28/2013	5:07	1	183	183	Tree related-tree broken	Tree	Repair		V
131790461	N54214	06/28/2013	2:13	06/28/2013	5:15	24	4368	182	Underground equipment	Underground Primary	Switch/Reset	Repair	II
131790371	D16004	06/28/2013	2:29	06/28/2013	5:35	127	23622	186	Underground equipment	Disconnect Switch			I
131794156	Q37370	06/28/2013	4:07	06/28/2013	10:43	1	396	396	Transmission outage	Other	No Work Required	No Work Required	I
131794158	N54107	06/28/2013	4:11	06/28/2013	5:50	1	99	99	Animal related	Transformer Fuse	Replace - Same Size		II
131794169	J79305	06/28/2013	5:06	06/28/2013	6:32	1	86	86	Animal related	Fuse	Replace - Same Size		I
131794185	A85001	06/28/2013	5:38	06/28/2013	8:31	1	173	173	Animal related	Fuse	Replace - Same Size		I
131794207	V31001	06/28/2013	5:52	06/28/2013	7:04	1	72	72	Overhead equipment				II
131794257	S62521	06/28/2013	6:21	06/28/2013	7:12	8	408	51	Animal related	Transformer Fuse	Replace - Same Size		VI
131794278	K30204	06/28/2013	6:41	06/28/2013	8:00	1	79	79	Animal related	Fuse	Replace - Same Size		III
131794279	M42107	06/28/2013	6:43	06/28/2013	7:04	1	21	21	Overhead equipment	Fuse	Replace - Same Size		I
131794267	A80001	06/28/2013	7:04	06/28/2013	9:00	1	116	116	Tree related-tree broken	Overhead Service	Remove		I
131794300	N67309	06/28/2013	7:07	06/28/2013	9:07	1	120	120	Weather	Overhead Transformer	Replace - Same Size		I
131794308	K57212	06/28/2013	7:10	06/28/2013	8:51	1	101	101	Overhead equipment	Transformer Fuse	Repair	Repair	VI
131794311	C52001	06/28/2013	7:13	06/28/2013	7:41	11	308	28	Overhead equipment	Fuse	Replace - Same Size		III
131794342	K07322	06/28/2013	7:22	06/28/2013	8:32	7	490	70	Animal related	Transformer Fuse	Replace - Same Size		I
131794368	B93003	06/28/2013	7:35	06/28/2013	15:00	1	445	445	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
131794578	374052	06/28/2013	8:27	06/28/2013	9:44	1	77	77	Overhead equipment	Fuse	Repair		VI
131794681	N44215	06/28/2013	8:30	06/28/2013	10:25	73	8395	115	Animal related	Fuse	Replace - Same Size		III
131794601	V69546	06/28/2013	8:33	06/28/2013	11:07	1	154	154	Unknown	Transformer Fuse	Replace - Same Size		II
131794648	K31120	06/28/2013	8:44	06/28/2013	9:42	1	58	58	Animal related	Transformer Fuse	Replace - Same Size		I
131794684	S47584	06/28/2013	8:51	06/28/2013	10:55	1	124	124	Overhead equipment				VI
131794717	L95110	06/28/2013	8:56	06/28/2013	9:31	1	35	35	Animal related	Fuse	Replace - Same Size		III
131794741	K91117	06/28/2013	9:02	06/28/2013	9:37	1	35	35	Animal related	Transformer Fuse	Replace - Same Size		III

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
131794757	B62003	06/28/2013	9:06	06/28/2013	10:21	1	75	75	Overhead equipment	Overhead Service	Replace - Same Size		I
131794802	K43386	06/28/2013	9:18	06/28/2013	10:50	1	92	92	Overhead equipment	Fuse	Patrol/Test/Inspect	Replace - New Size	V
131794928	S07536	06/28/2013	9:24	06/28/2013	14:45	5	1605	321	Underground equipment	Underground Primary	Repair	Repair	VI
131794903	B28006	06/28/2013	9:35	06/28/2013	10:08	1	33	33	Animal related	Transformer Fuse	Replace - Same Size	No Work Required	I
131794921		06/28/2013	9:39	06/28/2013	12:00	1	141	141	Public	Overhead Primary	Repair	Replace - Same Size	IV
131794982	R20502	06/28/2013	9:50	06/28/2013	11:19	1	89	89	Weather	Transformer Fuse	Install		IV
131794991		06/28/2013	9:52	06/28/2013	12:45	1	173	173	Tree related-tree contact	Overhead Secondary		Repair	VI
131795030	V59561	06/28/2013	9:58	06/28/2013	10:30	1	32	32	Other	Meter	Repair		II
131795095	B80002	06/28/2013	10:05	06/28/2013	12:50	85	14025	165	Tree related-tree broken	Tree	Patrol/Test/Inspect	Remove	I
131795078	X73001	06/28/2013	10:05	06/28/2013	11:14	10	690	69	Overhead equipment	Transformer Fuse	Repair		IV
131795083	B38001	06/28/2013	10:06	06/28/2013	10:47	1	41	41	Overhead equipment	Fuse	Replace - Same Size	No Work Required	I
131795098	Z33507	06/28/2013	10:08	06/28/2013	10:53	1	45	45	Overhead equipment	Transformer Fuse	Repair	Replace - Same Size	IV
131795122	P62113	06/28/2013	10:11	06/28/2013	10:36	1	25	25	Other	Meter	Reconnect		VI
131795127	Z06538	06/28/2013	10:12	06/28/2013	12:13	1	121	121	Overhead equipment	Overhead Service	Repair	Patrol/Test/Inspect	IV
131795205	T05540	06/28/2013	10:17	06/28/2013	11:22	12	780	65	Overhead equipment	Other	Repair	Replace - Same Size	VI
131795217	Q63835	06/28/2013	10:21	06/28/2013	12:00	39	3861	99	Underground equipment				V
131795235	H11340	06/28/2013	10:34	06/28/2013	11:30	1	56	56	Animal related	Fuse	Replace - Same Size		V
131795382	Q11517	06/28/2013	11:14	06/28/2013	12:36	1	82	82	Overhead equipment	Overhead Secondary	Repair	No Work Required	I
131795431	N54107	06/28/2013	11:27	06/28/2013	12:28	1	61	61	Tree related-tree broken	Transformer Fuse	Replace - Same Size		II
131795482	M42107	06/28/2013	11:27	06/28/2013	13:44	11	1507	137	Overhead equipment	Overhead Primary	Repair	Repair	I
131795548	B45005	06/28/2013	11:58	06/28/2013	14:14	30	4080	136	Overhead equipment	Jumper	Replace - Same Size	No Work Required	I
131795583	IP9009	06/28/2013	12:02	06/28/2013	13:15	37	2701	73	Tree related-tree broken	Tree	Patrol/Test/Inspect		VI
131795628	N18211	06/28/2013	12:31	06/28/2013	13:56	1	85	85	Tree related-tree contact	Overhead Secondary	Cut in Clear		III
131795714	Q95248	06/28/2013	12:57	06/28/2013	17:50	1	293	293	Underground equipment	Underground Service		Repair	VI
131795844	B93001	06/28/2013	13:30	06/28/2013	14:20	1	50	50	Overhead equipment	Overhead Service	Repair		I
131796151	X73001	06/28/2013	13:39	06/28/2013	13:56	1	17	17	Unknown				IV
131796379	S52515	06/28/2013	13:54	06/28/2013	17:15	9	1809	201	Underground equipment	Underground Primary	Repair	Repair	VI
131796528	T12527	06/28/2013	13:55	06/28/2013	16:30	4	620	155	Public	Guy Wire	Patrol/Test/Inspect	Repair	VI
131796991	M25144	06/28/2013	14:23	06/28/2013	16:44	47	6627	141	Overhead equipment	Overhead Primary	Repair		IV
131796447	B81003	06/28/2013	14:24	06/28/2013	16:20	1	116	116	Transmission outage				I
131796492		06/28/2013	14:35	06/28/2013	16:05	1	90	90	Overhead equipment	Transformer Fuse	Replace - Same Size		VI
131796512	K43386	06/28/2013	14:36	06/29/2013	0:46	674	411140	610	Overhead equipment				V
131796561		06/28/2013	14:46	06/28/2013	17:49	1	183	183	Overhead equipment				V
131796633	A49003	06/28/2013	15:00	06/28/2013	17:00	40	4800	120	Underground equipment	Other	No Work Required	Repair	I
131796646	Q74148	06/28/2013	15:05	06/28/2013	18:10	1	185	185	Weather	Transformer Fuse			IV
131796693	M36184	06/28/2013	15:24	06/28/2013	15:59	1	35	35	Overhead equipment				I
131796700	M36184	06/28/2013	15:24	06/28/2013	16:01	52	1924	37	Overhead equipment	Fuse	Replace - Same Size		I
131796779	P80145	06/28/2013	15:53	06/28/2013	17:50	6	702	117	Tree related-tree broken	Fuse	Replace - Same Size		I
131796791	U62510	06/28/2013	15:57	06/28/2013	16:20	8	184	23	Weather	Fuse	Replace - Same Size		II
131796830	K91117	06/28/2013	16:12	06/28/2013	17:00	1	48	48	Public	Transformer Fuse	Replace - Same Size		III
131796842	K91117	06/28/2013	16:18	06/28/2013	17:02	5	220	44	Public	Transformer Fuse	Replace - Same Size		III
131796845	348116	06/28/2013	16:20	06/28/2013	18:05	1	105	105	Tree related-tree contact	Overhead Service	Repair		V
131796863	K62102	06/28/2013	16:21	06/28/2013	18:06	9	945	105	Overhead equipment	Pole	Repair		II
131796919	P83710	06/28/2013	16:31	06/28/2013	18:52	102	14382	141	Overhead equipment	Fuse	Repair	Repair	I
131797007	D81002	06/28/2013	16:33	06/28/2013	17:52	11	869	79	Animal related	Fuse	Patrol/Test/Inspect		I
131796994	D37003	06/28/2013	17:07	06/28/2013	18:30	1	83	83	Overhead equipment	Jumper	Repair		I
131797034	L16213	06/28/2013	17:29	06/28/2013	17:35	1	6	6	Tree related-tree contact	Overhead Service	Repair		III
131797059	N50333	06/28/2013	17:51	06/28/2013	19:32	1	101	101	Tree related-tree contact	Overhead Secondary	Repair		II
131797064	335002	06/28/2013	17:55	06/28/2013	18:20	1	25	25	Overhead equipment	Overhead Transformer	Switch/Reset		VI
131797532	J61113	06/28/2013	18:23	06/28/2013	19:22	1	59	59	Tree related-tree contact	Overhead Service		Repair	III
131797924	B10002	06/28/2013	18:39	06/28/2013	20:15	1	96	96	Tree related-tree broken	Tree	Remove		I
131800051	S30518	06/28/2013	18:39	06/29/2013	0:37	7	2506	358	Underground equipment	Underground Primary	Switch/Reset		VI
131797930	S30518	06/28/2013	18:39	06/29/2013	4:27	3	1764	588	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	VI
131798140	S30518	06/28/2013	18:39	06/28/2013	23:20	32	8992	281	Underground equipment	Underground Primary	Switch/Reset		VI
131797932	346001	06/28/2013	18:46	06/28/2013	19:32	1	46	46	Public	Overhead Transformer	Switch/Reset		VI
131797933	B10002	06/28/2013	18:47	06/28/2013	20:15	1	88	88	Tree related-tree broken	Tree			I

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
131797951	A49003	06/28/2013	18:55	06/28/2013	21:45	40	6800	170	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
131797953	R60552	06/28/2013	19:04	06/28/2013	19:40	1	36	36	Tree related-tree contact	Fuse	Replace - Same Size	No Work Required	IV
131797990	L71171	06/28/2013	19:11	06/28/2013	20:08	867	49419	57	Tree related-tree broken	Overhead Primary	Repair	Repair	IV
131798015	338005	06/28/2013	19:58	06/28/2013	20:11	1	13	13	Tree related-tree broken	Tree	Remove		VI
131798026	B76003	06/28/2013	20:07	06/28/2013	22:30	27	3861	143	Underground equipment	Underground Primary	Switch/Reset	Repair	I
131798042	M45212	06/28/2013	20:28	06/29/2013	0:27	2	478	239	Tree related-tree broken	Overhead Service			IV
131798043	B80004	06/28/2013	20:30	06/29/2013	0:57	1	267	267	Underground equipment	Overhead Service		Repair	I
131798062	K74166	06/28/2013	21:05	06/28/2013	21:52	1	47	47	Animal related	Transformer Fuse	Replace - Same Size	No Work Required	IV
131798069	C50001	06/28/2013	21:13	06/29/2013	0:56	53	11819	223	Overhead equipment	Disconnect Switch	Replace - Same Size	No Work Required	III
131798072	L73160	06/28/2013	21:16	06/28/2013	22:50	11	1034	94	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
131798105	L70127	06/28/2013	22:17	06/28/2013	23:40	2	166	83	Animal related	Transformer Fuse	Replace - Same Size		IV
131798131	Y37593	06/28/2013	22:56	06/28/2013	23:45	1	49	49	Unknown	Transformer Fuse	Replace - Same Size		IV
131798149	J99141	06/28/2013	23:54	06/29/2013	1:22	1	88	88	Animal related	Fuse			VI
131800069	K43386	06/29/2013	0:49	06/29/2013	3:00	337	44147	131	Overhead equipment	Fuse	Replace - Same Size		V
131800041	K43386	06/29/2013	0:59	06/29/2013	2:18	46	3634	79	Overhead equipment	Fuse	Replace - Same Size		V
131800039	K43386	06/29/2013	1:03	06/29/2013	2:18	59	4425	75	Overhead equipment	Fuse	Replace - Same Size		V
131800042	K43386	06/29/2013	1:05	06/29/2013	6:15	16	4960	310	Overhead equipment	Overhead Primary	Repair		V
131800059	K43386	06/29/2013	2:23	06/29/2013	4:08	59	6195	105	Overhead equipment	Underground Primary	Switch/Reset		V
131800060	K43386	06/29/2013	2:24	06/29/2013	4:08	46	4784	104	Overhead equipment	Underground Primary	Switch/Reset		V
131800089	P58156	06/29/2013	3:04	06/29/2013	11:30	32	16192	506	Underground equipment	Underground Primary	Switch/Reset	Repair	VI
131800079	K43386	06/29/2013	3:17	06/29/2013	6:42	24	4920	205	Overhead equipment	Fuse	Patrol/Test/Inspect	Replace - Same Size	V
131800108	K43386	06/29/2013	3:24	06/29/2013	5:43	26	3614	139	Overhead equipment	Fuse	Replace - Same Size		V
131800094	K43386	06/29/2013	3:33	06/29/2013	5:22	35	3815	109	Overhead equipment	Fuse	Replace - Same Size		V
131800092	K43386	06/29/2013	3:42	06/29/2013	4:36	5	270	54	Overhead equipment	Overhead Primary	Switch/Reset		V
131800091	K43386	06/29/2013	3:42	06/29/2013	4:36	9	486	54	Overhead equipment	Overhead Primary	Switch/Reset		V
131800095	K43386	06/29/2013	3:47	06/29/2013	5:05	4	312	78	Overhead equipment				V
131800119	306001	06/29/2013	3:47	06/29/2013	9:02	28	8820	315	Overhead equipment	Fuse	Replace - Same Size		VI
131800109	K43386	06/29/2013	4:05	06/29/2013	5:05	7	420	60	Overhead equipment				V
131800115	K43386	06/29/2013	4:30	06/29/2013	5:55	46	3910	85	Overhead equipment				V
131800128	J71128	06/29/2013	6:02	06/29/2013	8:10	7	896	128	Overhead equipment	Fuse	Replace - Same Size		I
131800134	J56341	06/29/2013	6:17	06/29/2013	7:33	4	304	76	Animal related	Fuse		Repair	III
131800137		06/29/2013	6:22	06/29/2013	9:00	1	158	158	Animal related				IV
131800407	A36002	06/29/2013	6:25	06/29/2013	14:10	5	2325	465	Underground equipment	Underground Primary	Repair	Repair	I
131800147	A36002	06/29/2013	6:28	06/29/2013	9:50	34	6868	202	Underground equipment	Underground Primary	Switch/Reset		I
131800144	A36002	06/29/2013	6:30	06/29/2013	9:50	13	2600	200	Underground equipment	Underground Primary	Switch/Reset	Repair	I
131800152	P83705	06/29/2013	6:45	06/29/2013	9:40	1	175	175	Overhead equipment	Fuse	Repair	Repair	I
131800151	P83705	06/29/2013	6:45	06/29/2013	9:15	8	1200	150	Overhead equipment	Fuse	Repair	Repair	I
131800155	P83705	06/29/2013	6:48	06/29/2013	9:00	12	1584	132	Overhead equipment	Fuse	Repair	Repair	I
131800156	K43386	06/29/2013	6:51	06/29/2013	12:30	15	5085	339	Overhead equipment				V
131800158	R50910	06/29/2013	7:03	06/29/2013	9:53	1	170	170	Overhead equipment	Other	Replace - Same Size	No Work Required	I
131800179	K43386	06/29/2013	7:08	06/29/2013	8:20	35	2520	72	Overhead equipment				V
131800167		06/29/2013	7:09	06/29/2013	9:00	1	111	111	Animal related	Recloser	Repair		IV
131800169	K43386	06/29/2013	7:13	06/29/2013	8:43	1	90	90	Overhead equipment				V
131800172	K43386	06/29/2013	7:15	06/29/2013	9:56	7	1127	161	Overhead equipment				V
131800175	B44001	06/29/2013	7:16	06/29/2013	9:55	1	159	159	Tree related-tree broken	Overhead Service	Tie/Tighten		I
131800191	Q27185	06/29/2013	7:26	06/29/2013	8:55	17	1513	89	Animal related	Fuse	Replace - Same Size		VI
131800187	A80001	06/29/2013	7:27	06/29/2013	9:21	1	114	114	Weather	Transformer Fuse	Replace - Same Size		I
131800189	S86582	06/29/2013	7:27	06/29/2013	8:30	6	378	63	Animal related	Transformer Fuse	Replace - Same Size		VI
131800268	B82001	06/29/2013	7:30	06/29/2013	7:40	110	1100	10	Overhead equipment	Disconnect Switch	Replace - Same Size		I
131800205	B82001	06/29/2013	7:32	06/29/2013	10:53	97	19497	201	Overhead equipment	Disconnect Switch	Replace - Same Size		I
131800199	B82001	06/29/2013	7:32	06/29/2013	8:40	10	680	68	Overhead equipment	Overhead Transformer	Replace - Same Size		I
131800213	J88166	06/29/2013	7:47	06/29/2013	8:05	71	1278	18	Animal related	Fuse			VI
131800214		06/29/2013	7:49	06/29/2013	8:57	1	68	68	Animal related	Fuse	Replace - Same Size		VI
131800226	B84002	06/29/2013	8:02	06/29/2013	8:48	48	2208	46	Animal related	Fuse	Replace - Same Size		I
131800224	K36151	06/29/2013	8:04	06/29/2013	9:17	1	73	73	Weather	Transformer Fuse	Replace - Same Size		III
131800955	K43386	06/29/2013	8:22	06/29/2013	19:49	676	464412	687	Overhead equipment	Overhead Primary	Cut in Clear	Reconnect	V

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
131800248	R60551	06/29/2013	8:28	06/29/2013	9:54	1	86	86	Animal related	Transformer Fuse	Replace - Same Size	No Work Required	IV
131800251	B45004	06/29/2013	8:32	06/29/2013	17:00	5	2540	508	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
131800267	P81854	06/29/2013	8:47	06/29/2013	12:42	1	235	235	Tree related-tree contact	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	V
131800291	K76542	06/29/2013	9:26	06/29/2013	9:54	16	448	28	Animal related	Transformer Fuse	Replace - Same Size		IV
131800296	B00005	06/29/2013	9:32	06/29/2013	12:25	1	173	173	Overhead equipment	Overhead Service	Repair		I
131800295		06/29/2013	9:32	06/29/2013	10:55	1	83	83	Animal related	Transformer Fuse	Replace - Same Size		V
131800297	B93002	06/29/2013	9:34	06/29/2013	12:35	1	181	181	Animal related	Transformer Fuse	Replace - Same Size		I
131800304	V37537	06/29/2013	9:40	06/29/2013	11:06	1	86	86	Animal related	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	II
131800330	C00001	06/29/2013	9:47	06/29/2013	19:56	4	2436	609	Underground equipment	Underground Primary		Repair	I
131800325	C40002	06/29/2013	9:53	06/29/2013	11:12	30	2370	79	Unknown	Fuse	Replace - Same Size		I
131800419	R50910	06/29/2013	10:10	06/29/2013	12:39	11	1639	149	Overhead equipment	Lightning Arrestor	Repair		I
131800349	R50910	06/29/2013	10:10	06/29/2013	11:37	23	2001	87	Overhead equipment	Lightning Arrestor	Replace - Same Size		I
131800347	M37191	06/29/2013	10:11	06/29/2013	11:07	1	56	56	Overhead equipment	Overhead Service	Repair		I
131800369	H32370	06/29/2013	10:26	06/29/2013	12:00	1	94	94	Overhead equipment	Fuse	Replace - Same Size		V
131800373	R50910	06/29/2013	10:31	06/29/2013	12:47	1	136	136	Overhead equipment	Recloser	Repair	No Work Required	I
131800377	U33586	06/29/2013	10:36	06/29/2013	14:30	1	234	234	Underground equipment	Underground Service			II
131800385	J89125	06/29/2013	10:40	06/29/2013	11:15	1	35	35	Animal related	Fuse	Replace - Same Size		VI
131800570	Y39515	06/29/2013	11:15	06/29/2013	13:52	48	7536	157	Overhead equipment	Jumper	Repair	Patrol/Test/Inspect	IV
131800431	Y55594	06/29/2013	11:23	06/29/2013	12:36	2	146	73	Animal related	Animal Guard	Install		IV
131800447	T09559	06/29/2013	11:37	06/29/2013	13:05	1	88	88	Overhead equipment	Overhead Service	Patrol/Test/Inspect	Cut in Clear	VI
131800459	R07381	06/29/2013	11:48	06/29/2013	13:52	47	5828	124	Overhead equipment	Overhead Primary	Repair	Repair	I
131800492	U91599	06/29/2013	12:06	06/29/2013	14:35	1	149	149	Overhead equipment	Lightning Arrestor		Replace - Same Size	II
131800501	U32594	06/29/2013	12:13	06/29/2013	13:14	106	6466	61	Tree related-tree broken				II
131800541	P82291	06/29/2013	12:22	06/29/2013	13:30	1	68	68	Animal related	Fuse			VI
131800547	R07381	06/29/2013	12:27	06/29/2013	13:53	1	86	86	Overhead equipment	Crossarm	Replace - Same Size		I
131800560	A81004	06/29/2013	12:32	06/29/2013	15:47	132	25740	195	Weather	Disconnect Switch	Repair		I
131800572	Q28141	06/29/2013	12:42	06/29/2013	13:57	2	150	75	Animal related	Fuse	Replace - Same Size	Repair	VI
131800592	P26283	06/29/2013	13:02	06/29/2013	20:30	1	448	448	Weather	Fuse	Replace - Same Size		I
131800605	L23148	06/29/2013	13:10	06/29/2013	13:40	1	30	30	Unknown	Transformer Fuse	Replace - Same Size		III
131800610	M36184	06/29/2013	13:15	06/29/2013	18:30	1	315	315	Overhead equipment	Overhead Primary		Repair	I
131800619	K75312	06/29/2013	13:19	06/29/2013	14:12	71	3763	53	Tree related-tree broken	Transformer Fuse	Replace - Same Size	No Work Required	IV
131800620	Q54908	06/29/2013	13:20	06/29/2013	15:00	1	100	100	Animal related	Fuse	Replace - Same Size	Patrol/Test/Inspect	VI
131800639	Q93522	06/29/2013	13:24	06/29/2013	18:00	129	35604	276	Overhead equipment	Overhead Primary	Repair	Repair	I
131800633	M36184	06/29/2013	13:28	06/29/2013	18:30	1	302	302	Overhead equipment	Underground Primary		Repair	I
131800641		06/29/2013	13:34	06/29/2013	18:19	1	285	285	Jurisdictional	Underground Primary	Repair		I
131800643	K78352	06/29/2013	13:36	06/29/2013	14:40	1	64	64	Animal related	Fuse	Replace - Same Size	No Work Required	IV
131800656	N48106	06/29/2013	13:51	06/29/2013	15:24	1	93	93	Tree related-tree broken	Overhead Service	Cut in Clear		II
131800658	R99180	06/29/2013	13:53	06/29/2013	19:10	1	317	317	Weather	Overhead Transformer	Replace - Same Size	No Work Required	IV
131800436	A85002	06/29/2013	13:54	06/29/2013	18:17	2	526	263	Underground equipment	Underground Primary	Patrol/Test/Inspect		I
131800737	H01190	06/29/2013	13:55	06/29/2013	15:00	22	1430	65	Weather	Fuse	Replace - Same Size		III
131800667	P26284	06/29/2013	14:02	06/29/2013	15:50	2	216	108	Weather	Fuse	Replace - Same Size	Replace - Same Size	I
131800670	K78352	06/29/2013	14:03	06/29/2013	14:45	1	42	42	Animal related	Fuse	Replace - Same Size	No Work Required	IV
131800712	K89143	06/29/2013	14:06	06/29/2013	15:30	185	15540	84	Overhead equipment	Overhead Primary	Repair		III
131801841	L12126	06/29/2013	14:08	06/30/2013	2:20	3	2196	732	Underground equipment	Underground Primary			III
131801840	L12126	06/29/2013	14:08	06/30/2013	0:01	100	59300	593	Underground equipment	Underground Primary	Repair		III
131800715	M26161	06/29/2013	14:15	06/29/2013	15:21	23	1518	66	Weather	Fuse	Replace - Same Size		III
131800721	M26161	06/29/2013	14:30	06/29/2013	15:23	1	53	53	Weather	Fuse	Replace - Same Size		III
131800727	K89143	06/29/2013	14:34	06/29/2013	15:25	1	51	51	Overhead equipment	Overhead Primary	Repair		III
131800730	L12126	06/29/2013	14:37	06/29/2013	15:05	1	28	28	Overhead equipment	Fuse	Replace - Same Size		III
131800731	V95586	06/29/2013	14:40	06/29/2013	16:40	1	120	120	Tree related-tree broken	Transformer Fuse	Replace - Same Size		II
131800761	D70004	06/29/2013	15:00	06/29/2013	23:48	1	528	528	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	I
131800804		06/29/2013	15:00	06/29/2013	17:19	466	64774	139	Substation equipment				II
131800789	R07382	06/29/2013	15:04	06/29/2013	17:31	24	3528	147	Underground equipment	Fuse	Replace - Same Size	Repair	I
131800852	Y79500	06/29/2013	15:17	06/29/2013	17:14	13	1521	117	Unknown	Fuse	Repair	Replace - Same Size	IV
131800827	V77543	06/29/2013	15:21	06/29/2013	16:05	5	220	44	Weather	Transformer Fuse	Repair		II
131800825	W03570	06/29/2013	15:27	06/29/2013	17:10	21	2163	103	Tree related-tree broken	Tree	Remove	Patrol/Test/Inspect	II

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
131801129	Q23255	06/29/2013	16:05	06/29/2013	17:45	5	500	100	Weather	Fuse			VI
131800999	339160	06/29/2013	16:11	06/29/2013	17:55	30	3120	104	Weather	Overhead Primary	Repair		V
131801143	325007	06/29/2013	16:39	06/29/2013	17:34	10	550	55	Overhead equipment	Overhead Transformer	Switch/Reset		VI
131801119	R02121	06/29/2013	16:42	06/29/2013	19:55	2	386	193	Overhead equipment	Overhead Primary	Patrol/Test/Inspect	Repair	VI
131801260	Q21321	06/29/2013	16:45	06/29/2013	18:15	16	1440	90	Weather	Fuse			VI
131801261	K31124	06/29/2013	16:57	06/29/2013	23:45	1	408	408	Weather	Jumper	Repair	No Work Required	I
131801319	J34377	06/29/2013	17:16	06/29/2013	19:15	21	2499	119	Public	Fuse	Replace - Same Size	Replace - Same Size	V
131801357	J34377	06/29/2013	17:18	06/29/2013	19:15	31	3627	117	Public	Fuse	Replace - Same Size		V
131801336	M09144	06/29/2013	17:21	06/29/2013	19:22	1	121	121	Overhead equipment	Overhead Secondary	Replace - Same Size	Repair	VI
131801338	S24598	06/29/2013	17:22	06/29/2013	18:30	6	408	68	Weather	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
131801362	S25552	06/29/2013	17:25	06/29/2013	19:55	38	5700	150	Tree related-tree broken	Overhead Primary	Patrol/Test/Inspect	Repair	VI
131801363	R39934	06/29/2013	17:28	06/29/2013	18:40	1	72	72	Weather	Fuse		Patrol/Test/Inspect	VI
131801372	M54292	06/29/2013	17:31	06/29/2013	21:05	1	214	214	Overhead equipment				V
131801374	S24598	06/29/2013	17:33	06/29/2013	20:50	6	1182	197	Tree related-tree broken	Transformer Fuse	Replace - Same Size	Replace - Same Size	VI
131801447	S22595	06/29/2013	17:42	06/29/2013	19:20	117	11466	98	Tree related-tree broken	Overhead Primary	Trim		VI
131801401	P77233	06/29/2013	17:43	06/29/2013	20:14	1	151	151	Weather	Transformer Fuse			VI
131801422	P42230	06/29/2013	17:49	06/29/2013	19:25	3	288	96	Weather	Overhead Transformer			VI
131801421	T06503	06/29/2013	17:49	06/29/2013	20:10	1	141	141	Overhead equipment	Overhead Service	Cut in Clear	Cut in Clear	VI
131801465	L12126	06/29/2013	17:58	06/29/2013	20:50	21	3612	172	Underground equipment	Underground Primary			III
131801449		06/29/2013	18:01	06/29/2013	20:30	1	149	149	Tree related-tree broken	Tree	Trim	No Work Required	VI
131801477	N05172	06/29/2013	18:13	06/29/2013	22:22	1	249	249	Animal related	Fuse	Repair	Replace - Same Size	I
131801521	S43511	06/29/2013	18:30	06/29/2013	20:47	1	137	137	Tree related-tree broken	Overhead Primary	Repair	Replace - Same Size	VI
131801572	S24597	06/29/2013	19:00	06/29/2013	21:12	1	132	132	Tree related-tree contact	Overhead Service	Cut in Clear		VI
131801588	J80806	06/29/2013	19:13	06/29/2013	21:27	2	268	134	Overhead equipment	Overhead Transformer	Repair	Repair	V
131801779	S83533	06/29/2013	19:26	06/30/2013	2:30	9	3816	424	Overhead equipment	Recloser	Patrol/Test/Inspect	Switch/Reset	VI
131801614	D31015	06/29/2013	19:32	06/29/2013	20:49	7	539	77	Overhead equipment	Transformer Fuse			III
131801701	K31124	06/29/2013	19:41	06/29/2013	22:28	2	334	167	Weather	Overhead Primary	Repair		I
131801627		06/29/2013	19:42	06/29/2013	21:50	1	128	128	Overhead equipment	Fuse	Replace - Same Size		I
131801640	S34527	06/29/2013	20:00	06/30/2013	1:18	2	636	318	Tree related-tree broken	Overhead Service	Patrol/Test/Inspect	Repair	VI
131801646	K11373	06/29/2013	20:07	06/29/2013	22:00	4	452	113	Overhead equipment				V
131801690	T17581	06/29/2013	20:42	06/29/2013	21:12	363	10890	30	Tree related-tree broken	Tree			VI
131801692	J79304	06/29/2013	20:50	06/29/2013	21:45	1	55	55	Overhead equipment	Other	No Work Required		I
131801722	L35137	06/29/2013	21:21	06/30/2013	0:56	1	215	215	Underground equipment	Underground Secondary		Repair	III
131801726	S25551	06/29/2013	21:26	06/29/2013	23:35	1	129	129	Tree related-tree broken	Overhead Service	Raise	No Work Required	VI
131801761	K89141	06/29/2013	22:02	06/29/2013	23:59	1	117	117	Tree related-tree contact	Overhead Service	Repair		III
131801781	K43386	06/29/2013	22:50	06/29/2013	22:54	4	16	4	Unknown				V
131801789	L12127	06/29/2013	22:54	06/30/2013	3:00	18	4428	246	Underground equipment	Underground Primary		Repair	III
131810036	K11373	06/30/2013	1:21	06/30/2013	5:20	10	2390	239	Tree related-tree contact	Overhead Primary	Repair		V
131810058	L35137	06/30/2013	2:33	06/30/2013	3:30	20	1140	57	Underground equipment	Underground Primary	Switch/Reset	Repair	III
131810051	Y45504	06/30/2013	3:03	06/30/2013	4:20	1	77	77	Tree related-tree broken	Transformer Fuse	Repair	Replace - Same Size	IV
131810074	Q93522	06/30/2013	6:04	06/30/2013	11:30	1	326	326	Tree related-tree broken	Tree	Cut in Clear		I
131810081	V63570	06/30/2013	6:32	06/30/2013	7:47	1	75	75	Animal related	Transformer Fuse	Replace - Same Size		II
131810083	J88163	06/30/2013	6:50	06/30/2013	8:00	1	70	70	Animal related	Transformer Fuse			VI
131810088	R34920	06/30/2013	7:12	06/30/2013	8:40	1	88	88	Animal related	Fuse	Replace - Same Size		VI
131810089		06/30/2013	7:15	06/30/2013	11:30	1	255	255	Unknown	Fuse			III
131810096	L99392	06/30/2013	7:20	06/30/2013	8:16	2	112	56	Animal related	Transformer Fuse	Replace - Same Size	Replace - Same Size	V
131810132	V45526	06/30/2013	7:23	06/30/2013	9:47	5	720	144	Animal related	Transformer Fuse	Patrol/Test/Inspect	Repair	II
131810103	K69117	06/30/2013	7:25	06/30/2013	8:33	2	136	68	Animal related	Transformer Fuse	Replace - Same Size		IV
131810109	P42230	06/30/2013	7:29	06/30/2013	8:51	1	82	82	Overhead equipment	Overhead Service			VI
131810124	A42005	06/30/2013	7:43	06/30/2013	8:20	46	1702	37	Animal related	Disconnect Switch	Replace - Same Size		I
131810125	K15205	06/30/2013	7:52	06/30/2013	10:09	7	959	137	Animal related	Transformer Fuse			VI
131810130	K43383	06/30/2013	8:01	06/30/2013	8:07	1	6	6	Underground equipment	Underground Service	Patrol/Test/Inspect	Repair	V
131810133	Q74148	06/30/2013	8:08	06/30/2013	11:00	1	172	172	Weather	Transformer Fuse			IV
131810135	B93002	06/30/2013	8:10	06/30/2013	10:25	1	135	135	Unknown	Fuse	Replace - Same Size		I
131810134	D96001	06/30/2013	8:10	06/30/2013	9:01	1	51	51	Animal related	Transformer Fuse	Replace - Same Size	Replace - Same Size	I
131810139	D16001	06/30/2013	8:25	06/30/2013	12:30	1	245	245	Underground equipment	Underground Service	Replace - Same Size	Replace - Same Size	I

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
131810158	L50217	06/30/2013	9:01	06/30/2013	10:34	3	279	93	Animal related	Transformer Fuse			VI
131810159	M04364	06/30/2013	9:01	06/30/2013	10:07	10	660	66	Animal related	Transformer Fuse	Replace - Same Size	Replace - Same Size	V
131810165		06/30/2013	9:09	06/30/2013	10:00	1	51	51	Weather	Transformer Fuse	Replace - Same Size		IV
131810167	N54214	06/30/2013	9:11	06/30/2013	11:40	1	149	149	Animal related	Lightning Arrestor	Replace - Same Size		II
131810175	R02121	06/30/2013	9:27	06/30/2013	11:39	1	132	132	Overhead equipment	Transformer Fuse	Replace - Same Size	No Work Required	VI
131810195	S88502	06/30/2013	10:02	06/30/2013	11:11	1	69	69	Unknown	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
131810197	Y91500	06/30/2013	10:04	06/30/2013	11:00	1	56	56	Overhead equipment	Overhead Service	Repair	Replace - Same Size	IV
131810204	Q80353	06/30/2013	10:17	06/30/2013	12:36	1	139	139	Animal related	Transformer Fuse	Replace - Same Size	Replace - Same Size	V
131810209	344002	06/30/2013	10:21	06/30/2013	11:24	14	882	63	Public	Disconnect Switch	Replace - Same Size		VI
131810213	X82576	06/30/2013	10:33	06/30/2013	11:58	1	85	85	Animal related	Disconnect Switch		Install	IV
131810224	B71002	06/30/2013	10:44	06/30/2013	11:41	1	57	57	Tree related-tree broken	Overhead Service	Replace - Same Size		I
131810228	L99392	06/30/2013	10:56	06/30/2013	14:49	1	233	233	Animal related	Transformer Fuse	Replace - Same Size	Replace - Same Size	V
131810247	S34527	06/30/2013	11:02	06/30/2013	22:41	2	1398	699	Overhead equipment	Overhead Transformer	Repair	Repair	VI
131810238	S42578	06/30/2013	11:13	06/30/2013	12:24	1	71	71	Unknown	Transformer Fuse	Replace - Same Size	Replace - Same Size	VI
131810250	X42502	06/30/2013	11:29	06/30/2013	13:04	4	380	95	Overhead equipment	Disconnect Switch	Replace - Same Size		IV
131810264	R84148	06/30/2013	12:00	06/30/2013	14:07	1	127	127	Animal related	Fuse	Replace - Same Size		I
131810290	B93001	06/30/2013	12:49	06/30/2013	20:00	1	431	431	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
131810289	V45526	06/30/2013	12:49	06/30/2013	15:45	1	176	176	Overhead equipment	Overhead Service	Repair		II
131810294	Y82590	06/30/2013	12:59	06/30/2013	14:13	1	74	74	Animal related	Transformer Fuse	Replace - Same Size		IV
131810244	A80001	06/30/2013	13:05	06/30/2013	15:33	2	296	148	Overhead equipment	Overhead Transformer	Replace - New Size	Repair	I
131810441	Z17503	06/30/2013	14:03	06/30/2013	15:40	7	679	97	Overhead equipment	Fuse	Replace - Same Size		IV
131810443	Q91141	06/30/2013	14:04	06/30/2013	14:30	1	26	26	Overhead equipment	Overhead Service	Tie/Tighten		I
131810445	Z17522	06/30/2013	14:04	06/30/2013	15:20	2	152	76	Tree related-tree broken	Tree	Remove		IV
131810466	C37001	06/30/2013	14:16	06/30/2013	15:18	60	3720	62	Overhead equipment	Fuse	Replace - Same Size		III
131810484	G10002	06/30/2013	14:33	06/30/2013	15:25	15	780	52	Tree related-tree broken	Tree			I
131810503	P47169	06/30/2013	15:13	06/30/2013	20:30	10	3170	317	Underground equipment	Underground Secondary	Repair	Repair	I
131810533	N67309	06/30/2013	15:33	06/30/2013	16:49	1	76	76	Overhead equipment	Fuse	Replace - Same Size		I
131810546	A45003	06/30/2013	16:05	06/30/2013	20:21	1	256	256	Overhead equipment	Overhead Transformer	Replace - Same Size	Repair	I
131810600	T02534	06/30/2013	17:13	06/30/2013	19:05	4	448	112	Overhead equipment	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
131810824	U78756	06/30/2013	17:50	06/30/2013	20:00	1	130	130	Overhead equipment	Pole	Switch/Reset		II
131810631	R10925	06/30/2013	18:01	06/30/2013	21:20	2	398	199	Tree related-tree contact	Tree	Trim	Trim	VI
131810653	B28006	06/30/2013	18:07	06/30/2013	22:21	172	43688	254	Tree related-tree broken	Overhead Primary	Patrol/Test/Inspect	Repair	I
131810692	D32211	06/30/2013	18:54	06/30/2013	19:53	1	59	59	Weather	Transformer Fuse	Replace - Same Size		I
131810780	Q91141	06/30/2013	19:42	07/01/2013	1:00	41	13038	318	Overhead equipment	Overhead Transformer		Replace - Same Size	I
131810724	Z29579	06/30/2013	19:45	06/30/2013	21:30	1	105	105	Tree related-tree contact	Overhead Service	Repair		IV
131810732	D36001	06/30/2013	19:51	06/30/2013	20:41	1	50	50	Overhead equipment	Connector	Replace - Same Size		I
131810755	K89143	06/30/2013	20:52	06/30/2013	23:32	1	160	160	Underground equipment	Underground Secondary		Repair	III
131810766	V63570	06/30/2013	21:24	06/30/2013	22:44	1	80	80	Overhead equipment	Fuse	Replace - Same Size		II
131810772	P26284	06/30/2013	21:34	06/30/2013	22:39	1	65	65	Overhead equipment	Transformer Fuse	Replace - Same Size	Repair	I
131810789	339162	06/30/2013	22:31	06/30/2013	23:15	1	44	44	Overhead equipment	Overhead Secondary	Repair		V
131810791	R39934	06/30/2013	22:36	06/30/2013	23:18	1	42	42	Animal related	Fuse	Replace - Same Size	Patrol/Test/Inspect	VI
131820094	Y45504	07/01/2013	0:36	07/01/2013	4:50	1	254	254	Overhead equipment	Pole	Repair		IV
131823916	B80004	07/01/2013	1:09	07/01/2013	9:43	14	7196	514	Underground equipment	Underground Primary	Patrol/Test/Inspect	Replace - Urgent	I
131820107	Q47833	07/01/2013	2:29	07/01/2013	5:08	1	159	159	Animal related	Transformer Fuse			V
131823836	B19002	07/01/2013	3:35	07/01/2013	7:06	8	1688	211	Overhead equipment	Pole	Replace - Same Size	Install	I
131823839	Y34597	07/01/2013	4:50	07/01/2013	6:55	40	5000	125	Tree related-tree contact	Fuse			IV
131823858	G10002	07/01/2013	5:52	07/01/2013	10:40	14	4032	288	Overhead equipment				I
131823879		07/01/2013	6:28	07/01/2013	7:33	1	65	65	Weather	Transformer Fuse	Replace - Same Size		IV
131823880	Q70161	07/01/2013	6:30	07/01/2013	9:40	1	190	190	Overhead equipment	Overhead Transformer	Replace - Same Size		I
131823894	K65221	07/01/2013	6:40	07/01/2013	7:31	4	204	51	Public	Fuse	Repair	Repair	III
131823899	G10002	07/01/2013	6:43	07/01/2013	10:50	1	247	247	Overhead equipment				I
131823907	C37001	07/01/2013	6:47	07/01/2013	8:36	1	109	109	Overhead equipment	Disconnect Switch	Replace - Same Size	No Work Required	III
131823904	J99128	07/01/2013	6:47	07/01/2013	7:45	1	58	58	Animal related	Transformer Fuse			VI
131823910	J15303	07/01/2013	6:51	07/01/2013	8:00	1	69	69	Animal related	Fuse	Replace - Same Size	Replace - Same Size	I
131823913	B57002	07/01/2013	6:54	07/01/2013	13:57	1	423	423	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
131823924	J84146	07/01/2013	7:02	07/01/2013	8:32	1	90	90	Overhead equipment	Overhead Service			VI

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
131823935	J87150	07/01/2013	7:09	07/01/2013	8:00	1	51	51	Overhead equipment	Fuse	Repair	Repair	VI
131824070		07/01/2013	7:52	07/01/2013	8:38	1	46	46	Overhead equipment	Disconnect Switch	Replace - Same Size		VI
131824102	Y23513	07/01/2013	7:59	07/01/2013	14:45	1	406	406	Underground equipment	Underground Primary	Repair	Replace - Same Size	IV
131824113	N44217	07/01/2013	8:03	07/01/2013	12:07	1	244	244	Overhead equipment	Overhead Transformer			III
131824136	S47589	07/01/2013	8:10	07/01/2013	11:53	1	223	223	Underground equipment	Underground Primary	Repair	Repair	VI
131824279	A80001	07/01/2013	8:37	07/01/2013	9:42	1	65	65	Overhead equipment	Fuse	Repair	Replace - Same Size	I
131824326	R23333	07/01/2013	8:46	07/01/2013	12:00	1	194	194	Underground equipment	Underground Secondary	Repair		V
131824356	L23146	07/01/2013	8:48	07/01/2013	9:41	101	5353	53	Overhead equipment	Fuse	Replace - Same Size		III
131824371	J76804	07/01/2013	8:52	07/01/2013	10:28	1	96	96	Jurisdictional				V
131824411	L79159	07/01/2013	8:56	07/01/2013	11:22	6	876	146	Animal related	Fuse	Replace - Same Size		IV
131824486	K31120	07/01/2013	9:02	07/01/2013	10:41	195	19305	99	Overhead equipment	Jumper	Repair		I
131824538	D69003	07/01/2013	9:13	07/01/2013	13:30	1	257	257	Underground equipment	Underground Service		Repair	I
131824561	K05253	07/01/2013	9:17	07/01/2013	11:12	1	115	115	Overhead equipment	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
131824604	Z08509	07/01/2013	9:24	07/01/2013	11:22	2	236	118	Tree related-tree contact	Overhead Service	Repair	Replace - Same Size	IV
131824653	L17104	07/01/2013	9:36	07/01/2013	10:46	8	560	70	Animal related	Fuse	Replace - Same Size		III
131824666	J88166	07/01/2013	9:39	07/01/2013	10:23	1	44	44	Overhead equipment	Transformer Fuse	Repair	Repair	VI
131824698	Q24310	07/01/2013	9:44	07/01/2013	10:54	1	70	70	Animal related	Fuse	Replace - Same Size		VI
131825278	K11376	07/01/2013	10:26	07/01/2013	15:25	6	1794	299	Underground equipment	Underground Primary		Repair	V
131824936	X78536	07/01/2013	10:30	07/01/2013	11:24	1	54	54	Tree related-tree broken	Tree	Trim		IV
131825041	R59412	07/01/2013	10:48	07/01/2013	12:35	1	107	107	Unknown				IV
131825217	B77001	07/01/2013	11:26	07/01/2013	17:31	1	365	365	Underground equipment	Underground Primary		Repair	I
131825257	B28006	07/01/2013	11:36	07/01/2013	12:40	1	64	64	Animal related				I
131825302	P85145	07/01/2013	11:44	07/01/2013	12:22	6	228	38	Overhead equipment	Fuse	Repair	Repair	III
131825343	P85145	07/01/2013	11:57	07/01/2013	12:24	1	27	27	Overhead equipment	Fuse	Repair	Repair	III
131825473	M19222	07/01/2013	12:25	07/01/2013	13:57	1	92	92	Animal related	Fuse	Replace - Same Size		VI
131825499	N03297	07/01/2013	12:30	07/01/2013	13:27	58	3306	57	Tree related-tree broken	Overhead Primary	Patrol/Test/Inspect		V
131825680	Y36559	07/01/2013	13:09	07/01/2013	14:05	44	2464	56	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	IV
131825716	J61115	07/01/2013	13:20	07/01/2013	14:57	1	97	97	Unknown				III
131825760	R06209	07/01/2013	13:32	07/01/2013	14:35	1	63	63	Overhead equipment	Transformer Fuse	Replace - Same Size		II
131825803	X86543	07/01/2013	13:36	07/01/2013	14:15	7	273	39	Weather	Fuse	Replace - Same Size	No Work Required	IV
131825872	K43383	07/01/2013	13:53	07/01/2013	15:24	7	637	91	Overhead equipment	Overhead Transformer		Replace - Same Size	V
131825936	X12002	07/01/2013	14:05	07/01/2013	15:13	5	340	68	Tree related-tree broken	Tree	Remove		IV
131825982	S42579	07/01/2013	14:15	07/01/2013	15:50	1	95	95	Public	Overhead Service	Repair	Replace - Same Size	VI
131826138	P58155	07/01/2013	14:49	07/01/2013	15:54	1	65	65	Animal related	Transformer Fuse	Replace - Same Size		VI
131826227	337001	07/01/2013	15:07	07/01/2013	15:27	7	140	20	Tree related-tree broken	Tree	Remove		VI
131826255	D41003	07/01/2013	15:11	07/01/2013	17:36	3	435	145	Underground equipment	Underground Primary		Repair	I
131826268	S09520	07/01/2013	15:14	07/01/2013	16:20	1	66	66	Animal related	Fuse	Replace - Same Size	Replace - Same Size	VI
131826313	Y89535	07/01/2013	15:26	07/01/2013	16:00	1	34	34	Overhead equipment	Transformer Fuse	Repair	Replace - Same Size	IV
131826241	R23332	07/01/2013	15:26	07/01/2013	18:48	2	404	202	Overhead equipment	Tree	Trim	Repair	V
131826394	N72240	07/01/2013	15:43	07/01/2013	16:58	1	75	75	Unknown	Other			III
131826453		07/01/2013	16:01	07/01/2013	17:45	1	104	104	Overhead equipment	Overhead Primary		Repair	IV
131826526	K15205	07/01/2013	16:32	07/01/2013	17:21	1	49	49	Tree related-tree broken	Overhead Service			VI
131826678	S93507	07/01/2013	17:11	07/01/2013	18:50	17	1683	99	Overhead equipment	Lightning Arrestor	Repair		VI
131826636	C10002	07/01/2013	17:47	07/01/2013	18:25	1	38	38	Tree related-tree contact	Overhead Secondary	Repair		III
131826849	E10001	07/01/2013	17:59	07/01/2013	19:18	1	79	79	Overhead equipment	Fuse	Replace - Same Size		III
131826920	D55001	07/01/2013	18:06	07/01/2013	22:25	8	2072	259	Overhead equipment	Overhead Transformer	Replace - Same Size	Replace - Same Size	I
131826933	S09520	07/01/2013	18:13	07/01/2013	20:40	29	4263	147	Animal related	Lightning Arrestor	Replace - Same Size	Patrol/Test/Inspect	VI
131827558	Q93522	07/01/2013	18:38	07/01/2013	20:30	1	112	112	Overhead equipment	Overhead Service	No Work Required	No Work Required	I
131827572	Y66557	07/01/2013	18:45	07/01/2013	19:42	16	912	57	Unknown	Transformer Fuse	Replace - Same Size		IV
131827570	Q34360	07/01/2013	18:46	07/01/2013	20:01	1	75	75	Animal related	Fuse	Replace - Same Size	Repair	I
131827580	M25144	07/01/2013	18:50	07/01/2013	20:32	4	408	102	Tree related-tree contact	Fuse	Replace - Same Size		IV
131827577	M25143	07/01/2013	18:54	07/01/2013	21:23	1	149	149	Weather	Transformer Fuse	Replace - Same Size		IV
131827631	D67001	07/01/2013	20:13	07/01/2013	21:49	1	96	96	Weather	Transformer Fuse	Replace - Same Size		IV
131827650	Y23513	07/01/2013	21:04	07/01/2013	22:35	1	91	91	Overhead equipment	Overhead Service			IV
131827664	N73121	07/01/2013	21:33	07/01/2013	23:40	1	127	127	Tree related-tree contact	Overhead Service	Repair		IV
131827705	Q91141	07/01/2013	21:39	07/02/2013	1:18	302	66138	219	Overhead equipment	Overhead Primary	Repair	Repair	I

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
131827692	X02548	07/01/2013	22:14	07/01/2013	23:05	1	51	51	Weather	Transformer Fuse	Replace - Same Size		IV
131827707	T01534	07/01/2013	22:45	07/02/2013	5:10	1	385	385	Tree related-tree broken	Overhead Primary	Repair	Patrol/Test/Inspect	VI
131827720	T01534	07/01/2013	23:00	07/02/2013	5:15	1	375	375	Tree related-tree broken	Overhead Secondary	Patrol/Test/Inspect	Repair	VI
131827713	B84006	07/01/2013	23:02	07/02/2013	5:30	1	388	388	Underground equipment	Underground Primary	Repair	Replace - Same Size	I
131827717	Q32171	07/01/2013	23:14	07/02/2013	0:30	1	76	76	Overhead equipment	Fuse	No Work Required	No Work Required	I
131827721	Y04508	07/01/2013	23:42	07/02/2013	8:00	1	498	498	Overhead equipment	Overhead Transformer	Replace - Same Size	Replace - Same Size	IV
131834170	N44215	07/02/2013	1:32	07/02/2013	3:21	6	654	109	Underground equipment	Underground Primary	Switch/Reset		III
131833769	N44215	07/02/2013	1:32	07/02/2013	3:21	14	1526	109	Underground equipment	Underground Primary	No Work Required	No Work Required	III
131830157	N44215	07/02/2013	1:32	07/02/2013	6:25	30	8790	293	Overhead equipment	Fuse	Patrol/Test/Inspect		III
131830166	B68002	07/02/2013	1:42	07/02/2013	2:57	89	6675	75	Overhead equipment	Fuse	Replace - Same Size		III
131830169	A28001	07/02/2013	1:51	07/02/2013	7:19	1	328	328	Underground equipment	Underground Service	Patrol/Test/Inspect	Replace - Urgent	I
131830236	B25002	07/02/2013	2:08	07/02/2013	6:55	1	287	287	Overhead equipment	Overhead Primary	Repair	Repair	I
131830238	R08910	07/02/2013	2:12	07/02/2013	3:45	1	93	93	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	VI
131834146	D32211	07/02/2013	2:53	07/02/2013	9:02	30	11070	369	Tree related-tree broken	Overhead Primary		Repair	I
131831024	B68002	07/02/2013	3:00	07/02/2013	3:45	25	1125	45	Underground equipment	Underground Primary	Switch/Reset		III
131831031	B68002	07/02/2013	3:03	07/02/2013	3:30	64	1728	27	Overhead equipment	Fuse	Replace - Same Size		III
131834191	J84146	07/02/2013	6:06	07/02/2013	9:26	1	200	200	Tree related-tree contact	Overhead Service		Replace - Same Size	VI
131834197	B28004	07/02/2013	6:15	07/02/2013	7:11	23	1288	56	Animal related	Fuse	Replace - Same Size		I
131834207	J07135	07/02/2013	6:24	07/02/2013	7:12	22	1056	48	Overhead equipment	Fuse	Replace - Same Size		I
131834242	S07535	07/02/2013	7:02	07/02/2013	7:45	1	43	43	Animal related	Transformer Fuse	Repair		VI
131834257	S47537	07/02/2013	7:16	07/02/2013	8:42	1	86	86	Animal related	Disconnect Switch	Replace - Same Size	Replace - Same Size	VI
131834289	D36002	07/02/2013	7:21	07/02/2013	9:19	1	118	118	Overhead equipment	Fuse	Repair		I
131834317	K73362	07/02/2013	7:30	07/02/2013	8:50	1	80	80	Animal related	Transformer Fuse	Replace - Same Size		IV
131834323	Y45503	07/02/2013	7:35	07/02/2013	11:09	1	214	214	Overhead equipment	Pole	Repair	Replace - New Size	IV
131834340	A50002	07/02/2013	7:41	07/02/2013	11:02	1	201	201	Overhead equipment	Overhead Primary	Patrol/Test/Inspect	Repair	I
131834366	L93133	07/02/2013	7:51	07/02/2013	8:40	3	147	49	Weather				VI
131834386	D90002	07/02/2013	7:56	07/02/2013	8:25	1	29	29	Animal related	Fuse	Replace - Same Size		III
131834392	L93133	07/02/2013	7:59	07/02/2013	8:41	1	42	42	Weather				VI
131834425	B62003	07/02/2013	8:07	07/02/2013	14:47	1	400	400	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
131834441	N70330	07/02/2013	8:13	07/02/2013	9:20	1	67	67	Animal related	Fuse	Replace - Same Size		I
131834459	M22812	07/02/2013	8:21	07/02/2013	10:10	1	109	109	Weather	Transformer Fuse	Replace - Same Size		V
131834677	J20931	07/02/2013	8:38	07/02/2013	11:50	77	14784	192	Overhead equipment	Pole	Replace - Same Size	Repair	VI
131834995	B19002	07/02/2013	8:42	07/02/2013	10:11	2	178	89	Underground equipment	Underground Primary	Switch/Reset		I
131834990	B19002	07/02/2013	8:42	07/02/2013	15:29	2	814	407	Overhead equipment	Fuse	Replace - Same Size	Repair	I
131834550	J20931	07/02/2013	8:44	07/02/2013	9:12	16	448	28	Overhead equipment	Overhead Primary	Switch/Reset		VI
131834681	J50186	07/02/2013	8:45	07/02/2013	9:27	24	1008	42	Animal related	Fuse			III
131834543	D31018	07/02/2013	8:46	07/02/2013	10:50	1	124	124	Overhead equipment	High Line Switch	Replace - Same Size	Repair	III
131834649	HB6281	07/02/2013	9:07	07/02/2013	10:11	1	64	64	Overhead equipment	Transformer Fuse	Repair	Repair	VI
131834745	D96002	07/02/2013	9:32	07/02/2013	15:29	1	357	357	Overhead equipment	Overhead Transformer	Replace - Same Size	Repair	I
131834900	S49550	07/02/2013	9:55	07/02/2013	10:50	825	45375	55	Overhead equipment	Overhead Primary	Repair	Repair	VI
131834855	D96002	07/02/2013	9:56	07/02/2013	11:51	1	115	115	Animal related	Transformer Fuse	Replace - Same Size	No Work Required	I
131834961	K71822	07/02/2013	10:13	07/02/2013	11:00	1	47	47	Animal related	Transformer Fuse	Replace - Same Size		IV
131835010	S43512	07/02/2013	10:25	07/02/2013	12:40	1	135	135	Overhead equipment	Connector	Tie/Tighten	No Work Required	VI
131835046	B27009	07/02/2013	10:35	07/02/2013	11:16	1	41	41	Overhead equipment	Connector	Repair	Replace - Same Size	I
131835074	P25150	07/02/2013	10:44	07/02/2013	11:50	1	66	66	Tree related-tree broken	Overhead Service	Repair		III
131835104	Q93522	07/02/2013	10:51	07/02/2013	13:30	1	159	159	Overhead equipment	Overhead Primary	Repair	Repair	I
131835109	N15849	07/02/2013	10:53	07/02/2013	11:41	1	48	48	Overhead equipment	Connector	Replace - Same Size	No Work Required	V
131835133	IP9009	07/02/2013	10:59	07/02/2013	14:00	37	6697	181	Tree related-tree contact	Tree	Trim		VI
131835179	K28180	07/02/2013	11:13	07/02/2013	12:52	1	99	99	Overhead equipment	Fuse	Replace - Same Size		III
131835198	R99180	07/02/2013	11:19	07/02/2013	14:20	1	181	181	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	IV
131835218	X23516	07/02/2013	11:24	07/02/2013	12:37	1	73	73	Overhead equipment	Overhead Primary			IV
131835259	V49541	07/02/2013	11:36	07/02/2013	12:17	1	41	41	Overhead equipment	Transformer Fuse	Repair	Repair	II
131835351	R10903	07/02/2013	12:09	07/02/2013	13:11	6	372	62	Animal related	Fuse	Replace - Same Size	Replace - Same Size	VI
131835367	Y45504	07/02/2013	12:14	07/02/2013	12:52	1	38	38	Unknown	Transformer Fuse	Repair	Replace - Same Size	IV
131835473	C40001	07/02/2013	12:40	07/02/2013	16:54	193	49022	254	Underground equipment	Other	Replace - Same Size	Repair	I
131835463		07/02/2013	12:41	07/02/2013	13:29	1	48	48	Animal related	Transformer Fuse	Replace - New Size		VI

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
131835519	D60001	07/02/2013	12:51	07/02/2013	14:20	36	3204	89	Underground equipment	Underground Primary		Repair	III
131835563	K89141	07/02/2013	13:03	07/02/2013	13:43	35	1400	40	Overhead equipment	Overhead Primary	Repair		III
131835681	J85160	07/02/2013	13:32	07/02/2013	14:24	5	260	52	Animal related	Fuse	Replace - Same Size		VI
131835707	X02547	07/02/2013	13:47	07/02/2013	15:08	1	81	81	Weather	Transformer Fuse	Replace - Same Size		IV
131835774	M37192	07/02/2013	14:04	07/02/2013	14:30	1	26	26	Overhead equipment	Overhead Service	No Work Required		I
131835876	D93002	07/02/2013	14:31	07/02/2013	15:18	1	47	47	Overhead equipment	Overhead Service	Patrol/Test/Inspect	Replace - New Size	IV
131836003	Y66556	07/02/2013	15:07	07/02/2013	18:40	3	639	213	Overhead equipment	Overhead Transformer		Replace - Same Size	IV
131836085	C40001	07/02/2013	15:23	07/02/2013	16:54	170	15470	91	Underground equipment	Switchgear	Repair	Repair	I
131836112	S14511	07/02/2013	15:36	07/02/2013	16:05	1	29	29	Animal related	Disconnect Switch	Repair		VI
131836173	P69174	07/02/2013	15:54	07/02/2013	16:53	1	59	59	Animal related	Transformer Fuse	Replace - Same Size		III
131836200	H22346	07/02/2013	16:03	07/02/2013	17:00	1	57	57	Animal related	Transformer Fuse	Replace - Same Size		V
131836456	L81141	07/02/2013	16:22	07/02/2013	18:21	9	1071	119	Overhead equipment	Overhead Transformer			IV
131836281	M45211	07/02/2013	16:37	07/02/2013	18:32	1	115	115	Tree related-tree contact	Overhead Service	Repair		IV
131836294	D48001	07/02/2013	16:42	07/02/2013	17:56	1	74	74	Overhead equipment	Overhead Service	Replace - Same Size		I
131836360	S60581	07/02/2013	17:08	07/02/2013	19:49	1	161	161	Tree related-tree broken	Tree			VI
131836813	M54292	07/02/2013	18:48	07/02/2013	20:19	45	4095	91	Overhead equipment	Fuse	Repair		V
131836905	J89126	07/02/2013	19:48	07/02/2013	22:05	15	2055	137	Overhead equipment	Overhead Primary		Replace - Same Size	VI
131837174	J18267	07/02/2013	20:10	07/02/2013	22:00	217	23870	110	Overhead equipment	Recloser			VI
131836901	S03531	07/02/2013	20:29	07/02/2013	21:40	1	71	71	Tree related-tree broken	Overhead Service	Repair	Repair	VI
131836917	X86543	07/02/2013	20:51	07/02/2013	22:30	1	99	99	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
131837167	M18131	07/02/2013	21:39	07/02/2013	22:44	1	65	65	Overhead equipment	Connector	Repair		III
131837201	Z20542	07/02/2013	23:35	07/03/2013	1:06	1	91	91	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
131837205	S78551	07/02/2013	23:46	07/03/2013	1:38	1	112	112	Overhead equipment	Overhead Service			VI
131844717	K71812	07/03/2013	3:11	07/03/2013	4:50	20	1980	99	Tree related-tree broken	Fuse			IV
131845183	B93002	07/03/2013	4:17	07/03/2013	13:04	1	527	527	Underground equipment	Underground Primary	Patrol/Test/Inspect	Replace - Urgent	I
131844947	A17026	07/03/2013	5:15	07/03/2013	6:29	1	74	74	Overhead equipment	Connector	Replace - Same Size		I
131844957	L79159	07/03/2013	5:58	07/03/2013	6:38	8	320	40	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
131844983	U84587	07/03/2013	6:30	07/03/2013	7:10	22	880	40	Animal related	Fuse	Replace - Same Size		II
131845055	M36185	07/03/2013	7:08	07/03/2013	8:13	5	325	65	Overhead equipment	Transformer Fuse	Replace - Same Size		I
131845040	M78325	07/03/2013	7:08	07/03/2013	8:26	1	78	78	Underground equipment	Underground Service	Replace - Same Size	Patrol/Test/Inspect	V
131845058	Y61007	07/03/2013	7:15	07/03/2013	8:40	1	85	85	Tree related-tree broken	Overhead Service	Repair		IV
131845113	M09143	07/03/2013	7:23	07/03/2013	9:10	6	642	107	Animal related	Fuse	Replace - Same Size	Repair	VI
131845119	M05362	07/03/2013	7:23	07/03/2013	8:35	51	3672	72	Animal related	Fuse	Replace - Same Size		V
131845137	B21002	07/03/2013	7:34	07/03/2013	11:06	14	2968	212	Underground equipment	Fuse	Patrol/Test/Inspect	Repair	I
131845202	P60170	07/03/2013	8:01	07/03/2013	8:50	1	49	49	Tree related-tree broken	Overhead Service	Repair		VI
131845252	D16003	07/03/2013	8:14	07/03/2013	11:50	1	216	216	Tree related-tree contact	Overhead Service	Repair		I
131845709	B45005	07/03/2013	8:28	07/03/2013	11:58	5	1050	210	Tree related-tree broken	Overhead Primary	Patrol/Test/Inspect	Repair	I
131845366	J89126	07/03/2013	8:39	07/03/2013	9:30	1	51	51	Animal related	Fuse	Replace - Same Size		VI
131845404	W03570	07/03/2013	8:50	07/03/2013	10:15	1	85	85	Animal related	Transformer Fuse	Replace - Same Size		II
131845413	K07322	07/03/2013	8:54	07/03/2013	10:32	1	98	98	Overhead equipment	Lightning Arrestor	Replace - Same Size		I
131845415	R66470	07/03/2013	8:54	07/03/2013	11:14	1	140	140	Tree related-tree broken	Overhead Service			IV
131845454	J98130	07/03/2013	9:05	07/03/2013	9:52	1	47	47	Overhead equipment	Transformer Fuse			VI
131845566	A81001	07/03/2013	9:34	07/03/2013	10:05	1	31	31	Animal related	Fuse	Patrol/Test/Inspect	Replace - Same Size	I
131845611	N67309	07/03/2013	9:34	07/03/2013	10:34	294	17640	60	Overhead equipment	Connector	Repair	No Work Required	I
131846074	N70330	07/03/2013	9:34	07/03/2013	10:34	68	4080	60	Overhead equipment	Connector	Repair	Repair	I
131845679	R66470	07/03/2013	9:58	07/03/2013	11:01	1	63	63	Animal related	Transformer Fuse	Replace - Same Size	No Work Required	IV
131845743	J89126	07/03/2013	10:11	07/03/2013	10:34	1	23	23	Overhead equipment			No Work Required	VI
131845608	N67309	07/03/2013	10:32	07/03/2013	10:34	511	1022	2	Overhead equipment	Connector	Repair	No Work Required	I
131845836	N70330	07/03/2013	10:32	07/03/2013	10:34	1587	3174	2	Overhead equipment	Connector	Repair	No Work Required	I
131845878	K80388	07/03/2013	10:36	07/03/2013	11:32	24	1344	56	Animal related	Fuse	Replace - Same Size	No Work Required	IV
131845890	B44001	07/03/2013	10:44	07/03/2013	11:08	1	24	24	Overhead equipment	Customer Equipment			I
131845911	T14575	07/03/2013	10:52	07/03/2013	11:49	1	57	57	Public	Overhead Primary	Patrol/Test/Inspect	Patrol/Test/Inspect	VI
131845938	Y23513	07/03/2013	10:59	07/03/2013	12:25	1	86	86	Animal related	Disconnect Switch	Repair	Replace - Same Size	IV
131845971	N70331	07/03/2013	11:09	07/03/2013	12:35	7	602	86	Public	Underground Transformer	Repair		I
131846008	R84148	07/03/2013	11:19	07/03/2013	13:06	1	107	107	Overhead equipment	Overhead Service	Tie/Tighten	Repair	I
131846075	L82187	07/03/2013	11:39	07/03/2013	12:50	1	71	71	Overhead equipment	Overhead Service			IV

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
131846198	Q16868	07/03/2013	12:20	07/03/2013	17:43	28	9044	323	Underground equipment	Underground Primary	Switch/Reset	Replace - Same Size	V
131846231	N44215	07/03/2013	12:32	07/03/2013	13:30	1	58	58	Unknown	Transformer Fuse	Replace - Same Size		III
131846343	U09517	07/03/2013	12:59	07/03/2013	13:28	1	29	29	Unknown	Fuse	Replace - Same Size		II
131846476	Q28141	07/03/2013	13:38	07/03/2013	15:52	1	134	134	Overhead equipment	Connector	Replace - Same Size	Repair	VI
131846528	N94180	07/03/2013	13:50	07/03/2013	14:35	1	45	45	Animal related	Transformer Fuse	Replace - Same Size		I
131846677	S61529	07/03/2013	14:08	07/03/2013	14:26	502	9036	18	Overhead equipment				VI
131846671	J99141	07/03/2013	14:17	07/03/2013	15:01	43	1892	44	Underground equipment	Underground Primary			VI
131846687	S64501	07/03/2013	14:22	07/03/2013	14:26	3	12	4	Overhead equipment	Overhead Primary			VI
131846706	S62520	07/03/2013	14:29	07/03/2013	14:38	1	9	9	Overhead equipment				VI
131846746	X24536	07/03/2013	14:40	07/03/2013	15:30	1	50	50	Weather	Transformer Fuse			IV
131846770	D70004	07/03/2013	14:49	07/03/2013	16:05	335	25460	76	Public	Overhead Primary	Repair	Repair	I
131846778	N58144	07/03/2013	14:52	07/03/2013	17:30	1	158	158	Overhead equipment	Transformer Fuse	Patrol/Test/Inspect		I
131846846	Q16868	07/03/2013	15:02	07/03/2013	15:12	25	250	10	Underground equipment	Underground Primary	Switch/Reset		V
131847123	P20930	07/03/2013	16:57	07/03/2013	18:20	1	83	83	Animal related	Fuse		Patrol/Test/Inspect	VI
131847128	S25551	07/03/2013	16:59	07/03/2013	20:00	1	181	181	Tree related-tree broken	Overhead Service	Patrol/Test/Inspect	Cut in Clear	VI
131847203	D55002	07/03/2013	17:49	07/03/2013	19:28	37	3663	99	Overhead equipment	Fuse	Replace - Same Size		I
131847205	K28183	07/03/2013	17:52	07/03/2013	19:01	1	69	69	Animal related	Transformer Fuse	Replace - Same Size		III
131847226	M49410	07/03/2013	18:15	07/03/2013	18:28	1	13	13	Underground equipment	Underground Secondary	Cut in Clear	Repair	V
131847750	J80806	07/03/2013	19:05	07/03/2013	19:40	1	35	35	Animal related	Overhead Transformer	Repair	Repair	V
131847773	J34377	07/03/2013	19:52	07/03/2013	21:02	1	70	70	Underground equipment	Underground Secondary	Patrol/Test/Inspect	Repair	V
131847802	312115	07/03/2013	20:35	07/04/2013	0:43	1	248	248	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	V
131847811	N35851	07/03/2013	20:50	07/03/2013	22:20	1	90	90	Public	Meter	Replace - Same Size	No Work Required	V
131847836	J30201	07/03/2013	22:26	07/04/2013	0:10	1	104	104	Overhead equipment	Overhead Transformer	Switch/Reset	Patrol/Test/Inspect	VI
131847848	R05114	07/03/2013	22:48	07/03/2013	23:30	1	42	42	Public	Meter	Replace - New Size	Replace - Same Size	I
131847850	334001	07/03/2013	23:09	07/04/2013	1:07	4	472	118	Public	Fuse	Replace - Same Size		VI
131847857	334001	07/03/2013	23:12	07/04/2013	1:14	3	366	122	Public	Fuse	Replace - Same Size		VI
131850012	N70330	07/04/2013	1:05	07/04/2013	3:30	1	145	145	Overhead equipment	Other	Replace - Same Size	Replace - Same Size	I
131850014	334001	07/04/2013	6:19	07/04/2013	6:27	1	8	8	Public				VI
131850126	Q18242	07/04/2013	7:10	07/04/2013	9:24	1	134	134	Underground equipment			No Work Required	VI
131850131	J86108	07/04/2013	7:16	07/04/2013	8:31	7	525	75	Animal related	Fuse			VI
131850130	J99128	07/04/2013	7:19	07/04/2013	8:45	1	86	86	Underground equipment	Underground Primary		Replace - Same Size	VI
131850134	P49183	07/04/2013	7:29	07/04/2013	8:25	1	56	56	Animal related	Transformer Fuse	Replace - Same Size		I
131850145	Y68581	07/04/2013	7:42	07/04/2013	9:50	10	1280	128	Unknown	Fuse	Replace - Same Size		IV
131850163	U84534	07/04/2013	8:20	07/04/2013	9:22	1	62	62	Overhead equipment	Transformer Fuse	Replace - Same Size		II
131850170	K57211	07/04/2013	8:23	07/04/2013	9:20	17	969	57	Animal related	Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
131850173	Q06142	07/04/2013	8:30	07/04/2013	12:36	1	246	246	Underground equipment	Riser		Replace - Same Size	IV
131850179	M09144	07/04/2013	8:51	07/04/2013	10:51	1	120	120	Overhead equipment	Overhead Secondary	Replace - Same Size	Repair	VI
131850185	M40132	07/04/2013	9:02	07/04/2013	9:40	1	38	38	Overhead equipment	Transformer Fuse	Replace - Same Size		I
131850215	A49002	07/04/2013	9:52	07/04/2013	13:30	1	218	218	Underground equipment	Underground Secondary	Patrol/Test/Inspect	Repair	I
131850221	M78325	07/04/2013	10:18	07/04/2013	15:42	1	324	324	Underground equipment	Underground Secondary	Repair		V
131850226	U02597	07/04/2013	10:20	07/04/2013	11:45	2	170	85	Overhead equipment	Transformer Fuse	Replace - Same Size	Patrol/Test/Inspect	II
131850228	B25001	07/04/2013	10:22	07/04/2013	11:29	1	67	67	Overhead equipment	Transformer Fuse	Replace - Same Size		I
131850242	R09226	07/04/2013	11:31	07/04/2013	12:15	2	88	44	Animal related	Fuse	Replace - Same Size		III
131850263	314167	07/04/2013	11:37	07/04/2013	12:44	1	67	67	Overhead equipment	Overhead Service	Replace - Same Size	No Work Required	V
131850286	A56013	07/04/2013	12:02	07/04/2013	13:05	1	63	63	Weather	Disconnect Switch	Replace - Same Size		I
131850295	U80511	07/04/2013	12:28	07/04/2013	13:42	9	666	74	Unknown	Transformer Fuse	Replace - Same Size		II
131850304	R68903	07/04/2013	12:53	07/04/2013	13:44	1	51	51	Overhead equipment	Disconnect Switch	Repair		I
131850419	B81002	07/04/2013	13:41	07/04/2013	21:55	2	988	494	Underground equipment	Underground Primary	Switch/Reset	Repair	I
131850327	B81002	07/04/2013	13:41	07/04/2013	16:22	24	3864	161	Underground equipment	Underground Primary	Switch/Reset	Repair	I
131850345	343008	07/04/2013	14:20	07/04/2013	17:03	1	163	163	Overhead equipment	Fuse	Repair		VI
131850351	B28006	07/04/2013	14:33	07/04/2013	17:28	1	175	175	Overhead equipment	Fuse	Replace - Same Size		I
131850360	A28001	07/04/2013	14:48	07/04/2013	17:25	1	157	157	Overhead equipment	Connector	Repair		I
131850399	P42230	07/04/2013	16:17	07/04/2013	20:05	1	228	228	Overhead equipment	Overhead Transformer	Disconnect	Replace - Same Size	VI
131850404	Y35001	07/04/2013	16:21	07/04/2013	17:19	47	2726	58	Tree related-tree broken	Overhead Primary	Repair	Replace - Same Size	IV
131850416	Q69926	07/04/2013	16:47	07/04/2013	18:20	1	93	93	Overhead equipment	Fuse	Replace - Same Size		VI
131850418	K52401	07/04/2013	16:53	07/04/2013	17:57	1	64	64	Overhead equipment	Jumper	Repair	No Work Required	V

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
131850433	D36001	07/04/2013	17:22	07/04/2013	18:41	1	79	79	Underground equipment	Underground Secondary	Repair		I
131850478	K30205	07/04/2013	18:28	07/04/2013	19:47	1	79	79	Animal related	Transformer Fuse	Replace - Same Size		III
131850480	B28006	07/04/2013	18:29	07/05/2013	5:10	1	641	641	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
131850493	J58381	07/04/2013	18:43	07/04/2013	19:43	1	60	60	Animal related	Fuse			III
131850520	N90246	07/04/2013	19:48	07/04/2013	21:31	1	103	103	Tree related-tree contact	Overhead Secondary			III
131850533	V61563	07/04/2013	20:28	07/04/2013	21:12	1	44	44	Weather	Transformer Fuse	Replace - Same Size		II
131850539	S27598	07/04/2013	20:38	07/04/2013	22:30	1	112	112	Tree related-tree contact	Overhead Service			VI
131850679	L74193	07/04/2013	21:21	07/04/2013	23:30	25	3225	129	Overhead equipment	Overhead Primary	Repair		IV
131850664	F03004	07/04/2013	22:27	07/05/2013	0:04	1	97	97	Animal related	Fuse	Replace - Same Size	No Work Required	III
131860095	J88166	07/05/2013	0:18	07/05/2013	1:12	1	54	54	Public	Transformer Fuse	Tie/Tighten		VI
131860103	X29003	07/05/2013	1:30	07/05/2013	3:41	1	131	131	Overhead equipment	Overhead Service	Replace - Same Size		IV
131860111	L73155	07/05/2013	1:53	07/05/2013	3:25	1	92	92	Tree related-tree broken	Tree	Trim		IV
131860130	M37192	07/05/2013	1:56	07/05/2013	6:12	347	88832	256	Overhead equipment	Overhead Primary	Repair	Repair	I
131860128	M37192	07/05/2013	2:01	07/05/2013	4:10	1	129	129	Overhead equipment	Overhead Primary	Switch/Reset		I
131860149	M37192	07/05/2013	2:04	07/05/2013	4:10	63	7938	126	Overhead equipment	Overhead Primary	Switch/Reset		I
131862020	L12127	07/05/2013	3:17	07/05/2013	6:02	18	2970	165	Underground equipment	Underground Primary	Switch/Reset		III
131862025	V78002	07/05/2013	3:51	07/05/2013	5:07	1	76	76	Overhead equipment	Other			II
131862032	N93260	07/05/2013	3:58	07/05/2013	5:22	70	5880	84	Animal related	Fuse	Repair	Repair	III
131862063	Q93522	07/05/2013	5:40	07/05/2013	12:31	1	411	411	Overhead equipment	Underground Service			I
131862079		07/05/2013	6:06	07/05/2013	7:04	1	58	58	Overhead equipment	Fuse	Replace - Same Size		I
131862081	Q54908	07/05/2013	6:13	07/05/2013	9:16	1	183	183	Tree related-tree broken	Overhead Service	Repair	No Work Required	VI
131862117	Q11517	07/05/2013	6:51	07/05/2013	7:52	1	61	61	Animal related	Transformer Fuse	Replace - Same Size		I
131862121	Q32171	07/05/2013	6:52	07/05/2013	7:50	1	58	58	Overhead equipment	Transformer Fuse	Replace - Same Size	Replace - Same Size	I
131862172	Z06537	07/05/2013	7:38	07/05/2013	9:13	2	190	95	Animal related	Transformer Fuse	Replace - Same Size	Patrol/Test/Inspect	IV
131862235	V44504	07/05/2013	7:51	07/05/2013	9:25	1	94	94	Animal related	Transformer Fuse	Replace - Same Size		II
131862294	U84587	07/05/2013	8:07	07/05/2013	9:13	1	66	66	Animal related	Fuse	Replace - Same Size		II
131862326	Q95248	07/05/2013	8:13	07/05/2013	10:10	44	5148	117	Animal related	Fuse	Replace - Same Size		VI
131862316		07/05/2013	8:16	07/05/2013	10:45	1	149	149	Public	Overhead Service	Patrol/Test/Inspect	Repair	V
131862333	M36185	07/05/2013	8:19	07/05/2013	9:04	6	270	45	Overhead equipment	Transformer Fuse	Replace - Same Size		I
131862486	A85001	07/05/2013	8:21	07/05/2013	10:04	17	1751	103	Animal related	Fuse	Replace - Same Size		I
131862346	M49424	07/05/2013	8:24	07/05/2013	10:02	1	98	98	Tree related-tree broken	Overhead Service	Repair		V
131862366	A97003	07/05/2013	8:29	07/05/2013	10:24	1	115	115	Overhead equipment	Connector	Replace - Same Size		I
131862267	D89001	07/05/2013	8:31	07/05/2013	11:45	1	194	194	Public	Underground Primary	Patrol/Test/Inspect	Repair	I
131862422	R60552	07/05/2013	8:46	07/05/2013	9:26	1	40	40	Animal related	Transformer Fuse	Replace - Same Size	No Work Required	IV
131862436	346004	07/05/2013	8:49	07/05/2013	10:00	1	71	71	Overhead equipment	Overhead Service	Repair		VI
131862456	R16510	07/05/2013	8:57	07/05/2013	9:42	9	405	45	Public	Overhead Transformer	Switch/Reset		I
131862500	K28180	07/05/2013	9:10	07/05/2013	9:57	1	47	47	Animal related	Fuse	Replace - Same Size		III
131862526	J86118	07/05/2013	9:20	07/05/2013	12:11	1	171	171	Tree related-tree broken	Overhead Service			VI
131862804	R68903	07/05/2013	10:54	07/05/2013	12:11	1	77	77	Animal related	Fuse	Replace - Same Size		I
131862833	G20002	07/05/2013	11:00	07/05/2013	12:32	1	92	92	Overhead equipment	Jumper	Repair		III
131862857	Q93522	07/05/2013	11:06	07/05/2013	12:31	1	85	85	Underground equipment	Underground Service			I
131862917	S20555	07/05/2013	11:27	07/05/2013	13:14	1	107	107	Tree related-tree broken	Overhead Service	Cut in Clear	Advise Customer	VI
131863133	B19002	07/05/2013	12:39	07/05/2013	18:02	1	323	323	Underground equipment	Underground Primary	Replace - Same Size	Repair	I
131863128	M45211	07/05/2013	12:39	07/05/2013	13:38	1	59	59	Animal related	Transformer Fuse	Replace - Same Size		IV
131863134	B84006	07/05/2013	12:40	07/05/2013	13:30	1	50	50	Unknown	Fuse	Repair		I
131863187	Y48002	07/05/2013	12:59	07/05/2013	14:00	2	122	61	Tree related-tree contact	Overhead Service	Raise		IV
131863247	J80807	07/05/2013	13:20	07/05/2013	14:39	1	79	79	Animal related	Overhead Transformer	Repair	Repair	V
131863285	A85002	07/05/2013	13:32	07/05/2013	16:10	1	158	158	Overhead equipment	Overhead Service	Repair		I
131863579	M21134	07/05/2013	15:08	07/05/2013	16:46	1	98	98	Overhead equipment	Overhead Primary	Repair	Repair	VI
131863662	P47169	07/05/2013	15:58	07/05/2013	19:15	9	1773	197	Overhead equipment	Overhead Transformer	Replace - Urgent		I
131863729	D35003	07/05/2013	16:32	07/05/2013	18:41	1	129	129	Overhead equipment	Fuse	Replace - Same Size		I
131863754	325010	07/05/2013	16:47	07/05/2013	17:52	1	65	65	Overhead equipment	Overhead Service	Repair		VI
131863756	P57108	07/05/2013	16:49	07/05/2013	17:24	1	35	35	Other				VI
131864062	X99702	07/05/2013	16:59	07/05/2013	17:46	6	282	47	Public				IV
131863776	X99702	07/05/2013	16:59	07/05/2013	18:00	3	183	61	Unknown				IV
131864541	Z57516	07/05/2013	16:59	07/05/2013	22:15	610	192760	316	Public	Pole	Replace - Same Size	Replace - Same Size	IV

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
131863786	L68114	07/05/2013	17:09	07/05/2013	19:30	1	141	141	Overhead equipment	Connector	Replace - Same Size		IV
131863820	J83138	07/05/2013	17:40	07/05/2013	18:34	1	54	54	Animal related	Transformer Fuse			VI
131863834	P26283	07/05/2013	17:44	07/05/2013	21:37	21	4893	233	Overhead equipment	Pole	Replace - Same Size		I
131864071	M18131	07/05/2013	18:26	07/05/2013	21:36	1	190	190	Overhead equipment	Pole		Replace - Same Size	III
131864624	U62510	07/05/2013	18:35	07/05/2013	22:31	18	4248	236	Public	Overhead Primary	Repair		II
131864548	A24001	07/05/2013	19:24	07/05/2013	23:10	1	226	226	Underground equipment	Pole		Repair	I
131864595	M31204	07/05/2013	19:29	07/05/2013	23:25	5	1180	236	Underground equipment	Underground Primary	Repair		I
131864564	M31204	07/05/2013	19:29	07/05/2013	20:20	2	102	51	Underground equipment	Underground Primary	Replace - Same Size	Replace - Same Size	I
131864567	H06135	07/05/2013	19:33	07/05/2013	20:35	2	124	62	Overhead equipment	Jumper	Repair		IV
131864580	J34357	07/05/2013	20:06	07/05/2013	21:36	14	1260	90	Animal related	Underground Primary	Switch/Reset	Repair	V
131864584	A45002	07/05/2013	20:15	07/05/2013	21:49	1	94	94	Overhead equipment	Overhead Service	Repair		I
131864592	342004	07/05/2013	20:31	07/05/2013	21:40	1	69	69	Tree related-tree broken	Tree	Cut in Clear		VI
131864599	U44529	07/05/2013	20:53	07/05/2013	21:37	1	44	44	Animal related	Transformer Fuse	Repair	Repair	II
131864633	D69005	07/05/2013	21:30	07/06/2013	2:02	1	272	272	Underground equipment	Underground Secondary		Repair	I
131864645	U33509	07/05/2013	21:50	07/05/2013	23:05	16	1200	75	Underground equipment	Underground Primary		Switch/Reset	II
131864651	K69117	07/05/2013	21:54	07/06/2013	0:28	64	9856	154	Underground equipment	Underground Primary		Repair	IV
131864660	X02548	07/05/2013	22:31	07/05/2013	23:25	1	54	54	Overhead equipment	Fuse	Repair		IV
131864675	R25906	07/05/2013	23:44	07/06/2013	7:01	1	437	437	Overhead equipment	Overhead Primary	Repair		I
131870023	R05186	07/05/2013	23:51	07/06/2013	2:35	28	4592	164	Underground equipment	Underground Primary	Switch/Reset	Repair	I
131864680	D96002	07/05/2013	23:52	07/06/2013	2:00	1	128	128	Underground equipment	Underground Primary		Repair	I
131880774	Q25363	07/05/2013	23:53	07/06/2013	7:01	13	5564	428	Overhead equipment				I
131870016	P20930	07/06/2013	0:28	07/06/2013	4:00	1	212	212	Underground equipment	Lightning Arrestor	Replace - Same Size	Repair	VI
131870020	Q32170	07/06/2013	0:33	07/06/2013	4:50	4	1028	257	Tree related-tree broken	Overhead Primary	Cut in Clear	Repair	I
131870036	Z57516	07/06/2013	4:10	07/06/2013	4:55	1	45	45	Overhead equipment	Fuse	Repair	Replace - Same Size	IV
131870129	L12126	07/06/2013	5:57	07/06/2013	11:20	28	9044	323	Underground equipment	Underground Primary	Repair		III
131870062	L12126	07/06/2013	5:57	07/06/2013	7:00	36	2268	63	Underground equipment	Underground Primary			III
131870047	L12126	07/06/2013	5:57	07/06/2013	8:28	30	4530	151	Underground equipment	Underground Primary	No Work Required		III
131870055	K76546	07/06/2013	6:13	07/06/2013	7:15	23	1426	62	Animal related	Transformer Fuse	Replace - Same Size	No Work Required	IV
131870203	D70004	07/06/2013	6:15	07/06/2013	9:16	486	87966	181	Underground equipment	Underground Primary		Repair	I
131870052	S61580	07/06/2013	6:25	07/06/2013	7:35	1	70	70	Overhead equipment	Disconnect Switch	Repair	Repair	VI
131870071	K89144	07/06/2013	7:42	07/06/2013	8:20	12	456	38	Unknown	Fuse	Replace - Same Size		III
131870075	B73003	07/06/2013	7:50	07/06/2013	8:31	1	41	41	Animal related	Transformer Fuse	Replace - Same Size		I
131870192	B21004	07/06/2013	8:30	07/06/2013	12:00	7	1470	210	Underground equipment	Underground Primary	Switch/Reset	Repair	I
131870139	S42578	07/06/2013	8:36	07/06/2013	9:42	1	66	66	Animal related	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
131870145	M36189	07/06/2013	8:42	07/06/2013	13:27	1	285	285	Underground equipment	Underground Primary	Repair	Repair	I
131870148	X02546	07/06/2013	8:48	07/06/2013	10:00	1	72	72	Tree related-tree broken	Fuse	Repair	Replace - Same Size	IV
131870210	V18582	07/06/2013	9:25	07/06/2013	10:24	6	354	59	Jurisdictional	Transformer Fuse	Repair		II
131870217	Y98518	07/06/2013	9:30	07/06/2013	10:54	1	84	84	Unknown	Disconnect Switch	Repair	Replace - Same Size	IV
131870232	D55001	07/06/2013	9:54	07/06/2013	10:25	1	31	31	Overhead equipment	Overhead Service	Replace - Same Size		I
131870387	D70004	07/06/2013	10:01	07/06/2013	17:00	2	838	419	Underground equipment	Underground Primary		Patrol/Test/Inspect	I
131870250	D70004	07/06/2013	10:01	07/06/2013	13:43	37	8214	222	Underground equipment	Underground Primary		Repair	I
131870272	X69555	07/06/2013	10:32	07/06/2013	11:10	1	38	38	Overhead equipment	Fuse	Repair	Replace - Same Size	IV
131870273	Q47833	07/06/2013	10:35	07/06/2013	11:23	1	48	48	Overhead equipment	Fuse	Repair		V
131870293	A91004	07/06/2013	11:05	07/06/2013	12:09	11	704	64	Overhead equipment	Disconnect Switch	Replace - Same Size		I
131870296	D36001	07/06/2013	11:08	07/06/2013	12:37	1	89	89	Overhead equipment	Transformer Fuse	Replace - Same Size		I
131870307	R01152	07/06/2013	11:30	07/06/2013	13:10	1	100	100	Overhead equipment	Overhead Service			III
131870324	K80381	07/06/2013	11:45	07/06/2013	13:30	20	2100	105	Underground equipment	Underground Primary	Switch/Reset	Repair	IV
131870339	Q16868	07/06/2013	12:27	07/06/2013	14:12	1	105	105	Overhead equipment	Fuse	Replace - Same Size		V
131870341	X02548	07/06/2013	12:32	07/06/2013	13:43	1	71	71	Animal related	Transformer Fuse			IV
131870389	Q32171	07/06/2013	13:44	07/06/2013	15:07	1	83	83	Overhead equipment	Overhead Service			I
131870406	P26283	07/06/2013	14:23	07/06/2013	17:00	1	157	157	Public	Underground Transformer	Replace - Same Size	No Work Required	I
131870508	R73841	07/06/2013	15:30	07/06/2013	22:20	3	1230	410	Public	Pole	Replace - New Size	Replace - Same Size	V
131870441	S02501	07/06/2013	15:32	07/06/2013	17:45	4	532	133	Overhead equipment	Disconnect Switch	Repair	Repair	VI
131870535	X12002	07/06/2013	18:34	07/06/2013	19:32	1	58	58	Tree related-tree broken	Tree	Remove		IV
131870589	R49263	07/06/2013	19:13	07/06/2013	20:45	9	828	92	Weather	Fuse	Replace - Same Size	Patrol/Test/Inspect	VI
131870624	D87001	07/06/2013	19:55	07/06/2013	20:45	1	50	50	Overhead equipment	Disconnect Switch	Replace - Same Size		I

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
131870629	S88503	07/06/2013	20:07	07/07/2013	5:25	1	558	558	Underground equipment	Underground Secondary	Repair	Repair	VI
131870636	J30201	07/06/2013	20:20	07/06/2013	23:13	1	173	173	Weather	Fuse		Patrol/Test/Inspect	VI
131870655	P57108	07/06/2013	20:52	07/06/2013	22:44	14	1568	112	Tree related-tree broken	Tree	Patrol/Test/Inspect		VI
131870670	L59929	07/06/2013	21:56	07/07/2013	0:49	1	173	173	Tree related-tree contact	Overhead Service	Repair	Repair	VI
131870678	U61001	07/06/2013	22:02	07/07/2013	2:27	1	265	265	Overhead equipment	Pole	Replace - Same Size		II
131870699	S25551	07/06/2013	22:28	07/07/2013	3:12	2	568	284	Weather	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	VI
131880006	L59929	07/06/2013	22:37	07/07/2013	1:43	12	2232	186	Weather	Fuse	Repair	No Work Required	VI
131880008	HA5431	07/07/2013	0:35	07/07/2013	7:40	1	425	425	Overhead equipment	Overhead Primary	Repair	Repair	V
131880032	Q10702	07/07/2013	1:24	07/07/2013	3:40	129	17544	136	Other	Substation Breaker			V
131880026	A85002	07/07/2013	1:36	07/07/2013	2:43	1	67	67	Overhead equipment	Fuse	Replace - Same Size		I
131880038	B57002	07/07/2013	3:38	07/07/2013	5:11	1	93	93	Animal related	Fuse	Replace - Same Size		I
131880067	312112	07/07/2013	5:49	07/07/2013	10:55	40	12240	306	Tree related-tree broken	Pole	Repair	Replace - New Size	V
131880062	P49187	07/07/2013	6:15	07/07/2013	7:15	1	60	60	Animal related	Fuse	Replace - Same Size		I
131880075	P20930	07/07/2013	6:54	07/07/2013	8:27	1	93	93	Animal related	Transformer Fuse	Repair	No Work Required	VI
131880077	Y11555	07/07/2013	6:59	07/07/2013	8:02	9	567	63	Animal related	Transformer Fuse	Replace - Same Size		IV
131880078	J87120	07/07/2013	7:10	07/07/2013	8:00	8	400	50	Animal related	Fuse			VI
131880096	Q80352	07/07/2013	8:02	07/07/2013	9:13	3	213	71	Animal related	Overhead Primary	Repair	Replace - Same Size	V
131880132	Q32171	07/07/2013	8:40	07/07/2013	9:45	14	910	65	Animal related	Fuse	Replace - Same Size	Replace - Same Size	I
131880109	X69554	07/07/2013	8:42	07/07/2013	10:00	4	312	78	Overhead equipment	Fuse	Repair	Replace - Same Size	IV
131880110	S79510	07/07/2013	8:48	07/07/2013	9:56	1	68	68	Animal related	Overhead Transformer	Switch/Reset		VI
131880131	K28180	07/07/2013	9:19	07/07/2013	10:38	86	6794	79	Animal related	Fuse	Repair	Install	III
131880175	B93002	07/07/2013	9:49	07/07/2013	11:59	1	130	130	Underground equipment	Underground Primary	Switch/Reset	Repair	I
131880208	D36001	07/07/2013	10:53	07/07/2013	11:45	5	260	52	Overhead equipment	Fuse	Replace - Same Size		I
131880224	310122	07/07/2013	11:26	07/07/2013	13:00	1	94	94	Overhead equipment	Overhead Service	Repair		V
131880231	K01238	07/07/2013	11:33	07/07/2013	14:05	34	5168	152	Underground equipment	Underground Primary			VI
131880247	J47175	07/07/2013	12:04	07/07/2013	13:39	1	95	95	Overhead equipment	Fuse			III
131880370	R39934	07/07/2013	13:23	07/07/2013	17:00	1	217	217	Overhead equipment	Fuse			VI
131880379	T14576	07/07/2013	13:45	07/07/2013	17:30	7	1575	225	Other	Overhead Transformer	Patrol/Test/Inspect	Replace - New Size	VI
131880395	X66582	07/07/2013	14:01	07/07/2013	16:05	1	124	124	Overhead equipment	Overhead Service	Repair		IV
131880436	R10903	07/07/2013	14:35	07/07/2013	16:00	3	255	85	Overhead equipment	Fuse	Repair		VI
131880424	S95570	07/07/2013	14:38	07/07/2013	15:47	1	69	69	Animal related	Transformer Fuse	Replace - Same Size		VI
131880446	N58144	07/07/2013	14:51	07/07/2013	17:00	1	129	129	Animal related	Fuse	Replace - Same Size		I
131880449	U33509	07/07/2013	14:54	07/07/2013	15:39	1	45	45	Overhead equipment	Meter			II
131880585	X48716	07/07/2013	15:07	07/07/2013	18:10	658	120414	183	Animal related				IV
131880469	R50910	07/07/2013	15:09	07/07/2013	16:14	1	65	65	Animal related	Transformer Fuse	Replace - Same Size		I
131880523	Y07576	07/07/2013	15:14	07/07/2013	19:10	7	1652	236	Animal related	Pole	Replace - Same Size	Replace - Same Size	IV
131880545	J71128	07/07/2013	15:33	07/07/2013	23:40	1	487	487	Underground equipment	Underground Primary	Repair	Repair	I
131880557	D89003	07/07/2013	15:47	07/07/2013	16:38	1	51	51	Animal related	Transformer Fuse	Replace - Same Size		I
131880572	Q83171	07/07/2013	15:53	07/07/2013	17:55	1	122	122	Overhead equipment	Jumper	Repair	Repair	VI
131880592	U11531	07/07/2013	16:19	07/07/2013	18:12	1	113	113	Animal related	Transformer Fuse	Repair	Repair	II
131880594	E10003	07/07/2013	16:21	07/07/2013	17:25	1	64	64	Animal related	Fuse	Replace - Same Size		III
131880693	D66004	07/07/2013	16:34	07/07/2013	18:00	514	44204	86	Overhead equipment	Pole	Replace - Same Size	Replace - Same Size	IV
131880606	S88551	07/07/2013	16:35	07/07/2013	17:30	7	385	55	Overhead equipment	Transformer Fuse	Replace - Same Size		VI
131880662	P69173	07/07/2013	17:02	07/07/2013	17:43	1	41	41	Overhead equipment	Connector	Repair		III
131880663	Y34596	07/07/2013	17:02	07/07/2013	19:05	1	123	123	Animal related	Fuse	Replace - Same Size	No Work Required	IV
131880666	U61568	07/07/2013	17:10	07/07/2013	17:55	1	45	45	Overhead equipment	Transformer Fuse	Replace - Same Size	Repair	II
131880670	Z19547	07/07/2013	17:23	07/07/2013	23:21	1	358	358	Underground equipment	Underground Primary	Repair	Repair	IV
131880682	K76545	07/07/2013	17:40	07/07/2013	19:01	1	81	81	Animal related	Fuse	Replace - Same Size		IV
131880750	J87120	07/07/2013	19:32	07/07/2013	20:04	1	32	32	Animal related	Transformer Fuse			VI
131880753	T08502	07/07/2013	19:33	07/08/2013	6:00	1	627	627	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	VI
131880756	W03570	07/07/2013	19:39	07/07/2013	21:50	1	131	131	Overhead equipment	Overhead Service	Repair		II
131880681	J39391	07/07/2013	19:42	07/07/2013	20:59	30	2310	77	Overhead equipment	Fuse	Replace - Same Size		III
131880873	A49002	07/07/2013	19:47	07/07/2013	23:14	5	1035	207	Overhead equipment	Disconnect Switch	Replace - Same Size	Repair	I
131880818	J67134	07/07/2013	20:09	07/07/2013	22:27	14	1932	138	Overhead equipment	Fuse			III
131880783	N50331	07/07/2013	20:17	07/07/2013	21:30	1	73	73	Animal related	Transformer Fuse	Replace - Same Size		II
131880814	V80506	07/07/2013	20:44	07/07/2013	21:51	23	1541	67	Overhead equipment	Fuse	Replace - New Size		II

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
131880854	R39934	07/07/2013	21:38	07/08/2013	0:34	1	176	176	Weather	Fuse	Repair	No Work Required	VI
131880879	D92001	07/07/2013	22:38	07/08/2013	6:11	4	1812	453	Underground equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	I
131880897	Q91141	07/07/2013	23:30	07/08/2013	5:30	1	360	360	Overhead equipment	Overhead Transformer	Replace - Same Size	Replace - Same Size	I
131890096	B81003	07/08/2013	0:07	07/08/2013	1:47	54	5400	100	Overhead equipment	Fuse	Replace - Same Size		I
131890110	Q91175	07/08/2013	0:47	07/08/2013	6:33	1	346	346	Overhead equipment	Overhead Transformer	Replace - Same Size	Replace - Same Size	I
131890118	B81002	07/08/2013	1:07	07/08/2013	3:11	30	3720	124	Overhead equipment	Fuse	Replace - Same Size		I
131890132	U97002	07/08/2013	2:18	07/08/2013	3:26	6	408	68	Overhead equipment	Transformer Fuse	Replace - Same Size	Replace - Same Size	II
131890133	S88503	07/08/2013	2:30	07/08/2013	7:15	1	285	285	Underground equipment	Underground Transformer	Replace - Same Size	Replace - Same Size	VI
131891844	313136	07/08/2013	4:45	07/08/2013	6:55	26	3380	130	Overhead equipment				V
131891845	329146	07/08/2013	4:55	07/08/2013	6:55	1	120	120	Overhead equipment				V
131891870	M40132	07/08/2013	5:23	07/08/2013	9:15	5	1160	232	Tree related-tree broken	Overhead Primary	Tie/Tighten	No Work Required	I
131891847	J06168	07/08/2013	5:25	07/08/2013	9:50	2	530	265	Overhead equipment	Fuse		Replace - Same Size	I
131891851	B81002	07/08/2013	5:26	07/08/2013	7:55	30	4470	149	Underground equipment	Underground Transformer	Patrol/Test/Inspect	Replace - Urgent	I
131891853	J07135	07/08/2013	5:43	07/08/2013	13:05	1	442	442	Overhead equipment	Transformer Fuse	Replace - Same Size	Replace - Same Size	I
131891858	M40117	07/08/2013	5:58	07/08/2013	7:58	35	4200	120	Overhead equipment	Fuse		Replace - Same Size	I
131891869	K80382	07/08/2013	6:01	07/08/2013	7:57	39	4524	116	Underground equipment	Underground Primary		Repair	IV
131891892	N60181	07/08/2013	6:06	07/08/2013	8:47	61	9821	161	Overhead equipment	Fuse	Replace - Same Size		I
131891922	B19002	07/08/2013	6:13	07/08/2013	7:23	10	700	70	Weather	Fuse	Replace - Same Size		I
131891883	N60181	07/08/2013	6:15	07/08/2013	8:47	1	152	152	Overhead equipment	Fuse	Replace - Same Size		I
131891923	M61302	07/08/2013	6:46	07/08/2013	8:56	1	130	130	Animal related	Transformer Fuse			V
131891931	N58144	07/08/2013	6:51	07/08/2013	8:40	1	109	109	Overhead equipment	Fuse	Patrol/Test/Inspect	Replace - Same Size	I
131891944	D69007	07/08/2013	7:04	07/08/2013	10:50	1	226	226	Underground equipment	Underground Primary	Replace - Same Size	Replace - Same Size	I
131891968	M40132	07/08/2013	7:12	07/08/2013	8:55	5	515	103	Tree related-tree broken	Transformer Fuse	Cut in Clear		I
131891988	R50910	07/08/2013	7:17	07/08/2013	8:11	1	54	54	Overhead equipment	Transformer Fuse	Replace - Same Size		I
131892005	P52306	07/08/2013	7:24	07/08/2013	12:20	1	296	296	Public	Pole	Patrol/Test/Inspect	Replace - Same Size	IV
131892009	P52306	07/08/2013	7:25	07/08/2013	12:26	1	301	301	Public	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	IV
131892696	B61001	07/08/2013	7:34	07/08/2013	10:14	14	2240	160	Overhead equipment	Fuse	Replace - Same Size	No Work Required	I
131892044	J34377	07/08/2013	7:37	07/08/2013	11:01	1	204	204	Underground equipment	Underground Service	Cut in Clear	Repair	V
131892221	Q34360	07/08/2013	7:51	07/08/2013	9:15	24	2016	84	Overhead equipment	Jumper	Repair		I
131892189	A85001	07/08/2013	8:03	07/08/2013	10:04	44	5324	121	Animal related	Fuse	Replace - Same Size	No Work Required	I
131892193	D81002	07/08/2013	8:14	07/08/2013	11:35	1	201	201	Tree related-tree contact	Tree	Cut in Clear		I
131892220	M41113	07/08/2013	8:18	07/08/2013	9:36	54	4212	78	Animal related	Fuse	Replace - Same Size		I
131892226	P73182	07/08/2013	8:20	07/08/2013	12:00	1	220	220	Animal related	Fuse		Replace - Same Size	VI
131892250	A85002	07/08/2013	8:24	07/08/2013	10:56	1	152	152	Unknown	Fuse	Replace - Same Size	No Work Required	I
131892282	L99392	07/08/2013	8:31	07/08/2013	9:54	1	83	83	Weather			Patrol/Test/Inspect	V
131892399	J07135	07/08/2013	8:57	07/08/2013	13:05	1	248	248	Overhead equipment	Overhead Transformer	Replace - Same Size	Replace - Same Size	I
131892429	M37192	07/08/2013	9:04	07/08/2013	9:50	7	322	46	Tree related-tree broken	Overhead Transformer	Switch/Reset	No Work Required	I
131892469	L86175	07/08/2013	9:11	07/08/2013	12:10	20	3580	179	Underground equipment	Underground Primary	Switch/Reset	Repair	IV
131892494	M37192	07/08/2013	9:17	07/08/2013	9:54	1	37	37	Tree related-tree broken	Overhead Transformer	Switch/Reset	No Work Required	I
131892609	B84002	07/08/2013	9:42	07/08/2013	13:30	86	19608	228	Underground equipment	Underground Transformer	Patrol/Test/Inspect	Replace - Same Size	I
131893171	Y68581	07/08/2013	10:09	07/08/2013	11:22	411	30003	73	Tree related-tree broken	Recloser	Switch/Reset		IV
131892759	A56017	07/08/2013	10:15	07/08/2013	12:27	1	132	132	Overhead equipment	Disconnect Switch	Replace - Same Size		I
131893167	Y68581	07/08/2013	10:37	07/08/2013	17:38	3	1263	421	Tree related-tree broken				IV
131893163	Y68581	07/08/2013	10:37	07/08/2013	11:56	2	158	79	Overhead equipment	Pole	Replace - New Size	Repair	IV
131893233	M37192	07/08/2013	10:47	07/08/2013	12:02	10	750	75	Overhead equipment	Pole	Switch/Reset		I
131892961	M37192	07/08/2013	10:48	07/08/2013	15:35	31	8897	287	Overhead equipment	Pole		Replace - Same Size	I
131893181	B84002	07/08/2013	11:28	07/08/2013	14:20	36	6192	172	Overhead equipment	Jumper	Tie/Tighten		I
131893214	M31204	07/08/2013	11:40	07/08/2013	12:18	1	38	38	Overhead equipment				I
131893247	307005	07/08/2013	11:49	07/08/2013	12:30	30	1230	41	Public	Fuse	Replace - Same Size		VI
131893306	B44002	07/08/2013	12:02	07/08/2013	12:52	1	50	50	Animal related	Fuse	Repair	Replace - Same Size	I
131893343	B82001	07/08/2013	12:12	07/08/2013	12:50	1	38	38	Overhead equipment	Fuse	Repair		I
131893359	623001	07/08/2013	12:17	07/08/2013	20:28	1	491	491	Underground equipment	Underground Transformer	Patrol/Test/Inspect	Replace - Same Size	I
131893445	P62138	07/08/2013	12:25	07/08/2013	13:56	175	15925	91	Overhead equipment				VI
131893386	J76804	07/08/2013	12:29	07/08/2013	14:56	1	147	147	Overhead equipment	Overhead Service	Replace - Same Size	Replace - Same Size	V
131893471	B61001	07/08/2013	12:43	07/08/2013	15:18	1	155	155	Animal related	Disconnect Switch	Replace - Same Size	No Work Required	I
131893494	N60181	07/08/2013	12:48	07/08/2013	14:49	1	121	121	Overhead equipment	Overhead Transformer	Replace - Same Size	Replace - Same Size	I

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
131893535	M19222	07/08/2013	12:58	07/08/2013	15:13	1	135	135	Tree related-tree contact	Fuse	Replace - Same Size		VI
131893657		07/08/2013	13:25	07/08/2013	14:40	1	75	75	Public	Underground Secondary		Repair	III
131893685	D31015	07/08/2013	13:29	07/08/2013	14:24	54	2970	55	Underground equipment	Underground Primary			III
131893946	K80382	07/08/2013	14:30	07/08/2013	16:20	31	3410	110	Underground equipment	Underground Primary		Repair	IV
131893896	R73841	07/08/2013	14:30	07/08/2013	20:54	448	172032	384	Overhead equipment	Overhead Primary			V
131893963	K80382	07/08/2013	14:31	07/08/2013	16:10	38	3762	99	Underground equipment	Underground Primary		Repair	IV
131894598	R34920	07/08/2013	14:32	07/08/2013	16:40	231	29568	128	Tree related-tree broken				VI
131894593	R34920	07/08/2013	14:32	07/08/2013	16:23	155	17205	111	Tree related-tree broken				VI
131894602	R34920	07/08/2013	14:33	07/08/2013	16:40	29	3683	127	Tree related-tree broken				VI
131894164	R34920	07/08/2013	14:33	07/08/2013	19:20	247	70889	287	Tree related-tree broken	Overhead Primary	Repair	Repair	VI
131894017		07/08/2013	14:43	07/08/2013	16:20	1	97	97	Overhead equipment	Overhead Service	Patrol/Test/Inspect	Replace - New Size	VI
131894078	R95520	07/08/2013	14:54	07/08/2013	17:12	1	138	138	Overhead equipment	Fuse	Replace - Same Size		I
131894213	M40132	07/08/2013	15:22	07/08/2013	16:25	1	63	63	Overhead equipment	Transformer Fuse	Replace - Same Size	No Work Required	I
131894248	R60551	07/08/2013	15:29	07/08/2013	19:28	1	239	239	Underground equipment	Underground Service	Patrol/Test/Inspect	Repair	IV
131894583	B00002	07/08/2013	15:31	07/08/2013	20:31	22	6600	300	Underground equipment	Underground Primary	Repair		I
131894575	B00002	07/08/2013	15:31	07/08/2013	17:23	16	1792	112	Underground equipment	Underground Primary	Switch/Reset		I
131894276	P20913	07/08/2013	15:37	07/08/2013	16:45	1	68	68	Overhead equipment	Overhead Secondary	Repair	No Work Required	VI
131894295	S47586	07/08/2013	15:41	07/08/2013	16:36	12	660	55	Overhead equipment	Overhead Secondary	Repair		VI
131894345	Y35001	07/08/2013	15:54	07/08/2013	16:50	1	56	56	Overhead equipment	Overhead Service			IV
131894466	D70004	07/08/2013	16:23	07/08/2013	18:15	2	224	112	Underground equipment	Underground Transformer	Reconnect	Reconnect	I
131894430	U41517	07/08/2013	16:24	07/08/2013	18:00	1	96	96	Overhead equipment	Overhead Service	Repair	No Work Required	II
131894438	L71171	07/08/2013	16:26	07/08/2013	17:31	1	65	65	Animal related	Fuse	Repair		IV
131894458	K74166	07/08/2013	16:35	07/08/2013	17:44	1	69	69	Tree related-tree broken	Overhead Service	Repair	No Work Required	IV
131894505	N95823	07/08/2013	16:55	07/08/2013	20:22	9	1863	207	Overhead equipment	Overhead Transformer	Replace - Same Size	Replace - Same Size	V
131894528	342003	07/08/2013	16:56	07/08/2013	18:10	8	592	74	Tree related-tree broken	Tree	Cut in Clear		VI
131894539	M81402	07/08/2013	17:03	07/08/2013	18:03	79	4740	60	Overhead equipment	Fuse	Repair		V
131894656	L90359	07/08/2013	17:04	07/08/2013	18:50	53	5618	106	Animal related	Fuse	Replace - Same Size		V
131894561	J34357	07/08/2013	17:22	07/09/2013	0:34	1	432	432	Other	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	V
131894565	Q82906	07/08/2013	17:25	07/08/2013	23:15	8	2800	350	Overhead equipment	Overhead Transformer	Replace - Same Size	Replace - Same Size	VI
131894568	P47120	07/08/2013	17:30	07/08/2013	20:15	1	165	165	Overhead equipment	Overhead Transformer	Replace - Same Size		I
131894618	K74166	07/08/2013	17:56	07/08/2013	19:24	13	1144	88	Animal related	Transformer Fuse	Replace - Same Size	No Work Required	IV
131895398	R33126	07/08/2013	18:58	07/09/2013	5:20	21	13062	622	Overhead equipment	Pole	Replace - New Size	Replace - New Size	I
131895401	343008	07/08/2013	19:14	07/08/2013	20:35	8	648	81	Overhead equipment	Disconnect Switch	Repair		VI
131895395	M37191	07/08/2013	19:19	07/08/2013	20:30	1	71	71	Overhead equipment	Overhead Service	Repair	No Work Required	I
131895399	K80382	07/08/2013	19:21	07/08/2013	19:24	1	3	3	Underground equipment	Underground Transformer		Replace - Same Size	IV
131895417	R29904	07/08/2013	19:49	07/08/2013	21:00	1	71	71	Overhead equipment	Overhead Transformer	Replace - Same Size		VI
131895445	K95204	07/08/2013	20:41	07/08/2013	21:29	1	48	48	Tree related-tree contact	Overhead Service	Repair		III
131895451	Q34366	07/08/2013	21:02	07/09/2013	3:55	20	8260	413	Underground equipment	Fuse	Replace - Same Size	Repair	I
131895494	S78551	07/08/2013	21:46	07/08/2013	23:03	5	385	77	Animal related	Fuse			VI
131895505	S49550	07/08/2013	22:17	07/09/2013	5:53	1	456	456	Public	Overhead Transformer	Repair	Repair	VI
131900122	A85002	07/09/2013	0:13	07/09/2013	6:36	3	1149	383	Underground equipment	Underground Primary	Patrol/Test/Inspect	Replace - Urgent	I
131901958	S47584	07/09/2013	5:43	07/09/2013	6:30	35	1645	47	Tree related-tree broken	Fuse	Replace - Same Size	Replace - Same Size	VI
131901959	N58144	07/09/2013	5:46	07/09/2013	8:37	1	171	171	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	I
131902032	A85001	07/09/2013	7:09	07/09/2013	7:59	1	50	50	Animal related	Fuse	Replace - Same Size		I
131902048	S01501	07/09/2013	7:13	07/09/2013	8:40	1	87	87	Underground equipment	Underground Primary			VI
131902070	D31016	07/09/2013	7:22	07/09/2013	8:46	1	84	84	Overhead equipment	Other	Patrol/Test/Inspect	Patrol/Test/Inspect	III
131902135	K09864	07/09/2013	7:42	07/09/2013	9:10	101	8888	88	Animal related	Recloser		Repair	V
131902354	Q04411	07/09/2013	8:50	07/09/2013	10:00	40	2800	70	Underground equipment	Underground Primary	Repair		III
131902441	C30002	07/09/2013	9:07	07/09/2013	14:45	1	338	338	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	III
131902682	J15303	07/09/2013	9:14	07/09/2013	10:24	454	31780	70	Overhead equipment	Insulator	Replace - Same Size		I
131902077	N86226	07/09/2013	9:15	07/09/2013	13:30	2	510	255	Underground equipment	Underground Secondary	Patrol/Test/Inspect	Repair	VI
131902517	X75512	07/09/2013	9:21	07/09/2013	16:30	1	429	429	Underground equipment	Underground Service	Repair		IV
131902609	V92542	07/09/2013	9:41	07/09/2013	11:47	1	126	126	Public	Overhead Service	Tie/Tighten		II
131902640	V69532	07/09/2013	9:49	07/09/2013	10:44	1	55	55	Animal related	Fuse	Replace - Same Size		II
131902674	R93350	07/09/2013	9:56	07/09/2013	11:10	1	74	74	Overhead equipment	Fuse	Replace - Same Size		V
131902815	A36001	07/09/2013	10:22	07/09/2013	12:10	14	1512	108	Overhead equipment	Fuse	Repair		I

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
131902911	D35002	07/09/2013	10:45	07/09/2013	11:00	26	390	15	Overhead equipment	Overhead Primary	Repair		I
131903008	D66004	07/09/2013	11:08	07/09/2013	14:25	1	197	197	Underground equipment	Underground Service		Replace - Same Size	IV
131903020	B93002	07/09/2013	11:10	07/09/2013	13:00	1	110	110	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
131903065	B19002	07/09/2013	11:20	07/09/2013	17:30	1	370	370	Overhead equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
131903273	Q11516	07/09/2013	12:08	07/09/2013	13:54	1	106	106	Tree related-tree contact	Overhead Service		Repair	I
131903408	P12290	07/09/2013	12:10	07/09/2013	19:30	649	285560	440	Public	Overhead Primary		Repair	V
131903462	P12290	07/09/2013	12:28	07/09/2013	12:51	187	4301	23	Public	Pole			V
131903486	N67309	07/09/2013	12:58	07/09/2013	14:34	1	96	96	Animal related	Fuse	Replace - Same Size		I
131903557	Q27185	07/09/2013	13:15	07/09/2013	14:19	1	64	64	Animal related	Fuse	Replace - Same Size		VI
131903612		07/09/2013	13:31	07/09/2013	14:00	1	29	29	Animal related	Fuse	Replace - Same Size	Repair	VI
131904083	C36001	07/09/2013	13:41	07/09/2013	16:45	14	2576	184	Underground equipment	Underground Primary	Repair		III
131903660	C36001	07/09/2013	13:41	07/09/2013	14:48	27	1809	67	Underground equipment	Underground Primary	Switch/Reset		III
131903706	Y12560	07/09/2013	13:59	07/09/2013	14:35	1	36	36	Overhead equipment	Transformer Fuse	Replace - Same Size	No Work Required	IV
131903751	332003	07/09/2013	14:09	07/09/2013	16:41	1	152	152	Overhead equipment	Overhead Service	Patrol/Test/Inspect	Replace - Same Size	VI
131903819	T08501	07/09/2013	14:24	07/09/2013	15:07	59	2537	43	Overhead equipment	Fuse	Patrol/Test/Inspect	Repair	VI
131903861	K67924	07/09/2013	14:33	07/09/2013	15:39	1	66	66	Animal related	Transformer Fuse	Repair	No Work Required	VI
131903874	J71128	07/09/2013	14:36	07/09/2013	17:06	1	150	150	Overhead equipment	Overhead Service	Replace - Same Size		I
131903907	V23003	07/09/2013	14:44	07/09/2013	15:17	1	33	33	Overhead equipment	Connector	Repair		II
131903953	Q32171	07/09/2013	14:59	07/09/2013	16:30	1	91	91	Animal related	Transformer Fuse	Replace - Same Size	Replace - Same Size	I
131903985	J34356	07/09/2013	15:06	07/09/2013	16:27	1	81	81	Public	Overhead Secondary	Repair		V
131904046	337003	07/09/2013	15:19	07/09/2013	17:35	1	136	136	Overhead equipment	Tree	Trim		VI
131904054	N97887	07/09/2013	15:21	07/09/2013	17:10	1	109	109	Animal related	Disconnect Switch	Replace - Same Size		V
131904232	U84587	07/09/2013	15:31	07/09/2013	15:55	3	72	24	Overhead equipment	Pole	Switch/Reset	No Work Required	II
131904094	D96002	07/09/2013	15:32	07/09/2013	17:02	1	90	90	Public	Connector	Repair		I
131904137	P07179	07/09/2013	15:51	07/09/2013	18:21	1	150	150	Overhead equipment	Overhead Transformer			I
131904150	V44504	07/09/2013	15:55	07/09/2013	16:26	1	31	31	Overhead equipment	Jumper	Repair		II
131904198	Y13043	07/09/2013	16:07	07/09/2013	16:44	39	1443	37	Overhead equipment	Fuse	Replace - Same Size	No Work Required	IV
131904222		07/09/2013	16:22	07/10/2013	3:30	1	668	668	Public	Underground Service	Patrol/Test/Inspect	Repair	I
131904240	A27011	07/09/2013	16:27	07/09/2013	20:48	153	39933	261	Underground equipment	Overhead Primary	Patrol/Test/Inspect	Patrol/Test/Inspect	I
131904261	A27011	07/09/2013	16:35	07/09/2013	19:15	1	160	160	Animal related	Tree		Patrol/Test/Inspect	I
131904974	Y06573	07/09/2013	16:59	07/10/2013	0:30	5	2255	451	Underground equipment	Underground Primary	Repair	Repair	IV
131904370	Q06131	07/09/2013	17:42	07/09/2013	19:03	1	81	81	Tree related-tree broken	Overhead Service	Repair	No Work Required	IV
131904371	342004	07/09/2013	17:42	07/09/2013	19:00	1	78	78	Overhead equipment	Overhead Service	Repair		VI
131904403	P07179	07/09/2013	17:50	07/09/2013	21:00	9	1710	190	Overhead equipment	Overhead Primary	Patrol/Test/Inspect	Repair	I
131904393	L24122	07/09/2013	17:51	07/09/2013	20:20	1	149	149	Overhead equipment	Overhead Transformer		Replace - Same Size	III
131904445	N48101	07/09/2013	17:58	07/09/2013	19:19	1	81	81	Overhead equipment	Overhead Service	Repair	No Work Required	II
131904967	V99562	07/09/2013	18:27	07/09/2013	19:40	13	949	73	Overhead equipment	Fuse	Replace - Same Size		II
131904833	D69006	07/09/2013	18:28	07/09/2013	23:09	1	281	281	Underground equipment	Underground Primary		Repair	I
131904920	C00002	07/09/2013	18:33	07/09/2013	22:20	1	227	227	Overhead equipment				I
131904929	B10001	07/09/2013	18:40	07/10/2013	5:40	1	660	660	Underground equipment	Overhead Service	Patrol/Test/Inspect	Repair	I
131904931	J99141	07/09/2013	18:41	07/09/2013	19:28	1	47	47	Jurisdictional				VI
131904971	IP9009	07/09/2013	19:22	07/09/2013	22:00	1	158	158	Overhead equipment	Other			VI
131904972	R73838	07/09/2013	19:24	07/09/2013	20:19	1	55	55	Tree related-tree contact	Overhead Service	Repair	No Work Required	V
131904991	P62112	07/09/2013	19:42	07/09/2013	20:36	1	54	54	Tree related-tree broken	Overhead Service	Replace - Same Size		VI
131905042	S60581	07/09/2013	20:50	07/09/2013	23:25	70	10850	155	Tree related-tree contact	Tree	Patrol/Test/Inspect	Repair	VI
131905043	Q32170	07/09/2013	21:13	07/09/2013	22:10	1	57	57	Animal related	Transformer Fuse	Replace - Same Size	Replace - Same Size	I
131905046	X96543	07/09/2013	21:23	07/10/2013	2:36	1	313	313	Underground equipment	Underground Primary	Repair	Repair	IV
131905047	K79223	07/09/2013	21:27	07/09/2013	22:15	1	48	48	Tree related-tree broken	Overhead Service	Repair	No Work Required	IV
131905072	Y60593	07/09/2013	22:36	07/09/2013	23:48	4	288	72	Public	Transformer Fuse	Replace - Same Size	Repair	IV
131910103	V18582	07/10/2013	0:05	07/10/2013	1:08	1	63	63	Animal related	Transformer Fuse	Replace - Same Size		II
131910104	Q21321	07/10/2013	0:11	07/10/2013	5:08	1	297	297	Underground equipment	Underground Service		Replace - Same Size	VI
131910110	R20501	07/10/2013	0:34	07/10/2013	2:08	1	94	94	Overhead equipment	Connector	Repair	No Work Required	IV
131910131	D72002	07/10/2013	1:45	07/10/2013	3:47	20	2440	122	Overhead equipment	Overhead Transformer		Repair	I
131912078	R08910	07/10/2013	3:08	07/10/2013	13:29	1	621	621	Underground equipment	Underground Primary	Repair	Repair	VI
131911553	R08910	07/10/2013	3:08	07/10/2013	7:21	1	253	253	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	VI
131911493	Q83171	07/10/2013	3:19	07/10/2013	6:05	26	4316	166	Underground equipment	Underground Primary	Repair	Repair	VI

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
131911580	R84148	07/10/2013	4:34	07/10/2013	6:51	1	137	137	Overhead equipment	Fuse	Patrol/Test/Inspect	Replace - Same Size	I
131911603	351001	07/10/2013	5:16	07/10/2013	9:55	1	279	279	Weather	Overhead Primary	Patrol/Test/Inspect	Repair	VI
131911622	P82291	07/10/2013	5:23	07/10/2013	7:04	11	1111	101	Weather	Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
131911674	Q06132	07/10/2013	5:48	07/10/2013	7:13	33	2805	85	Animal related	Fuse	Replace - Same Size		IV
131911694	B93002	07/10/2013	6:00	07/10/2013	6:57	1	57	57	Tree related-tree broken	Fuse	Replace - Same Size		I
131911742	P12290	07/10/2013	6:08	07/10/2013	8:51	1	163	163	Underground equipment	Underground Transformer	Replace - Same Size	Replace - Same Size	V
131911810	M40131	07/10/2013	6:23	07/10/2013	8:40	1	137	137	Overhead equipment	Overhead Service	No Work Required		I
131911848	D16002	07/10/2013	6:44	07/10/2013	10:30	6	1356	226	Overhead equipment	Overhead Primary	Repair	Repair	I
131911866	D16002	07/10/2013	6:51	07/10/2013	10:37	1	226	226	Overhead equipment	Overhead Primary	Repair	No Work Required	I
131911870	M25143	07/10/2013	6:53	07/10/2013	8:55	1	122	122	Weather	Transformer Fuse	Replace - Same Size	No Work Required	IV
131911878	M04365	07/10/2013	6:55	07/10/2013	7:35	1	40	40	Overhead equipment	Fuse	Replace - Same Size		V
131911889	L99392	07/10/2013	6:58	07/10/2013	9:11	8	1064	133	Weather	Fuse	Replace - Same Size	Replace - Same Size	V
131913574	M22812	07/10/2013	7:04	07/10/2013	13:23	10	3790	379	Tree related-tree broken	Overhead Primary	Repair		V
131912773	M22812	07/10/2013	7:04	07/10/2013	11:36	62	16864	272	Tree related-tree broken	Overhead Primary	Patrol/Test/Inspect		V
131911910	P25150	07/10/2013	7:07	07/10/2013	9:06	1	119	119	Overhead equipment	Overhead Service	Replace - Same Size	No Work Required	III
131913013	M22812	07/10/2013	7:15	07/10/2013	11:00	4	900	225	Weather	Fuse	Replace - Same Size	No Work Required	V
131911979	N18211	07/10/2013	7:17	07/10/2013	9:32	1	135	135	Unknown	Transformer Fuse	Replace - Same Size		III
131912041	P54827	07/10/2013	7:33	07/10/2013	8:52	1	79	79	Overhead equipment	Disconnect Switch	Replace - Same Size		V
131912047	R04415	07/10/2013	7:34	07/10/2013	9:26	68	7616	112	Weather	Fuse	Patrol/Test/Inspect	Replace - Same Size	V
131912072	M47816	07/10/2013	7:43	07/10/2013	8:50	1	67	67	Tree related-tree contact	Overhead Service			V
131912096	K30204	07/10/2013	7:48	07/10/2013	9:00	1	72	72	Unknown	Transformer Fuse	Replace - Same Size		III
131912526	R04415	07/10/2013	7:54	07/10/2013	9:24	7	630	90	Weather	Fuse	Repair		V
131912203	B68003	07/10/2013	8:05	07/10/2013	9:20	18	1350	75	Overhead equipment	Fuse	Replace - Same Size		III
131912204	Q16867	07/10/2013	8:06	07/10/2013	10:17	16	2096	131	Tree related-tree broken	Overhead Primary	Patrol/Test/Inspect	Repair	V
131912181	D16002	07/10/2013	8:11	07/10/2013	10:34	1	143	143	Overhead equipment	Overhead Primary	Repair	No Work Required	I
131912189	N50331	07/10/2013	8:13	07/10/2013	9:38	1	85	85	Tree related-tree contact	Overhead Service	Cut in Clear	Reconnect	II
131912188	R04415	07/10/2013	8:13	07/10/2013	9:00	1	47	47	Weather			Replace - Same Size	V
131912199	Q16867	07/10/2013	8:14	07/10/2013	10:00	5	530	106	Weather	Tree	Remove		V
131912197	N95822	07/10/2013	8:14	07/10/2013	10:56	1	162	162	Tree related-tree broken	Tree	Trim		V
131912662	Y84552	07/10/2013	8:16	07/10/2013	13:00	101	28684	284	Weather	Overhead Primary	Repair	Repair	IV
131912220	N15849	07/10/2013	8:17	07/10/2013	9:41	57	4788	84	Weather	Insulator	Replace - Same Size	No Work Required	V
131913095	X75512	07/10/2013	8:26	07/10/2013	11:24	545	97010	178	Weather	Crossarm	Replace - Same Size	Repair	IV
131912262	Q47833	07/10/2013	8:27	07/10/2013	9:13	1	46	46	Weather	Fuse	Repair	Repair	V
131912645	V03734	07/10/2013	8:29	07/10/2013	9:48	1	79	79	Tree related-tree contact	Tree			II
131912322	V03734	07/10/2013	8:29	07/10/2013	9:28	935	55165	59	Tree related-tree contact				II
131912285	C10001	07/10/2013	8:32	07/10/2013	11:40	1	188	188	Overhead equipment	Fuse	Replace - Same Size	Repair	III
131912289	D90002	07/10/2013	8:33	07/10/2013	10:00	1	87	87	Weather	Other	Patrol/Test/Inspect	Patrol/Test/Inspect	III
131912566	E10002	07/10/2013	8:35	07/10/2013	10:07	138	12696	92	Weather	Lightning Arrestor	Cut in Clear		III
131912341	P71830	07/10/2013	8:41	07/10/2013	10:16	1	95	95	Weather	Transformer Fuse	Replace - Same Size	No Work Required	V
131912522	M09143	07/10/2013	8:53	07/10/2013	9:10	880	14960	17	Overhead equipment	Overhead Primary			VI
131912426	E10002	07/10/2013	8:56	07/10/2013	10:14	1	78	78	Overhead equipment	Other		No Work Required	III
131912521	L23146	07/10/2013	9:11	07/10/2013	12:04	84	14532	173	Tree related-tree contact	Overhead Primary	Repair	Repair	III
131912532	L99392	07/10/2013	9:13	07/10/2013	10:03	1	50	50	Weather	Fuse	Replace - Same Size	Replace - Same Size	V
131912541	M26164	07/10/2013	9:15	07/10/2013	10:14	1	59	59	Weather	Fuse			III
131912550	M18131	07/10/2013	9:18	07/10/2013	10:09	1	51	51	Tree related-tree contact	Recloser	Replace - Same Size		III
131912619	M18131	07/10/2013	9:19	07/10/2013	10:09	136	6800	50	Tree related-tree contact	Recloser	Replace - Same Size		III
131912607	B68003	07/10/2013	9:28	07/10/2013	11:59	2	302	151	Underground equipment	Underground Primary			III
131913174	D66001	07/10/2013	9:32	07/10/2013	13:05	23	4899	213	Tree related-tree broken	Tree			IV
131913700	C52001	07/10/2013	9:35	07/10/2013	14:00	33	8745	265	Overhead equipment	Overhead Primary	Repair		III
131913599	C52001	07/10/2013	9:35	07/10/2013	11:56	349	49209	141	Tree related-tree broken	Overhead Primary	Repair		III
131912863	C52001	07/10/2013	9:35	07/10/2013	11:23	181	19548	108	Tree related-tree broken	Tree	Remove		III
131914232	R66470	07/10/2013	9:36	07/10/2013	14:46	148	45880	310	Overhead equipment	Overhead Primary			IV
131915007	C52002	07/10/2013	9:41	07/10/2013	17:29	19	8892	468	Tree related-tree broken	Overhead Primary			III
131912734	C52002	07/10/2013	9:41	07/10/2013	13:01	82	16400	200	Tree related-tree broken	Overhead Primary			III
131913520	C52002	07/10/2013	9:42	07/10/2013	11:58	69	9384	136	Tree related-tree broken	Overhead Primary	Patrol/Test/Inspect	Repair	III
131913109	M26161	07/10/2013	9:43	07/10/2013	10:50	41	2747	67	Unknown	Recloser	Patrol/Test/Inspect		III

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
131912707	K28183	07/10/2013	9:44	07/10/2013	11:14	3	270	90	Weather	Overhead Primary	Repair		III
131912718	D93001	07/10/2013	9:45	07/10/2013	13:00	1	195	195	Unknown	Transformer Fuse	Replace - Same Size		IV
131912720	M26164	07/10/2013	9:46	07/10/2013	10:49	1	63	63	Weather	Fuse			III
131912716	L70127	07/10/2013	9:46	07/10/2013	13:49	1	243	243	Overhead equipment	Overhead Transformer	Replace - Same Size		IV
131912742	P07179	07/10/2013	9:48	07/10/2013	13:10	1	202	202	Overhead equipment	Fuse	Patrol/Test/Inspect	Replace - Same Size	I
131912749	C36002	07/10/2013	9:49	07/10/2013	11:26	25	2425	97	Overhead equipment	Fuse	Repair	Replace - Same Size	III
131912758	P25150	07/10/2013	9:51	07/10/2013	12:21	1	150	150	Tree related-tree contact	Overhead Service	Replace - New Size		III
131912784	N90247	07/10/2013	9:52	07/10/2013	11:51	1	119	119	Overhead equipment	Fuse			III
131912886	L23145	07/10/2013	9:55	07/10/2013	13:12	3	591	197	Tree related-tree contact	Fuse			III
131912835	R20501	07/10/2013	9:58	07/10/2013	23:10	1	792	792	Weather	Underground Primary	Patrol/Test/Inspect	Replace - Same Size	IV
131912859	P62112	07/10/2013	10:00	07/10/2013	10:16	1	16	16	Tree related-tree broken	Overhead Service	Cut in Clear	Cut in Clear	VI
131913907	K74166	07/10/2013	10:04	07/10/2013	13:07	1163	212829	183	Weather	Overhead Primary		Repair	IV
131913673	R53416	07/10/2013	10:07	07/10/2013	11:46	5	495	99	Weather	Fuse	Patrol/Test/Inspect	Replace - Same Size	V
131912918	K79213	07/10/2013	10:07	07/10/2013	11:40	23	2139	93	Tree related-tree contact	Overhead Primary	Patrol/Test/Inspect	Repair	IV
131912912	C52002	07/10/2013	10:09	07/10/2013	11:59	1	110	110	Overhead equipment	Fuse	Replace - Same Size		III
131913022	M45212	07/10/2013	10:10	07/10/2013	16:15	70	25550	365	Tree related-tree broken	Overhead Primary			IV
131912942	K71812	07/10/2013	10:12	07/10/2013	14:12	45	10800	240	Tree related-tree broken	Overhead Primary	Patrol/Test/Inspect	Repair	IV
131912938		07/10/2013	10:13	07/10/2013	11:19	1	66	66	Overhead equipment	Overhead Primary	Cut in Clear		I
131912940	L99392	07/10/2013	10:13	07/10/2013	10:58	1	45	45	Weather	Fuse	Replace - Same Size	Replace - Same Size	V
131912961	V42572	07/10/2013	10:16	07/10/2013	10:35	7	133	19	Tree related-tree broken	Transformer Fuse	Replace - Same Size		II
131915044	M45212	07/10/2013	10:20	07/10/2013	19:00	9	4680	520	Weather	Overhead Transformer			IV
131913021	Q74148	07/10/2013	10:21	07/10/2013	14:25	13	3172	244	Tree related-tree broken	Overhead Primary	Repair		IV
131913046	C00002	07/10/2013	10:22	07/10/2013	11:19	20	1140	57	Overhead equipment	Fuse	Repair		I
131913107	R61241	07/10/2013	10:24	07/10/2013	12:10	142	15052	106	Weather	Fuse		Replace - Same Size	IV
131913149	R66470	07/10/2013	10:24	07/10/2013	14:25	956	230396	241	Overhead equipment				IV
131913036	L23145	07/10/2013	10:25	07/10/2013	13:14	1	169	169	Tree related-tree contact	Fuse			III
131913186	L81141	07/10/2013	10:29	07/10/2013	13:39	40	7600	190	Tree related-tree broken	Overhead Primary			IV
131913517	M25144	07/10/2013	10:29	07/10/2013	16:50	16	6096	381	Overhead equipment	Pole			IV
131913075	L99392	07/10/2013	10:30	07/10/2013	12:08	1	98	98	Weather	Fuse	Replace - Same Size	Replace - Same Size	V
131913074	M05361	07/10/2013	10:30	07/10/2013	10:58	1	28	28	Animal related	Fuse	Replace - Same Size		V
131914217	D66004	07/10/2013	10:30	07/10/2013	16:47	333	125541	377	Tree related-tree broken	Overhead Primary			IV
131913097	R61241	07/10/2013	10:32	07/10/2013	18:09	1	457	457	Overhead equipment	Overhead Service			IV
131913175	F22001	07/10/2013	10:32	07/10/2013	11:55	111	9213	83	Tree related-tree broken	Fuse	Replace - Same Size		IV
131913108	M30301	07/10/2013	10:33	07/10/2013	11:20	1	47	47	Tree related-tree contact	Fuse			VI
131913167	M53312	07/10/2013	10:36	07/10/2013	12:23	40	4280	107	Public	Overhead Primary	Cut in Clear	Repair	V
131914401	L74191	07/10/2013	10:40	07/10/2013	13:58	33	6534	198	Tree related-tree broken	Overhead Primary			IV
131913183	L81141	07/10/2013	10:41	07/10/2013	16:24	1	343	343	Overhead equipment				IV
131913197	R20502	07/10/2013	10:42	07/10/2013	16:00	1	318	318	Overhead equipment	Fuse	Patrol/Test/Inspect	Replace - Same Size	IV
131913269	L74191	07/10/2013	10:43	07/10/2013	13:00	287	39319	137	Tree related-tree broken	Overhead Primary			IV
131913228	H06135	07/10/2013	10:46	07/10/2013	23:40	4	3096	774	Tree related-tree contact	Overhead Transformer	Repair		IV
131913245	R20502	07/10/2013	10:47	07/10/2013	16:26	1	339	339	Weather	Underground Primary	Patrol/Test/Inspect	Repair	IV
131913398	X31730	07/10/2013	10:47	07/10/2013	11:39	5740	298480	52	Tree related-tree broken				IV
131913241	V10545	07/10/2013	10:48	07/10/2013	12:00	1	72	72	Overhead equipment	Connector	Repair		II
131913246	K79212	07/10/2013	10:48	07/10/2013	14:35	9	2043	227	Weather	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	IV
131913518	H06135	07/10/2013	10:48	07/10/2013	13:30	228	36936	162	Tree related-tree broken	Overhead Primary			IV
131914726	R48167	07/10/2013	10:49	07/10/2013	15:30	31	8711	281	Tree related-tree broken	Overhead Primary			IV
131913271	P71830	07/10/2013	10:52	07/10/2013	11:40	1	48	48	Weather	Transformer Fuse	Replace - Same Size	No Work Required	V
131913322	H06135	07/10/2013	10:53	07/10/2013	17:58	82	34850	425	Tree related-tree broken	Overhead Primary			IV
131913405	M09143	07/10/2013	10:54	07/10/2013	12:34	6	600	100	Overhead equipment	Overhead Primary	Replace - Same Size	Repair	VI
131913431	R60551	07/10/2013	11:04	07/10/2013	18:10	1	426	426	Tree related-tree broken	Overhead Service		Raise	IV
131913440	Y07575	07/10/2013	11:05	07/10/2013	11:50	8	360	45	Overhead equipment	Overhead Service	Repair	Repair	IV
131913436	D93002	07/10/2013	11:05	07/10/2013	11:41	31	1116	36	Tree related-tree broken	Tree	Cut in Clear	Remove	IV
131913495	H10843	07/10/2013	11:08	07/10/2013	14:23	55	10725	195	Weather	Fuse	Replace - Same Size		V
131916020	M45212	07/10/2013	11:11	07/10/2013	20:55	27	15768	584	Unknown	Pole	Replace - New Size	Replace - New Size	IV
131915387	M45212	07/10/2013	11:11	07/10/2013	17:00	119	41531	349	Overhead equipment	Pole			IV
131913065	C52002	07/10/2013	11:12	07/10/2013	16:07	69	20355	295	Tree related-tree broken	Overhead Primary	Patrol/Test/Inspect	Repair	III

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
131913534	341003	07/10/2013	11:16	07/10/2013	15:20	1	244	244	Tree related-tree broken	Overhead Secondary	Patrol/Test/Inspect	Repair	VI
131913575	R60552	07/10/2013	11:23	07/10/2013	17:10	1	347	347	Weather	Overhead Service			IV
131913653	R60552	07/10/2013	11:37	07/10/2013	13:25	1	108	108	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	IV
131913685	L70127	07/10/2013	11:44	07/10/2013	14:36	1	172	172	Overhead equipment	Overhead Transformer			IV
131913787	P18102	07/10/2013	11:47	07/10/2013	12:47	30	1800	60	Weather	Fuse	Patrol/Test/Inspect	Replace - Same Size	IV
131913821	A73002	07/10/2013	11:50	07/10/2013	15:00	13	2470	190	Underground equipment	Fuse		Repair	I
131913757	310123	07/10/2013	11:52	07/10/2013	14:05	1	133	133	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	V
131913760	L12126	07/10/2013	11:53	07/10/2013	12:49	1	56	56	Animal related	Fuse	Replace - Same Size		III
131913780	K80386	07/10/2013	12:00	07/10/2013	16:11	1	251	251	Tree related-tree broken	Overhead Service		Replace - New Size	IV
131913803	D96001	07/10/2013	12:02	07/10/2013	14:00	1	118	118	Animal related	Disconnect Switch	Replace - Same Size	No Work Required	I
131913819	Q47833	07/10/2013	12:04	07/10/2013	12:50	1	46	46	Weather	Fuse	Repair	Repair	V
131914741	R66470	07/10/2013	12:26	07/10/2013	15:00	584	89936	154	Overhead equipment	Overhead Primary	Repair		IV
131913999	L70127	07/10/2013	12:35	07/10/2013	16:12	1	217	217	Overhead equipment	Overhead Secondary	Repair		IV
131914011		07/10/2013	12:38	07/10/2013	13:51	1	73	73	Weather	Overhead Primary	Repair		IV
131914030	Q06131	07/10/2013	12:42	07/10/2013	13:06	1	24	24	Weather				IV
131914091	D88002	07/10/2013	12:53	07/10/2013	14:30	1	97	97	Overhead equipment	Other	No Work Required	Repair	I
131914125	L23145	07/10/2013	12:54	07/10/2013	14:20	37	3182	86	Tree related-tree broken	Fuse	Replace - Same Size		III
131914183	T41556	07/10/2013	13:10	07/10/2013	14:24	1	74	74	Weather	Fuse	Repair		IV
131914264	K95202	07/10/2013	13:24	07/10/2013	14:20	1	56	56	Tree related-tree contact	Overhead Service	Repair		III
131914277	D39001	07/10/2013	13:26	07/10/2013	21:37	1	491	491	Underground equipment	Underground Transformer	Patrol/Test/Inspect	Patrol/Test/Inspect	I
131914286	Z51551	07/10/2013	13:28	07/10/2013	15:26	1	118	118	Tree related-tree broken	Overhead Primary			IV
131914287	307004	07/10/2013	13:28	07/10/2013	14:28	1	60	60	Public	Overhead Service	Repair		VI
131914295	L00134	07/10/2013	13:29	07/10/2013	14:37	51	3468	68	Overhead equipment	Fuse			III
131914316	X30506	07/10/2013	13:35	07/10/2013	14:00	1	25	25	Weather	Transformer Fuse	Replace - New Size		IV
131914333	M45211	07/10/2013	13:37	07/10/2013	16:13	16	2496	156	Weather	Transformer Fuse	Replace - Same Size		IV
131914368	M45211	07/10/2013	13:48	07/10/2013	17:19	1	211	211	Overhead equipment	Fuse	Repair		IV
131914384	U62521	07/10/2013	13:50	07/10/2013	15:05	1	75	75	Animal related	Transformer Fuse	Repair		II
131915391	D66004	07/10/2013	13:55	07/10/2013	20:30	58	22910	395	Tree related-tree broken	Overhead Primary		Repair	IV
131916044	M25144	07/10/2013	14:01	07/10/2013	21:00	4	1676	419	Overhead equipment	Overhead Primary	Repair	Repair	IV
131914429	L14232	07/10/2013	14:02	07/10/2013	17:50	1	228	228	Tree related-tree contact	Tree	Remove	Repair	III
131914517	R48166	07/10/2013	14:17	07/10/2013	17:02	1	165	165	Tree related-tree contact	Transformer Fuse	Replace - Same Size		IV
131914972	M45212	07/10/2013	14:19	07/10/2013	18:10	1	231	231	Overhead equipment	Overhead Transformer		Replace - Same Size	IV
131914595	A97002	07/10/2013	14:34	07/10/2013	15:56	1	82	82	Tree related-tree broken	Overhead Service	Repair	Replace - Same Size	I
131914707		07/10/2013	14:40	07/10/2013	15:21	1828	74948	41	Animal related				III
131915064	R73839	07/10/2013	14:48	07/10/2013	19:14	3	798	266	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	V
131914753	X99538	07/10/2013	14:53	07/10/2013	19:26	1	273	273	Underground equipment	Underground Primary	Replace - Same Size	Replace - Same Size	IV
131914856	M25144	07/10/2013	15:15	07/10/2013	15:57	1	42	42	Tree related-tree broken	Overhead Service			IV
131915009	Z08509	07/10/2013	15:47	07/10/2013	16:41	1	54	54	Overhead equipment	Transformer Fuse	Repair	Replace - Same Size	IV
131915038	Y04504	07/10/2013	15:54	07/10/2013	21:45	1	351	351	Weather	Lightning Arrestor	Replace - Same Size		IV
131915092	L73160	07/10/2013	16:12	07/10/2013	18:29	1	137	137	Tree related-tree broken	Overhead Service	Repair	Repair	IV
131915101	Z05548	07/10/2013	16:13	07/10/2013	19:30	1	197	197	Tree related-tree broken	Overhead Service	Repair	Patrol/Test/Inspect	IV
131915239	61072	07/10/2013	16:14	07/10/2013	20:40	1	266	266	Underground equipment	Underground Primary	Replace - Same Size		VI
131915362	C37001	07/10/2013	16:16	07/10/2013	17:28	11	792	72	Overhead equipment	Overhead Primary	Patrol/Test/Inspect	Repair	III
131915148	R20501	07/10/2013	16:29	07/10/2013	17:26	1	57	57	Weather	Transformer Fuse	Replace - Same Size	No Work Required	IV
131916114	M45212	07/10/2013	16:34	07/10/2013	23:06	2	784	392	Unknown				IV
131915172	M22812	07/10/2013	16:35	07/10/2013	18:05	1	90	90	Animal related	Transformer Fuse	Replace - Same Size	No Work Required	V
131915189	L74191	07/10/2013	16:39	07/10/2013	17:27	1	48	48	Overhead equipment	Fuse			IV
131915203	L16213	07/10/2013	16:43	07/10/2013	18:36	1	113	113	Tree related-tree contact	Tree	Trim		III
131915207	D66004	07/10/2013	16:46	07/10/2013	19:21	63	9765	155	Tree related-tree broken	Overhead Primary	Replace - Same Size		IV
131915251	M25144	07/10/2013	16:57	07/10/2013	21:48	1	291	291	Tree related-tree broken	Tree			IV
131915269	D66004	07/10/2013	17:00	07/10/2013	18:30	1	90	90	Weather	Underground Primary	Replace - Same Size		IV
131915328	J39391	07/10/2013	17:00	07/10/2013	17:56	35	1960	56	Overhead equipment	Fuse			III
131914069	M45212	07/10/2013	17:02	07/10/2013	23:00	2	716	358	Tree related-tree broken	Overhead Service	Raise		IV
131915303	J39391	07/10/2013	17:03	07/10/2013	18:00	2	114	57	Overhead equipment	Fuse			III
131915342	X83533	07/10/2013	17:11	07/10/2013	18:35	1	84	84	Tree related-tree contact	Overhead Service	Repair		IV
131915359	L08225	07/10/2013	17:20	07/10/2013	18:37	1	77	77	Tree related-tree contact	Overhead Service	Repair		III

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
131915415	N58144	07/10/2013	17:50	07/10/2013	20:26	1	156	156	Overhead equipment	Fuse	Patrol/Test/Inspect		I
131915422	U73599	07/10/2013	17:53	07/10/2013	17:59	1	6	6	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	II
131915469	Q16867	07/10/2013	18:13	07/10/2013	21:30	1	197	197	Weather	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	V
131920114	M45212	07/10/2013	18:16	07/11/2013	2:40	4	2016	504	Overhead equipment	Pole	Replace - Same Size		IV
131915486	M45212	07/10/2013	18:25	07/10/2013	19:15	1	50	50	Overhead equipment	Fuse	Repair		IV
131916016	U60518	07/10/2013	18:30	07/10/2013	21:00	25	3750	150	Tree related-tree broken	Tree	Cut in Clear	No Work Required	II
131915496	K79212	07/10/2013	18:31	07/10/2013	20:52	1	141	141	Tree related-tree broken	Overhead Service	Patrol/Test/Inspect	Repair	IV
131915500	L93132	07/10/2013	18:34	07/10/2013	22:25	5	1155	231	Overhead equipment	Overhead Transformer	Disconnect	Replace - Same Size	VI
131915915	D72001	07/10/2013	18:46	07/10/2013	19:42	1	56	56	Overhead equipment	Connector	Replace - Same Size		I
131916028	R48167	07/10/2013	20:15	07/10/2013	21:44	1	89	89	Tree related-tree broken	Overhead Service			IV
131916031	L42158	07/10/2013	20:54	07/10/2013	22:50	2	232	116	Tree related-tree contact	Overhead Secondary	Repair		III
131916057	L81141	07/10/2013	21:03	07/10/2013	22:56	1	113	113	Overhead equipment	Jumper	Repair	No Work Required	IV
131916097	307001	07/10/2013	21:30	07/10/2013	23:20	203	22330	110	Overhead equipment	Fuse	Replace - Same Size		VI
131916076	L24122	07/10/2013	21:48	07/10/2013	23:08	1	80	80	Unknown	Fuse	Replace - Same Size		III
131916080	M25144	07/10/2013	22:00	07/10/2013	23:35	1	95	95	Overhead equipment				IV
131920139	D93001	07/10/2013	23:01	07/11/2013	4:10	16	4944	309	Overhead equipment				IV
131920140	R20501	07/10/2013	23:20	07/11/2013	5:07	2	694	347	Underground equipment	Underground Primary		Repair	IV
131920361	M45212	07/11/2013	0:57	07/11/2013	3:50	40	6920	173	Overhead equipment	Ground Wire	Repair		IV
131920148	K19115	07/11/2013	1:46	07/11/2013	5:13	1	207	207	Overhead equipment	Overhead Transformer	Repair	Repair	VI
131920360	N42856	07/11/2013	2:37	07/11/2013	3:30	1	53	53	Animal related	Transformer Fuse	Replace - Same Size	No Work Required	V
131923521	V18582	07/11/2013	5:19	07/11/2013	9:30	37	9287	251	Underground equipment	Underground Primary		Repair	II
131924964	X72535	07/11/2013	5:20	07/11/2013	13:30	6	2940	490	Underground equipment	Underground Primary	Switch/Reset	Repair	IV
131923544	X23516	07/11/2013	6:07	07/11/2013	7:40	1	93	93	Tree related-tree broken	Overhead Service	Repair		IV
131923586	P07179	07/11/2013	6:58	07/11/2013	8:05	1	67	67	Animal related	Fuse	Patrol/Test/Inspect	Replace - Same Size	I
131923669	V74506	07/11/2013	7:27	07/11/2013	8:20	1	53	53	Animal related	Underground Service	Repair	Repair	II
131923681	U84534	07/11/2013	7:32	07/11/2013	8:39	1	67	67	Animal related	Transformer Fuse	Replace - Same Size	No Work Required	II
131923691	J18268	07/11/2013	7:34	07/11/2013	8:16	1	42	42	Animal related	Transformer Fuse	Replace - Same Size	Patrol/Test/Inspect	VI
131923711	R60552	07/11/2013	7:40	07/11/2013	12:51	1	311	311	Public	Pole	Patrol/Test/Inspect	Repair	IV
131923786	L17101	07/11/2013	8:08	07/11/2013	10:03	1	115	115	Animal related	Underground Primary		Repair	III
131923808	A45002	07/11/2013	8:18	07/11/2013	8:49	11	341	31	Overhead equipment	Fuse			I
131924055	K57211	07/11/2013	8:44	07/11/2013	8:58	662	9268	14	Substation equipment	Substation Misc.			VI
131924064	Z10501	07/11/2013	9:05	07/11/2013	9:25	1	20	20	Animal related	Fuse	Replace - Same Size		IV
131924075	CW1016	07/11/2013	9:07	07/11/2013	9:27	1	20	20	Animal related	Fuse	Replace - Same Size		III
131924261	S47537	07/11/2013	9:29	07/11/2013	10:13	1	44	44	Overhead equipment	Fuse	Replace - Same Size		VI
131924360	N67309	07/11/2013	9:44	07/11/2013	10:14	1	30	30	Overhead equipment	Transformer Fuse	Replace - New Size		I
131924364	K89143	07/11/2013	9:46	07/11/2013	10:31	1	45	45	Animal related	Fuse	Replace - Same Size		III
131924409	P82290	07/11/2013	9:53	07/11/2013	10:35	1	42	42	Public	Fuse	Replace - Same Size		VI
131924413	J83138	07/11/2013	9:54	07/11/2013	10:40	1	46	46	Animal related	Fuse			VI
131924455	L16213	07/11/2013	10:04	07/11/2013	11:54	1	110	110	Overhead equipment	Overhead Transformer	Replace - Same Size	No Work Required	III
131924611	C52001	07/11/2013	10:31	07/11/2013	11:03	1	32	32	Overhead equipment	Overhead Secondary	Cut in Clear	Repair	III
131924939	U60559	07/11/2013	10:32	07/11/2013	13:23	12	2052	171	Public	Underground Primary			II
131924665	K28183	07/11/2013	10:42	07/11/2013	11:30	1	48	48	Animal related	Fuse	Replace - Same Size		III
131924702	D39002	07/11/2013	10:50	07/11/2013	11:24	1	34	34	Overhead equipment	Transformer Fuse	Replace - Same Size		I
131924726	H06135	07/11/2013	10:52	07/11/2013	13:35	7	1141	163	Overhead equipment	Connector	Repair		IV
131924737	V99562	07/11/2013	10:53	07/11/2013	14:00	1	187	187	Overhead equipment	Overhead Transformer	Replace - Same Size	Replace - Same Size	II
131924786	J87111	07/11/2013	11:01	07/11/2013	11:40	1	39	39	Overhead equipment	Fuse	Replace - Same Size		VI
131925473	L79157	07/11/2013	11:21	07/11/2013	13:34	104	13832	133	Animal related	Fuse	Replace - Same Size		IV
131924908	P73182	07/11/2013	11:25	07/11/2013	13:04	1	99	99	Overhead equipment	Fuse	Replace - Same Size		VI
131924944	Q67938	07/11/2013	11:28	07/11/2013	12:05	3	111	37	Overhead equipment	Fuse	Replace - Same Size		VI
131924993	C10002	07/11/2013	11:38	07/11/2013	12:30	1	52	52	Overhead equipment	Overhead Service	Repair		III
131925008	P57108	07/11/2013	11:41	07/11/2013	12:49	1	68	68	Overhead equipment	Transformer Fuse	Repair		VI
131925504	K89143	07/11/2013	13:33	07/11/2013	14:44	1	71	71	Tree related-tree contact	Overhead Service	Repair		III
131925508	Y37593	07/11/2013	13:33	07/11/2013	14:24	19	969	51	Underground equipment	Underground Primary	Replace - Same Size	Repair	IV
131925830	Y39515	07/11/2013	14:52	07/11/2013	16:06	1	74	74	Overhead equipment	Overhead Service	Repair		IV
131925864	A50002	07/11/2013	15:00	07/11/2013	16:30	1	90	90	Animal related	Fuse	Replace - Same Size	No Work Required	I
131925831	E10003	07/11/2013	15:03	07/11/2013	16:32	24	2136	89	Tree related-tree broken	Tree	Remove		III

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
131925969	339161	07/11/2013	15:30	07/11/2013	15:54	1	24	24	Other	Meter	Reconnect		V
131925970	342002	07/11/2013	15:30	07/11/2013	17:34	1	124	124	Overhead equipment	Overhead Transformer	Repair		VI
131925997	M45211	07/11/2013	15:38	07/11/2013	17:45	1	127	127	Animal related	Fuse	Replace - Same Size		IV
131926098	Y23521	07/11/2013	16:14	07/11/2013	17:05	1	51	51	Tree related-tree broken	Overhead Service	Repair	Replace - Same Size	IV
131927209	A97001	07/11/2013	16:20	07/12/2013	1:53	5	2865	573	Underground equipment	Underground Primary	Repair	Repair	I
131926304	A97001	07/11/2013	16:20	07/11/2013	22:00	1	340	340	Underground equipment	Underground Primary	Switch/Reset	Switch/Reset	I
131926170	A97001	07/11/2013	16:20	07/11/2013	17:01	1002	41082	41	Overhead equipment	Jumper	Switch/Reset		I
131926152	B48001	07/11/2013	16:20	07/11/2013	17:01	443	18163	41	Overhead equipment	Jumper	Switch/Reset		I
131926227	IPB423	07/11/2013	16:36	07/11/2013	18:31	1	115	115	Overhead equipment	Fuse	Replace - Same Size		VI
131926249	S86597	07/11/2013	16:44	07/11/2013	19:00	1	136	136	Other				VI
131926517	N70332	07/11/2013	17:04	07/11/2013	19:30	61	8906	146	Overhead equipment	Recloser	Switch/Reset	Replace - Same Size	I
131926340	Y24523	07/11/2013	17:22	07/11/2013	18:03	1	41	41	Animal related	Transformer Fuse	Replace - Same Size		IV
131926375	P77233	07/11/2013	17:40	07/11/2013	18:37	8	456	57	Animal related	Transformer Fuse	Replace - Same Size		VI
131926402	K07320	07/11/2013	17:43	07/11/2013	20:10	24	3528	147	Animal related	Fuse	Replace - Same Size	Replace - Same Size	I
131927138	X02548	07/11/2013	19:58	07/11/2013	22:20	74	10508	142	Overhead equipment	Capacitor	Repair		IV
131927147	B93001	07/11/2013	20:23	07/11/2013	23:48	1	205	205	Overhead equipment	Connector	Replace - Same Size		I
131927178	A85002	07/11/2013	20:26	07/12/2013	1:22	88	26048	296	Overhead equipment	Overhead Primary	Repair	Replace - Same Size	I
131927188	D87001	07/11/2013	21:13	07/11/2013	22:12	32	1888	59	Tree related-tree broken	Other			I
131927191	L70125	07/11/2013	21:18	07/12/2013	1:00	1	222	222	Tree related-tree broken	Overhead Service	Replace - Same Size		IV
131927222	307001	07/11/2013	22:06	07/12/2013	2:50	9	2556	284	Overhead equipment	Overhead Transformer	Switch/Reset	Repair	VI
131927246	B71003	07/11/2013	22:59	07/12/2013	0:35	1	96	96	Tree related-tree contact	Overhead Service	Repair		I
131930139	M81402	07/11/2013	23:15	07/12/2013	1:43	165	24420	148	Jurisdictional	Overhead Primary	Repair		V
131927262	J18267	07/11/2013	23:35	07/12/2013	1:16	1	101	101	Overhead equipment	Jumper		Repair	VI
131927272	Y55594	07/11/2013	23:43	07/12/2013	6:17	14	5516	394	Underground equipment	Underground Primary	Repair	Repair	IV
131930118	R53416	07/12/2013	0:17	07/12/2013	6:04	1	347	347	Underground equipment	Underground Service	Patrol/Test/Inspect	Repair	V
131930142	M81402	07/12/2013	2:06	07/12/2013	2:21	1	15	15	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	V
131930406	L93133	07/12/2013	3:03	07/12/2013	8:30	10	3270	327	Underground equipment	Underground Primary		Replace - Same Size	VI
131934106	B68004	07/12/2013	4:07	07/12/2013	5:33	1	86	86	Overhead equipment	Connector	Replace - Same Size		III
131934115	V21002	07/12/2013	5:28	07/12/2013	6:10	114	4788	42	Overhead equipment	Fuse	Replace - Same Size		II
131934130		07/12/2013	6:00	07/12/2013	7:22	1	82	82	Animal related	Overhead Primary	No Work Required		I
131934135	P20930	07/12/2013	6:06	07/12/2013	7:16	1	70	70	Overhead equipment	Fuse	Replace - Same Size		VI
131934177	L17104	07/12/2013	6:44	07/12/2013	7:50	1	66	66	Animal related	Transformer Fuse	Replace - Same Size		III
131935247	Q01280	07/12/2013	6:45	07/12/2013	10:04	9	1791	199	Underground equipment	Underground Primary	Switch/Reset		III
131935250	Q01280	07/12/2013	6:45	07/12/2013	9:00	14	1890	135	Underground equipment	Underground Primary	Switch/Reset		III
131934187	Q01280	07/12/2013	6:45	07/12/2013	13:00	14	5250	375	Underground equipment	Underground Primary	Switch/Reset		III
131934216	N54214	07/12/2013	7:08	07/12/2013	7:50	2	84	42	Animal related	Transformer Fuse	Replace - Same Size		II
131934231	B57002	07/12/2013	7:09	07/12/2013	9:35	166	24236	146	Unknown	Fuse	Replace - Same Size		I
131934230	350103	07/12/2013	7:11	07/12/2013	9:53	1	162	162	Underground equipment	Underground Secondary	Repair	Repair	V
131934403	X77543	07/12/2013	7:35	07/12/2013	8:40	29	1885	65	Overhead equipment	Overhead Primary	Repair		IV
131934326	R10925	07/12/2013	7:41	07/12/2013	8:30	1	49	49	Animal related	Fuse	Replace - Same Size	Replace - Same Size	VI
131934347	U97528	07/12/2013	7:46	07/12/2013	10:04	1	138	138	Underground equipment	Meter	Repair		II
131934405	X77001	07/12/2013	8:05	07/12/2013	8:40	1	35	35	Overhead equipment	Overhead Primary	Repair		IV
131934434	B61001	07/12/2013	8:14	07/12/2013	13:00	1	286	286	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
131934454	B45005	07/12/2013	8:19	07/12/2013	9:50	1	91	91	Animal related	Transformer Fuse			I
131934580	P47120	07/12/2013	8:23	07/12/2013	15:00	1	397	397	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	I
131934721	Q64919	07/12/2013	9:00	07/12/2013	9:29	1	29	29	Animal related	Fuse	Replace - Same Size		VI
131934862	L93134	07/12/2013	9:31	07/12/2013	10:17	1	46	46	Overhead equipment	Fuse	Repair	Repair	VI
131935075	D32212	07/12/2013	10:22	07/15/2013	8:18	1	4196	4196	Overhead equipment	Disconnect Switch	Replace - Same Size	Replace - Same Size	I
131935093	R84148	07/12/2013	10:25	07/12/2013	12:15	12	1320	110	Animal related	Fuse	Replace - Same Size		I
131935100	L86175	07/12/2013	10:28	07/12/2013	12:56	1	148	148	Overhead equipment	Overhead Service	Replace - New Size	Replace - New Size	IV
131935239	339163	07/12/2013	10:58	07/12/2013	12:00	1	62	62	Overhead equipment	Disconnect Switch	Replace - Same Size	No Work Required	V
131935264	D35001	07/12/2013	11:04	07/12/2013	12:13	1	69	69	Weather	Transformer Fuse	Replace - Same Size		I
131935475	H11339	07/12/2013	12:00	07/12/2013	13:59	1	119	119	Overhead equipment	Overhead Service	Cut in Clear	Repair	V
131935558	D48002	07/12/2013	12:14	07/12/2013	13:09	694	38170	55	Public	Tree	Remove		I
131935591	J34377	07/12/2013	12:27	07/12/2013	12:38	1	11	11	Overhead equipment	Overhead Service	Repair		V
131935666	Q27185	07/12/2013	12:51	07/12/2013	13:59	1	68	68	Tree related-tree contact	Fuse	Replace - Same Size		VI

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
131935749	R53391	07/12/2013	12:52	07/12/2013	14:57	16	2000	125	Underground equipment	Underground Primary	Patrol/Test/Inspect	Replace - Same Size	V
131936370	R53391	07/12/2013	12:56	07/12/2013	16:29	3	639	213	Underground equipment	Underground Primary	Patrol/Test/Inspect		V
131935818	U60559	07/12/2013	13:24	07/12/2013	14:20	1	56	56	Unknown				II
131935822	V61563	07/12/2013	13:25	07/12/2013	15:00	1	95	95	Overhead equipment	Transformer Fuse	Replace - Same Size	Patrol/Test/Inspect	II
131935915	K76543	07/12/2013	13:45	07/17/2013	10:18	1	6993	6993	Overhead equipment	Connector		Replace - Same Size	IV
131936179	K25164	07/12/2013	14:48	07/12/2013	15:40	5	260	52	Overhead equipment	Fuse	Repair	Repair	VI
131936461	J14142	07/12/2013	15:12	07/12/2013	19:49	6	1662	277	Public	Pole	Repair		VI
131936278	J14142	07/12/2013	15:18	07/12/2013	20:05	3	861	287	Public	Pole	Repair		VI
131936332	V37509	07/12/2013	15:32	07/12/2013	16:15	9	387	43	Unknown	Transformer Fuse	Replace - Same Size		II
131936427		07/12/2013	16:18	07/12/2013	17:30	1	72	72	Overhead equipment	Lightning Arrestor	Repair	Repair	VI
131936540	B93002	07/12/2013	17:10	07/12/2013	22:42	13	4316	332	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Repair	I
131936552	B82002	07/12/2013	17:26	07/12/2013	19:00	1	94	94	Overhead equipment	Overhead Primary	Repair		I
131936558	M45212	07/12/2013	17:27	07/12/2013	19:00	1	93	93	Overhead equipment	Overhead Service	Repair		IV
131936578	K55397	07/12/2013	17:41	07/12/2013	18:51	4	280	70	Animal related	Fuse	Replace - Same Size		V
131936852	311001	07/12/2013	18:37	07/12/2013	20:08	470	42770	91	Unknown				VI
131936731	311002	07/12/2013	18:37	07/12/2013	20:18	513	51813	101	Overhead equipment				VI
131936702	311003	07/12/2013	18:37	07/12/2013	20:18	408	41208	101	Overhead equipment				VI
131937499	L81141	07/12/2013	19:27	07/12/2013	20:48	1	81	81	Tree related-tree broken	Transformer Fuse	Repair		IV
131937501	M09175	07/12/2013	19:29	07/12/2013	20:41	1	72	72	Overhead equipment	Overhead Secondary	Replace - Same Size	Repair	VI
131937507	Q91141	07/12/2013	19:35	07/12/2013	20:40	1	65	65	Animal related	Transformer Fuse	Replace - Same Size		I
131937552	Q95249	07/12/2013	19:35	07/12/2013	20:15	624	24960	40	Overhead equipment	Recloser			VI
131937498	D67001	07/12/2013	20:21	07/13/2013	9:28	1	787	787	Tree related-tree broken	Overhead Primary		Repair	IV
131937660	Q95249	07/12/2013	20:30	07/12/2013	22:30	7	840	120	Underground equipment	Underground Primary			VI
131937594	Q95249	07/12/2013	20:30	07/12/2013	21:27	14	798	57	Overhead equipment				VI
131937595	311003	07/12/2013	20:35	07/12/2013	20:53	1	18	18	Overhead equipment				VI
131937628	Q95249	07/12/2013	21:17	07/12/2013	21:27	396	3960	10	Overhead equipment	Recloser			VI
131937661	D88001	07/12/2013	22:07	07/13/2013	14:50	1	1003	1003	Underground equipment	Fuse		Repair	I
131937674	D37004	07/12/2013	22:49	07/13/2013	0:20	31	2821	91	Underground equipment	Underground Primary	Switch/Reset	Repair	I
131937684	P82291	07/12/2013	23:12	07/13/2013	1:15	48	5904	123	Overhead equipment	Fuse	Replace - Same Size		VI
131937691	Q01282	07/12/2013	23:45	07/13/2013	1:22	50	4850	97	Unknown	Fuse			III
131940042	S36570	07/13/2013	1:25	07/13/2013	3:50	1	145	145	Other	Transformer Fuse			VI
131940044	R23332	07/13/2013	1:32	07/13/2013	3:20	3	324	108	Overhead equipment	Fuse	Repair		V
131940056	P81854	07/13/2013	2:00	07/13/2013	6:49	83	23987	289	Animal related	Lightning Arrestor			V
131940062	V36002	07/13/2013	3:13	07/13/2013	3:47	2	68	34	Animal related	Other	Remove		II
131940001	351001	07/13/2013	4:06	07/13/2013	6:56	2	340	170	Public	Pole	Patrol/Test/Inspect	Replace - Same Size	VI
131940075	X75512	07/13/2013	4:59	07/13/2013	8:00	29	5249	181	Overhead equipment	Disconnect Switch	Repair	Repair	IV
131940189	B80004	07/13/2013	5:32	07/13/2013	9:07	737	158455	215	Overhead equipment	Overhead Primary	Switch/Reset		I
131940101	C10001	07/13/2013	6:15	07/13/2013	12:42	1	387	387	Underground equipment	Underground Primary	Repair		III
131940115	U16522	07/13/2013	6:58	07/13/2013	8:32	1	94	94	Animal related	Transformer Fuse	Replace - Same Size		II
131940133	A50002	07/13/2013	7:21	07/13/2013	8:37	1	76	76	Animal related	Fuse	Replace - Same Size	No Work Required	I
131940142	J07173	07/13/2013	7:55	07/13/2013	9:30	6	570	95	Overhead equipment	Transformer Fuse	Replace - Same Size		I
131940143	J83138	07/13/2013	7:56	07/13/2013	8:44	1	48	48	Overhead equipment	Fuse	Replace - Same Size		VI
131940183	Q01280	07/13/2013	8:10	07/13/2013	8:44	5	170	34	Animal related	Fuse			III
131940161	D28123	07/13/2013	8:11	07/13/2013	10:19	1	128	128	Animal related	Transformer Fuse	Replace - Same Size	No Work Required	I
131940163	L93133	07/13/2013	8:15	07/13/2013	9:35	12	960	80	Animal related	Fuse		Replace - Same Size	VI
131940474	Y89535	07/13/2013	8:36	07/13/2013	18:59	1	623	623	Underground equipment	Underground Transformer		Replace - Same Size	IV
131940204	Y89535	07/13/2013	8:36	07/13/2013	12:12	13	2808	216	Underground equipment	Underground Primary	Repair	Replace - Same Size	IV
131940110	J20931	07/13/2013	8:37	07/13/2013	10:55	1	138	138	Overhead equipment	Overhead Transformer		Replace - Same Size	VI
131940313	K39153	07/13/2013	8:46	07/13/2013	10:00	8	592	74	Animal related	Transformer Fuse	Replace - Same Size		III
131940275	B45005	07/13/2013	8:51	07/13/2013	9:46	30	1650	55	Overhead equipment	Disconnect Switch	Replace - Same Size		I
131940212	V49541	07/13/2013	8:56	07/13/2013	10:14	1	78	78	Animal related	Transformer Fuse	Replace - Same Size		II
131940289	N97887	07/13/2013	9:19	07/13/2013	11:53	1	154	154	Public	Overhead Primary	Patrol/Test/Inspect	Repair	V
131940299	B21004	07/13/2013	9:34	07/13/2013	11:28	1	114	114	Tree related-tree broken	Tree	Cut in Clear	No Work Required	I
131940311	B28004	07/13/2013	9:48	07/13/2013	13:02	1	194	194	Tree related-tree broken	Overhead Service	Repair		I
131940315	Q47833	07/13/2013	9:51	07/13/2013	11:01	1	70	70	Overhead equipment	Transformer Fuse	Replace - Same Size		V
131940318	Q32170	07/13/2013	9:54	07/13/2013	10:45	1	51	51	Animal related	Transformer Fuse	Replace - Same Size	Replace - Same Size	I

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
131940365	U66515	07/13/2013	10:30	07/13/2013	12:19	1	109	109	Other	Transformer Fuse	Switch/Reset		II
131940375	V33003	07/13/2013	10:40	07/13/2013	11:50	31	2170	70	Overhead equipment	Jumper	Repair		II
131940406	R50910	07/13/2013	11:21	07/13/2013	12:10	1	49	49	Animal related	Transformer Fuse	Replace - Same Size		I
131940430	B68001	07/13/2013	11:21	07/13/2013	12:27	8	528	66	Animal related	Fuse	Replace - Same Size		III
131940408	U13551	07/13/2013	11:23	07/13/2013	14:00	1	157	157	Overhead equipment	Overhead Transformer	Replace - Same Size	Patrol/Test/Inspect	II
131940411	X66582	07/13/2013	11:25	07/13/2013	12:55	1	90	90	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
131940441	N18210	07/13/2013	11:47	07/13/2013	13:25	143	14014	98	Unknown	Fuse	Replace - Same Size		III
131940454	V33003	07/13/2013	12:04	07/13/2013	12:08	1	4	4	Overhead equipment	Overhead Primary	Repair		II
131940507	R20501	07/13/2013	13:07	07/13/2013	14:50	1	103	103	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	IV
131940527	Y69565	07/13/2013	13:29	07/13/2013	16:30	1	181	181	Overhead equipment	Overhead Transformer	Repair		IV
131940538	L12128	07/13/2013	13:45	07/13/2013	15:13	20	1760	88	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	III
131940570	P49180	07/13/2013	14:00	07/13/2013	15:55	2	230	115	Overhead equipment	Overhead Service	Replace - Same Size		I
131940577	R16511	07/13/2013	14:07	07/13/2013	18:50	119	33677	283	Overhead equipment	Pole	Replace - Same Size	Replace - Same Size	I
131940562	L71171	07/13/2013	14:15	07/13/2013	14:43	1	28	28	Overhead equipment	Disconnect Switch			IV
131940571	309139	07/13/2013	14:19	07/13/2013	15:27	1	68	68	Overhead equipment	Overhead Service	Replace - New Size		V
131940582	X72535	07/13/2013	14:25	07/13/2013	15:04	1	39	39	Overhead equipment	Fuse	Replace - Same Size		IV
131940595	HB6283	07/13/2013	14:45	07/13/2013	16:16	1	91	91	Animal related	Disconnect Switch	Replace - Same Size		VI
131940645	M54317	07/13/2013	14:47	07/13/2013	19:57	1	310	310	Overhead equipment	Pole	Patrol/Test/Inspect	No Work Required	V
131940598	B68001	07/13/2013	14:48	07/13/2013	16:40	1	112	112	Tree related-tree contact	Overhead Service	Repair		III
131940601	303005	07/13/2013	14:49	07/13/2013	15:30	1	41	41	Public	Overhead Service	Repair		VI
131940644	B00003	07/13/2013	15:48	07/13/2013	17:02	6	444	74	Overhead equipment	Connector	Replace - Same Size		I
131940676	D28123	07/13/2013	16:35	07/13/2013	18:25	6	660	110	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
131940709	Q85162	07/13/2013	17:41	07/13/2013	19:24	1	103	103	Other	Meter	Replace - Same Size		VI
131940734	S53542	07/13/2013	18:45	07/14/2013	1:40	13	5395	415	Tree related-tree broken	Overhead Primary	Cut in Clear	Repair	VI
131940739	Z19547	07/13/2013	19:00	07/13/2013	20:30	1	90	90	Unknown	Fuse	Replace - Same Size		IV
131940804	T06505	07/13/2013	20:29	07/13/2013	22:30	1	121	121	Overhead equipment	Overhead Primary	Repair		VI
131940782	U06551	07/13/2013	21:11	07/14/2013	0:34	1	203	203	Overhead equipment	Disconnect Switch	Replace - Same Size		II
131940820	B80003	07/13/2013	22:17	07/14/2013	1:15	1	178	178	Underground equipment	Underground Primary	Switch/Reset	Repair	I
131940822	D69008	07/13/2013	22:26	07/14/2013	3:11	6	1710	285	Underground equipment	Underground Transformer	Patrol/Test/Inspect	Patrol/Test/Inspect	I
131940826	Z21564	07/13/2013	22:36	07/14/2013	3:05	1	269	269	Public	Underground Transformer	Repair	Replace - Same Size	IV
131940833	J14140	07/13/2013	22:57	07/14/2013	0:13	1	76	76	Overhead equipment	Fuse	Replace - Same Size		VI
131950007	J14140	07/14/2013	0:18	07/14/2013	4:04	1	226	226	Overhead equipment	Overhead Transformer		Replace - Same Size	VI
131950048	K31120	07/14/2013	3:15	07/14/2013	3:55	1	40	40	Public	Overhead Transformer	Switch/Reset	No Work Required	I
131950067	C40001	07/14/2013	3:51	07/14/2013	5:50	61	7259	119	Underground equipment	Underground Primary	Repair	Repair	I
131950073	S66578	07/14/2013	4:21	07/14/2013	9:25	23	6992	304	Public	Pole	Replace - Same Size	Replace - Same Size	VI
131950077	P42229	07/14/2013	4:40	07/14/2013	10:43	5	1815	363	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	VI
131950083	S27598	07/14/2013	4:54	07/14/2013	12:50	2	952	476	Underground equipment	Underground Primary			VI
131950118	L70127	07/14/2013	5:09	07/14/2013	11:00	30	10530	351	Underground equipment	Underground Primary	Repair	Repair	IV
131950124	J34377	07/14/2013	6:23	07/14/2013	12:12	337	117613	349	Animal related	Overhead Primary	Patrol/Test/Inspect	Replace - Urgent	V
131950095	Y35515	07/14/2013	6:36	07/14/2013	8:28	1	112	112	Overhead equipment	Meter			IV
131950106	H06135	07/14/2013	6:49	07/14/2013	9:00	62	8122	131	Unknown				IV
131950104	K30204	07/14/2013	6:51	07/14/2013	8:20	1	89	89	Overhead equipment	Fuse	Replace - Same Size		III
131950119	X88502	07/14/2013	7:14	07/14/2013	8:10	2	112	56	Overhead equipment	Fuse	Replace - Same Size		IV
131950121	D31017	07/14/2013	7:21	07/14/2013	10:22	1	181	181	Underground equipment	Underground Primary	Repair		III
131950131	J58380	07/14/2013	7:38	07/14/2013	10:57	25	4975	199	Other	Underground Primary	Repair		III
131950164	V20502	07/14/2013	7:41	07/14/2013	10:40	16	2864	179	Underground equipment	Underground Primary			II
131950144	M41111	07/14/2013	8:09	07/14/2013	9:25	1	76	76	Animal related	Transformer Fuse	Replace - Same Size		I
131950146	S93553	07/14/2013	8:21	07/14/2013	8:40	1	19	19	Weather	Fuse	Replace - Same Size	Advise Customer	VI
131950166	K09864	07/14/2013	8:54	07/14/2013	10:03	1	69	69	Overhead equipment				V
131950169	P52305	07/14/2013	8:58	07/26/2013	10:05	1	17347	17347	Tree related-tree contact	Transformer Fuse	Replace - Same Size		IV
131950222	V24583	07/14/2013	10:25	07/14/2013	11:34	1	69	69	Animal related	Fuse	Replace - Same Size		II
131950230	S07536	07/14/2013	10:38	07/14/2013	11:55	37	2849	77	Animal related	Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
131950238		07/14/2013	11:09	07/14/2013	14:48	1	219	219	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	V
131950241	A24001	07/14/2013	11:15	07/14/2013	12:09	1	54	54	Overhead equipment	Connector	Replace - Same Size		I
131950246	Z11506	07/14/2013	11:23	07/14/2013	12:53	1	90	90	Animal related	Fuse	Replace - Same Size	No Work Required	IV
131950268	Z06537	07/14/2013	11:54	07/14/2013	19:15	1	441	441	Overhead equipment	Underground Primary	Repair		IV

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
131950277	342002	07/14/2013	12:26	07/14/2013	13:07	3	123	41	Public	Overhead Secondary	Repair		VI
131950285	M19222	07/14/2013	12:56	07/14/2013	16:52	4	944	236	Public	Underground Transformer	Disconnect	Replace - Same Size	VI
131950406	L17102	07/14/2013	14:13	07/14/2013	15:12	1	59	59	Overhead equipment	Overhead Service	Replace - Same Size		III
131950417	K76541	07/14/2013	14:39	07/14/2013	16:33	12	1368	114	Animal related	Transformer Fuse	Replace - Same Size		IV
131950421	U12540	07/14/2013	14:43	07/14/2013	15:55	1	72	72	Animal related	Fuse	Replace - Same Size		II
131950462	Y61003	07/14/2013	15:37	07/14/2013	18:35	42	7476	178	Overhead equipment	Crossarm	Replace - New Size	Replace - Same Size	IV
131950479		07/14/2013	16:34	07/14/2013	17:27	1	53	53	Other	Fuse	Repair		III
131950491	P69173	07/14/2013	16:46	07/14/2013	18:03	126	9702	77	Unknown	Fuse	Replace - Same Size		III
131950504	328120	07/14/2013	17:08	07/14/2013	18:14	1	66	66	Overhead equipment	Fuse	Replace - New Size		V
131950512	A85001	07/14/2013	17:34	07/14/2013	19:00	1	86	86	Animal related	Transformer Fuse	Replace - Same Size		I
131950515	S42579	07/14/2013	17:40	07/14/2013	18:36	5	280	56	Unknown	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
131950525	Y55555	07/14/2013	17:50	07/14/2013	18:30	5	200	40	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
131950537	K30204	07/14/2013	18:06	07/14/2013	20:25	1	139	139	Unknown	Transformer Fuse	Replace - Same Size		III
131950544	D16002	07/14/2013	18:19	07/14/2013	20:30	5	655	131	Overhead equipment	Overhead Primary	Repair		I
131950547	D16002	07/14/2013	18:19	07/14/2013	20:30	11	1441	131	Overhead equipment	Overhead Primary	Patrol/Test/Inspect	Patrol/Test/Inspect	I
131950553	Q36410	07/14/2013	18:26	07/14/2013	19:15	1	49	49	Tree related-tree broken	Overhead Service	Repair		I
131950594	Q82907	07/14/2013	19:05	07/14/2013	20:59	2	228	114	Public	Fuse		Patrol/Test/Inspect	VI
131950587	L24123	07/14/2013	19:16	07/14/2013	20:28	2	144	72	Animal related	Fuse	Replace - Same Size		III
131950603	K74164	07/14/2013	19:32	07/14/2013	21:45	33	4389	133	Underground equipment	Underground Primary	Switch/Reset	Repair	IV
131950625	A85002	07/14/2013	19:53	07/15/2013	4:15	1	502	502	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
131950638	Q27185	07/14/2013	20:41	07/15/2013	0:29	1	228	228	Tree related-tree contact	Fuse		Replace - Same Size	VI
131950642	K11376	07/14/2013	20:50	07/14/2013	22:45	1	115	115	Underground equipment	Tree	Patrol/Test/Inspect	Patrol/Test/Inspect	V
131950648	C15002	07/14/2013	21:13	07/14/2013	22:55	9	918	102	Overhead equipment	Overhead Secondary	Repair	No Work Required	III
131950651	X12002	07/14/2013	21:14	07/14/2013	23:20	15	1890	126	Overhead equipment	Overhead Secondary	Repair	Repair	IV
131950661	S60581	07/14/2013	21:36	07/14/2013	23:00	1	84	84	Other	Fuse	Repair		VI
131950687		07/14/2013	23:28	07/15/2013	1:50	1	142	142	Underground equipment	Underground Primary	Repair	Repair	VI
131960109	T16528	07/15/2013	1:39	07/15/2013	7:04	3	975	325	Underground equipment	Underground Primary	Repair	Repair	VI
131960112	V30004	07/15/2013	1:55	07/15/2013	3:18	1	83	83	Animal related	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	II
131964179	B58002	07/15/2013	4:45	07/15/2013	5:51	1	66	66	Animal related	Fuse	Replace - Same Size		I
131964224	J20931	07/15/2013	6:57	07/15/2013	8:15	1	78	78	Animal related	Fuse	Replace - Same Size	Replace - Same Size	VI
131964227	Y86595	07/15/2013	6:59	07/15/2013	8:15	1	76	76	Unknown	Fuse	Replace - Same Size		IV
131964245	S02502	07/15/2013	7:15	07/15/2013	9:09	1	114	114	Animal related	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
131964318	D32212	07/15/2013	7:39	07/15/2013	13:15	1	336	336	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
131964547	T16527	07/15/2013	7:40	07/15/2013	11:15	2	430	215	Underground equipment	Underground Primary	Repair	Repair	VI
131964321	T16527	07/15/2013	7:40	07/15/2013	8:36	1	56	56	Underground equipment	Underground Primary	Switch/Reset		VI
131964346	X57566	07/15/2013	7:50	07/15/2013	9:50	1	120	120	Underground equipment	Underground Primary	Switch/Reset		IV
131964366	X23516	07/15/2013	7:55	07/15/2013	10:00	1	125	125	Tree related-tree contact	Transformer Fuse			IV
131964406	P73182	07/15/2013	8:04	07/15/2013	10:08	1	124	124	Weather	Fuse	Repair	Replace - Same Size	VI
131964465	X66582	07/15/2013	8:21	07/15/2013	12:30	1	249	249	Tree related-tree contact	Overhead Service	Repair		IV
131964475	U33509	07/15/2013	8:23	07/15/2013	8:49	1	26	26	Animal related	Transformer Fuse	Replace - Same Size		II
131964492	K71821	07/15/2013	8:29	07/15/2013	10:15	1	106	106	Overhead equipment	Connector			IV
131964506	X23516	07/15/2013	8:33	07/15/2013	10:00	1	87	87	Tree related-tree broken	Overhead Primary			IV
131964596	Y41559	07/15/2013	8:59	07/15/2013	9:50	1	51	51	Animal related	Fuse	Replace - Same Size	No Work Required	IV
131964605	J83138	07/15/2013	9:00	07/15/2013	10:38	1	98	98	Animal related	Overhead Transformer			VI
131964615	Q04410	07/15/2013	9:03	07/15/2013	9:31	1	28	28	Animal related	Transformer Fuse	Repair	Repair	III
131964687	J06168	07/15/2013	9:17	07/15/2013	11:17	1	120	120	Overhead equipment	Overhead Transformer	Switch/Reset		I
131964783	V39001	07/15/2013	9:39	07/15/2013	14:29	1	290	290	Overhead equipment				II
131964874	346003	07/15/2013	9:58	07/15/2013	11:23	1	85	85	Tree related-tree contact	Overhead Service	Repair		VI
131964890	X96524	07/15/2013	10:03	07/15/2013	15:00	1	297	297	Underground equipment	Underground Secondary	Repair	Repair	IV
131965018	Q36410	07/15/2013	10:25	07/15/2013	11:37	1	72	72	Jurisdictional	Overhead Service	Repair		I
131965096	H10843	07/15/2013	10:41	07/15/2013	12:27	1	106	106	Animal related	Transformer Fuse	Replace - Same Size		V
131965126	310124	07/15/2013	10:44	07/15/2013	13:35	1	171	171	Public	Underground Service	Cut in Clear		V
131965359	S25552	07/15/2013	11:27	07/15/2013	12:18	1	51	51	Overhead equipment	Other	Patrol/Test/Inspect	Repair	VI
131965704	D89003	07/15/2013	12:30	07/15/2013	14:10	13	1300	100	Underground equipment	Underground Primary	Repair	Replace - Same Size	I
131965790	J86108	07/15/2013	12:46	07/15/2013	13:29	221	9503	43	Overhead equipment	Overhead Primary			VI
131965785	Z04520	07/15/2013	12:56	07/15/2013	14:45	1	109	109	Tree related-tree contact	Overhead Service	Trim		IV

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
131965882	X92507	07/15/2013	13:14	07/15/2013	13:47	1	33	33	Overhead equipment	Transformer Fuse	Repair	Replace - Same Size	IV
131966287	S57518	07/15/2013	14:29	07/15/2013	15:21	1	52	52	Animal related	Transformer Fuse			VI
131966531	N15850	07/15/2013	15:14	07/15/2013	15:45	1	31	31	Overhead equipment	Transformer Fuse	Replace - Same Size	No Work Required	V
131966539	T22507	07/15/2013	15:16	07/15/2013	15:44	1	28	28	Unknown	Meter	Replace - Same Size		VI
131966574	Z17503	07/15/2013	15:21	07/15/2013	16:15	26	1404	54	Underground equipment	Fuse	Replace - Same Size		IV
131966577	J34377	07/15/2013	15:23	07/15/2013	19:10	2	454	227	Animal related	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	V
131966640	D61001	07/15/2013	15:35	07/15/2013	21:33	1	358	358	Underground equipment	Underground Primary			III
131966637	K69112	07/15/2013	15:36	07/15/2013	17:47	1	131	131	Weather	Overhead Service	Repair	No Work Required	IV
131966722	Q68836	07/15/2013	15:54	07/15/2013	16:42	1	48	48	Animal related	Transformer Fuse	Replace - Same Size	No Work Required	V
131966761	P47169	07/15/2013	15:58	07/15/2013	17:15	277	21329	77	Overhead equipment	Jumper	Repair		I
131966760	M22812	07/15/2013	15:59	07/15/2013	19:22	64	12992	203	Overhead equipment	Fuse			V
131966781	P47169	07/15/2013	16:07	07/15/2013	17:27	1	80	80	Overhead equipment	Fuse	Replace - Same Size		I
131966832	J18268	07/15/2013	16:21	07/15/2013	17:49	1	88	88	Animal related				VI
131966838	Q70161	07/15/2013	16:23	07/15/2013	17:06	1	43	43	Overhead equipment	Overhead Transformer			I
131966883	R09225	07/15/2013	16:39	07/15/2013	17:27	1	48	48	Unknown	Fuse			III
131966923	K79211	07/15/2013	16:41	07/15/2013	18:43	108	13176	122	Public	Pole	Replace - Same Size		IV
131966934	V24583	07/15/2013	16:50	07/15/2013	22:20	1	330	330	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	II
131967044	P17108	07/15/2013	17:20	07/15/2013	22:36	1	316	316	Underground equipment	Underground Secondary	Repair		IV
131967086	J63174	07/15/2013	17:38	07/15/2013	19:03	1	85	85	Unknown	Other			III
131967157	C50001	07/15/2013	18:10	07/15/2013	22:36	1	266	266	Overhead equipment	Lightning Arrestor	Cut in Clear	No Work Required	III
131967343	D96001	07/15/2013	18:23	07/15/2013	19:08	1	45	45	Animal related	Fuse	Replace - Same Size	Patrol/Test/Inspect	I
131967352	D28123	07/15/2013	18:25	07/15/2013	19:34	121	8349	69	Animal related	Fuse	Replace - Same Size		I
131967357	H00162	07/15/2013	18:30	07/15/2013	19:07	1	37	37	Other	Customer Equipment			III
131967360	K62102	07/15/2013	18:34	07/15/2013	19:26	1	52	52	Overhead equipment	Transformer Fuse	Repair		II
131967369	330127	07/15/2013	18:40	07/15/2013	20:10	2	180	90	Overhead equipment	Fuse	Replace - Same Size		V
131967919	M07236	07/15/2013	19:03	07/15/2013	20:00	1	57	57	Tree related-tree contact	Overhead Service	Repair		III
131967937	U84534	07/15/2013	19:15	07/15/2013	22:11	1	176	176	Overhead equipment	Overhead Transformer	Replace - Same Size	Cut in Clear	II
131968010	Y89004	07/15/2013	19:40	07/15/2013	21:05	34	2890	85	Overhead equipment	Overhead Primary	Raise		IV
131968014	S47538	07/15/2013	19:50	07/15/2013	20:33	1	43	43	Other	Meter	Advise Customer		VI
131968028	B73001	07/15/2013	20:06	07/15/2013	21:50	1	104	104	Animal related	Fuse	Replace - Same Size	Patrol/Test/Inspect	I
131968038	B45005	07/15/2013	20:16	07/15/2013	22:50	1	154	154	Overhead equipment	Overhead Service		Repair	I
131968039	U90566	07/15/2013	20:17	07/15/2013	21:20	1	63	63	Overhead equipment	Transformer Fuse	Repair	Repair	II
131968087	S30518	07/15/2013	21:10	07/15/2013	22:47	55	5335	97	Tree related-tree broken	Overhead Primary			VI
131968075	S30518	07/15/2013	21:18	07/15/2013	23:49	1	151	151	Tree related-tree contact	Overhead Primary	Repair		VI
131968107	D87001	07/15/2013	22:25	07/16/2013	4:58	1	393	393	Underground equipment	Underground Primary	Repair	Repair	I
131968110	X96524	07/15/2013	22:30	07/16/2013	0:04	35	3290	94	Animal related	Fuse	Replace - Same Size	No Work Required	IV
131968126	Q01280	07/15/2013	23:01	07/16/2013	1:38	57	8949	157	Underground equipment	Underground Primary			III
131970727	Y63539	07/16/2013	3:00	07/16/2013	4:30	5	450	90	Animal related	Fuse	Replace - Same Size	No Work Required	IV
131974810	L99392	07/16/2013	4:15	07/16/2013	5:47	1	92	92	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	V
131974983	M40117	07/16/2013	6:54	07/16/2013	8:34	15	1500	100	Overhead equipment	Connector	Repair		I
131974908	M47816	07/16/2013	6:57	07/16/2013	7:25	69	1932	28	Animal related	Fuse	Repair	Repair	V
131974909	Q32171	07/16/2013	6:59	07/16/2013	9:13	1	134	134	Tree related-tree broken	Overhead Primary	Repair	Repair	I
131974913	P05825	07/16/2013	7:03	07/16/2013	7:40	1	37	37	Animal related	Transformer Fuse	Replace - Same Size		V
131974947	Y51506	07/16/2013	7:19	07/16/2013	8:30	1	71	71	Overhead equipment	Overhead Secondary	Repair		IV
131975040	341001	07/16/2013	7:55	07/16/2013	9:00	6	390	65	Overhead equipment	Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
131975097	K62102	07/16/2013	8:09	07/16/2013	9:31	1	82	82	Overhead equipment	Fuse	Replace - Same Size	No Work Required	II
131975126	Y35515	07/16/2013	8:20	07/16/2013	8:40	2	40	20	Animal related	Fuse	Repair	Replace - Same Size	IV
131975381	L16213	07/16/2013	9:25	07/16/2013	10:44	1	79	79	Tree related-tree contact	Overhead Service	Repair		III
131975454	U99593	07/16/2013	9:42	07/16/2013	10:20	1	38	38	Animal related	Disconnect Switch	Repair		II
131975500	L14232	07/16/2013	9:52	07/16/2013	11:49	1	117	117	Tree related-tree contact	Overhead Service	Raise		III
131975520	P19395	07/16/2013	9:56	07/16/2013	10:48	1	52	52	Overhead equipment	Fuse	Replace - Same Size		V
131975557	M40117	07/16/2013	10:06	07/16/2013	10:23	1	17	17	Overhead equipment	Overhead Service	No Work Required		I
131975646		07/16/2013	10:25	07/16/2013	11:26	1	61	61	Animal related	Fuse	Replace - Same Size		V
131975722	K89141	07/16/2013	10:34	07/16/2013	11:48	10	740	74	Underground equipment	Underground Primary		Repair	III
131976454	A81001	07/16/2013	10:46	07/16/2013	14:30	1	224	224	Underground equipment	Underground Transformer	Replace - Same Size		I
131975765	A81001	07/16/2013	10:46	07/16/2013	11:00	40	560	14	Underground equipment	Underground Primary	Switch/Reset	Repair	I

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
131976056	329145	07/16/2013	11:00	07/16/2013	11:46	8	368	46	Other	Fuse	Replace - Same Size	Replace - New Size	V
131976077	P49183	07/16/2013	11:04	07/16/2013	12:27	1	83	83	Overhead equipment	Overhead Service	No Work Required		I
131976112	K30205	07/16/2013	11:09	07/16/2013	13:50	39	6279	161	Overhead equipment	Overhead Primary			III
131976186	K78351	07/16/2013	11:25	07/16/2013	12:10	1	45	45	Overhead equipment	Connector	Replace - Same Size	No Work Required	IV
131976202	P69173	07/16/2013	11:30	07/16/2013	12:17	1	47	47	Unknown	Fuse	Replace - Same Size		III
131976392	B19002	07/16/2013	11:40	07/16/2013	13:25	7	735	105	Public	Pole	Replace - Same Size	Replace - Same Size	I
131976336	B19002	07/16/2013	11:43	07/16/2013	12:23	36	1440	40	Public	Pole	Replace - Same Size	Replace - Same Size	I
131976286	342001	07/16/2013	11:50	07/16/2013	12:31	1	41	41	Public	Other	Patrol/Test/Inspect		VI
131976335	J68402	07/16/2013	11:59	07/16/2013	12:25	1	26	26	Animal related	Transformer Fuse			III
131976369	B62003	07/16/2013	12:04	07/16/2013	14:40	9	1404	156	Underground equipment	Underground Transformer	Replace - Same Size	Repair	I
131976427	M49411	07/16/2013	12:27	07/16/2013	13:27	1	60	60	Animal related	Fuse	Patrol/Test/Inspect	Replace - Same Size	V
131976440	R50910	07/16/2013	12:30	07/16/2013	13:44	1	74	74	Animal related	Transformer Fuse	Replace - Same Size	No Work Required	I
131976679	S43512	07/16/2013	13:19	07/16/2013	13:42	1	23	23	Unknown			No Work Required	VI
131976763	X77543	07/16/2013	13:33	07/16/2013	14:49	1	76	76	Animal related	Animal Guard	Install		IV
131977517	J71128	07/16/2013	13:36	07/16/2013	17:45	1	249	249	Overhead equipment	Overhead Primary	Repair		I
131977001	J71128	07/16/2013	13:36	07/16/2013	16:10	612	94248	154	Overhead equipment	Overhead Primary	Repair	Repair	I
131976809	M25143	07/16/2013	13:40	07/16/2013	15:34	1	114	114	Underground equipment	Underground Service	Repair		IV
131976923	V17574	07/16/2013	14:00	07/16/2013	14:45	1	45	45	Overhead equipment	Connector			II
131976940	B54004	07/16/2013	14:03	07/16/2013	15:27	14	1176	84	Tree related-tree broken	Tree	Remove	No Work Required	I
131977130	L12127	07/16/2013	14:07	07/16/2013	15:50	22	2266	103	Underground equipment	Underground Primary		Repair	III
131977051	Y61003	07/16/2013	14:13	07/16/2013	15:18	16	1040	65	Public	Underground Primary			IV
131977477	T41540	07/16/2013	14:19	07/16/2013	19:13	7	2058	294	Public	Underground Primary	Repair	Repair	IV
131977034	309139	07/16/2013	14:22	07/16/2013	19:05	1	283	283	Overhead equipment	Pole	Patrol/Test/Inspect	Replace - New Size	V
131977047	L50215	07/16/2013	14:25	07/16/2013	18:35	6	1500	250	Animal related	Animal Guard	Install		VI
131977085	309139	07/16/2013	14:32	07/16/2013	19:05	15	4095	273	Overhead equipment	Pole	Replace - Same Size	Replace - Same Size	V
131977274	M21134	07/16/2013	15:11	07/16/2013	15:45	1	34	34	Overhead equipment	Fuse	Repair	Repair	VI
131977412	D28124	07/16/2013	15:47	07/16/2013	16:33	4	184	46	Overhead equipment	Fuse	Replace - Same Size	No Work Required	I
131977493	N05172	07/16/2013	16:13	07/16/2013	17:16	1	63	63	Weather	Transformer Fuse	Replace - Same Size		I
131977706	K80382	07/16/2013	16:34	07/16/2013	18:23	6	654	109	Overhead equipment	Connector	Replace - Same Size	No Work Required	IV
131977555	303001	07/16/2013	16:34	07/16/2013	17:40	1	66	66	Overhead equipment				VI
131977568	D28124	07/16/2013	16:38	07/16/2013	19:10	2	304	152	Overhead equipment	Disconnect Switch	Patrol/Test/Inspect	Replace - Same Size	I
131977577	B54004	07/16/2013	16:43	07/16/2013	17:34	1	51	51	Tree related-tree broken				I
131977598	B44002	07/16/2013	16:45	07/16/2013	18:36	59	6549	111	Overhead equipment	Fuse	Patrol/Test/Inspect		I
131977610	M04365	07/16/2013	16:56	07/16/2013	20:55	4	956	239	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - New Size	V
131977630	G20001	07/16/2013	17:04	07/16/2013	18:47	1	103	103	Overhead equipment	Fuse	Replace - Same Size		III
131977633	T06503	07/16/2013	17:05	07/16/2013	20:29	1	204	204	Overhead equipment	Overhead Transformer		Replace - Same Size	VI
131977701	H06135	07/16/2013	17:29	07/16/2013	18:49	1	80	80	Overhead equipment	Connector	Replace - Same Size		IV
131977722	L24122	07/16/2013	17:44	07/16/2013	18:32	1	48	48	Tree related-tree contact	Transformer Fuse	Replace - Same Size		III
131977746	F10002	07/16/2013	18:00	07/16/2013	20:14	1	134	134	Overhead equipment	Fuse	Replace - Same Size		III
131978319	P62138	07/16/2013	18:02	07/16/2013	21:00	9	1602	178	Overhead equipment	Overhead Primary	Raise	Raise	VI
131977846	P62138	07/16/2013	18:02	07/16/2013	19:00	31	1798	58	Overhead equipment				VI
131977894	G30001	07/16/2013	18:25	07/16/2013	19:11	1	46	46	Overhead equipment	Disconnect Switch	Replace - Same Size		III
131978301	Y31589	07/16/2013	18:49	07/16/2013	20:28	1	99	99	Overhead equipment	Overhead Transformer	Replace - Same Size	Replace - Same Size	IV
131978310	Y31589	07/16/2013	18:54	07/16/2013	20:37	1	103	103	Overhead equipment	Overhead Transformer	Replace - Same Size		IV
131978320	Q91175	07/16/2013	19:16	07/16/2013	20:58	2	204	102	Tree related-tree contact	Overhead Service	Repair		I
131978368	T04513	07/16/2013	19:33	07/16/2013	22:25	5	860	172	Tree related-tree broken	Overhead Service	Repair	No Work Required	VI
131978389	B82001	07/16/2013	19:48	07/17/2013	1:00	16	4992	312	Underground equipment	Underground Primary	Repair	Repair	I
131978480	Q91141	07/16/2013	21:32	07/16/2013	23:25	560	63280	113	Overhead equipment	Overhead Primary	Repair	Reconnect	I
131978482	Q91141	07/16/2013	21:38	07/16/2013	23:30	2	224	112	Overhead equipment	Other			I
131978601	R00452	07/16/2013	22:35	07/17/2013	0:03	2965	260920	88	Animal related				VI
131978747		07/16/2013	22:47	07/17/2013	0:15	1	88	88	Animal related				VI
131978772	N05170	07/16/2013	23:15	07/17/2013	3:12	1	237	237	Overhead equipment	Overhead Transformer	Replace - Same Size		I
131980366	J18268	07/16/2013	23:28	07/17/2013	5:55	3	1161	387	Overhead equipment	Overhead Transformer	Replace - Same Size	Replace - Same Size	VI
131978779	J18268	07/16/2013	23:28	07/17/2013	2:35	38	7106	187	Overhead equipment	Fuse		Patrol/Test/Inspect	VI
131978780	HB6251	07/16/2013	23:33	07/17/2013	0:14	1	41	41	Animal related				VI
131978786	N18211	07/16/2013	23:59	07/17/2013	1:50	1	111	111	Unknown	Transformer Fuse	Replace - Same Size		III

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
131980193	R00452	07/17/2013	0:53	07/17/2013	1:04	1844	20284	11	Overhead equipment				VI
131980196	H22349	07/17/2013	1:25	07/17/2013	2:20	11	605	55	Public	Transformer Fuse	Replace - Same Size		V
131980197	S36570	07/17/2013	1:29	07/17/2013	3:45	1	136	136	Animal related	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
131980367	HA5431	07/17/2013	2:35	07/17/2013	4:26	1	111	111	Animal related	Tree	Cut in Clear	Replace - Same Size	V
131983955	B65004	07/17/2013	3:25	07/17/2013	4:55	1	90	90	Overhead equipment	Overhead Primary			I
131983956	B65004	07/17/2013	3:27	07/17/2013	4:45	23	1794	78	Overhead equipment	Overhead Transformer		Repair	I
131983974	V20502	07/17/2013	5:22	07/17/2013	8:42	46	9200	200	Tree related-tree broken	Overhead Primary	Repair	Repair	II
131984013	B62003	07/17/2013	6:28	07/17/2013	7:53	108	9180	85	Overhead equipment	Fuse	Replace - Same Size		I
131984021	Y91500	07/17/2013	6:44	07/17/2013	8:25	1	101	101	Tree related-tree broken	Overhead Service	Repair	Replace - Same Size	IV
131984011	X75573	07/17/2013	6:54	07/17/2013	7:58	8	512	64	Overhead equipment	Recloser	Switch/Reset	Repair	IV
131984038	T08501	07/17/2013	6:59	07/17/2013	8:17	5	390	78	Animal related	Transformer Fuse	Repair	Repair	VI
131984059		07/17/2013	7:09	07/17/2013	9:24	1	135	135	Animal related	Transformer Fuse	Replace - Same Size		V
131984163	N50334	07/17/2013	7:26	07/17/2013	8:25	45	2655	59	Animal related	Transformer Fuse	Replace - Same Size		II
131984181	V25504	07/17/2013	7:34	07/17/2013	8:45	43	3053	71	Public	Overhead Primary	Repair	No Work Required	II
131984174	K95201	07/17/2013	7:36	07/17/2013	8:30	47	2538	54	Overhead equipment	Jumper	Replace - Same Size		III
131984294	J99121	07/17/2013	7:47	07/17/2013	9:26	11	1089	99	Animal related	Fuse			VI
131984267	P12290	07/17/2013	7:54	07/17/2013	10:09	1	135	135	Tree related-tree broken	Overhead Service		Repair	V
131984297	329148	07/17/2013	8:04	07/17/2013	8:46	10	420	42	Tree related-tree broken	Overhead Transformer	Repair		V
131984712	S64501	07/17/2013	9:39	07/17/2013	10:06	1	27	27	Other	Meter	Reconnect		VI
131984729	K46388	07/17/2013	9:42	07/17/2013	10:08	7	182	26	Animal related	Fuse	Replace - Same Size		V
131984774	T06505	07/17/2013	9:56	07/17/2013	10:50	528	28512	54	Public	Recloser	Switch/Reset		VI
131984932	S53542	07/17/2013	10:16	07/17/2013	11:12	1	56	56	Other				VI
131985583	B80004	07/17/2013	10:29	07/17/2013	12:30	1	121	121	Underground equipment	Underground Primary	Switch/Reset		I
131985575	B80004	07/17/2013	10:29	07/17/2013	12:30	1	121	121	Underground equipment	Underground Primary	Switch/Reset		I
131985552	B80004	07/17/2013	10:29	07/17/2013	12:30	3	363	121	Underground equipment	Underground Primary	Switch/Reset		I
131985537	B80004	07/17/2013	10:29	07/17/2013	12:30	2	242	121	Underground equipment	Underground Primary	Switch/Reset		I
131985520	B80004	07/17/2013	10:29	07/17/2013	12:30	1	121	121	Underground equipment	Underground Primary	Switch/Reset		I
131985002	B80004	07/17/2013	10:29	07/17/2013	20:35	7	4242	606	Public	Underground Primary	Repair		I
131985022	B80003	07/17/2013	10:34	07/17/2013	12:30	26	3016	116	Underground equipment	Underground Primary	Switch/Reset		I
131985062	D72002	07/17/2013	10:45	07/17/2013	11:57	1	72	72	Overhead equipment	Overhead Service	Repair	Replace - Same Size	I
131985563	T16526	07/17/2013	12:44	07/17/2013	13:30	1	46	46	Animal related	Transformer Fuse	Replace - Same Size	Replace - Same Size	VI
131985585	S50541	07/17/2013	12:49	07/17/2013	13:14	1	25	25	Animal related	Transformer Fuse	Replace - Same Size	Replace - Same Size	VI
131985635	B76003	07/17/2013	12:59	07/17/2013	15:08	32	4128	129	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
131985676	R84148	07/17/2013	13:09	07/17/2013	14:30	1	81	81	Animal related	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	I
131985792	V46563	07/17/2013	13:25	07/17/2013	14:17	1	52	52	Overhead equipment	Connector	Repair		II
131985825	D87001	07/17/2013	13:30	07/17/2013	14:45	1	75	75	Overhead equipment	Jumper	Repair		I
131986009	N44215	07/17/2013	14:10	07/17/2013	15:03	9	477	53	Unknown	Fuse	Replace - Same Size		III
131986101	B77002	07/17/2013	14:28	07/17/2013	15:23	68	3740	55	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	I
131986088	Y37592	07/17/2013	14:29	07/17/2013	15:35	1	66	66	Overhead equipment	Overhead Service	Repair	Replace - Same Size	IV
131986153	307003	07/17/2013	14:40	07/17/2013	15:51	1	71	71	Overhead equipment	Overhead Service	Cut in Clear	Replace - New Size	VI
131986349	V76001	07/17/2013	15:15	07/17/2013	16:37	145	11890	82	Overhead equipment	Fuse	Replace - New Size		II
131986403	P69173	07/17/2013	15:32	07/17/2013	17:15	127	13081	103	Overhead equipment	Fuse	Replace - Same Size		III
131986406	J68402	07/17/2013	15:35	07/17/2013	16:00	2	50	25	Overhead equipment	Transformer Fuse	Replace - Same Size		III
131986575	P62113	07/17/2013	16:41	07/17/2013	19:36	8	1400	175	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	VI
131986602	V76001	07/17/2013	16:44	07/17/2013	17:32	145	6960	48	Overhead equipment	Fuse			II
131986620	B08003	07/17/2013	16:57	07/17/2013	18:28	1	91	91	Overhead equipment	Overhead Service	Repair		I
131986646	K48380	07/17/2013	17:06	07/17/2013	18:01	1	55	55	Overhead equipment	Fuse	Replace - Same Size		V
131986670	D69001	07/17/2013	17:14	07/17/2013	22:28	1	314	314	Underground equipment	Underground Transformer		Replace - Same Size	I
131986905	P82291	07/17/2013	17:20	07/17/2013	19:25	621	77625	125	Overhead equipment	Overhead Primary	Repair	Repair	VI
131986722	X73002	07/17/2013	17:25	07/17/2013	19:00	90	8550	95	Overhead equipment	Fuse	Repair		IV
131986709	S02502	07/17/2013	17:26	07/17/2013	22:00	1	274	274	Overhead equipment	Overhead Service	Patrol/Test/Inspect	Repair	VI
131986729	J15302	07/17/2013	17:31	07/17/2013	20:50	1	199	199	Tree related-tree contact	Other	Replace - Same Size	Replace - Same Size	I
131986735	Q74150	07/17/2013	17:33	07/17/2013	19:09	1	96	96	Tree related-tree contact	Overhead Service	Repair		IV
131986758	V82002	07/17/2013	17:43	07/17/2013	20:39	6	1056	176	Overhead equipment				II
131986812	J87119	07/17/2013	17:49	07/17/2013	19:23	92	8648	94	Overhead equipment	Fuse			VI
131986780	U84587	07/17/2013	17:56	07/17/2013	20:08	3	396	132	Other	Overhead Transformer	Replace - New Size		II

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
131986912	IP9009	07/17/2013	18:15	07/17/2013	18:38	11	253	23	Overhead equipment	Overhead Transformer	Switch/Reset		VI
131987432	U52516	07/17/2013	18:16	07/17/2013	20:11	584	67160	115	Overhead equipment	Disconnect Switch	Replace - Same Size		II
131986949	M48815	07/17/2013	18:29	07/17/2013	19:15	40	1840	46	Overhead equipment	Fuse	Repair	Repair	V
131987367	T06505	07/17/2013	18:39	07/17/2013	21:13	1	154	154	Overhead equipment	Disconnect Switch	Replace - Same Size		VI
131987424	A45001	07/17/2013	18:39	07/17/2013	21:44	17	3145	185	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Repair	I
131987374	N60181	07/17/2013	18:43	07/17/2013	19:53	1	70	70	Overhead equipment	Overhead Service	Repair		I
131986764	B80003	07/17/2013	18:56	07/18/2013	1:53	1	417	417	Overhead equipment	Overhead Transformer	Replace - Same Size	Repair	I
131987408	J88166	07/17/2013	19:06	07/17/2013	23:00	1	234	234	Overhead equipment	Overhead Transformer		Replace - Same Size	VI
131987409	R78301	07/17/2013	19:07	07/17/2013	23:25	7	1806	258	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	V
131987421	R10925	07/17/2013	19:11	07/17/2013	22:30	1	199	199	Overhead equipment	Disconnect Switch	Replace - New Size	Replace - Same Size	VI
131987520	A85001	07/17/2013	19:40	07/17/2013	21:41	27	3267	121	Overhead equipment	Fuse	Replace - Same Size		I
131987547	S15560	07/17/2013	20:25	07/17/2013	22:33	1	128	128	Overhead equipment	Overhead Service	Patrol/Test/Inspect	Repair	VI
131987563	J83138	07/17/2013	20:41	07/17/2013	21:35	23	1242	54	Overhead equipment	Fuse			VI
131987568	B28004	07/17/2013	20:48	07/18/2013	4:50	17	8194	482	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	I
131987615	Q68836	07/17/2013	21:44	07/17/2013	22:53	44	3036	69	Animal related	Fuse	Replace - Same Size	No Work Required	V
131987620	L00133	07/17/2013	21:50	07/17/2013	22:13	1	23	23	Animal related	Fuse	Replace - Same Size		III
131987625	D16003	07/17/2013	21:58	07/18/2013	0:23	19	2755	145	Overhead equipment	Overhead Transformer	Replace - Same Size	Repair	I
131987643	M81403	07/17/2013	22:25	07/18/2013	3:03	1	278	278	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	V
131987657	P69173	07/17/2013	23:27	07/18/2013	0:30	1	63	63	Overhead equipment	Overhead Secondary	Repair		III
131990088	X60597	07/18/2013	0:01	07/18/2013	2:00	6	714	119	Underground equipment	Underground Transformer	Replace - Same Size	Replace - Same Size	IV
131995113	C36001	07/18/2013	3:52	07/18/2013	13:14	3	1686	562	Underground equipment	Underground Primary	Repair		III
131995088	B38001	07/18/2013	4:15	07/18/2013	5:44	1	89	89	Overhead equipment	Overhead Transformer			I
131995103	U61001	07/18/2013	5:36	07/18/2013	8:50	14	2716	194	Overhead equipment	Overhead Transformer	Replace - Same Size		II
131995125	N70330	07/18/2013	6:11	07/18/2013	6:44	1	33	33	Animal related	Fuse	Replace - Same Size	Replace - Same Size	I
131995127	J87111	07/18/2013	6:12	07/18/2013	6:47	2	70	35	Animal related	Transformer Fuse			VI
131995165	N58144	07/18/2013	6:49	07/19/2013	13:47	1	1858	1858	Overhead equipment	Overhead Transformer	Replace - Same Size	Replace - Same Size	I
131995171	S88502	07/18/2013	6:52	07/18/2013	8:00	5	340	68	Animal related	Transformer Fuse	Replace - Same Size		VI
131995292	N67315	07/18/2013	7:42	07/18/2013	8:47	1	65	65	Overhead equipment			No Work Required	I
131995295	C37001	07/18/2013	7:43	07/18/2013	8:16	1	33	33	Overhead equipment	Fuse	Replace - Same Size	No Work Required	III
131995307	C37001	07/18/2013	7:48	07/18/2013	8:18	1	30	30	Overhead equipment	Fuse	Replace - Same Size	No Work Required	III
131995305	C37001	07/18/2013	7:48	07/18/2013	8:19	1	31	31	Overhead equipment	Fuse	Replace - Same Size	No Work Required	III
131995327	R48167	07/18/2013	7:54	07/18/2013	8:33	7	273	39	Animal related	Transformer Fuse			IV
131995364	M07236	07/18/2013	7:58	07/18/2013	8:30	10	320	32	Animal related	Transformer Fuse	Replace - Same Size		III
131995352	R48167	07/18/2013	8:00	07/18/2013	8:36	1	36	36	Animal related				IV
131995371	U31598	07/18/2013	8:05	07/18/2013	8:44	1	39	39	Animal related	Fuse	Replace - Same Size		II
131995372		07/18/2013	8:06	07/18/2013	10:02	1	116	116	Unknown	Transformer Fuse	Replace - Same Size		I
131995493	M49410	07/18/2013	8:33	07/18/2013	9:03	1	30	30	Public	Fuse	Switch/Reset		V
131995555	Q10702	07/18/2013	8:51	07/18/2013	10:26	1	95	95	Overhead equipment	Fuse	Patrol/Test/Inspect		V
131995576	HB6283	07/18/2013	8:57	07/19/2013	8:19	46	64492	1402	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	VI
131995726	R05115	07/18/2013	9:06	07/18/2013	9:55	19	931	49	Animal related	Overhead Transformer	Switch/Reset		I
131995644	R05115	07/18/2013	9:11	07/18/2013	9:56	12	540	45	Animal related	Overhead Transformer	Switch/Reset		I
131995670	M53308	07/18/2013	9:18	07/18/2013	11:16	1	118	118	Tree related-tree contact	Overhead Service	Patrol/Test/Inspect		V
131995971	P52306	07/18/2013	10:05	07/18/2013	10:42	6	222	37	Overhead equipment	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	IV
131996420	J84145	07/18/2013	10:16	07/18/2013	13:46	9	1890	210	Tree related-tree contact	Overhead Primary	Patrol/Test/Inspect	Repair	VI
131996069	J84145	07/18/2013	10:16	07/18/2013	12:04	52	5616	108	Tree related-tree contact	Overhead Primary			VI
131996327	R02649	07/18/2013	10:57	07/18/2013	11:48	3	153	51	Other	Ground Wire			VI
131996477	K01236	07/18/2013	11:41	07/18/2013	13:05	45	3780	84	Weather	Fuse	Replace - Same Size	Repair	VI
131996532	M45212	07/18/2013	12:02	07/18/2013	12:35	3	99	33	Animal related	Fuse	Replace - Same Size		IV
131996626	P52306	07/18/2013	12:29	07/18/2013	16:08	1	219	219	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	IV
131996635	K74164	07/18/2013	12:34	07/18/2013	12:42	13	104	8	Underground equipment	Underground Transformer	Patrol/Test/Inspect	Replace - Same Size	IV
131996693	Y32002	07/18/2013	12:46	07/18/2013	13:18	1	32	32	Tree related-tree broken	Overhead Service	Raise	Repair	IV
131996696	V82002	07/18/2013	12:47	07/18/2013	13:20	1	33	33	Overhead equipment	Overhead Service	Replace - Same Size		II
131996752	Q32171	07/18/2013	12:59	07/18/2013	14:34	1	95	95	Overhead equipment	Fuse	No Work Required	No Work Required	I
131996783	A56014	07/18/2013	13:08	07/18/2013	15:11	1	123	123	Overhead equipment	Connector	Repair	Replace - Same Size	I
131996883	X23516	07/18/2013	13:32	07/18/2013	14:30	3	174	58	Animal related	Disconnect Switch			IV
131997291	Y93005	07/18/2013	14:14	07/18/2013	15:40	87	7482	86	Substation equipment	Fuse	Replace - Same Size		IV

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
131997086	343001	07/18/2013	14:18	07/18/2013	15:30	1	72	72	Overhead equipment	Fuse	Repair	Replace - New Size	VI
131997151	A45002	07/18/2013	14:31	07/18/2013	16:00	1	89	89	Tree related-tree contact	Tree	Cut in Clear		I
131997356	Y55003	07/18/2013	15:13	07/18/2013	16:44	1	91	91	Overhead equipment	Overhead Secondary	Repair		IV
131997869	C15002	07/18/2013	15:21	07/18/2013	19:10	2	458	229	Underground equipment	Underground Primary	Repair		III
131997439	C15002	07/18/2013	15:21	07/18/2013	17:56	4	620	155	Underground equipment	Underground Transformer	Switch/Reset		III
131997436	R60551	07/18/2013	15:36	07/18/2013	17:30	1	114	114	Weather	Fuse	Replace - Same Size	No Work Required	IV
131997474	R61242	07/18/2013	15:44	07/18/2013	16:40	30	1680	56	Weather	Fuse	Replace - Same Size	No Work Required	IV
131997466	T08502	07/18/2013	15:45	07/18/2013	16:30	1	45	45	Animal related	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
131997544	B19002	07/18/2013	16:03	07/18/2013	22:02	1	359	359	Underground equipment	Underground Primary	Repair	Repair	I
131997545	V82002	07/18/2013	16:03	07/18/2013	17:04	2	122	61	Overhead equipment	Overhead Transformer	Replace - New Size		II
131997548	M31203	07/18/2013	16:04	07/18/2013	16:52	1	48	48	Animal related	Transformer Fuse	Replace - Same Size	Replace - Same Size	I
131997581	L50215	07/18/2013	16:04	07/18/2013	17:10	25	1650	66	Overhead equipment	Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
131997621	Q11516	07/18/2013	16:25	07/18/2013	18:35	1	130	130	Tree related-tree contact	Overhead Service	Repair	No Work Required	I
131997483	B73001	07/18/2013	16:40	07/18/2013	19:39	10	1790	179	Public	Pole	Replace - New Size	Repair	I
131997690	Y91500	07/18/2013	16:44	07/18/2013	17:50	6	396	66	Overhead equipment	Fuse	Replace - Same Size		IV
131997734	K71812	07/18/2013	17:00	07/18/2013	17:47	1	47	47	Overhead equipment	Transformer Fuse	Replace - Same Size	No Work Required	IV
131997791	D89001	07/18/2013	17:29	07/18/2013	20:00	35	5285	151	Overhead equipment	Overhead Primary	Patrol/Test/Inspect	Repair	I
131997751	A49003	07/18/2013	17:33	07/18/2013	23:46	1	373	373	Underground equipment	Underground Secondary	Patrol/Test/Inspect	Repair	I
131999031	C40001	07/18/2013	17:53	07/18/2013	21:40	114	25878	227	Underground equipment	Underground Primary	Switch/Reset	Repair	I
131998500	C40001	07/18/2013	17:53	07/18/2013	21:40	62	14074	227	Underground equipment	Underground Primary	Switch/Reset	Repair	I
131997835	Y31589	07/18/2013	18:01	07/18/2013	18:51	1	50	50	Overhead equipment	Overhead Service			IV
131997837	J75272	07/18/2013	18:05	07/18/2013	18:56	1	51	51	Overhead equipment	Jumper	Replace - Same Size	No Work Required	IV
131998465	P58159	07/18/2013	18:18	07/18/2013	20:25	1	127	127	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	VI
131997988	P58159	07/18/2013	18:18	07/18/2013	20:00	22	2244	102	Underground equipment				VI
131998440	329146	07/18/2013	18:32	07/18/2013	20:00	11	968	88	Tree related-tree broken	Overhead Primary	Repair		V
131998052	N54107	07/18/2013	18:39	07/18/2013	20:05	14	1204	86	Overhead equipment	Jumper	Repair		II
131998382	A85001	07/18/2013	19:07	07/18/2013	21:00	27	3051	113	Overhead equipment	Fuse	Replace - Same Size		I
131998441	S09520	07/18/2013	19:34	07/18/2013	20:26	1	52	52	Overhead equipment	Jumper	Repair		VI
131998482	Q21293	07/18/2013	20:16	07/18/2013	21:49	1	93	93	Overhead equipment	Overhead Transformer	Repair		VI
131999051	B44001	07/18/2013	21:55	07/18/2013	22:04	1	9	9	Overhead equipment	Connector	Replace - Same Size		I
132000125	D28123	07/18/2013	22:46	07/19/2013	1:05	187	25993	139	Underground equipment	Underground Primary	Switch/Reset		I
132005620	D28123	07/18/2013	22:48	07/19/2013	6:39	2	942	471	Underground equipment	Underground Primary	Repair		I
132000141	D28123	07/18/2013	22:48	07/19/2013	2:49	6	1446	241	Underground equipment	Underground Primary	Repair	Repair	I
132000099	C66001	07/19/2013	0:01	07/19/2013	3:15	36	6984	194	Tree related-tree broken	Overhead Primary	Repair	No Work Required	III
132000098	A81001	07/19/2013	0:04	07/19/2013	1:44	16	1600	100	Overhead equipment	Fuse	Replace - Same Size		I
132000183	B73002	07/19/2013	0:36	07/19/2013	6:51	14	5250	375	Public	Pole	Replace - Urgent	Repair	I
132000117	B73002	07/19/2013	0:36	07/19/2013	1:53	911	70147	77	Public	Pole			I
132000124	X24536	07/19/2013	0:38	07/19/2013	2:15	1	97	97	Public	Underground Primary	Tie/Tighten	No Work Required	IV
132000139	L73160	07/19/2013	1:17	07/19/2013	2:55	49	4802	98	Overhead equipment	Fuse	Replace - New Size		IV
132000146	L73160	07/19/2013	1:42	07/19/2013	2:55	1	73	73	Overhead equipment				IV
132007577	J97136	07/19/2013	3:50	07/19/2013	14:46	57	37392	656	Overhead equipment	Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
132005761	K36252	07/19/2013	6:04	07/19/2013	13:08	46	19504	424	Public	Overhead Primary	Repair		III
132005634	J74125	07/19/2013	6:19	07/19/2013	7:21	2	124	62	Tree related-tree broken	Overhead Service	Repair	Repair	VI
132005651	D92001	07/19/2013	6:40	07/19/2013	15:07	53	26871	507	Underground equipment	Underground Primary	Switch/Reset	Repair	I
132005679	S55534	07/19/2013	7:04	07/19/2013	8:40	1	96	96	Overhead equipment	Overhead Service			VI
132005814	K89143	07/19/2013	7:09	07/19/2013	9:36	31	4557	147	Animal related	Overhead Primary	Repair		III
132005776	M47802	07/19/2013	7:30	07/19/2013	7:56	24	624	26	Animal related	Fuse	Replace - Same Size		V
132005817	S79510	07/19/2013	7:44	07/19/2013	9:53	1	129	129	Overhead equipment	Transformer Fuse	Repair	Replace - Same Size	VI
132005845	N58144	07/19/2013	7:54	07/19/2013	9:30	6	576	96	Animal related	Transformer Fuse	Replace - Same Size		I
132005962	Q91175	07/19/2013	8:28	07/19/2013	9:17	1	49	49	Overhead equipment	Transformer Fuse	Replace - Same Size		I
132005988	Q32171	07/19/2013	8:36	07/19/2013	13:23	1	287	287	Tree related-tree broken	Overhead Primary	Repair	Repair	I
132006009	S19552	07/19/2013	8:50	07/19/2013	13:13	5	1315	263	Underground equipment	Underground Primary		Repair	VI
132006039	S22595	07/19/2013	8:51	07/19/2013	9:10	1	19	19	Animal related	Transformer Fuse			VI
132006246	S63292	07/19/2013	9:05	07/19/2013	9:21	2499	39984	16	Public				VI
132006153	Z04520	07/19/2013	9:13	07/19/2013	10:07	1	54	54	Unknown	Transformer Fuse	Replace - Same Size		IV
132006374	S64501	07/19/2013	9:29	07/19/2013	9:51	1	22	22	Transmission outage				VI

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
132006412	K89143	07/19/2013	9:37	07/19/2013	9:46	2	18	9	Animal related	Overhead Primary	Repair		III
132006559	K89143	07/19/2013	10:07	07/19/2013	10:16	1	9	9	Overhead equipment				III
132006637	310123	07/19/2013	10:27	07/19/2013	12:16	4	436	109	Tree related-tree broken	Overhead Service	Repair		V
132006654	X49569	07/19/2013	10:30	07/19/2013	12:05	1	95	95	Animal related	Jumper	Repair		IV
132006737	347001	07/19/2013	10:50	07/19/2013	11:54	4	256	64	Animal related	Transformer Fuse	Replace - Same Size		VI
132006944		07/19/2013	11:23	07/19/2013	12:10	1172	55084	47	Substation equipment				III
132007168	C70001	07/19/2013	12:25	07/19/2013	16:41	1	256	256	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	III
132007229	A80002	07/19/2013	12:39	07/19/2013	18:08	1	329	329	Underground equipment	Underground Primary	Replace - Same Size	Replace - Same Size	I
132007290	U05595	07/19/2013	12:53	07/19/2013	15:21	1	148	148	Overhead equipment	Overhead Service	Raise		II
132007323	K27150	07/19/2013	12:58	07/19/2013	14:30	3	276	92	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	VI
132007463	K05253	07/19/2013	13:27	07/19/2013	14:43	1	76	76	Overhead equipment	Connector	Repair		VI
132007644	Q36412	07/19/2013	14:08	07/19/2013	14:41	1	33	33	Public	Fuse	Replace - Same Size		I
132007741	U90566	07/19/2013	14:31	07/19/2013	15:38	1	67	67	Overhead equipment	Transformer Fuse	Repair	Repair	II
132007777	Q32171	07/19/2013	14:40	07/19/2013	14:56	1	16	16	Overhead equipment	Pole	Patrol/Test/Inspect		I
132007792	Q11517	07/19/2013	14:44	07/19/2013	17:07	1	143	143	Other	Meter	Replace - Same Size		I
132007798	Q32171	07/19/2013	14:46	07/19/2013	15:06	1	20	20	Weather	Transformer Fuse	Patrol/Test/Inspect	Repair	I
132007869		07/19/2013	15:18	07/19/2013	15:45	1	27	27	Weather	Transformer Fuse	Replace - Same Size		IV
132007884	M53308	07/19/2013	15:23	07/19/2013	18:45	4	808	202	Jurisdictional	Transformer Fuse	Replace - Same Size	Repair	V
132008100	P14392	07/19/2013	15:24	07/19/2013	18:55	1	211	211	Overhead equipment	Overhead Primary	Cut in Clear		V
132007913	V24583	07/19/2013	15:32	07/19/2013	17:09	1	97	97	Underground equipment	Underground Service	Replace - Same Size		II
132008250	Q80353	07/19/2013	15:42	07/19/2013	22:53	6	2586	431	Underground equipment	Underground Transformer	Replace - Same Size	Replace - Same Size	V
132007961	Q80353	07/19/2013	15:43	07/19/2013	18:30	32	5344	167	Underground equipment	Underground Transformer			V
132007963	R78300	07/19/2013	15:50	07/19/2013	19:10	1	200	200	Jurisdictional	High Line Switch	Patrol/Test/Inspect		V
132008023	V49541	07/19/2013	16:20	07/19/2013	19:53	1	213	213	Underground equipment	Underground Primary	Repair	Repair	II
132008027	D69006	07/19/2013	16:21	07/19/2013	18:09	1	108	108	Tree related-tree broken	Overhead Service			I
132008053	N91255	07/19/2013	16:32	07/19/2013	18:05	9	837	93	Overhead equipment	Overhead Secondary	Repair		III
132008061	M51275	07/19/2013	16:36	07/19/2013	19:45	1	189	189	Tree related-tree broken	Overhead Service	Repair		III
132008070	T01534	07/19/2013	16:39	07/19/2013	18:25	1	106	106	Overhead equipment	Overhead Service	Patrol/Test/Inspect	Repair	VI
132008073	L73156	07/19/2013	16:40	07/19/2013	16:45	9	45	5	Overhead equipment	Overhead Transformer	Replace - New Size		IV
132008082	S53543	07/19/2013	16:47	07/19/2013	18:00	1	73	73	Overhead equipment	Overhead Service	Tie/Tighten		VI
132008106	K01240	07/19/2013	16:54	07/19/2013	18:10	26	1976	76	Underground equipment	Underground Primary	Replace - Same Size		VI
132008142	U11531	07/19/2013	17:10	07/19/2013	19:40	1	150	150	Overhead equipment	Overhead Transformer	Repair	Repair	II
132008218	X73002	07/19/2013	18:08	07/19/2013	19:20	163	11736	72	Overhead equipment	Fuse	Repair		IV
132008242	P52305	07/19/2013	18:33	07/19/2013	19:45	1	72	72	Overhead equipment	Transformer Fuse	Replace - Same Size	No Work Required	IV
132008304	D48001	07/19/2013	19:21	07/19/2013	20:00	1	39	39	Animal related	Transformer Fuse	Replace - Same Size		I
132008458	N54213	07/19/2013	19:29	07/20/2013	0:49	11	3520	320	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	II
132008583	L11242	07/19/2013	19:38	07/19/2013	20:44	1	66	66	Tree related-tree contact	Overhead Service	Repair		III
132009022	X77001	07/19/2013	20:35	07/19/2013	21:33	6	348	58	Tree related-tree broken	Overhead Secondary	Repair	Patrol/Test/Inspect	IV
132009110	V10551	07/19/2013	21:18	07/19/2013	23:10	1	112	112	Overhead equipment	Connector	Repair		II
132009152	K52400	07/19/2013	22:45	07/20/2013	2:00	30	5850	195	Underground equipment	Underground Primary	Repair	Repair	V
132009159	D92002	07/19/2013	22:54	07/19/2013	23:52	42	2436	58	Tree related-tree broken	Fuse	Replace - Same Size		I
132010020	K82202	07/20/2013	0:25	07/20/2013	5:48	35	11305	323	Public	Overhead Primary	Raise		III
132010045	K15207	07/20/2013	2:22	07/20/2013	6:36	1	254	254	Underground equipment	Underground Secondary		Replace - Same Size	VI
132010050	K65221	07/20/2013	2:30	07/20/2013	4:53	84	12012	143	Overhead equipment	Fuse	Replace - Same Size		III
132010140	Q95248	07/20/2013	2:55	07/20/2013	11:02	4	1948	487	Underground equipment	Underground Primary		Repair	VI
132010076	Q95248	07/20/2013	2:55	07/20/2013	6:40	8	1800	225	Underground equipment	Underground Primary		Replace - Same Size	VI
132010052	Z06537	07/20/2013	2:56	07/20/2013	4:54	1	118	118	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
132010077	N35851	07/20/2013	4:26	07/20/2013	5:58	1	92	92	Tree related-tree broken	Overhead Service	Cut in Clear	Cut in Clear	V
132010081	M73330	07/20/2013	5:34	07/20/2013	8:38	1	184	184	Tree related-tree contact	Overhead Secondary	Repair		V
132010096	U97520	07/20/2013	6:30	07/20/2013	7:15	1	45	45	Overhead equipment	Transformer Fuse	Replace - Same Size		II
132010107	M07235	07/20/2013	6:38	07/20/2013	7:40	1	62	62	Overhead equipment	Transformer Fuse	Replace - Same Size		III
132010171	K76542	07/20/2013	7:01	07/20/2013	8:08	24	1608	67	Animal related	Transformer Fuse	Replace - Same Size	No Work Required	IV
132010158	A26006	07/20/2013	7:38	07/20/2013	9:18	112	11200	100	Public	Fuse	Replace - Same Size		I
132010169	R73841	07/20/2013	8:02	07/20/2013	11:12	4	760	190	Overhead equipment	Overhead Transformer	Replace - Same Size	Replace - Same Size	V
132010174	L79159	07/20/2013	8:06	07/20/2013	12:02	1	236	236	Tree related-tree broken	Overhead Service	Patrol/Test/Inspect	Repair	IV
132010180	U27001	07/20/2013	8:13	07/20/2013	9:26	1	73	73	Overhead equipment	Transformer Fuse	Replace - Same Size	Patrol/Test/Inspect	II

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
132010182	Q32171	07/20/2013	8:16	07/20/2013	11:00	1	164	164	Overhead equipment	Transformer Fuse	Replace - Same Size		I
132010187	H00163	07/20/2013	8:25	07/20/2013	10:28	1	123	123	Animal related				III
132010355	S47576	07/20/2013	9:25	07/20/2013	15:41	691	259816	376	Underground equipment	Underground Primary	Repair		VI
132010525	F03003	07/20/2013	9:29	07/20/2013	13:27	1	238	238	Underground equipment	Underground Primary	Repair		III
132010322	F03003	07/20/2013	9:29	07/20/2013	11:12	9	927	103	Underground equipment	Underground Primary	Switch/Reset		III
132010307	L81141	07/20/2013	9:35	07/20/2013	11:36	1	121	121	Overhead equipment	Transformer Fuse	Replace - Same Size	No Work Required	IV
132010335	M37191	07/20/2013	9:47	07/20/2013	12:19	1	152	152	Animal related	Transformer Fuse	Replace - Same Size		I
132010336	U64518	07/20/2013	9:47	07/20/2013	11:15	1	88	88	Animal related	Fuse	Replace - Same Size		II
132010381	R49275	07/20/2013	10:16	07/20/2013	14:03	1	227	227	Overhead equipment	Overhead Transformer		Replace - Same Size	VI
132010397	A48005	07/20/2013	10:29	07/20/2013	12:14	2	210	105	Tree related-tree contact	Fuse	Replace - Same Size		I
132010435	J18268	07/20/2013	10:56	07/20/2013	12:53	17	1989	117	Animal related	Fuse		Patrol/Test/Inspect	VI
132010443	X77543	07/20/2013	11:13	07/20/2013	12:43	1	90	90	Tree related-tree contact	Tree	Trim		IV
132010453	U68581	07/20/2013	11:37	07/20/2013	13:25	4	432	108	Animal related	Transformer Fuse	Repair	Repair	II
132010564	K58213	07/20/2013	12:25	07/20/2013	14:07	6	612	102	Animal related	Fuse			VI
132010541	U30006	07/20/2013	13:13	07/20/2013	14:01	9	432	48	Overhead equipment	Transformer Fuse	Repair	Repair	II
132010581	Y39521	07/20/2013	13:56	07/20/2013	15:00	2	128	64	Animal related	Animal Guard	Install		IV
132011124	X31731	07/20/2013	14:00	07/20/2013	16:45	2234	368610	165	Jurisdictional				IV
132010590	V92543	07/20/2013	14:01	07/20/2013	14:55	1	54	54	Overhead equipment	Transformer Fuse	Replace - Same Size	Patrol/Test/Inspect	II
132011307	Y11556	07/20/2013	14:01	07/20/2013	17:30	420	87780	209	Tree related-tree contact	Substation Breaker			IV
132011850	Y11556	07/20/2013	14:09	07/20/2013	20:55	210	85260	406	Tree related-tree broken	Tree	Remove		IV
132010767	Y13042	07/20/2013	14:21	07/20/2013	18:08	8	1816	227	Tree related-tree broken	Overhead Service	Raise		IV
132011140	Y08552	07/20/2013	14:24	07/20/2013	18:50	13	3458	266	Weather	Fuse	Replace - Same Size		IV
132011064	Y12560	07/20/2013	14:27	07/20/2013	17:20	28	4844	173	Tree related-tree broken	Tree			IV
132010807	Y11556	07/20/2013	14:29	07/20/2013	18:40	1	251	251	Tree related-tree broken	Overhead Service	Cut in Clear		IV
132010810	Q64918	07/20/2013	14:29	07/20/2013	16:15	1	106	106	Overhead equipment	Other	Replace - Same Size		VI
132010840	Y11556	07/20/2013	14:34	07/20/2013	18:48	1	254	254	Tree related-tree broken	Overhead Service	Cut in Clear	Advise Customer	IV
132011415	Y12560	07/20/2013	14:40	07/20/2013	18:15	5	1075	215	Tree related-tree broken	Overhead Primary		Repair	IV
132011014	P62138	07/20/2013	14:45	07/20/2013	19:29	879	249636	284	Tree related-tree broken	Overhead Primary			VI
132011020	P62138	07/20/2013	14:47	07/20/2013	16:20	670	62310	93	Tree related-tree broken	Overhead Primary			VI
132011009	X86546	07/20/2013	15:03	07/20/2013	19:50	40	11480	287	Overhead equipment	Crossarm	Replace - Same Size	Replace - Same Size	IV
132010987	Y34596	07/20/2013	15:04	07/20/2013	16:50	1	106	106	Overhead equipment	Connector	Repair	No Work Required	IV
132011172	Z19547	07/20/2013	15:05	07/20/2013	17:20	4	540	135	Weather	Fuse	Replace - Same Size	No Work Required	IV
132011021	Y61003	07/20/2013	15:14	07/20/2013	18:00	4	664	166	Tree related-tree broken	Overhead Secondary			IV
132011035	Y61007	07/20/2013	15:21	07/20/2013	17:33	1	132	132	Overhead equipment	Connector	Repair	No Work Required	IV
132011062	Q82907	07/20/2013	15:35	07/20/2013	17:55	1	140	140	Weather	Lightning Arrestor	Replace - Same Size	Patrol/Test/Inspect	VI
132011103	Y66557	07/20/2013	15:41	07/20/2013	17:05	16	1344	84	Overhead equipment	Transformer Fuse			IV
132011114		07/20/2013	15:47	07/20/2013	16:50	1	63	63	Tree related-tree broken	Fuse	Replace - Same Size		IV
132011126	311001	07/20/2013	15:52	07/20/2013	16:41	1	49	49	Jurisdictional	Other	Patrol/Test/Inspect		VI
132011128	Y36541	07/20/2013	15:53	07/20/2013	16:50	1	57	57	Tree related-tree broken	Fuse	Replace - Same Size		IV
132011265	Q16867	07/20/2013	16:10	07/20/2013	18:45	7	1085	155	Weather	Fuse	Replace - Same Size		V
132011158	J14140	07/20/2013	16:10	07/20/2013	21:24	49	15386	314	Weather	Fuse		Replace - Same Size	VI
132011156	R73840	07/20/2013	16:11	07/20/2013	18:46	77	11935	155	Weather	Fuse	Replace - Same Size		V
132011152	343001	07/20/2013	16:12	07/20/2013	17:48	1	96	96	Other	Fuse	Replace - Same Size		VI
132011163	308003	07/20/2013	16:18	07/20/2013	18:40	2	284	142	Tree related-tree contact	Tree	Trim		VI
132011208	N42856	07/20/2013	16:25	07/20/2013	21:59	94	31396	334	Tree related-tree broken	Tree	Patrol/Test/Inspect	Remove	V
132011196	P71830	07/20/2013	16:36	07/20/2013	19:09	1	153	153	Overhead equipment	Pole	Patrol/Test/Inspect	Replace - New Size	V
132011207	X69554	07/20/2013	16:39	07/20/2013	18:31	4	448	112	Weather	Fuse	Repair		IV
132011218	X69555	07/20/2013	16:45	07/20/2013	18:30	1	105	105	Tree related-tree broken	Fuse	Replace - Same Size		IV
132011225	U33586	07/20/2013	16:49	07/20/2013	17:33	1	44	44	Overhead equipment				II
132011226	R41131	07/20/2013	16:50	07/20/2013	17:45	1	55	55	Weather	Pole	Patrol/Test/Inspect	No Work Required	VI
132011240	N44217	07/20/2013	16:56	07/20/2013	18:30	39	3666	94	Overhead equipment	Fuse	Replace - Same Size		III
132011261	X69554	07/20/2013	17:00	07/20/2013	18:05	48	3120	65	Tree related-tree broken	Fuse	Repair		IV
132011250	K26136	07/20/2013	17:01	07/21/2013	0:22	27	11907	441	Tree related-tree broken	Overhead Primary	Patrol/Test/Inspect	Repair	VI
132011243	X69555	07/20/2013	17:02	07/20/2013	18:30	1	88	88	Tree related-tree broken	Fuse	Replace - Same Size		IV
132011245	Q82906	07/20/2013	17:03	07/20/2013	20:49	1	226	226	Weather	Overhead Transformer	Replace - Same Size	Repair	VI
132011249	N42856	07/20/2013	17:04	07/20/2013	23:30	1	386	386	Tree related-tree broken	Tree	Patrol/Test/Inspect	Remove	V

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
132011257	J14140	07/20/2013	17:07	07/20/2013	18:25	1	78	78	Weather	Fuse	Replace - Same Size		VI
132011271	R41131	07/20/2013	17:11	07/20/2013	18:45	1	94	94	Weather	Disconnect Switch	Replace - Same Size	No Work Required	VI
132011726	K27153	07/20/2013	17:12	07/21/2013	2:10	1	538	538	Weather				VI
132011474	R41131	07/20/2013	17:13	07/20/2013	18:55	182	18564	102	Overhead equipment	Overhead Primary			VI
132011303	R41131	07/20/2013	17:14	07/20/2013	19:15	174	21054	121	Weather				VI
132011277	Q16867	07/20/2013	17:15	07/20/2013	18:54	1	99	99	Weather	Fuse	Replace - Same Size		V
132011278	P62113	07/20/2013	17:15	07/20/2013	17:55	4	160	40	Weather	Fuse	Repair	Replace - Same Size	VI
132011287	Y39521	07/20/2013	17:17	07/20/2013	22:55	1	338	338	Underground equipment	Underground Primary	Repair		IV
132011291	P20930	07/20/2013	17:17	07/20/2013	21:53	8	2208	276	Weather	Overhead Primary		Repair	VI
132011323	Q67938	07/20/2013	17:27	07/20/2013	18:10	39	1677	43	Weather	Recloser	Replace - Same Size		VI
132011314	R41131	07/20/2013	17:28	07/20/2013	18:45	1	77	77	Weather	Disconnect Switch	Replace - Same Size	No Work Required	VI
132011345	P57104	07/20/2013	17:30	07/20/2013	20:20	349	59330	170	Overhead equipment	Lightning Arrestor			VI
132011321	P62138	07/20/2013	17:32	07/20/2013	21:20	1	228	228	Unknown				VI
132011325	Y11556	07/20/2013	17:33	07/20/2013	19:48	1	135	135	Overhead equipment	Overhead Service			IV
132011328	R39934	07/20/2013	17:33	07/20/2013	23:33	1	360	360	Weather	Fuse	Replace - Same Size	Patrol/Test/Inspect	VI
132011408	Y11556	07/20/2013	17:35	07/20/2013	19:30	2	230	115	Tree related-tree broken	Overhead Service	Repair	Replace - Same Size	IV
132011396	Y11556	07/20/2013	17:36	07/20/2013	17:54	210	3780	18	Tree related-tree broken	Tree			IV
132011399	Y11556	07/20/2013	17:44	07/20/2013	19:30	73	7738	106	Tree related-tree broken	Overhead Primary		Repair	IV
132011366	R50910	07/20/2013	17:45	07/20/2013	19:12	1	87	87	Overhead equipment	Fuse	Replace - Same Size	Repair	I
132011368	N90246	07/20/2013	17:46	07/20/2013	20:15	1	149	149	Tree related-tree contact	Overhead Service			III
132011416	Y11556	07/20/2013	18:02	07/20/2013	19:54	1	112	112	Tree related-tree broken	Overhead Service	Repair	Replace - Same Size	IV
132011418	P62138	07/20/2013	18:04	07/20/2013	20:57	1	173	173	Weather	Fuse	Repair	Replace - Same Size	VI
132011432	L95209	07/20/2013	18:09	07/20/2013	20:01	20	2240	112	Other	Fuse	Replace - Same Size		III
132011430	T15570	07/20/2013	18:10	07/21/2013	1:22	7	3024	432	Overhead equipment	Overhead Transformer			VI
132011437	S03525	07/20/2013	18:11	07/20/2013	20:48	1	157	157	Tree related-tree broken	Overhead Service			VI
132011447	J87120	07/20/2013	18:16	07/21/2013	0:46	1	390	390	Tree related-tree broken	Overhead Secondary	Replace - Same Size		VI
132011451	N50334	07/20/2013	18:18	07/20/2013	23:15	1	297	297	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	II
132011449	J30203	07/20/2013	18:18	07/20/2013	20:05	1	107	107	Weather	Fuse	Replace - Same Size	Patrol/Test/Inspect	VI
132011677	R23313	07/20/2013	18:20	07/20/2013	19:20	2308	138480	60	Unknown				V
132011272	IP9009	07/20/2013	18:30	07/20/2013	19:20	273	13650	50	Tree related-tree broken	Overhead Primary	Repair	Repair	VI
132011747	L59929	07/20/2013	18:30	07/20/2013	20:20	12	1320	110	Weather	Fuse	Replace - Same Size	Patrol/Test/Inspect	VI
132011729	IP9009	07/20/2013	18:34	07/20/2013	19:20	1	46	46	Weather	Overhead Primary			VI
132011592	K46388	07/20/2013	18:38	07/20/2013	19:57	1	79	79	Overhead equipment				V
132011599	L59933	07/20/2013	18:39	07/21/2013	2:22	1	463	463	Weather	Lightning Arrestor	Replace - Same Size	Patrol/Test/Inspect	VI
132011864	P82290	07/20/2013	18:43	07/20/2013	22:17	4	856	214	Weather	Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
132011707	L59933	07/20/2013	18:50	07/20/2013	21:37	17	2839	167	Weather	Fuse		Patrol/Test/Inspect	VI
132011651	K57211	07/20/2013	18:51	07/20/2013	20:47	19	2204	116	Tree related-tree broken	Overhead Primary	Patrol/Test/Inspect	Repair	VI
132011654	R73840	07/20/2013	18:58	07/20/2013	19:35	1	37	37	Weather	Overhead Transformer	Patrol/Test/Inspect	Patrol/Test/Inspect	V
132011656	K57211	07/20/2013	19:00	07/20/2013	20:56	1	116	116	Tree related-tree broken				VI
132011676	R49275	07/20/2013	19:02	07/20/2013	21:00	31	3658	118	Weather	Fuse	Replace - Same Size	Patrol/Test/Inspect	VI
132011664	A24004	07/20/2013	19:03	07/20/2013	19:58	1	55	55	Overhead equipment	Connector	Replace - Same Size		I
132011666		07/20/2013	19:03	07/20/2013	19:20	1	17	17	Overhead equipment				VI
132011681	Q95248	07/20/2013	19:15	07/20/2013	21:45	1	150	150	Weather				VI
132011052	Q83148	07/20/2013	19:18	07/20/2013	20:50	1	92	92	Tree related-tree broken	Overhead Service	Patrol/Test/Inspect	Repair	VI
132011687	S41565	07/20/2013	19:20	07/20/2013	22:50	1	210	210	Tree related-tree broken	Overhead Service			VI
132011874	R41131	07/20/2013	19:22	07/20/2013	23:54	182	49504	272	Overhead equipment	Overhead Primary			VI
132011876	R41131	07/20/2013	19:23	07/20/2013	21:49	121	17666	146	Overhead equipment	Overhead Primary			VI
132011705	E10003	07/20/2013	19:31	07/21/2013	3:52	1	501	501	Underground equipment	Underground Primary			III
132011708	P62138	07/20/2013	19:32	07/20/2013	22:00	1	148	148	Unknown				VI
132011754	R41131	07/20/2013	19:41	07/20/2013	21:15	7	658	94	Overhead equipment	Overhead Primary			VI
132011735	M54317	07/20/2013	19:47	07/20/2013	21:40	1	113	113	Tree related-tree broken	Tree	Patrol/Test/Inspect		V
132011738	M54317	07/20/2013	19:50	07/20/2013	21:42	5	560	112	Tree related-tree broken				V
132011741	X69555	07/20/2013	19:51	07/20/2013	21:34	4	412	103	Overhead equipment	Overhead Primary	Cut in Clear	Repair	IV
132011749	S09520	07/20/2013	20:11	07/20/2013	22:23	1	132	132	Tree related-tree broken	Overhead Service	Replace - New Size		VI
132011840	B93003	07/20/2013	20:39	07/21/2013	0:01	1	202	202	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
132011985	S25552	07/20/2013	20:46	07/20/2013	23:35	3	507	169	Weather	Overhead Transformer			VI

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
132011861	S86582	07/20/2013	20:57	07/21/2013	3:49	1	412	412	Overhead equipment	Overhead Transformer	Replace - Same Size	Replace - Same Size	VI
132011760	P57104	07/20/2013	21:09	07/20/2013	23:28	1	139	139	Weather				VI
132011891	T12528	07/20/2013	21:15	07/21/2013	5:40	1	505	505	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect		VI
132011943	G30001	07/20/2013	22:20	07/21/2013	0:11	2	222	111	Overhead equipment	Transformer Fuse	Replace - Same Size	No Work Required	III
132011969	P57102	07/20/2013	22:51	07/21/2013	0:07	1	76	76	Unknown	Meter	Patrol/Test/Inspect	No Work Required	VI
132011970	HB6281	07/20/2013	22:54	07/21/2013	2:44	1	230	230	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	VI
132011983	343001	07/20/2013	23:29	07/21/2013	0:55	1	86	86	Overhead equipment	Transformer Fuse	Replace - Same Size		VI
132020014	D67001	07/21/2013	0:43	07/21/2013	6:30	10	3470	347	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	IV
132020023	V40556	07/21/2013	1:46	07/21/2013	6:11	14	3710	265	Underground equipment	Underground Primary			II
132020039	B19002	07/21/2013	2:04	07/21/2013	3:49	21	2205	105	Overhead equipment	Disconnect Switch			I
132020035	V33006	07/21/2013	2:26	07/21/2013	4:26	66	7920	120	Overhead equipment	Overhead Primary	Replace - Same Size		II
132020036	P57108	07/21/2013	2:42	07/21/2013	3:54	1	72	72	Weather	Fuse	Repair	Repair	VI
132020052	A17025	07/21/2013	3:26	07/21/2013	8:10	2	568	284	Underground equipment	Fuse		Repair	I
132020048	R02121	07/21/2013	4:13	07/21/2013	5:05	1	52	52	Weather	Transformer Fuse	Replace - Same Size	No Work Required	VI
132020061	J71128	07/21/2013	4:23	07/21/2013	7:25	18	3276	182	Underground equipment	Underground Primary	Switch/Reset	Repair	I
132020055	K74166	07/21/2013	4:36	07/21/2013	7:30	43	7482	174	Underground equipment	Underground Primary	Patrol/Test/Inspect	Switch/Reset	IV
132020066	X02546	07/21/2013	5:29	07/21/2013	7:10	1	101	101	Tree related-tree broken	Overhead Service	Repair		IV
132020078	K79212	07/21/2013	6:29	07/21/2013	8:30	1	121	121	Tree related-tree broken	Overhead Service	Patrol/Test/Inspect	Repair	IV
132020080	P57108	07/21/2013	6:40	07/21/2013	7:58	1	78	78	Weather	Fuse	Repair	Replace - Same Size	VI
132020084	Z10501	07/21/2013	6:44	07/21/2013	7:45	8	488	61	Overhead equipment	Fuse	Replace - Same Size		IV
132020093	S22594	07/21/2013	7:07	07/21/2013	8:50	3	309	103	Other	Disconnect Switch	Replace - Same Size	Replace - Same Size	VI
132020109	K89143	07/21/2013	7:15	07/21/2013	8:30	8	600	75	Unknown	Fuse	Replace - Same Size		III
132020098	L79159	07/21/2013	7:16	07/21/2013	8:04	1	48	48	Animal related	Transformer Fuse	Replace - Same Size	No Work Required	IV
132020106	P20913	07/21/2013	7:22	07/21/2013	9:41	44	6116	139	Animal related	Fuse	Replace - Same Size	Patrol/Test/Inspect	VI
132020110	HB6283	07/21/2013	7:37	07/21/2013	9:09	1	92	92	Weather	Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
132020111	S64501	07/21/2013	7:38	07/21/2013	12:18	1	280	280	Underground equipment	Underground Primary	Repair	Patrol/Test/Inspect	VI
132020117	D67002	07/21/2013	7:53	07/21/2013	9:20	1	87	87	Overhead equipment	Other	Replace - Same Size		IV
132020119	B00002	07/21/2013	7:58	07/21/2013	9:39	1	101	101	Tree related-tree broken	Overhead Service	Replace - Same Size		I
132020132	Q28141	07/21/2013	8:32	07/21/2013	9:55	1	83	83	Animal related	Fuse	Replace - Same Size		VI
132020228	N05173	07/21/2013	9:01	07/21/2013	17:44	12	6276	523	Underground equipment	Underground Primary	Repair		I
132020156	S01521	07/21/2013	9:19	07/21/2013	11:00	4	404	101	Unknown	Transformer Fuse			VI
132020160	K32915	07/21/2013	9:31	07/21/2013	10:30	1	59	59	Animal related	Fuse	Replace - Same Size		VI
132020178	N05173	07/21/2013	10:03	07/21/2013	12:35	41	6232	152	Overhead equipment	Disconnect Switch	Replace - Same Size	Repair	I
132020180	L93135	07/21/2013	10:07	07/21/2013	11:13	1	66	66	Animal related	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
132020186	L93132	07/21/2013	10:13	07/21/2013	11:00	23	1081	47	Animal related	Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
132020210	J15303	07/21/2013	11:07	07/21/2013	12:22	1	75	75	Animal related	Fuse	Replace - Same Size		I
132020220	X96543	07/21/2013	11:29	07/21/2013	16:25	1	296	296	Weather	Overhead Transformer		Replace - Same Size	IV
132020225	X69555	07/21/2013	11:42	07/21/2013	14:10	1	148	148	Overhead equipment	Overhead Transformer	Replace - Same Size	Replace - Same Size	IV
132020232	B62004	07/21/2013	11:50	07/21/2013	12:55	1	65	65	Animal related	Fuse	Replace - Same Size		I
132020353	Y96564	07/21/2013	14:13	07/21/2013	18:05	8	1856	232	Underground equipment	Underground Primary	Repair	Replace - Same Size	IV
132020354	V49541	07/21/2013	14:18	07/21/2013	15:21	1	63	63	Unknown				II
132020393	N14879	07/21/2013	14:39	07/21/2013	18:30	6	1386	231	Underground equipment	Underground Primary			V
132020372	N14879	07/21/2013	14:39	07/21/2013	15:40	9	549	61	Public	Underground Primary	Switch/Reset	Repair	V
132020382	Q32171	07/21/2013	15:27	07/21/2013	18:00	1	153	153	Tree related-tree contact	Fuse	Replace - Same Size		I
132020404	B08002	07/21/2013	16:14	07/21/2013	17:02	1	48	48	Tree related-tree broken	Overhead Service	Repair		I
132020416	X02547	07/21/2013	16:54	07/21/2013	18:25	1	91	91	Weather	Fuse	Replace - Same Size		IV
132020428	D96002	07/21/2013	17:16	07/21/2013	18:30	1	74	74	Overhead equipment	Fuse	Repair		I
132020429	P20930	07/21/2013	17:16	07/21/2013	20:25	1	189	189	Overhead equipment	Overhead Service	Repair		VI
132020432	L63936	07/21/2013	17:27	07/23/2013	8:18	1	2331	2331	Tree related-tree broken	Overhead Service		Repair	VI
132020434	K67911	07/21/2013	17:30	07/21/2013	20:20	1	170	170	Overhead equipment	Lightning Arrestor	Replace - Same Size	Patrol/Test/Inspect	VI
132020441	S83533	07/21/2013	17:52	07/21/2013	19:06	1	74	74	Overhead equipment	Transformer Fuse	Repair	Replace - Same Size	VI
132020507	N35851	07/21/2013	18:24	07/21/2013	22:19	2	470	235	Overhead equipment	Overhead Transformer	Replace - Same Size	Replace - Same Size	V
132020464	Q75146	07/21/2013	18:41	07/21/2013	20:21	1	100	100	Other				VI
132020474	S83533	07/21/2013	19:14	07/21/2013	20:27	1	73	73	Overhead equipment	Fuse	Repair	Replace - Same Size	VI
132020481	N54213	07/21/2013	19:19	07/21/2013	20:03	14	616	44	Weather	Fuse	Repair		II
132020485	H10843	07/21/2013	19:34	07/21/2013	21:06	1	92	92	Animal related	Overhead Transformer			V

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
132020496	S28552	07/21/2013	20:02	07/21/2013	20:57	1	55	55	Overhead equipment	Transformer Fuse	Replace - New Size		VI
132020502	N50333	07/21/2013	20:13	07/21/2013	21:48	1	95	95	Overhead equipment	Lightning Arrestor	Repair		II
132020504	M09143	07/21/2013	20:14	07/21/2013	21:49	1	95	95	Tree related-tree broken	Tree	Replace - Same Size		VI
132020508	T15570	07/21/2013	20:25	07/21/2013	23:45	1	200	200	Weather	Disconnect Switch	Replace - Same Size		VI
132020509	T15570	07/21/2013	20:30	07/21/2013	22:30	3	360	120	Weather	Lightning Arrestor	Replace - Same Size		VI
132020513	K31120	07/21/2013	20:38	07/21/2013	22:45	1	127	127	Overhead equipment	Fuse	Replace - Same Size	Repair	I
132020518	S07536	07/21/2013	20:41	07/21/2013	22:51	7	910	130	Tree related-tree contact	Overhead Primary	Patrol/Test/Inspect	Repair	VI
132020531	J63172	07/21/2013	21:14	07/21/2013	22:25	16	1136	71	Overhead equipment	Transformer Fuse	Replace - Same Size		III
132020552	V14579	07/21/2013	21:18	07/21/2013	23:30	97	12804	132	Weather	Fuse	Repair	Repair	II
132020553	S83533	07/21/2013	21:36	07/21/2013	21:55	1	19	19	Overhead equipment	Transformer Fuse	Repair	Replace - Same Size	VI
132020595	K82202	07/21/2013	21:44	07/22/2013	1:15	18	3798	211	Underground equipment	Underground Primary	Switch/Reset		III
132020569	U11531	07/21/2013	22:12	07/21/2013	23:06	1	54	54	Overhead equipment	Transformer Fuse	Repair	Repair	II
132020574	A97001	07/21/2013	22:15	07/22/2013	2:30	9	2295	255	Tree related-tree contact	Overhead Primary	Patrol/Test/Inspect	Repair	I
132020580	L23146	07/21/2013	22:33	07/21/2013	23:10	6	222	37	Overhead equipment	Transformer Fuse	Replace - New Size		III
132020581	C00002	07/21/2013	22:37	07/21/2013	23:40	1	63	63	Overhead equipment	Fuse	Repair		I
132030113	C36002	07/21/2013	23:38	07/22/2013	5:30	30	10560	352	Underground equipment	Underground Primary	Switch/Reset		III
132030105	J75271	07/22/2013	0:07	07/22/2013	3:10	13	2379	183	Overhead equipment	Recloser	Switch/Reset	No Work Required	IV
132030081	K28180	07/22/2013	0:10	07/22/2013	4:28	1	258	258	Weather	Fuse	Replace - Same Size		III
132030087	K71811	07/22/2013	0:13	07/22/2013	1:58	37	3885	105	Weather	Fuse	Replace - Same Size	No Work Required	IV
132030108	Q74148	07/22/2013	0:44	07/22/2013	1:56	29	2088	72	Weather	Recloser	Switch/Reset		IV
132030117	Q71846	07/22/2013	1:25	07/22/2013	3:12	1	107	107	Weather	Fuse	Replace - Same Size	Patrol/Test/Inspect	V
132030123	L82187	07/22/2013	2:10	07/22/2013	3:23	1	73	73	Weather	Transformer Fuse	Replace - Same Size	No Work Required	IV
132030124	Y54002	07/22/2013	2:13	07/22/2013	4:25	1	132	132	Tree related-tree broken	Fuse	Replace - Same Size		IV
132030153	B76001	07/22/2013	2:20	07/22/2013	4:25	236	29500	125	Tree related-tree broken	Overhead Primary	Repair	Repair	I
132030130	S61575	07/22/2013	2:21	07/22/2013	9:23	2	844	422	Underground equipment	Underground Primary		Repair	VI
132033880	Y54591	07/22/2013	3:10	07/22/2013	4:40	9	810	90	Animal related	Fuse	Replace - Same Size		IV
132031301	Q74148	07/22/2013	3:15	07/22/2013	4:05	1	50	50	Weather	Transformer Fuse	Replace - Same Size		IV
132033890	M45212	07/22/2013	3:42	07/22/2013	6:14	2	304	152	Weather	Fuse	Replace - Same Size		IV
132033891	Q74148	07/22/2013	3:43	07/22/2013	5:40	1	117	117	Weather	Transformer Fuse	Replace - Same Size		IV
132033895	Q74148	07/22/2013	3:49	07/22/2013	5:10	1	81	81	Weather	Transformer Fuse	Replace - Same Size		IV
132033898	J14140	07/22/2013	4:24	07/22/2013	6:01	1	97	97	Tree related-tree broken	Overhead Service	Repair	Repair	VI
132033903	J07135	07/22/2013	4:48	07/22/2013	5:42	1	54	54	Overhead equipment	Transformer Fuse	Replace - Same Size		I
132033907	Y23513	07/22/2013	5:23	07/22/2013	6:55	1	92	92	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
132033910	J89126	07/22/2013	5:37	07/22/2013	7:21	5	520	104	Overhead equipment	Transformer Fuse	Repair	Repair	VI
132033917	S41563	07/22/2013	5:58	07/22/2013	7:14	1	76	76	Unknown			No Work Required	VI
132033936	P49183	07/22/2013	6:17	07/22/2013	7:20	1	63	63	Animal related	Transformer Fuse	Replace - Same Size		I
132033961	S47589	07/22/2013	6:33	07/22/2013	7:25	39	2028	52	Overhead equipment	Fuse			VI
132034015	M26164	07/22/2013	7:09	07/22/2013	10:20	1	191	191	Overhead equipment	Overhead Transformer		Replace - Same Size	III
132034022	M45212	07/22/2013	7:11	07/22/2013	10:48	1	217	217	Weather	Overhead Transformer			IV
132034081	K71811	07/22/2013	7:16	07/22/2013	8:28	1	72	72	Weather	Transformer Fuse	Replace - Same Size		IV
132034422	L50217	07/22/2013	7:16	07/22/2013	9:17	9	1089	121	Animal related	Lightning Arrestor			VI
132034161	U03001	07/22/2013	7:19	07/22/2013	8:51	12	1104	92	Overhead equipment	Fuse	Replace - Same Size		II
132034065	L50217	07/22/2013	7:21	07/22/2013	8:40	38	3002	79	Animal related	Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
132034055	A45003	07/22/2013	7:22	07/22/2013	12:40	1	318	318	Underground equipment	Underground Primary	Repair	Repair	I
132034067	V29001	07/22/2013	7:27	07/22/2013	12:20	1	293	293	Underground equipment	Other		Repair	II
132034068	A48005	07/22/2013	7:28	07/22/2013	9:41	1	133	133	Overhead equipment	Connector	Repair	Replace - Same Size	I
132034097	K69112	07/22/2013	7:35	07/22/2013	9:30	1	115	115	Weather	Lightning Arrestor	Replace - Same Size		IV
132034102	R41131	07/22/2013	7:37	07/22/2013	8:15	1	38	38	Weather	Transformer Fuse	Replace - Same Size	No Work Required	VI
132034101	Q82907	07/22/2013	7:37	07/22/2013	8:05	1	28	28	Animal related	Fuse	Replace - Same Size	Replace - Same Size	VI
132034188	N54108	07/22/2013	8:09	07/22/2013	10:09	1	120	120	Tree related-tree broken	Overhead Service	Replace - Same Size		II
132034200	M05360	07/22/2013	8:11	07/22/2013	9:07	5	280	56	Overhead equipment	Fuse			V
132034234	C52001	07/22/2013	8:19	07/22/2013	9:13	1	54	54	Overhead equipment	Overhead Service	Advise Customer	Advise Customer	III
132034277	M05360	07/22/2013	8:23	07/22/2013	9:36	12	876	73	Animal related	Fuse	Replace - Same Size	Replace - Same Size	V
132034305	Y98518	07/22/2013	8:35	07/22/2013	10:50	1	135	135	Animal related	Fuse	Replace - Same Size		IV
132034313	V63570	07/22/2013	8:37	07/22/2013	9:49	1	72	72	Overhead equipment	Transformer Fuse	Replace - Same Size		II
132034408	X57525	07/22/2013	8:57	07/22/2013	9:25	1	28	28	Overhead equipment	Transformer Fuse	Replace - Same Size		IV

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
132034435	D72002	07/22/2013	9:02	07/22/2013	10:35	1	93	93	Underground equipment	Underground Primary		Repair	I
132034441	P83710	07/22/2013	9:05	07/22/2013	10:28	1	83	83	Animal related	Transformer Fuse	Replace - Same Size	No Work Required	I
132034671	K52400	07/22/2013	9:23	07/22/2013	11:57	21	3234	154	Underground equipment	Underground Primary	Patrol/Test/Inspect	Patrol/Test/Inspect	V
132034693	B73001	07/22/2013	9:53	07/22/2013	11:20	10	870	87	Animal related	Transformer Fuse	Replace - Same Size	No Work Required	I
132034702	R53416	07/22/2013	9:56	07/22/2013	10:39	1	43	43	Animal related	Fuse	Replace - Same Size		V
132034730		07/22/2013	10:02	07/22/2013	12:30	1	148	148	Overhead equipment	Overhead Transformer	Replace - Same Size	Replace - Same Size	I
132034887	Y97513	07/22/2013	10:30	07/22/2013	11:35	1	65	65	Animal related	Transformer Fuse	Replace - Same Size		IV
132034929	K28180	07/22/2013	10:36	07/22/2013	11:38	1	62	62	Animal related	EYE	Replace - Same Size		III
132034962	K80386	07/22/2013	10:41	07/22/2013	11:15	1	34	34	Animal related	Fuse	Replace - Same Size		IV
132035192	V23522	07/22/2013	10:45	07/22/2013	12:00	13	975	75	Public	Overhead Primary	Repair		II
132035113	C50001	07/22/2013	11:11	07/22/2013	11:35	1	24	24	Overhead equipment	Disconnect Switch	Replace - Same Size	Repair	III
132035140	V18553	07/22/2013	11:18	07/22/2013	21:53	1	635	635	Public	Underground Primary	Repair	Repair	II
132035167	V23522	07/22/2013	11:22	07/22/2013	13:02	1	100	100	Public	Fuse	Replace - Same Size		II
132035237	T06537	07/22/2013	11:36	07/22/2013	13:40	2	248	124	Overhead equipment	Fuse	Patrol/Test/Inspect	Cut in Clear	VI
132035254	L70128	07/22/2013	11:38	07/22/2013	17:00	1	322	322	Weather	Overhead Transformer		Replace - Same Size	IV
132035266	S43501	07/22/2013	11:41	07/22/2013	11:55	1	14	14	Unknown			No Work Required	VI
132035670	D92002	07/22/2013	12:18	07/22/2013	14:15	590	69030	117	Overhead equipment	Disconnect Switch	Replace - Same Size		I
132035573	S15559	07/22/2013	12:42	07/22/2013	13:23	1	41	41	Overhead equipment	Fuse	Repair		VI
132035614	K71812	07/22/2013	12:50	07/22/2013	13:22	1	32	32	Underground equipment	Underground Service		Repair	IV
132035779	P72320	07/22/2013	13:26	07/22/2013	14:12	1	46	46	Overhead equipment	Overhead Service	Replace - Same Size		V
132035801	X36550	07/22/2013	13:29	07/22/2013	15:01	1	92	92	Animal related	Transformer Fuse	Replace - Same Size		IV
132035830	Q32171	07/22/2013	13:36	07/22/2013	14:57	1	81	81	Overhead equipment	Pole		Straighten	I
132035829	K71812	07/22/2013	13:36	07/22/2013	15:19	1	103	103	Underground equipment	Underground Service		Repair	IV
132035872	R10925	07/22/2013	13:44	07/22/2013	15:05	1	81	81	Jurisdictional				VI
132035893		07/22/2013	13:46	07/22/2013	16:46	1	180	180	Weather	Fuse	Replace - Same Size		V
132035955	Q16867	07/22/2013	13:57	07/22/2013	16:58	1	181	181	Weather	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	V
132035348	L23148	07/22/2013	14:24	07/22/2013	15:45	2	162	81	Tree related-tree contact	Tree	Remove		III
132036140		07/22/2013	14:32	07/22/2013	15:20	1	48	48	Unknown	Fuse	Patrol/Test/Inspect	Replace - Same Size	I
132036454	J07135	07/22/2013	15:35	07/22/2013	16:09	1	34	34	Overhead equipment	Meter	Patrol/Test/Inspect		I
132036569	R58961	07/22/2013	16:00	07/22/2013	17:30	1	90	90	Overhead equipment	Pole	Patrol/Test/Inspect	Remove	IV
132036570	L74193	07/22/2013	16:01	07/22/2013	18:09	1	128	128	Tree related-tree broken	Overhead Service	Repair		IV
132036652	D96001	07/22/2013	16:20	07/22/2013	18:42	1	142	142	Animal related	Fuse	Replace - Same Size		I
132036773	S86582	07/22/2013	16:58	07/22/2013	18:27	1	89	89	Animal related	Transformer Fuse	Replace - Same Size		VI
132036819	A49001	07/22/2013	17:18	07/22/2013	18:25	7	469	67	Overhead equipment	Disconnect Switch	Replace - Same Size		I
132036834	H07106	07/22/2013	17:23	07/22/2013	21:05	1	222	222	Weather	Transformer Fuse	Replace - Same Size	Replace - Same Size	IV
132036869	N50334	07/22/2013	17:43	07/22/2013	23:29	1	346	346	Overhead equipment	Overhead Transformer	Repair	Replace - New Size	II
132036933	S07536	07/22/2013	18:18	07/22/2013	20:02	1	104	104	Tree related-tree contact	Overhead Service	Patrol/Test/Inspect	Repair	VI
132036957	Q71846	07/22/2013	18:37	07/22/2013	23:34	3	891	297	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - New Size	V
132037000	D41002	07/22/2013	19:14	07/23/2013	0:03	14	4046	289	Overhead equipment	Overhead Transformer		Repair	I
132037195	P69175	07/22/2013	19:48	07/22/2013	20:54	1	66	66	Overhead equipment	Connector	Replace - Same Size		III
132037766	303006	07/22/2013	20:37	07/22/2013	21:12	7	245	35	Tree related-tree broken	Tree	Cut in Clear		VI
132037778	M78322	07/22/2013	20:49	07/22/2013	22:10	42	3402	81	Tree related-tree contact	Overhead Primary	Repair	Patrol/Test/Inspect	V
132037802	P73182	07/22/2013	21:35	07/23/2013	0:02	1	147	147	Animal related	Transformer Fuse	Replace - Same Size		VI
132037813	K71812	07/22/2013	21:50	07/22/2013	23:08	44	3432	78	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	IV
132037832	P49180	07/22/2013	22:07	07/23/2013	4:45	7	2786	398	Tree related-tree contact	Pole	Patrol/Test/Inspect	Replace - New Size	I
132037833	350104	07/22/2013	22:14	07/22/2013	23:29	1	75	75	Overhead equipment	Overhead Service	Repair	Replace - New Size	V
132037842	J06167	07/22/2013	22:27	07/23/2013	1:30	3	549	183	Tree related-tree contact	Overhead Secondary	Cut in Clear		I
132037895	N70330	07/22/2013	22:29	07/23/2013	3:00	1537	416527	271	Weather	Overhead Primary			I
132037824	K07322	07/22/2013	22:35	07/23/2013	1:51	1	196	196	Tree related-tree contact	Overhead Secondary	Replace - Same Size		I
132037876	R05186	07/22/2013	22:36	07/23/2013	2:15	5	1095	219	Tree related-tree broken	Overhead Secondary	Patrol/Test/Inspect	Repair	I
132037917	B81003	07/22/2013	23:10	07/23/2013	3:20	39	9750	250	Tree related-tree broken	Overhead Primary	Repair	Repair	I
132037921	N67312	07/22/2013	23:29	07/23/2013	2:45	1	196	196	Weather	Fuse	Replace - Same Size		I
132040092	D69006	07/23/2013	0:12	07/23/2013	4:42	1	270	270	Overhead equipment	Crossarm		Repair	I
132040259	B81003	07/23/2013	0:24	07/23/2013	3:23	1	179	179	Tree related-tree contact	Overhead Service	No Work Required	Repair	I
132041456		07/23/2013	0:40	07/23/2013	3:22	1	162	162	Weather	Overhead Primary	Reconnect		I
132041797	M81403	07/23/2013	0:53	07/23/2013	2:53	1	120	120	Underground equipment	Overhead Service	Patrol/Test/Inspect	Repair	V

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
132043401	V74513	07/23/2013	2:06	07/23/2013	3:31	54	4590	85	Weather	Fuse	Replace - Same Size		II
132043413	J01119	07/23/2013	2:26	07/23/2013	3:18	5	260	52	Overhead equipment	Fuse	Replace - Same Size		I
132045236	P69174	07/23/2013	4:40	07/23/2013	6:47	1	127	127	Tree related-tree broken	Tree	Repair		III
132045241	A49003	07/23/2013	4:49	07/23/2013	8:10	22	4422	201	Underground equipment	Underground Primary	Repair	Repair	I
132045248	S50541	07/23/2013	5:14	07/23/2013	6:40	3	258	86	Animal related	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
132045286	U93507	07/23/2013	6:24	07/23/2013	7:38	1	74	74	Overhead equipment	Transformer Fuse	Replace - Same Size	Replace - Same Size	II
132045292	R01153	07/23/2013	6:27	07/23/2013	13:05	78	31044	398	Underground equipment	Underground Primary	Repair	Repair	III
132045300	U44529	07/23/2013	6:42	07/23/2013	7:37	9	495	55	Animal related	Transformer Fuse	Repair	Repair	II
132045302	S61575	07/23/2013	6:42	07/23/2013	13:55	2	866	433	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	VI
132045324	V92543	07/23/2013	6:57	07/23/2013	7:58	7	427	61	Animal related	Transformer Fuse	Replace - Same Size	Patrol/Test/Inspect	II
132045346	Q16868	07/23/2013	7:07	07/23/2013	8:10	1	63	63	Weather	Fuse	Replace - Same Size		V
132045352	S07536	07/23/2013	7:10	07/23/2013	11:12	28	6776	242	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	VI
132045411	R59412	07/23/2013	7:30	07/23/2013	8:32	1	62	62	Tree related-tree broken			No Work Required	IV
132045539	P07179	07/23/2013	8:11	07/23/2013	11:21	1	190	190	Overhead equipment	Insulator			I
132045793	V41533	07/23/2013	8:36	07/23/2013	15:13	3	1191	397	Underground equipment	Underground Primary			II
132045662	U33586	07/23/2013	8:38	07/23/2013	9:20	1	42	42	Animal related	Transformer Fuse	Replace - Same Size		II
132045693	N93260	07/23/2013	8:43	07/23/2013	10:07	1	84	84	Overhead equipment	Fuse	Repair		III
132047404	B93003	07/23/2013	8:45	07/23/2013	18:08	13	7319	563	Underground equipment	Underground Primary	Repair		I
132045745	U16522	07/23/2013	8:52	07/23/2013	10:55	1	123	123	Animal related	Transformer Fuse	Replace - Same Size		II
132046587	P07179	07/23/2013	8:56	07/23/2013	11:25	1	149	149	Animal related				I
132045840	A28001	07/23/2013	9:08	07/23/2013	11:20	1	132	132	Overhead equipment	Transformer Fuse	Replace - Same Size	No Work Required	I
132045888	J07173	07/23/2013	9:17	07/23/2013	10:47	1	90	90	Overhead equipment	Overhead Service	No Work Required		I
132046031	M73330	07/23/2013	9:42	07/23/2013	11:28	1	106	106	Overhead equipment	Overhead Service	Repair	No Work Required	V
132046027	T17581	07/23/2013	9:42	07/23/2013	10:10	1	28	28	Unknown	Transformer Fuse	Replace - Same Size	No Work Required	VI
132046095	R05186	07/23/2013	9:53	07/23/2013	13:31	1	218	218	Overhead equipment	Tree	Cut in Clear		I
132046121	J07135	07/23/2013	9:57	07/23/2013	11:49	1	112	112	Overhead equipment	Overhead Transformer	Switch/Reset		I
132046340	D88001	07/23/2013	10:41	07/23/2013	12:17	107	10272	96	Animal related	Fuse	Replace - Same Size	No Work Required	I
132046960	A91004	07/23/2013	11:25	07/23/2013	12:20	20	1100	55	Overhead equipment	Fuse	Repair	No Work Required	I
132046581	R05186	07/23/2013	11:26	07/23/2013	13:59	1	153	153	Underground equipment	Underground Service	No Work Required		I
132046717	M83326	07/23/2013	11:54	07/23/2013	12:10	1	16	16	Overhead equipment	Overhead Service	Patrol/Test/Inspect		V
132047082	B93003	07/23/2013	11:54	07/23/2013	14:10	170	23120	136	Underground equipment	Underground Primary	Replace - Same Size		I
132046770	X66582	07/23/2013	12:10	07/23/2013	14:10	1	120	120	Animal related	Fuse	Replace - Same Size		IV
132046851	K39153	07/23/2013	12:27	07/23/2013	22:35	2	1216	608	Underground equipment				III
132046942	P60170	07/23/2013	12:46	07/23/2013	13:43	1	57	57	Overhead equipment	Connector	Repair		VI
132046971	L70128	07/23/2013	12:49	07/23/2013	14:19	1	90	90	Overhead equipment	Fuse			IV
132047031	J80807	07/23/2013	12:59	07/23/2013	13:43	1	44	44	Overhead equipment	Overhead Primary	Repair	Repair	V
132047139	Y35005	07/23/2013	13:23	07/23/2013	13:55	1	32	32	Overhead equipment	Fuse		Replace - Same Size	IV
132047134	J80806	07/23/2013	13:23	07/23/2013	14:45	1	82	82	Overhead equipment	Overhead Transformer	Repair	Repair	V
132047140	V74513	07/23/2013	13:24	07/23/2013	13:55	2	62	31	Weather	Transformer Fuse	Repair		II
132047308	303006	07/23/2013	13:58	07/23/2013	15:45	1	107	107	Overhead equipment	Overhead Service	Advise Customer		VI
132047322	D66002	07/23/2013	14:00	07/23/2013	15:05	1	65	65	Overhead equipment				IV
132047574	M09175	07/23/2013	14:49	07/23/2013	16:11	7	574	82	Overhead equipment	Overhead Transformer	Replace - Same Size	Repair	VI
132047625	D69006	07/23/2013	15:01	07/23/2013	15:55	1	54	54	Overhead equipment	Fuse	Replace - Same Size		I
132047853	V23592	07/23/2013	15:22	07/23/2013	16:25	12	756	63	Animal related	Fuse	Replace - Same Size		II
132047778	Q80352	07/23/2013	15:36	07/23/2013	16:55	1	79	79	Tree related-tree broken	Overhead Service	Repair		V
132047810	Y35001	07/23/2013	15:47	07/23/2013	16:38	1	51	51	Overhead equipment	Overhead Service			IV
132047851	U68001	07/23/2013	15:59	07/23/2013	18:02	1	123	123	Underground equipment	Underground Service	Repair		II
132048024	D28124	07/23/2013	16:57	07/23/2013	23:00	1	363	363	Public	Overhead Primary	Patrol/Test/Inspect	Repair	I
132048058	K08909	07/23/2013	17:16	07/23/2013	21:06	12	2760	230	Overhead equipment	Connector			VI
132048089	P69175	07/23/2013	17:18	07/23/2013	18:13	11	605	55	Overhead equipment	Fuse	Replace - Same Size		III
132048112	R06212	07/23/2013	17:32	07/23/2013	20:01	65	9685	149	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	II
132048134	334003	07/23/2013	17:47	07/23/2013	19:01	1	74	74	Public	Overhead Service	Repair		VI
132048272	X42502	07/23/2013	18:11	07/23/2013	20:39	1	148	148	Overhead equipment	Overhead Transformer	Replace - Same Size	Replace - Same Size	IV
132048340	Y04508	07/23/2013	18:28	07/23/2013	19:45	1	77	77	Animal related	Fuse	Replace - Same Size		IV
132048678	J14142	07/23/2013	18:38	07/23/2013	20:15	1	97	97	Overhead equipment	Fuse	Repair	Repair	VI
132048871	C70004	07/23/2013	20:13	07/24/2013	1:41	1	328	328	Underground equipment	Underground Primary	Repair		III

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
132048932	T05539	07/23/2013	20:50	07/23/2013	23:40	6	1020	170	Tree related-tree broken	Overhead Primary	Repair	Repair	VI
132048917	S88503	07/23/2013	21:04	07/23/2013	22:32	1	88	88	Tree related-tree broken	Tree			VI
132048928	S28552	07/23/2013	21:20	07/24/2013	0:15	1	175	175	Tree related-tree contact	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
132050100	J01119	07/24/2013	0:16	07/24/2013	1:15	1	59	59	Animal related	Transformer Fuse	Replace - Same Size		I
132050138	X87576	07/24/2013	0:16	07/24/2013	4:28	5	1260	252	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	IV
132050129	T06503	07/24/2013	1:01	07/24/2013	2:40	1	99	99	Overhead equipment	Other	Patrol/Test/Inspect	Repair	VI
132053292	L82188	07/24/2013	3:14	07/24/2013	3:54	1	40	40	Animal related	Transformer Fuse	Replace - Same Size	No Work Required	IV
132054389	D36002	07/24/2013	3:19	07/24/2013	6:00	24	3864	161	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
132054385	B73001	07/24/2013	3:29	07/24/2013	4:55	1	86	86	Overhead equipment	Overhead Transformer	Switch/Reset		I
132054399	T04512	07/24/2013	4:26	07/24/2013	6:30	1	124	124	Animal related	Transformer Fuse			VI
132054408	J79304	07/24/2013	5:13	07/24/2013	7:55	3	486	162	Underground equipment	Underground Primary	Replace - Same Size		I
132054699	A81003	07/24/2013	7:09	07/24/2013	10:30	5	1005	201	Underground equipment	Underground Primary	Switch/Reset	Repair	I
132055036	B81002	07/24/2013	7:34	07/24/2013	11:30	4	944	236	Underground equipment	Underground Transformer	Replace - Same Size		I
132054588	B81002	07/24/2013	7:34	07/24/2013	9:32	18	2124	118	Underground equipment	Underground Primary	Patrol/Test/Inspect	Cut in Clear	I
132054606	P73182	07/24/2013	7:46	07/24/2013	8:10	1	24	24	Animal related	Fuse	Replace - Same Size		VI
132054713	U16522	07/24/2013	8:16	07/24/2013	9:03	1	47	47	Animal related	Transformer Fuse	Replace - Same Size		II
132054800	Y11555	07/24/2013	8:37	07/24/2013	9:20	1	43	43	Weather	Transformer Fuse	Repair	Replace - Same Size	IV
132054852	P73157	07/24/2013	8:46	07/24/2013	18:17	48	27408	571	Underground equipment	Underground Primary	Repair	Repair	VI
132054851	D36001	07/24/2013	8:47	07/24/2013	10:20	1	93	93	Overhead equipment	Fuse	Replace - Same Size		I
132054904	P73157	07/24/2013	9:02	07/24/2013	10:24	1	82	82	Underground equipment	Underground Primary			VI
132054924	K31120	07/24/2013	9:05	07/24/2013	10:17	1	72	72	Animal related	Transformer Fuse	Replace - Same Size		I
132054955	Y59519	07/24/2013	9:13	07/24/2013	9:49	1	36	36	Animal related	Disconnect Switch	Replace - Same Size		IV
132055280	R01153	07/24/2013	10:08	07/24/2013	13:38	78	16380	210	Underground equipment	Underground Primary	Repair	Repair	III
132055469	L70128	07/24/2013	10:52	07/24/2013	11:24	1	32	32	Overhead equipment	Fuse			IV
132055510	U60559	07/24/2013	10:59	07/24/2013	11:36	1	37	37	Animal related	Fuse	Replace - Same Size		II
132055578	N05170	07/24/2013	11:13	07/24/2013	12:33	1	80	80	Overhead equipment	Transformer Fuse	Replace - Same Size		I
132055648	P42229	07/24/2013	11:20	07/24/2013	11:44	165	3960	24	Overhead equipment				VI
132055687	S78551	07/24/2013	11:32	07/24/2013	12:46	1	74	74	Animal related	Transformer Fuse			VI
132055693	P58154	07/24/2013	11:33	07/24/2013	13:44	1	131	131	Animal related	Fuse	Repair	Replace - Same Size	VI
132055735	Y59519	07/24/2013	11:39	07/24/2013	13:38	1	119	119	Weather	Disconnect Switch	Replace - Same Size		IV
132055749	H06135	07/24/2013	11:41	07/24/2013	12:27	7	322	46	Unknown	Transformer Fuse	Replace - Same Size		IV
132055916	P73157	07/24/2013	13:18	07/24/2013	15:12	1	114	114	Overhead equipment	Recloser	Replace - Same Size		VI
132056759	F10002	07/24/2013	13:33	07/24/2013	18:00	1	267	267	Underground equipment	Underground Primary	Repair		III
132056389	F10002	07/24/2013	13:45	07/24/2013	14:40	9	495	55	Underground equipment	Underground Primary			III
132056446	M37192	07/24/2013	13:56	07/24/2013	15:14	1	78	78	Overhead equipment	Overhead Service	Tie/Tighten		I
132056499		07/24/2013	14:03	07/24/2013	14:36	1	33	33	Weather	Fuse	Replace - Same Size		VI
132056718	X39542	07/24/2013	14:37	07/24/2013	15:58	1	81	81	Overhead equipment	Lightning Arrestor	Replace - Same Size		IV
132056813	M22812	07/24/2013	14:57	07/24/2013	16:18	1	81	81	Overhead equipment	Overhead Service	Repair		V
132057226	C36001	07/24/2013	15:08	07/24/2013	20:08	2	600	300	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	III
132056898	C36001	07/24/2013	15:08	07/24/2013	16:35	39	3393	87	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	III
132056932	K31120	07/24/2013	15:19	07/24/2013	16:28	1	69	69	Overhead equipment	Transformer Fuse	Replace - Same Size		I
132057094	Y61003	07/24/2013	15:44	07/24/2013	16:30	12	552	46	Unknown	Fuse	Replace - Same Size		IV
132057124	X95001	07/24/2013	16:07	07/24/2013	16:54	1	47	47	Overhead equipment	Overhead Service			IV
132057223	K30204	07/24/2013	16:33	07/24/2013	18:50	1	137	137	Unknown	Transformer Fuse	Replace - Same Size		III
132057293	K01238	07/24/2013	16:51	07/24/2013	22:16	1	325	325	Underground equipment	Underground Secondary	Disconnect	Repair	VI
132057299	H01190	07/24/2013	16:52	07/24/2013	23:27	1	395	395	Underground equipment	Underground Primary	Patrol/Test/Inspect		III
132057318	P58156	07/24/2013	17:00	07/24/2013	20:02	1	182	182	Underground equipment	Underground Service		Repair	VI
132058184	B93003	07/24/2013	17:35	07/25/2013	5:40	3	2175	725	Underground equipment	Underground Primary	Repair		I
132057409	B93003	07/24/2013	17:35	07/24/2013	19:52	11	1507	137	Underground equipment	Underground Primary	Replace - Same Size		I
132057605	J58380	07/24/2013	18:31	07/24/2013	19:16	1	45	45	Animal related	Transformer Fuse			III
132058210	C40001	07/24/2013	20:21	07/25/2013	1:45	88	28512	324	Underground equipment	Underground Primary		Repair	I
132058539	T14576	07/24/2013	21:08	07/24/2013	22:35	196	17052	87	Overhead equipment	Fuse	Replace - New Size		VI
132058561	P58155	07/24/2013	21:35	07/24/2013	22:44	65	4485	69	Animal related	Fuse	Replace - Same Size		VI
132058563	J06168	07/24/2013	21:51	07/24/2013	23:30	1	99	99	Animal related	Fuse	Replace - Same Size		I
132058579	R60552	07/24/2013	22:58	07/25/2013	0:28	1	90	90	Animal related	Transformer Fuse	Replace - Same Size		IV
132058576	M81402	07/24/2013	22:58	07/25/2013	5:13	1	375	375	Public	Overhead Service	Patrol/Test/Inspect	Repair	V

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
132058590	M07235	07/24/2013	23:54	07/25/2013	1:15	1	81	81	Animal related	Transformer Fuse	Replace - Same Size		III
132060163	N25974	07/25/2013	2:00	07/25/2013	4:09	1	129	129	Overhead equipment	Fuse	Replace - Same Size	No Work Required	III
132060289	B81002	07/25/2013	2:13	07/25/2013	5:30	56	11032	197	Overhead equipment				I
132066817	B81002	07/25/2013	2:15	07/25/2013	12:35	2	1240	620	Underground equipment	Underground Primary	Repair		I
132060294	J39392	07/25/2013	2:23	07/25/2013	4:21	12	1416	118	Overhead equipment	Fuse			III
132064965	Y13043	07/25/2013	4:39	07/25/2013	6:05	6	516	86	Overhead equipment	Disconnect Switch	Repair	Repair	IV
132064985	B81002	07/25/2013	4:46	07/25/2013	10:12	11	3586	326	Underground equipment	Underground Primary		Repair	I
132065001	M42105	07/25/2013	6:20	07/25/2013	11:00	2	560	280	Overhead equipment	Fuse	Replace - Same Size		I
132065159	J61112	07/25/2013	6:32	07/25/2013	8:12	60	6000	100	Overhead equipment	Overhead Primary			III
132065040	R58961	07/25/2013	6:47	07/25/2013	10:00	33	6369	193	Underground equipment	Underground Primary		Repair	IV
132065299	J87111	07/25/2013	7:08	07/25/2013	9:17	92	11868	129	Animal related	Transformer Fuse			VI
132065076	X92508	07/25/2013	7:10	07/25/2013	8:35	1	85	85	Overhead equipment	Fuse	Repair	Replace - Same Size	IV
132065201	K31120	07/25/2013	7:32	07/25/2013	8:06	1	34	34	Overhead equipment	Transformer Fuse	Replace - Same Size		I
132065200	M09144	07/25/2013	7:32	07/25/2013	11:04	1	212	212	Underground equipment	Underground Primary	Cut in Clear	Cut in Clear	VI
132065227	R73841	07/25/2013	7:42	07/25/2013	9:13	8	728	91	Animal related	Overhead Primary	Repair		V
132065354	N91255	07/25/2013	7:51	07/25/2013	8:50	32	1888	59	Animal related	Fuse	Repair		III
132065296	K74166	07/25/2013	8:09	07/25/2013	8:55	1	46	46	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
132065425	Q21293	07/25/2013	8:38	07/25/2013	14:10	23	7636	332	Public	Underground Primary			VI
132065438	N70332	07/25/2013	8:41	07/25/2013	9:09	1	28	28	Overhead equipment	Jumper	Reconnect		I
132065513	Y35514	07/25/2013	8:57	07/25/2013	9:45	3	144	48	Animal related	Fuse	Replace - Same Size		IV
132065581	J34357	07/25/2013	9:10	07/25/2013	10:43	82	7626	93	Overhead equipment	Fuse	Replace - Same Size		V
132065591	S36570	07/25/2013	9:14	07/25/2013	10:23	1	69	69	Public	Overhead Service	Patrol/Test/Inspect	Disconnect	VI
132747047	J87111	07/25/2013	9:24	07/25/2013	9:52	629	17612	28	Other	Substation Breaker	Switch/Reset		VI
132066435	K05253	07/25/2013	9:24	07/25/2013	10:50	97	8342	86	Other				VI
132065724	J83140	07/25/2013	9:27	07/25/2013	9:34	968	6776	7	Other	Recloser	Switch/Reset		VI
132066663	K05253	07/25/2013	9:36	07/25/2013	12:20	2	328	164	Overhead equipment				VI
132065897	Q32170	07/25/2013	10:00	07/25/2013	12:37	1	157	157	Animal related	Transformer Fuse	Replace - Same Size	Patrol/Test/Inspect	I
132065902	Q71846	07/25/2013	10:02	07/25/2013	11:02	1	60	60	Animal related	Transformer Fuse	Replace - Same Size		V
132065917	X49569	07/25/2013	10:05	07/25/2013	11:18	1	73	73	Unknown	Transformer Fuse	Replace - Same Size		IV
132066818	J87120	07/25/2013	10:06	07/25/2013	13:50	403	90272	224	Overhead equipment	Jumper		Repair	VI
132066598	J87150	07/25/2013	10:06	07/25/2013	13:50	258	57792	224	Other	Jumper	Replace - Same Size	Replace - Same Size	VI
132066183	J87150	07/25/2013	10:06	07/25/2013	13:50	164	36736	224	Other	Recloser			VI
132066168	K05253	07/25/2013	10:28	07/25/2013	13:08	1	160	160	Overhead equipment	Overhead Primary	Patrol/Test/Inspect		VI
132066179	D32211	07/25/2013	10:29	07/25/2013	11:49	1	80	80	Overhead equipment	Fuse	Replace - Same Size		I
132066362	S86582	07/25/2013	10:36	07/25/2013	11:08	766	24512	32	Unknown				VI
132066372		07/25/2013	10:47	07/25/2013	11:09	1	22	22	Overhead equipment	Overhead Service			VI
132066474	S24598	07/25/2013	11:04	07/25/2013	14:27	1	203	203	Overhead equipment	Overhead Service	Patrol/Test/Inspect	Repair	VI
132066608	Q32171	07/25/2013	11:17	07/25/2013	15:00	1	223	223	Tree related-tree broken	Overhead Service	Repair	Patrol/Test/Inspect	I
132066617	S86582	07/25/2013	11:18	07/25/2013	11:24	1	6	6	Overhead equipment	Overhead Service			VI
132066755	R65451	07/25/2013	11:38	07/25/2013	13:50	65	8580	132	Underground equipment	Underground Primary		Repair	IV
132066773	S28551	07/25/2013	11:45	07/25/2013	14:41	1	176	176	Overhead equipment	Overhead Secondary	Repair		VI
132066776	Q95249	07/25/2013	11:46	07/25/2013	13:08	1	82	82	Animal related	Fuse	Replace - Same Size		VI
132066941	S86582	07/25/2013	12:05	07/25/2013	12:33	766	21448	28	Unknown				VI
132066884		07/25/2013	12:09	07/25/2013	12:33	2	48	24	Jurisdictional				VI
132067118	S86582	07/25/2013	12:49	07/25/2013	13:06	1	17	17	Overhead equipment	Overhead Service	Patrol/Test/Inspect	No Work Required	VI
132067131	S86582	07/25/2013	12:52	07/25/2013	13:10	1	18	18	Overhead equipment	Overhead Service	Patrol/Test/Inspect	No Work Required	VI
132067194	X23516	07/25/2013	13:03	07/25/2013	17:00	3	711	237	Overhead equipment	Overhead Transformer	Replace - Same Size	Replace - Same Size	IV
132067219	S21529	07/25/2013	13:10	07/25/2013	14:03	1	53	53	Tree related-tree broken	Pole		Replace - Same Size	VI
132067389	E10001	07/25/2013	13:20	07/25/2013	14:00	4	160	40	Overhead equipment	Other	No Work Required	No Work Required	III
132067302	X23516	07/25/2013	13:21	07/25/2013	18:00	1	279	279	Public	Underground Transformer	Replace - New Size		IV
132067477	A45003	07/25/2013	13:25	07/25/2013	15:48	12	1716	143	Underground equipment	Fuse	Patrol/Test/Inspect	Replace - Same Size	I
132067452	J87150	07/25/2013	13:35	07/25/2013	13:50	15	225	15	Overhead equipment	Overhead Primary			VI
132067492	U06524	07/25/2013	13:53	07/25/2013	14:25	1	32	32	Overhead equipment	Transformer Fuse	Replace - Same Size		II
132067788	Q28141	07/25/2013	14:49	07/25/2013	15:51	1	62	62	Animal related	Fuse	Replace - Same Size		VI
132067813	Q21293	07/25/2013	14:58	07/25/2013	18:30	13	2756	212	Public				VI
132067911	U61568	07/25/2013	15:15	07/25/2013	15:36	1	21	21	Overhead equipment	Fuse	Replace - Same Size		II

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
132067942	K30204	07/25/2013	15:20	07/25/2013	17:45	1	145	145	Animal related	Transformer Fuse	Replace - Same Size		III
132068037	R58921	07/25/2013	15:35	07/25/2013	15:42	483	3381	7	Overhead equipment	Overhead Primary			IV
132068100	R59411	07/25/2013	15:36	07/25/2013	15:42	310	1860	6	Jurisdictional	Substation Breaker	Switch/Reset		IV
132068272	J71129	07/25/2013	16:22	07/25/2013	18:40	1	138	138	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	I
132068281	L74191	07/25/2013	16:24	07/25/2013	17:17	4	212	53	Animal related	Transformer Fuse	Replace - Same Size		IV
132068452	V26292	07/25/2013	16:25	07/25/2013	16:47	792	17424	22	Jurisdictional				II
132068401		07/25/2013	16:39	07/25/2013	18:38	1	119	119	Overhead equipment				II
132068586	S42578	07/25/2013	17:11	07/25/2013	17:23	288	3456	12	Jurisdictional	Jumper			VI
132068567	T17581	07/25/2013	17:12	07/25/2013	17:16	398	1592	4	Jurisdictional	Jumper			VI
132068637	A85002	07/25/2013	17:44	07/25/2013	19:00	1	76	76	Overhead equipment	Fuse	Replace - Same Size		I
132068644	A85002	07/25/2013	17:45	07/26/2013	1:20	2	910	455	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
132068711	Y68581	07/25/2013	18:06	07/25/2013	20:13	1	127	127	Overhead equipment	Overhead Service	Replace - Same Size	Replace - Same Size	IV
132069188	Q21293	07/25/2013	18:31	07/25/2013	20:53	11	1562	142	Underground equipment	Underground Primary	Patrol/Test/Inspect	Replace - Same Size	VI
132069242	A73002	07/25/2013	18:39	07/25/2013	20:44	13	1625	125	Underground equipment	Underground Primary	Patrol/Test/Inspect		I
132069224	R33127	07/25/2013	18:54	07/25/2013	19:50	1	56	56	Animal related	Transformer Fuse	Replace - Same Size	Patrol/Test/Inspect	I
132069240	310124	07/25/2013	19:03	07/25/2013	19:25	1	22	22	Animal related	Fuse	Replace - Same Size	No Work Required	V
132069282	D67001	07/25/2013	19:41	07/26/2013	4:40	12	6468	539	Underground equipment	Underground Primary		Repair	IV
132069320	M19222	07/25/2013	20:30	07/25/2013	21:22	1	52	52	Animal related	Transformer Fuse	Replace - Same Size		VI
132069406	Q27185	07/25/2013	22:46	07/26/2013	0:31	6	630	105	Animal related	Fuse	Replace - Same Size		VI
132070110	S07536	07/25/2013	22:57	07/26/2013	4:04	80	24560	307	Tree related-tree broken	Overhead Primary			VI
132069398	S07536	07/25/2013	22:58	07/26/2013	1:00	24	2928	122	Tree related-tree broken				VI
132070146	X65540	07/25/2013	23:45	07/26/2013	1:45	14	1680	120	Underground equipment	Underground Primary	Switch/Reset		IV
132069410	X65540	07/25/2013	23:45	07/26/2013	5:43	17	6086	358	Underground equipment	Underground Primary	Repair	Repair	IV
132070103	J98104	07/26/2013	0:03	07/26/2013	1:10	1	67	67	Jurisdictional				VI
132070143	K46388	07/26/2013	1:40	07/26/2013	2:45	1	65	65	Animal related	Fuse	Replace - Same Size		V
132070251	Q01280	07/26/2013	3:01	07/26/2013	7:04	37	8991	243	Underground equipment	Underground Primary		Repair	III
132070254	V40556	07/26/2013	3:27	07/26/2013	5:00	1	93	93	Overhead equipment	Transformer Fuse	Repair	Repair	II
132074228	M31201	07/26/2013	5:43	07/26/2013	8:12	1	149	149	Tree related-tree broken	Overhead Service	Replace - Same Size		I
132074238	V10533	07/26/2013	6:09	07/26/2013	9:50	1	221	221	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	II
132074254	303006	07/26/2013	6:35	07/26/2013	9:25	11	1870	170	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	VI
132074295	303006	07/26/2013	7:11	07/26/2013	7:15	1	4	4	Unknown	Other	Patrol/Test/Inspect		VI
132074357	A81004	07/26/2013	7:33	07/26/2013	8:50	1	77	77	Overhead equipment	Disconnect Switch	Replace - Same Size		I
132074403	L08226	07/26/2013	7:45	07/26/2013	8:50	1	65	65	Overhead equipment	Fuse	Replace - Same Size		III
132074298	M36189	07/26/2013	7:51	07/26/2013	12:45	2	588	294	Animal related	Overhead Primary	Patrol/Test/Inspect	No Work Required	I
132074431	S27599	07/26/2013	7:54	07/26/2013	8:54	1	60	60	Overhead equipment	Transformer Fuse	Repair	Replace - Same Size	VI
132074444	L86175	07/26/2013	8:00	07/26/2013	9:05	1	65	65	Animal related	Overhead Transformer			IV
132074482	J71129	07/26/2013	8:11	07/26/2013	14:58	1	407	407	Overhead equipment	Transformer Fuse	Replace - Same Size	Replace - Same Size	I
132074499	M30301	07/26/2013	8:12	07/26/2013	9:34	4	328	82	Overhead equipment	Fuse	Replace - Same Size		VI
132074527		07/26/2013	8:25	07/26/2013	8:46	1	21	21	Overhead equipment	Other			IV
132074528	U28510	07/26/2013	8:26	07/26/2013	10:12	1	106	106	Overhead equipment	Transformer Fuse	Replace - Same Size		II
132074596	V22555	07/26/2013	8:39	07/26/2013	11:58	1	199	199	Animal related	Transformer Fuse	Replace - Same Size		II
132075260	F03003	07/26/2013	8:48	07/26/2013	12:22	2	428	214	Underground equipment	Underground Primary	Repair		III
132074673	F03003	07/26/2013	8:48	07/26/2013	9:52	13	832	64	Underground equipment	Underground Primary		Repair	III
132074690	D36001	07/26/2013	8:49	07/26/2013	9:55	3	198	66	Weather	Disconnect Switch	Replace - Same Size		I
132074633	R16510	07/26/2013	8:49	07/26/2013	10:13	1	84	84	Animal related	Transformer Fuse	Replace - Same Size		I
132074666	L50215	07/26/2013	8:53	07/26/2013	10:09	1	76	76	Animal related	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
132074853	B00002	07/26/2013	9:36	07/26/2013	10:45	1	69	69	Overhead equipment	Overhead Service	Repair		I
132075240	B19002	07/26/2013	9:39	07/26/2013	11:49	10	1300	130	Overhead equipment	Fuse	Replace - Same Size	No Work Required	I
132075021	B73003	07/26/2013	9:45	07/26/2013	15:00	6	1890	315	Public	Pole	Patrol/Test/Inspect	Repair	I
132074957	M07235	07/26/2013	9:52	07/26/2013	12:24	1	152	152	Public	Overhead Secondary		Replace - Same Size	III
132075017	P47123	07/26/2013	10:01	07/26/2013	11:10	24	1656	69	Overhead equipment	Recloser	Switch/Reset		I
132075371	P47123	07/26/2013	10:06	07/26/2013	11:18	23	1656	72	Overhead equipment	Recloser	Switch/Reset		I
132075207	V21500	07/26/2013	10:11	07/26/2013	11:00	132	6468	49	Overhead equipment	Overhead Primary			II
132075836	B58001	07/26/2013	10:16	07/26/2013	12:45	96	14304	149	Overhead equipment	Overhead Primary	Repair		I
132075096	Z33507	07/26/2013	10:18	07/26/2013	11:30	1	72	72	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
132075282	V14579	07/26/2013	10:53	07/26/2013	11:58	1	65	65	Weather	Overhead Primary	Repair		II

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
132075524	P47123	07/26/2013	11:30	07/26/2013	13:10	41	4100	100	Overhead equipment	Recloser	Switch/Reset	Repair	I
132076216	K80386	07/26/2013	11:31	07/26/2013	15:35	6	1464	244	Underground equipment	Underground Transformer	Cut in Clear	Replace - Same Size	IV
132076210	K80386	07/26/2013	11:31	07/26/2013	14:40	5	945	189	Underground equipment	Underground Primary	Switch/Reset	Repair	IV
132075488	K80386	07/26/2013	11:31	07/26/2013	13:54	25	3575	143	Underground equipment	Underground Primary	Cut in Clear		IV
132075699	N15849	07/26/2013	12:10	07/26/2013	13:21	17	1207	71	Animal related	Fuse	Replace - Same Size	No Work Required	V
132075705	P47123	07/26/2013	12:21	07/26/2013	13:22	1	61	61	Overhead equipment	Recloser	Switch/Reset		I
132075617	K80386	07/26/2013	13:00	07/26/2013	13:54	59	3186	54	Underground equipment	Underground Primary	Cut in Clear		IV
132075988	307003	07/26/2013	13:18	07/26/2013	14:25	1	67	67	Overhead equipment	Fuse	Repair	Repair	VI
132076143	B58001	07/26/2013	13:43	07/26/2013	15:00	70	5390	77	Unknown	Fuse	Replace - Same Size	No Work Required	I
132076248	B61001	07/26/2013	14:10	07/26/2013	15:31	16	1296	81	Overhead equipment	Fuse	Replace - Same Size	Patrol/Test/Inspect	I
132076304	R10903	07/26/2013	14:22	07/26/2013	15:30	20	1360	68	Underground equipment	Underground Primary		Patrol/Test/Inspect	VI
132076395	J86118	07/26/2013	14:44	07/26/2013	15:34	1	50	50	Overhead equipment	Connector	Repair		VI
132076461	B45005	07/26/2013	15:02	07/26/2013	16:04	30	1860	62	Animal related	Fuse	Replace - Same Size	No Work Required	I
132076466	P98192	07/26/2013	15:06	07/26/2013	15:29	1	23	23	Other	Overhead Service			III
132076782	J89125	07/26/2013	15:30	07/26/2013	19:35	16	3920	245	Underground equipment	Underground Primary		Replace - Same Size	VI
132076548	J89125	07/26/2013	15:31	07/26/2013	17:10	39	3861	99	Underground equipment				VI
132076574	R10903	07/26/2013	15:39	07/26/2013	15:43	1	4	4	Underground equipment	Underground Primary	Cut in Clear		VI
132076618	V39002	07/26/2013	15:55	07/26/2013	17:34	1	99	99	Overhead equipment	Overhead Transformer	Replace - Same Size	Replace - Same Size	II
132076635	R10903	07/26/2013	16:02	07/26/2013	16:05	1	3	3	Underground equipment	Underground Primary	Cut in Clear	Repair	VI
132076650	V39002	07/26/2013	16:10	07/26/2013	17:45	8	760	95	Overhead equipment	Overhead Transformer	Replace - Same Size	Replace - Same Size	II
132076724	J89125	07/26/2013	16:40	07/26/2013	16:50	48	480	10	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	VI
132076746	B73002	07/26/2013	16:44	07/26/2013	19:21	50	7850	157	Overhead equipment	Crossarm	Replace - Same Size	Repair	I
132076967	Y26520	07/26/2013	17:51	07/26/2013	19:06	1	75	75	Tree related-tree broken	Tree	Repair	Repair	IV
132077449	A49001	07/26/2013	18:31	07/26/2013	19:15	1	44	44	Overhead equipment	Fuse	Replace - Same Size		I
132077536	B28006	07/26/2013	19:13	07/27/2013	4:49	63	36288	576	Underground equipment	Underground Primary	Switch/Reset	Repair	I
132077514	B58001	07/26/2013	19:16	07/26/2013	22:11	70	12250	175	Overhead equipment	Disconnect Switch	Replace - Same Size		I
132077530	R02120	07/26/2013	19:37	07/26/2013	20:05	1	28	28	Overhead equipment	Fuse	Repair	Repair	VI
132077808	U33586	07/26/2013	22:09	07/26/2013	23:12	1	63	63	Overhead equipment				II
132077812	P58154	07/26/2013	22:21	07/26/2013	23:50	23	2047	89	Tree related-tree broken				VI
132077840	N15850	07/26/2013	23:51	07/27/2013	3:28	1	217	217	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	V
132080046	N50331	07/27/2013	0:39	07/27/2013	3:06	436	64092	147	Overhead equipment	Recloser	Patrol/Test/Inspect		II
132080105	V04717	07/27/2013	1:08	07/27/2013	3:45	1788	280716	157	Tree related-tree broken				II
132080111	X23516	07/27/2013	2:42	07/27/2013	4:00	6	468	78	Overhead equipment	Disconnect Switch	Repair	Patrol/Test/Inspect	IV
132080116	V76526	07/27/2013	3:15	07/27/2013	7:00	14	3150	225	Tree related-tree broken				II
132080117	S36570	07/27/2013	3:21	07/27/2013	4:37	1	76	76	Animal related	Fuse	Repair		VI
132080175	V14579	07/27/2013	3:33	07/27/2013	7:30	168	39816	237	Overhead equipment	Crossarm	Repair	Repair	II
132080157	N50331	07/27/2013	3:36	07/27/2013	5:52	168	22848	136	Overhead equipment	Fuse	Repair		II
132080155	B19002	07/27/2013	3:37	07/27/2013	8:25	2	576	288	Underground equipment	Underground Primary		Repair	I
132080134	N50331	07/27/2013	3:42	07/27/2013	5:59	1	137	137	Overhead equipment				II
132080158	N50331	07/27/2013	4:46	07/27/2013	6:16	1	90	90	Overhead equipment				II
132080177	B45004	07/27/2013	5:05	07/27/2013	11:35	9	3510	390	Underground equipment	Underground Primary		Repair	I
132080166	N50331	07/27/2013	5:17	07/27/2013	6:28	1	71	71	Overhead equipment				II
132080179	Y73504	07/27/2013	6:09	07/27/2013	10:52	1	283	283	Underground equipment	Underground Secondary	Patrol/Test/Inspect	Repair	IV
132080194	L79180	07/27/2013	6:18	07/27/2013	7:50	19	1748	92	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	IV
132080212	Q34366	07/27/2013	6:54	07/27/2013	8:04	1	70	70	Animal related	Fuse	Replace - Same Size	Replace - Same Size	I
132080215	A91001	07/27/2013	6:56	07/27/2013	8:38	32	3264	102	Underground equipment	Underground Primary	Repair	Repair	I
132080219	V20502	07/27/2013	7:02	07/27/2013	8:34	1	92	92	Unknown	Transformer Fuse	Replace - Same Size		II
132080232	D90003	07/27/2013	7:32	07/27/2013	11:27	1	235	235	Underground equipment	Underground Primary	Repair		III
132080246	Q95249	07/27/2013	8:09	07/27/2013	8:50	1	41	41	Animal related	Fuse	Replace - Same Size		VI
132080265	D36002	07/27/2013	8:38	07/27/2013	9:32	1	54	54	Overhead equipment	Disconnect Switch	Replace - Same Size		I
132080282	B68003	07/27/2013	8:50	07/27/2013	10:15	1	85	85	Overhead equipment	Overhead Service	Repair		III
132080286	J83140	07/27/2013	8:54	07/27/2013	9:31	1	37	37	Animal related	Fuse	Replace - Same Size		VI
132080316	M09144	07/27/2013	9:23	07/27/2013	11:50	14	2058	147	Animal related	Overhead Primary	Replace - Same Size	Repair	VI
132080323	V10551	07/27/2013	9:34	07/27/2013	11:48	1	134	134	Weather	Fuse	Replace - Same Size		II
132080330	Y41559	07/27/2013	9:39	07/27/2013	11:00	1	81	81	Tree related-tree contact	Overhead Service			IV
132080338	D35001	07/27/2013	9:52	07/27/2013	16:00	1	368	368	Underground equipment	Underground Primary	Raise	Repair	I

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
132080339	K94224	07/27/2013	9:53	07/27/2013	11:33	1	100	100	Tree related-tree broken	Overhead Service	Repair		III
132080389	T12528	07/27/2013	10:15	07/27/2013	11:14	1	59	59	Animal related	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
132080395	X96524	07/27/2013	10:20	07/27/2013	11:45	1	85	85	Animal related	Fuse			IV
132080501	L74191	07/27/2013	11:50	07/27/2013	13:25	72	6840	95	Overhead equipment	Lightning Arrestor	Replace - Same Size	No Work Required	IV
132080503	N15850	07/27/2013	11:53	07/27/2013	13:49	1	116	116	Overhead equipment	Overhead Primary	Repair	No Work Required	V
132080511	U37579	07/27/2013	12:02	07/27/2013	14:27	8	1160	145	Overhead equipment	Jumper	Repair		II
132080528	K27150	07/27/2013	12:19	07/27/2013	13:10	10	510	51	Animal related	Fuse	Repair		VI
132080534	B71002	07/27/2013	12:30	07/27/2013	12:57	1	27	27	Overhead equipment	Transformer Fuse	Replace - Same Size		I
132080583	R99180	07/27/2013	13:41	07/27/2013	15:20	1	99	99	Overhead equipment	Fuse	Replace - Same Size	No Work Required	IV
132080625	B84006	07/27/2013	14:30	07/27/2013	23:25	5	2675	535	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
132080619	Y10012	07/27/2013	14:31	07/27/2013	16:00	1	89	89	Overhead equipment	Transformer Fuse	Repair	Repair	IV
132080618	P52305	07/27/2013	14:31	07/28/2013	2:28	1	717	717	Underground equipment	Underground Secondary		Switch/Reset	IV
132080629	H14343	07/27/2013	14:47	07/27/2013	16:39	1	112	112	Overhead equipment	Overhead Service	Repair	No Work Required	V
132080715	Q37372	07/27/2013	14:49	07/27/2013	17:00	46	6026	131	Animal related	Substation Recloser	Switch/Reset		I
132080651	R99180	07/27/2013	15:26	07/27/2013	23:30	1	484	484	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	IV
132080658	S88503	07/27/2013	15:35	07/27/2013	16:35	1	60	60	Animal related	Transformer Fuse	Replace - Same Size		VI
132080664	T16528	07/27/2013	15:43	07/27/2013	16:45	1	62	62	Overhead equipment	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
132080704	Y97514	07/27/2013	15:48	07/27/2013	15:51	585	1755	3	Overhead equipment	Substation Breaker			IV
132080723	U97528	07/27/2013	16:07	07/27/2013	18:01	10	1140	114	Underground equipment	Underground Primary	Repair	Replace - Same Size	II
132080738	D69003	07/27/2013	16:46	07/27/2013	20:26	47	10340	220	Underground equipment	Underground Primary	Replace - Same Size	Repair	I
132080776	X30506	07/27/2013	17:57	07/27/2013	19:25	1	88	88	Animal related	Transformer Fuse	Repair	Repair	IV
132080787	J34357	07/27/2013	18:03	07/28/2013	1:09	12	5112	426	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	V
132080788	U97528	07/27/2013	18:08	07/27/2013	22:06	1	238	238	Underground equipment	Underground Primary	Repair		II
132080799	J56341	07/27/2013	18:18	07/27/2013	21:30	30	5760	192	Underground equipment	Underground Primary	Switch/Reset	Repair	III
132080792	D48001	07/27/2013	18:19	07/28/2013	2:15	1	476	476	Public	Underground Transformer	Patrol/Test/Inspect	Repair	I
132080797	Q70161	07/27/2013	18:27	07/27/2013	20:30	1	123	123	Animal related	Transformer Fuse	Replace - Same Size		I
132080818	M21133	07/27/2013	19:12	07/27/2013	20:31	1	79	79	Overhead equipment	Fuse	Repair		VI
132080918	M12151	07/27/2013	22:13	07/28/2013	0:59	2	332	166	Overhead equipment	Overhead Primary	Repair		VI
132080896	M12151	07/27/2013	22:13	07/27/2013	23:45	101	9292	92	Overhead equipment				VI
132080894	K82202	07/27/2013	22:24	07/28/2013	0:26	1	122	122	Overhead equipment	Overhead Transformer		Replace - Same Size	III
132080902	D96002	07/27/2013	22:46	07/28/2013	6:42	1	476	476	Underground equipment	Underground Primary	Patrol/Test/Inspect	Patrol/Test/Inspect	I
132090006	B84003	07/27/2013	23:56	07/28/2013	4:12	30	7680	256	Underground equipment	Underground Primary	Patrol/Test/Inspect	Cut in Clear	I
132090057	T16528	07/28/2013	4:23	07/28/2013	9:30	1	307	307	Underground equipment	Underground Primary			VI
132090070	P73158	07/28/2013	5:54	07/28/2013	11:52	15	5370	358	Underground equipment	Underground Primary	Replace - Same Size	Replace - Same Size	VI
132090071	U16001	07/28/2013	6:15	07/28/2013	9:40	1	205	205	Overhead equipment	Overhead Transformer	Replace - Same Size	Replace - Same Size	II
132090076	K52401	07/28/2013	6:24	07/28/2013	8:11	33	3531	107	Animal related	Fuse	Replace - Same Size		V
132090083	M36189	07/28/2013	7:06	07/28/2013	8:20	1	74	74	Animal related	Overhead Transformer	Repair		I
132090147	M25144	07/28/2013	7:33	07/28/2013	10:30	1	177	177	Overhead equipment	Overhead Primary	Cut in Clear	Repair	IV
132090128	M25144	07/28/2013	7:33	07/28/2013	9:15	6	612	102	Overhead equipment	Overhead Primary	Cut in Clear	No Work Required	IV
132090100	S61531	07/28/2013	7:48	07/28/2013	8:55	1	67	67	Animal related	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
132090108	B93003	07/28/2013	7:57	07/28/2013	9:30	1	93	93	Animal related	Fuse	Replace - Same Size		I
132090117	N54214	07/28/2013	8:03	07/28/2013	10:25	13	1846	142	Animal related	Fuse	Repair		II
132090131	S60581	07/28/2013	8:30	07/28/2013	10:12	1	102	102	Animal related	Fuse	Repair		VI
132090144	B57001	07/28/2013	8:59	07/28/2013	12:08	7	1323	189	Animal related	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	I
132090161	Y66557	07/28/2013	9:44	07/28/2013	11:24	4	400	100	Overhead equipment	Transformer Fuse	Repair	Patrol/Test/Inspect	IV
132090186	C30002	07/28/2013	10:55	07/28/2013	11:45	8	400	50	Overhead equipment	Fuse	Replace - Same Size		III
132090188	S47575	07/28/2013	11:00	07/28/2013	11:45	1	45	45	Animal related	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
132090257	J88165	07/28/2013	11:09	07/28/2013	14:10	5	905	181	Animal related	Fuse	Replace - Same Size		VI
132090209	P19395	07/28/2013	11:27	07/28/2013	15:00	45	9585	213	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	V
132090197	D96001	07/28/2013	11:28	07/28/2013	12:56	4	352	88	Overhead equipment	Connector	Replace - Same Size		I
132090204	A85001	07/28/2013	11:31	07/28/2013	12:38	1	67	67	Animal related	Fuse	Replace - Same Size		I
132090226	X02546	07/28/2013	11:44	07/28/2013	16:38	14	4116	294	Underground equipment	Underground Primary	Repair	Repair	IV
132090227	A81001	07/28/2013	11:55	07/28/2013	13:30	1	95	95	Overhead equipment	Connector	Replace - Same Size	No Work Required	I
132090240	L17104	07/28/2013	12:39	07/28/2013	13:57	1	78	78	Overhead equipment	Lightning Arrestor	Repair		III
132090249	D93001	07/28/2013	12:56	07/28/2013	14:45	1	109	109	Overhead equipment	Jumper	Repair		IV
132090256	R49261	07/28/2013	12:56	07/28/2013	16:39	82	18286	223	Underground equipment	Fuse		Patrol/Test/Inspect	VI

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
132090306	B21004	07/28/2013	13:17	07/28/2013	17:07	7	1610	230	Tree related-tree broken	Overhead Primary	Patrol/Test/Inspect	Repair	I
132090320	B73003	07/28/2013	13:57	07/28/2013	15:00	27	1701	63	Underground equipment	Underground Primary			I
132090323	V69558	07/28/2013	14:01	07/28/2013	15:13	1	72	72	Animal related	Transformer Fuse	Replace - Same Size		II
132090335	M07236	07/28/2013	14:54	07/28/2013	16:30	1	96	96	Animal related	Transformer Fuse	Replace - Same Size		III
132090341	B73003	07/28/2013	15:05	07/28/2013	18:26	2	402	201	Underground equipment	Underground Primary		Repair	I
132090344	K73362	07/28/2013	15:11	07/28/2013	19:29	1	258	258	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Repair	IV
132090370	303007	07/28/2013	16:29	07/28/2013	17:21	5	260	52	Tree related-tree broken	Tree	Remove		VI
132090382	307003	07/28/2013	16:49	07/28/2013	18:30	1	101	101	Tree related-tree broken	Tree	Remove		VI
132090426	R05186	07/28/2013	18:46	07/28/2013	23:30	28	7952	284	Underground equipment	Overhead Transformer	Replace - Same Size	Replace - Same Size	I
132090427	K27150	07/28/2013	18:52	07/28/2013	19:40	1	48	48	Animal related	Fuse	Repair		VI
132090432	X23516	07/28/2013	19:21	07/28/2013	20:56	6	570	95	Overhead equipment	Transformer Fuse			IV
132090447	M37192	07/28/2013	20:17	07/28/2013	20:31	82	1148	14	Overhead equipment	Fuse	Replace - Same Size		I
132090457	D92001	07/28/2013	20:31	07/28/2013	23:10	93	14787	159	Underground equipment	Underground Primary	Patrol/Test/Inspect	Switch/Reset	I
132100110	U84534	07/28/2013	23:53	07/29/2013	1:15	65	5330	82	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	II
132100108	S30518	07/29/2013	0:36	07/29/2013	1:45	1	69	69	Animal related	Fuse	Repair		VI
132104228	Y45504	07/29/2013	3:46	07/29/2013	4:37	1	51	51	Overhead equipment	Transformer Fuse	Repair	Replace - Same Size	IV
132104240	D31016	07/29/2013	5:52	07/29/2013	7:50	1	118	118	Overhead equipment	Fuse	Replace - Same Size		III
132104290	K78352	07/29/2013	7:03	07/29/2013	8:16	8	584	73	Animal related	Fuse	Replace - Same Size		IV
132104334	V46552	07/29/2013	7:20	07/29/2013	13:26	1	366	366	Underground equipment	Underground Primary	Repair	Repair	II
132104373	Y91500	07/29/2013	7:29	07/29/2013	8:35	11	726	66	Animal related	Transformer Fuse	Repair	Replace - Same Size	IV
132104456	X64503	07/29/2013	7:55	07/29/2013	9:15	1	80	80	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
132104582	U68581	07/29/2013	8:21	07/29/2013	9:03	1	42	42	Animal related	Transformer Fuse	Repair		II
132104668	D93002	07/29/2013	8:36	07/29/2013	10:43	9	1143	127	Animal related	Overhead Transformer	No Work Required	No Work Required	IV
132104865	M47802	07/29/2013	8:57	07/29/2013	9:57	23	1380	60	Animal related	Fuse	Repair	Repair	V
132105010	S93553	07/29/2013	9:38	07/29/2013	10:01	391	8993	23	Overhead equipment	Ground Wire	Cut in Clear		VI
132105085	S28552	07/29/2013	9:56	07/29/2013	11:40	1	104	104	Animal related	Fuse	Replace - Same Size	Replace - Same Size	VI
132105117	K39153	07/29/2013	10:02	07/29/2013	10:30	1	28	28	Overhead equipment	Overhead Primary	Repair		III
132105205	J71129	07/29/2013	10:16	07/29/2013	12:15	1	119	119	Overhead equipment	Disconnect Switch	Patrol/Test/Inspect	Replace - Same Size	I
132105599	D93001	07/29/2013	11:27	07/29/2013	13:51	1	144	144	Animal related	Overhead Transformer	No Work Required	No Work Required	IV
132105667	C70001	07/29/2013	11:38	07/29/2013	15:56	1	258	258	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	III
132105752	P49180	07/29/2013	11:57	07/29/2013	13:40	1	103	103	Overhead equipment	Overhead Service	Reconnect		I
132105781	D69004	07/29/2013	12:01	07/29/2013	14:45	260	42640	164	Underground equipment	Underground Primary		Patrol/Test/Inspect	I
132106232	P62138	07/29/2013	13:23	07/29/2013	14:22	1	59	59	Overhead equipment	Overhead Primary	Remove		VI
132106249	U64518	07/29/2013	13:25	07/29/2013	14:00	1	35	35	Animal related	Fuse	Replace - Same Size		II
132106782	S61581	07/29/2013	14:47	07/29/2013	15:11	1	24	24	Animal related	Fuse	Replace - Same Size	Replace - Same Size	VI
132107198	M45211	07/29/2013	15:02	07/29/2013	17:30	21	3108	148	Overhead equipment	Overhead Primary	Repair		IV
132106910	Q91175	07/29/2013	15:08	07/29/2013	20:10	1	302	302	Overhead equipment	Overhead Transformer		Replace - Same Size	I
132107007	L17102	07/29/2013	15:25	07/29/2013	16:55	1	90	90	Tree related-tree contact	Overhead Service	Repair		III
132107042	K80386	07/29/2013	15:30	07/29/2013	17:51	42	5922	141	Underground equipment	Underground Connector	Repair		IV
132107140	Z04002	07/29/2013	15:53	07/29/2013	19:05	1	192	192	Public	Overhead Transformer	Replace - Same Size	Replace - Same Size	IV
132107197	A49003	07/29/2013	16:10	07/29/2013	17:14	7	448	64	Animal related	Fuse	Replace - Same Size		I
132107237	J56342	07/29/2013	16:13	07/29/2013	18:50	8	1256	157	Underground equipment	Underground Primary			III
132107302	N54214	07/29/2013	16:32	07/29/2013	19:09	58	9106	157	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	II
132107343	A56013	07/29/2013	16:44	07/29/2013	18:33	1	109	109	Overhead equipment	Overhead Service	Repair		I
132107353	K80386	07/29/2013	16:48	07/29/2013	16:53	1	5	5	Other	Other			IV
132107387	P77235	07/29/2013	16:58	07/29/2013	18:59	5	605	121	Animal related	Transformer Fuse	Replace - Same Size		VI
132107483	X57566	07/29/2013	17:34	07/29/2013	19:00	1	86	86	Animal related	Fuse	Replace - Same Size		IV
132107809	D01001	07/29/2013	18:50	07/29/2013	21:38	1	168	168	Animal related	Fuse	Replace - Same Size		I
132108432	B81003	07/29/2013	20:58	07/29/2013	22:00	21	1302	62	Animal related	Fuse	Replace - Same Size		I
132108433	L79159	07/29/2013	21:04	07/29/2013	23:05	10	1210	121	Animal related	Tree	Trim		IV
132108439	H07106	07/29/2013	21:13	07/30/2013	1:45	1	272	272	Underground equipment	Underground Service	Patrol/Test/Inspect	Repair	IV
132108442	R01152	07/29/2013	21:18	07/29/2013	22:05	1	47	47	Animal related	Other			III
132108452	J46180	07/29/2013	21:37	07/29/2013	22:21	1	44	44	Unknown	Other			III
132108455	A16002	07/29/2013	21:41	07/29/2013	23:52	1	131	131	Overhead equipment	Overhead Service	Repair		I
132111764	V40549	07/30/2013	3:01	07/30/2013	6:15	5	970	194	Overhead equipment				II
132114064	V99562	07/30/2013	4:37	07/30/2013	6:44	1	127	127	Tree related-tree contact	Tree	Cut in Clear		II

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
132114105	HA5431	07/30/2013	5:24	07/30/2013	7:18	1	114	114	Overhead equipment	Overhead Service	Advise Customer	Replace - Same Size	V
132114164	L70128	07/30/2013	6:05	07/30/2013	8:00	9	1035	115	Overhead equipment	Fuse			IV
132114144	J80807	07/30/2013	6:23	07/30/2013	9:57	55	11770	214	Overhead equipment	Overhead Primary	Repair	Repair	V
132114349	M48814	07/30/2013	6:35	07/30/2013	8:35	204	24480	120	Unknown				V
132114160	341002	07/30/2013	6:43	07/30/2013	9:30	30	5010	167	Overhead equipment	Overhead Primary	Patrol/Test/Inspect	Repair	VI
132114162	R28870	07/30/2013	6:46	07/30/2013	7:46	1	60	60	Animal related	Fuse	Repair		V
132114169	V03562	07/30/2013	6:54	07/30/2013	8:25	1	91	91	Weather	Lightning Arrestor	Replace - Same Size		II
132114271	X02548	07/30/2013	7:35	07/30/2013	8:19	1	44	44	Animal related	Lightning Arrestor	Move		IV
132114280	Q06131	07/30/2013	7:38	07/30/2013	8:10	1	32	32	Animal related	Transformer Fuse	Replace - Same Size		IV
132114304	M53312	07/30/2013	7:46	07/30/2013	9:28	1	102	102	Jurisdictional				V
132114416	J89126	07/30/2013	8:15	07/30/2013	9:05	1	50	50	Overhead equipment	Fuse	Repair		VI
132114571	D81001	07/30/2013	8:56	07/30/2013	11:18	1	142	142	Overhead equipment	Other	Replace - Same Size	Replace - Same Size	I
132114634	311003	07/30/2013	9:00	07/30/2013	11:22	20	2840	142	Tree related-tree broken	Overhead Primary	Patrol/Test/Inspect	Repair	VI
132114590	Q82906	07/30/2013	9:04	07/30/2013	9:40	1	36	36	Overhead equipment	Fuse			VI
132114680	P47169	07/30/2013	9:24	07/30/2013	10:41	1	77	77	Overhead equipment	Transformer Fuse	Replace - Same Size		I
132114734	P47120	07/30/2013	9:36	07/30/2013	13:26	1	230	230	Overhead equipment	Transformer Fuse	Replace - Same Size	Replace - Same Size	I
132114759	S13546	07/30/2013	9:43	07/30/2013	10:30	1	47	47	Animal related	Disconnect Switch	Replace - Same Size		VI
132114923	T04512	07/30/2013	9:57	07/30/2013	11:32	22	2090	95	Overhead equipment	Overhead Primary			VI
132114992	A80001	07/30/2013	10:29	07/30/2013	12:00	1	91	91	Overhead equipment	Fuse	Repair		I
132115071	D37003	07/30/2013	10:44	07/30/2013	11:46	2	124	62	Tree related-tree contact	Tree	Trim	No Work Required	I
132115116	P25152	07/30/2013	10:51	07/30/2013	12:50	5	595	119	Underground equipment	Underground Primary	Switch/Reset	Repair	III
132115252	L42158	07/30/2013	11:09	07/30/2013	13:20	167	21877	131	Overhead equipment	Pole	Patrol/Test/Inspect	Replace - Same Size	III
132115400	Q32170	07/30/2013	11:23	07/30/2013	12:15	129	6708	52	Animal related	Fuse	Replace - Same Size	Patrol/Test/Inspect	I
132115349	B58001	07/30/2013	11:24	07/30/2013	13:10	129	13674	106	Unknown	Fuse	Replace - Same Size		I
132115548	B93003	07/30/2013	12:05	07/30/2013	13:12	1	67	67	Animal related	Fuse	Repair	Replace - Same Size	I
132115696	K94224	07/30/2013	12:34	07/30/2013	12:56	1	22	22	Underground equipment	Underground Primary	Repair		III
132116782	D87002	07/30/2013	12:52	07/30/2013	22:10	2	1116	558	Underground equipment	Underground Primary	Repair	Repair	I
132115783	K09863	07/30/2013	12:52	07/30/2013	17:15	1	263	263	Underground equipment	Underground Secondary	Replace - New Size	Replace - New Size	V
132115788	D87002	07/30/2013	12:52	07/30/2013	14:52	27	3240	120	Underground equipment	Underground Primary	Switch/Reset	Patrol/Test/Inspect	I
132115917	D41003	07/30/2013	13:16	07/30/2013	14:10	1	54	54	Overhead equipment	Transformer Fuse	Replace - Same Size		I
132115956	S14511	07/30/2013	13:25	07/30/2013	13:52	1	27	27	Animal related	Transformer Fuse	Replace - Same Size		VI
132116083	L82188	07/30/2013	13:30	07/30/2013	16:15	3	495	165	Underground equipment	Underground Primary			IV
132116448	Q64919	07/30/2013	13:30	07/30/2013	14:55	7	595	85	Overhead equipment	Pole	Patrol/Test/Inspect	Replace - Same Size	VI
132116027	D88001	07/30/2013	13:38	07/30/2013	15:02	9	756	84	Overhead equipment	Fuse	Repair		I
132116811	S57502	07/30/2013	13:47	07/30/2013	18:00	14	3542	253	Overhead equipment	Crossarm			VI
132116126	S59737	07/30/2013	13:47	07/30/2013	15:53	303	38178	126	Overhead equipment				VI
132116142	J56342	07/30/2013	13:55	07/30/2013	15:50	1	115	115	Overhead equipment	Overhead Service	Repair		III
132116351	K91117	07/30/2013	14:27	07/30/2013	15:30	9	567	63	Tree related-tree broken	Tree	Remove		III
132116306	K91117	07/30/2013	14:28	07/30/2013	15:06	25	950	38	Overhead equipment	Overhead Primary	Switch/Reset	No Work Required	III
132116359	D81003	07/30/2013	14:40	07/30/2013	18:00	101	20200	200	Underground equipment	Underground Primary		Repair	I
132116288	J80806	07/30/2013	14:41	07/30/2013	19:04	1	263	263	Tree related-tree contact	Pole	Replace - Same Size	Replace - Same Size	V
132116456	Q64919	07/30/2013	14:55	07/30/2013	17:25	1	150	150	Overhead equipment	Pole	Replace - Same Size		VI
132116585	Q82906	07/30/2013	15:22	07/30/2013	16:20	1	58	58	Animal related	Overhead Primary			VI
132116630	303006	07/30/2013	15:32	07/30/2013	16:24	1	52	52	Public	Meter	Patrol/Test/Inspect		VI
132116743	J47178	07/30/2013	15:58	07/30/2013	17:09	1	71	71	Unknown				III
132116765	R10925	07/30/2013	16:03	07/30/2013	16:50	1	47	47	Overhead equipment	Connector	Replace - New Size		VI
132116862	X23516	07/30/2013	16:24	07/30/2013	17:37	1	73	73	Overhead equipment	Overhead Service	Repair	Patrol/Test/Inspect	IV
132116924	U09517	07/30/2013	16:44	07/30/2013	17:47	3	189	63	Overhead equipment	Disconnect Switch	Repair		II
132117055	P26284	07/30/2013	16:46	07/30/2013	18:45	1	119	119	Overhead equipment	Pole			I
132116980	J61115	07/30/2013	17:04	07/30/2013	18:22	1	78	78	Unknown				III
132117003	L70127	07/30/2013	17:09	07/30/2013	18:35	1	86	86	Tree related-tree contact	Overhead Service	Repair		IV
132117022	M21133	07/30/2013	17:16	07/30/2013	18:18	1	62	62	Animal related	Fuse	Repair		VI
132117056	B44002	07/30/2013	17:37	07/30/2013	18:55	9	702	78	Overhead equipment	Fuse	Replace - Same Size		I
132117081	T16528	07/30/2013	17:48	07/30/2013	19:19	1	91	91	Overhead equipment	Fuse			VI
132117116	P07179	07/30/2013	18:02	07/30/2013	19:55	1	113	113	Overhead equipment	Transformer Fuse	Replace - Same Size	No Work Required	I
132117124	M09175	07/30/2013	18:08	07/30/2013	20:32	1	144	144	Tree related-tree contact	Overhead Service	Replace - Same Size	Repair	VI

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
132117131	D32211	07/30/2013	18:10	07/31/2013	0:58	1	408	408	Underground equipment	Underground Primary		Repair	I
132117357	V92555	07/30/2013	18:47	07/30/2013	20:30	1	103	103	Overhead equipment	Tree	Cut in Clear		II
132117355	J61114	07/30/2013	18:47	07/30/2013	19:18	1	31	31	Unknown				III
132117808	T06505	07/30/2013	19:00	07/30/2013	19:57	1	57	57	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	VI
132117854	S60581	07/30/2013	19:35	07/31/2013	6:15	8	5120	640	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	VI
132117885	L79157	07/30/2013	20:13	07/30/2013	21:25	1	72	72	Animal related	Transformer Fuse	Replace - Same Size		IV
132117887	K43382	07/30/2013	20:16	07/30/2013	20:39	1	23	23	Jurisdictional				V
132118123	A68002	07/30/2013	21:41	07/30/2013	23:29	1	108	108	Tree related-tree contact	Overhead Service	Repair		I
132118125	D55001	07/30/2013	21:42	07/30/2013	22:50	1	68	68	Jurisdictional	Meter	Reconnect		I
132118133	J99128	07/30/2013	22:08	07/30/2013	23:32	1	84	84	Tree related-tree contact	Tree	Patrol/Test/Inspect		VI
132118136	D72003	07/30/2013	22:16	07/30/2013	23:10	1	54	54	Tree related-tree broken	Tree	Remove	Patrol/Test/Inspect	I
132118158	D39001	07/30/2013	22:59	07/31/2013	1:34	14	2170	155	Overhead equipment	Connector	Replace - Same Size		I
132120088	A81001	07/31/2013	0:02	07/31/2013	6:25	1	383	383	Underground equipment	Underground Primary	Patrol/Test/Inspect	Replace - Urgent	I
132120109	S84710	07/31/2013	0:20	07/31/2013	1:40	2431	194480	80	Overhead equipment				VI
132120114	335002	07/31/2013	0:38	07/31/2013	2:20	11	1122	102	Overhead equipment	Overhead Primary	Patrol/Test/Inspect		VI
132120298	M54316	07/31/2013	3:08	07/31/2013	5:16	1	128	128	Overhead equipment	Overhead Service	Patrol/Test/Inspect		V
132124686	A85002	07/31/2013	3:59	07/31/2013	5:28	12	1068	89	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
132124690	S04545	07/31/2013	4:21	07/31/2013	9:30	1	309	309	Tree related-tree broken	Crossarm	Repair	Repair	VI
132124694	B73001	07/31/2013	4:40	07/31/2013	6:47	1	127	127	Overhead equipment	Fuse			I
132124699	B58001	07/31/2013	4:49	07/31/2013	6:54	129	16125	125	Overhead equipment	Fuse	Patrol/Test/Inspect	Replace - Same Size	I
132126015	B76003	07/31/2013	5:02	07/31/2013	11:07	27	9855	365	Underground equipment	Underground Primary	Switch/Reset		I
132125423	B76003	07/31/2013	5:02	07/31/2013	12:41	15	6885	459	Underground equipment	Underground Primary		Repair	I
132124702	B76003	07/31/2013	5:02	07/31/2013	9:10	63	15624	248	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
132124717	K74164	07/31/2013	5:17	07/31/2013	7:42	1	145	145	Tree related-tree contact			No Work Required	IV
132124767	T15570	07/31/2013	5:48	07/31/2013	7:25	1	97	97	Tree related-tree broken	Overhead Service	Repair	Repair	VI
132124789	A45003	07/31/2013	6:11	07/31/2013	13:17	1	426	426	Underground equipment	Underground Primary		Patrol/Test/Inspect	I
132124798	Y66557	07/31/2013	6:16	07/31/2013	12:45	61	23729	389	Underground equipment	Underground Primary	Repair	Repair	IV
132124902	X85723	07/31/2013	6:27	07/31/2013	11:08	1	281	281	Overhead equipment	Crossarm	Replace - Same Size		IV
132125142	X85723	07/31/2013	6:27	07/31/2013	8:00	1430	132990	93	Overhead equipment				IV
132124864	Z10500	07/31/2013	6:51	07/31/2013	9:30	2	318	159	Unknown	Transformer Fuse	Replace - Same Size		IV
132124914	K32932	07/31/2013	7:06	07/31/2013	8:12	1	66	66	Overhead equipment	Fuse	Replace - Same Size		VI
132124980	A85001	07/31/2013	7:19	07/31/2013	15:45	3	1518	506	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
132124976	J87120	07/31/2013	7:22	07/31/2013	8:04	9	378	42	Animal related	Fuse	Replace - Same Size		VI
132125085	N70331	07/31/2013	7:52	07/31/2013	10:22	1	150	150	Tree related-tree contact	Overhead Service	Repair		I
132125166	B80003	07/31/2013	8:13	07/31/2013	9:40	60	5220	87	Unknown	Overhead Primary	Patrol/Test/Inspect		I
132125244	X96543	07/31/2013	8:33	07/31/2013	10:26	1	113	113	Unknown	Transformer Fuse			IV
132125308	P98191	07/31/2013	8:42	07/31/2013	9:27	12	540	45	Animal related	Transformer Fuse	Repair	Repair	III
132125509	R48165	07/31/2013	9:19	07/31/2013	11:09	8	880	110	Public	Pole		Replace - Same Size	IV
132125505	M09144	07/31/2013	9:27	07/31/2013	11:02	1	95	95	Transmission outage	Other			VI
132125521	P47123	07/31/2013	9:30	07/31/2013	12:53	1	203	203	Overhead equipment	Overhead Service	Tie/Tighten		I
132125561	R48165	07/31/2013	9:40	07/31/2013	10:34	1	54	54	Overhead equipment	Pole	Replace - Same Size		IV
132125576	L24122	07/31/2013	9:48	07/31/2013	11:01	1	73	73	Overhead equipment	Overhead Service	Repair		III
132125647	J74125	07/31/2013	10:03	07/31/2013	11:21	1	78	78	Animal related	Fuse	Repair	Replace - Same Size	VI
132125863	Q82907	07/31/2013	10:41	07/31/2013	11:03	1	22	22	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	VI
132125874	R95520	07/31/2013	10:43	07/31/2013	12:38	1	115	115	Overhead equipment	Transformer Fuse	Repair		I
132125945	U52516	07/31/2013	10:55	07/31/2013	12:02	5	335	67	Weather	Lightning Arrestor	Repair		II
132125958	308002	07/31/2013	10:57	07/31/2013	11:57	1	60	60	Jurisdictional	Overhead Service	Reconnect		VI
132126006	S43511	07/31/2013	11:05	07/31/2013	11:43	1	38	38	Animal related	Transformer Fuse	Raise	No Work Required	VI
132126128	N22295	07/31/2013	11:21	07/31/2013	11:24	177	531	3	Substation equipment	Substation Breaker	Replace - Same Size		VI
132126153	P19395	07/31/2013	11:21	07/31/2013	12:44	45	3735	83	Animal related	Connector			V
132126307	P49187	07/31/2013	11:48	07/31/2013	12:15	1	27	27	Tree related-tree broken	Overhead Service	Repair	Replace - Same Size	I
132126771	K15205	07/31/2013	13:09	07/31/2013	14:27	1	78	78	Overhead equipment	Meter	Replace - Same Size		VI
132126819	U02597	07/31/2013	13:15	07/31/2013	14:00	1	45	45	Overhead equipment	Lightning Arrestor	Replace - Same Size	Patrol/Test/Inspect	II
132126835	M73331	07/31/2013	13:18	07/31/2013	15:34	1	136	136	Tree related-tree broken	Tree	Trim		V
132126966	Y63539	07/31/2013	13:41	07/31/2013	15:08	1	87	87	Public	Overhead Service	Repair		IV
132127387	C66001	07/31/2013	14:43	07/31/2013	15:34	54	2754	51	Overhead equipment	Fuse	Replace - Same Size		III

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
132127435	J63172	07/31/2013	14:54	07/31/2013	16:21	52	4524	87	Underground equipment	Underground Primary	Switch/Reset	Repair	III
132127645	Z19547	07/31/2013	15:37	07/31/2013	18:03	1	146	146	Unknown	Transformer Fuse	Repair	Patrol/Test/Inspect	IV
132127642	R04407	07/31/2013	15:37	07/31/2013	19:59	7	1834	262	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	V
132128971	C00002	07/31/2013	16:31	08/01/2013	0:26	2	950	475	Underground equipment	Underground Primary	Repair		I
132127959	C00002	07/31/2013	16:31	07/31/2013	20:40	14	3486	249	Underground equipment	Underground Primary	Patrol/Test/Inspect	Patrol/Test/Inspect	I
132128003	R28870	07/31/2013	16:48	07/31/2013	21:36	4	1152	288	Overhead equipment				V
132128039	X96524	07/31/2013	17:01	07/31/2013	22:08	1	307	307	Public	Underground Service	Repair		IV
132128125	K57211	07/31/2013	17:31	07/31/2013	18:35	1	64	64	Animal related	Animal Guard	Install	Replace - Same Size	VI
132128132	R84148	07/31/2013	17:34	07/31/2013	20:47	12	2316	193	Unknown	Fuse	Replace - Same Size	No Work Required	I
132128193	341002	07/31/2013	17:56	07/31/2013	18:37	1	41	41	Tree related-tree contact	Other			VI
132128241	J86118	07/31/2013	18:25	07/31/2013	22:04	4	876	219	Overhead equipment	Overhead Transformer	Disconnect	Replace - Same Size	VI
132128923	Z33507	07/31/2013	20:38	07/31/2013	21:05	1	27	27	Overhead equipment	Overhead Service	Repair	Replace - Same Size	IV
132128925	M09143	07/31/2013	20:44	07/31/2013	21:22	1	38	38	Other	Fuse	Replace - Same Size	Repair	VI
132128991	Y04504	07/31/2013	22:16	07/31/2013	23:10	1	54	54	Animal related	Fuse	Replace - Same Size		IV
132129004	U44529	07/31/2013	23:24	08/01/2013	1:53	1	149	149	Overhead equipment	Transformer Fuse	Repair		II
132130294	D89002	08/01/2013	2:20	08/01/2013	6:43	83	21829	263	Tree related-tree broken	Overhead Primary		Repair	I
132131745	K69117	08/01/2013	3:31	08/01/2013	7:01	20	4200	210	Underground equipment	Underground Transformer	Switch/Reset	Repair	IV
132135144	N60181	08/01/2013	3:53	08/01/2013	5:35	20	2040	102	Underground equipment	Underground Primary	Repair	Repair	I
132135431	D16004	08/01/2013	4:42	08/01/2013	10:26	32	11008	344	Underground equipment	Underground Primary		Repair	I
132135433	X57566	08/01/2013	4:42	08/01/2013	7:45	267	48861	183	Public	Overhead Primary	Repair	Repair	IV
132135462	D55002	08/01/2013	5:32	08/01/2013	6:33	3	183	61	Overhead equipment	Fuse			I
132135464	D87002	08/01/2013	5:33	08/01/2013	10:10	1	277	277	Underground equipment	Underground Primary		Repair	I
132135507	Q67938	08/01/2013	6:35	08/01/2013	8:05	1	90	90	Overhead equipment	Connector	Repair		VI
132135572	Q91175	08/01/2013	7:14	08/01/2013	8:46	1	92	92	Animal related	Transformer Fuse	Replace - Same Size		I
132135790	X96543	08/01/2013	8:08	08/01/2013	13:45	1	337	337	Underground equipment	Underground Primary	Repair		IV
132136079	S49550	08/01/2013	8:16	08/01/2013	9:30	3	222	74	Overhead equipment				VI
132135891	B68004	08/01/2013	8:26	08/01/2013	9:28	1	62	62	Overhead equipment	Overhead Service	Repair		III
132136609	B93002	08/01/2013	8:37	08/01/2013	17:15	3	1554	518	Underground equipment	Underground Primary	Repair	No Work Required	I
132136222	B93002	08/01/2013	8:37	08/01/2013	10:24	8	856	107	Underground equipment	Underground Primary	Repair	Replace - Same Size	I
132136062	L08226	08/01/2013	8:58	08/01/2013	10:15	3	231	77	Overhead equipment	Insulator	Replace - Same Size		III
132136243	K62102	08/01/2013	9:32	08/01/2013	11:23	1	111	111	Weather	Transformer Fuse	Replace - Same Size		II
132136947	D36001	08/01/2013	9:35	08/01/2013	14:58	5	1615	323	Public	Pole	Replace - Same Size	Repair	I
132136302	P82291	08/01/2013	9:50	08/01/2013	11:17	68	5916	87	Jurisdictional	Recloser	Patrol/Test/Inspect	Switch/Reset	VI
132136400	K55398	08/01/2013	9:54	08/01/2013	11:01	1	67	67	Tree related-tree broken	Overhead Service	Repair	Reconnect	V
132136536	V41533	08/01/2013	10:12	08/01/2013	10:36	1	24	24	Other				II
132136838	V99562	08/01/2013	10:26	08/01/2013	12:10	77	8008	104	Overhead equipment	Overhead Primary	Repair	Repair	II
132136706	R68903	08/01/2013	10:31	08/01/2013	14:01	7	1470	210	Animal related	Overhead Transformer	Replace - Same Size	No Work Required	I
132137257	J89126	08/01/2013	11:53	08/01/2013	13:33	1	100	100	Overhead equipment	Overhead Service		Repair	VI
132137288	Q32171	08/01/2013	11:58	08/01/2013	14:12	1	134	134	Tree related-tree broken	Overhead Service			I
132137408	K71812	08/01/2013	12:15	08/01/2013	13:45	21	1890	90	Overhead equipment	Fuse	Replace - Same Size		IV
132137255	Q21423	08/01/2013	12:18	08/01/2013	12:49	1	31	31	Underground equipment	Underground Secondary	Cut in Clear	Repair	VI
132137600	U80511	08/01/2013	13:02	08/01/2013	13:35	1	33	33	Overhead equipment	Fuse	Repair		II
132138049	N18210	08/01/2013	14:15	08/01/2013	19:12	13	3861	297	Underground equipment	Underground Primary	Repair		III
132138113	P85141	08/01/2013	14:35	08/01/2013	15:25	1	50	50	Overhead equipment	Overhead Transformer			III
132138199	L23145	08/01/2013	14:50	08/01/2013	15:25	1	35	35	Animal related	Transformer Fuse	Replace - Same Size		III
132138356	S64505	08/01/2013	14:51	08/01/2013	14:58	58	406	7	Underground equipment	Substation Breaker			VI
132138318	K07320	08/01/2013	15:12	08/01/2013	16:20	1	68	68	Tree related-tree contact	Other	No Work Required	No Work Required	I
132138337	S64502	08/01/2013	15:13	08/01/2013	15:36	1	23	23	Underground equipment	Underground Primary	Switch/Reset		VI
132138365	S64505	08/01/2013	15:20	08/01/2013	15:36	1	16	16	Underground equipment	Underground Primary	Switch/Reset		VI
132138411	K71822	08/01/2013	15:25	08/01/2013	16:30	127	8255	65	Overhead equipment	Fuse	Replace - Same Size	No Work Required	IV
132138493	X02547	08/01/2013	15:57	08/01/2013	16:41	1	44	44	Unknown	Transformer Fuse	Replace - Same Size		IV
132138538	A56013	08/01/2013	16:10	08/01/2013	17:56	1	106	106	Overhead equipment	Connector	Replace - Same Size		I
132138553	D90004	08/01/2013	16:14	08/01/2013	17:03	1	49	49	Overhead equipment	Overhead Service	Repair		III
132138728	N05172	08/01/2013	17:08	08/01/2013	18:26	1	78	78	Overhead equipment	Transformer Fuse	Replace - Same Size		I
132138787	V46563	08/01/2013	17:30	08/01/2013	22:28	2	596	298	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	II
132138797	Y31589	08/01/2013	17:35	08/01/2013	18:46	1	71	71	Tree related-tree broken	Overhead Service	Raise		IV

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
132138867	R49261	08/01/2013	18:05	08/01/2013	19:40	1	95	95	Overhead equipment	Transformer Fuse		Patrol/Test/Inspect	VI
132138883	B80004	08/01/2013	18:08	08/01/2013	21:23	69	13455	195	Underground equipment	Other		Repair	I
132139054	B93002	08/01/2013	18:32	08/01/2013	21:21	1	169	169	Overhead equipment	Connector	Replace - Same Size		I
132139536	S55534	08/01/2013	18:44	08/01/2013	20:50	8	1008	126	Overhead equipment	Fuse	Repair	Replace - Same Size	VI
132139473	Y10011	08/01/2013	18:53	08/01/2013	21:35	5	810	162	Overhead equipment	Disconnect Switch	Replace - Same Size		IV
132139480	S55534	08/01/2013	18:57	08/01/2013	20:50	1	113	113	Overhead equipment	Fuse	Repair	Replace - Same Size	VI
132139503	B80004	08/01/2013	19:14	08/01/2013	21:28	1	134	134	Underground equipment	Underground Primary			I
132139620	R06212	08/01/2013	21:14	08/01/2013	22:48	5	470	94	Animal related	Underground Primary	Repair		II
132139640	K28180	08/01/2013	23:03	08/02/2013	0:25	1	82	82	Unknown	Fuse	Replace - Same Size		III
132139650	K31120	08/01/2013	23:32	08/02/2013	2:10	1	158	158	Overhead equipment	Disconnect Switch	Repair	Repair	I
132140195	T04513	08/02/2013	1:51	08/02/2013	3:00	1	69	69	Overhead equipment	Overhead Service			VI
132145696	K78352	08/02/2013	5:48	08/02/2013	13:15	5	2235	447	Underground equipment	Underground Primary		Repair	IV
132147058	K78352	08/02/2013	5:48	08/02/2013	10:30	15	4230	282	Underground equipment	Underground Primary			IV
132145734	J89126	08/02/2013	6:59	08/02/2013	7:34	3	105	35	Overhead equipment	Fuse	Repair	Repair	VI
132145740	M54292	08/02/2013	7:07	08/02/2013	8:42	1	95	95	Overhead equipment	Transformer Fuse	Replace - Same Size		V
132145773	B80004	08/02/2013	7:16	08/02/2013	9:22	1	126	126	Unknown	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	I
132145780	J71128	08/02/2013	7:17	08/02/2013	8:30	1	73	73	Animal related	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	I
132145778	J89125	08/02/2013	7:17	08/02/2013	8:50	1	93	93	Overhead equipment	Customer Equipment	No Work Required	No Work Required	VI
132145803	B77001	08/02/2013	7:24	08/02/2013	15:05	1	461	461	Underground equipment	Underground Primary	Repair	Replace - Same Size	I
132145901	Q06131	08/02/2013	7:30	08/02/2013	8:45	9	675	75	Animal related	Fuse	Replace - Same Size		IV
132145853	S86580	08/02/2013	7:42	08/02/2013	11:11	1	209	209	Overhead equipment	Lightning Arrestor	Patrol/Test/Inspect	Replace - Same Size	VI
132146655	B93002	08/02/2013	7:43	08/02/2013	11:01	13	2574	198	Overhead equipment	Overhead Primary	Patrol/Test/Inspect	Repair	I
132146245	351002	08/02/2013	9:08	08/02/2013	11:20	1	132	132	Overhead equipment	Connector	Replace - Same Size		VI
132146414	U90566	08/02/2013	9:40	08/02/2013	10:25	1	45	45	Animal related	Transformer Fuse	Replace - Same Size		II
132146485	M40131	08/02/2013	9:53	08/02/2013	10:35	49	2058	42	Overhead equipment	Fuse	Replace - Same Size		I
132146595	B21004	08/02/2013	10:04	08/02/2013	15:00	31	9176	296	Public	Other		Patrol/Test/Inspect	I
132146603	H06135	08/02/2013	10:15	08/02/2013	12:28	1	133	133	Tree related-tree contact	Overhead Service			IV
132146689	U09557	08/02/2013	10:36	08/02/2013	11:09	4	132	33	Animal related	Transformer Fuse			II
132147049	311002	08/02/2013	11:41	08/02/2013	12:45	35	2240	64	Other	Fuse	Replace - Same Size		VI
132147221	N78244	08/02/2013	12:29	08/02/2013	12:45	1	16	16	Other	Customer Equipment	No Work Required	No Work Required	I
132147264	R01152	08/02/2013	12:37	08/02/2013	13:24	1	47	47	Other	Overhead Transformer			III
132147587		08/02/2013	13:51	08/02/2013	15:10	1	79	79	Overhead equipment	Transformer Fuse			IV
132147866	Y37010	08/02/2013	14:51	08/02/2013	15:55	1	64	64	Public	Overhead Service	Raise		IV
132147886	Z04520	08/02/2013	14:55	08/02/2013	15:15	1	20	20	Jurisdictional	Overhead Service	Reconnect		IV
132147957	311002	08/02/2013	15:17	08/02/2013	16:31	35	2590	74	Overhead equipment	Fuse	Replace - Same Size		VI
132148085	J61115	08/02/2013	16:02	08/02/2013	16:35	1	33	33	Tree related-tree contact	Other			III
132148158	340101	08/02/2013	16:33	08/02/2013	17:18	1	45	45	Overhead equipment	Overhead Service	Repair		V
132148188	311002	08/02/2013	16:42	08/02/2013	20:10	35	7280	208	Tree related-tree contact	Fuse	Replace - Same Size		VI
132148243	D96002	08/02/2013	17:08	08/02/2013	19:27	1	139	139	Animal related	Fuse	Replace - Same Size	Patrol/Test/Inspect	I
132149039	L81141	08/02/2013	17:52	08/02/2013	23:00	1	308	308	Public	Transformer Fuse	Replace - Same Size		IV
132148937	L81141	08/02/2013	17:52	08/02/2013	21:20	2	416	208	Public	Underground Secondary	Repair		IV
132148304	M78325	08/02/2013	17:52	08/02/2013	19:02	28	1960	70	Tree related-tree contact	Fuse	Repair		V
132148314	M53311	08/02/2013	17:58	08/02/2013	22:24	1	266	266	Overhead equipment	Overhead Secondary	Replace - New Size	Replace - New Size	V
132148891	X29002	08/02/2013	18:56	08/02/2013	20:45	5	545	109	Tree related-tree broken	Overhead Secondary	Repair		IV
132148895	K76543	08/02/2013	18:59	08/02/2013	20:00	1	61	61	Overhead equipment	Overhead Service	Replace - Same Size	No Work Required	IV
132148923	H07106	08/02/2013	19:11	08/03/2013	2:33	1	442	442	Underground equipment	Underground Secondary	Advise Customer		IV
132148926	N67311	08/02/2013	19:12	08/02/2013	20:10	38	2204	58	Unknown	Fuse	Replace - Same Size		I
132148939	N67311	08/02/2013	19:14	08/02/2013	20:10	29	1624	56	Unknown	Fuse	Replace - Same Size		I
132148960	P12290	08/02/2013	19:52	08/02/2013	22:09	1	137	137	Tree related-tree broken	Tree	Trim		V
132148986	K01240	08/02/2013	20:21	08/02/2013	21:22	84	5124	61	Animal related	Fuse			VI
132148994	X91511	08/02/2013	20:36	08/02/2013	22:00	1	84	84	Tree related-tree contact	Overhead Service	Repair	Replace - Same Size	IV
132149002	U90572	08/02/2013	20:50	08/02/2013	21:55	1	65	65	Overhead equipment	Overhead Service	Repair		II
132149019	307001	08/02/2013	21:12	08/02/2013	22:40	1	88	88	Overhead equipment	Fuse	Replace - Same Size		VI
132149044	N18210	08/02/2013	22:12	08/02/2013	23:50	24	2352	98	Weather	Fuse	Replace - Same Size	Replace - Same Size	III
132149045	B45002	08/02/2013	22:20	08/03/2013	0:17	1	117	117	Overhead equipment	Fuse	Replace - Same Size		I
132150009	P09305	08/02/2013	22:33	08/03/2013	1:38	16	2960	185	Animal related	Fuse			V

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
132150048	C36001	08/02/2013	22:49	08/03/2013	3:44	5	1475	295	Underground equipment	Underground Primary	Repair		III
132149065	C36001	08/02/2013	22:49	08/03/2013	0:05	36	2736	76	Underground equipment	Underground Primary			III
132150054	A91001	08/02/2013	22:52	08/03/2013	7:02	1	490	490	Underground equipment	Underground Primary	Repair	Repair	I
132149070	A91001	08/02/2013	22:52	08/03/2013	2:38	9	2034	226	Underground equipment	Underground Primary		Repair	I
132150021	D87001	08/03/2013	0:47	08/03/2013	2:20	1	93	93	Tree related-tree broken	Overhead Service	Patrol/Test/Inspect	Repair	I
132150026	R60551	08/03/2013	1:06	08/03/2013	2:58	1	112	112	Overhead equipment	Fuse	Replace - Same Size		IV
132150029	K01240	08/03/2013	1:10	08/03/2013	2:25	1	75	75	Animal related	Transformer Fuse			VI
132150093	H01192	08/03/2013	1:43	08/03/2013	8:43	2	840	420	Underground equipment	Underground Primary	Repair		III
132150076	H01192	08/03/2013	1:43	08/03/2013	4:15	3	456	152	Underground equipment	Underground Primary	Repair		III
132150074	H01192	08/03/2013	1:43	08/03/2013	3:40	15	1755	117	Underground equipment	Fuse	Replace - Same Size		III
132150044	K71821	08/03/2013	1:53	08/03/2013	4:05	14	1848	132	Tree related-tree broken	Fuse	Replace - Same Size		IV
132150077	M54316	08/03/2013	4:01	08/03/2013	6:11	1	130	130	Animal related	Fuse	Replace - Same Size	Repair	V
132150082	D41003	08/03/2013	4:54	08/03/2013	9:20	1	266	266	Underground equipment	Underground Primary		Repair	I
132150084	HA5430	08/03/2013	5:50	08/03/2013	8:43	6	1038	173	Underground equipment	Underground Primary	Patrol/Test/Inspect		V
132150092	311002	08/03/2013	6:03	08/03/2013	7:45	36	3672	102	Tree related-tree contact	Tree			VI
132150097	C00002	08/03/2013	6:31	08/03/2013	13:30	1	419	419	Underground equipment	Underground Primary	Repair	Repair	I
132150112	Y54560	08/03/2013	7:11	08/03/2013	10:51	1	220	220	Overhead equipment	Overhead Transformer	Repair	Repair	IV
132150117	P18102	08/03/2013	7:13	08/03/2013	12:00	10	2870	287	Underground equipment	Underground Primary	Repair	Repair	IV
132150173	J50186	08/03/2013	7:25	08/03/2013	8:36	865	61415	71	Substation equipment	Substation Breaker	Repair		III
132150210	S20554	08/03/2013	8:34	08/03/2013	10:17	1	103	103	Overhead equipment				VI
132150244	L50217	08/03/2013	9:10	08/03/2013	10:08	43	2494	58	Animal related	Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
132150260	R34920	08/03/2013	9:31	08/03/2013	11:41	1	130	130	Unknown	Fuse	Replace - Same Size		VI
132150270	K79213	08/03/2013	9:41	08/03/2013	10:52	1	71	71	Overhead equipment	Fuse			IV
132150279	L46811	08/03/2013	9:50	08/03/2013	10:34	1	44	44	Animal related	Transformer Fuse	Replace - Same Size	No Work Required	V
132150280	T29561	08/03/2013	9:51	08/03/2013	10:58	1	67	67	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	VI
132150293	K43385	08/03/2013	10:06	08/03/2013	11:08	1	62	62	Animal related	Fuse	Replace - New Size	No Work Required	V
132150314	V23592	08/03/2013	10:24	08/03/2013	12:37	1	133	133	Overhead equipment	Connector			II
132150383	Q28141	08/03/2013	10:45	08/03/2013	12:06	1	81	81	Overhead equipment	Overhead Service	Replace - Same Size		VI
132150412	T29561	08/03/2013	11:15	08/03/2013	11:20	1	5	5	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	VI
132150431	D69008	08/03/2013	11:33	08/03/2013	12:14	1	41	41	Underground equipment	Underground Service	Patrol/Test/Inspect		I
132150492	K27123	08/03/2013	12:33	08/03/2013	14:16	1	103	103	Public	Overhead Service	Replace - Same Size		VI
132150509	P57108	08/03/2013	13:02	08/03/2013	14:36	1	94	94	Overhead equipment	Fuse	Replace - Same Size		VI
132150529	J88165	08/03/2013	13:07	08/03/2013	14:10	45	2835	63	Public	Underground Primary	Switch/Reset	Switch/Reset	VI
132150545	J06168	08/03/2013	13:20	08/03/2013	16:30	14	2660	190	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	I
132150538		08/03/2013	13:31	08/03/2013	14:41	1	70	70	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
132150552	R68903	08/03/2013	13:51	08/03/2013	15:00	7	483	69	Animal related	Transformer Fuse	Replace - Same Size	Replace - Same Size	I
132150604	B19002	08/03/2013	15:12	08/03/2013	20:25	1	313	313	Underground equipment	Underground Primary	Replace - Same Size	Repair	I
132150636	342001	08/03/2013	16:19	08/03/2013	17:18	1	59	59	Tree related-tree contact	Tree	Cut in Clear		VI
132150647	X66581	08/03/2013	16:42	08/03/2013	18:10	1	88	88	Tree related-tree broken	Overhead Service	Repair		IV
132150659	X88510	08/03/2013	17:17	08/03/2013	18:35	1	78	78	Overhead equipment	Overhead Secondary	Repair		IV
132150680	V23530	08/03/2013	18:04	08/03/2013	22:15	4	1004	251	Underground equipment	Underground Primary		Repair	II
132150698	R33126	08/03/2013	18:15	08/03/2013	19:05	63	3150	50	Overhead equipment	Jumper	Repair	Patrol/Test/Inspect	I
132150707	R33126	08/03/2013	18:43	08/03/2013	19:10	1	27	27	Overhead equipment	Jumper	Replace - Same Size	Patrol/Test/Inspect	I
132150736	D35001	08/03/2013	20:26	08/03/2013	21:32	1	66	66	Overhead equipment	Disconnect Switch	Replace - Same Size		I
132150765	D36002	08/03/2013	22:02	08/04/2013	1:03	8	1448	181	Underground equipment	Underground Primary	Repair	Repair	I
132160014	N73120	08/04/2013	2:38	08/04/2013	4:17	1	99	99	Overhead equipment	Transformer Fuse			IV
132160271	K15205	08/04/2013	6:28	08/04/2013	9:15	192	32064	167	Overhead equipment	Recloser	Patrol/Test/Inspect		VI
132160267	K15205	08/04/2013	6:28	08/04/2013	8:55	817	120099	147	Overhead equipment	Substation Breaker	Patrol/Test/Inspect		VI
132160275	C70001	08/04/2013	6:44	08/04/2013	14:10	3	1338	446	Underground equipment	Underground Primary	Repair		III
132160090	C70001	08/04/2013	6:44	08/04/2013	8:53	5	645	129	Underground equipment	Underground Primary			III
132160096	P47123	08/04/2013	7:17	08/04/2013	8:30	11	803	73	Animal related	Fuse	Replace - Same Size		I
132160098		08/04/2013	7:20	08/04/2013	8:37	1	77	77	Animal related	Fuse	Replace - Same Size		I
132160392	U44568	08/04/2013	7:33	08/04/2013	10:43	295	56050	190	Substation equipment	Lightning Arrestor	Repair		II
132160243	U78742	08/04/2013	7:34	08/04/2013	11:03	303	63327	209	Substation equipment				II
132160257	P58155	08/04/2013	8:50	08/04/2013	10:25	21	1995	95	Animal related	Fuse	Repair		VI
132160261	B19002	08/04/2013	8:57	08/04/2013	10:09	17	1224	72	Overhead equipment	Disconnect Switch	Raise		I

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
132160280	X34531	08/04/2013	9:23	08/04/2013	11:00	1	97	97	Overhead equipment	Overhead Service	Repair		IV
132160302	U44568	08/04/2013	10:09	08/04/2013	10:58	1	49	49	Overhead equipment	Disconnect Switch	Repair		II
132160319	K79213	08/04/2013	10:40	08/04/2013	14:05	1	205	205	Tree related-tree contact	Overhead Service	Patrol/Test/Inspect	Replace - Same Size	IV
132160322	R94269	08/04/2013	10:43	08/04/2013	12:00	1	77	77	Animal related	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
132160340	X92507	08/04/2013	11:18	08/04/2013	13:00	2	204	102	Unknown	Transformer Fuse	Repair	Replace - Same Size	IV
132160352	Q91175	08/04/2013	11:25	08/04/2013	12:40	1	75	75	Overhead equipment	Transformer Fuse	Replace - Same Size		I
132160366	M07236	08/04/2013	11:37	08/04/2013	13:19	11	1122	102	Unknown	Fuse	Replace - Same Size		III
132160367	U68002	08/04/2013	11:48	08/04/2013	13:11	4	332	83	Overhead equipment	Transformer Fuse	Replace - Same Size		II
132160378	K71812	08/04/2013	11:58	08/04/2013	13:24	2	172	86	Tree related-tree contact	Overhead Service			IV
132160390	UE2001	08/04/2013	12:12	08/04/2013	15:40	1	208	208	Overhead equipment	Overhead Primary	Patrol/Test/Inspect	Repair	V
132160395	L46811	08/04/2013	12:30	08/04/2013	14:40	1	130	130	Overhead equipment	Fuse	Replace - Same Size		V
132160486	F03003	08/04/2013	14:40	08/04/2013	17:54	1	194	194	Underground equipment	Underground Service	Repair	No Work Required	III
132160514	D69006	08/04/2013	14:59	08/04/2013	17:18	108	15012	139	Animal related	Underground Primary	Replace - Same Size	Replace - Same Size	I
132160525	C10001	08/04/2013	16:16	08/04/2013	17:15	1	59	59	Overhead equipment	Fuse	Replace - Same Size		III
132160549	B93002	08/04/2013	17:36	08/05/2013	5:40	1	724	724	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
132160550	Q32170	08/04/2013	17:40	08/04/2013	18:35	1	55	55	Tree related-tree contact	Fuse	Cut in Clear	Patrol/Test/Inspect	I
132160556	U06551	08/04/2013	17:59	08/04/2013	18:53	1	54	54	Overhead equipment	Fuse	Replace - Same Size		II
132160574	N54108	08/04/2013	19:03	08/04/2013	22:05	40	7280	182	Underground equipment	Underground Primary	Switch/Reset	Repair	II
132160605	J76804	08/04/2013	20:23	08/05/2013	3:39	12	5232	436	Underground equipment	Overhead Primary	Repair	Repair	V
132160655	M19222	08/04/2013	22:36	08/05/2013	6:49	9	4437	493	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	VI
132160657	U61001	08/04/2013	22:42	08/05/2013	0:10	25	2200	88	Overhead equipment	Overhead Primary	Switch/Reset	No Work Required	II
132174490	D16002	08/05/2013	5:28	08/05/2013	8:45	49	9653	197	Underground equipment	Underground Primary	Patrol/Test/Inspect	Patrol/Test/Inspect	I
132174495	E05001	08/05/2013	5:54	08/05/2013	8:34	1	160	160	Underground equipment	Underground Service		Repair	IV
132174506	Z51551	08/05/2013	6:20	08/05/2013	7:35	1	75	75	Animal related	Transformer Fuse			IV
132174511	N50331	08/05/2013	6:35	08/05/2013	8:13	1	98	98	Overhead equipment	Overhead Service	Repair		II
132174530	U41545	08/05/2013	6:47	08/05/2013	8:00	1	73	73	Animal related	Transformer Fuse	Replace - Same Size	Replace - Same Size	II
132174701	Q47833	08/05/2013	7:35	08/05/2013	9:40	162	20250	125	Animal related	Overhead Primary	Patrol/Test/Inspect	No Work Required	V
132174659	V20502	08/05/2013	7:41	08/05/2013	8:30	1	49	49	Animal related	Animal Guard	Install		II
132174679	T23527	08/05/2013	7:43	08/05/2013	9:02	1	79	79	Animal related	Transformer Fuse	Replace - New Size		VI
132174710		08/05/2013	7:53	08/05/2013	10:00	1	127	127	Animal related	Overhead Primary	No Work Required	No Work Required	V
132174733	310122	08/05/2013	7:57	08/05/2013	8:39	27	1134	42	Animal related	Fuse	Replace - Same Size	No Work Required	V
132174828	E05002	08/05/2013	8:25	08/05/2013	9:00	1	35	35	Animal related	Transformer Fuse	Replace - Same Size		IV
132174886		08/05/2013	8:41	08/05/2013	9:40	1	59	59	Animal related	Fuse	Replace - Same Size	Replace - Same Size	V
132175038	K27150	08/05/2013	9:09	08/05/2013	10:05	1	56	56	Overhead equipment	Transformer Fuse	Replace - Same Size	No Work Required	VI
132175047	K30204	08/05/2013	9:12	08/05/2013	10:19	1	67	67	Unknown	Transformer Fuse	Replace - Same Size		III
132175105	L86175	08/05/2013	9:23	08/05/2013	11:32	1	129	129	Animal related	Fuse	Replace - Same Size		IV
132175182	306001	08/05/2013	9:38	08/05/2013	10:35	1	57	57	Public	Meter	Patrol/Test/Inspect		VI
132175690	S25551	08/05/2013	9:54	08/05/2013	12:20	8	1168	146	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	VI
132175563	Q32170	08/05/2013	9:58	08/05/2013	10:40	129	5418	42	Animal related	Fuse	Replace - Same Size	Patrol/Test/Inspect	I
132175781		08/05/2013	10:35	08/05/2013	11:58	1	83	83	Overhead equipment	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
132175858	Y10011	08/05/2013	10:46	08/05/2013	11:40	1	54	54	Overhead equipment	Overhead Service	Repair	Repair	IV
132175887	L80221	08/05/2013	10:49	08/05/2013	13:19	1	150	150	Overhead equipment	Overhead Service			IV
132176283	Y39001	08/05/2013	11:59	08/05/2013	12:54	2	110	55	Overhead equipment	Transformer Fuse	Replace - Same Size	Patrol/Test/Inspect	IV
132176611	340102	08/05/2013	13:02	08/05/2013	14:26	1	84	84	Overhead equipment	Overhead Service	Repair	No Work Required	V
132176869	R84148	08/05/2013	13:54	08/05/2013	14:40	1	46	46	Overhead equipment	Transformer Fuse	Replace - Same Size		I
132177222	V44504	08/05/2013	15:05	08/05/2013	16:09	1	64	64	Jurisdictional	Meter			II
132177434	M21134	08/05/2013	15:48	08/05/2013	17:30	1	102	102	Overhead equipment	Jumper	Repair		VI
132177440	J86108	08/05/2013	15:49	08/05/2013	16:22	1	33	33	Tree related-tree contact	Transformer Fuse	Replace - Same Size		VI
132177806	K89142	08/05/2013	18:10	08/05/2013	18:25	1	15	15	Animal related	Fuse	Replace - Same Size		III
132178592	D36001	08/05/2013	19:30	08/05/2013	20:33	5	315	63	Animal related	Fuse	Replace - Same Size		I
132178624	M45211	08/05/2013	20:27	08/05/2013	21:40	3	219	73	Unknown	Transformer Fuse	Replace - Same Size		IV
132182132	D66001	08/06/2013	0:03	08/06/2013	3:34	14	2954	211	Tree related-tree contact	Overhead Primary	Trim		IV
132184327	M21134	08/06/2013	5:54	08/06/2013	8:17	1	143	143	Overhead equipment	Overhead Transformer	Repair	Repair	VI
132184423	N60181	08/06/2013	7:11	08/06/2013	8:00	1	49	49	Overhead equipment	Overhead Service	Tie/Tighten		I
132184629	J06168	08/06/2013	8:17	08/06/2013	9:33	1	76	76	Overhead equipment	Overhead Transformer	Switch/Reset		I
132184679	F22001	08/06/2013	8:30	08/06/2013	8:47	1	17	17	Animal related	Fuse	Replace - Same Size		IV

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
132184711	C76002	08/06/2013	8:33	08/06/2013	10:12	70	6930	99	Tree related-tree broken	Overhead Primary	Repair	Repair	I
132184824		08/06/2013	8:57	08/06/2013	10:18	1	81	81	Weather	Lightning Arrestor	Replace - Same Size		I
132184906	B80003	08/06/2013	9:14	08/06/2013	10:00	1	46	46	Jurisdictional	Meter	Reconnect	No Work Required	I
132185016	L81141	08/06/2013	9:35	08/06/2013	10:36	1	61	61	Animal related	Transformer Fuse	Replace - Same Size	No Work Required	IV
132185080	J75271	08/06/2013	9:45	08/06/2013	9:49	1	4	4	Overhead equipment	Overhead Transformer			IV
132185184	M18131	08/06/2013	10:01	08/06/2013	10:43	1	42	42	Animal related	Fuse	Replace - Same Size		III
132185322	R60552	08/06/2013	10:04	08/06/2013	14:28	18	4752	264	Public	Pole	Replace - New Size	Replace - New Size	IV
132185306	K27150	08/06/2013	10:12	08/06/2013	11:00	73	3504	48	Overhead equipment	Recloser	Switch/Reset	No Work Required	VI
132185324	D66001	08/06/2013	10:27	08/06/2013	11:50	1	83	83	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
132185482	D89002	08/06/2013	10:50	08/06/2013	11:12	63	1386	22	Jurisdictional				I
132185480	X24536	08/06/2013	10:59	08/06/2013	12:40	1	101	101	Animal related	Fuse	Replace - Same Size	No Work Required	IV
132185553	M78325	08/06/2013	11:11	08/06/2013	14:15	2	368	184	Underground equipment	Underground Primary			V
132185564	N22296	08/06/2013	11:12	08/06/2013	15:43	1	271	271	Underground equipment	Underground Service	Patrol/Test/Inspect	Replace - Same Size	VI
132185607	K39154	08/06/2013	11:20	08/06/2013	12:59	1	99	99	Animal related	Transformer Fuse	Replace - Same Size		III
132185775		08/06/2013	11:43	08/06/2013	12:46	1	63	63	Animal related	Overhead Transformer		Advise Customer	VI
132185786	M09143	08/06/2013	11:44	08/06/2013	13:04	1	80	80	Animal related	Fuse	Replace - Same Size	Repair	VI
132185802	U61568	08/06/2013	11:45	08/06/2013	13:54	1	129	129	Weather	Transformer Fuse	Replace - Same Size		II
132185838	303006	08/06/2013	11:50	08/06/2013	13:22	1	92	92	Jurisdictional	Overhead Transformer	Switch/Reset		VI
132185845	S75505	08/06/2013	11:51	08/06/2013	12:48	1	57	57	Animal related	Overhead Transformer			VI
132185882	P19395	08/06/2013	11:58	08/06/2013	12:25	11	297	27	Underground equipment	Underground Transformer			V
132187116	B57001	08/06/2013	12:25	08/06/2013	17:29	26	7904	304	Overhead equipment	Other	No Work Required	No Work Required	I
132186122	S60581	08/06/2013	12:53	08/06/2013	16:13	1	200	200	Underground equipment	Underground Primary	Repair		VI
132186273	M40116	08/06/2013	13:21	08/06/2013	14:43	1	82	82	Overhead equipment	Overhead Primary	No Work Required		I
132186386	U29001	08/06/2013	13:44	08/06/2013	17:24	1	220	220	Public	Pole	Patrol/Test/Inspect	Replace - Same Size	II
132186433	B80002	08/06/2013	13:47	08/06/2013	14:55	124	8432	68	Public	Underground Primary	Patrol/Test/Inspect	Repair	I
132186508	B80002	08/06/2013	14:01	08/06/2013	18:40	1	279	279	Public	Underground Primary	Patrol/Test/Inspect	Repair	I
132186659	K32916	08/06/2013	14:37	08/06/2013	15:43	1	66	66	Overhead equipment	Pole			VI
132186701	312115	08/06/2013	14:44	08/06/2013	15:34	1	50	50	Overhead equipment	Overhead Transformer	Repair		V
132186927		08/06/2013	15:31	08/06/2013	20:54	1	323	323	Public	Underground Service	Patrol/Test/Inspect	Repair	I
132186969	L24122	08/06/2013	15:43	08/06/2013	16:13	1	30	30	Unknown	Fuse	Replace - Same Size		III
132186987	U60559	08/06/2013	15:50	08/06/2013	16:58	1	68	68	Public	Overhead Service	Repair	No Work Required	II
132187081	J47178	08/06/2013	16:16	08/06/2013	20:37	1	261	261	Underground equipment	Underground Service			III
132187090	Q16867	08/06/2013	16:17	08/06/2013	18:50	1	153	153	Overhead equipment	Overhead Transformer	Replace - Same Size	Replace - Same Size	V
132187248	K09863	08/06/2013	17:17	08/06/2013	18:15	10	580	58	Animal related	Transformer Fuse	Replace - Same Size	Repair	V
132187273	N54107	08/06/2013	17:26	08/06/2013	21:53	1	267	267	Underground equipment	Underground Primary	Repair	No Work Required	II
132187280	310123	08/06/2013	17:34	08/06/2013	19:01	1	87	87	Animal related	Fuse	Repair		V
132187323	B73001	08/06/2013	18:00	08/06/2013	19:15	1	75	75	Animal related	Fuse	Replace - Same Size		I
132187938	B45005	08/06/2013	19:30	08/06/2013	21:19	1	109	109	Tree related-tree contact	Overhead Service	Repair		I
132187939	R16510	08/06/2013	19:31	08/06/2013	21:06	1	95	95	Overhead equipment	Overhead Service	Repair		I
132188019	D37003	08/06/2013	21:41	08/06/2013	23:45	29	3596	124	Underground equipment	Underground Primary	Switch/Reset		I
132188057		08/06/2013	23:12	08/07/2013	6:23	1	431	431	Overhead equipment	Overhead Transformer	Repair	No Work Required	V
132190163	M36185	08/07/2013	0:29	08/07/2013	1:55	1	86	86	Tree related-tree broken	Overhead Transformer	Switch/Reset		I
132190224	S27598	08/07/2013	2:36	08/07/2013	7:50	1	314	314	Overhead equipment	Overhead Primary	Repair	Repair	VI
132194570	D69008	08/07/2013	4:31	08/07/2013	7:51	58	11600	200	Underground equipment	Underground Primary		Patrol/Test/Inspect	I
132194591	D69008	08/07/2013	5:20	08/07/2013	7:32	6	792	132	Underground equipment	Underground Primary	Switch/Reset		I
132194615	S27598	08/07/2013	6:20	08/07/2013	7:50	1	90	90	Overhead equipment				VI
132194814	K74166	08/07/2013	6:56	08/07/2013	8:26	52	4680	90	Animal related	Transformer Fuse	Replace - Same Size		IV
132194654	Y66557	08/07/2013	7:08	08/07/2013	8:30	1	82	82	Overhead equipment	Connector	Repair		IV
132194749	N35852	08/07/2013	7:30	08/07/2013	8:42	4	288	72	Animal related	Transformer Fuse	Replace - Same Size		V
132194887	S27598	08/07/2013	8:05	08/07/2013	11:23	1	198	198	Underground equipment	Underground Primary		Repair	VI
132194948	P09304	08/07/2013	8:28	08/07/2013	9:45	1	77	77	Tree related-tree contact	Tree	Patrol/Test/Inspect		V
132195034	R58921	08/07/2013	8:29	08/07/2013	8:47	489	8802	18	Underground equipment				IV
132194999	B57001	08/07/2013	8:36	08/07/2013	9:11	1	35	35	Unknown	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	I
132195052	N70332	08/07/2013	8:44	08/07/2013	11:08	21	3024	144	Underground equipment	Underground Primary	Repair	Repair	I
132195078	S28552	08/07/2013	8:52	08/07/2013	9:50	7	406	58	Overhead equipment	Disconnect Switch	Replace - New Size		VI
132195292	A85002	08/07/2013	9:25	08/07/2013	17:00	2	910	455	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
132195247	S24598	08/07/2013	9:28	08/07/2013	10:50	1	82	82	Tree related-tree contact	Tree	Patrol/Test/Inspect	Repair	VI
132195252	Q63835	08/07/2013	9:29	08/07/2013	11:23	1	114	114	Public	Underground Service		Repair	V
132195429	U13551	08/07/2013	10:02	08/07/2013	11:10	1	68	68	Weather	Transformer Fuse	Replace - Same Size		II
132195482	K36151	08/07/2013	10:14	08/07/2013	11:13	1	59	59	Animal related	Transformer Fuse	Replace - Same Size		III
132195583	P49180	08/07/2013	10:31	08/07/2013	11:12	1	41	41	Animal related	Overhead Transformer	Switch/Reset		I
132195710	Y45002	08/07/2013	10:55	08/07/2013	14:30	5	1075	215	Overhead equipment	Overhead Transformer	Repair	Replace - New Size	IV
132195947	A97003	08/07/2013	11:42	08/07/2013	12:27	1	45	45	Overhead equipment	Overhead Service	No Work Required	No Work Required	I
132196400	B21002	08/07/2013	12:40	08/07/2013	15:05	15	2175	145	Underground equipment	Underground Primary		Repair	I
132196355	B21002	08/07/2013	12:40	08/07/2013	14:06	133	11438	86	Unknown	Recloser	Reconnect		I
132196544	V21500	08/07/2013	13:18	08/07/2013	14:35	1	77	77	Tree related-tree broken	Transformer Fuse	Repair		II
132196580	K31120	08/07/2013	13:25	08/07/2013	13:59	1	34	34	Animal related	Transformer Fuse	Replace - Same Size		I
132196603	A85001	08/07/2013	13:29	08/07/2013	14:25	1	56	56	Overhead equipment	Transformer Fuse	Replace - Same Size	No Work Required	I
132196770		08/07/2013	13:56	08/07/2013	14:16	1	20	20	Overhead equipment	Fuse			IV
132196829	S27598	08/07/2013	14:06	08/07/2013	16:52	1	166	166	Underground equipment	Underground Primary	Repair	Replace - Same Size	VI
132197072	N18211	08/07/2013	14:58	08/07/2013	15:45	1	47	47	Overhead equipment	Overhead Primary		Repair	III
132197181		08/07/2013	15:17	08/07/2013	18:05	1	168	168	Weather	Transformer Fuse	Replace - Same Size		III
132197321	302001	08/07/2013	15:21	08/07/2013	17:15	40	4560	114	Public	Overhead Primary			VI
132197265	N18210	08/07/2013	15:26	08/07/2013	17:40	24	3216	134	Weather	Fuse	Replace - Same Size		III
132197447	J34357	08/07/2013	15:50	08/07/2013	18:44	3	522	174	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	V
132197335	K43386	08/07/2013	15:57	08/07/2013	17:18	3	243	81	Overhead equipment	Lightning Arrestor	Replace - Same Size		V
132197409	K39154	08/07/2013	16:11	08/07/2013	16:55	3	132	44	Unknown	Fuse	Replace - Same Size		III
132197386	K39154	08/07/2013	16:12	08/07/2013	16:55	1	43	43	Unknown	Fuse	Replace - Same Size		III
132197486	K39154	08/07/2013	16:13	08/07/2013	16:44	7	217	31	Unknown	Fuse	Replace - Same Size		III
132198574	J99141	08/07/2013	16:17	08/08/2013	0:20	8	3864	483	Tree related-tree broken	Overhead Primary	Repair		VI
132197749	J99141	08/07/2013	16:17	08/07/2013	22:00	93	31899	343	Tree related-tree contact				VI
132197398	J99141	08/07/2013	16:19	08/07/2013	17:37	59	4602	78	Tree related-tree contact	Overhead Primary	Patrol/Test/Inspect	Remove	VI
132197410	J99141	08/07/2013	16:20	08/07/2013	22:00	1	340	340	Tree related-tree contact	Overhead Transformer		Replace - Same Size	VI
132197428	V44504	08/07/2013	16:25	08/07/2013	19:14	1	169	169	Overhead equipment				II
132197468	N44216	08/07/2013	16:29	08/07/2013	17:07	24	912	38	Weather	Fuse			III
132197470	L17101	08/07/2013	16:35	08/07/2013	17:38	1	63	63	Overhead equipment	Overhead Secondary	Repair		III
132197510	V44504	08/07/2013	16:36	08/07/2013	23:40	11	4664	424	Public	Pole	Replace - Same Size	No Work Required	II
132197492		08/07/2013	16:40	08/07/2013	16:55	1	15	15	Unknown	Fuse	Replace - Same Size		III
132197516	P98192	08/07/2013	16:44	08/07/2013	18:30	32	3392	106	Weather	Fuse			III
132205921	J50185	08/07/2013	16:50	08/07/2013	16:53	95	285	3	Weather	Recloser	Switch/Reset	Switch/Reset	III
132197709	J63484	08/07/2013	16:54	08/07/2013	18:08	1569	116106	74	Unknown				III
132197568	K65220	08/07/2013	16:58	08/07/2013	18:19	1	81	81	Overhead equipment	Overhead Primary		Repair	III
132197717		08/07/2013	17:33	08/07/2013	19:00	1	87	87	Tree related-tree contact	Overhead Service	Reconnect	Advise Customer	IV
132197747	P98191	08/07/2013	17:46	08/07/2013	19:09	1	83	83	Weather				III
132197758	J67131	08/07/2013	17:52	08/07/2013	19:06	1	74	74	Weather	Other			III
132197780	F10002	08/07/2013	18:09	08/07/2013	21:45	2	432	216	Overhead equipment	Disconnect Switch	Replace - Same Size	No Work Required	III
132197853	C30002	08/07/2013	18:18	08/07/2013	21:50	39	8268	212	Weather	Fuse	Replace - Same Size	No Work Required	III
132198576	Q34380	08/07/2013	18:27	08/07/2013	23:20	101	29593	293	Underground equipment	Underground Primary	Patrol/Test/Inspect	Switch/Reset	I
132197823	C30002	08/07/2013	18:29	08/07/2013	22:13	1	224	224	Weather	Transformer Fuse	Replace - Same Size	No Work Required	III
132198028	Q34380	08/07/2013	18:29	08/07/2013	20:19	80	8800	110	Underground equipment	Underground Primary	Patrol/Test/Inspect	Switch/Reset	I
132197837	J50185	08/07/2013	18:32	08/07/2013	19:00	1	28	28	Weather	Other			III
132197874	N35852	08/07/2013	18:57	08/07/2013	19:00	9	27	3	Underground equipment	Underground Primary	Patrol/Test/Inspect	No Work Required	V
132197993	D31018	08/07/2013	19:02	08/07/2013	20:19	217	16709	77	Overhead equipment	Fuse	Replace - Same Size		III
132198492	X92507	08/07/2013	19:45	08/07/2013	21:05	1	80	80	Unknown	Underground Primary	Repair	Replace - Same Size	IV
132198538	M47802	08/07/2013	20:47	08/07/2013	22:00	6	438	73	Weather	Fuse	Repair	Repair	V
132198562	M47816	08/07/2013	21:28	08/07/2013	22:30	1	62	62	Weather	Fuse	Repair	Repair	V
132198588	Q15845	08/07/2013	21:35	08/07/2013	22:48	7	511	73	Weather	Fuse	Replace - Same Size		V
132198575	M47816	08/07/2013	21:41	08/07/2013	22:42	1	61	61	Weather	Fuse	Repair	Repair	V
132198583	Q95248	08/07/2013	21:54	08/07/2013	23:43	33	3597	109	Underground equipment	Underground Primary			VI
132198601	P05825	08/07/2013	22:02	08/07/2013	23:22	18	1440	80	Weather	Transformer Fuse	Replace - Same Size		V
132198592	L59929	08/07/2013	22:09	08/07/2013	23:28	1	79	79	Overhead equipment	Fuse	Replace - Same Size		VI
132198612	X30505	08/07/2013	23:05	08/08/2013	2:30	1	205	205	Overhead equipment	Overhead Transformer		Replace - Same Size	IV

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
132198650	K39153	08/07/2013	23:42	08/08/2013	1:25	51	5253	103	Overhead equipment	Fuse	Replace - Same Size		III
132198654	D92001	08/07/2013	23:50	08/08/2013	3:10	83	16600	200	Underground equipment	Underground Primary	Patrol/Test/Inspect	Switch/Reset	I
132202086	V24583	08/08/2013	0:53	08/08/2013	1:59	1	66	66	Unknown	Overhead Transformer	Replace - Same Size		II
132202087	J99128	08/08/2013	1:02	08/08/2013	2:00	1	58	58	Animal related	Fuse			VI
132202090	V24583	08/08/2013	1:21	08/08/2013	2:00	1	39	39	Unknown	Fuse	Replace - Same Size		II
132202121	A91001	08/08/2013	2:46	08/08/2013	3:44	1	58	58	Unknown	Fuse			I
132203920	U80564	08/08/2013	3:45	08/08/2013	5:09	1	84	84	Tree related-tree broken	Overhead Service	Repair	No Work Required	II
132203928	X72535	08/08/2013	4:18	08/08/2013	6:10	1	112	112	Overhead equipment	Fuse	Repair		IV
132204343	D96002	08/08/2013	6:03	08/08/2013	12:20	1	377	377	Underground equipment	Underground Primary	Repair	Repair	I
132203989	D96002	08/08/2013	6:03	08/08/2013	8:11	3	384	128	Underground equipment	Underground Primary	Switch/Reset		I
132204009	B83001	08/08/2013	7:05	08/08/2013	8:25	1	80	80	Overhead equipment	Customer Equipment	Replace - Same Size	Repair	III
132204986	D69006	08/08/2013	7:13	08/08/2013	13:49	1	396	396	Underground equipment	Underground Primary	Repair	Repair	I
132204281	D69006	08/08/2013	7:13	08/08/2013	10:27	2	388	194	Underground equipment	Underground Primary	Repair	Repair	I
132204111	B83001	08/08/2013	7:35	08/08/2013	8:41	1	66	66	Overhead equipment	Fuse	Replace - Same Size	Repair	III
132204301	B44001	08/08/2013	8:14	08/08/2013	9:43	1	89	89	Overhead equipment	Connector	Repair	Replace - Same Size	I
132204305	P73158	08/08/2013	8:15	08/08/2013	10:05	1	110	110	Overhead equipment	Overhead Secondary		Replace - Same Size	VI
132204449	Q01281	08/08/2013	8:47	08/08/2013	9:26	86	3354	39	Unknown	Fuse			III
132204678	Q06132	08/08/2013	9:38	08/08/2013	10:45	1	67	67	Tree related-tree contact	Overhead Service	Repair		IV
132204774	J15303	08/08/2013	9:51	08/08/2013	11:27	17	1632	96	Overhead equipment	Overhead Primary	Repair		I
132205503	D32212	08/08/2013	10:09	08/08/2013	12:18	1	129	129	Animal related	Recloser	Switch/Reset		I
132205215	D32212	08/08/2013	10:09	08/08/2013	12:18	74	9546	129	Animal related	Recloser	Switch/Reset		I
132204886	J01118	08/08/2013	10:14	08/08/2013	11:59	31	3255	105	Underground equipment	Underground Primary	Patrol/Test/Inspect	Switch/Reset	I
132204956	D32212	08/08/2013	10:32	08/08/2013	12:18	1	106	106	Animal related	Recloser	Switch/Reset		I
132204959	R34920	08/08/2013	10:33	08/08/2013	11:30	1	57	57	Overhead equipment	Transformer Fuse	Replace - Same Size	No Work Required	VI
132204958	S42579	08/08/2013	10:33	08/08/2013	13:25	1	172	172	Overhead equipment	Overhead Transformer	Repair	Replace - Same Size	VI
132205264	J01118	08/08/2013	11:31	08/08/2013	12:33	1	62	62	Overhead equipment	Overhead Service	No Work Required		I
132205295	D32212	08/08/2013	11:39	08/08/2013	12:18	1	39	39	Animal related	Recloser	Switch/Reset		I
132205339	Q69926	08/08/2013	11:47	08/08/2013	12:59	1	72	72	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	VI
132205343	M06621	08/08/2013	11:49	08/08/2013	13:40	1	111	111	Animal related	Fuse	Replace - Same Size		V
132205403	Q15844	08/08/2013	11:54	08/08/2013	12:24	46	1380	30	Animal related	Fuse	Replace - Same Size		V
132205458	Q15844	08/08/2013	12:08	08/08/2013	12:24	1	16	16	Animal related	Fuse	Replace - Same Size		V
132205484	V24583	08/08/2013	12:13	08/08/2013	13:40	1	87	87	Unknown	Fuse	Replace - Same Size		II
132205543	D32212	08/08/2013	12:18	08/08/2013	14:47	1	149	149	Animal related	Overhead Primary	Repair	Repair	I
132214436	B25001	08/08/2013	12:23	08/09/2013	10:14	10	13110	1311	Public	Pole		Replace - Same Size	I
132205738	S47576	08/08/2013	13:03	08/08/2013	14:30	1	87	87	Tree related-tree broken	Overhead Service			VI
132205748	M45212	08/08/2013	13:05	08/08/2013	13:59	1	54	54	Overhead equipment	Overhead Service			IV
132205873	S86580	08/08/2013	13:33	08/08/2013	14:19	1	46	46	Overhead equipment	Disconnect Switch	Patrol/Test/Inspect	Replace - Same Size	VI
132206068	J58381	08/08/2013	14:14	08/08/2013	15:08	1	54	54	Unknown				III
132206095	L50214	08/08/2013	14:19	08/08/2013	15:45	1	86	86	Overhead equipment	Fuse	Replace - Same Size		VI
132206117	Y36541	08/08/2013	14:25	08/08/2013	15:10	1	45	45	Unknown	Fuse	Repair		IV
132206269	B76001	08/08/2013	14:57	08/08/2013	21:20	1	383	383	Underground equipment	Underground Primary	Repair	Replace - Same Size	I
132206564	S13550	08/08/2013	16:09	08/08/2013	17:55	1	106	106	Tree related-tree broken	Overhead Service	Patrol/Test/Inspect	Repair	VI
132206618	J18268	08/08/2013	16:24	08/08/2013	17:46	1	82	82	Weather	Transformer Fuse		Patrol/Test/Inspect	VI
132206698	M12151	08/08/2013	16:52	08/08/2013	17:25	1	33	33	Jurisdictional				VI
132206821	Y35515	08/08/2013	17:33	08/08/2013	19:15	49	4998	102	Tree related-tree broken	Overhead Primary			IV
132206804	Y37009	08/08/2013	17:57	08/08/2013	21:00	7	1281	183	Tree related-tree broken	Overhead Primary	Replace - Same Size	Replace - Same Size	IV
132207544	X15746	08/08/2013	18:00	08/08/2013	21:24	2	408	204	Overhead equipment	Jumper	Repair		IV
132207397	R01152	08/08/2013	18:48	08/08/2013	21:31	60	9780	163	Underground equipment	Underground Primary	Patrol/Test/Inspect	Switch/Reset	III
132207456	S13550	08/08/2013	19:19	08/08/2013	21:27	1	128	128	Tree related-tree broken	Overhead Service	Reconnect	No Work Required	VI
132207464	U73599	08/08/2013	19:23	08/09/2013	0:40	15	4755	317	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	II
132207524	X42502	08/08/2013	20:58	08/09/2013	2:45	9	3123	347	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	IV
132207571	L95210	08/08/2013	22:32	08/08/2013	23:30	1	58	58	Tree related-tree contact	Overhead Service	Repair		III
132214626	D70001	08/09/2013	6:13	08/09/2013	8:46	26	3978	153	Underground equipment	Underground Primary			I
132214448	D70001	08/09/2013	6:13	08/09/2013	8:51	96	15168	158	Underground equipment	Underground Primary	Switch/Reset	Repair	I
132214467	X72535	08/09/2013	6:43	08/09/2013	8:02	1	79	79	Overhead equipment	Fuse	Replace - Same Size		IV
132214573	Z19547	08/09/2013	7:34	08/09/2013	10:00	1	146	146	Overhead equipment	Overhead Transformer	Replace - New Size	Replace - New Size	IV

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
132214593	K69117	08/09/2013	7:42	08/09/2013	9:45	1	123	123	Overhead equipment	Overhead Transformer	Replace - Same Size	No Work Required	IV
132214675	P26283	08/09/2013	8:05	08/09/2013	9:15	102	7140	70	Animal related	Fuse	Patrol/Test/Inspect		I
132214685	P98190	08/09/2013	8:13	08/09/2013	9:26	1	73	73	Tree related-tree broken	Overhead Service			III
132214749	M04365	08/09/2013	8:29	08/09/2013	10:15	56	5936	106	Public	Underground Primary	Cut in Clear	Repair	V
132214807	X66582	08/09/2013	8:48	08/09/2013	10:39	1	111	111	Public	Overhead Service	Cut in Clear	Advise Customer	IV
132214885	D88002	08/09/2013	9:08	08/09/2013	9:35	12	324	27	Animal related	Fuse	Replace - Same Size		I
132214895	D88002	08/09/2013	9:10	08/09/2013	9:41	1	31	31	Animal related	Fuse	Replace - Same Size		I
132214904	B19001	08/09/2013	9:14	08/09/2013	12:07	1	173	173	Animal related	Overhead Primary			I
132214949	S66595	08/09/2013	9:17	08/09/2013	13:48	33	8943	271	Tree related-tree broken	Pole	Replace - Same Size	Replace - Same Size	VI
132215113	P52305	08/09/2013	9:39	08/09/2013	11:32	38	4294	113	Overhead equipment	Overhead Primary		Repair	IV
132214924	N42856	08/09/2013	10:30	08/09/2013	11:25	1	55	55	Tree related-tree broken	Tree			V
132215278	N93260	08/09/2013	10:32	08/09/2013	12:40	1	128	128	Overhead equipment	Transformer Fuse	Replace - Same Size		III
132215510	P69174	08/09/2013	11:22	08/09/2013	11:49	1	27	27	Unknown	Fuse	Replace - Same Size		III
132215626	F10002	08/09/2013	11:54	08/09/2013	13:33	1	99	99	Overhead equipment	Other	Patrol/Test/Inspect	Patrol/Test/Inspect	III
132215799	B80004	08/09/2013	12:47	08/09/2013	15:00	2	266	133	Underground equipment	Switchgear	Patrol/Test/Inspect	Repair	I
132216186	Q91175	08/09/2013	14:25	08/09/2013	15:20	1	55	55	Overhead equipment	Transformer Fuse	Replace - Same Size		I
132216243	R60552	08/09/2013	14:40	08/09/2013	17:25	1	165	165	Overhead equipment	Transformer Fuse	Replace - Same Size	No Work Required	IV
132216327	Y35003	08/09/2013	14:55	08/09/2013	15:30	1	35	35	Overhead equipment	Overhead Service			IV
132216353	M81402	08/09/2013	14:58	08/09/2013	16:13	1	75	75	Overhead equipment	Fuse	Repair		V
132216356	U03001	08/09/2013	15:00	08/09/2013	17:02	1	122	122	Public	Underground Primary	Repair	Repair	II
132216473	Q32171	08/09/2013	15:45	08/09/2013	17:26	1	101	101	Jurisdictional	Meter	No Work Required	No Work Required	I
132216474		08/09/2013	15:46	08/09/2013	16:45	1	59	59	Overhead equipment	Fuse	Repair		VI
132216502	B73001	08/09/2013	16:01	08/09/2013	16:55	1	54	54	Overhead equipment	Disconnect Switch	Replace - Same Size		I
132216695	315110	08/09/2013	16:02	08/09/2013	20:41	11	3069	279	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	V
132216521	K73362	08/09/2013	16:09	08/09/2013	16:53	1	44	44	Overhead equipment				IV
132216626	C30002	08/09/2013	16:59	08/09/2013	20:20	38	7638	201	Overhead equipment	Fuse	Replace - Same Size	No Work Required	III
132216697	B25001	08/09/2013	17:47	08/09/2013	21:16	1	209	209	Tree related-tree broken	Overhead Primary		Repair	I
132217403	B84005	08/09/2013	22:47	08/10/2013	2:17	13	2730	210	Underground equipment	Underground Primary	Switch/Reset		I
132220031	S27598	08/10/2013	0:34	08/10/2013	8:15	2	922	461	Underground equipment	Underground Primary	Repair	Repair	VI
132220025	B82001	08/10/2013	2:23	08/10/2013	5:11	1	168	168	Animal related	Fuse			I
132220041	J63173	08/10/2013	3:24	08/10/2013	5:30	20	2520	126	Underground equipment	Underground Primary			III
132220065	B45005	08/10/2013	4:14	08/10/2013	5:16	25	1550	62	Unknown	Fuse	Repair		I
132220070	T09559	08/10/2013	4:53	08/10/2013	6:32	1	99	99	Overhead equipment				VI
132220081	D70001	08/10/2013	5:40	08/10/2013	7:16	1059	101664	96	Underground equipment	Underground Primary	Switch/Reset	Repair	I
132220104	S61530	08/10/2013	7:05	08/10/2013	7:32	38	1026	27	Overhead equipment				VI
132220122	B76002	08/10/2013	7:41	08/10/2013	10:45	1	184	184	Underground equipment	Underground Service	Patrol/Test/Inspect	Repair	I
132220136	H11340	08/10/2013	8:11	08/10/2013	8:57	1	46	46	Overhead equipment	Overhead Transformer	Switch/Reset		V
132220067	306003	08/10/2013	8:28	08/10/2013	9:45	1	77	77	Public	Pole	Patrol/Test/Inspect	Repair	VI
132220174	B08004	08/10/2013	8:34	08/10/2013	13:24	6	1740	290	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
132220151	Q11516	08/10/2013	8:45	08/10/2013	9:53	5	340	68	Animal related	Fuse	Replace - Same Size	No Work Required	I
132220152	Q91175	08/10/2013	8:47	08/10/2013	9:46	1	59	59	Weather	Transformer Fuse	Replace - Same Size		I
132220169	L95110	08/10/2013	9:14	08/10/2013	10:34	1	80	80	Tree related-tree contact	Tree	Trim		III
132220230	D70001	08/10/2013	9:40	08/10/2013	11:49	30	3870	129	Underground equipment	Underground Primary	Patrol/Test/Inspect		I
132220198	K89142	08/10/2013	9:45	08/10/2013	15:54	1	369	369	Underground equipment	Underground Service	Patrol/Test/Inspect	Repair	III
132220265	M37192	08/10/2013	11:10	08/10/2013	13:49	1	159	159	Overhead equipment	Transformer Fuse	Replace - Same Size	Replace - New Size	I
132220278	T28561	08/10/2013	11:19	08/10/2013	12:40	1	81	81	Animal related	Transformer Fuse			VI
132220283	S28552	08/10/2013	11:27	08/10/2013	12:16	1	49	49	Overhead equipment	Meter			VI
132220286	V50001	08/10/2013	11:31	08/10/2013	12:37	5	330	66	Animal related	Transformer Fuse	Replace - Same Size		II
132220300	X96524	08/10/2013	11:42	08/10/2013	17:06	1	324	324	Underground equipment	Lightning Arrestor		Patrol/Test/Inspect	IV
132220398	V23530	08/10/2013	12:38	08/10/2013	14:15	6	582	97	Animal related	Transformer Fuse	Repair		II
132220400	P47123	08/10/2013	12:42	08/10/2013	15:20	1	158	158	Overhead equipment	Transformer Fuse	Replace - Same Size	No Work Required	I
132220424	N67315	08/10/2013	13:09	08/10/2013	14:44	1	95	95	Tree related-tree contact	Overhead Service	Repair		I
132220439	S86592	08/10/2013	13:44	08/10/2013	14:20	8	288	36	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Repair	VI
132220450	Z05550	08/10/2013	14:04	08/10/2013	15:05	1	61	61	Overhead equipment	Fuse	Replace - Same Size		IV
132220457	R49275	08/10/2013	14:18	08/10/2013	16:31	1	133	133	Tree related-tree contact	Overhead Service	Replace - Same Size		VI
132220458	Z06537	08/10/2013	14:21	08/10/2013	15:05	1	44	44	Overhead equipment	Fuse	Replace - Same Size		IV

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
132220461	X03533	08/10/2013	14:22	08/10/2013	15:28	1	66	66	Animal related	Fuse	Replace - Same Size		IV
132220470	B80002	08/10/2013	14:31	08/10/2013	16:25	86	9804	114	Public	Underground Primary	Switch/Reset	Repair	I
132220476	Z05550	08/10/2013	14:36	08/10/2013	15:05	1	29	29	Overhead equipment	Fuse	Replace - Same Size		IV
132220483	B61001	08/10/2013	14:51	08/10/2013	23:30	1	519	519	Underground equipment	Underground Primary	Replace - Same Size	Replace - Same Size	I
132220525	M04365	08/10/2013	15:44	08/10/2013	17:15	29	2639	91	Animal related	Fuse	Replace - Same Size		V
132220526	B21003	08/10/2013	15:53	08/10/2013	20:00	1	247	247	Overhead equipment	Meter	Cut in Clear	Repair	I
132220561	X75571	08/10/2013	16:47	08/10/2013	19:19	1	152	152	Animal related	Overhead Transformer	Repair		IV
132220580	B80002	08/10/2013	17:11	08/10/2013	21:31	74	19240	260	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
132220587	Q64919	08/10/2013	17:25	08/10/2013	21:10	1	225	225	Weather	Underground Secondary	Patrol/Test/Inspect	Replace - Same Size	VI
132220660	D70004	08/10/2013	18:13	08/11/2013	4:45	2	1264	632	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
132220609	D70004	08/10/2013	18:13	08/10/2013	20:33	116	16240	140	Underground equipment	Underground Primary	Replace - Same Size	Replace - Same Size	I
132220622	R33126	08/10/2013	18:47	08/10/2013	21:40	20	3460	173	Animal related	Fuse	Patrol/Test/Inspect	Patrol/Test/Inspect	I
132220623	V95586	08/10/2013	19:01	08/10/2013	21:33	1	152	152	Animal related	Transformer Fuse	Replace - Same Size		II
132220627	R33126	08/10/2013	19:13	08/10/2013	21:40	1	147	147	Animal related	Fuse	Replace - Same Size	Patrol/Test/Inspect	I
132220630	Q34360	08/10/2013	19:23	08/10/2013	22:47	13	2652	204	Tree related-tree broken	Overhead Secondary	Repair	Repair	I
132220636	L59923	08/10/2013	19:40	08/10/2013	23:27	24	5448	227	Tree related-tree broken	Overhead Primary		Repair	VI
132230066	D37004	08/10/2013	23:12	08/11/2013	6:25	6	2598	433	Underground equipment	Underground Primary	Repair	No Work Required	I
132230033	D37004	08/10/2013	23:12	08/11/2013	1:38	2	292	146	Underground equipment	Underground Primary	Switch/Reset	Repair	I
132230032	D37004	08/10/2013	23:12	08/11/2013	1:38	103	15038	146	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
132220731	310122	08/10/2013	23:21	08/11/2013	1:06	34	3570	105	Overhead equipment	Fuse	Replace - Same Size		V
132230026		08/11/2013	1:19	08/11/2013	3:00	1	101	101	Tree related-tree contact	Overhead Secondary	Repair		I
132230086	X96738	08/11/2013	6:37	08/11/2013	9:08	179	27029	151	Overhead equipment				IV
132230104	K22173	08/11/2013	7:21	08/11/2013	8:34	1	73	73	Overhead equipment	Transformer Fuse	Repair	Repair	VI
132230107	B35002	08/11/2013	7:26	08/11/2013	8:48	8	656	82	Overhead equipment	Disconnect Switch			I
132230114	P52305	08/11/2013	7:28	08/11/2013	16:22	86	45924	534	Public	Pole		Replace - New Size	IV
132230119	P60170	08/11/2013	7:33	08/11/2013	9:03	3	270	90	Animal related	Transformer Fuse	Replace - Same Size		VI
132230120	K52401	08/11/2013	7:36	08/11/2013	8:08	6	192	32	Animal related	Transformer Fuse	Replace - Same Size	Replace - Same Size	V
132230121	Q32170	08/11/2013	7:39	08/11/2013	8:55	1	76	76	Animal related	Fuse	Patrol/Test/Inspect	Repair	I
132230129	X69555	08/11/2013	8:12	08/11/2013	9:12	1	60	60	Overhead equipment	Fuse			IV
132230188	L74191	08/11/2013	9:30	08/11/2013	11:28	4	472	118	Animal related	Transformer Fuse	Replace - Same Size		IV
132230168	B84003	08/11/2013	9:49	08/11/2013	11:25	1	96	96	Animal related	Disconnect Switch	Replace - Same Size	No Work Required	I
132230170	S86582	08/11/2013	9:53	08/11/2013	11:24	1	91	91	Animal related	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
132230196	J39392	08/11/2013	10:33	08/11/2013	12:56	1	143	143	Underground equipment	Underground Primary		Repair	III
132230219	P62138	08/11/2013	11:14	08/11/2013	18:14	9	3780	420	Underground equipment	Underground Primary	Patrol/Test/Inspect		VI
132230217	C50001	08/11/2013	11:18	08/11/2013	13:11	1	113	113	Overhead equipment	Overhead Secondary	Repair	No Work Required	III
132230239	P26283	08/11/2013	12:04	08/11/2013	18:34	1	390	390	Underground equipment	Underground Service	Patrol/Test/Inspect	Repair	I
132230258	B84005	08/11/2013	13:00	08/12/2013	1:00	24	17280	720	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
132230337	H06135	08/11/2013	13:26	08/11/2013	14:55	1	89	89	Animal related	Transformer Fuse	Replace - Same Size		IV
132230364	S47575	08/11/2013	14:29	08/11/2013	15:10	1	41	41	Overhead equipment	Fuse	Replace - Same Size		VI
132230365	A81004	08/11/2013	14:32	08/11/2013	17:15	2	326	163	Overhead equipment	Transformer Fuse	Repair		I
132230441	S86581	08/11/2013	16:59	08/11/2013	18:28	1	89	89	Animal related	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
132230472	C76002	08/11/2013	18:02	08/12/2013	4:50	1	648	648	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
132230487	K30204	08/11/2013	18:49	08/11/2013	21:09	1	140	140	Animal related	Transformer Fuse		Replace - Same Size	III
132230506	K07322	08/11/2013	19:40	08/11/2013	20:07	1	27	27	Animal related	Transformer Fuse	Replace - Same Size		I
132230514	L70128	08/11/2013	19:59	08/11/2013	21:03	1	64	64	Animal related	Transformer Fuse	Replace - Same Size		IV
132230535	J20931	08/11/2013	20:55	08/12/2013	1:20	1	265	265	Underground equipment	Lightning Arrestor		Repair	VI
132230553	P73182	08/11/2013	21:42	08/11/2013	23:55	1	133	133	Animal related	Fuse	Replace - Same Size		VI
132230565	L35139	08/11/2013	22:20	08/11/2013	23:50	22	1980	90	Overhead equipment	Jumper	Repair		III
132230575	L71170	08/11/2013	23:03	08/12/2013	0:34	2	182	91	Animal related	Transformer Fuse	Replace - Same Size		IV
132240085	Z10500	08/12/2013	0:01	08/12/2013	1:02	1	61	61	Unknown	Transformer Fuse			IV
132240102	V82002	08/12/2013	1:51	08/12/2013	3:35	1	104	104	Overhead equipment	Transformer Fuse	Replace - Same Size		II
132240106	Y59519	08/12/2013	2:47	08/12/2013	4:35	1	108	108	Overhead equipment	Lightning Arrestor	Replace - Same Size		IV
132243885	X39530	08/12/2013	3:46	08/12/2013	6:12	1	146	146	Animal related	Lightning Arrestor	Replace - Same Size		IV
132243889	J63173	08/12/2013	3:57	08/12/2013	8:20	52	13676	263	Underground equipment	Underground Primary	Repair	Repair	III
132243898	Q82906	08/12/2013	4:12	08/12/2013	5:45	6	558	93	Tree related-tree broken	Tree			VI
132243936	L90359	08/12/2013	6:20	08/12/2013	7:20	1	60	60	Public	Overhead Service	Cut in Clear	Repair	V

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
132243968	D48003	08/12/2013	6:57	08/12/2013	10:49	1	232	232	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
132243976	B19002	08/12/2013	7:02	08/12/2013	8:35	1	93	93	Animal related	Transformer Fuse	Replace - Same Size	No Work Required	I
132243981	D81001	08/12/2013	7:06	08/12/2013	8:03	1	57	57	Overhead equipment	Connector	Repair		I
132244065	B84006	08/12/2013	7:31	08/12/2013	10:12	16	2576	161	Underground equipment	Underground Primary	Switch/Reset	Repair	I
132244083	342004	08/12/2013	7:39	08/12/2013	8:45	1	66	66	Tree related-tree broken	Tree	Patrol/Test/Inspect		VI
132244090	342004	08/12/2013	7:41	08/12/2013	8:17	1	36	36	Tree related-tree broken	Tree	Cut in Clear		VI
132244092	B65001	08/12/2013	7:42	08/12/2013	9:20	1	98	98	Overhead equipment	Connector	Repair	Replace - Same Size	I
132244119	Q25802	08/12/2013	7:53	08/12/2013	14:41	1	408	408	Underground equipment	Underground Primary	Repair	Repair	I
132244141	J83137	08/12/2013	7:56	08/12/2013	9:02	67	4422	66	Overhead equipment	Lightning Arrestor	Replace - Same Size		VI
132244167	T06505	08/12/2013	8:05	08/12/2013	13:03	1	298	298	Overhead equipment				VI
132244418	P52305	08/12/2013	9:08	08/12/2013	9:52	1	44	44	Animal related	Disconnect Switch		Replace - Same Size	IV
132244694	V24583	08/12/2013	9:51	08/12/2013	15:00	1	309	309	Underground equipment	Underground Primary	Repair		II
132245637	B84006	08/12/2013	10:12	08/12/2013	14:16	7	1708	244	Underground equipment	Underground Primary			I
132244880	Q01282	08/12/2013	10:25	08/12/2013	13:01	4	624	156	Underground equipment	Underground Primary			III
132244934	Q91175	08/12/2013	10:32	08/12/2013	12:16	1	104	104	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	I
132244929	B65003	08/12/2013	10:32	08/12/2013	11:53	1	81	81	Overhead equipment	Connector	Repair	Replace - Same Size	I
132245161	U31598	08/12/2013	10:54	08/12/2013	15:56	6	1812	302	Underground equipment	Underground Primary	Repair	Repair	II
132245130	Y51505	08/12/2013	11:07	08/12/2013	12:35	6	528	88	Animal related	Transformer Fuse			IV
132245196	S22595	08/12/2013	11:21	08/12/2013	14:30	1	189	189	Overhead equipment	Overhead Transformer			VI
132245336	M36185	08/12/2013	11:44	08/12/2013	13:12	1	88	88	Overhead equipment	Overhead Service	No Work Required		I
132245437		08/12/2013	12:01	08/12/2013	14:30	1	149	149	Public	Underground Primary		Repair	IV
132245474	R09226	08/12/2013	12:12	08/12/2013	14:05	1	113	113	Animal related	Transformer Fuse		Replace - Same Size	III
132245522	X23516	08/12/2013	12:25	08/12/2013	16:05	1	220	220	Overhead equipment	Overhead Transformer	Replace - Same Size	Patrol/Test/Inspect	IV
132245606	L90359	08/12/2013	12:43	08/12/2013	13:14	1	31	31	Public				V
132245671	M06622	08/12/2013	12:53	08/12/2013	16:53	1	240	240	Overhead equipment	Overhead Transformer	Cut in Clear	Replace - Same Size	V
132245752	J06168	08/12/2013	13:05	08/12/2013	14:09	1	64	64	Overhead equipment	Overhead Service	No Work Required		I
132245774	J06168	08/12/2013	13:07	08/12/2013	14:32	1	85	85	Overhead equipment	Fuse	Replace - Same Size		I
132245763	Y28597	08/12/2013	13:07	08/12/2013	14:02	1	55	55	Overhead equipment	Overhead Service	Repair		IV
132245984	T16526	08/12/2013	13:07	08/12/2013	19:30	15	5745	383	Overhead equipment	Fuse			VI
132245838	310124	08/12/2013	13:15	08/12/2013	14:12	45	2565	57	Weather	Fuse	Replace - Same Size	No Work Required	V
132245864	H11337	08/12/2013	13:25	08/12/2013	15:50	22	3190	145	Weather	Overhead Primary	Repair		V
132245902	J34357	08/12/2013	13:33	08/12/2013	15:40	1	127	127	Tree related-tree contact	Overhead Service	Repair		V
132245969	S28551	08/12/2013	13:43	08/12/2013	15:22	1	99	99	Tree related-tree broken	Customer Equipment	Replace - Same Size		VI
132246096	J71128	08/12/2013	14:07	08/12/2013	15:30	1	83	83	Public	Fuse	Patrol/Test/Inspect	Replace - Same Size	I
132246148	T16527	08/12/2013	14:18	08/12/2013	15:15	1	57	57	Overhead equipment	Overhead Service	Repair		VI
132246541	M61302	08/12/2013	14:44	08/12/2013	16:53	35	4515	129	Tree related-tree contact	Transformer Fuse	Trim	Trim	V
132246347	U93001	08/12/2013	14:57	08/12/2013	15:35	1	38	38	Public	Overhead Service	Repair	Repair	II
132246439	S41564	08/12/2013	15:18	08/12/2013	16:08	1	50	50	Overhead equipment	Overhead Service	Repair	Replace - Same Size	VI
132246515	M22812	08/12/2013	15:35	08/12/2013	16:17	1	42	42	Overhead equipment	Transformer Fuse	Replace - Same Size		V
132246619	D88002	08/12/2013	16:01	08/12/2013	20:30	1	269	269	Underground equipment	Underground Service	Patrol/Test/Inspect	Repair	I
132246634	K28180	08/12/2013	16:06	08/12/2013	18:00	1	114	114	Overhead equipment	Overhead Transformer		Replace - Same Size	III
132246761	K46388	08/12/2013	16:08	08/12/2013	18:16	5	640	128	Animal related	Fuse	Replace - Same Size		V
132246655	M18131	08/12/2013	16:09	08/12/2013	17:00	1	51	51	Animal related	Transformer Fuse	Replace - Same Size		III
132246824	T28561	08/12/2013	17:16	08/12/2013	18:50	1	94	94	Overhead equipment	Transformer Fuse	Repair	No Work Required	VI
132246928	342001	08/12/2013	17:19	08/12/2013	19:00	24	2424	101	Tree related-tree broken	Tree	Remove		VI
132246852	P58155	08/12/2013	17:19	08/12/2013	20:54	157	33755	215	Tree related-tree broken	Overhead Primary		Reconnect	VI
132246884	Q01282	08/12/2013	17:40	08/12/2013	19:59	4	556	139	Unknown				III
132246890	D96001	08/12/2013	17:41	08/13/2013	1:30	1	469	469	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
132247211	K74166	08/12/2013	19:14	08/12/2013	20:00	1	46	46	Unknown	Fuse	Replace - Same Size	No Work Required	IV
132247727	E10002	08/12/2013	19:37	08/12/2013	20:45	1	68	68	Overhead equipment	Fuse	Replace - Same Size	Repair	III
132247731	B68002	08/12/2013	19:40	08/12/2013	20:08	1	28	28	Overhead equipment	Fuse	Replace - Same Size	Repair	III
132247740	K76545	08/12/2013	19:49	08/13/2013	0:09	2	520	260	Public	Overhead Service	Repair	No Work Required	IV
132247737	J89126	08/12/2013	19:49	08/12/2013	22:27	1	158	158	Overhead equipment	Disconnect Switch	Patrol/Test/Inspect	Replace - Same Size	VI
132247964	Q06695	08/12/2013	20:12	08/12/2013	21:55	1	103	103	Overhead equipment	Overhead Primary			IV
132247802	Q06695	08/12/2013	20:12	08/13/2013	1:28	2	632	316	Overhead equipment	Overhead Primary			IV
132248002	Q06695	08/12/2013	20:12	08/12/2013	21:59	968	103576	107	Substation equipment				IV

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
132247804	K71812	08/12/2013	20:23	08/12/2013	23:17	17	2958	174	Overhead equipment	Overhead Primary			IV
132247806	S41564	08/12/2013	20:24	08/12/2013	21:08	1	44	44	Tree related-tree broken	Overhead Service	Replace - Same Size	No Work Required	VI
132247835	B58001	08/12/2013	20:28	08/12/2013	22:58	68	10200	150	Overhead equipment	Overhead Primary	Repair	Repair	I
132247827	U33586	08/12/2013	20:34	08/12/2013	21:53	1	79	79	Overhead equipment	Transformer Fuse	Repair	Repair	II
132247832	D96002	08/12/2013	20:35	08/12/2013	23:55	1	200	200	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
132247956	Q28141	08/12/2013	21:00	08/12/2013	22:18	3	234	78	Underground equipment	Underground Primary	Cut in Clear	Repair	VI
132247857	R49275	08/12/2013	21:14	08/13/2013	3:24	1	370	370	Tree related-tree broken	Overhead Primary		Repair	VI
132247862	N54214	08/12/2013	21:16	08/12/2013	23:29	50	6650	133	Underground equipment	Underground Primary	Switch/Reset	Repair	II
132247962	D16002	08/12/2013	21:34	08/13/2013	2:56	829	266938	322	Underground equipment	Underground Primary	Repair	Repair	I
132247926		08/12/2013	21:39	08/13/2013	2:52	1	313	313	Underground equipment				I
132248012	J06167	08/12/2013	22:20	08/13/2013	1:53	14	2982	213	Overhead equipment	Recloser	Switch/Reset	Patrol/Test/Inspect	I
132248025	J06167	08/12/2013	22:41	08/13/2013	2:29	1	228	228	Overhead equipment	Transformer Fuse	Replace - Same Size	Patrol/Test/Inspect	I
132248029	L00134	08/12/2013	22:48	08/13/2013	1:38	28	4760	170	Underground equipment	Underground Primary	Switch/Reset	Repair	III
132253614	B68004	08/13/2013	3:58	08/13/2013	11:24	7	3122	446	Underground equipment	Underground Primary			III
132253906	D36002	08/13/2013	5:22	08/13/2013	13:30	26	12688	488	Underground equipment	Underground Primary	Repair	Repair	I
132253909	K69117	08/13/2013	5:28	08/13/2013	7:20	1	112	112	Tree related-tree contact			No Work Required	IV
132253922	V69546	08/13/2013	5:44	08/13/2013	11:15	46	15226	331	Public	Pole	Replace - New Size	Replace - New Size	II
132254049	310124	08/13/2013	6:12	08/13/2013	8:58	7	1162	166	Overhead equipment	Fuse	Replace - New Size	Repair	V
132253947	M81405	08/13/2013	6:14	08/13/2013	7:06	1	52	52	Animal related	Transformer Fuse	Replace - Same Size	Replace - Same Size	V
132253920	B65003	08/13/2013	6:23	08/13/2013	12:06	1	343	343	Overhead equipment	Pole		Replace - Same Size	I
132253959	X52537	08/13/2013	6:39	08/13/2013	7:45	1	66	66	Animal related	Fuse	Replace - Same Size		IV
132253985	R84148	08/13/2013	6:59	08/13/2013	7:45	1	46	46	Animal related	Transformer Fuse	Replace - Same Size		I
132254007	K46388	08/13/2013	7:12	08/13/2013	8:37	1	85	85	Tree related-tree contact	Tree	Cut in Clear	Cut in Clear	V
132254047	D90003	08/13/2013	7:23	08/13/2013	8:35	1	72	72	Animal related	Animal Guard			III
132254076	Q06142	08/13/2013	7:30	08/13/2013	8:30	1	60	60	Animal related	Transformer Fuse	Replace - Same Size	No Work Required	IV
132254088	D88001	08/13/2013	7:35	08/13/2013	10:08	10	1530	153	Animal related	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	I
132254102	Y89540	08/13/2013	7:40	08/13/2013	9:30	1	110	110	Tree related-tree broken	Overhead Service	Raise		IV
132254117	S61530	08/13/2013	7:43	08/13/2013	8:30	38	1786	47	Animal related	Fuse			VI
132254176		08/13/2013	7:49	08/13/2013	8:48	1008	59472	59	Animal related				I
132254600	R58941	08/13/2013	9:29	08/13/2013	10:26	1	57	57	Overhead equipment	Overhead Service	Repair	No Work Required	IV
132254623	L70128	08/13/2013	9:29	08/13/2013	10:13	25	1100	44	Unknown	Fuse	Repair		IV
132254758		08/13/2013	9:56	08/16/2013	15:52	1	4676	4676	Weather	Overhead Transformer		Replace - Same Size	II
132254870	V18541	08/13/2013	10:17	08/13/2013	11:11	20	1080	54	Animal related	Other			II
132255021	P62138	08/13/2013	10:40	08/13/2013	11:11	1541	47771	31	Animal related				VI
132255454	K80386	08/13/2013	12:09	08/13/2013	13:00	1	51	51	Underground equipment	Underground Service		Repair	IV
132255482	R84148	08/13/2013	12:16	08/13/2013	13:26	1	70	70	Overhead equipment	Transformer Fuse	Replace - Same Size		I
132255492	P98193	08/13/2013	12:20	08/13/2013	13:08	1	48	48	Overhead equipment	Connector	Repair	Repair	III
132255805	R60554	08/13/2013	12:28	08/13/2013	14:06	6	588	98	Underground equipment	Underground Primary	Switch/Reset	Repair	IV
132255691	P62138	08/13/2013	13:05	08/13/2013	13:36	1	31	31	Unknown				VI
132255706	C10002	08/13/2013	13:09	08/13/2013	14:08	1	59	59	Overhead equipment	Transformer Fuse	Replace - Same Size	No Work Required	III
132255913	D28123	08/13/2013	13:40	08/13/2013	19:30	4	1400	350	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
132256853	Q32170	08/13/2013	15:29	08/13/2013	20:30	2	602	301	Overhead equipment	Overhead Transformer	Replace - Same Size	Patrol/Test/Inspect	I
132256667	Q32170	08/13/2013	15:29	08/13/2013	17:43	7	938	134	Overhead equipment	Fuse	Patrol/Test/Inspect	Patrol/Test/Inspect	I
132256462	D16002	08/13/2013	15:37	08/13/2013	17:37	7	840	120	Tree related-tree broken	Crossarm	Replace - Same Size	Repair	I
132256744	J75271	08/13/2013	16:20	08/13/2013	17:51	26	2366	91	Unknown				IV
132256702	D32211	08/13/2013	16:47	08/13/2013	20:10	1	203	203	Public	Underground Primary	Repair		I
132256733	L12127	08/13/2013	16:57	08/13/2013	18:30	41	3813	93	Underground equipment	Underground Primary		Repair	III
132256836	L79180	08/13/2013	17:27	08/13/2013	21:12	8	1800	225	Underground equipment	Underground Primary		Repair	IV
132257316	L79180	08/13/2013	17:27	08/13/2013	18:33	11	726	66	Underground equipment	Underground Transformer	Switch/Reset		IV
132256828	B44002	08/13/2013	17:28	08/13/2013	18:27	1	59	59	Tree related-tree contact	Tree	No Work Required		I
132256891	314167	08/13/2013	18:03	08/13/2013	18:49	7	322	46	Overhead equipment	Overhead Transformer	Repair		V
132256969	J63172	08/13/2013	18:26	08/13/2013	19:27	129	7869	61	Overhead equipment	Disconnect Switch	Switch/Reset	Repair	III
132257441	L79180	08/13/2013	19:07	08/13/2013	19:24	18	306	17	Underground equipment	Underground Primary	Switch/Reset		IV
132257451	Q85162	08/13/2013	19:24	08/13/2013	20:08	1	44	44	Overhead equipment	Fuse	Repair	Repair	VI
132257456	J63172	08/13/2013	19:27	08/13/2013	20:04	5	185	37	Animal related	Fuse			III
132257464	U44568	08/13/2013	19:45	08/13/2013	20:07	1	22	22	Overhead equipment	Transformer Fuse	Repair	Repair	II

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
132258305	B81001	08/13/2013	21:00	08/14/2013	5:50	1	530	530	Underground equipment	Other		Repair	I
132258320	303002	08/13/2013	21:25	08/13/2013	22:09	1	44	44	Tree related-tree broken	Overhead Service	Repair	Replace - New Size	VI
132258327	A45003	08/13/2013	21:40	08/14/2013	2:13	1	273	273	Underground equipment	Underground Primary		Repair	I
132258334	348117	08/13/2013	21:52	08/13/2013	22:29	1	37	37	Tree related-tree broken	Overhead Service	Move	Install	V
132258343	Q27185	08/13/2013	22:05	08/14/2013	0:15	12	1560	130	Tree related-tree contact	Fuse	Replace - Same Size		VI
132260106	348118	08/14/2013	0:08	08/14/2013	1:50	22	2244	102	Other	Overhead Primary			V
132260120	U60559	08/14/2013	0:42	08/14/2013	2:00	1	78	78	Animal related	Transformer Fuse	Replace - Same Size		II
132263511	Q06144	08/14/2013	4:45	08/14/2013	5:50	1	65	65	Animal related	Transformer Fuse	Replace - Same Size	No Work Required	IV
132263522	Q32171	08/14/2013	4:47	08/14/2013	6:00	54	3942	73	Animal related	Recloser	No Work Required	No Work Required	I
132263753	K31124	08/14/2013	5:32	08/14/2013	11:09	3	1011	337	Underground equipment	Underground Primary	Repair		I
132263544	Q32171	08/14/2013	6:05	08/14/2013	6:35	1	30	30	Animal related	Transformer Fuse	Replace - Same Size	Patrol/Test/Inspect	I
132263547	Y45504	08/14/2013	6:14	08/14/2013	7:20	1	66	66	Overhead equipment	Transformer Fuse	Repair	Replace - Same Size	IV
132263568	S42579	08/14/2013	6:51	08/14/2013	8:20	1	89	89	Animal related	Disconnect Switch	Replace - New Size		VI
132263656	S22594	08/14/2013	7:13	08/14/2013	7:50	29	1073	37	Public				VI
132263666	U37579	08/14/2013	7:27	08/14/2013	8:00	1	33	33	Overhead equipment	Transformer Fuse	Replace - Same Size	Patrol/Test/Inspect	II
132263716	D69004	08/14/2013	7:38	08/14/2013	10:49	89	16999	191	Underground equipment	Underground Primary	Switch/Reset	Repair	I
132263743	J74125	08/14/2013	7:47	08/14/2013	8:32	1	45	45	Animal related	Transformer Fuse			VI
132263821	K05253	08/14/2013	8:14	08/14/2013	8:51	1	37	37	Animal related	Transformer Fuse			VI
132263960	P54828	08/14/2013	8:47	08/14/2013	9:34	1	47	47	Animal related	Transformer Fuse	Replace - Same Size		V
132264062	D89001	08/14/2013	9:01	08/14/2013	14:30	4	1316	329	Underground equipment	Underground Primary	Repair	Replace - Same Size	I
132264265	J14140	08/14/2013	9:54	08/14/2013	11:59	1	125	125	Weather	Fuse	Replace - Same Size		VI
132264365	P52305	08/14/2013	10:15	08/14/2013	10:38	1	23	23	Animal related	Transformer Fuse	Replace - Same Size	No Work Required	IV
132264454	V20502	08/14/2013	10:35	08/14/2013	15:53	1	318	318	Underground equipment	Underground Service			II
132264704	X13001	08/14/2013	11:04	08/14/2013	11:13	348	3132	9	Unknown	Substation Breaker			IV
132264669	Z33507	08/14/2013	11:05	08/14/2013	11:13	376	3008	8	Unknown	Substation Breaker			IV
132264725	R20502	08/14/2013	11:21	08/14/2013	12:15	1	54	54	Overhead equipment	Fuse	Replace - Same Size		IV
132264982	B28006	08/14/2013	12:10	08/14/2013	14:11	28	3388	121	Underground equipment	Underground Primary	Switch/Reset	Repair	I
132265040	P17108	08/14/2013	12:27	08/14/2013	13:35	1	68	68	Unknown	Transformer Fuse	Replace - Same Size		IV
132265163	J06167	08/14/2013	12:55	08/14/2013	13:57	1	62	62	Overhead equipment	Fuse	Replace - Same Size		I
132265357	V21548	08/14/2013	13:23	08/14/2013	18:27	11	3344	304	Underground equipment	Underground Primary	Repair		II
132265587	N86225	08/14/2013	15:14	08/14/2013	16:38	1	84	84	Public	Overhead Service		Replace - Same Size	VI
132265969	V92555	08/14/2013	15:50	08/14/2013	16:30	1	40	40	Animal related	Transformer Fuse	Replace - Same Size	Patrol/Test/Inspect	II
132266018	P98190	08/14/2013	15:56	08/14/2013	18:06	12	1560	130	Underground equipment	Underground Primary			III
132266073	J08205	08/14/2013	16:29	08/14/2013	17:55	1	86	86	Overhead equipment	Transformer Fuse	Replace - Same Size	Replace - Same Size	I
132266215	P83710	08/14/2013	17:24	08/14/2013	19:50	1	146	146	Overhead equipment	Transformer Fuse	Repair		I
132266375	R29904	08/14/2013	18:18	08/14/2013	21:25	1	187	187	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Repair	VI
132266956	R20502	08/14/2013	18:51	08/14/2013	19:22	1	31	31	Animal related	Transformer Fuse	Replace - Same Size	No Work Required	IV
132266972	D33143	08/14/2013	19:28	08/14/2013	20:40	6	432	72	Overhead equipment	Overhead Secondary	Tie/Tighten		I
132267010	Q80352	08/14/2013	20:36	08/14/2013	21:16	2	80	40	Animal related	Transformer Fuse	Replace - Same Size		V
132267193	A85001	08/14/2013	20:41	08/15/2013	5:50	3	1647	549	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
132267162	U86001	08/14/2013	21:55	08/14/2013	22:54	1	59	59	Overhead equipment	Transformer Fuse	Repair	Repair	II
132267173	B00002	08/14/2013	21:58	08/14/2013	22:01	1	3	3	Overhead equipment	Overhead Service	Repair		I
132267200	R34921	08/14/2013	23:35	08/15/2013	2:05	1	150	150	Overhead equipment	Connector	Replace - New Size		VI
132267202	L17102	08/14/2013	23:47	08/15/2013	0:18	3	93	31	Animal related	Transformer Fuse	Replace - Same Size		III
132270120	J88164	08/15/2013	1:08	08/15/2013	3:24	9	1224	136	Tree related-tree broken	Tree		Replace - Same Size	VI
132273933	B80004	08/15/2013	3:22	08/15/2013	5:56	2	308	154	Underground equipment	Underground Primary	Patrol/Test/Inspect		I
132273805	B80004	08/15/2013	3:33	08/15/2013	11:07	1	454	454	Underground equipment	Underground Primary		Repair	I
132273836	R99180	08/15/2013	6:17	08/15/2013	7:35	1	78	78	Animal related	Fuse	Patrol/Test/Inspect	Replace - Same Size	IV
132273891	D70005	08/15/2013	7:14	08/15/2013	8:45	1	91	91	Animal related	Fuse			I
132273897	M81403	08/15/2013	7:15	08/15/2013	10:04	18	3042	169	Underground equipment	Underground Primary	Replace - Same Size	Patrol/Test/Inspect	V
132274130	Y37593	08/15/2013	8:22	08/15/2013	9:25	36	2268	63	Animal related	Fuse	Replace - Same Size		IV
132274108	D53002	08/15/2013	8:23	08/15/2013	10:42	1	139	139	Underground equipment	Underground Primary	Switch/Reset	Repair	I
132274212	P07179	08/15/2013	8:29	08/15/2013	11:10	98	15778	161	Overhead equipment	Recloser	Switch/Reset		I
132274193	Q32171	08/15/2013	8:40	08/15/2013	12:15	1	215	215	Unknown	Fuse	Patrol/Test/Inspect	Replace - Same Size	I
132274200	K79223	08/15/2013	8:42	08/15/2013	9:06	1	24	24	Animal related	Transformer Fuse	Replace - Same Size		IV
132274441	D28124	08/15/2013	8:47	08/15/2013	10:12	56	4760	85	Public	Pole	Patrol/Test/Inspect	Replace - Same Size	I

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
132274630	D28124	08/15/2013	9:04	08/15/2013	14:45	24	8184	341	Public	Pole	Patrol/Test/Inspect	Replace - Same Size	I
132274348	P07179	08/15/2013	9:09	08/15/2013	11:10	1	121	121	Overhead equipment	Recloser	Switch/Reset		I
132274430	P07179	08/15/2013	9:25	08/15/2013	11:10	1	105	105	Overhead equipment	Recloser	Switch/Reset		I
132274521	L11244	08/15/2013	9:42	08/15/2013	13:30	1	228	228	Overhead equipment	Overhead Service	Repair		III
132275245	B58001	08/15/2013	10:33	08/15/2013	15:50	5	1585	317	Underground equipment	Underground Primary	Repair	Repair	I
132274936	V50001	08/15/2013	11:02	08/15/2013	11:33	5	155	31	Unknown	Transformer Fuse	Replace - Same Size	Replace - Same Size	II
132275033	D53001	08/15/2013	11:18	08/15/2013	12:59	1	101	101	Animal related	Transformer Fuse	Replace - Same Size		I
132275219	343004	08/15/2013	12:00	08/15/2013	12:53	1	53	53	Jurisdictional	Other	Patrol/Test/Inspect		VI
132275259	335002	08/15/2013	12:11	08/15/2013	13:15	1	64	64	Jurisdictional	Overhead Service	Reconnect		VI
132275268	N44217	08/15/2013	12:14	08/15/2013	13:01	1	47	47	Overhead equipment	Overhead Service		Repair	III
132275462	J14140	08/15/2013	12:53	08/15/2013	13:19	1	26	26	Overhead equipment	Fuse	Replace - Same Size		VI
132275467	Y68581	08/15/2013	12:54	08/15/2013	14:02	1	68	68	Animal related	Animal Guard		Install	IV
132275551	V23530	08/15/2013	13:17	08/15/2013	14:50	1	93	93	Tree related-tree broken	Overhead Service	Repair		II
132275612	Q15844	08/15/2013	13:17	08/15/2013	13:25	1570	12560	8	Animal related	Recloser	Switch/Reset		V
132275916	U90566	08/15/2013	14:30	08/15/2013	17:45	2	390	195	Underground equipment	Underground Primary	Repair	Repair	II
132276004	F03003	08/15/2013	14:41	08/15/2013	19:57	1	316	316	Underground equipment	Underground Primary			III
132276147	X60597	08/15/2013	14:46	08/15/2013	17:10	1	144	144	Underground equipment	Underground Secondary	Repair	Repair	IV
132276275	L59933	08/15/2013	14:50	08/15/2013	16:49	22	2618	119	Overhead equipment	Fuse	Replace - Same Size		VI
132276880	D01002	08/15/2013	15:30	08/15/2013	16:29	1	59	59	Overhead equipment	Transformer Fuse	Replace - Same Size		I
132277030	N44215	08/15/2013	16:19	08/15/2013	18:30	1	131	131	Unknown	Fuse	Replace - Same Size		III
132277051	K58213	08/15/2013	16:23	08/15/2013	17:28	1	65	65	Overhead equipment	Fuse	Replace - Same Size		VI
132277065	R48167	08/15/2013	16:27	08/15/2013	18:19	1	112	112	Tree related-tree broken	Overhead Service	Repair		IV
132277197	B28006	08/15/2013	17:12	08/15/2013	20:33	88	17688	201	Underground equipment	Underground Connector	Patrol/Test/Inspect	Repair	I
132277265	P85142	08/15/2013	17:45	08/15/2013	17:58	1	13	13	Unknown				III
132277663	D28124	08/15/2013	19:18	08/16/2013	3:50	1	512	512	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
132278149	S93504	08/15/2013	20:41	08/15/2013	22:09	1	88	88	Overhead equipment	Connector	Repair		VI
132278161	H10843	08/15/2013	20:55	08/15/2013	22:33	1	98	98	Tree related-tree contact	Fuse	Replace - Same Size	Replace - Same Size	V
132278214	R93351	08/15/2013	21:22	08/15/2013	22:00	1	38	38	Animal related	Transformer Fuse	Replace - Same Size		V
132278234	V99562	08/15/2013	22:27	08/15/2013	23:40	1	73	73	Overhead equipment	Transformer Fuse	Replace - Same Size	Patrol/Test/Inspect	II
132278241	A91004	08/15/2013	23:05	08/16/2013	1:05	1	120	120	Overhead equipment	Fuse			I
132284945	W01528	08/16/2013	6:02	08/16/2013	11:56	3	1062	354	Underground equipment	Underground Primary	Repair	Repair	II
132284893	R07382	08/16/2013	6:10	08/16/2013	7:27	4	308	77	Animal related	Fuse	Replace - Same Size	Replace - Same Size	I
132284939	D70005	08/16/2013	6:56	08/16/2013	8:11	1	75	75	Animal related	Fuse			I
132285177	Z06538	08/16/2013	8:12	08/16/2013	9:42	1	90	90	Animal related	Animal Guard	Install		IV
132285227	N18210	08/16/2013	8:27	08/16/2013	9:10	1	43	43	Animal related	Transformer Fuse	Replace - Same Size		III
132285245	Q28141	08/16/2013	8:31	08/16/2013	10:09	10	980	98	Animal related	Transformer Fuse	Replace - Same Size		VI
132285299	Q21293	08/16/2013	8:41	08/16/2013	9:45	1	64	64	Animal related	Fuse	Replace - Same Size	Replace - Same Size	VI
132285320	N35852	08/16/2013	8:47	08/16/2013	9:39	1	52	52	Animal related	Transformer Fuse	Replace - Same Size		V
132285519		08/16/2013	9:16	08/16/2013	23:30	1288	1099952	854	Substation equipment				VI
132285892	S60581	08/16/2013	10:31	08/16/2013	11:35	46	2944	64	Animal related	Transformer Fuse	Replace - Same Size		VI
132285941	Z10501	08/16/2013	10:48	08/16/2013	11:55	1	67	67	Animal related	Fuse	Repair		IV
132285966	U41545	08/16/2013	10:54	08/16/2013	11:50	1	56	56	Animal related	Transformer Fuse	Repair	Repair	II
132286002	A49002	08/16/2013	10:56	08/16/2013	12:15	80	6320	79	Unknown	Fuse	Replace - Same Size	No Work Required	I
132286043	Q23258	08/16/2013	11:10	08/16/2013	13:57	44	7348	167	Overhead equipment	Overhead Primary		Repair	VI
132286066	V23530	08/16/2013	11:17	08/16/2013	12:00	1	43	43	Public	Fuse	Replace - Same Size		II
132286075	X69554	08/16/2013	11:19	08/16/2013	12:50	1	91	91	Unknown	Fuse	Repair		IV
132286262	Q91141	08/16/2013	12:13	08/16/2013	12:58	11	495	45	Animal related	Transformer Fuse	Replace - Same Size		I
132286594	D69006	08/16/2013	13:44	08/16/2013	15:12	1	88	88	Public	Overhead Service	Tie/Tighten	Repair	I
132286783	B84005	08/16/2013	14:27	08/16/2013	15:41	1	74	74	Overhead equipment	Fuse	Repair	Replace - Same Size	I
132286989	D55003	08/16/2013	15:05	08/16/2013	16:22	1	77	77	Overhead equipment	Overhead Service	Repair		I
132287173	Q32170	08/16/2013	16:01	08/16/2013	17:30	1	89	89	Animal related	Transformer Fuse	Replace - Same Size		I
132287239	X69554	08/16/2013	16:26	08/16/2013	19:20	2	348	174	Overhead equipment	Overhead Transformer		Replace - Same Size	IV
132287265	M25144	08/16/2013	16:38	08/16/2013	17:32	9	486	54	Unknown	Fuse	Replace - Same Size		IV
132287379	V10551	08/16/2013	16:43	08/16/2013	18:33	3	330	110	Unknown	Fuse	Patrol/Test/Inspect	Replace - Same Size	II
132287276	Z43549	08/16/2013	16:47	08/16/2013	18:21	1	94	94	Tree related-tree contact	Tree	Trim		IV
132287429	Q47833	08/16/2013	18:15	08/16/2013	19:45	163	14670	90	Overhead equipment	Recloser	Switch/Reset		V

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
132287547	Y35515	08/16/2013	18:49	08/16/2013	20:15	58	4988	86	Unknown	Fuse	Repair		IV
132288023	Y05001	08/16/2013	19:36	08/16/2013	21:09	3	279	93	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
132288175	R58961	08/16/2013	21:28	08/16/2013	22:39	1	71	71	Tree related-tree broken	Overhead Service	Cut in Clear	Reconnect	IV
132288182	X64002	08/16/2013	21:41	08/16/2013	23:28	6	642	107	Overhead equipment	Animal Guard	Install		IV
132290015	P57102	08/16/2013	22:43	08/17/2013	0:40	70	8190	117	Overhead equipment	Fuse	Replace - Same Size		VI
132290029	S09520	08/17/2013	1:38	08/17/2013	3:15	23	2231	97	Overhead equipment	Sectionalizer			VI
132290058	B62004	08/17/2013	4:31	08/17/2013	5:47	4	304	76	Overhead equipment	Fuse	Patrol/Test/Inspect	Replace - Same Size	I
132290065	Y54560	08/17/2013	5:47	08/17/2013	6:39	1	52	52	Animal related	Fuse	Replace - Same Size		IV
132290087	N54214	08/17/2013	6:56	08/17/2013	8:13	19	1463	77	Animal related	Fuse	Replace - Same Size		II
132290088	Y98561	08/17/2013	6:56	08/17/2013	13:58	10	4220	422	Underground equipment	Overhead Primary	Patrol/Test/Inspect	Repair	IV
132290106	B81003	08/17/2013	7:38	08/17/2013	8:14	1	36	36	Overhead equipment	Fuse	Replace - Same Size		I
132290113	D88002	08/17/2013	7:42	08/17/2013	8:30	39	1872	48	Animal related	Fuse	Replace - Same Size	No Work Required	I
132290115	R04407	08/17/2013	7:47	08/17/2013	9:21	1	94	94	Animal related	Fuse	Patrol/Test/Inspect	Replace - Same Size	V
132290319	K80381	08/17/2013	9:04	08/17/2013	10:36	19	1748	92	Underground equipment	Underground Primary	Switch/Reset		IV
132290186	K80381	08/17/2013	9:07	08/17/2013	11:53	44	7304	166	Underground equipment	Underground Primary	Switch/Reset		IV
132290189	L62928	08/17/2013	9:11	08/17/2013	11:00	5	545	109	Overhead equipment	Disconnect Switch	Replace - Same Size	Repair	VI
132290325	T42525	08/17/2013	10:40	08/17/2013	11:03	1	23	23	Animal related	Fuse	Replace - Same Size		IV
132290359	R73838	08/17/2013	11:26	08/17/2013	14:23	1	177	177	Tree related-tree contact	Overhead Service	Replace - New Size	Replace - New Size	V
132290640	R65451	08/17/2013	12:00	08/17/2013	16:35	6	1650	275	Overhead equipment	Overhead Transformer	Replace - Same Size		IV
132290527	R65451	08/17/2013	12:00	08/17/2013	16:02	121	29282	242	Overhead equipment	Overhead Primary	Repair		IV
132290507	R65451	08/17/2013	12:00	08/17/2013	13:13	234	17082	73	Overhead equipment	Overhead Primary	Switch/Reset		IV
132290490	R65451	08/17/2013	12:00	08/17/2013	13:32	842	77464	92	Overhead equipment	Overhead Primary	Switch/Reset		IV
132290417	B82001	08/17/2013	12:05	08/17/2013	12:40	1	35	35	Overhead equipment	Transformer Fuse	Replace - Same Size		I
132290423	J14140	08/17/2013	12:08	08/17/2013	13:30	1	82	82	Animal related	Transformer Fuse	Repair	Replace - Same Size	VI
132290450	M26161	08/17/2013	12:33	08/17/2013	16:52	1	259	259	Underground equipment	Underground Service	Repair		III
132290451	S41564	08/17/2013	12:34	08/17/2013	14:00	1	86	86	Tree related-tree contact	Overhead Service	Replace - Same Size	No Work Required	VI
132290534	Q01282	08/17/2013	13:42	08/17/2013	14:21	50	1950	39	Animal related	Fuse			III
132290541	U13551	08/17/2013	13:52	08/17/2013	15:00	1	68	68	Overhead equipment	Fuse	Replace - Same Size	Patrol/Test/Inspect	II
132290558	Z11536	08/17/2013	14:01	08/17/2013	15:30	13	1157	89	Animal related	Fuse	Repair	Replace - Same Size	IV
132290626	Y82587	08/17/2013	15:29	08/18/2013	0:01	11	5632	512	Underground equipment	Underground Transformer	Replace - Same Size		IV
132290639	Z04001	08/17/2013	16:00	08/17/2013	17:16	12	912	76	Overhead equipment				IV
132290684	X69554	08/17/2013	17:50	08/17/2013	19:11	1	81	81	Overhead equipment	Meter			IV
132290687	D92002	08/17/2013	18:01	08/17/2013	18:59	14	812	58	Animal related	Transformer Fuse	Replace - Same Size		I
132290695	S66578	08/17/2013	18:20	08/17/2013	19:56	1	96	96	Overhead equipment	Connector			VI
132290747	A81003	08/17/2013	21:41	08/18/2013	1:55	26	6604	254	Underground equipment	Underground Primary	Repair	Repair	I
132290776	B10001	08/17/2013	23:31	08/18/2013	5:10	67	22713	339	Tree related-tree broken	Overhead Primary	Patrol/Test/Inspect	Repair	I
132300013	A27011	08/18/2013	1:25	08/18/2013	4:28	136	24888	183	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
132300023	Y45503	08/18/2013	3:27	08/18/2013	6:24	1	177	177	Overhead equipment	Overhead Transformer	Repair	Replace - New Size	IV
132300043	K69117	08/18/2013	4:51	08/18/2013	7:25	46	7084	154	Underground equipment	Underground Primary	Switch/Reset	Repair	IV
132300053	B10001	08/18/2013	6:48	08/18/2013	7:12	1	24	24	Tree related-tree broken	Jumper	Patrol/Test/Inspect	Repair	I
132300062	Z11506	08/18/2013	7:28	08/18/2013	8:45	1	77	77	Animal related	Transformer Fuse	Replace - Same Size		IV
132300067	Y37593	08/18/2013	7:33	08/18/2013	8:20	36	1692	47	Overhead equipment	Fuse			IV
132300075	V50001	08/18/2013	8:13	08/18/2013	9:00	5	235	47	Overhead equipment	Overhead Transformer	Replace - Same Size	Replace - Same Size	II
132300083	V20502	08/18/2013	8:43	08/18/2013	15:01	1	378	378	Underground equipment	Underground Primary			II
132300087	U11531	08/18/2013	8:45	08/18/2013	9:16	4	124	31	Overhead equipment	Disconnect Switch	Repair	Repair	II
132300101	L23148	08/18/2013	9:12	08/18/2013	10:37	1	85	85	Tree related-tree contact	Overhead Service	Repair		III
132300104	K46422	08/18/2013	9:26	08/18/2013	10:03	1	37	37	Animal related	Transformer Fuse	Replace - Same Size	Replace - Same Size	V
132300111	R84148	08/18/2013	9:37	08/18/2013	10:43	1	66	66	Animal related	Transformer Fuse	Replace - Same Size		I
132300115	T28561	08/18/2013	9:53	08/18/2013	11:13	3	240	80	Overhead equipment	Overhead Transformer	Switch/Reset	Advise Customer	VI
132300118	S43512	08/18/2013	9:58	08/18/2013	11:39	2	202	101	Tree related-tree broken	Overhead Service	Replace - Same Size	No Work Required	VI
132300120	Q34360	08/18/2013	10:04	08/18/2013	11:02	1	58	58	Other	Other	Replace - Same Size	Repair	I
132300131	X57566	08/18/2013	10:36	08/18/2013	11:20	1	44	44	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
132300156	U31003	08/18/2013	11:44	08/18/2013	12:52	1	68	68	Overhead equipment	Overhead Service	Repair	Repair	II
132300161	Y50002	08/18/2013	11:59	08/18/2013	14:26	1	147	147	Tree related-tree contact	Overhead Service	Repair		IV
132300186	Q82907	08/18/2013	12:35	08/18/2013	14:40	1	125	125	Animal related	Fuse	Replace - Same Size		VI
132300189	A81003	08/18/2013	12:50	08/18/2013	13:21	26	806	31	Underground equipment				I