Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
132300252	J58380	08/18/2013	13:14	08/18/2013	13:40	1	26	26	Animal related	Transformer Fuse		Replace - Same Size	III
132300254	S09520	08/18/2013	13:18	08/18/2013	14:10	1	52	52	Overhead equipment	Transformer Fuse			VI
132300283	S01511	08/18/2013	14:39	08/18/2013	16:10	1	91	91	Overhead equipment	Transformer Fuse			VI
132300344	J05139	08/18/2013	16:13	08/18/2013	17:50	1	97	97	Overhead equipment	Jumper	Replace - Same Size		I
132300349	B76003	08/18/2013	16:21	08/18/2013	18:09	15	1620	108	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
132300346	J05139	08/18/2013	16:22	08/18/2013	17:50	1	88	88	Overhead equipment	Jumper	Replace - Same Size		I
132300378	V36002	08/18/2013	17:03	08/18/2013	23:21	7	2646	378	Underground equipment	Underground Primary			II
132300366	J05139	08/18/2013	17:11	08/18/2013	17:50	1	39	39	Overhead equipment	Jumper	Replace - Same Size		I
132300371		08/18/2013	17:25	08/19/2013	2:50	1	565	565	Public	Crossarm	Patrol/Test/Inspect	Repair	I
132300390	L46810	08/18/2013	18:11	08/18/2013	18:55	1	44	44	Animal related	Transformer Fuse	Replace - Same Size	No Work Required	V
132300467	S56736	08/18/2013	18:21	08/19/2013	5:45	2	1368	684	Overhead equipment	Crossarm			VI
132300514	S56736	08/18/2013	18:21	08/18/2013	19:55	1123	105562	94	Overhead equipment				VI
132300493	S56736	08/18/2013	18:21	08/18/2013	19:03	400	16800	42	Overhead equipment				VI
132300479	S56736	08/18/2013	18:21	08/18/2013	18:48	242	6534	27	Jurisdictional				VI
132300437	R16511	08/18/2013	18:26	08/18/2013	19:32	1	66	66	Animal related	Transformer Fuse	Replace - Same Size	No Work Required	I
132300478	K62102	08/18/2013	18:48	08/18/2013	21:26	9	1422	158	Overhead equipment	Overhead Transformer	Replace - Same Size		II
132300509	D01002	08/18/2013	20:03	08/18/2013	22:00	1	117	117	Overhead equipment	Fuse	Repair	Replace - Same Size	I
132300535	Y61004	08/18/2013	21:32	08/18/2013	22:29	10	570	57	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
132310099	Q21481	08/18/2013	21:58	08/19/2013	0:02	2818	349432	124	Overhead equipment				VI
132300662	Q18243	08/18/2013	22:05	08/19/2013	0:01	4	464	116	Overhead equipment	Overhead Primary	Switch/Reset		VI
132300708	K57212	08/18/2013	22:13	08/19/2013	0:02	1	109	109	Overhead equipment	Overhead Primary	Switch/Reset		VI
132300717		08/18/2013	22:34	08/19/2013	0:02	1	88	88	Overhead equipment	Overhead Primary	Switch/Reset		VI
132310116	V92542	08/18/2013	23:28	08/19/2013	2:35	4	748	187	Underground equipment	Underground Primary	Cut in Clear	Patrol/Test/Inspect	II
132313657	D16002	08/19/2013	4:30	08/19/2013	8:22	46	10672	232	Underground equipment	Underground Primary		Repair	I
132313680	D16004	08/19/2013	5:44	08/19/2013	8:22	1	158	158	Underground equipment	Underground Primary		Repair	I
132313704	D81002	08/19/2013	6:26	08/19/2013	9:35	1	189	189	Underground equipment	Animal Guard		Repair	I
132313712		08/19/2013	6:37	08/19/2013	7:44	1	67	67	Animal related	Transformer Fuse	Replace - Same Size		IV
132313730	P49187	08/19/2013	6:53	08/19/2013	7:48	7	385	55	Overhead equipment	Fuse		Replace - Same Size	I
132313774	P58156	08/19/2013	7:15	08/19/2013	9:43	1	148	148	Unknown				VI
132313845	P58159	08/19/2013	7:16	08/19/2013	8:46	326	29340	90	Overhead equipment				VI
132313785	N44216	08/19/2013	7:17	08/19/2013	8:20	1	63	63	Underground equipment	Underground Primary		Replace - Same Size	III
132313790	B68004	08/19/2013	7:19	08/19/2013	8:05	1	46	46	Overhead equipment	Fuse	Replace - Same Size	Repair	III
132313817	Y31589	08/19/2013	7:23	08/19/2013	8:00	1	37	37	Tree related-tree broken	Fuse			IV
132313882	L50214	08/19/2013	7:29	08/19/2013	9:50	19	2679	141	Animal related	Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
132313876	P58155	08/19/2013	7:36	08/19/2013	9:07	1	91	91	Underground equipment	Underground Transformer	Patrol/Test/Inspect	No Work Required	VI
132313829	K91115	08/19/2013	7:42	08/19/2013	10:17	1	155	155	Overhead equipment	Overhead Primary	Repair		III
132313901	T28561	08/19/2013	7:43	08/19/2013	9:15	3	276	92	Animal related	Transformer Fuse			VI
132314334	P12290	08/19/2013	8:34	08/19/2013	9:15	342	14022	41	Overhead equipment	Overhead Primary	Switch/Reset		V
132314305	P58159	08/19/2013	8:47	08/19/2013	9:46	290	17110	59	Overhead equipment	Recloser		Replace - Same Size	VI
132314378	R33126	08/19/2013	9:14	08/19/2013	10:57	1	103	103	Unknown	Fuse	Repair	Replace - Same Size	I
132314385	M81403	08/19/2013	9:15	08/19/2013	11:44	12	1788	149	Animal related	Underground Primary		Repair	V
132314402	J87120	08/19/2013	9:19	08/19/2013	10:05	1	46	46	Animal related	Transformer Fuse	Replace - Same Size		VI
132314456		08/19/2013	9:29	08/19/2013	10:04	1	35	35	Overhead equipment	Overhead Primary	Repair		V
132314498	P60170	08/19/2013	9:34	08/19/2013	10:12	10	380	38	Animal related	Fuse	Repair	Repair	VI
132314575	P58159	08/19/2013	9:53	08/19/2013	13:57	2	488	244	Overhead equipment				VI
132314626	Y50002	08/19/2013	10:02	08/19/2013	10:25	1	23	23	Public	Overhead Service	Repair		IV
132315190	P58159	08/19/2013	10:05	08/19/2013	13:43	242	52756	218	Underground equipment	Underground Primary	Repair	Repair	VI
132314712	D90002	08/19/2013	10:13	08/19/2013	10:30	1	17	17	Overhead equipment	Fuse	Replace - Same Size	Repair	III
132314805	P49187	08/19/2013	10:29	08/19/2013	11:36	1	67	67	Underground equipment	Underground Service	Repair	Repair	I
132314854	D90002	08/19/2013	10:36	08/19/2013	12:25	1	109	109	Overhead equipment	Overhead Transformer			III
132315074	M37192	08/19/2013	11:24	08/19/2013	12:38	1	74	74	Jurisdictional				I
132315102	R65452	08/19/2013	11:27	08/19/2013	12:21	18	972	54	Public	Underground Primary		Repair	IV
132315101	Q11516	08/19/2013	11:30	08/19/2013	12:56	1	86	86	Animal related	Fuse	Repair		I
132315162	U62510	08/19/2013	11:45	08/19/2013	12:52	2	134	67	Overhead equipment	Transformer Fuse	Replace - Urgent		II
132315213	K30204	08/19/2013	11:49	08/19/2013	12:40	57	2907	51	Unknown	Fuse	Replace - Same Size		III
132315235	N60181	08/19/2013	11:58	08/19/2013	12:47	1	49	49	Animal related	Overhead Transformer	Switch/Reset		I

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
132315262	T04514	08/19/2013	12:03	08/19/2013	12:45	1	42	42	Overhead equipment	Overhead Service			VI
132315517	J30201	08/19/2013	12:59	08/19/2013	14:18	1	79	79	Animal related	Transformer Fuse	Replace - Same Size		VI
132315657	C36002	08/19/2013	13:10	08/19/2013	14:30	14	1120	80	Overhead equipment	Fuse	Replace - Same Size		III
132315890	R53391	08/19/2013	14:10	08/19/2013	16:20	169	21970	130	Overhead equipment	Fuse	Patrol/Test/Inspect	Replace - Same Size	V
132316218	P19395	08/19/2013	14:24	08/20/2013	0:12	36	21168	588	Public	Pole	Patrol/Test/Inspect	Replace - Same Size	V
132316174	M45212	08/19/2013	15:05	08/19/2013	16:00	1	55	55	Unknown	Transformer Fuse	Replace - Same Size		IV
132316302	S47538	08/19/2013	15:30	08/19/2013	16:49	1	79	79	Tree related-tree contact	Tree	Trim		VI
132316458	D72002	08/19/2013	16:16	08/19/2013	16:44	1	28	28	Overhead equipment	Overhead Transformer	Replace - Same Size		I
132316517	P62138	08/19/2013	16:23	08/19/2013	19:20	293	51861	177	Overhead equipment	Overhead Primary		Repair	VI
132316474	V42586	08/19/2013	16:24	08/19/2013	17:20	1	56	56	Unknown	Transformer Fuse	Replace - Same Size		II
132316494	L82188	08/19/2013	16:27	08/20/2013	0:01	1	454	454	Underground equipment	Underground Secondary		Repair	IV
132316568	310124	08/19/2013	16:47	08/19/2013	17:11	1	24	24	Overhead equipment	Fuse	Repair		V
132316607	N67309	08/19/2013	17:01	08/19/2013	19:29	1	148	148	Overhead equipment	Transformer Fuse	Replace - Same Size	Replace - Same Size	I
132316669	V31001	08/19/2013	17:06	08/19/2013	18:10	1	64	64	Overhead equipment	Overhead Service	Tie/Tighten		II
132316814	L50217	08/19/2013	18:18	08/19/2013	18:54	67	2412	36	Animal related	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
132316963	C52001	08/19/2013	18:29	08/19/2013	19:09	1	40	40	Overhead equipment	Overhead Service			III
132317545	A81001	08/19/2013	19:10	08/20/2013	5:35	1	625	625	Underground equipment	Underground Secondary	Patrol/Test/Inspect	Repair	I
132317605	B57002	08/19/2013	20:30	08/20/2013	2:51	1	381	381	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
132317618	X69555	08/19/2013	20:39	08/19/2013	21:50	3	213	71	Public	Fuse	Replace - Same Size	Replace - Same Size	IV
132317691	R59417	08/19/2013	22:30	08/20/2013	0:10	1161	116100	100	Underground equipment	Substation Misc.	Switch/Reset		IV
132317737	P17108	08/19/2013	22:58	08/20/2013	1:33	1	155	155	Underground equipment	Underground Service		Repair	IV
132322139	Y05001	08/20/2013	2:10	08/20/2013	4:00	1	110	110	Overhead equipment	Overhead Service	Repair		IV
132324308	Y39515	08/20/2013	5:50	08/20/2013	7:08	2	156	78	Animal related	Animal Guard	Install		IV
132324345	M37191	08/20/2013	6:44	08/20/2013	7:35	1	51	51	Overhead equipment	Overhead Service	Tie/Tighten		I
132324408	X78002	08/20/2013	7:16	08/20/2013	8:20	1	64	64	Overhead equipment	Jumper	Repair		IV
132324450	M47816	08/20/2013	7:25	08/20/2013	7:53	69	1932	28	Animal related	Fuse	Repair	Repair	V
132324627	B84004	08/20/2013	8:18	08/20/2013	8:20	1	2	2	Overhead equipment	Overhead Service	No Work Required	No Work Required	I
132324786	U90572	08/20/2013	9:00	08/20/2013	9:40	1	40	40	Overhead equipment	Transformer Fuse	Repair		II
132324821	S25551	08/20/2013	9:06	08/20/2013	9:33	1	27	27	Animal related	Transformer Fuse	Patrol/Test/Inspect	Repair	VI
132324934	Q27185	08/20/2013	9:14	08/20/2013	9:42	6	168	28	Animal related	Fuse	Replace - Same Size		VI
132325391	Y97513	08/20/2013	9:27	08/20/2013	14:54	4	1308	327	Underground equipment	Underground Primary		Repair	IV
132325152	P47120	08/20/2013	10:05	08/20/2013	11:05	1	60	60	Animal related	Transformer Fuse	Replace - Same Size		I
132325375	N60181	08/20/2013	10:43	08/20/2013	12:05	1	82	82	Overhead equipment	Fuse	Replace - Same Size		I
132325473	Q54908	08/20/2013	11:03	08/20/2013	12:18	1	75	75	Overhead equipment	Disconnect Switch	Replace - Same Size		VI
132325574	M26164	08/20/2013	11:20	08/20/2013	15:25	14	3430	245	Public	Pole	Patrol/Test/Inspect	Replace - Same Size	III
132325798	S31527	08/20/2013	12:00	08/20/2013	13:00	19	1140	60	Animal related	Fuse	Replace - Same Size		VI
132325864	T06505	08/20/2013	12:23	08/20/2013	17:24	1	301	301	Underground equipment	Underground Service	Repair	Repair	VI
132325970	V40549	08/20/2013	12:33	08/20/2013	14:36	211	25953	123	Public	Overhead Primary		Repair	II
132326436	X02547	08/20/2013	14:23	08/20/2013	15:17	1	54	54	Animal related	Transformer Fuse	Replace - Same Size		IV
132326645		08/20/2013	15:04	08/20/2013	16:45	1	101	101	Animal related	Fuse			VI
132326695	L12127	08/20/2013	15:07	08/20/2013	21:11	32	11648	364	Underground equipment	Underground Primary		Repair	III
132326710	Z06537	08/20/2013	15:15	08/20/2013	16:21	9	594	66	Overhead equipment	Animal Guard	Install		IV
132326805	B93001	08/20/2013	15:39	08/20/2013	20:25	1	286	286	Overhead equipment	Disconnect Switch	Patrol/Test/Inspect		I
132326801	S50541	08/20/2013	15:39	08/20/2013	16:49	1	70	70	Underground equipment	Underground Service	Reconnect		VI
132326842	M19222	08/20/2013	15:53	08/20/2013	16:38	1	45	45	Animal related	Transformer Fuse	Replace - Same Size		VI
132326858	N70331	08/20/2013	15:56	08/20/2013	16:15	1	19	19	Animal related	Transformer Fuse	Replace - Same Size	Replace - Same Size	I
132327779	D88001	08/20/2013	17:06	08/21/2013	2:33	4	2268	567	Public	Pole	Replace - Same Size		I
132327067	D88001	08/20/2013	17:06	08/20/2013	18:10	9	576	64	Public	Pole	Replace - Same Size	Repair	I
132327049	R73838	08/20/2013	17:08	08/20/2013	23:39	1	391	391	Tree related-tree broken	Overhead Service		Repair	V
132327078	R10903	08/20/2013	17:20	08/20/2013	21:09	1	229	229	Underground equipment	Underground Service	Repair	Repair	VI
132327092	B00005	08/20/2013	17:28	08/20/2013	17:48	10	200	20	Animal related	Fuse	Replace - Same Size		I
132327152	D70004	08/20/2013	17:58	08/20/2013	19:51	19	2147	113	Underground equipment	Underground Primary		Repair	I
132327164	X34531	08/20/2013	18:12	08/20/2013	19:51	2	198	99	Animal related	Transformer Fuse	Replace - Same Size		IV
132327173	D96002	08/20/2013	18:21	08/20/2013	19:22	1	61	61	Animal related	Fuse	Replace - Same Size		I
132327716	S25552	08/20/2013	18:48	08/20/2013	20:37	1	109	109	Overhead equipment	Overhead Service	Repair		VI
132327747	A56013	08/20/2013	19:20	08/20/2013	20:38	1	78	78	Overhead equipment	Connector	Replace - Same Size		I

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
132327929	C70004	08/20/2013	19:53	08/20/2013	22:00	209	26543	127	Underground equipment	Underground Primary	Unsafe Tag	Repair	III
132327788	V20502	08/20/2013	20:02	08/20/2013	23:30	23	4784	208	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	II
132327795	D36003	08/20/2013	20:13	08/20/2013	21:22	4	276	69	Overhead equipment	Jumper	Replace - Same Size		I
132327805		08/20/2013	20:26	08/20/2013	22:00	1	94	94	Underground equipment	Underground Secondary	Repair		III
132327909	J79304	08/20/2013	20:57	08/20/2013	23:24	408	59976	147	Overhead equipment	Overhead Primary			I
132327918	X62031	08/20/2013	21:26	08/20/2013	22:25	7	413	59	Overhead equipment	Disconnect Switch	Repair		IV
132330097	N74230	08/21/2013	0:17	08/21/2013	1:44	1	87	87	Other	Meter	Install	Install	I
132334622	K46388	08/21/2013	7:22	08/21/2013	8:19	7	399	57	Animal related	Fuse	Replace - Same Size	Replace - Same Size	V
132334679	K95201	08/21/2013	7:46	08/21/2013	9:00	1	74	74	Overhead equipment	Overhead Service	Tie/Tighten		III
132334716	D92002	08/21/2013	7:55	08/21/2013	10:23	1	148	148	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	I
132335856	S86582	08/21/2013	8:13	08/21/2013	11:30	93	18321	197	Underground equipment	Underground Primary	Repair	Repair	VI
132334803	D31016	08/21/2013	8:24	08/21/2013	9:35	1	71	71	Tree related-tree contact	Tree	Trim	Repair	III
132334970	N03299	08/21/2013	9:06	08/21/2013	12:09	10	1830	183	Tree related-tree broken	Tree	Trim	Trim	V
132335066	U73583	08/21/2013	9:25	08/21/2013	10:17	3	156	52	Animal related	Transformer Fuse	Replace - Same Size		II
132335119	J18267	08/21/2013	9:35	08/21/2013	10:44	1	69	69	Animal related	Fuse	Replace - Same Size	Patrol/Test/Inspect	VI
132335373	N58144	08/21/2013	10:18	08/21/2013	12:30	1	132	132	Unknown	Fuse	Replace - Same Size		I
132335378	B38002	08/21/2013	10:20	08/21/2013	10:40	1	20	20	Unknown	Fuse	Repair		I
132335542	S04513	08/21/2013	10:48	08/21/2013	12:10	56	4592	82	Tree related-tree contact	Disconnect Switch	Repair		VI
132335619	S04512	08/21/2013	10:58	08/21/2013	12:10	1	72	72	Tree related-tree contact	Disconnect Switch	Repair		VI
132336043	R59412	08/21/2013	12:25	08/21/2013	13:23	1	58	58	Overhead equipment	Overhead Service	Repair	No Work Required	IV
132336188	314167	08/21/2013	13:01	08/21/2013	14:04	5	315	63	Overhead equipment	Fuse	Replace - New Size		V
132336343	P42229	08/21/2013	13:27	08/21/2013	13:48	165	3465	21	Overhead equipment	Recloser			VI
132336683	V22555	08/21/2013	14:44	08/21/2013	16:34	1	110	110	Public	Overhead Service	Repair		II
132336786	Y51506	08/21/2013	15:11	08/21/2013	15:40	1	29	29	Animal related	Transformer Fuse	Repair		IV
132336835	Q74149	08/21/2013	15:21	08/21/2013	18:00	2	318	159	Tree related-tree contact	Overhead Secondary	Repair		IV
132336850	Q01282	08/21/2013	15:25	08/21/2013	16:48	1	83	83	Overhead equipment	Overhead Transformer			III
132336919	X73001	08/21/2013	15:42	08/21/2013	17:15	1	93	93	Overhead equipment	Overhead Service	Repair		IV
132336961	341003	08/21/2013	15:57	08/21/2013	16:31	1	34	34	Jurisdictional	Overhead Service	Reconnect		VI
132337037	V22555	08/21/2013	16:26	08/21/2013	17:45	1	79	79	Overhead equipment	Overhead Service	Repair		II
132337150	R06212	08/21/2013	16:56	08/21/2013	19:20	10	1440	144	Underground equipment	Underground Primary	Switch/Reset	Repair	II
132337220	L93133	08/21/2013	17:49	08/21/2013	19:28	1	99	99	Tree related-tree contact	Overhead Service	Repair		VI
132337245	N50331	08/21/2013	17:57	08/21/2013	19:19	29	2378	82	Overhead equipment	Jumper	Repair		II
132337256	K46389	08/21/2013	18:13	08/21/2013	19:15	1	62	62	Overhead equipment	Overhead Service	Repair		V
132337690	B65003	08/21/2013	19:08	08/21/2013	19:53	7	315	45	Animal related	Transformer Fuse	Replace - Same Size		I
132337711	B84005	08/21/2013	19:14	08/22/2013	4:34	37	20720	560	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
132337724	K80386	08/21/2013	19:30	08/21/2013	23:11	42	9282	221	Underground equipment	Underground Primary	Switch/Reset	Repair	IV
132337778	K62102	08/21/2013	20:51	08/21/2013	21:46	1	55	55	Overhead equipment	Fuse	Replace - Same Size	No Work Required	II
132337855	M22812	08/21/2013	21:28	08/21/2013	23:19	1	111	111	Overhead equipment	Connector	Tie/Tighten		V
132337857	D70006	08/21/2013	21:36	08/21/2013	23:54	1	138	138	Underground equipment	Underground Service	Repair		I
132340112	D01002	08/22/2013	1:55	08/22/2013	5:38	1	223	223	Weather	Disconnect Switch		Repair	I
132340319	B00002	08/22/2013	2:28	08/22/2013	4:49	126	17766	141	Weather				I
132344446	C76002	08/22/2013	2:58	08/22/2013	6:33	136	29240	215	Weather	Fuse	Replace - Same Size	Repair	I
132340354	Y35513	08/22/2013	3:04	08/22/2013	6:35	1	211	211	Underground equipment	Underground Primary		Repair	IV
132344376	D89002	08/22/2013	3:25	08/22/2013	8:15	1	290	290	Weather	Overhead Transformer	Replace - Same Size	No Work Required	I
132344457	P25150	08/22/2013	6:41	08/22/2013	7:44	17	1071	63	Overhead equipment	Overhead Primary	Repair		III
132344578	R94269	08/22/2013	7:17	08/22/2013	10:05	10	1680	168	Overhead equipment	Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
132344623	N94180	08/22/2013	7:34	08/22/2013	8:09	8	280	35	Animal related	Fuse	Replace - Same Size		I
132344600	D90002	08/22/2013	7:46	08/22/2013	11:55	1	249	249	Underground equipment	Underground Primary			III
132344608	M81403	08/22/2013	7:46	08/22/2013	9:42	19	2204	116	Underground equipment	Underground Transformer	Replace - Same Size		V
132344660	A73002	08/22/2013	8:02	08/22/2013	15:17	1	435	435	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
132345148	D16001	08/22/2013	8:05	08/22/2013	10:00	140	16100	115	Underground equipment	Underground Primary		Repair	I
132344828	Q11517	08/22/2013	8:40	08/22/2013	10:51	1	131	131	Weather	Transformer Fuse	Replace - Same Size	No Work Required	I
132345056	Q34363	08/22/2013	8:51	08/22/2013	10:51	1767	212040	120	Overhead equipment				I
132344875	M37192	08/22/2013	8:53	08/22/2013	10:11	10	780	78	Animal related	Overhead Transformer	Switch/Reset		I
132344937	P26284	08/22/2013	9:04	08/22/2013	16:36	1	452	452	Weather	Overhead Transformer	Replace - Same Size	Repair	I
132345006	Q34360	08/22/2013	9:09	08/22/2013	11:49	1	160	160	Transmission outage			No Work Required	I

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
132345055	K79213	08/22/2013	9:09	08/22/2013	13:15	14	3444	246	Tree related-tree broken	Overhead Primary			IV
132345091	Y45504	08/22/2013	9:23	08/22/2013	9:45	5	110	22	Animal related	Transformer Fuse	Repair	Replace - Same Size	IV
132345109	C70001	08/22/2013	9:26	08/22/2013	13:27	1	241	241	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Repair	III
132345138	K31120	08/22/2013	9:30	08/22/2013	11:25	2	230	115	Weather	Fuse	Replace - Same Size		I
132345197	X42502	08/22/2013	9:41	08/22/2013	12:12	1	151	151	Overhead equipment				IV
132345277	B21004	08/22/2013	9:55	08/22/2013	11:10	1	75	75	Overhead equipment	Fuse	Repair	Replace - Same Size	I
132345291	310123	08/22/2013	9:59	08/22/2013	10:30	1	31	31	Animal related	Fuse	Replace - Same Size	No Work Required	V
132345317	M37191	08/22/2013	10:02	08/22/2013	11:05	1	63	63	Overhead equipment				I
132345367	J76804	08/22/2013	10:15	08/22/2013	10:42	7	189	27	Animal related	Overhead Transformer	Repair	Repair	V
132345571	R68903	08/22/2013	10:31	08/22/2013	12:14	117	12051	103	Weather				I
132345514	M36184	08/22/2013	10:39	08/22/2013	11:25	5	230	46	Overhead equipment	Transformer Fuse	Replace - Same Size		I
132345611		08/22/2013	10:59	08/22/2013	12:29	1	90	90	Weather	Other	No Work Required		I
132345952	N78243	08/22/2013	11:44	08/22/2013	14:07	502	71786	143	Overhead equipment	Fuse			I
132345852	S19553	08/22/2013	12:20	08/22/2013	13:45	71	6035	85	Public	Underground Primary	Repair	Repair	VI
132346155	A91004	08/22/2013	12:50	08/22/2013	16:15	1	205	205	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	I
132346301	V50001	08/22/2013	13:18	08/22/2013	14:40	1	82	82	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	II
132346450	K31124	08/22/2013	13:43	08/22/2013	16:55	1	192	192	Overhead equipment	Overhead Transformer	Replace - Same Size	Replace - Same Size	I
132346503	S03531	08/22/2013	14:01	08/22/2013	15:12	18	1278	71	Tree related-tree contact	Overhead Primary			VI
132346620	J67131	08/22/2013	14:13	08/22/2013	15:45	1	92	92	Tree related-tree contact	Overhead Service			III
132346629	A73002	08/22/2013	14:14	08/22/2013	15:27	1	73	73	Tree related-tree broken	Fuse	Replace - Same Size		I
132346782	V74001	08/22/2013	14:31	08/22/2013	15:13	51	2142	42	Overhead equipment	Fuse	Replace - New Size		II
132346761	Y39521	08/22/2013	14:32	08/22/2013	15:25	2	106	53	Unknown	Fuse	Replace - Same Size		IV
132346814	P47124	08/22/2013	14:39	08/22/2013	15:48	1	69	69	Tree related-tree broken	Overhead Transformer	Switch/Reset		I
132346843	B80004	08/22/2013	14:43	08/22/2013	15:20	128	4736	37	Jurisdictional	Fuse	Replace - Same Size	No Work Required	I
132346949	B93003	08/22/2013	15:09	08/22/2013	16:21	1	72	72	Animal related	Transformer Fuse	Replace - Same Size		I
132347004	K89142	08/22/2013	15:17	08/22/2013	16:44	1	87	87	Tree related-tree contact	Overhead Service	Repair		III
132347048	K52400	08/22/2013	15:26	08/22/2013	16:26	1	60	60	Overhead equipment	Connector	Tie/Tighten		V
132347248	B80004	08/22/2013	15:31	08/22/2013	15:50	60	1140	19	Jurisdictional	Fuse	Replace - Same Size	No Work Required	I
132347083	B80004	08/22/2013	15:31	08/22/2013	15:50	109	2071	19	Jurisdictional	Fuse	Replace - Same Size	No Work Required	I
132347110	S47585	08/22/2013	15:41	08/22/2013	17:05	1	84	84	Overhead equipment	Fuse	Replace - New Size		VI
132347324	S95571	08/22/2013	16:03	08/22/2013	17:02	151	8909	59	Overhead equipment	Overhead Primary			VI
132347222	N05172	08/22/2013	16:11	08/22/2013	17:20	1	69	69	Weather	Disconnect Switch	Repair	Repair	I
132348319	R03413	08/22/2013	16:17	08/22/2013	18:07	2	220	110	Overhead equipment	Crossarm	Switch/Reset		III
132347856	K36151	08/22/2013	16:25	08/22/2013	20:40	204	52020	255	Overhead equipment	Crossarm	Repair	No Work Required	III
132347318	K36151	08/22/2013	16:25	08/22/2013	20:40	115	29325	255	Overhead equipment	Crossarm	Repair	No Work Required	III
132347320	Q47833	08/22/2013	16:29	08/22/2013	18:20	1	111	111	Animal related	Transformer Fuse	Replace - Same Size		V
132347345		08/22/2013	16:36	08/22/2013	18:07	1	91	91	Overhead equipment	Crossarm	Switch/Reset	No Work Required	III
132347376	S64501	08/22/2013	16:42	08/22/2013	17:45	36	2268	63	Underground equipment	Underground Transformer	Replace - New Size		VI
132347388	Q74148	08/22/2013	16:48	08/22/2013	19:22	3	471	154	Animal related	Lightning Arrestor	Replace - Same Size		IV
132347511	B25002	08/22/2013	16:55	08/22/2013	18:55	27	3240	120	Overhead equipment	Recloser	Replace - Same Size		I
132347412	K32916	08/22/2013	16:58	08/22/2013	18:40	1	102	102	Animal related	Fuse	Replace - Same Size	Patrol/Test/Inspect	VI
132347456	J47175	08/22/2013	17:30	08/22/2013	18:10	2	80	40	Public	Fuse			III
132347522	B65003	08/22/2013	17:47	08/22/2013	18:50	1	63	63	Jurisdictional	Overhead Service	Reconnect		I
132347524	M41112	08/22/2013	17:48	08/22/2013	18:30	1	42	42	Tree related-tree broken	Tree	Cut in Clear		I
132347531	J56341	08/22/2013	17:51	08/22/2013	18:13	22	484	22	Public	Fuse			III
132347795	X22001	08/22/2013	17:53	08/22/2013	18:55	6	372	62	Weather	Fuse	Replace - Same Size		IV
132347782	B62003	08/22/2013	18:22	08/22/2013	23:50	1	328	328	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
132348298	S36570	08/22/2013	18:44	08/22/2013	20:10	2	172	86	Animal related	Transformer Fuse	Replace - Same Size		VI
132348360	X22001	08/22/2013	19:39	08/22/2013	21:15	1	96	96	Overhead equipment	Disconnect Switch	Replace - New Size		IV
132348397	M54315	08/22/2013	20:28	08/22/2013	21:34	1	66	66	Tree related-tree broken	Connector	Repair		V
132348408	K36151	08/22/2013	20:52	08/22/2013	21:34	6	252	42	Overhead equipment	Recloser	Switch/Reset		III
132347304	K36151	08/22/2013	21:00	08/22/2013	21:16	7	112	16	Overhead equipment	Fuse	Replace - Same Size		III
132348892	K36151	08/22/2013	21:03	08/22/2013	21:50	1	47	47	Overhead equipment	Overhead Transformer	Switch/Reset		III
132348898	K36151	08/22/2013	21:05	08/22/2013	21:29	1	24	24	Overhead equipment	Recloser	Switch/Reset	No Work Required	III
132348918	P57102	08/22/2013	21:30	08/23/2013	1:22	2	464	232	Overhead equipment	Overhead Primary		Raise	VI
132348927	K36151	08/22/2013	21:50	08/22/2013	22:50	1	60	60	Overhead equipment	Fuse	Replace - Same Size		III

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
132348904	P26281	08/22/2013	21:56	08/23/2013	2:30	3	822	274	Tree related-tree broken	Overhead Primary	Repair	Repair	I
132348938	A45002	08/22/2013	22:03	08/23/2013	4:32	1	389	389	Underground equipment	Underground Primary		Repair	I
132350142	V19002	08/23/2013	1:53	08/23/2013	6:38	11	3135	285	Weather	Overhead Transformer		Replace - Same Size	II
132350144	V19002	08/23/2013	1:57	08/23/2013	5:53	12	2832	236	Weather	Overhead Transformer		Replace - Same Size	II
132351232	P62138	08/23/2013	3:12	08/23/2013	5:32	18	2520	140	Overhead equipment	Overhead Primary	Repair	Repair	VI
132354587	V19002	08/23/2013	3:29	08/23/2013	5:12	8	824	103	Weather	Overhead Transformer		Replace - New Size	II
132354600	R73447	08/23/2013	4:31	08/23/2013	6:22	1	111	111	Unknown	Recloser	Patrol/Test/Inspect		V
132354610	M22812	08/23/2013	5:45	08/23/2013	6:51	1	66	66	Weather	Transformer Fuse	Replace - Same Size		V
132354636	Q83148	08/23/2013	5:51	08/23/2013	8:45	37	6438	174	Underground equipment				VI
132354645	R50910	08/23/2013	6:35	08/23/2013	8:11	1	96	96	Weather	Transformer Fuse	Replace - Same Size	No Work Required	I
132354783	C70001	08/23/2013	7:41	08/23/2013	8:19	1	38	38	Animal related	Fuse	Replace - Same Size		III
132355085	V25504	08/23/2013	7:42	08/23/2013	9:38	3	348	116	Unknown	Fuse	Replace - Same Size		II
132354850	K58213	08/23/2013	7:56	08/23/2013	8:49	13	689	53	Animal related	Fuse	Replace - Same Size		VI
132354997	U09557	08/23/2013	8:37	08/23/2013	10:10	52	4836	93	Public	Underground Primary			II
132355108	A42005	08/23/2013	9:05	08/23/2013	11:36	1	151	151	Underground equipment	Underground Primary			I
132355133	A42005	08/23/2013	9:10	08/23/2013	11:37	1	147	147	Underground equipment	Underground Primary			I
132355226	A42005	08/23/2013	9:27	08/23/2013	10:20	1	53	53	Underground equipment	Underground Primary		Repair	I
132355243	J99141	08/23/2013	9:30	08/23/2013	11:33	1	123	123	Overhead equipment	Underground Primary		Repair	VI
132355336	Q71846	08/23/2013	9:50	08/23/2013	12:15	1	145	145	Tree related-tree broken	Overhead Service	Repair		V
132355374	K36151	08/23/2013	9:56	08/23/2013	11:45	1	109	109	Overhead equipment	Transformer Fuse	Repair		III
132355528	B28006	08/23/2013	10:30	08/23/2013	11:30	2	120	60	Animal related	Transformer Fuse	Replace - Same Size	No Work Required	I
132355551	V19002	08/23/2013	10:35	08/23/2013	11:42	9	603	67	Overhead equipment	Disconnect Switch	Replace - Same Size		II
132355798	N54213	08/23/2013	11:28	08/23/2013	13:22	1	114	114	Overhead equipment	Fuse	Replace - Same Size		II
132356025	K05253	08/23/2013	11:33	08/23/2013	17:10	5	1685	337	Public	Pole	Replace - Same Size		VI
132355991	K05253	08/23/2013	11:33	08/23/2013	12:17	364	16016	44	Public	Recloser	Replace - Same Size		VI
132356008	K57211	08/23/2013	12:14	08/23/2013	13:05	33	1683	51	Overhead equipment	Connector	Patrol/Test/Inspect	Repair	VI
132356069	S14511	08/23/2013	12:35	08/23/2013	13:55	1	80	80	Overhead equipment	Overhead Primary	Patrol/Test/Inspect	Repair	VI
132356151	B68004	08/23/2013	12:54	08/23/2013	13:45	1	51	51	Overhead equipment	Connector			III
132356192	K05253	08/23/2013	13:02	08/23/2013	13:26	1	24	24	Overhead equipment	Overhead Primary	Repair		VI
132356207	L12125	08/23/2013	13:04	08/23/2013	15:10	42	5292	126	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	III
132355842	K05253	08/23/2013	13:54	08/23/2013	17:10	5	980	196	Overhead equipment	Pole		Replace - Same Size	VI
132356624	M45212	08/23/2013	14:29	08/23/2013	16:13	15	1560	104	Overhead equipment	Guy Wire	Repair		IV
132356803	Z05549	08/23/2013	14:30	08/23/2013	15:59	477	42453	89	Public	Substation Breaker	Switch/Reset		IV
132356812	N15850	08/23/2013	15:02	08/23/2013	15:30	10	280	28	Tree related-tree broken	Tree	Remove	No Work Required	V
132356848	A26005	08/23/2013	15:23	08/23/2013	16:46	3	249	83	Public	Overhead Service	Repair	Repair	I
132356918	P54828	08/23/2013	15:42	08/23/2013	16:21	5	195	39	Animal related	Fuse	Replace - Same Size		V
132356941	M37191	08/23/2013	15:50	08/23/2013	18:16	5	730	146	Overhead equipment	Overhead Transformer	Switch/Reset		I
132357571	V14579	08/23/2013	16:05	08/23/2013	22:10	2	730	365	Underground equipment	Underground Primary	Repair	Repair	II
132357126	312114	08/23/2013	16:24	08/23/2013	18:00	64	6144	96	Overhead equipment	Disconnect Switch	Replace - Same Size		V
132357099	B80002	08/23/2013	16:46	08/23/2013	18:02	1	76	76	Overhead equipment	Overhead Service	Repair		I
132357624	S25552	08/23/2013	17:01	08/23/2013	18:55	1083	123462	114	Substation equipment	Substation Misc.	Patrol/Test/Inspect	Repair	VI
132357149	N05172	08/23/2013	17:03	08/24/2013	0:09	1	426	426	Overhead equipment	Overhead Transformer			I
132357216	U42512	08/23/2013	17:37	08/23/2013	18:37	1	60	60	Animal related	Transformer Fuse	Repair		II
132357228	H10843	08/23/2013	17:41	08/23/2013	19:42	1	121	121	Animal related	Fuse	Replace - Same Size		V
132357497	337003	08/23/2013	18:05	08/23/2013	18:57	1	52	52	Overhead equipment	Overhead Transformer	Repair		VI
132358128	L24122	08/23/2013	19:55	08/23/2013	20:38	1	43	43	Overhead equipment	Jumper	Repair		III
132358147	B58001	08/23/2013	20:17	08/23/2013	22:50	1	153	153	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Repair	I
132358150	L24122	08/23/2013	20:21	08/23/2013	20:38	2	34	17	Overhead equipment	Jumper	Repair		III
132360057	D16001	08/23/2013	21:38	08/24/2013	3:44	140	51240	366	Underground equipment	Underground Primary		Repair	I
132358558	X83533	08/23/2013	21:57	08/23/2013	22:54	4	228	57	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
132358578	V14579	08/23/2013	22:36	08/24/2013	0:45	15	1935	129	Overhead equipment	Overhead Primary	Repair	Repair	II
132358584	S62521	08/23/2013	22:47	08/23/2013	23:59	1	72	72	Tree related-tree broken	Overhead Service	Repair		VI
132360074	V21500	08/23/2013	23:05	08/24/2013	7:37	5	2560	512	Underground equipment	Underground Primary		Repair	II
132358598	V21500	08/23/2013	23:05	08/24/2013	3:10	9	2205	245	Underground equipment	Underground Primary	Repair	Repair	II
132358621	P98191	08/23/2013	23:42	08/24/2013	2:05	65	9295	143	Underground equipment	Underground Primary			III
132358624	D16002	08/23/2013	23:45	08/24/2013	0:09	45	1080	24	Underground equipment	Underground Primary		Repair	I

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
132360034	R60551	08/24/2013	1:02	08/24/2013	5:18	40	10240	256	Underground equipment	Underground Primary	Switch/Reset	Repair	IV
132360043	R66472	08/24/2013	2:06	08/24/2013	9:10	53	22472	424	Underground equipment	Underground Primary	Switch/Reset	Repair	IV
132360152	R66472	08/24/2013	2:09	08/24/2013	6:40	30	8130	271	Underground equipment				IV
132360058	A91001	08/24/2013	2:35	08/24/2013	7:15	105	29400	280	Underground equipment	Underground Primary		Repair	I
132360130	S30518	08/24/2013	3:13	08/24/2013	7:40	12	3204	267	Underground equipment	Underground Primary	Patrol/Test/Inspect	Switch/Reset	VI
132360137	335002	08/24/2013	3:27	08/24/2013	4:40	11	803	73	Overhead equipment	Fuse	Replace - Same Size		VI
132360145	R78301	08/24/2013	5:28	08/24/2013	7:47	1	139	139	Tree related-tree broken	Overhead Service	Repair		V
132360228	S55535	08/24/2013	7:51	08/24/2013	9:40	3	327	109	Animal related	Fuse	Replace - Same Size		VI
132360257	J20931	08/24/2013	8:46	08/24/2013	10:56	1	130	130	Overhead equipment	Transformer Fuse	Repair	No Work Required	VI
132360265	R48166	08/24/2013	8:52	08/24/2013	14:06	7	2198	314	Underground equipment	Underground Primary	Repair		IV
132360300	X96524	08/24/2013	9:14	08/24/2013	10:15	1	61	61	Tree related-tree broken	Tree			IV
132360335	D53002	08/24/2013	9:43	08/24/2013	10:40	1	57	57	Animal related	Fuse	Replace - Same Size		I
132360360	C70004	08/24/2013	9:55	08/24/2013	10:43	6	288	48	Animal related	Fuse	Replace - Same Size	No Work Required	III
132360367	U91584	08/24/2013	9:58	08/24/2013	11:11	1	73	73	Unknown	Fuse	Replace - Same Size		II
132360389	Q67938	08/24/2013	10:24	08/24/2013	11:29	1	65	65	Overhead equipment	Connector	Repair		VI
132360511	H01192	08/24/2013	10:31	08/24/2013	12:45	5	670	134	Underground equipment	Underground Primary	Switch/Reset	Repair	III
132360393	N15850	08/24/2013	10:31	08/24/2013	13:10	1	159	159	Animal related	Fuse	Replace - Same Size		V
132360515	R73447	08/24/2013	10:58	08/24/2013	12:28	958	86220	90	Substation equipment				V
132360435	K01240	08/24/2013	11:05	08/24/2013	14:01	1	176	176	Underground equipment	Underground Transformer		Replace - Same Size	VI
132360844	M18131	08/24/2013	12:33	08/24/2013	18:45	3	1116	372	Underground equipment	Underground Primary	Repair		III
132360680	M18131	08/24/2013	12:33	08/24/2013	13:26	1	53	53	Underground equipment	Underground Primary	Switch/Reset		III
132360608	M18131	08/24/2013	12:33	08/24/2013	15:17	6	984	164	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	III
132360631	B81002	08/24/2013	13:03	08/24/2013	13:40	69	2553	37	Overhead equipment	Fuse	Replace - Same Size		I
132360667	K67924	08/24/2013	13:43	08/24/2013	14:40	1	57	57	Animal related	Fuse	Replace - Same Size		VI
132360831	V49541	08/24/2013	14:32	08/24/2013	21:48	2	872	436	Underground equipment	Underground Primary		Patrol/Test/Inspect	II
132360838	K30205	08/24/2013	14:56	08/24/2013	18:11	20	3900	195	Underground equipment	Underground Primary		Repair	III
132360887	N94182	08/24/2013	15:58	08/24/2013	17:43	1	105	105	Overhead equipment	Fuse	Repair	Repair	I
132360889	J01119	08/24/2013	16:00	08/24/2013	16:52	1	52	52	Overhead equipment	Overhead Service	No Work Required		I
132360897	Y34597	08/24/2013	16:06	08/24/2013	17:15	3	207	69	Overhead equipment	Transformer Fuse			IV
132360934	F03003	08/24/2013	16:56	08/24/2013	21:14	1	258	258	Underground equipment	Underground Primary			III
132360967	C30002	08/24/2013	17:59	08/24/2013	20:10	1	131	131	Animal related	Fuse	Replace - Same Size		III
132361008	C40001	08/24/2013	19:03	08/24/2013	22:25	62	12524	202	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
132361017	D35003	08/24/2013	19:20	08/24/2013	21:10	1	110	110	Overhead equipment	Jumper	Repair		I
132361024	M81404	08/24/2013	19:25	08/24/2013	20:11	1	46	46	Animal related	Fuse	Replace - Same Size		V
132361029	A85001	08/24/2013	19:49	08/24/2013	21:10	1	81	81	Unknown	Fuse	Replace - New Size		I
132361051	H00163	08/24/2013	20:33	08/24/2013	22:20	56	5992	107	Underground equipment	Underground Primary	Switch/Reset	Repair	III
132361056	R59417	08/24/2013	21:00	08/28/2013	22:12	1	5832	5832	Animal related	Transformer Fuse	Replace - Same Size	Trim	IV
132361062	C70001	08/24/2013	21:06	08/24/2013	22:00	1	54	54	Animal related	Fuse	Replace - Same Size	No Work Required	III
132361082	B68003	08/24/2013	21:48	08/25/2013	2:00	7	1764	252	Unknown	Recloser	Switch/Reset	No Work Required	III
132361093	K52400	08/24/2013	22:05	08/25/2013	0:50	28	4620	165	Underground equipment	Overhead Transformer			V
132361094	Y51506	08/24/2013	22:08	08/24/2013	23:40	20	1840	92	Animal related	Transformer Fuse	Repair		IV
132370028	B21004	08/25/2013	4:40	08/25/2013	7:20	36	5760	160	Underground equipment	Underground Primary	Patrol/Test/Inspect	Replace - Urgent	I
132370054	S48273	08/25/2013	6:49	08/25/2013	8:41	4121	461552	112	Substation equipment				VI
132370093	HD0573	08/25/2013	6:50	08/25/2013	8:41	405	44955	111	Substation equipment	Lightning Arrestor			VI
132370091	HD0574	08/25/2013	6:50	08/25/2013	8:41	567	62937	111	Substation equipment	Lightning Arrestor			VI
132370097	A85001	08/25/2013	7:02	08/25/2013	14:42	1	460	460	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
132370111	N54214	08/25/2013	7:14	08/25/2013	8:07	51	2703	53	Overhead equipment	Fuse	Replace - Same Size	No Work Required	II
132370110	X02546	08/25/2013	7:30	08/25/2013	9:00	1	90	90	Overhead equipment	Fuse			IV
132370112	P62138	08/25/2013	7:35	08/25/2013	8:39	7	448	64	Animal related	Transformer Fuse	Replace - Same Size		VI
132370125	A48005	08/25/2013	7:50	08/25/2013	8:31	71	2911	41	Unknown	Fuse			I
132370130	310123	08/25/2013	7:57	08/25/2013	9:04	1	67	67	Animal related	Fuse	Replace - Same Size	No Work Required	V
132370140	B57002	08/25/2013	8:15	08/25/2013	9:45	52	4680	90	Unknown	Fuse	Replace - Same Size		I
132370143	B73001	08/25/2013	8:18	08/25/2013	14:00	1	342	342	Underground equipment	Underground Primary	Replace - Same Size	Repair	I
132370147	T16528	08/25/2013	8:31	08/25/2013	8:51	1	20	20	Overhead equipment	Substation Breaker	Switch/Reset		VI
132370149	S15566	08/25/2013	8:35	08/25/2013	10:10	1	95	95	Overhead equipment	Transformer Fuse	Replace - Same Size		VI
132370245	U97528	08/25/2013	8:50	08/25/2013	16:10	5	2200	440	Underground equipment	Underground Transformer		Replace - Same Size	II

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
132370161	U97528	08/25/2013	8:50	08/25/2013	11:41	1	171	171	Underground equipment	Underground Primary			II
132370163	U97528	08/25/2013	8:50	08/25/2013	11:36	18	2988	166	Underground equipment	Underground Primary	Switch/Reset	Repair	II
132370185	P18104	08/25/2013	9:25	08/25/2013	12:34	7	1323	189	Underground equipment	Underground Primary	Switch/Reset		IV
132370194	P18104	08/25/2013	9:30	08/25/2013	12:45	24	4680	195	Underground equipment	Underground Primary	Switch/Reset	Repair	IV
132370196	V61584	08/25/2013	9:34	08/25/2013	10:45	1	71	71	Overhead equipment	Fuse	Replace - Same Size		II
132370211	R61241	08/25/2013	10:23	08/25/2013	11:52	5	445	89	Animal related	Transformer Fuse	Replace - Same Size	No Work Required	IV
132370229	U97528	08/25/2013	11:06	08/25/2013	11:09	44	132	3	Jurisdictional	Fuse	Replace - Same Size		II
132370235	U97528	08/25/2013	11:29	08/25/2013	11:41	1	12	12	Underground equipment	Underground Primary			II
132370301	Y98001	08/25/2013	12:26	08/25/2013	13:11	6	270	45	Overhead equipment	Transformer Fuse	No Work Required	Repair	IV
132370317		08/25/2013	12:53	08/25/2013	14:33	1	100	100	Underground equipment	Underground Service	Repair		I
132370333	U02597	08/25/2013	13:04	08/25/2013	14:15	1	71	71	Animal related	Animal Guard	Install		II
132370404	B93002	08/25/2013	13:57	08/25/2013	15:40	5	515	103	Unknown	Fuse	Replace - Same Size		I
132370418	L00133	08/25/2013	14:35	08/25/2013	14:59	1	24	24	Overhead equipment	Overhead Service	Repair		III
132370460	N73121	08/25/2013	15:45	08/25/2013	17:17	1	92	92	Tree related-tree contact	Overhead Service	Repair		IV
132370492		08/25/2013	16:32	08/25/2013	20:19	1	227	227	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	I
132370508	B21001	08/25/2013	16:52	08/25/2013	21:44	33	9636	292	Underground equipment	Underground Primary	Patrol/Test/Inspect	Patrol/Test/Inspect	I
132370539	K57211	08/25/2013	17:39	08/26/2013	3:50	4	2444	611	Overhead equipment	Overhead Transformer		Replace - Same Size	VI
132370559	P12290	08/25/2013	18:09	08/25/2013	19:48	1	99	99	Overhead equipment	Overhead Service	Repair	Repair	V
132370589	Q14392	08/25/2013	18:56	08/25/2013	22:38	1	222	222	Animal related	Underground Primary	Replace - Same Size	Repair	I
132370587	L70127	08/25/2013	18:56	08/25/2013	21:12	6	816	136	Overhead equipment	Overhead Transformer	Replace - Same Size	No Work Required	IV
132370641	U91584	08/25/2013	20:27	08/26/2013	1:30	1	303	303	Underground equipment	Underground Primary		Repair	II
132370661	X19561	08/25/2013	21:18	08/26/2013	3:37	7	2653	379	Underground equipment	Underground Primary	Repair	Repair	IV
132370685	L59929	08/25/2013	22:32	08/26/2013	14:00	8	7424	928	Underground equipment	Underground Primary	Repair	Repair	VI
132370689	N54214	08/25/2013	22:41	08/26/2013	0:34	50	5650	113	Underground equipment	Underground Primary	Switch/Reset	Repair	II
132370696	P18104	08/25/2013	22:54	08/26/2013	0:15	23	1863	81	Underground equipment	Underground Primary	Switch/Reset	Repair	IV
132380112	J07173	08/26/2013	1:36	08/26/2013	3:51	6	810	135	Underground equipment	Underground Primary	No Work Required	Switch/Reset	I
132380115	V36001	08/26/2013	2:19	08/26/2013	5:45	8	1648	206	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	II
132380116	J07173	08/26/2013	2:42	08/26/2013	3:47	1	65	65	Underground equipment	Underground Primary	No Work Required		I
132380119	Q82906	08/26/2013	2:56	08/26/2013	3:47	1	51	51	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	VI
132383908	J79305	08/26/2013	3:45	08/26/2013	5:39	1	114	114	Unknown	Fuse	Replace - Same Size		I
132383913	K05253	08/26/2013	4:14	08/26/2013	7:15	91	16471	181	Overhead equipment	Fuse	Repair	Repair	VI
132383921	K80382	08/26/2013	4:31	08/26/2013	6:55	39	5616	144	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	IV
132383955	C70001	08/26/2013	6:51	08/26/2013	8:32	1	101	101	Animal related	Fuse	Replace - Same Size		III
132384010	J80806	08/26/2013	7:09	08/26/2013	9:15	179	22554	126	Overhead equipment	Jumper	Repair	Repair	V
132384014	Y37592	08/26/2013	7:13	08/26/2013	8:00	7	329	47	Animal related	Fuse	Replace - Same Size		IV
132384028	N93260	08/26/2013	7:15	08/26/2013	8:18	1	63	63	Overhead equipment	Transformer Fuse		Replace - Same Size	III
132384105	X87578	08/26/2013	7:42	08/26/2013	9:30	1	108	108	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
132384132	A17025	08/26/2013	7:47	08/26/2013	10:40	4	692	173	Animal related	Underground Primary		Replace - Same Size	I
132384227	T05539	08/26/2013	8:16	08/26/2013	10:01	1	105	105	Animal related	Fuse			VI
132384320	B61001	08/26/2013	8:36	08/26/2013	15:17	1	401	401	Underground equipment	Underground Primary		Repair	I
132384366	N50331	08/26/2013	8:44	08/26/2013	9:53	1	69	69	Overhead equipment	Overhead Service	Repair		II
132384378	U93563	08/26/2013	8:49	08/26/2013	10:30	1	101	101	Animal related	Transformer Fuse	Replace - Same Size		II
132384618	V25513	08/26/2013	9:38	08/26/2013	10:51	3	219	73	Animal related	Transformer Fuse	Replace - Same Size		II
132384954	D16002	08/26/2013	9:58	08/26/2013	11:32	6	564	94	Public	Underground Primary		Repair	I
132384747	J06168	08/26/2013	10:03	08/26/2013	10:59	1	56	56	Overhead equipment	Transformer Fuse	Replace - Same Size		I
132384805	L80222	08/26/2013	10:13	08/26/2013	11:20	3	201	67	Unknown	Fuse	Replace - Same Size		IV
132384958		08/26/2013	10:44	08/26/2013	11:30	1	46	46	Overhead equipment	Disconnect Switch	Replace - Same Size	Replace - Same Size	II
132385076	R05186	08/26/2013	10:46	08/26/2013	12:23	41	3977	97	Underground equipment	Underground Primary	Replace - Same Size	Replace - Same Size	I
132385015	R05186	08/26/2013	10:55	08/26/2013	12:26	1	91	91	Underground equipment	Underground Primary	No Work Required		I
132385049	X99538	08/26/2013	11:00	08/26/2013	11:50	2	100	50	Animal related	Fuse	Replace - Same Size		IV
132385898	L93BUS	08/26/2013	12:24	08/26/2013	13:17	3099	164247	53	Substation equipment				VI
132385692	Q23255	08/26/2013	12:34	08/26/2013	14:11	1	97	97	Substation equipment				VI
132385679	T14575	08/26/2013	12:34	08/26/2013	14:23	1	109	109	Tree related-tree broken	Overhead Service	Patrol/Test/Inspect	Repair	VI
132386206	L93135	08/26/2013	14:01	08/26/2013	14:37	1	36	36	Overhead equipment				VI
132386257	M19222	08/26/2013	14:10	08/26/2013	16:05	3	345	115	Animal related	Overhead Transformer			VI
132386443	79076	08/26/2013	14:23	08/26/2013	17:32	1953	369117	189	Overhead equipment				V

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
132386597	U10547	08/26/2013	14:48	08/26/2013	14:51	1	3	3	Animal related	Transformer Fuse	Replace - Same Size		II
132386718	79073	08/26/2013	15:01	08/26/2013	17:05	445	55180	124	Overhead equipment				V
132386934	348117	08/26/2013	15:47	08/26/2013	16:05	1	18	18	Jurisdictional	Overhead Service	Reconnect		V
132387042	Z20542	08/26/2013	16:11	08/26/2013	19:51	1	220	220	Public	Underground Primary	Patrol/Test/Inspect	Repair	IV
132387153	B45004	08/26/2013	16:44	08/26/2013	17:57	57	4161	73	Tree related-tree broken	Tree	Remove		I
132387165	B84003	08/26/2013	16:51	08/26/2013	17:25	5	170	34	Animal related	Transformer Fuse	Replace - Same Size		I
132387284	K52421	08/26/2013	17:33	08/26/2013	19:59	1	146	146	Overhead equipment	Fuse	Replace - Same Size		V
132387342	Y50002	08/26/2013	18:01	08/26/2013	19:20	7	553	79	Animal related	Transformer Fuse	Replace - Same Size		IV
132387553	Q68836	08/26/2013	18:26	08/26/2013	22:38	1	252	252	Tree related-tree broken	Overhead Secondary	Repair	Repair	V
132387569	P26284	08/26/2013	18:35	08/26/2013	22:21	1	226	226	Overhead equipment	Disconnect Switch	Replace - Same Size	Repair	I
132387909	M31204	08/26/2013	18:52	08/26/2013	19:18	1	26	26	Jurisdictional	Other	No Work Required	No Work Required	I
132388208	D48003	08/26/2013	19:26	08/27/2013	3:25	17	8143	479	Underground equipment	Underground Primary	Repair	Repair	I
132388200	L12127	08/26/2013	19:35	08/26/2013	20:06	9	279	31	Underground equipment	Underground Primary	Switch/Reset		III
132388172	L12127	08/26/2013	19:35	08/26/2013	21:36	24	2904	121	Underground equipment	Underground Primary		Repair	III
132388183	M47816	08/26/2013	19:57	08/26/2013	21:35	1	98	98	Overhead equipment	Overhead Service		Replace - Same Size	V
132388403	M42105	08/26/2013	23:23	08/27/2013	3:33	591	147750	250	Underground equipment	Underground Primary	Switch/Reset	Repair	I
132390106	J46182	08/27/2013	1:25	08/27/2013	3:41	1	136	136	Tree related-tree contact	Tree			III
132390248	307001	08/27/2013	2:43	08/27/2013	4:14	2	182	91	Tree related-tree broken	Overhead Service	Repair		VI
132394973	D41003	08/27/2013	7:14	08/27/2013	9:54	1	160	160	Public	Overhead Primary		Repair	I
132394792	D41003	08/27/2013	7:14	08/27/2013	8:19	112	7280	65	Public	Overhead Primary		Repair	I
132394988	N60172	08/27/2013	8:16	08/27/2013	9:30	22	1628	74	Underground equipment	Underground Primary	Replace - Same Size	Replace - Same Size	I
132395000	S86582	08/27/2013	8:21	08/27/2013	10:04	1	103	103	Animal related	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
132395147	U28510	08/27/2013	9:02	08/27/2013	10:55	1	113	113	Animal related	Underground Primary			II
132395189		08/27/2013	9:12	08/27/2013	10:24	1	72	72	Overhead equipment	Other	Patrol/Test/Inspect	Patrol/Test/Inspect	I
132395206	S36571	08/27/2013	9:17	08/27/2013	10:05	9	432	48	Animal related	Fuse	Replace - Same Size		VI
132395272	J87150	08/27/2013	9:29	08/27/2013	10:07	1	38	38	Animal related	Fuse	Replace - Same Size		VI
132395282	J87150	08/27/2013	9:32	08/27/2013	10:07	1	35	35	Animal related	Fuse	Replace - Same Size		VI
132395498	HB6251	08/27/2013	10:10	08/27/2013	11:32	13	1066	82	Unknown	Fuse	Replace - Same Size		VI
132395537	T23528	08/27/2013	10:24	08/27/2013	12:04	1	100	100	Animal related	Fuse	Replace - New Size		VI
132395843	N74240	08/27/2013	11:17	08/27/2013	12:44	174	15138	87	Overhead equipment	Recloser	Switch/Reset		I
132395878	N74242	08/27/2013	11:18	08/27/2013	14:06	17	2856	168	Overhead equipment	Overhead Transformer	Replace - Same Size	No Work Required	I
132395863	N74241	08/27/2013	11:21	08/27/2013	12:49	1	88	88	Overhead equipment	Overhead Transformer	Repair		I
132396170	R05115	08/27/2013	11:59	08/27/2013	13:28	203	18067	89	Overhead equipment	Overhead Primary	Repair		I
132396023	R05115	08/27/2013	12:00	08/27/2013	12:44	499	21956	44	Overhead equipment	Overhead Primary	Repair		I
132396087	D70004	08/27/2013	12:16	08/27/2013	14:27	1	131	131	Public	Crossarm	Patrol/Test/Inspect	Replace - Same Size	I
132396164	V92555	08/27/2013	12:37	08/27/2013	14:00	1	83	83	Overhead equipment	Connector	Replace - Same Size		II
132396176	S92559	08/27/2013	12:39	08/27/2013	13:35	1	56	56	Animal related	Transformer Fuse	Replace - Same Size		VI
132396189	D70004	08/27/2013	12:43	08/27/2013	14:27	1	104	104	Public	Crossarm	Patrol/Test/Inspect	Repair	I
132396249	N74240	08/27/2013	12:57	08/27/2013	14:05	1	68	68	Overhead equipment	Overhead Transformer	Replace - Same Size	No Work Required	I
132396278	M07236	08/27/2013	13:06	08/27/2013	13:52	1	46	46	Overhead equipment				III
132396348	T06539	08/27/2013	13:21	08/27/2013	13:40	3	57	19	Overhead equipment	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
132396392	Q68836	08/27/2013	13:30	08/27/2013	14:26	1	56	56	Public				V
132396420	R49275	08/27/2013	13:34	08/27/2013	15:34	1	120	120	Tree related-tree broken	Fuse		Patrol/Test/Inspect	VI
132397152	B19002	08/27/2013	13:41	08/27/2013	18:50	8	2472	309	Overhead equipment	Crossarm	Patrol/Test/Inspect	Repair	I
132396567	R60552	08/27/2013	13:58	08/27/2013	15:31	1	93	93	Overhead equipment	Meter	Replace - Same Size	No Work Required	IV
132396658	B76003	08/27/2013	14:29	08/28/2013	4:03	1	814	814	Public	Underground Service	Cut in Clear	Repair	I
132396781	D87001	08/27/2013	14:41	08/27/2013	16:38	208	24336	117	Tree related-tree contact	Tree	Remove		I
132396788	D37003	08/27/2013	14:49	08/28/2013	1:00	1	611	611	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
132396786		08/27/2013	14:49	08/27/2013	16:40	1	111	111	Tree related-tree contact	Tree	Remove		I
132396864	M45212	08/27/2013	15:06	08/27/2013	17:57	1	171	171	Tree related-tree contact	Overhead Service	Repair		IV
132396940	344002	08/27/2013	15:19	08/27/2013	16:15	13	728	56	Other	Fuse	Replace - Same Size		VI
132396967	J18268	08/27/2013	15:32	08/27/2013	21:24	1	352	352	Underground equipment	Overhead Service		Repair	VI
132397080	U01514	08/27/2013	16:00	08/27/2013	16:42	1	42	42	Animal related	Transformer Fuse	Replace - Same Size	Replace - Same Size	II
132397141	J87150	08/27/2013	16:22	08/27/2013	17:35	96	7008	73	Underground equipment				VI
132397135	R60551	08/27/2013	16:26	08/27/2013	18:11	1	105	105	Other	Other			IV
132397143	M41111	08/27/2013	16:27	08/27/2013	17:15	9	432	48	Overhead equipment	Transformer Fuse	Replace - Same Size		I

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
132397183	B58001	08/27/2013	16:43	08/27/2013	17:53	8	560	70	Overhead equipment	Overhead Service	Repair		I
132397207	D89002	08/27/2013	16:49	08/27/2013	18:00	45	3195	71	Underground equipment	Underground Primary	Switch/Reset		I
132397338	R49275	08/27/2013	17:58	08/27/2013	19:37	1	99	99	Unknown	Fuse		Replace - Same Size	VI
132397343	F03003	08/27/2013	18:03	08/27/2013	19:11	11	748	68	Overhead equipment	Fuse	Replace - Same Size		III
132397348	H00162	08/27/2013	18:06	08/27/2013	18:54	1	48	48	Tree related-tree contact	Tree			III
132397404	J14140	08/27/2013	18:42	08/27/2013	20:50	1	128	128	Animal related	Transformer Fuse	Replace - Same Size		VI
132397971	L35138	08/27/2013	19:54	08/27/2013	20:33	1	39	39	Overhead equipment	Transformer Fuse	Replace - Same Size		III
132397975	L35138	08/27/2013	20:06	08/27/2013	20:33	1	27	27	Overhead equipment	Transformer Fuse	Replace - Same Size		III
132397980	Q27185	08/27/2013	20:14	08/27/2013	22:16	3	366	122	Overhead equipment	Fuse	Replace - Same Size		VI
132397981	D72003	08/27/2013	20:15	08/27/2013	22:12	18	2106	117	Tree related-tree broken	Tree	Remove		I
132397984	D72003	08/27/2013	20:17	08/27/2013	23:07	1	170	170	Tree related-tree broken	Overhead Service	Repair		I
132397986	D72003	08/27/2013	20:19	08/27/2013	23:08	1	169	169	Tree related-tree broken	Tree	Remove		I
132398094	B00002	08/27/2013	20:28	08/28/2013	3:44	56	24416	436	Underground equipment	Underground Primary		Repair	I
132398014	B00002	08/27/2013	20:28	08/27/2013	22:50	123	17466	142	Underground equipment				I
132400132	B76001	08/27/2013	22:41	08/28/2013	6:10	2	898	449	Underground equipment	Underground Primary	Repair	Repair	I
132398074	B76001	08/27/2013	22:41	08/28/2013	0:30	42	4578	109	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
132400141	L17102	08/28/2013	1:27	08/28/2013	3:45	75	10350	138	Overhead equipment	Overhead Primary	Repair		III
132400169	R60551	08/28/2013	1:39	08/28/2013	4:30	42	7182	171	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	IV
132404161	L35138	08/28/2013	2:48	08/28/2013	12:45	4	2388	597	Underground equipment	Underground Primary			III
132400318	L35138	08/28/2013	2:48	08/28/2013	7:20	41	11152	272	Underground equipment	Underground Primary			III
132400319	B82001	08/28/2013	2:55	08/28/2013	4:36	1	101	101	Unknown	Fuse			I
132403834	M18131	08/28/2013	4:57	08/28/2013	7:23	1	146	146	Animal related	Overhead Transformer	Repair		III
132403983		08/28/2013	4:59	08/28/2013	7:10	1203	157593	131	Animal related				III
132404007	P99428	08/28/2013	4:59	08/28/2013	6:47	1794	193752	108	Animal related				III
132403995	Q01280	08/28/2013	4:59	08/28/2013	10:11	892	278304	312	Animal related				III
132404003	S47576	08/28/2013	6:40	08/28/2013	8:25	1	105	105	Animal related	Lightning Arrestor	Replace - Same Size		VI
132404112	L50215	08/28/2013	7:19	08/28/2013	7:58	1	39	39	Animal related	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
132404105	R59412	08/28/2013	7:22	08/28/2013	8:24	1	62	62	Unknown	Fuse			IV
132404170	N97887	08/28/2013	7:42	08/28/2013	9:33	1	111	111	Overhead equipment	Overhead Transformer	Replace - New Size	Replace - New Size	V
132404920	Q32171	08/28/2013	8:07	08/28/2013	11:02	1	175	175	Underground equipment	Overhead Primary	Patrol/Test/Inspect	Patrol/Test/Inspect	I
132404442	R58942	08/28/2013	8:54	08/28/2013	10:34	1	100	100	Tree related-tree broken	Overhead Service	Repair	Trim	IV
132404572	U31542	08/28/2013	9:28	08/28/2013	9:45	1	17	17	Animal related	Transformer Fuse	Replace - Same Size		II
132404585		08/28/2013	9:31	08/28/2013	10:11	1	40	40	Animal related	Substation Breaker	Repair		III
132404599	Q32171	08/28/2013	9:36	08/28/2013	9:45	46	414	9	Underground equipment	Underground Primary	Switch/Reset		I
132404759	D89002	08/28/2013	10:00	08/28/2013	17:15	23	10005	435	Underground equipment	Underground Primary	Repair	Repair	I
132404805	Q01282	08/28/2013	10:19	08/28/2013	12:56	33	5181	157	Underground equipment	Underground Primary	Repair	Repair	III
132404809	E10002	08/28/2013	10:23	08/28/2013	11:00	1	37	37	Overhead equipment	Transformer Fuse	Replace - Same Size		III
132404901	B82001	08/28/2013	10:36	08/28/2013	11:18	1	42	42	Animal related	Fuse	Replace - Same Size		I
132405076	R01153	08/28/2013	11:15	08/28/2013	15:15	1	240	240	Tree related-tree contact	Overhead Service	Repair	Repair	III
132405217	J20931	08/28/2013	11:19	08/28/2013	12:33	12	888	74	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	VI
132405283	K27122	08/28/2013	12:14	08/28/2013	13:19	1	65	65	Overhead equipment	Connector	Repair	No Work Required	VI
132405365	305130	08/28/2013	12:37	08/28/2013	13:55	1	78	78	Overhead equipment	Overhead Primary		Repair	V
132405430	A85001	08/28/2013	12:56	08/28/2013	23:00	1	604	604	Underground equipment	Underground Primary	Repair	Repair	I
132405526	B80004	08/28/2013	13:01	08/28/2013	15:36	13	2015	155	Underground equipment	Underground Primary	Switch/Reset	Repair	I
132405497	B80003	08/28/2013	13:10	08/28/2013	15:36	19	2774	146	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
132405506	P57104	08/28/2013	13:16	08/28/2013	13:43	1	27	27	Overhead equipment	Overhead Secondary	Repair	Repair	VI
132405561	K39156	08/28/2013	13:18	08/28/2013	14:49	1046	95186	91	Public	Pole	Replace - Same Size		III
132406062	J14140	08/28/2013	14:08	08/28/2013	23:00	9	4788	532	Underground equipment	Underground Primary		Repair	VI
132405932	J58380	08/28/2013	14:49	08/28/2013	16:12	1	83	83	Overhead equipment	Overhead Transformer		Replace - Same Size	III
132406086	X96543	08/28/2013	15:34	08/28/2013	16:26	1	52	52	Animal related	Transformer Fuse	Repair	Patrol/Test/Inspect	IV
132406223		08/28/2013	16:28	08/30/2013	2:01	2	4026	2013	Public	Overhead Service	Patrol/Test/Inspect	Replace - Same Size	I
132406268	M47802	08/28/2013	16:45	08/28/2013	19:20	1	155	155	Overhead equipment	Overhead Transformer	Repair	Repair	V
132406356	N74241	08/28/2013	17:21	08/28/2013	19:40	11	1529	139	Overhead equipment	Overhead Secondary	Repair	No Work Required	I
132406392	Y59519	08/28/2013	17:39	08/28/2013	19:20	13	1313	101	Underground equipment	Underground Primary		Repair	IV
132406443	A97001	08/28/2013	18:21	08/28/2013	19:57	1	96	96	Unknown	Fuse	Replace - Same Size		I
132406460	D66002	08/28/2013	18:23	08/28/2013	20:15	74	8288	112	Overhead equipment	Connector	Replace - Same Size		IV

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
132407622	V10533	08/28/2013	18:36	08/28/2013	22:42	168	41328	246	Underground equipment	Underground Primary	Switch/Reset	Repair	II
132406730	M15375	08/28/2013	18:46	08/28/2013	20:32	1	106	106	Tree related-tree broken	Overhead Service	Repair		V
132407294	V17539	08/28/2013	19:20	08/28/2013	22:38	5	990	198	Overhead equipment	Overhead Transformer		Replace - New Size	II
132407333	N44217	08/28/2013	19:59	08/28/2013	20:58	15	885	59	Overhead equipment	Fuse			III
132407317	D72003	08/28/2013	20:02	08/28/2013	22:00	1	118	118	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Repair	I
132407326	M54315	08/28/2013	20:03	08/28/2013	21:18	105	7875	75	Other	Fuse	Repair		V
132407330	306001	08/28/2013	20:10	08/28/2013	22:50	59	9440	160	Overhead equipment	Overhead Primary	Repair	Repair	VI
132407371	V01002	08/28/2013	20:47	08/28/2013	22:31	6	624	104	Public	Overhead Primary	Repair		II
132407574	V01002	08/28/2013	21:04	08/28/2013	22:00	1	56	56	Overhead equipment	Overhead Primary	Repair		II
132407580	V46552	08/28/2013	21:05	08/29/2013	0:39	36	7704	214	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	II
132407584	Y93005	08/28/2013	21:11	08/28/2013	22:25	23	1702	74	Overhead equipment	Fuse	Repair	Replace - Same Size	IV
132407607	L74191	08/28/2013	22:13	08/29/2013	0:10	1	117	117	Tree related-tree broken	Overhead Service	Repair		IV
132407684	D70004	08/28/2013	22:32	08/29/2013	4:52	5	1900	380	Underground equipment	Underground Primary	Repair	Repair	I
132407634	D70004	08/28/2013	22:32	08/28/2013	23:55	4	332	83	Underground equipment	Underground Primary	Switch/Reset		I
132407670	C66002	08/28/2013	23:31	08/29/2013	7:56	2	1010	505	Tree related-tree broken	Overhead Secondary	Patrol/Test/Inspect		III
132413981	U60518	08/29/2013	5:13	08/29/2013	6:50	1	97	97	Overhead equipment	Transformer Fuse	Replace - Same Size		II
132413990	Q06144	08/29/2013	5:39	08/29/2013	8:13	1	154	154	Animal related	Fuse	Replace - Same Size		IV
132413988	J83139	08/29/2013	5:39	08/29/2013	6:47	1	68	68	Animal related	Transformer Fuse			VI
132414811	B21004	08/29/2013	5:57	08/29/2013	13:53	24	11424	476	Underground equipment	Underground Primary		Repair	I
132413999	B21004	08/29/2013	5:57	08/29/2013	9:30	197	41961	213	Underground equipment	Underground Primary		Repair	I
132414001	Q06144	08/29/2013	6:00	08/29/2013	8:13	1	133	133	Animal related	Fuse	Replace - Same Size		IV
132414017	B21004	08/29/2013	6:18	08/29/2013	9:26	1	188	188	Underground equipment				I
132414023	N35852	08/29/2013	6:31	08/29/2013	7:08	10	370	37	Animal related	Fuse	Replace - Same Size		V
132414079	S02502	08/29/2013	7:14	08/29/2013	8:40	1	86	86	Animal related	Transformer Fuse	Replace - Same Size		VI
132414611	D16003	08/29/2013	7:33	08/29/2013	9:28	359	41285	115	Underground equipment				I
132414201	D16003	08/29/2013	7:34	08/29/2013	11:07	426	90738	213	Underground equipment	Underground Primary	Patrol/Test/Inspect		I
132414213	N14880	08/29/2013	7:53	08/29/2013	9:34	1	101	101	Animal related	Transformer Fuse	Replace - Same Size		V
132414310	K11376	08/29/2013	8:21	08/29/2013	11:40	10	1990	199	Overhead equipment	Overhead Secondary	Patrol/Test/Inspect	Repair	V
132414366	U93563	08/29/2013	8:37	08/29/2013	9:16	1	39	39	Animal related	Transformer Fuse	Replace - Same Size		II
132415148	Q74150	08/29/2013	8:46	08/29/2013	12:40	5	1170	234	Overhead equipment	Overhead Primary	Repair		IV
132414395	N03297	08/29/2013	8:46	08/29/2013	9:31	1	45	45	Overhead equipment				V
132414417	P20913	08/29/2013	8:52	08/29/2013	10:19	29	2523	87	Animal related	Fuse	Replace - Same Size		VI
132414418	P20913	08/29/2013	8:54	08/29/2013	10:18	1	84	84	Animal related	Fuse	Replace - Same Size		VI
132414532	J20931	08/29/2013	9:14	08/29/2013	10:50	12	1152	96	Unknown	Other			VI
132414541	S47538	08/29/2013	9:19	08/29/2013	10:40	1	81	81	Animal related	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
132414768	M41113	08/29/2013	10:04	08/29/2013	10:55	49	2499	51	Overhead equipment	Fuse	Replace - Same Size		I
132414834	U73583	08/29/2013	10:18	08/29/2013	10:53	1	35	35	Overhead equipment	Overhead Service	Repair		II
132414939	D16001	08/29/2013	10:35	08/29/2013	10:57	1	22	22	Underground equipment	Meter			I
132414946	D16004	08/29/2013	10:36	08/29/2013	10:39	1	3	3	Underground equipment				I
132414945	D16004	08/29/2013	10:36	08/29/2013	10:43	1	7	7	Underground equipment				I
132415027	HB6283	08/29/2013	10:49	08/29/2013	17:25	1	396	396	Public	Underground Primary		Replace - Same Size	VI
132415156	Y23521	08/29/2013	11:14	08/29/2013	11:55	1	41	41	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
132415664	S28551	08/29/2013	13:33	08/29/2013	14:45	1	72	72	Animal related	Transformer Fuse	Replace - New Size		VI
132415777	D88001	08/29/2013	13:58	08/29/2013	18:07	1	249	249	Underground equipment	Underground Primary	Repair	Replace - Same Size	I
132415947	P98190	08/29/2013	14:37	08/29/2013	16:53	25	3400	136	Underground equipment	Underground Primary			III
132415986	K62102	08/29/2013	14:50	08/29/2013	16:05	1	75	75	Tree related-tree contact	Overhead Primary	Repair		II
132416151	N67315	08/29/2013	15:36	08/29/2013	15:55	1	19	19	Other	Other	No Work Required	No Work Required	I
132416152	V37537	08/29/2013	15:36	08/29/2013	17:05	1	89	89	Tree related-tree contact	Overhead Service	Repair	Repair	II
132416300	R53391	08/29/2013	16:27	08/29/2013	18:53	1	146	146	Overhead equipment	Connector	Repair		V
132416440	J97136	08/29/2013	17:20	08/29/2013	17:45	41	1025	25	Overhead equipment	Fuse			VI
132416467	R53416	08/29/2013	17:34	08/29/2013	19:41	4	508	127	Underground equipment	Transformer Fuse	Replace - Same Size		V
132416495	J97136	08/29/2013	17:51	08/29/2013	17:56	1	5	5	Overhead equipment	Fuse			VI
132416510	B81003	08/29/2013	18:04	08/29/2013	20:10	1	126	126	Underground equipment	Underground Primary	Switch/Reset	Repair	I
132417263	P18104	08/29/2013	18:21	08/29/2013	22:51	15	4050	270	Overhead equipment	Fuse		Replace - Same Size	IV
132416527	Q63835	08/29/2013	18:22	08/29/2013	20:47	5	725	145	Tree related-tree broken	Overhead Service		Repair	V
132416542	R73841	08/29/2013	18:28	08/29/2013	23:16	11	3168	288	Other	Overhead Secondary	Replace - Same Size	Replace - Same Size	V

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
132416656	350104	08/29/2013	18:52	08/29/2013	20:01	46	3174	69	Overhead equipment	Fuse	Replace - Same Size		V
132417421	L68113	08/29/2013	21:05	08/29/2013	23:28	3	429	143	Overhead equipment	Overhead Transformer	Replace - Same Size		IV
132417452	J99141	08/29/2013	23:30	08/30/2013	1:08	19	1862	98	Underground equipment	Underground Primary			VI
132417468	U31598	08/29/2013	23:58	08/30/2013	4:30	22	5984	272	Underground equipment	Underground Primary	Switch/Reset	Repair	II
132420110	Q18244	08/30/2013	0:13	08/30/2013	2:02	195	21255	109	Overhead equipment	Fuse	Replace - Same Size		VI
132420168	D28124	08/30/2013	0:45	08/30/2013	3:30	277	45705	165	Overhead equipment	Recloser	Switch/Reset	Repair	I
132420163	D28124	08/30/2013	1:08	08/30/2013	3:30	1	142	142	Overhead equipment				I
132420285	K46389	08/30/2013	2:51	08/30/2013	5:40	1	169	169	Underground equipment			Patrol/Test/Inspect	V
132425675	K46389	08/30/2013	2:51	08/30/2013	5:10	53	7367	139	Animal related	Fuse		Repair	V
132420286	D28124	08/30/2013	2:53	08/30/2013	4:13	1	80	80	Overhead equipment				I
132420293	Y54001	08/30/2013	2:54	08/30/2013	4:20	32	2752	86	Overhead equipment	Overhead Primary			IV
132420294	U52516	08/30/2013	3:10	08/30/2013	4:25	1	75	75	Unknown	Transformer Fuse	Replace - Same Size		II
132425669	Y54001	08/30/2013	3:53	08/30/2013	4:20	6	162	27	Overhead equipment	Overhead Primary	Repair		IV
132425708	R33126	08/30/2013	6:05	08/30/2013	7:15	9	630	70	Animal related	Fuse	Replace - Same Size	Patrol/Test/Inspect	I
132425722	R60552	08/30/2013	6:36	08/30/2013	7:35	1	59	59	Unknown	Fuse	Replace - Same Size		IV
132425732	D28124	08/30/2013	6:48	08/30/2013	15:22	1	514	514	Underground equipment	Bracket	Repair	Repair	I
132426032	D16003	08/30/2013	7:26	08/30/2013	10:55	30	6270	209	Overhead equipment	Other	Replace - Same Size	Repair	I
132425844	D16003	08/30/2013	7:26	08/30/2013	8:53	92	8004	87	Overhead equipment	Crossarm	Patrol/Test/Inspect	Repair	I
132425946	M04365	08/30/2013	8:05	08/30/2013	9:13	54	3672	68	Overhead equipment	Fuse	Replace - Same Size		V
132426046	M25144	08/30/2013	8:32	08/30/2013	9:13	1	41	41	Animal related	Transformer Fuse	Replace - Same Size		IV
132426525	Q09370	08/30/2013	8:53	08/30/2013	9:36	3595	154585	43	Animal related				III
132426770	Q09377	08/30/2013	8:53	08/30/2013	9:36	4975	213925	43	Animal related				III
132426389	R02121	08/30/2013	9:02	08/30/2013	15:07	1	365	365	Underground equipment	Underground Service	Repair	Repair	VI
132426697	D89002	08/30/2013	9:33	08/30/2013	11:45	1	132	132	Unknown	Other		No Work Required	I
132426739	T17581	08/30/2013	9:44	08/30/2013	10:30	1	46	46	Animal related	Disconnect Switch	Replace - Same Size	No Work Required	VI
132426896	H07106	08/30/2013	10:16	08/30/2013	10:42	3	78	26	Underground equipment	Underground Primary	Cut in Clear	Repair	IV
132426967	D28124	08/30/2013	10:32	08/30/2013	11:53	1	81	81	Overhead equipment	Disconnect Switch	Replace - Same Size		I
132426991	T06539	08/30/2013	10:39	08/30/2013	13:00	1	141	141	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	VI
132427409	P73182	08/30/2013	11:07	08/30/2013	12:15	20	1360	68	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	VI
132427126	Y73505	08/30/2013	11:14	08/30/2013	13:00	75	7950	106	Public	Underground Primary	Switch/Reset	Repair	IV
132427616	J01119	08/30/2013	11:22	08/30/2013	16:03	1	281	281	Underground equipment	Underground Primary		Repair	I
132427203	J01119	08/30/2013	11:27	08/30/2013	13:15	50	5400	108	Overhead equipment	Fuse	Replace - Same Size		I
132427317	J01119	08/30/2013	11:52	08/30/2013	13:15	58	4814	83	Overhead equipment	Fuse	Replace - Same Size		I
132427363	L12127	08/30/2013	12:03	08/30/2013	15:20	33	6501	197	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	III
132427419	J01119	08/30/2013	12:23	08/30/2013	12:46	1	23	23	Overhead equipment				I
132427614	D96001	08/30/2013	13:07	08/30/2013	15:02	19	2185	115	Jurisdictional	Underground Primary	Switch/Reset		I
132427620	V77543	08/30/2013	13:17	08/30/2013	14:05	7	336	48	Animal related	Transformer Fuse	Replace - Same Size		II
132427627	Q32171	08/30/2013	13:19	08/30/2013	15:00	1	101	101	Overhead equipment	Connector	Replace - Same Size	Replace - Same Size	I
132427973	V04718	08/30/2013	13:27	08/30/2013	14:39	344	24768	72	Overhead equipment				II
132427950	V06536	08/30/2013	13:36	08/30/2013	14:40	8	512	64	Overhead equipment	Fuse	Replace - Urgent		II
132427797	W03570	08/30/2013	13:45	08/30/2013	14:45	1	60	60	Overhead equipment	Fuse	Replace - Same Size	Patrol/Test/Inspect	II
132427824	D16002	08/30/2013	13:51	08/30/2013	15:40	1	109	109	Overhead equipment	Overhead Service	Replace - Same Size		I
132427879	CW1017	08/30/2013	14:00	08/30/2013	16:58	22	3916	178	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	III
132427956	X86543	08/30/2013	14:21	08/30/2013	15:30	1	69	69	Overhead equipment	Transformer Fuse			IV
132427985	A81001	08/30/2013	14:29	08/30/2013	15:09	1	40	40	Tree related-tree broken	Overhead Service	Repair	No Work Required	I
132428020	Y82587	08/30/2013	14:36	08/30/2013	18:41	1	245	245	Underground equipment	Underground Primary	Repair	Patrol/Test/Inspect	IV
132428108	U05001	08/30/2013	15:01	08/30/2013	16:45	1	104	104	Overhead equipment	Overhead Secondary	Repair	Repair	II
132428121	U05001	08/30/2013	15:03	08/30/2013	16:45	1	102	102	Overhead equipment	Overhead Secondary	Repair	Repair	II
132428140	T06538	08/30/2013	15:07	08/30/2013	15:38	1	31	31	Animal related	Fuse	Patrol/Test/Inspect	Repair	VI
132428201	Q75146	08/30/2013	15:28	08/30/2013	18:02	1	154	154	Animal related	Fuse	Replace - Same Size	Repair	VI
132428624		08/30/2013	15:32	08/30/2013	19:15	1	223	223	Public	Underground Transformer	Patrol/Test/Inspect	Replace - Same Size	IV
132428256	S60581	08/30/2013	15:43	08/30/2013	17:10	1	87	87	Overhead equipment	Disconnect Switch	Patrol/Test/Inspect	Replace - Same Size	VI
132428505	B10001	08/30/2013	15:45	08/30/2013	17:45	37	4440	120	Overhead equipment	Fuse	Replace - Same Size		I
132428473	R34920	08/30/2013	15:46	08/30/2013	19:30	52	11648	224	Overhead equipment	Overhead Primary			VI
132428437	R34920	08/30/2013	15:46	08/30/2013	16:55	441	30429	69	Overhead equipment	Overhead Primary			VI
132428341	Q23258	08/30/2013	16:00	08/30/2013	16:45	4	180	45	Overhead equipment	Underground Transformer			VI

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
132428542	A85002	08/30/2013	16:04	08/30/2013	20:21	12	3084	257	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
132428427	303005	08/30/2013	16:42	08/30/2013	18:15	1	93	93	Tree related-tree broken	Tree			VI
132428746	K76546	08/30/2013	16:49	08/30/2013	22:26	1	337	337	Underground equipment	Underground Primary	Replace - Same Size	Repair	IV
132428501	R68903	08/30/2013	17:13	08/31/2013	4:00	2	1294	647	Underground equipment	Underground Primary	Repair	Repair	I
132428521	334001	08/30/2013	17:22	08/30/2013	18:35	1	73	73	Tree related-tree broken	Overhead Service	Repair		VI
132428540	J88165	08/30/2013	17:27	08/30/2013	22:30	6	1818	303	Underground equipment	Underground Transformer		Replace - Same Size	VI
132428549	R58921	08/30/2013	17:30	08/30/2013	18:13	1	43	43	Tree related-tree broken				IV
132428585	334001	08/30/2013	17:40	08/30/2013	19:29	1	109	109	Tree related-tree broken	Overhead Service	Repair	Repair	VI
132428601	B79004	08/30/2013	17:47	08/30/2013	19:10	11	913	83	Overhead equipment	Transformer Fuse	Repair		I
132428603	V10001	08/30/2013	17:49	08/30/2013	20:15	1	146	146	Tree related-tree broken	Overhead Service	Repair		II
132428761	J83140	08/30/2013	18:03	08/30/2013	18:23	146	2920	20	Overhead equipment	Capacitor	Disconnect		VI
132429200	P53341	08/30/2013	18:33	08/30/2013	20:00	3	261	87	Overhead equipment	Fuse	Replace - Same Size	No Work Required	IV
132429218	K62102	08/30/2013	18:39	08/30/2013	20:29	13	1430	110	Underground equipment	Underground Primary	Switch/Reset		II
132429211	K28180	08/30/2013	18:43	08/30/2013	19:40	1	57	57	Animal related	Transformer Fuse	Replace - Same Size		III
132429228	309143	08/30/2013	18:52	08/30/2013	19:34	52	2184	42	Overhead equipment	Fuse	Replace - Same Size		V
132429229	309143	08/30/2013	18:53	08/30/2013	19:37	1	44	44	Overhead equipment	Fuse	Replace - Same Size		V
132429236	R07381	08/30/2013	18:58	08/30/2013	22:30	3	636	212	Other	Overhead Transformer	Replace - Same Size	Repair	I
132430675	Q82907	08/30/2013	19:05	08/30/2013	21:00	68	7820	115	Public	Overhead Primary	Repair	Repair	VI
132429245	K01240	08/30/2013	19:08	08/31/2013	1:32	1	384	384	Underground equipment	Overhead Service		Replace - Same Size	VI
132429247	R95520	08/30/2013	19:09	08/30/2013	21:20	1	131	131	Overhead equipment	Connector	Repair		I
132429294	Z61524	08/30/2013	19:32	08/30/2013	20:39	22	1474	67	Overhead equipment	Fuse	Replace - Same Size	Patrol/Test/Inspect	IV
132429298	B93003	08/30/2013	19:33	08/30/2013	20:43	9	630	70	Overhead equipment	Fuse	Replace - Same Size		I
132429283	J82116	08/30/2013	19:38	08/30/2013	21:04	6	516	86	Overhead equipment	Overhead Secondary			VI
132429368	N58144	08/30/2013	21:08	08/30/2013	23:00	1	112	112	Overhead equipment	Overhead Secondary	Repair		I
132429375	V23522	08/30/2013	21:14	08/30/2013	22:57	1	103	103	Overhead equipment	Connector	Repair		II
132429398	L73160	08/30/2013	21:46	08/30/2013	23:23	85	8245	97	Tree related-tree broken	Tree		Remove	IV
132429404	L82187	08/30/2013	21:52	08/31/2013	3:00	1	308	308	Tree related-tree broken	Overhead Primary			IV
132429428	Q34360	08/30/2013	22:02	08/31/2013	0:25	432	61776	143	Tree related-tree broken				I
132429425	Q37372	08/30/2013	22:02	08/31/2013	11:30	13	10504	808	Tree related-tree broken	Overhead Primary	Repair	Repair	I
132429421	334001	08/30/2013	22:05	08/30/2013	22:38	3	99	33	Overhead equipment	Tree			VI
132429427	J83140	08/30/2013	22:09	08/30/2013	23:35	1	86	86	Overhead equipment	Overhead Service			VI
132429430	326168	08/30/2013	22:11	08/30/2013	22:40	6	174	29	Overhead equipment	Fuse	Replace - New Size		V
132429444	R50910	08/30/2013	22:21	08/31/2013	2:08	39	8853	227	Tree related-tree broken	Fuse	Replace - Same Size		I
132429447		08/30/2013	22:28	08/31/2013	0:25	1	117	117	Tree related-tree broken	Substation Breaker	Switch/Reset		I
132429472	R50910	08/30/2013	22:36	08/31/2013	4:14	8	2704	338	Tree related-tree contact	Recloser	Switch/Reset		I
132429457	343008	08/30/2013	22:42	08/30/2013	23:49	1	67	67	Overhead equipment	Fuse	Patrol/Test/Inspect		VI
132429475	Q36410	08/30/2013	22:46	08/31/2013	3:46	1	300	300	Tree related-tree contact	Overhead Service	Tie/Tighten	Disconnect	I
132429468	L82187	08/30/2013	22:58	08/31/2013	3:44	1	286	286	Tree related-tree broken	Overhead Primary			IV
132429470	L43153	08/30/2013	23:03	08/31/2013	0:03	1	60	60	Weather	Fuse	Replace - Same Size		I
132429458	D37001	08/30/2013	23:25	08/31/2013	3:05	13	2860	220	Tree related-tree contact	Overhead Secondary	Patrol/Test/Inspect	Repair	I
132429480	F22001	08/30/2013	23:30	08/31/2013	1:15	1	105	105	Weather	Fuse	Replace - Same Size		IV
132430021	M19222	08/31/2013	0:12	08/31/2013	4:46	6	1644	274	Tree related-tree contact	Fuse		Replace - Same Size	VI
132430035	L79180	08/31/2013	0:35	08/31/2013	2:11	30	2880	96	Overhead equipment	Fuse			IV
132430039	Q32170	08/31/2013	0:38	08/31/2013	4:20	402	89244	222	Tree related-tree broken	Overhead Primary	Repair	Patrol/Test/Inspect	I
132430045	Q32170	08/31/2013	0:46	08/31/2013	4:45	1	239	239	Overhead equipment	Overhead Primary	No Work Required	No Work Required	I
132430047		08/31/2013	0:47	08/31/2013	4:45	1	238	238	Tree related-tree broken	Overhead Primary	Repair	Patrol/Test/Inspect	I
132430086	S64502	08/31/2013	0:47	08/31/2013	2:00	180	13140	73	Substation equipment	Lightning Arrestor			VI
132430053	R95520	08/31/2013	1:00	08/31/2013	7:32	1	392	392	Overhead equipment	Overhead Service	Repair		I
132430056	N70331	08/31/2013	1:06	08/31/2013	1:57	4	204	51	Animal related	Transformer Fuse	Replace - Same Size	Replace - Same Size	I
132430108	J79305	08/31/2013	2:56	08/31/2013	5:24	1	148	148	Animal related	Fuse	Replace - Same Size		I
132430131	B73003	08/31/2013	3:28	08/31/2013	5:00	1	92	92	Animal related	Fuse			I
132430150	D89003	08/31/2013	3:32	08/31/2013	11:00	5	2240	448	Underground equipment	Underground Primary	Repair		I
132430134	D89003	08/31/2013	3:32	08/31/2013	6:12	8	1280	160	Underground equipment	Underground Primary	Switch/Reset	Repair	I
132430141	R10925	08/31/2013	3:38	08/31/2013	7:14	9	1944	216	Tree related-tree broken	Overhead Secondary	Repair	Repair	VI
132430140	Q37370	08/31/2013	5:22	08/31/2013	7:06	1	104	104	Tree related-tree contact	Fuse	Replace - Same Size	Repair	I
132430157	A85002	08/31/2013	6:40	08/31/2013	13:15	1	395	395	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
132430192	H00163	08/31/2013	6:40	08/31/2013	8:01	17	1377	81	Overhead equipment				III
132430159	Q54908	08/31/2013	6:42	08/31/2013	7:20	1	38	38	Animal related	Fuse	Replace - Same Size		VI
132430161	Q37370	08/31/2013	7:04	08/31/2013	7:23	1	19	19	Tree related-tree contact	Lightning Arrestor	Replace - Same Size	Repair	I
132430169	R50910	08/31/2013	7:08	08/31/2013	20:22	8	6352	794	Tree related-tree contact	Overhead Service			I
132430171	J88165	08/31/2013	7:10	08/31/2013	10:02	1	172	172	Overhead equipment	Meter		No Work Required	VI
132430179	B58001	08/31/2013	7:26	08/31/2013	7:48	12	264	22	Animal related	Fuse	Replace - Same Size		I
132430183	R95520	08/31/2013	7:31	08/31/2013	11:38	1	247	247	Weather	Transformer Fuse	Patrol/Test/Inspect		I
132430186	Q37370	08/31/2013	7:34	08/31/2013	12:05	8	2168	271	Tree related-tree contact	Customer Equipment	No Work Required	No Work Required	I
132430261	Y07577	08/31/2013	8:14	08/31/2013	9:06	1	52	52	Animal related	Transformer Fuse	Replace - Same Size		IV
132430297	B57001	08/31/2013	8:29	08/31/2013	10:05	21	2016	96	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	I
132430478	K09863	08/31/2013	9:01	08/31/2013	10:28	215	18705	87	Overhead equipment	Overhead Primary			V
132430378	K09863	08/31/2013	9:01	08/31/2013	13:00	527	125953	239	Overhead equipment	Overhead Primary			V
132430377	N44215	08/31/2013	9:01	08/31/2013	11:45	27	4428	164	Underground equipment	Underground Primary			III
132430376	P20913	08/31/2013	9:09	08/31/2013	10:30	1	81	81	Animal related	Fuse	Replace - Same Size	No Work Required	VI
132430396	P20913	08/31/2013	9:10	08/31/2013	10:30	42	3360	80	Animal related	Fuse	Replace - Same Size	No Work Required	VI
132430381	U06551	08/31/2013	9:12	08/31/2013	11:42	1	150	150	Animal related	Transformer Fuse	Replace - Same Size	Patrol/Test/Inspect	II
132430439	X02548	08/31/2013	9:53	08/31/2013	10:43	2	100	50	Overhead equipment	Fuse	Replace - Same Size		IV
132430486	303006	08/31/2013	10:30	08/31/2013	12:41	1	131	131	Tree related-tree broken	Overhead Service	Repair	Replace - New Size	VI
132430502	K09863	08/31/2013	10:38	08/31/2013	13:24	1	166	166	Overhead equipment	Overhead Primary	Replace - New Size	Replace - New Size	V
132430577	N18211	08/31/2013	11:42	08/31/2013	13:09	1	87	87	Tree related-tree broken	Overhead Service			III
132430612	324002	08/31/2013	12:18	08/31/2013	14:45	35	5145	147	Overhead equipment	Overhead Primary	Repair		VI
132430610	Q36412	08/31/2013	12:19	08/31/2013	13:38	1	79	79	Weather	Transformer Fuse	Replace - Same Size	Repair	I
132430621	D16002	08/31/2013	12:21	08/31/2013	16:12	3	693	231	Underground equipment	Underground Primary	Patrol/Test/Inspect	Switch/Reset	I
132430664	D28123	08/31/2013	12:49	08/31/2013	15:00	1	131	131	Tree related-tree broken	Overhead Primary	Raise	No Work Required	I
132430820	K08909	08/31/2013	13:00	08/31/2013	14:37	394	38218	97	Overhead equipment	Overhead Primary	Switch/Reset		VI
132430703	K08909	08/31/2013	13:02	08/31/2013	14:40	96	9408	98	Overhead equipment	Recloser			VI
132430689	U30003	08/31/2013	13:05	08/31/2013	13:51	10	460	46	Overhead equipment	Transformer Fuse	Repair	Repair	II
132430701	L35282	08/31/2013	13:08	08/31/2013	14:20	1	72	72	Overhead equipment	Connector	Replace - Same Size		III
132430709	D28123	08/31/2013	13:11	08/31/2013	15:00	1	109	109	Tree related-tree broken	Overhead Primary	Raise	No Work Required	I
132430713	K09863	08/31/2013	13:15	08/31/2013	13:51	1	36	36	Overhead equipment				V
132430745	V74003	08/31/2013	13:25	08/31/2013	15:48	10	1430	143	Overhead equipment	Fuse	Replace - Same Size		II
132430730	Q82907	08/31/2013	13:27	08/31/2013	14:05	10	380	38	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	VI
132430732	V74003	08/31/2013	13:28	08/31/2013	16:16	6	1008	168	Overhead equipment	Transformer Fuse	Replace - Same Size	Repair	II
132430743	U29001	08/31/2013	13:34	08/31/2013	19:24	5	1750	350	Underground equipment	Underground Secondary	Patrol/Test/Inspect	Repair	II
132430741	J82106	08/31/2013	13:34	08/31/2013	14:10	1	36	36	Overhead equipment	Customer Equipment	No Work Required	No Work Required	VI
132430746	Q37370	08/31/2013	13:35	08/31/2013	15:04	1	89	89	Overhead equipment	Connector	Replace - Same Size	Repair	I
132430781	Q37370	08/31/2013	14:06	08/31/2013	15:45	1	99	99	Tree related-tree contact	Fuse	Replace - Same Size	Repair	I
132430796	L81141	08/31/2013	14:27	08/31/2013	15:34	1	67	67	Tree related-tree broken	Fuse	Replace - Same Size		IV
132430847	V74003	08/31/2013	15:13	08/31/2013	18:03	8	1360	170	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - New Size	II
132430925	M07235	08/31/2013	15:25	08/31/2013	20:22	81	24057	297	Public				III
132430886	M07235	08/31/2013	15:26	08/31/2013	16:28	268	16616	62	Public				III
132431053	D70006	08/31/2013	15:39	08/31/2013	22:53	1	434	434	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
132430891	D70006	08/31/2013	15:39	08/31/2013	17:40	2	242	121	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
132430912	H01192	08/31/2013	15:56	08/31/2013	17:02	1	66	66	Overhead equipment	Transformer Fuse	Repair		III
132430916	X75512	08/31/2013	16:03	08/31/2013	17:43	2	200	100	Weather	Transformer Fuse	Replace - Same Size		IV
132430928	K74164	08/31/2013	16:16	08/31/2013	17:40	7	588	84	Animal related	Fuse			IV
132430932	R60552	08/31/2013	16:20	08/31/2013	18:24	1	124	124	Unknown	Fuse			IV
132430940	S22595	08/31/2013	16:26	08/31/2013	17:52	1	86	86	Animal related	Fuse	Replace - New Size		VI
132430949	H10843	08/31/2013	16:33	08/31/2013	17:40	55	3685	67	Animal related	Fuse	Replace - Same Size		V
132430937	U66524	08/31/2013	16:34	08/31/2013	17:44	20	1400	70	Tree related-tree broken	Fuse	Replace - Same Size		II
132430947	X72536	08/31/2013	16:36	08/31/2013	21:18	1	282	282	Overhead equipment	Pole	Replace - New Size		IV
132430974	G50002	08/31/2013	17:05	08/31/2013	17:46	2	82	41	Overhead equipment	Fuse	Patrol/Test/Inspect	Replace - Same Size	IV
132431003	M25144	08/31/2013	17:33	09/01/2013	3:51	1	618	618	Overhead equipment	Crossarm	Replace - Same Size	No Work Required	IV
132431026	F22001	08/31/2013	17:38	08/31/2013	21:10	100	21200	212	Tree related-tree broken	Overhead Primary	Patrol/Test/Inspect	Repair	IV
132431085	R20501	08/31/2013	17:38	08/31/2013	21:14	11	2376	216	Tree related-tree broken	Tree	Remove		IV
132431019	M25143	08/31/2013	17:44	09/01/2013	0:46	8	3376	422	Weather	Overhead Transformer		Replace - Same Size	IV

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
132431021	R20502	08/31/2013	17:46	08/31/2013	23:13	1	327	327	Tree related-tree broken				IV
132431041	F22001	08/31/2013	17:52	08/31/2013	22:16	19	5016	264	Weather	Fuse	Replace - Same Size		IV
132431039	D67002	08/31/2013	17:55	08/31/2013	22:49	2	588	294	Weather	Fuse	Replace - Same Size		IV
132431055	F22001	08/31/2013	18:03	08/31/2013	22:10	1	247	247	Tree related-tree broken	Overhead Primary	No Work Required	Patrol/Test/Inspect	IV
132431156	Q74149	08/31/2013	18:04	09/01/2013	3:50	135	79110	586	Tree related-tree broken	Overhead Primary			IV
132431321	D66002	08/31/2013	18:05	08/31/2013	21:37	30	6360	212	Overhead equipment	Overhead Primary	Repair	No Work Required	IV
132431115	Q74148	08/31/2013	18:05	08/31/2013	22:24	25	6475	259	Tree related-tree contact	Fuse	Replace - Same Size		IV
132431063	D67001	08/31/2013	18:07	09/01/2013	3:02	1	535	535	Weather	Overhead Transformer		Replace - Same Size	IV
132431067	Y28598	08/31/2013	18:08	08/31/2013	20:40	40	6080	152	Weather	Fuse	Replace - Same Size		IV
132431070	Y28598	08/31/2013	18:09	08/31/2013	21:28	6	1194	199	Unknown	Transformer Fuse	Replace - Same Size		IV
132431069	J88164	08/31/2013	18:09	08/31/2013	20:36	1	147	147	Weather	Fuse	Replace - Same Size		VI
132431072	Y28598	08/31/2013	18:10	08/31/2013	21:48	1	218	218	Weather	Fuse	Replace - Same Size		IV
132431071	Z04002	08/31/2013	18:10	09/01/2013	2:51	5	2605	521	Tree related-tree broken	Tree	Remove	Advise Customer	IV
132431320	D66002	08/31/2013	18:11	08/31/2013	22:13	25	6050	242	Overhead equipment	Overhead Primary	Repair	No Work Required	IV
132431076	Y05002	08/31/2013	18:13	08/31/2013	19:25	1	72	72	Tree related-tree broken	Overhead Secondary	Repair		IV
132431081	M45212	08/31/2013	18:17	08/31/2013	23:41	13	4212	324	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
132431086	K39153	08/31/2013	18:22	08/31/2013	20:45	1	143	143	Overhead equipment	Meter	Replace - New Size		III
132431098	309139	08/31/2013	18:26	08/31/2013	18:44	1	18	18	Overhead equipment				V
132431359	Q74149	08/31/2013	18:28	08/31/2013	22:50	25	6550	262	Overhead equipment	Overhead Primary	Repair		IV
132431351	M45211	08/31/2013	18:32	09/01/2013	5:00	9	5652	628	Tree related-tree contact	Tree			IV
132432411	Q74149	08/31/2013	18:45	09/01/2013	0:08	24	7752	323	Tree related-tree broken	Overhead Primary			IV
132431137	Q74149	08/31/2013	18:49	09/01/2013	1:34	2	810	405	Tree related-tree broken	Overhead Service	Repair		IV
132431145	Y51505	08/31/2013	18:51	08/31/2013	21:55	1	184	184	Tree related-tree broken	Overhead Secondary	Repair		IV
132431257	Y28597	08/31/2013	18:52	08/31/2013	23:58	32	9792	306	Overhead equipment	Overhead Primary	Patrol/Test/Inspect	Repair	IV
132431282	Z18553	08/31/2013	18:52	08/31/2013	20:50	135	15930	118	Tree related-tree broken	Overhead Primary	Trim		IV
132431218	Z18553	08/31/2013	18:52	08/31/2013	21:00	96	12288	128	Tree related-tree broken	Tree	Repair		IV
132431159	M45212	08/31/2013	18:53	09/01/2013	1:25	1	392	392	Tree related-tree broken	Tree	Remove		IV
132431189	Z18553	08/31/2013	19:01	08/31/2013	20:40	30	2970	99	Tree related-tree broken	Tree	Repair		IV
132431198		08/31/2013	19:06	08/31/2013	22:17	2	382	191	Tree related-tree broken	Pole	Cut in Clear		IV
132431342	M45211	08/31/2013	19:11	08/31/2013	23:19	9	2232	248	Tree related-tree broken	Tree	Remove		IV
132432230	Q37370	08/31/2013	19:16	08/31/2013	23:34	35	9030	258	Overhead equipment	Transformer Fuse	Replace - Same Size	No Work Required	I
132431239	P12290	08/31/2013	19:23	08/31/2013	20:44	1	81	81	Weather	Transformer Fuse	Replace - Same Size		V
132431304	R60551	08/31/2013	19:35	09/01/2013	2:08	1	393	393	Weather	Overhead Transformer		Replace - Same Size	IV
132431313	U06524	08/31/2013	19:39	08/31/2013	22:46	1	187	187	Tree related-tree contact	Overhead Service	Repair		II
132431319	M45211	08/31/2013	19:41	08/31/2013	23:20	1	219	219	Overhead equipment	Fuse	Replace - Same Size		IV
132431380	M18216	08/31/2013	19:47	08/31/2013	22:32	44	7260	165	Overhead equipment	Fuse	Repair		III
132431371	Z18553	08/31/2013	19:55	08/31/2013	21:01	1	66	66	Tree related-tree broken	Tree	Repair		IV
132431389	Y28596	08/31/2013	19:57	09/01/2013	0:10	1	253	253	Overhead equipment	Disconnect Switch	Replace - New Size		IV
132431449	D67001	08/31/2013	20:03	09/01/2013	3:20	1	437	437	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	IV
132432420	R23333	08/31/2013	20:10	09/01/2013	0:50	5	1400	280	Tree related-tree contact	Overhead Primary		Repair	V
132431595	X88507	08/31/2013	20:13	08/31/2013	22:59	1	166	166	Tree related-tree broken	Overhead Secondary	Repair		IV
132431604	M25144	08/31/2013	20:14	09/01/2013	13:55	1	1061	1061	Tree related-tree contact	Overhead Service			IV
132431865	N15850	08/31/2013	20:23	09/01/2013	1:11	116	33408	288	Tree related-tree broken	Overhead Primary			V
132431821	341001	08/31/2013	20:25	08/31/2013	21:50	23	1955	85	Weather	Fuse	Repair		VI
132431831	N15850	08/31/2013	20:26	09/01/2013	3:00	6	2364	394	Tree related-tree contact	Overhead Primary	Patrol/Test/Inspect	Repair	V
132431734	P71830	08/31/2013	20:27	09/01/2013	1:17	1	290	290	Tree related-tree broken	Overhead Service	Cut in Clear	Repair	V
132432237	N15850	08/31/2013	20:31	09/01/2013	4:33	7	3374	482	Tree related-tree broken	Overhead Primary	Cut in Clear	Cut in Clear	V
132431843	N15850	08/31/2013	20:33	09/01/2013	2:31	51	18258	358	Tree related-tree broken	Overhead Primary	Cut in Clear		V
132431925	N15849	08/31/2013	20:36	09/01/2013	3:47	43	18533	431	Tree related-tree contact	Fuse	Replace - Same Size	Replace - Same Size	V
132432205	J18268	08/31/2013	20:42	08/31/2013	22:42	324	38880	120	Weather	Recloser		Patrol/Test/Inspect	VI
132431883	308001	08/31/2013	20:46	09/01/2013	0:27	1	221	221	Tree related-tree broken	Tree			VI
132431972	J99121	08/31/2013	20:46	09/01/2013	0:58	13	3276	252	Weather	Overhead Primary	Patrol/Test/Inspect		VI
132431892	P71830	08/31/2013	20:48	09/01/2013	0:13	1	205	205	Tree related-tree contact	Overhead Transformer	Switch/Reset	No Work Required	V
132432253	N15850	08/31/2013	20:48	09/01/2013	0:19	107	22577	211	Tree related-tree contact	Overhead Primary	Cut in Clear	Cut in Clear	V
132431290	Q74148	08/31/2013	20:49	09/01/2013	4:25	5	2280	456	Overhead equipment	Pole			IV
132431906	K15205	08/31/2013	20:50	09/01/2013	4:14	2	888	444	Tree related-tree broken	Overhead Service	Repair		VI

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
132432045	J85161	08/31/2013	20:51	08/31/2013	23:37	122	20252	166	Weather	Overhead Primary	Patrol/Test/Inspect		VI
132432061	K80382	08/31/2013	20:53	08/31/2013	20:59	8	48	6	Weather	Transformer Fuse	Replace - New Size		IV
132431932	337001	08/31/2013	20:54	09/01/2013	0:40	1	226	226	Tree related-tree broken	Overhead Primary	Patrol/Test/Inspect		VI
132431955	P71830	08/31/2013	20:56	09/01/2013	6:00	1	544	544	Weather	Fuse	Replace - Same Size	No Work Required	V
132431958	345002	08/31/2013	20:57	09/01/2013	2:10	1	313	313	Tree related-tree broken	Tree	Patrol/Test/Inspect		VI
132431996	L93132	08/31/2013	20:57	09/01/2013	0:25	261	54288	208	Weather	Jumper	Patrol/Test/Inspect	Repair	VI
132432149	K01240	08/31/2013	20:58	09/01/2013	4:19	11	4851	441	Tree related-tree broken	Overhead Primary	Patrol/Test/Inspect		VI
132432031	L93135	08/31/2013	20:59	09/01/2013	0:33	16	3424	214	Weather	Jumper	Patrol/Test/Inspect	Repair	VI
132431988	K15207	08/31/2013	21:00	09/01/2013	6:16	11	6116	556	Weather	Transformer Fuse		Promise to Pay	VI
132432004	337001	08/31/2013	21:02	08/31/2013	23:24	1	142	142	Overhead equipment	Fuse	Replace - Same Size		VI
132432005	337002	08/31/2013	21:02	09/01/2013	3:30	11	4268	388	Tree related-tree broken	Overhead Secondary	Patrol/Test/Inspect		VI
132432019	R09225	08/31/2013	21:04	08/31/2013	23:00	1	116	116	Overhead equipment	Overhead Primary		Replace - Same Size	III
132432018	332004	08/31/2013	21:04	09/01/2013	1:50	1	286	286	Tree related-tree broken	Overhead Service	Repair		VI
132432033	J84145	08/31/2013	21:07	09/01/2013	1:30	4	1052	263	Tree related-tree broken	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
132432054	337001	08/31/2013	21:12	09/02/2013	6:14	1	1982	1982	Tree related-tree broken	Tree	Patrol/Test/Inspect		VI
132432057	345002	08/31/2013	21:13	08/31/2013	23:00	1	107	107	Tree related-tree broken	Overhead Service	Cut in Clear	Replace - Same Size	VI
132432079	Q74150	08/31/2013	21:20	08/31/2013	23:32	4	528	132	Tree related-tree broken				IV
132432089	T46001	08/31/2013	21:23	09/01/2013	0:50	10	2070	207	Overhead equipment	Other	Repair		VI
132440123	Q63835	08/31/2013	21:24	09/01/2013	8:26	269	178078	662	Overhead equipment				V
132432201	Q63835	08/31/2013	21:24	09/01/2013	7:07	13	7579	583	Tree related-tree broken	Overhead Primary	Repair	No Work Required	V
132432140	Q63835	08/31/2013	21:25	09/01/2013	7:59	194	122996	634	Tree related-tree broken	Overhead Primary	Repair		V
132432138	Q63835	08/31/2013	21:25	09/01/2013	1:40	382	97410	255	Overhead equipment				V
132432107	P71830	08/31/2013	21:26	09/01/2013	4:58	1	452	452	Tree related-tree contact	Overhead Transformer	Switch/Reset	No Work Required	V
132432154	X66580	08/31/2013	21:35	09/01/2013	0:28	1	173	173	Tree related-tree broken	Overhead Primary	Repair		IV
132432164		08/31/2013	21:39	09/01/2013	0:17	1	158	158	Overhead equipment	Overhead Transformer	Switch/Reset	No Work Required	V
132440035	P71830	08/31/2013	21:50	09/01/2013	1:20	24	5040	210	Overhead equipment	Fuse	Replace - Same Size	No Work Required	V
132432212	N14879	08/31/2013	21:56	09/01/2013	5:23	1	447	447	Tree related-tree contact	Overhead Service	No Work Required	No Work Required	V
132432216	Y26520	08/31/2013	21:57	09/01/2013	3:47	1	350	350	Overhead equipment	Overhead Service	Repair	No Work Required	IV
132432217	Q18244	08/31/2013	21:57	09/01/2013	8:25	2	1256	628	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	VI
132432220	Y51505	08/31/2013	21:58	09/01/2013	0:20	1	142	142	Tree related-tree broken	Overhead Service	Cut in Clear		IV
132432218	R20502	08/31/2013	21:58	08/31/2013	22:52	1	54	54	Tree related-tree broken	Tree	Remove		IV
132432224	Y06544	08/31/2013	21:59	09/01/2013	1:05	1	186	186	Tree related-tree broken	Overhead Service	Repair		IV
132432290	K26136	08/31/2013	22:01	08/31/2013	23:20	4	316	79	Weather	Fuse	Repair	Repair	VI
132432270	Q85162	08/31/2013	22:12	09/01/2013	2:15	1	243	243	Weather	Transformer Fuse	Replace - Same Size	Replace - Same Size	VI
132432317	J34377	08/31/2013	22:28	09/01/2013	3:48	65	20800	320	Tree related-tree contact				V
132432343	R41132	08/31/2013	22:38	09/01/2013	1:11	1	153	153	Weather	Fuse	Replace - Same Size	Replace - Same Size	VI
132432350	B25002	08/31/2013	22:40	09/01/2013	4:40	1	360	360	Underground equipment	Underground Primary	Repair	Repair	I
132432374	Q83148	08/31/2013	22:54	08/31/2013	23:58	1	64	64	Tree related-tree broken	Overhead Service	Replace - Same Size	Replace - Same Size	VI
132432380	P12290	08/31/2013	23:00	09/01/2013	1:22	3	426	142	Weather	Fuse	Replace - Same Size		V
132432394	X96524	08/31/2013	23:04	09/01/2013	0:55	70	7770	111	Weather	Fuse	Replace - Same Size	No Work Required	IV
132440038	X31730	08/31/2013	23:24	09/01/2013	1:40	1175	159800	136	Animal related				IV
132440039	X34531	08/31/2013	23:24	09/01/2013	0:25	932	56852	61	Animal related				IV
132432422	X29547	08/31/2013	23:26	09/01/2013	0:25	1	59	59	Animal related	Substation Breaker	Switch/Reset		IV
132440006	J85161	09/01/2013	0:01	09/01/2013	5:11	1	310	310	Overhead equipment	Transformer Fuse	Replace - Same Size		VI
132440152	S78551	09/01/2013	0:02	09/01/2013	8:40	11	5698	518	Underground equipment	Underground Primary		Repair	VI
132440001	Q74149	09/01/2013	0:04	09/01/2013	1:23	1	79	79	Tree related-tree broken	Overhead Service	Replace - Same Size		IV
132440025	349001	09/01/2013	0:15	09/01/2013	2:22	1	127	127	Overhead equipment	Overhead Secondary	Repair		VI
132440057	X34531	09/01/2013	0:47	09/01/2013	2:24	1	97	97	Animal related	Fuse	Replace - Same Size		IV
132440063	L93132	09/01/2013	0:57	09/01/2013	2:17	48	3840	80	Tree related-tree broken	Overhead Primary	Patrol/Test/Inspect		VI
132440072	S78551	09/01/2013	1:04	09/01/2013	1:35	425	13175	31	Overhead equipment				VI
132440170	S78551	09/01/2013	1:34	09/01/2013	2:45	648	46008	71	Underground equipment	Underground Primary			VI
132440222	A91002	09/01/2013	1:59	09/01/2013	7:25	2	652	326	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
132440150	A91002	09/01/2013	2:08	09/01/2013	3:25	44	3388	77	Underground equipment	Underground Primary	Switch/Reset	No Work Required	I
132440204	N15850	09/01/2013	3:00	09/01/2013	13:00	1	600	600	Overhead equipment	Pole	Repair		V
132440213	S78551	09/01/2013	3:07	09/01/2013	3:15	647	5176	8	Underground equipment	Underground Primary			VI
132440228	X23516	09/01/2013	3:54	09/01/2013	5:40	1	106	106	Weather	Substation Breaker	Switch/Reset	Switch/Reset	IV

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
132440506	J85161	09/01/2013	5:02	09/01/2013	12:25	6	2658	443	Tree related-tree broken	Tree	Patrol/Test/Inspect	Trim	VI
132440512	N15850	09/01/2013	5:19	09/01/2013	6:08	1	49	49	Tree related-tree contact	Transformer Fuse	Replace - Same Size	Replace - Same Size	V
132440525	Y51505	09/01/2013	6:16	09/01/2013	8:20	1	124	124	Tree related-tree broken	Overhead Secondary	Repair		IV
132440531	N15850	09/01/2013	6:34	09/01/2013	6:46	1	12	12	Tree related-tree broken	Overhead Primary	Cut in Clear	Cut in Clear	V
132440533	Q63835	09/01/2013	6:37	09/01/2013	10:21	1	224	224	Tree related-tree broken			No Work Required	V
132440539		09/01/2013	6:44	09/01/2013	9:00	1	136	136	Tree related-tree broken	Overhead Service	Replace - Same Size	Repair	VI
132440550	Q63835	09/01/2013	6:50	09/01/2013	12:19	1	329	329	Tree related-tree broken	Overhead Service	Repair		V
132440572	M41112	09/01/2013	7:12	09/01/2013	8:21	1	69	69	Animal related	Transformer Fuse	Replace - Same Size		I
132440590	Y51505	09/01/2013	7:20	09/01/2013	10:00	1	160	160	Tree related-tree broken	Overhead Secondary	Repair		IV
132440592	N15850	09/01/2013	7:20	09/01/2013	7:28	1	8	8	Tree related-tree contact	Overhead Primary	Cut in Clear	Cut in Clear	V
132440589	P71830	09/01/2013	7:20	09/01/2013	11:02	1	222	222	Tree related-tree broken	Overhead Service	Replace - Same Size	Replace - Same Size	V
132440596	J34377	09/01/2013	7:23	09/01/2013	8:32	8	552	69	Animal related	Fuse	Replace - Same Size	Replace - Same Size	V
132440602	Q63835	09/01/2013	7:25	09/01/2013	8:30	1	65	65	Tree related-tree broken			No Work Required	V
132440599	N15850	09/01/2013	7:25	09/01/2013	7:34	1	9	9	Tree related-tree broken	Overhead Primary	Cut in Clear	Cut in Clear	V
132440625	Q63835	09/01/2013	7:44	09/01/2013	8:32	1	48	48	Tree related-tree broken			No Work Required	V
132440698	N15850	09/01/2013	7:45	09/01/2013	13:19	7	2338	334	Tree related-tree broken	Overhead Primary	Repair	No Work Required	V
132440631	Y37592	09/01/2013	7:46	09/01/2013	14:55	5	2145	429	Animal related	Transformer Fuse	Replace - Same Size		IV
132440653	Q63835	09/01/2013	7:53	09/01/2013	8:34	1	41	41	Tree related-tree broken			No Work Required	V
132440703	N15849	09/01/2013	8:15	09/01/2013	9:27	1	72	72	Tree related-tree contact	Overhead Service	Repair	Repair	V
132440708	F22001	09/01/2013	8:17	09/01/2013	9:33	1	76	76	Weather	Transformer Fuse	Replace - Same Size		IV
132440721	H07106	09/01/2013	8:26	09/01/2013	9:33	1	67	67	Weather	Transformer Fuse			IV
132440731	D01001	09/01/2013	8:33	09/01/2013	13:42	1	309	309	Underground equipment	Underground Primary		Repair	I
132440758	N15850	09/01/2013	8:48	09/01/2013	11:23	1	155	155	Tree related-tree broken	Overhead Primary	Repair	No Work Required	V
132440771	K07322	09/01/2013	8:58	09/01/2013	10:22	1	84	84	Animal related	Transformer Fuse	Replace - Same Size		I
132440812	Q32171	09/01/2013	9:17	09/01/2013	10:05	1	48	48	Animal related	Transformer Fuse	Replace - Same Size	Patrol/Test/Inspect	I
132440823	X96543	09/01/2013	9:27	09/01/2013	11:10	1	103	103	Tree related-tree broken	Overhead Service	Raise	No Work Required	IV
132440834	Y93002	09/01/2013	9:33	09/01/2013	10:00	3	81	27	Overhead equipment	Transformer Fuse	Repair	Replace - Same Size	IV
132440903	Q64939	09/01/2013	10:07	09/01/2013	11:19	4	288	72	Animal related	Fuse	Replace - Same Size		VI
132441002	D32211	09/01/2013	10:22	09/01/2013	12:17	295	33925	115	Tree related-tree broken	Tree	Remove		I
132440996	X34530	09/01/2013	10:23	09/01/2013	11:18	1	55	55	Animal related	Transformer Fuse	Replace - Same Size		IV
132441128	Q06142	09/01/2013	11:26	09/01/2013	12:25	1	59	59	Unknown	Transformer Fuse			IV
132441146	D88002	09/01/2013	11:35	09/01/2013	12:22	39	1833	47	Animal related	Other			I
132441153	P26283	09/01/2013	11:43	09/01/2013	14:24	1	161	161	Underground equipment	Underground Service			I
132441211	M09144	09/01/2013	12:04	09/01/2013	13:40	29	2784	96	Overhead equipment	Overhead Primary	Replace - Same Size	Repair	VI
132441235	D36002	09/01/2013	12:21	09/01/2013	12:55	1	34	34	Animal related	Fuse	Replace - Same Size		I
132441254	Q01281	09/01/2013	12:26	09/01/2013	16:40	17	4318	254	Underground equipment	Underground Primary	Patrol/Test/Inspect	Switch/Reset	III
132440594	X02548	09/01/2013	12:58	09/01/2013	15:25	1	147	147	Tree related-tree broken	Overhead Primary	Replace - Same Size		IV
132441375	D66004	09/01/2013	13:17	09/01/2013	15:19	1	122	122	Tree related-tree broken	Overhead Service	Repair		IV
132441633	338003	09/01/2013	13:26	09/01/2013	14:49	10	830	83	Overhead equipment	Overhead Primary	Repair		VI
132441410	T03582	09/01/2013	13:44	09/01/2013	14:50	1	66	66	Animal related	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
132441512	HB6281	09/01/2013	14:10	09/01/2013	19:59	54	18846	349	Tree related-tree broken	Overhead Primary	Patrol/Test/Inspect	Repair	VI
132441527	B80004	09/01/2013	14:13	09/01/2013	15:25	1	72	72	Overhead equipment	Connector	Repair		I
132441659	P77233	09/01/2013	14:13	09/01/2013	15:21	540	36720	68	Overhead equipment	Recloser	Switch/Reset		VI
132441681	307001	09/01/2013	14:20	09/01/2013	20:15	26	9230	355	Tree related-tree broken	Overhead Primary	Repair		VI
132441611	307003	09/01/2013	14:20	09/02/2013	1:00	49	31360	640	Tree related-tree broken	Overhead Service	Patrol/Test/Inspect		VI
132441590	307003	09/01/2013	14:23	09/01/2013	16:46	1	143	143	Tree related-tree broken	Other			VI
132441605	307002	09/01/2013	14:25	09/01/2013	22:26	1	481	481	Tree related-tree broken	Tree	Patrol/Test/Inspect		VI
132441642	307005	09/01/2013	14:25	09/01/2013	20:00	31	10385	335	Tree related-tree broken	Overhead Primary	Repair	Repair	VI
132441679	342003	09/01/2013	14:25	09/01/2013	17:30	23	4255	185	Overhead equipment	Fuse	Replace - Same Size		VI
132441622	307002	09/01/2013	14:28	09/02/2013	1:20	1	652	652	Tree related-tree broken	Tree	Patrol/Test/Inspect	Repair	VI
132442091	M78323	09/01/2013	14:29	09/01/2013	21:20	10	4110	411	Overhead equipment	Overhead Transformer	Cut in Clear	Replace - Same Size	V
132441641	M78323	09/01/2013	14:29	09/01/2013	18:00	28	5908	211	Weather	Fuse	Replace - Same Size		V
132441660	P77235	09/01/2013	14:29	09/01/2013	22:51	36	18072	502	Tree related-tree contact	Overhead Primary	Patrol/Test/Inspect	Repair	VI
132441645	307001	09/01/2013	14:30	09/01/2013	16:36	4	504	126	Tree related-tree broken	Fuse	Patrol/Test/Inspect		VI
132441684	M78323	09/01/2013	14:31	09/01/2013	18:35	43	10492	244	Weather	Fuse	Replace - Same Size		V
132441655		09/01/2013	14:33	09/01/2013	16:33	1	120	120	Tree related-tree broken	Overhead Secondary	Repair		VI

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
132441662	J88163	09/01/2013	14:34	09/01/2013	17:51	1	197	197	Weather	Fuse	Replace - Same Size		VI
132441747	M19222	09/01/2013	14:34	09/01/2013	19:05	33	8943	271	Tree related-tree contact	Overhead Primary	Patrol/Test/Inspect	Repair	VI
132441668	J99141	09/01/2013	14:35	09/01/2013	21:39	1	424	424	Weather	Overhead Transformer			VI
132441680	307003	09/01/2013	14:37	09/01/2013	16:15	1	98	98	Tree related-tree broken				VI
132442003	342003	09/01/2013	14:38	09/01/2013	20:15	14	4718	337	Tree related-tree contact	Overhead Secondary	Trim		VI
132442110	307004	09/01/2013	14:41	09/01/2013	18:35	115	26910	234	Tree related-tree contact	Overhead Primary			VI
132441774	307004	09/01/2013	14:41	09/01/2013	18:16	554	119110	215	Tree related-tree contact	Tree			VI
132441698	M19222	09/01/2013	14:42	09/01/2013	17:07	1	145	145	Overhead equipment	Other	Patrol/Test/Inspect		VI
132441706	325008	09/01/2013	14:43	09/01/2013	23:47	7	3808	544	Tree related-tree broken	Overhead Transformer	Switch/Reset		VI
132441837	M19222	09/01/2013	14:44	09/01/2013	17:07	9	1287	143	Tree related-tree contact	Fuse	Replace - Same Size		VI
132441942	V82002	09/01/2013	14:48	09/01/2013	17:40	3	516	172	Overhead equipment	Overhead Transformer	Replace - New Size		II
132441870	344002	09/01/2013	14:48	09/01/2013	19:22	6	1644	274	Weather	Fuse	Repair		VI
132441734	M19222	09/01/2013	14:48	09/01/2013	19:36	1	288	288	Overhead equipment	Fuse	Replace - Same Size		VI
132441738	Q18244	09/01/2013	14:49	09/01/2013	21:00	1	371	371	Tree related-tree broken	Overhead Service	Replace - Same Size		VI
132441750	M54314	09/01/2013	14:51	09/01/2013	23:40	1	529	529	Tree related-tree broken	Tree	Remove		V
132441876	J99128	09/01/2013	14:54	09/01/2013	17:05	23	3013	131	Weather	Fuse			VI
132441795	K43386	09/01/2013	14:54	09/01/2013	22:20	34	15164	446	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	V
132441801	A91001	09/01/2013	14:55	09/01/2013	17:45	64	10880	170	Underground equipment	Underground Primary	Patrol/Test/Inspect	Switch/Reset	I
132441780	Q95248	09/01/2013	14:55	09/01/2013	23:16	15	7515	501	Tree related-tree broken	Overhead Secondary	Patrol/Test/Inspect	Repair	VI
132442133	Q10702	09/01/2013	14:56	09/01/2013	19:46	3	870	290	Weather	Fuse	Replace - Same Size		V
132441825	HA5430	09/01/2013	14:56	09/02/2013	0:13	13	7241	557	Underground equipment	Underground Primary		Repair	V
132441847	K55397	09/01/2013	14:59	09/02/2013	1:02	15	9045	603	Weather	Overhead Transformer	Repair		V
132442171	325010	09/01/2013	15:00	09/01/2013	19:44	629	178636	284	Overhead equipment	Overhead Primary	Switch/Reset		VI
132441810	Q01281	09/01/2013	15:01	09/01/2013	15:34	1	33	33	Underground equipment	Underground Primary			III
132441977	M54314	09/01/2013	15:06	09/01/2013	16:45	38	3762	99	Tree related-tree contact				V
132441830	HA5430	09/01/2013	15:09	09/02/2013	0:56	2	1174	587	Weather	Transformer Fuse	Replace - Same Size		V
132441832	P73160	09/01/2013	15:09	09/01/2013	17:39	1	150	150	Weather	Fuse	Replace - Same Size		VI
132441834	M19222	09/01/2013	15:10	09/01/2013	17:34	1	144	144	Overhead equipment	Fuse	Replace - Same Size		VI
132442121	Q27185	09/01/2013	15:10	09/01/2013	20:00	23	6670	290	Tree related-tree broken	Overhead Primary	Repair		VI
132441841	307002	09/01/2013	15:14	09/02/2013	0:24	1	550	550	Tree related-tree broken	Overhead Service	Repair		VI
132441845	Q24313	09/01/2013	15:15	09/01/2013	19:12	1	237	237	Weather	Fuse			VI
132441853	M53312	09/01/2013	15:19	09/01/2013	18:48	1	209	209	Tree related-tree broken	Overhead Service	Repair	Repair	V
132441852	P73160	09/01/2013	15:19	09/01/2013	21:30	1	371	371	Overhead equipment	Overhead Transformer		Replace - Same Size	VI
132441914	344002	09/01/2013	15:21	09/01/2013	19:17	10	2360	236	Weather	Fuse	Patrol/Test/Inspect		VI
132442105	M54314	09/01/2013	15:23	09/01/2013	23:28	90	43650	485	Tree related-tree broken	Overhead Secondary	Patrol/Test/Inspect	Repair	V
132441883	K43382	09/01/2013	15:30	09/02/2013	3:16	1	706	706	Overhead equipment	Overhead Secondary	Patrol/Test/Inspect	Repair	V
132441886	P77233	09/01/2013	15:33	09/01/2013	19:06	1	213	213	Tree related-tree contact	Overhead Primary	Repair		VI
132441900	P77233	09/01/2013	15:44	09/01/2013	21:52	1	368	368	Tree related-tree contact	Overhead Primary	Patrol/Test/Inspect	Repair	VI
132441898	Q18245	09/01/2013	15:44	09/02/2013	1:56	1	612	612	Tree related-tree broken	Tree	Patrol/Test/Inspect	Replace - Same Size	VI
132441902	341001	09/01/2013	15:46	09/01/2013	21:20	10	3340	334	Tree related-tree broken	Tree	Remove		VI
132441910	341001	09/01/2013	15:53	09/01/2013	22:21	1	388	388	Tree related-tree broken	Overhead Service	Repair		VI
132441935	J18267	09/01/2013	16:07	09/01/2013	17:26	1	79	79	Weather	Fuse		Patrol/Test/Inspect	VI
132441936	Q28141	09/01/2013	16:08	09/01/2013	19:49	1	221	221	Tree related-tree contact	Overhead Primary	Replace - Same Size	Repair	VI
132441962	P47169	09/01/2013	16:15	09/01/2013	17:15	12	720	60	Other	Fuse	Replace - Same Size		I
132441948	P47169	09/01/2013	16:21	09/01/2013	17:15	1	54	54	Other	Fuse	Replace - Same Size		I
132442014	P57108	09/01/2013	16:23	09/02/2013	0:39	5	2480	496	Overhead equipment	Pole	Replace - Same Size		VI
132441953	P77235	09/01/2013	16:23	09/01/2013	19:18	1	175	175	Tree related-tree broken	Fuse	Replace - Same Size		VI
132442013	P57108	09/01/2013	16:23	09/01/2013	17:28	32	2080	65	Weather				VI
132442051	P20930	09/01/2013	16:26	09/01/2013	19:40	42	8148	194	Tree related-tree broken	Fuse		Repair	VI
132441967	Q27185	09/01/2013	16:32	09/01/2013	19:20	1	168	168	Tree related-tree broken	Overhead Transformer	Replace - Same Size	Replace - Same Size	VI
132441972	M21134	09/01/2013	16:34	09/01/2013	17:39	1	65	65	Weather	Fuse	Repair	Repair	VI
132441980	P47169	09/01/2013	16:41	09/01/2013	17:15	1	34	34	Other	Fuse	Replace - Same Size		I
132441982	M19222	09/01/2013	16:45	09/01/2013	23:29	1	404	404	Weather	Overhead Transformer	Replace - Same Size		VI
132441985	P73158	09/01/2013	16:48	09/01/2013	18:01	1	73	73	Weather	Transformer Fuse	Replace - Same Size		VI
132441992	334001	09/01/2013	16:50	09/01/2013	23:00	1	370	370	Tree related-tree broken	Overhead Service	Repair		VI
132442029	P39298	09/01/2013	17:17	09/01/2013	18:10	1	53	53	Weather	Fuse		Patrol/Test/Inspect	VI

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
132442045	M19222	09/01/2013	17:27	09/02/2013	4:46	2	1358	679	Tree related-tree contact	Pole	Disconnect	Replace - Same Size	VI
132442048	M21133	09/01/2013	17:31	09/01/2013	17:55	1	24	24	Weather	Transformer Fuse	Repair	Repair	VI
132442092	L95110	09/01/2013	18:03	09/01/2013	18:31	1	28	28	Overhead equipment	Overhead Service	Repair		III
132442150		09/01/2013	19:10	09/01/2013	20:27	1	77	77	Weather	Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
132442159	Q18245	09/01/2013	19:23	09/01/2013	20:21	1	58	58	Weather	Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
132442160	H00162	09/01/2013	19:25	09/01/2013	21:46	14	1974	141	Overhead equipment	Overhead Transformer		Repair	III
132442165	R49275	09/01/2013	19:29	09/01/2013	20:26	1	57	57	Weather	Transformer Fuse	Replace - Same Size		VI
132442170	M19222	09/01/2013	19:34	09/01/2013	19:56	1	22	22	Other				VI
132442214	325010	09/01/2013	19:44	09/02/2013	0:50	698	213588	306	Tree related-tree broken	Overhead Primary	Patrol/Test/Inspect	Repair	VI
132442209	N58144	09/01/2013	20:04	09/01/2013	22:30	1	146	146	Public	Crossarm	Repair	Replace - Same Size	I
132442220	308003	09/01/2013	20:13	09/02/2013	1:07	1	294	294	Tree related-tree broken	Overhead Service	Repair		VI
132442259	U92593	09/01/2013	21:04	09/01/2013	22:30	1	86	86	Overhead equipment	Transformer Fuse	Repair		II
132442287	K11376	09/01/2013	21:28	09/02/2013	10:00	6	4512	752	Underground equipment	Underground Primary		Repair	V
132442296	R05186	09/01/2013	21:42	09/02/2013	7:45	28	16884	603	Underground equipment	Underground Primary	Switch/Reset	Repair	I
132442342	Q80353	09/01/2013	23:17	09/02/2013	9:25	3	1824	608	Underground equipment	Underground Primary		Repair	V
132442291		09/02/2013	0:09	09/02/2013	2:15	1	126	126	Overhead equipment	Overhead Transformer		Repair	V
132450025	307003	09/02/2013	1:28	09/02/2013	4:27	33	5907	179	Overhead equipment				VI
132450031	A68001	09/02/2013	2:19	09/02/2013	12:07	1	588	588	Underground equipment	Underground Primary	Patrol/Test/Inspect	Replace - Urgent	I
132450044	K05253	09/02/2013	3:05	09/02/2013	4:44	4	396	99	Overhead equipment	Transformer Fuse	Repair	Repair	VI
132450063	V69532	09/02/2013	4:40	09/02/2013	6:10	1	90	90	Animal related	Fuse	Replace - Same Size		II
132450085	E05002	09/02/2013	5:02	09/02/2013	6:36	6	564	94	Underground equipment	Underground Primary			IV
132450069	E05002	09/02/2013	5:02	09/02/2013	7:20	45	6210	138	Underground equipment	Underground Primary		Repair	IV
132450142	K71821	09/02/2013	5:46	09/02/2013	9:36	9	2070	230	Underground equipment	Underground Primary	Switch/Reset	Repair	IV
132450079	S01558	09/02/2013	6:10	09/02/2013	7:35	1	85	85	Overhead equipment	Regulator			VI
132450220	J30201	09/02/2013	6:41	09/02/2013	9:02	9	1269	141	Overhead equipment	Fuse			VI
132450151	J30201	09/02/2013	6:41	09/02/2013	9:02	3	423	141	Weather	Fuse		Patrol/Test/Inspect	VI
132450099	D92001	09/02/2013	6:53	09/02/2013	9:15	93	13206	142	Unknown	Fuse	Replace - Same Size		I
132450126	Q95249	09/02/2013	7:26	09/02/2013	8:50	1	84	84	Animal related	Fuse			VI
132450143	M61302	09/02/2013	7:45	09/02/2013	8:44	1	59	59	Animal related	Transformer Fuse	Replace - Same Size	Replace - Same Size	V
132450172	K27153	09/02/2013	7:57	09/02/2013	9:00	2	126	63	Animal related	Transformer Fuse	Repair	Repair	VI
132450157	Q18245	09/02/2013	8:02	09/02/2013	9:00	22	1276	58	Animal related	Fuse			VI
132450160	X42502	09/02/2013	8:05	09/02/2013	9:15	1	70	70	Animal related	Transformer Fuse	Replace - Same Size		IV
132450167	B61001	09/02/2013	8:28	09/02/2013	9:00	1	32	32	Overhead equipment	Transformer Fuse	Replace - Same Size	No Work Required	I
132450174	U31542	09/02/2013	8:33	09/02/2013	9:05	7	224	32	Overhead equipment	Transformer Fuse	Repair	Repair	II
132450173	M05361	09/02/2013	8:33	09/02/2013	9:21	1	48	48	Animal related	Transformer Fuse	Replace - Same Size		V
132450184	K71821	09/02/2013	8:37	09/02/2013	8:43	28	168	6	Overhead equipment	Fuse	Replace - Same Size		IV
132450194	P52305	09/02/2013	8:50	09/02/2013	9:47	1	57	57	Weather	Transformer Fuse	Replace - Same Size		IV
132450199	P73157	09/02/2013	8:56	09/02/2013	9:52	1	56	56	Animal related	Fuse	Repair	Replace - Same Size	VI
132450202	S07535	09/02/2013	8:59	09/02/2013	10:15	1	76	76	Animal related	Disconnect Switch	Replace - Same Size		VI
132450222	J30201	09/02/2013	9:02	09/02/2013	14:04	1	302	302	Overhead equipment	Overhead Transformer	Replace - Same Size	Replace - Same Size	VI
132450219	P98193	09/02/2013	9:18	09/02/2013	9:43	1	25	25	Animal related	Transformer Fuse		Replace - Same Size	III
132450221	S27599	09/02/2013	9:21	09/02/2013	10:03	1	42	42	Animal related	Overhead Transformer	Switch/Reset		VI
132450438	Y23521	09/02/2013	9:34	09/02/2013	13:02	16	3328	208	Underground equipment	Underground Primary	Switch/Reset		IV
132450444	Y23521	09/02/2013	10:00	09/02/2013	14:38	8	2224	278	Underground equipment	Underground Transformer	Repair		IV
132450304	B71002	09/02/2013	10:19	09/02/2013	11:00	1	41	41	Overhead equipment	Connector	Replace - Same Size	No Work Required	I
132450322	Q74149	09/02/2013	10:30	09/03/2013	10:14	1	1424	1424	Tree related-tree broken	Overhead Service	Repair		IV
132450327	U31542	09/02/2013	10:33	09/02/2013	11:30	1	57	57	Overhead equipment	Other	Repair	Repair	II
132450342	S22595	09/02/2013	10:47	09/02/2013	12:12	1	85	85	Animal related	Disconnect Switch	Replace - Same Size		VI
132450347	K48380	09/02/2013	10:50	09/02/2013	12:04	1	74	74	Tree related-tree contact	Overhead Secondary	Repair	Repair	V
132450397	N93260	09/02/2013	12:13	09/02/2013	13:18	1	65	65	Overhead equipment	Transformer Fuse		Replace - Same Size	III
132450422	U86500	09/02/2013	12:46	09/02/2013	13:37	1	51	51	Overhead equipment	Overhead Primary	Repair	Repair	II
132450441	R65451	09/02/2013	13:01	09/02/2013	15:30	24	3576	149	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	IV
132450510	Y23521	09/02/2013	13:20	09/02/2013	20:21	4	1684	421	Underground equipment	Underground Primary	Repair		IV
132450457	U52516	09/02/2013	13:28	09/02/2013	19:20	1	352	352	Underground equipment	Underground Primary	Repair	Repair	II
132450458	U03001	09/02/2013	13:32	09/02/2013	15:10	1	98	98	Overhead equipment	Connector	Repair		II
132450464	U90566	09/02/2013	13:34	09/02/2013	14:31	1	57	57	Overhead equipment	Transformer Fuse	Repair	Repair	II

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
132450469	S83533	09/02/2013	13:38	09/02/2013	15:25	1	107	107	Overhead equipment				VI
132450474	B68002	09/02/2013	13:45	09/02/2013	16:57	15	2880	192	Overhead equipment	Overhead Primary		Repair	III
132450496	D69006	09/02/2013	14:21	09/02/2013	14:47	1	26	26	Overhead equipment	Customer Equipment	Advise Customer		I
132450514	E05002	09/02/2013	14:44	09/02/2013	16:27	1	103	103	Overhead equipment	Connector	Replace - Same Size		IV
132450525	F03003	09/02/2013	15:12	09/02/2013	15:55	6	258	43	Animal related	Fuse	Replace - Same Size		III
132450545	R09225	09/02/2013	15:23	09/02/2013	16:28	1	65	65	Unknown	Overhead Transformer			III
132450550	V44504	09/02/2013	15:30	09/02/2013	16:55	1	85	85	Animal related	Lightning Arrestor		Replace - Same Size	II
132450556	307002	09/02/2013	15:41	09/02/2013	17:15	1	94	94	Tree related-tree broken	Overhead Service	Patrol/Test/Inspect	Replace - Same Size	VI
132450569	S15558	09/02/2013	16:10	09/02/2013	22:12	49	17738	362	Underground equipment	Underground Primary	Repair		VI
132450602	Y34596	09/02/2013	17:27	09/02/2013	19:00	1	93	93	Overhead equipment	Connector			IV
132450606	K11373	09/02/2013	17:34	09/02/2013	18:38	4	256	64	Overhead equipment	Fuse	Replace - Same Size		V
132450609	V20502	09/02/2013	17:42	09/02/2013	18:15	1	33	33	Animal related	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	II
132450719	T17581	09/02/2013	17:44	09/03/2013	0:21	39	15483	397	Tree related-tree broken	Crossarm	Patrol/Test/Inspect	Replace - Same Size	VI
132450717	T17581	09/02/2013	17:44	09/02/2013	19:46	364	44408	122	Tree related-tree broken	Tree	Cut in Clear		VI
132450682	S49550	09/02/2013	18:41	09/02/2013	20:20	6	594	99	Overhead equipment	Transformer Fuse	Replace - Same Size		VI
132450718	E05002	09/02/2013	19:29	09/02/2013	23:00	1	211	211	Underground equipment	Underground Service		Patrol/Test/Inspect	IV
132450757	Y59519	09/02/2013	20:22	09/02/2013	21:34	14	1008	72	Underground equipment	Underground Primary	Repair	Repair	IV
132450767	J47176	09/02/2013	20:43	09/02/2013	21:14	1	31	31	Overhead equipment	Connector			III
132450776	D55002	09/02/2013	20:55	09/02/2013	21:30	1	35	35	Overhead equipment	Meter	Replace - Same Size		I
132450832	A49003	09/02/2013	22:14	09/03/2013	4:50	71	28116	396	Overhead equipment	Bracket	Patrol/Test/Inspect	Replace - New Size	I
132450868	P58156	09/02/2013	23:18	09/03/2013	2:18	1	180	180	Tree related-tree broken	Overhead Service	Reconnect		VI
132450870	D69009	09/02/2013	23:21	09/03/2013	2:44	1	203	203	Underground equipment	Underground Service	Patrol/Test/Inspect	Repair	I
132450878	S03531	09/02/2013	23:46	09/03/2013	1:07	4	324	81	Overhead equipment	Transformer Fuse	Replace - Same Size		VI
132464686	A49003	09/03/2013	2:34	09/03/2013	4:50	22	2992	136	Overhead equipment	Jumper	Replace - Same Size	Replace - Same Size	I
132464683	J74125	09/03/2013	2:48	09/03/2013	6:16	11	2288	208	Tree related-tree broken	Recloser			VI
132464727	K52401	09/03/2013	6:18	09/03/2013	9:35	1	197	197	Animal related	Disconnect Switch	Cut in Clear	Replace - New Size	V
132464733	P82290	09/03/2013	6:27	09/03/2013	7:28	2	122	61	Animal related	Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
132464736	Z06537	09/03/2013	6:29	09/03/2013	7:43	1	74	74	Overhead equipment	Fuse	Replace - Same Size		IV
132464737	M41111	09/03/2013	6:32	09/03/2013	6:51	1	19	19	Overhead equipment	Transformer Fuse	Replace - Same Size		I
132464788	L50215	09/03/2013	7:10	09/03/2013	8:47	3	291	97	Animal related	Animal Guard	Install	Replace - Same Size	VI
132465058	HB6283	09/03/2013	7:30	09/03/2013	11:42	23	5796	252	Animal related	Fuse	Replace - Same Size		VI
132464883	N35852	09/03/2013	7:36	09/03/2013	8:23	13	611	47	Animal related	Fuse	Replace - Same Size		V
132464851	S86581	09/03/2013	7:37	09/03/2013	9:52	1	135	135	Animal related	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
132464966	S79510	09/03/2013	8:11	09/03/2013	11:00	1	169	169	Animal related	Disconnect Switch			VI
132464992	A73002	09/03/2013	8:19	09/03/2013	15:35	1	436	436	Underground equipment	Underground Primary	Patrol/Test/Inspect	Patrol/Test/Inspect	I
132465080	X65540	09/03/2013	8:33	09/03/2013	10:20	1	107	107	Animal related	Lightning Arrestor	Replace - Same Size		IV
132465096	K30204	09/03/2013	8:36	09/03/2013	9:12	1	36	36	Unknown	Transformer Fuse	Replace - Same Size		III
132465246	V95586	09/03/2013	8:43	09/03/2013	10:49	80	10080	126	Tree related-tree broken	Tree	Replace - Same Size		II
132465348	V10545	09/03/2013	9:19	09/03/2013	11:25	1	126	126	Underground equipment	Underground Primary	Switch/Reset	Repair	II
132465396	J75271	09/03/2013	9:30	09/03/2013	11:20	1	110	110	Weather	Transformer Fuse	Replace - Same Size		IV
132465423	P05825	09/03/2013	9:34	09/03/2013	9:56	1	22	22	Animal related	Transformer Fuse	Replace - Same Size		V
132467086	J68435	09/03/2013	9:35	09/03/2013	13:46	1413	354663	251	Animal related				III
132465714	J68435	09/03/2013	9:35	09/03/2013	13:47	509	128268	252	Animal related				III
132465674	P20930	09/03/2013	9:55	09/03/2013	10:57	1	62	62	Animal related	Fuse	Replace - Same Size		VI
132465724	B08002	09/03/2013	10:03	09/03/2013	10:55	1	52	52	Animal related	Fuse	Replace - Same Size		I
132465786	J80807	09/03/2013	10:11	09/03/2013	11:03	1	52	52	Overhead equipment	Overhead Service	Repair		V
132465855	Y50003	09/03/2013	10:23	09/03/2013	10:45	1	22	22	Overhead equipment	Overhead Service		Repair	IV
132465947	308002	09/03/2013	10:35	09/03/2013	11:30	1	55	55	Overhead equipment	Overhead Service		Repair	VI
132465995	J61115	09/03/2013	10:43	09/03/2013	13:13	1	150	150	Other				III
132466645	V18582	09/03/2013	10:43	09/03/2013	13:25	26	4212	162	Underground equipment	Underground Primary	Switch/Reset	Repair	II
132466062	K09863	09/03/2013	10:52	09/03/2013	14:25	1	213	213	Overhead equipment	Overhead Transformer		Replace - Same Size	V
132466067		09/03/2013	10:54	09/03/2013	12:04	1	70	70	Other	Overhead Service	Cut in Clear		I
132466126	Q11516	09/03/2013	11:01	09/03/2013	11:26	17	425	25	Unknown	Fuse	Replace - Same Size		I
132466451	T06505	09/03/2013	11:56	09/03/2013	12:45	1	49	49	Animal related	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
132466584	A45002	09/03/2013	11:59	09/03/2013	16:24	22	5830	265	Underground equipment	Underground Primary	Patrol/Test/Inspect	Patrol/Test/Inspect	I
132466550	L24122	09/03/2013	12:14	09/03/2013	13:11	1	57	57	Unknown	Transformer Fuse	Replace - Same Size		III

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
132466924	K08909	09/03/2013	13:21	09/03/2013	13:35	1	14	14	Animal related	Transformer Fuse	Repair	No Work Required	VI
132467026	U68581	09/03/2013	13:38	09/03/2013	14:15	1	37	37	Overhead equipment	Overhead Service	Repair		II
132467233	R33127	09/03/2013	14:17	09/03/2013	14:52	2	70	35	Animal related	Transformer Fuse	Replace - Same Size	Patrol/Test/Inspect	I
132467324	P71830	09/03/2013	14:34	09/03/2013	16:25	1	111	111	Overhead equipment	Overhead Service	Repair	No Work Required	V
132467404	Q21423	09/03/2013	14:49	09/03/2013	20:09	2	640	320	Underground equipment	Underground Transformer	Patrol/Test/Inspect	Replace - Same Size	VI
132467689		09/03/2013	15:47	09/03/2013	20:55	1	308	308	Underground equipment	Underground Primary			III
132467727	N78243	09/03/2013	15:55	09/03/2013	19:44	1	229	229	Overhead equipment	Overhead Primary	Repair	No Work Required	I
132467766	S09520	09/03/2013	16:04	09/03/2013	16:35	3	93	31	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	VI
132468619	L82188	09/03/2013	16:23	09/03/2013	18:43	9	1260	140	Underground equipment	Underground Primary			IV
132467837	L82188	09/03/2013	16:23	09/03/2013	19:39	13	2309	196	Underground equipment	Underground Primary		Repair	IV
132467854	B21002	09/03/2013	16:26	09/03/2013	19:23	2	354	177	Animal related	Transformer Fuse	Replace - Same Size		I
132468393	A50001	09/03/2013	17:02	09/04/2013	1:19	5	2485	497	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
132467980	340101	09/03/2013	17:05	09/03/2013	17:39	1	34	34	Jurisdictional	Overhead Service	Reconnect		V
132468014	M22812	09/03/2013	17:18	09/03/2013	19:27	1	129	129	Animal related	Fuse	Replace - Same Size		V
132468020	N78243	09/03/2013	17:24	09/03/2013	19:46	1	142	142	Overhead equipment	Overhead Primary	Repair	No Work Required	I
132468029	S04513	09/03/2013	17:27	09/03/2013	19:25	1	118	118	Tree related-tree contact	Overhead Service	Repair		VI
132468113	M25143	09/03/2013	18:01	09/03/2013	22:35	1	274	274	Overhead equipment	Fuse	Replace - Same Size		IV
132468127	A50001	09/03/2013	18:06	09/03/2013	18:30	66	1584	24	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
132468139	307003	09/03/2013	18:15	09/03/2013	19:08	1	53	53	Tree related-tree broken	Overhead Service	Reconnect		VI
132468299	A42005	09/03/2013	18:25	09/03/2013	19:10	1	45	45	Tree related-tree broken	Overhead Service	Repair		I
132468388	R29905	09/03/2013	18:38	09/03/2013	19:36	1	58	58	Overhead equipment	Transformer Fuse	Repair	No Work Required	VI
132468400	J34357	09/03/2013	18:49	09/03/2013	19:51	6	372	62	Animal related	Transformer Fuse	Replace - Same Size		V
132469107	L81141	09/03/2013	19:12	09/03/2013	21:07	1	115	115	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
132469123	C76002	09/03/2013	19:23	09/04/2013	4:10	1	527	527	Underground equipment	Underground Primary	Repair	Repair	I
132469137	B61001	09/03/2013	19:23	09/03/2013	20:25	60	3720	62	Animal related	Fuse	Replace - Same Size		I
132469141	N05172	09/03/2013	19:39	09/03/2013	21:06	1	87	87	Overhead equipment	Overhead Service	Repair	No Work Required	I
132469145	M22812	09/03/2013	19:50	09/03/2013	21:59	1	129	129	Weather	Transformer Fuse	Replace - Same Size		V
132469163	B61001	09/03/2013	20:06	09/03/2013	20:46	1	40	40	Animal related	Fuse	Replace - Same Size		I
132469166	N78243	09/03/2013	20:09	09/03/2013	20:45	1	36	36	Overhead equipment	Overhead Service	Repair	No Work Required	I
132469259	V50001	09/03/2013	21:18	09/03/2013	23:15	4	468	117	Overhead equipment	Transformer Fuse	Replace - Same Size	Replace - Same Size	II
132469268	S88551	09/03/2013	21:39	09/04/2013	4:51	31	13392	432	Overhead equipment	Overhead Transformer	Replace - Same Size	Replace - Same Size	VI
132469276	D32211	09/03/2013	21:56	09/04/2013	5:30	1	454	454	Underground equipment	Underground Primary		Repair	I
132469278	B00004	09/03/2013	22:00	09/04/2013	5:37	1	457	457	Underground equipment	Underground Primary	Patrol/Test/Inspect	Patrol/Test/Inspect	I
132469290	V29003	09/03/2013	22:36	09/03/2013	23:46	13	910	70	Overhead equipment	Transformer Fuse	Replace - Same Size	Replace - Same Size	II
132472125	M05361	09/04/2013	2:03	09/04/2013	9:25	35	15470	442	Underground equipment	Underground Primary		Repair	V
132472133	J88166	09/04/2013	3:19	09/04/2013	4:54	1	95	95	Overhead equipment	Overhead Transformer		Replace - Same Size	VI
132474431	J84124	09/04/2013	6:44	09/04/2013	9:43	1	179	179	Overhead equipment	Connector	Replace - New Size		VI
132474556	K89143	09/04/2013	7:23	09/04/2013	7:54	44	1364	31	Overhead equipment	Overhead Primary	Repair		III
132474702	B44002	09/04/2013	8:03	09/04/2013	9:29	1	86	86	Underground equipment	Underground Primary		Repair	I
132474708	D39002	09/04/2013	8:06	09/04/2013	9:35	1	89	89	Overhead equipment	Fuse	Replace - Same Size		I
132474729	K46388	09/04/2013	8:07	09/04/2013	8:30	4	92	23	Animal related	Fuse	Replace - Same Size		V
132474816	B57001	09/04/2013	8:17	09/04/2013	10:30	17	2261	133	Unknown	Fuse	Replace - Same Size		I
132474768	S60581	09/04/2013	8:21	09/04/2013	10:00	1	99	99	Animal related	Transformer Fuse	Replace - Same Size		VI
132474821	S79510	09/04/2013	8:36	09/04/2013	10:10	1	94	94	Animal related	Transformer Fuse			VI
132475067	N58144	09/04/2013	9:04	09/04/2013	10:15	1	71	71	Animal related	Fuse	Repair	Replace - Same Size	I
132475131	J01118	09/04/2013	9:12	09/04/2013	10:22	11	770	70	Overhead equipment	Fuse	Replace - Same Size		I
132475278	L50214	09/04/2013	9:20	09/04/2013	13:37	9	2313	257	Overhead equipment	Lightning Arrestor			VI
132475259		09/04/2013	9:36	09/04/2013	10:14	1	38	38	Animal related	Transformer Fuse	Replace - Same Size		I
132475491	L79180	09/04/2013	9:39	09/04/2013	12:10	10	1510	151	Underground equipment	Underground Primary	Switch/Reset	Switch/Reset	IV
132475387	S03530	09/04/2013	9:57	09/04/2013	14:10	1	253	253	Tree related-tree broken	Pole	Repair	Repair	VI
132475441	Q24313	09/04/2013	10:07	09/04/2013	14:38	1	271	271	Overhead equipment	Overhead Transformer		Patrol/Test/Inspect	VI
132475554		09/04/2013	10:25	09/04/2013	10:54	1	29	29	Animal related	Fuse	Replace - Same Size		III
132475632	Q91141	09/04/2013	10:37	09/04/2013	11:26	1	49	49	Unknown	Fuse	Repair	Replace - Same Size	I
132475846	L24122	09/04/2013	11:09	09/04/2013	14:21	1	192	192	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	III
132476583	R07381	09/04/2013	12:15	09/04/2013	16:40	18	4770	265	Underground equipment	Fuse	Replace - Same Size	Repair	I
132476392	S83532	09/04/2013	12:32	09/04/2013	13:35	1	63	63	Overhead equipment	Disconnect Switch			VI

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
132476679	R99180	09/04/2013	13:25	09/04/2013	14:08	1	43	43	Overhead equipment	Jumper		Repair	IV
132476768	X83533	09/04/2013	13:39	09/04/2013	15:58	5	695	139	Animal related	Transformer Fuse	Replace - Same Size	Replace - Same Size	IV
132476895	J07173	09/04/2013	14:03	09/04/2013	15:12	1	69	69	Animal related	Transformer Fuse	Replace - Same Size		I
132476971	U57560	09/04/2013	14:16	09/04/2013	18:57	1	281	281	Overhead equipment	Underground Primary		Patrol/Test/Inspect	II
132477129	C10002	09/04/2013	14:44	09/04/2013	16:29	1	105	105	Public	Customer Equipment			III
132477263	M04365	09/04/2013	15:02	09/04/2013	20:43	1	341	341	Animal related	Overhead Primary	Repair	Replace - Same Size	V
132477572	J47178	09/04/2013	15:47	09/04/2013	17:18	35	3185	91	Underground equipment	Underground Primary			III
132477560	J87150	09/04/2013	16:08	09/04/2013	16:58	2	100	50	Overhead equipment	Overhead Service			VI
132477603	S01560	09/04/2013	16:22	09/04/2013	16:53	1	31	31	Jurisdictional	Overhead Service			VI
132477687	Z04520	09/04/2013	16:34	09/04/2013	21:50	3	948	316	Underground equipment	Underground Primary	Patrol/Test/Inspect		IV
132477740	V99562	09/04/2013	17:00	09/04/2013	18:10	1	70	70	Overhead equipment	Disconnect Switch	Replace - Same Size	Patrol/Test/Inspect	II
132477875	R95520	09/04/2013	17:47	09/04/2013	19:23	1	96	96	Other	Fuse	Patrol/Test/Inspect		I
132477998	J12166	09/04/2013	18:43	09/04/2013	19:40	1	57	57	Overhead equipment	Overhead Service	Repair		III
132478111	R07382	09/04/2013	18:56	09/04/2013	22:08	20	3840	192	Underground equipment	Underground Primary	Replace - Same Size	Repair	I
132478133	H00162	09/04/2013	19:16	09/04/2013	21:34	6	828	138	Unknown	Fuse	Replace - Same Size		III
132478445	M51275	09/04/2013	19:27	09/04/2013	21:26	1	119	119	Public	Other			III
132478728	J15303	09/04/2013	21:14	09/04/2013	22:05	1	51	51	Animal related	Transformer Fuse	Replace - Same Size	Replace - Same Size	I
132478736	H00162	09/04/2013	21:56	09/04/2013	22:33	1	37	37	Overhead equipment	Other			III
132478759	R07382	09/04/2013	22:17	09/05/2013	5:45	20	8960	448	Underground equipment				I
132481861	R07382	09/04/2013	22:20	09/05/2013	0:01	11	1111	101	Underground equipment				I
132481710	F03003	09/04/2013	22:34	09/05/2013	7:09	2	1030	515	Underground equipment	Underground Primary	Repair		III
132478763	F03003	09/04/2013	22:34	09/05/2013	1:47	13	2509	193	Underground equipment	Underground Primary	Switch/Reset		III
132480093	L93134	09/05/2013	0:20	09/05/2013	1:40	1	80	80	Overhead equipment	Fuse			VI
132481660	R66470	09/05/2013	0:56	09/05/2013	2:15	6	474	79	Overhead equipment	Fuse	Replace - Same Size	No Work Required	IV
132483825	B21002	09/05/2013	2:07	09/05/2013	5:56	18	4122	229	Underground equipment	Underground Primary	Switch/Reset	Repair	I
132481859	X65540	09/05/2013	3:02	09/05/2013	4:48	1	106	106	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
132483816	J99127	09/05/2013	3:34	09/05/2013	4:52	30	2340	78	Overhead equipment	Overhead Primary			VI
132483824	B21002	09/05/2013	4:47	09/05/2013	4:58	3	33	11	Underground equipment	Underground Primary	Replace - Same Size		I
132483835	P26283	09/05/2013	5:10	09/05/2013	7:11	29	3509	121	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
132483870	B80002	09/05/2013	6:32	09/05/2013	11:22	26	7540	290	Underground equipment	Underground Primary	Switch/Reset	Repair	I
132483970	Q16867	09/05/2013	7:26	09/05/2013	8:37	1	71	71	Overhead equipment	Connector	Replace - Same Size		V
132484059	M81404	09/05/2013	8:01	09/05/2013	9:11	1	70	70	Animal related	Fuse	Replace - Same Size	Repair	V
132484102	R01153	09/05/2013	8:11	09/05/2013	9:07	1	56	56	Other	Meter			III
132484108	H10843	09/05/2013	8:12	09/05/2013	11:45	1	213	213	Overhead equipment	Overhead Transformer			V
132484438	G20002	09/05/2013	9:08	09/05/2013	10:20	16	1152	72	Unknown	Fuse	Replace - Same Size		III
132484486	Q95248	09/05/2013	9:11	09/05/2013	11:00	7	763	109	Underground equipment	Underground Primary	Patrol/Test/Inspect		VI
132484500	J68401	09/05/2013	9:27	09/05/2013	11:04	1	97	97	Overhead equipment				III
132484699	T15571	09/05/2013	9:59	09/05/2013	10:55	1	56	56	Animal related	Overhead Primary	Repair		VI
132484833	R58961	09/05/2013	10:20	09/05/2013	10:59	1	39	39	Animal related	Fuse	Replace - Same Size		IV
132484862	N18211	09/05/2013	10:26	09/05/2013	14:18	1	232	232	Other	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	III
132484896	HB6281	09/05/2013	10:34	09/05/2013	13:29	1	175	175	Overhead equipment	Overhead Primary	Repair		VI
132484998	Q15844	09/05/2013	10:48	09/05/2013	11:30	1	42	42	Overhead equipment	Overhead Service			V
132485099	X36550	09/05/2013	11:05	09/05/2013	12:09	1	64	64	Animal related	Animal Guard	Install		IV
132485100	H11340	09/05/2013	11:06	09/05/2013	12:50	1	104	104	Jurisdictional				V
132485171	B21003	09/05/2013	11:14	09/05/2013	11:54	5	200	40	Overhead equipment	Fuse	Repair	Replace - Same Size	I
132485149	K26136	09/05/2013	11:14	09/05/2013	11:18	1	4	4	Overhead equipment				VI
132485424	K62102	09/05/2013	12:01	09/05/2013	13:26	1	85	85	Animal related	Transformer Fuse	Replace - Same Size		II
132485460	U37579	09/05/2013	12:11	09/05/2013	13:34	4	332	83	Public	Fuse	Replace - Same Size		II
132485616	A80002	09/05/2013	12:43	09/05/2013	16:10	1	207	207	Public	Underground Service		Repair	I
132485674	B00002	09/05/2013	12:53	09/05/2013	14:27	20	1880	94	Overhead equipment	Transformer Fuse	Replace - Same Size		I
132485713	J08207	09/05/2013	12:58	09/05/2013	13:18	1	20	20	Animal related	Fuse	Replace - Same Size		I
132488315	M25144	09/05/2013	13:14	09/05/2013	21:29	6	2970	495	Overhead equipment	Overhead Primary	Repair		IV
132486001	U15003	09/05/2013	13:51	09/05/2013	15:30	1	99	99	Overhead equipment	Overhead Transformer	Replace - New Size	Replace - New Size	II
132486060	D66002	09/05/2013	14:03	09/05/2013	15:17	1	74	74	Overhead equipment	Overhead Secondary			IV
132487141	U99700	09/05/2013	14:35	09/05/2013	15:22	3	141	47	Jurisdictional	Substation Recloser			II
132487063	U73741	09/05/2013	14:35	09/05/2013	15:22	914	42958	47	Jurisdictional				II

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
132487018	U79726	09/05/2013	14:35	09/05/2013	15:35	1567	94020	60	Jurisdictional				II
132486896	U99706	09/05/2013	14:35	09/05/2013	15:22	1735	81545	47	Jurisdictional				II
132487133	U99749	09/05/2013	14:35	09/05/2013	15:22	4256	200032	47	Jurisdictional				II
132486291	P52301	09/05/2013	14:38	09/05/2013	16:00	1	82	82	Weather	Transformer Fuse	Replace - Same Size		IV
132486370	B73001	09/05/2013	14:39	09/05/2013	20:17	1	338	338	Overhead equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
132486919	S86582	09/05/2013	14:56	09/05/2013	18:31	1	215	215	Underground equipment	Underground Primary	Repair	Repair	VI
132487374	G20002	09/05/2013	16:34	09/05/2013	18:00	1	86	86	Animal related	Fuse	Replace - Same Size		III
132487430	X12526	09/05/2013	16:54	09/05/2013	19:00	1	126	126	Animal related	Lightning Arrestor	Replace - New Size	Repair	IV
132487433	B80002	09/05/2013	16:55	09/05/2013	22:30	1	335	335	Underground equipment	Underground Secondary	Patrol/Test/Inspect	Repair	I
132487528	P82291	09/05/2013	17:23	09/05/2013	17:37	62	868	14	Animal related	Recloser			VI
132487617	Q04411	09/05/2013	18:16	09/05/2013	22:54	1	278	278	Underground equipment	Underground Service			III
132488360	M25144	09/05/2013	18:55	09/05/2013	21:29	3	462	154	Overhead equipment	Overhead Primary	Repair		IV
132487765	Y50003	09/05/2013	18:56	09/05/2013	19:54	16	928	58	Overhead equipment	Transformer Fuse		Replace - Same Size	IV
132488523	V33001	09/05/2013	21:45	09/05/2013	22:38	1	53	53	Overhead equipment	Connector	Repair		II
132488536	X64501	09/05/2013	21:54	09/06/2013	0:06	19	2508	132	Animal related	Fuse	Replace - Same Size		IV
132488546	Z05548	09/05/2013	22:48	09/05/2013	23:36	5	240	48	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
132490101	J30201	09/06/2013	0:09	09/06/2013	1:51	1	102	102	Animal related	Fuse		Patrol/Test/Inspect	VI
132492639	N60181	09/06/2013	3:01	09/06/2013	4:25	53	4452	84	Overhead equipment	Fuse	Replace - Same Size		I
132494574	B84006	09/06/2013	3:19	09/06/2013	11:00	13	5993	461	Underground equipment	Underground Primary		Repair	I
132492564	B84006	09/06/2013	3:23	09/06/2013	5:15	9	1008	112	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
132494479	HA5431	09/06/2013	3:49	09/06/2013	5:35	13	1378	106	Animal related	Tree	Cut in Clear	Cut in Clear	V
132494485	K26136	09/06/2013	4:34	09/06/2013	5:30	1	56	56	Animal related	Fuse	Repair	Repair	VI
132494496	Q16868	09/06/2013	5:29	09/06/2013	10:50	24	7704	321	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	V
132494497	349001	09/06/2013	5:33	09/06/2013	8:09	1	156	156	Overhead equipment	Other		Replace - New Size	VI
132494553	K08909	09/06/2013	7:03	09/06/2013	7:57	1	54	54	Animal related	Transformer Fuse	Repair	No Work Required	VI
132494563	P62138	09/06/2013	7:10	09/06/2013	11:55	3	855	285	Underground equipment	Underground Secondary	No Work Required	Repair	VI
132494743	D37004	09/06/2013	8:17	09/06/2013	9:45	28	2464	88	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
132494858	K27150	09/06/2013	8:34	09/06/2013	10:01	13	1131	87	Animal related	Transformer Fuse	Replace - Same Size	Replace - Same Size	VI
132494838	T29562	09/06/2013	8:51	09/06/2013	9:18	1	27	27	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	VI
132494854	L50215	09/06/2013	8:56	09/06/2013	10:49	3	339	113	Overhead equipment	Transformer Fuse			VI
132494870	Q32171	09/06/2013	9:01	09/06/2013	9:45	1	44	44	Animal related	Transformer Fuse	Replace - Same Size	Patrol/Test/Inspect	I
132495089	J63172	09/06/2013	9:35	09/06/2013	10:36	125	7625	61	Animal related	Fuse	Repair	Repair	III
132495091	Y23521	09/06/2013	9:39	09/06/2013	11:00	11	891	81	Overhead equipment	Fuse	Replace - Same Size		IV
132495406	M49411	09/06/2013	10:48	09/06/2013	11:35	1	47	47	Animal related	Transformer Fuse			V
132495684	L73160	09/06/2013	12:00	09/06/2013	13:35	1	95	95	Tree related-tree broken	Overhead Service	Repair	Repair	IV
132495713	R78300	09/06/2013	12:12	09/06/2013	13:25	1	73	73	Public	Overhead Service	Repair		V
132495768	V10551	09/06/2013	12:30	09/06/2013	14:27	1	117	117	Animal related	Fuse	Replace - Same Size		II
132495785	X02548	09/06/2013	12:34	09/06/2013	13:15	1	41	41	Unknown	Transformer Fuse	Replace - Same Size		IV
132495901	K01239	09/06/2013	12:52	09/06/2013	13:45	1270	67310	53	Unknown				VI
132496001	K32932	09/06/2013	13:22	09/06/2013	13:45	1	23	23	Other	Overhead Service	Replace - New Size		VI
132496048	K69117	09/06/2013	13:25	09/06/2013	14:40	17	1275	75	Underground equipment	Underground Primary	Switch/Reset	Repair	IV
132496080	V04552	09/06/2013	13:39	09/06/2013	14:54	1	75	75	Overhead equipment	Lightning Arrestor	Replace - Same Size		II
132496286	R06212	09/06/2013	14:21	09/06/2013	17:00	22	3498	159	Underground equipment	Underground Primary	Switch/Reset	Repair	II
132496277	M09144	09/06/2013	14:24	09/06/2013	14:29	1	5	5	Overhead equipment	Fuse	Replace - Same Size	Repair	VI
132496309	N70330	09/06/2013	14:28	09/06/2013	14:52	1	24	24	Other				I
132496325	R48166	09/06/2013	14:33	09/06/2013	16:18	1	105	105	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
132496376	Y10011	09/06/2013	14:47	09/06/2013	15:32	1	45	45	Overhead equipment	Transformer Fuse	Repair	Repair	IV
132496489	Q01281	09/06/2013	15:17	09/06/2013	17:56	55	8745	159	Underground equipment	Underground Primary			III
132496591	U99515	09/06/2013	15:50	09/06/2013	18:30	1	160	160	Overhead equipment	Transformer Fuse	Replace - Same Size		II
132496625	K80388	09/06/2013	16:00	09/06/2013	20:13	21	5313	253	Public	Pole		Repair	IV
132496734	R61241	09/06/2013	16:31	09/06/2013	17:50	143	11297	79	Overhead equipment				IV
132496722	L59922	09/06/2013	16:32	09/06/2013	20:08	26	5616	216	Overhead equipment	Bracket	Repair	Tie/Tighten	VI
132496818	J71129	09/06/2013	17:15	09/06/2013	19:57	2	324	162	Public	Overhead Service	Repair		I
132496836	D48003	09/06/2013	17:26	09/06/2013	17:50	1	24	24	Overhead equipment				I
132496838	334001	09/06/2013	17:26	09/06/2013	19:00	1	94	94	Overhead equipment	Connector	Replace - Same Size		VI
132496903	P26284	09/06/2013	18:12	09/06/2013	19:32	1	80	80	Animal related	Transformer Fuse	Replace - Same Size	No Work Required	I

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
132497445	B57002	09/06/2013	18:12	09/06/2013	19:00	22	1056	48	Overhead equipment	Transformer Fuse	Replace - Same Size		I
132497091	S47575	09/06/2013	18:45	09/06/2013	19:45	4	240	60	Animal related	Transformer Fuse	Replace - Same Size	Replace - Same Size	VI
132497712	N78244	09/06/2013	19:23	09/06/2013	20:56	1	93	93	Other	Other	Patrol/Test/Inspect	No Work Required	I
132497738	D69006	09/06/2013	19:59	09/07/2013	3:48	1	469	469	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
132497804	M54314	09/06/2013	21:02	09/06/2013	23:18	1	136	136	Tree related-tree contact	Tree	Trim		V
132497832	P98192	09/06/2013	22:10	09/07/2013	1:16	72	13392	186	Underground equipment	Underground Primary			III
132497838	P18103	09/06/2013	22:50	09/07/2013	0:02	1	72	72	Animal related	Fuse	Replace - Same Size	No Work Required	IV
132497848	R16510	09/06/2013	23:40	09/07/2013	0:55	1	75	75	Other	Other	Patrol/Test/Inspect	No Work Required	I
132500035	P98192	09/07/2013	0:53	09/07/2013	1:20	52	1404	27	Overhead equipment				III
132500053	J99128	09/07/2013	3:00	09/07/2013	5:32	1	152	152	Overhead equipment	Fuse	Replace - Same Size		VI
132500078	Q34366	09/07/2013	3:46	09/07/2013	8:39	27	7911	293	Underground equipment	Underground Primary	Repair		I
132500091	K80382	09/07/2013	4:23	09/07/2013	9:22	19	5681	299	Underground equipment	Underground Primary		Repair	IV
132500082	V76001	09/07/2013	4:39	09/07/2013	6:08	1	89	89	Overhead equipment	Disconnect Switch	Replace - Same Size		II
132500115	Q11516	09/07/2013	7:02	09/07/2013	7:55	1	53	53	Other				I
132500150	Q74148	09/07/2013	7:51	09/07/2013	9:00	1	69	69	Animal related	Transformer Fuse			IV
132500172	Q54908	09/07/2013	8:16	09/07/2013	9:23	1	67	67	Animal related	Fuse	Replace - Same Size		VI
132500177	Y98561	09/07/2013	8:20	09/07/2013	9:20	1	60	60	Overhead equipment	Overhead Service	Repair		IV
132500182	V20512	09/07/2013	8:22	09/07/2013	10:06	1	104	104	Animal related	Animal Guard	Install		II
132500186	Z11506	09/07/2013	8:27	09/07/2013	9:27	2	120	60	Unknown	Transformer Fuse	Replace - Same Size	No Work Required	IV
132500196	P47123	09/07/2013	8:38	09/07/2013	10:00	1	82	82	Animal related	Transformer Fuse	Replace - Same Size		I
132500204	P58155	09/07/2013	8:38	09/07/2013	11:48	18	3420	190	Tree related-tree broken	Overhead Primary	Repair	Repair	VI
132500219	S88503	09/07/2013	8:47	09/07/2013	10:13	1	86	86	Animal related	Lightning Arrestor	Replace - Same Size		VI
132500225	S49550	09/07/2013	8:59	09/07/2013	10:44	6	630	105	Animal related	Fuse	Replace - Same Size		VI
132500232	S49550	09/07/2013	9:05	09/07/2013	10:44	1	99	99	Animal related	Transformer Fuse	Replace - Same Size		VI
132500254	M19222	09/07/2013	9:25	09/07/2013	10:15	1	50	50	Animal related	Lightning Arrestor	Replace - Same Size		VI
132500380	D32212	09/07/2013	9:40	09/07/2013	18:22	1	522	522	Underground equipment	Underground Primary	Repair	Repair	I
132500416	R33127	09/07/2013	9:55	09/07/2013	12:15	6	840	140	Overhead equipment	Fuse	Replace - Same Size	Patrol/Test/Inspect	I
132500421	M21133	09/07/2013	10:16	09/07/2013	11:34	1	78	78	Animal related	Transformer Fuse	Replace - Same Size	No Work Required	VI
132500472	J98114	09/07/2013	10:51	09/07/2013	12:03	26	1872	72	Overhead equipment	Fuse	Replace - Same Size		VI
132500465	B73003	09/07/2013	10:55	09/07/2013	13:01	1	126	126	Tree related-tree broken	Tree	Cut in Clear		I
132500481	J07135	09/07/2013	10:56	09/07/2013	12:30	3	282	94	Overhead equipment	Fuse	Replace - Same Size		I
132500498	K43386	09/07/2013	11:16	09/07/2013	12:35	5	395	79	Animal related	Fuse	Replace - Same Size		V
132500509	J63172	09/07/2013	11:31	09/07/2013	11:50	14	266	19	Animal related	Transformer Fuse			III
132500524	L90359	09/07/2013	11:46	09/07/2013	12:50	1	64	64	Overhead equipment	Transformer Fuse	Replace - Same Size		V
132500535	T06538	09/07/2013	11:59	09/07/2013	12:45	1	46	46	Overhead equipment	Fuse	Patrol/Test/Inspect	Repair	VI
132500638	L81142	09/07/2013	13:24	09/07/2013	14:10	1	46	46	Overhead equipment	Fuse			IV
132500697	S64502	09/07/2013	13:28	09/07/2013	17:25	26	6162	237	Underground equipment	Underground Primary	Switch/Reset	Repair	VI
132500731	P52305	09/07/2013	13:32	09/07/2013	15:50	15	2070	138	Tree related-tree broken	Overhead Primary	Repair		IV
132500739	M45212	09/07/2013	14:51	09/07/2013	16:04	2	146	73	Unknown	Transformer Fuse			IV
132500751	P77235	09/07/2013	15:04	09/07/2013	16:23	1	79	79	Public	Overhead Transformer	Switch/Reset		VI
132500764	N03296	09/07/2013	15:18	09/07/2013	17:08	18	1980	110	Overhead equipment	Fuse	Replace - Same Size		V
132500869	P26284	09/07/2013	18:41	09/07/2013	20:12	1	91	91	Weather	Fuse	Replace - Same Size	Replace - Same Size	I
132500873	D69004	09/07/2013	18:56	09/08/2013	1:15	1	379	379	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
132500911	Z19547	09/07/2013	19:57	09/07/2013	21:23	2	172	86	Animal related	Overhead Primary	Repair	Patrol/Test/Inspect	IV
132500909	U29001	09/07/2013	20:05	09/07/2013	21:38	1	93	93	Unknown	Fuse	Replace - Same Size		II
132500943		09/07/2013	22:05	09/07/2013	23:49	1	104	104	Animal related	Fuse		Repair	III
132510035	K55397	09/08/2013	0:13	09/08/2013	1:45	716	65872	92	Tree related-tree broken	Tree			V
132510504	R05114	09/08/2013	1:28	09/08/2013	8:11	83	33449	403	Weather	Fuse	Repair	Replace - Same Size	I
132510300	M42105	09/08/2013	1:31	09/08/2013	6:30	56	16744	299	Tree related-tree broken	Overhead Primary	Replace - Same Size	Replace - Same Size	I
132510058	M42105	09/08/2013	1:31	09/08/2013	11:35	123	74292	604	Unknown	Overhead Primary	Patrol/Test/Inspect		I
132510116	M42107	09/08/2013	1:31	09/08/2013	2:44	1500	109500	73	Tree related-tree broken	Recloser	Switch/Reset		I
132511154	M36185	09/08/2013	1:32	09/08/2013	20:38	12	13752	1146	Overhead equipment	Pole	Replace - Same Size		I
132510057	M36185	09/08/2013	1:32	09/08/2013	11:00	89	50552	568	Tree related-tree broken	Pole	Repair	Repair	I
132510071	M40132	09/08/2013	1:32	09/08/2013	6:00	168	45024	268	Tree related-tree broken	Fuse	Replace - Same Size		I
132510073	M42105	09/08/2013	1:35	09/08/2013	2:40	155	10075	65	Overhead equipment	Overhead Primary	Switch/Reset		I
132510088	M36185	09/08/2013	1:36	09/08/2013	7:08	1	332	332	Overhead equipment	Overhead Service	No Work Required		I

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
132510105	M40116	09/08/2013	1:37	09/08/2013	9:05	41	18368	448	Tree related-tree broken	Overhead Primary	Repair	Repair	I
132510119	M42105	09/08/2013	1:41	09/08/2013	2:40	1	59	59	Overhead equipment	Overhead Primary	Switch/Reset		I
132510122	M36185	09/08/2013	1:44	09/08/2013	6:48	7	2128	304	Tree related-tree broken	Overhead Secondary	No Work Required		I
132510123	M42105	09/08/2013	1:45	09/08/2013	2:40	1	55	55	Overhead equipment	Overhead Primary	Switch/Reset		I
132510125	M40116	09/08/2013	1:45	09/08/2013	18:56	41	42271	1031	Tree related-tree broken	Pole	Patrol/Test/Inspect	Replace - Same Size	I
132510130	M40131	09/08/2013	1:52	09/08/2013	18:29	6	5982	997	Tree related-tree broken	Tree	Cut in Clear		I
132510129	311003	09/08/2013	1:52	09/08/2013	2:45	1	53	53	Public				VI
132510134	M42105	09/08/2013	2:00	09/08/2013	2:40	181	7240	40	Overhead equipment	Overhead Primary	Switch/Reset		I
132510338	M40679	09/08/2013	2:05	09/08/2013	6:20	2103	536265	255	Substation equipment				I
132510255	M37192	09/08/2013	2:25	09/08/2013	10:09	5	2320	464	Weather	Overhead Primary	Repair	Repair	I
132510906	R05115	09/08/2013	2:34	09/08/2013	14:45	5	3655	731	Overhead equipment	Pole	Replace - New Size	Replace - New Size	I
132510367	R65452	09/08/2013	2:55	09/08/2013	6:00	32	5920	185	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	IV
132510373	V76002	09/08/2013	2:57	09/08/2013	7:09	35	8820	252	Overhead equipment	Pole	Replace - Same Size	Replace - Same Size	II
132510303	J07135	09/08/2013	3:11	09/08/2013	6:12	1	181	181	Weather	Overhead Transformer	No Work Required	No Work Required	I
132510312	M42107	09/08/2013	3:34	09/08/2013	5:19	1	105	105	Tree related-tree broken	Overhead Service	No Work Required		I
132510505	M42107	09/08/2013	3:35	09/08/2013	7:05	9	1890	210	Overhead equipment	Pole	Replace - Same Size		I
132510315	M42107	09/08/2013	3:35	09/08/2013	5:44	1	129	129	Tree related-tree broken	Overhead Service	No Work Required	No Work Required	I
132510334	M42107	09/08/2013	3:35	09/08/2013	8:52	39	12363	317	Overhead equipment	Pole			I
132510317	M42107	09/08/2013	3:36	09/08/2013	5:17	1	101	101	Tree related-tree broken	Overhead Service	No Work Required		I
132510324	R01153	09/08/2013	3:39	09/08/2013	5:50	25	3275	131	Weather	Fuse	Repair		III
132510330	J56341	09/08/2013	3:44	09/08/2013	6:54	33	6270	190	Weather	Overhead Primary			III
132510445	J63172	09/08/2013	3:46	09/08/2013	6:35	17	2873	169	Overhead equipment	Overhead Primary		Replace - Same Size	III
132510328	U33586	09/08/2013	3:49	09/08/2013	5:02	1	73	73	Overhead equipment	Fuse	Repair	Repair	II
132510336	R05115	09/08/2013	4:14	09/08/2013	7:02	3	504	168	Other	Other	Repair		I
132510337	U44568	09/08/2013	4:16	09/08/2013	5:25	1	69	69	Overhead equipment	Transformer Fuse	Repair	Repair	II
132510339	M36189	09/08/2013	4:33	09/08/2013	7:53	1	200	200	Overhead equipment				I
132510352	M40132	09/08/2013	4:41	09/08/2013	6:56	84	11340	135	Tree related-tree broken	Overhead Primary	Repair	Replace - Same Size	I
132510344	M40131	09/08/2013	4:42	09/08/2013	6:55	1	133	133	Overhead equipment	Overhead Transformer	Replace - Same Size	Replace - Same Size	I
132510358	J05139	09/08/2013	5:00	09/08/2013	7:00	1	120	120	Overhead equipment	Overhead Transformer	No Work Required	No Work Required	I
132510362	R05186	09/08/2013	5:00	09/08/2013	6:30	47	4230	90	Weather	Fuse	Replace - Same Size		I
132510364	U54503	09/08/2013	5:04	09/08/2013	9:25	1	261	261	Weather	Fuse	Replace - Same Size		II
132510376	U05595	09/08/2013	5:07	09/08/2013	6:30	27	2241	83	Weather	Fuse	Replace - Same Size		II
132510805	J01118	09/08/2013	5:20	09/08/2013	13:00	33	15180	460	Overhead equipment	Pole			I
132510423	U84002	09/08/2013	6:12	09/08/2013	10:08	9	2124	236	Overhead equipment	Transformer Fuse	Replace - Same Size	No Work Required	II
132510424	J01118	09/08/2013	6:14	09/08/2013	10:10	1	236	236	Overhead equipment	Pole	Repair	Repair	I
132510432	V82551	09/08/2013	6:22	09/08/2013	9:19	1	177	177	Tree related-tree broken	Overhead Secondary	Repair		II
132510453	M42107	09/08/2013	6:34	09/08/2013	12:04	1	330	330	Overhead equipment	Overhead Secondary	Repair	Repair	I
132510452	J56341	09/08/2013	6:34	09/08/2013	6:45	1	11	11	Overhead equipment	Overhead Primary		Replace - Same Size	III
132510905	N54107	09/08/2013	6:36	09/08/2013	11:30	37	10878	294	Weather	Regulator	Cut in Clear	Replace - Same Size	II
132510468	J06167	09/08/2013	6:43	09/08/2013	8:19	1	96	96	Overhead equipment	Overhead Service	No Work Required		I
132510467	M37192	09/08/2013	6:43	09/08/2013	11:00	1	257	257	Tree related-tree broken	Overhead Service	Tie/Tighten		I
132510470	D31018	09/08/2013	6:45	09/08/2013	8:31	2	212	106	Weather	Overhead Primary		Repair	III
132510879	V18732	09/08/2013	6:47	09/08/2013	9:23	3824	596544	156	Substation equipment				II
132510478	V10551	09/08/2013	6:48	09/08/2013	10:33	1	225	225	Weather	Fuse	Replace - Same Size		II
132510807		09/08/2013	6:58	09/08/2013	10:57	919	219641	239	Substation equipment				I
132510802		09/08/2013	6:58	09/08/2013	13:05	1783	654361	367	Substation equipment				I
132511534	D36001	09/08/2013	6:59	09/08/2013	12:16	318	100806	317	Animal related	Overhead Primary	Switch/Reset		I
132510799	D36001	09/08/2013	6:59	09/08/2013	14:23	1018	451992	444	Animal related	Overhead Primary		Repair	I
132510551	J06168	09/08/2013	7:00	09/08/2013	8:02	1	62	62	Overhead equipment	Transformer Fuse	Replace - Same Size	Patrol/Test/Inspect	I
132510794	M40132	09/08/2013	7:11	09/08/2013	8:40	1	89	89	Overhead equipment	Overhead Transformer	No Work Required	No Work Required	I
132510836	D36003	09/08/2013	7:21	09/08/2013	14:23	137	57814	422	Animal related				I
132510887	J14140	09/08/2013	7:25	09/08/2013	8:59	10	940	94	Overhead equipment	Fuse	Replace - Same Size		VI
132510869	M40131	09/08/2013	7:26	09/08/2013	15:45	1	499	499	Weather	Overhead Transformer	Repair	Repair	I
132510898	N54213	09/08/2013	7:29	09/08/2013	12:31	13	3926	302	Tree related-tree broken	Overhead Primary	Repair		II
132511549	M42107	09/08/2013	7:37	09/08/2013	19:25	9	6372	708	Overhead equipment	Pole	Replace - Same Size		I
132510894	V21548	09/08/2013	7:40	09/08/2013	9:54	1	134	134	Tree related-tree contact	Overhead Service	Repair		II

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
132511058		09/08/2013	7:59	09/08/2013	9:16	217	16709	77	Substation equipment				III
132510972		09/08/2013	7:59	09/08/2013	9:08	858	59202	69	Animal related				III
132511413	R05114	09/08/2013	8:25	09/08/2013	13:56	83	27473	331	Weather	Overhead Transformer			I
132510993	V10002	09/08/2013	8:28	09/08/2013	11:39	1	191	191	Weather	Fuse	Replace - Same Size		II
132510997	M40132	09/08/2013	8:30	09/08/2013	11:20	1	170	170	Tree related-tree contact	Overhead Transformer	Switch/Reset		I
132511003	J01118	09/08/2013	8:34	09/08/2013	11:15	1	161	161	Weather	Fuse	Repair	Repair	I
132511010	R41131	09/08/2013	8:39	09/08/2013	10:22	1	103	103	Animal related	Transformer Fuse	Replace - Same Size	No Work Required	VI
132511013	K62102	09/08/2013	8:41	09/08/2013	13:10	2	538	269	Tree related-tree contact	Overhead Service	Repair	No Work Required	II
132511019	U33586	09/08/2013	8:45	09/08/2013	10:28	1	103	103	Overhead equipment	Transformer Fuse	Repair	Repair	II
132511039	N60181	09/08/2013	8:47	09/08/2013	11:50	23	4209	183	Overhead equipment	Overhead Transformer			I
132511028	M40131	09/08/2013	8:48	09/08/2013	16:30	3	1386	462	Tree related-tree broken	Overhead Secondary	Replace - Same Size	Replace - Same Size	I
132511063	P39298	09/08/2013	8:58	09/08/2013	11:11	7	931	133	Weather	Disconnect Switch	Replace - Same Size	Patrol/Test/Inspect	VI
132511055	X60598	09/08/2013	8:59	09/08/2013	11:20	18	2538	141	Overhead equipment	Lightning Arrestor	Replace - Same Size		IV
132511059	U31598	09/08/2013	9:03	09/08/2013	9:58	1	55	55	Overhead equipment	Disconnect Switch	Repair	Repair	II
132511198	K01239	09/08/2013	9:14	09/08/2013	11:07	131	14803	113	Tree related-tree broken	Fuse	Replace - Same Size		VI
132511085	D35002	09/08/2013	9:17	09/08/2013	12:24	4	748	187	Animal related	Fuse	Replace - Same Size		I
132511131	V10551	09/08/2013	9:32	09/08/2013	10:42	1	70	70	Weather	Transformer Fuse	Replace - Same Size		II
132511142	V49541	09/08/2013	9:35	09/08/2013	13:26	1	231	231	Tree related-tree broken	Overhead Primary	Repair		II
132510310	M42107	09/08/2013	9:48	09/08/2013	15:00	15	4680	312	Tree related-tree broken	Pole	Replace - Same Size	Replace - Same Size	I
132511157	N60181	09/08/2013	9:49	09/08/2013	12:15	1	146	146	Tree related-tree broken	Overhead Secondary	Repair	Repair	I
132511164	K75312	09/08/2013	9:54	09/08/2013	10:00	1	6	6	Overhead equipment	Overhead Transformer	Switch/Reset	No Work Required	IV
132511170	R58951	09/08/2013	10:01	09/08/2013	10:50	86	4214	49	Animal related	Fuse	Replace - Same Size	No Work Required	IV
132511184	J01118	09/08/2013	10:08	09/08/2013	13:25	1	197	197	Weather	Fuse	Repair	Replace - Same Size	I
132511191	B84001	09/08/2013	10:14	09/08/2013	11:29	50	3750	75	Underground equipment	Underground Primary	Switch/Reset	Repair	I
132511210	X75571	09/08/2013	10:24	09/08/2013	13:20	14	2464	176	Animal related	Disconnect Switch	Replace - Same Size	Replace - Same Size	IV
132511233	D89003	09/08/2013	10:45	09/08/2013	14:30	1	225	225	Overhead equipment	Overhead Service	Repair		I
132511234	D92001	09/08/2013	10:45	09/08/2013	12:50	70	8750	125	Unknown	Fuse	Replace - Same Size		I
132511236	341003	09/08/2013	10:48	09/08/2013	12:22	1	94	94	Tree related-tree broken	Tree	Cut in Clear		VI
132511320	M42107	09/08/2013	10:52	09/08/2013	12:29	29	2813	97	Tree related-tree broken	Overhead Service	Repair		I
132511308	Z06537	09/08/2013	11:00	09/08/2013	16:00	17	5100	300	Underground equipment	Underground Primary	Repair	Patrol/Test/Inspect	IV
132511264	K67924	09/08/2013	11:01	09/08/2013	12:03	1	62	62	Animal related	Fuse	Replace - Same Size		VI
132511271	P57108	09/08/2013	11:02	09/08/2013	16:05	1	303	303	Overhead equipment	Overhead Transformer	Replace - Same Size	Replace - Same Size	VI
132511274	C15002	09/08/2013	11:04	09/08/2013	12:32	1	88	88	Animal related	Transformer Fuse	Replace - Same Size	No Work Required	III
132511273	Q95247	09/08/2013	11:04	09/08/2013	11:45	1	41	41	Weather	Transformer Fuse	Replace - Same Size		VI
132511285	D93001	09/08/2013	11:13	09/08/2013	12:25	1	72	72	Animal related	Transformer Fuse	Replace - Same Size	Replace - Same Size	IV
132511289	B38002	09/08/2013	11:19	09/08/2013	12:30	1	71	71	Underground equipment				I
132511325		09/08/2013	11:41	09/08/2013	15:15	1	214	214	Overhead equipment				I
132511333	V78001	09/08/2013	11:49	09/08/2013	15:25	1	216	216	Weather	Overhead Transformer	Replace - New Size	Repair	II
132511337	U84534	09/08/2013	11:52	09/08/2013	12:28	1	36	36	Tree related-tree broken	Overhead Secondary	Repair	No Work Required	II
132511567	J01119	09/08/2013	12:05	09/08/2013	17:46	6	2046	341	Animal related	Fuse	Repair	Replace - Same Size	I
132511364	X02547	09/08/2013	12:12	09/08/2013	13:29	1	77	77	Animal related	Transformer Fuse	Replace - Same Size		IV
132511369	K39154	09/08/2013	12:16	09/08/2013	14:11	48	5520	115	Animal related	Fuse	Replace - Same Size		III
132511384	J01118	09/08/2013	12:35	09/08/2013	14:51	1	136	136	Weather	Fuse	Replace - Same Size		I
132511406	U04589	09/08/2013	12:53	09/08/2013	14:05	1	72	72	Weather	Transformer Fuse	Replace - Same Size		II
132511483	M36185	09/08/2013	13:11	09/08/2013	14:40	1	89	89	Tree related-tree broken	Tree	Trim		I
132511487	B38002	09/08/2013	13:14	09/08/2013	16:28	1	194	194	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
132511492	J99151	09/08/2013	13:20	09/08/2013	15:14	1	114	114	Animal related	Fuse	Replace - Same Size		VI
132511500	K71812	09/08/2013	13:30	09/08/2013	16:51	6	1206	201	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	IV
132511505	K39154	09/08/2013	13:37	09/08/2013	14:13	1	36	36	Animal related	Fuse	Replace - Same Size		III
132511547	A26006	09/08/2013	14:48	09/08/2013	15:38	1	50	50	Overhead equipment	Connector	Replace - Same Size		I
132511553	U16522	09/08/2013	14:57	09/08/2013	21:42	1	405	405	Underground equipment	Underground Primary	Repair	Repair	II
132511562	D36001	09/08/2013	15:14	09/08/2013	22:09	1	415	415	Underground equipment	Underground Primary	Repair	Repair	I
132511564	J01118	09/08/2013	15:17	09/08/2013	17:09	1	112	112	Weather	Overhead Service	No Work Required	No Work Required	I
132511580	J01118	09/08/2013	15:53	09/08/2013	16:49	1	56	56	Overhead equipment	Overhead Transformer	Replace - Same Size	Replace - Same Size	I
132511702	V46563	09/08/2013	16:01	09/08/2013	20:40	6	1674	279	Underground equipment	Underground Primary	Repair	No Work Required	II
132511590	L08226	09/08/2013	16:05	09/08/2013	16:09	1	4	4	Tree related-tree contact	Overhead Service	Repair		III

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
132511417	M42105	09/08/2013	16:17	09/08/2013	18:06	1	109	109	Weather	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	I
132511608	U01514	09/08/2013	16:56	09/08/2013	18:44	1	108	108	Weather	Disconnect Switch	Repair		II
132511641	F10002	09/08/2013	17:35	09/08/2013	19:10	4	380	95	Overhead equipment	Lightning Arrestor	Cut in Clear		III
132511629	V92555	09/08/2013	17:38	09/08/2013	18:24	1	46	46	Animal related	Transformer Fuse	Replace - Same Size	Patrol/Test/Inspect	II
132511632	T06505	09/08/2013	17:42	09/08/2013	18:30	1	48	48	Animal related	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
132511633	K71812	09/08/2013	17:47	09/08/2013	18:00	1	13	13	Jurisdictional	Meter	Reconnect	No Work Required	IV
132511651	X29547	09/08/2013	18:24	09/08/2013	19:08	1	44	44	Overhead equipment	Transformer Fuse	Replace - Same Size	No Work Required	IV
132511656	J15303	09/08/2013	18:32	09/08/2013	19:41	1	69	69	Animal related	Fuse	Replace - Same Size		I
132511681	J47178	09/08/2013	19:04	09/08/2013	20:25	1	81	81	Other	Underground Secondary	Repair		III
132511682	Q63835	09/08/2013	19:07	09/08/2013	20:55	4	432	108	Overhead equipment	Overhead Transformer		Replace - Same Size	V
132511684	D66002	09/08/2013	19:11	09/08/2013	20:10	1	59	59	Overhead equipment	Transformer Fuse			IV
132511688	B84001	09/08/2013	19:17	09/08/2013	19:23	13	78	6	Underground equipment				I
132511712	R05115	09/08/2013	19:57	09/08/2013	20:24	7	189	27	Overhead equipment	Transformer Fuse	Replace - Same Size		I
132511715	U05001	09/08/2013	20:01	09/09/2013	4:00	1	479	479	Weather	Overhead Transformer	Replace - Same Size		II
132511738	E10001	09/08/2013	20:21	09/08/2013	21:24	14	882	63	Other	Recloser	Switch/Reset		III
132511736	S86582	09/08/2013	20:27	09/08/2013	23:13	1	166	166	Animal related	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
132511743	V59002	09/08/2013	20:34	09/08/2013	21:54	1	80	80	Weather	Transformer Fuse	Replace - Same Size		II
132511776	341002	09/08/2013	21:55	09/08/2013	22:22	1	27	27	Tree related-tree broken	Overhead Service	Cut in Clear		VI
132520079	L12125	09/09/2013	0:11	09/09/2013	7:20	56	24024	429	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	III
132523764	K27150	09/09/2013	4:02	09/09/2013	7:50	62	14136	228	Underground equipment	Underground Transformer	Repair	Repair	VI
132523782	M36184	09/09/2013	5:44	09/09/2013	11:00	2	632	316	Other	Underground Primary	Repair	Repair	I
132523786	J06168	09/09/2013	5:50	09/09/2013	13:28	5	2290	458	Other	Underground Primary	Repair	Repair	I
132523824	R58931	09/09/2013	7:00	09/09/2013	9:02	8	976	122	Tree related-tree contact	Overhead Service	Repair		IV
132523826	N70330	09/09/2013	7:10	09/09/2013	9:43	6	918	153	Animal related	Overhead Primary	Repair		I
132523863	P82291	09/09/2013	7:14	09/09/2013	8:45	1	91	91	Animal related	Animal Guard	Install	Replace - Same Size	VI
132523876	Q67938	09/09/2013	7:18	09/09/2013	7:58	1	40	40	Weather	Recloser	Replace - Same Size		VI
132523886	Q67938	09/09/2013	7:23	09/09/2013	8:30	1	67	67	Weather	Recloser	Replace - Same Size		VI
132523970	K27150	09/09/2013	7:39	09/09/2013	7:48	43	387	9	Underground equipment	Underground Transformer	Repair	Repair	VI
132523955	Q67938	09/09/2013	7:40	09/09/2013	8:25	1	45	45	Weather	Recloser	Replace - Same Size		VI
132524046	M37192	09/09/2013	8:00	09/09/2013	8:52	38	1976	52	Animal related	Overhead Transformer	Switch/Reset		I
132524061	L59929	09/09/2013	8:11	09/09/2013	9:12	1	61	61	Tree related-tree broken	Overhead Service	Repair		VI
132524285	Y68581	09/09/2013	8:14	09/09/2013	10:26	10	1320	132	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	IV
132524099	X42501	09/09/2013	8:21	09/09/2013	9:40	1	79	79	Animal related	Transformer Fuse	Replace - Same Size		IV
132524211	338003	09/09/2013	8:49	09/09/2013	9:09	1	20	20	Public	Meter	Patrol/Test/Inspect		VI
132524874	C15002	09/09/2013	9:04	09/09/2013	14:10	1	306	306	Underground equipment	Underground Primary	Repair		III
132524403	C15002	09/09/2013	9:04	09/09/2013	10:48	5	520	104	Underground equipment	Underground Primary	Switch/Reset		III
132524284	M37192	09/09/2013	9:05	09/09/2013	9:52	1	47	47	Animal related	Overhead Transformer	Switch/Reset		I
132524329	X75571	09/09/2013	9:11	09/09/2013	10:55	1	104	104	Animal related	Transformer Fuse	Replace - Same Size	Replace - Same Size	IV
132524362	U68581	09/09/2013	9:14	09/09/2013	9:47	35	1155	33	Other	Recloser	Switch/Reset		II
132524545	R95520	09/09/2013	9:31	09/09/2013	10:32	74	4514	61	Unknown	Recloser	Patrol/Test/Inspect		I
132524735	C10002	09/09/2013	10:27	09/09/2013	10:55	1	28	28	Overhead equipment	Transformer Fuse	Replace - Same Size		III
132524741	R34921	09/09/2013	10:28	09/09/2013	11:19	1	51	51	Weather	Transformer Fuse	Replace - Same Size	No Work Required	VI
132524767	J13108	09/09/2013	10:32	09/09/2013	11:39	1	67	67	Overhead equipment	Transformer Fuse	Replace - Same Size		I
132524906	A17026	09/09/2013	11:01	09/09/2013	15:03	1	242	242	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
132525100	H14342	09/09/2013	11:43	09/09/2013	16:04	1	261	261	Weather	Transformer Fuse	Replace - Same Size		V
132525169	L86175	09/09/2013	11:58	09/09/2013	14:00	19	2318	122	Underground equipment	Underground Primary	Switch/Reset	Switch/Reset	IV
132525486	N54107	09/09/2013	13:22	09/09/2013	15:35	1	133	133	Overhead equipment	Overhead Transformer	Replace - Same Size		II
132525504	X64501	09/09/2013	13:26	09/09/2013	14:13	1	47	47	Overhead equipment	Disconnect Switch	Replace - Same Size		IV
132525539	J07135	09/09/2013	13:35	09/09/2013	14:01	1	26	26	Overhead equipment				I
132525542	U37002	09/09/2013	13:36	09/09/2013	15:10	7	658	94	Overhead equipment	Overhead Transformer	Replace - New Size	Patrol/Test/Inspect	II
132525603	U99515	09/09/2013	13:49	09/09/2013	14:44	8	440	55	Unknown	Transformer Fuse	Replace - Same Size		II
132525606	K30204	09/09/2013	13:50	09/09/2013	15:03	1	73	73	Unknown	Transformer Fuse	Replace - Same Size		III
132525621	R05115	09/09/2013	13:54	09/09/2013	15:34	3	300	100	Overhead equipment	Overhead Transformer	Replace - Same Size	Replace - Same Size	I
132525650	M25143	09/09/2013	13:59	09/09/2013	15:32	2	186	93	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
132525663	A17026	09/09/2013	14:01	09/09/2013	20:28	1	387	387	Overhead equipment	Connector	Patrol/Test/Inspect	Repair	I
132525727	J07135	09/09/2013	14:15	09/09/2013	14:18	1	3	3	Overhead equipment				I

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
132525862	Y10012	09/09/2013	14:41	09/09/2013	15:35	2	108	54	Overhead equipment	Transformer Fuse	Repair	Repair	IV
132525901	B38001	09/09/2013	14:48	09/09/2013	18:57	1	249	249	Public	Pedestal	Repair	Repair	I
132525904	Z51551	09/09/2013	14:50	09/09/2013	19:00	1	250	250	Underground equipment	Underground Transformer	Repair	Patrol/Test/Inspect	IV
132525932	S79510	09/09/2013	14:50	09/09/2013	17:40	66	11220	170	Overhead equipment	Regulator		Repair	VI
132525987	J01118	09/09/2013	15:07	09/09/2013	16:40	1	93	93	Weather	Transformer Fuse	Replace - Same Size		I
132526029	Q74148	09/09/2013	15:17	09/09/2013	15:53	1	36	36	Unknown	Transformer Fuse	Replace - Same Size		IV
132526073	305132	09/09/2013	15:28	09/09/2013	16:10	1	42	42	Overhead equipment	Fuse	Repair		V
132526150	Q95248	09/09/2013	15:47	09/09/2013	16:31	1	44	44	Overhead equipment	Transformer Fuse	Replace - Same Size		VI
132526156	B82001	09/09/2013	15:48	09/09/2013	17:55	4	508	127	Overhead equipment	Overhead Transformer	Replace - Same Size	Repair	I
132526218	Q27186	09/09/2013	16:04	09/09/2013	19:51	1	227	227	Overhead equipment	Overhead Transformer	Replace - Same Size	Replace - Same Size	VI
132526374	X96523	09/09/2013	16:53	09/09/2013	18:15	1	82	82	Overhead equipment	Overhead Service			IV
132527590	B84002	09/09/2013	17:01	09/09/2013	23:59	10	4180	418	Underground equipment	Underground Transformer	Replace - Same Size		I
132526401	B84002	09/09/2013	17:01	09/09/2013	20:25	76	15504	204	Underground equipment	Underground Primary	Switch/Reset	Repair	I
132526460	R33126	09/09/2013	17:36	09/09/2013	18:03	1	27	27	Overhead equipment	Fuse	Replace - Same Size	Patrol/Test/Inspect	I
132526472	Y64011	09/09/2013	17:42	09/09/2013	18:51	6	414	69	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
132526491	N35851	09/09/2013	17:49	09/09/2013	19:07	1	78	78	Animal related	Transformer Fuse	Replace - Same Size		V
132526543	N54214	09/09/2013	18:22	09/09/2013	19:30	6	408	68	Overhead equipment	Overhead Transformer	Switch/Reset	Replace - New Size	II
132526552	P98190	09/09/2013	18:24	09/09/2013	19:05	10	410	41	Animal related	Overhead Transformer			III
132527942	Q34360	09/09/2013	19:13	09/10/2013	2:30	9	3933	437	Public	Pole	Replace - Same Size		I
132527523	Q34360	09/09/2013	19:13	09/09/2013	23:00	20	4540	227	Public	Pole	Replace - Same Size		I
132526836	U31565	09/09/2013	19:17	09/09/2013	20:51	58	5452	94	Underground equipment	Underground Primary	Switch/Reset	Repair	II
132526059	D87001	09/09/2013	19:24	09/10/2013	2:03	1	399	399	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Repair	I
132527501	303004	09/09/2013	19:29	09/10/2013	4:19	5	2650	530	Tree related-tree broken	Overhead Transformer		Repair	VI
132527515	303004	09/09/2013	19:36	09/09/2013	21:15	4	396	99	Tree related-tree broken	Pole	Patrol/Test/Inspect	Replace - Same Size	VI
132527913	M73328	09/09/2013	19:50	09/10/2013	1:00	169	52390	310	Overhead equipment	Jumper	Patrol/Test/Inspect	Repair	V
132527550	R07382	09/09/2013	19:58	09/09/2013	21:09	4	284	71	Tree related-tree contact	Overhead Secondary	Repair		I
132527579	P98190	09/09/2013	20:17	09/09/2013	23:46	28	5852	209	Underground equipment	Other			III
132527594	D32211	09/09/2013	20:42	09/10/2013	5:12	1	510	510	Underground equipment	Underground Primary	Repair	Repair	I
132527924	R61241	09/09/2013	22:08	09/10/2013	0:52	52	8528	164	Underground equipment	Underground Primary	Switch/Reset	Repair	IV
132527935	U52516	09/09/2013	22:32	09/10/2013	0:31	7	833	119	Overhead equipment	Jumper	Repair		II
132527953	Z29579	09/09/2013	23:43	09/10/2013	2:26	6	978	163	Animal related	Disconnect Switch		Install	IV
132527961	M54406	09/09/2013	23:57	09/10/2013	1:00	3	189	63	Other	Transformer Fuse	Repair		V
132530109	M05361	09/10/2013	0:05	09/10/2013	4:55	1	290	290	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	V
132530177	K76542	09/10/2013	0:43	09/10/2013	2:57	37	4958	134	Underground equipment	Underground Primary	Switch/Reset	Repair	IV
132532556	A49002	09/10/2013	1:11	09/10/2013	4:55	11	2464	224	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - New Size	I
132532583	D89001	09/10/2013	1:36	09/10/2013	3:39	41	5043	123	Underground equipment	Underground Primary	Switch/Reset	Repair	I
132532600	M73328	09/10/2013	2:02	09/10/2013	4:42	12	1920	160	Overhead equipment	Transformer Fuse	Replace - Same Size		V
132532618	J83138	09/10/2013	2:57	09/10/2013	5:10	37	4921	133	Overhead equipment	Fuse			VI
132534254	P62112	09/10/2013	4:11	09/10/2013	5:27	1	76	76	Tree related-tree broken	Overhead Secondary	Repair	Repair	VI
132534306	N67309	09/10/2013	5:25	09/10/2013	6:49	4	336	84	Animal related	Transformer Fuse	Replace - Same Size		I
132534268	D39002	09/10/2013	5:27	09/10/2013	7:01	1	94	94	Animal related	Fuse	Replace - Same Size		I
132534270	P44324	09/10/2013	5:35	09/10/2013	7:46	1	131	131	Animal related	Fuse	Replace - Same Size		I
132534273	N60181	09/10/2013	5:53	09/10/2013	6:43	3	150	50	Overhead equipment	Transformer Fuse	Replace - Same Size		I
132534297	T08502	09/10/2013	6:14	09/10/2013	13:34	2	880	440	Underground equipment	Underground Primary	Repair		VI
132534374	P69173	09/10/2013	7:05	09/10/2013	8:44	27	2673	99	Underground equipment	Underground Primary		Repair	III
132534490	J14142	09/10/2013	7:55	09/10/2013	8:40	1	45	45	Animal related	Fuse	Repair	Repair	VI
132534508	X96543	09/10/2013	7:59	09/10/2013	10:30	1	151	151	Overhead equipment	Overhead Primary			IV
132534534	B82001	09/10/2013	8:12	09/10/2013	9:13	1	61	61	Overhead equipment	Overhead Service	Repair		I
132534585	Q06144	09/10/2013	8:26	09/10/2013	9:29	8	504	63	Public	Fuse	Replace - Same Size	No Work Required	IV
132534663	B71002	09/10/2013	8:48	09/10/2013	11:39	1	171	171	Overhead equipment	Overhead Service	Repair		I
132534787	X96543	09/10/2013	9:15	09/10/2013	9:55	1	40	40	Overhead equipment	Transformer Fuse			IV
132534843	R05186	09/10/2013	9:24	09/10/2013	9:40	38	608	16	Jurisdictional				I
132534865	P20930	09/10/2013	9:32	09/10/2013	10:43	1	71	71	Animal related	Fuse	Replace - Same Size		VI
132534888	D36002	09/10/2013	9:37	09/10/2013	10:19	1	42	42	Overhead equipment	Fuse	Repair		I
132534901	K30205	09/10/2013	9:39	09/10/2013	10:15	1	36	36	Unknown	Transformer Fuse	Replace - Same Size		III
132534943	J99141	09/10/2013	9:48	09/10/2013	10:30	2	84	42	Animal related	Transformer Fuse	Replace - Same Size		VI

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
132534961	V79512	09/10/2013	9:51	09/10/2013	11:18	1	87	87	Overhead equipment	Overhead Service			II
132535086	J15302	09/10/2013	10:16	09/10/2013	11:35	1	79	79	Animal related	Transformer Fuse	Replace - Same Size		I
132535132	J12166	09/10/2013	10:22	09/10/2013	12:25	1	123	123	Tree related-tree contact	Tree	Trim		III
132535245	D89002	09/10/2013	10:29	09/10/2013	11:39	13	910	70	Public	Underground Primary	Repair	No Work Required	I
132535375		09/10/2013	11:13	09/10/2013	12:22	1	69	69	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
132535859	D89003	09/10/2013	12:00	09/10/2013	14:15	164	22140	135	Public	Overhead Primary	Repair	No Work Required	I
132535733	U99515	09/10/2013	12:40	09/10/2013	13:00	1	20	20	Overhead equipment				II
132535759	B25002	09/10/2013	12:45	09/10/2013	14:22	1	97	97	Animal related	Transformer Fuse	Replace - Same Size	No Work Required	I
132535925	K39154	09/10/2013	13:17	09/10/2013	17:00	33	7359	223	Underground equipment	Underground Primary	Switch/Reset	Repair	III
132535879	S09520	09/10/2013	13:19	09/10/2013	15:15	7	812	116	Overhead equipment				VI
132536099	D90003	09/10/2013	14:07	09/10/2013	14:42	1	35	35	Overhead equipment	Connector			III
132536166	Z10501	09/10/2013	14:22	09/10/2013	15:30	3	204	68	Overhead equipment	Overhead Service			IV
132536195	A97006	09/10/2013	14:30	09/10/2013	17:35	1	185	185	Underground equipment	Underground Primary		Repair	I
132536220	Y60593	09/10/2013	14:37	09/10/2013	19:00	1	263	263	Overhead equipment	Overhead Transformer	Replace - Same Size	Repair	IV
132536250	E10003	09/10/2013	14:49	09/10/2013	15:34	1	45	45	Other	Overhead Service	No Work Required		III
132536323	S86580	09/10/2013	15:11	09/10/2013	16:45	1	94	94	Overhead equipment	Tree	Patrol/Test/Inspect	Cut in Clear	VI
132536321	J86108	09/10/2013	15:11	09/10/2013	19:37	3	798	266	Overhead equipment	Overhead Transformer		Replace - Same Size	VI
132536382	J01119	09/10/2013	15:24	09/10/2013	16:29	22	1430	65	Underground equipment	Underground Primary	Switch/Reset		I
132536415	R07381	09/10/2013	15:26	09/10/2013	17:35	16	2064	129	Overhead equipment	Overhead Secondary	Repair	Repair	I
132536400	J01119	09/10/2013	15:27	09/10/2013	17:06	12	1188	99	Underground equipment	Underground Primary	Repair	Repair	I
132536470	K46388	09/10/2013	15:56	09/10/2013	18:00	1	124	124	Other	Overhead Service	Reconnect		V
132536472	X77001	09/10/2013	15:56	09/10/2013	16:23	12	324	27	Unknown	Transformer Fuse	Replace - Same Size		IV
132536486	303001	09/10/2013	15:58	09/10/2013	16:35	42	1554	37	Other	Fuse	Replace - Same Size		VI
132536681	S28551	09/10/2013	17:18	09/10/2013	18:20	1	62	62	Overhead equipment	Disconnect Switch	Replace - New Size		VI
132536710	X62031	09/10/2013	17:23	09/10/2013	18:35	49	3528	72	Overhead equipment	Fuse	Replace - Same Size		IV
132536715	R84148	09/10/2013	17:27	09/10/2013	19:09	1	102	102	Overhead equipment	Connector	Replace - Same Size		I
132536719	X52537	09/10/2013	17:29	09/10/2013	19:00	1	91	91	Tree related-tree broken	Overhead Service	Tie/Tighten		IV
132537027	K89142	09/10/2013	18:07	09/10/2013	18:56	155	7595	49	Tree related-tree broken	Pole	Repair	Repair	III
132537278	K89142	09/10/2013	18:15	09/11/2013	3:36	4	2244	561	Tree related-tree broken	Pole	Repair		III
132537403	345002	09/10/2013	18:39	09/10/2013	20:10	1	91	91	Tree related-tree broken	Tree	Cut in Clear		VI
132537993	A68001	09/10/2013	19:05	09/10/2013	20:18	1	73	73	Animal related	Transformer Fuse	Replace - Same Size		I
132537994	P12290	09/10/2013	19:05	09/10/2013	20:34	1	89	89	Other	Fuse	Replace - Same Size		V
132538132	K73362	09/10/2013	19:27	09/10/2013	22:10	2	326	163	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	IV
132538026	P62138	09/10/2013	19:29	09/10/2013	20:39	2	140	70	Public	Fuse	Replace - Same Size		VI
132538025	D88001	09/10/2013	19:30	09/10/2013	22:27	25	4425	177	Overhead equipment	Overhead Primary	Patrol/Test/Inspect	Repair	I
132538022	P47169	09/10/2013	19:32	09/10/2013	20:20	1	48	48	Tree related-tree contact	Overhead Service	Repair		I
132538045	S02502	09/10/2013	20:00	09/10/2013	20:30	1	30	30	Jurisdictional				VI
132538051		09/10/2013	20:04	09/10/2013	22:28	1	144	144	Overhead equipment	Overhead Primary	Replace - Same Size		I
132538087	L42158	09/10/2013	21:15	09/10/2013	23:49	1	154	154	Tree related-tree contact	Overhead Service	Repair		III
132538089	S53542	09/10/2013	21:16	09/10/2013	21:20	129	516	4	Other	Recloser			VI
132538127	D35002	09/10/2013	21:30	09/10/2013	23:55	103	14935	145	Overhead equipment	Fuse	Replace - Same Size		I
132538114	X29547	09/10/2013	21:53	09/10/2013	23:30	108	10476	97	Overhead equipment	Fuse	Repair	Replace - Same Size	IV
132538122	K01241	09/10/2013	22:15	09/11/2013	0:11	13	1508	116	Underground equipment	Underground Primary			VI
132538138	B62003	09/10/2013	22:51	09/11/2013	6:20	23	10327	449	Underground equipment	Underground Primary	Patrol/Test/Inspect	Replace - Urgent	I
132556653	L74193	09/10/2013	23:21	09/12/2013	16:30	7	17283	2469	Public				IV
132540107	M37191	09/11/2013	0:15	09/11/2013	1:03	1	48	48	Overhead equipment	Overhead Service	Repair		I
132540112	C00001	09/11/2013	1:09	09/11/2013	6:18	1	309	309	Underground equipment	Underground Primary		Repair	I
132540135	C40001	09/11/2013	2:16	09/11/2013	5:20	68	12512	184	Underground equipment	Underground Primary		Repair	I
132540150	D92001	09/11/2013	2:37	09/11/2013	5:53	65	12740	196	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
132540145	R07382	09/11/2013	2:37	09/11/2013	4:22	12	1260	105	Overhead equipment	Lightning Arrestor	Replace - Same Size		I
132543768	V18553	09/11/2013	4:46	09/11/2013	6:19	3	279	93	Unknown	Transformer Fuse	Replace - Same Size		II
132543772	L59933	09/11/2013	5:24	09/11/2013	6:17	1	53	53	Animal related	Transformer Fuse	Replace - Same Size	No Work Required	VI
132543820	Y04504	09/11/2013	6:45	09/11/2013	7:30	1	45	45	Animal related	Transformer Fuse	Replace - Same Size		IV
132543844	N44215	09/11/2013	7:04	09/11/2013	8:09	1	65	65	Unknown	Transformer Fuse	Replace - Same Size		III
132543900	Y37592	09/11/2013	7:18	09/11/2013	8:20	83	5146	62	Overhead equipment	Fuse			IV
132543915	Y20522	09/11/2013	7:26	09/11/2013	8:55	5	445	89	Animal related	Fuse	Patrol/Test/Inspect	Replace - Same Size	IV

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
132544143	313136	09/11/2013	8:35	09/11/2013	9:14	5	195	39	Public	Underground Secondary	Patrol/Test/Inspect	Repair	V
132544220	P57108	09/11/2013	8:54	09/11/2013	10:30	1	96	96	Animal related	Transformer Fuse			VI
132544309		09/11/2013	9:16	09/11/2013	10:03	1	47	47	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
132544342	D31015	09/11/2013	9:25	09/11/2013	10:23	1	58	58	Overhead equipment	Other	Patrol/Test/Inspect	Patrol/Test/Inspect	III
132544391	M36185	09/11/2013	9:40	09/11/2013	9:46	1	6	6	Overhead equipment	Overhead Service	No Work Required		I
132544429	R93350	09/11/2013	9:50	09/11/2013	11:04	1	74	74	Overhead equipment	Fuse	Replace - Same Size		V
132544497	M36185	09/11/2013	10:03	09/11/2013	10:41	1	38	38	Overhead equipment	Overhead Service	No Work Required		I
132544618	R06209	09/11/2013	10:11	09/11/2013	12:00	1	109	109	Overhead equipment	Connector	Repair		II
132544599	R65451	09/11/2013	10:29	09/11/2013	11:55	6	516	86	Overhead equipment	Fuse	Replace - Same Size		IV
132544620	X91511	09/11/2013	10:33	09/11/2013	11:29	1	56	56	Animal related	Transformer Fuse	Repair	Replace - Same Size	IV
132544631		09/11/2013	10:35	09/11/2013	10:53	1	18	18	Other	Meter	Reconnect		I
132544809	N05170	09/11/2013	11:10	09/11/2013	12:58	18	1944	108	Tree related-tree contact	Overhead Primary	Patrol/Test/Inspect	Repair	I
132544812	V13510	09/11/2013	11:13	09/11/2013	12:51	1	98	98	Tree related-tree broken	Overhead Service	Repair		II
132544839	Y86595	09/11/2013	11:18	09/11/2013	13:35	1	137	137	Overhead equipment	Lightning Arrestor	Replace - Same Size	Replace - Same Size	IV
132544886	M36185	09/11/2013	11:21	09/11/2013	12:29	31	2108	68	Animal related	Overhead Transformer	Switch/Reset		I
132544985	Y79503	09/11/2013	11:54	09/11/2013	11:58	33	132	4	Substation equipment	Substation Breaker			IV
132545059	K73362	09/11/2013	12:10	09/11/2013	14:00	9	990	110	Tree related-tree broken	Fuse	Replace - Same Size		IV
132545077	U84587	09/11/2013	12:17	09/11/2013	18:00	1	343	343	Underground equipment	Underground Primary	Repair		II
132545170	P73160	09/11/2013	12:54	09/11/2013	13:50	1	56	56	Animal related	Fuse	Replace - Same Size		VI
132545198	J34377	09/11/2013	12:59	09/11/2013	15:23	1	144	144	Overhead equipment	Connector	Replace - New Size		V
132545221	J71128	09/11/2013	13:03	09/11/2013	13:30	1	27	27	Other				I
132545227	N05170	09/11/2013	13:06	09/11/2013	13:44	1	38	38	Tree related-tree contact	Customer Equipment	Patrol/Test/Inspect		I
132545253	Y37592	09/11/2013	13:11	09/11/2013	14:00	1	49	49	Overhead equipment	Fuse	Repair		IV
132545335	C50001	09/11/2013	13:31	09/11/2013	14:22	1	51	51	Animal related	Transformer Fuse	Replace - Same Size		III
132545490	R05186	09/11/2013	13:48	09/11/2013	15:20	28	2576	92	Underground equipment	Underground Primary	Replace - Same Size	Replace - Same Size	I
132545807	B57001	09/11/2013	15:25	09/11/2013	17:38	1	133	133	Overhead equipment				I
132547090	Q54908	09/11/2013	15:48	09/11/2013	23:30	4	1848	462	Overhead equipment	Pole	Replace - Same Size	Replace - Same Size	VI
132545878	Q54908	09/11/2013	15:48	09/11/2013	22:40	33	13596	412	Overhead equipment	Pole	Cut in Clear	Replace - New Size	VI
132545922	D55002	09/11/2013	16:05	09/11/2013	21:30	1	325	325	Underground equipment	Underground Primary		Repair	I
132546926	J12166	09/11/2013	17:33	09/11/2013	20:06	2	306	153	Overhead equipment	Fuse	Replace - Same Size		III
132546920	J12166	09/11/2013	17:33	09/11/2013	19:56	42	6006	143	Overhead equipment	Overhead Transformer			III
132546113	J12166	09/11/2013	17:33	09/11/2013	19:56	76	10868	143	Overhead equipment	Overhead Transformer	Switch/Reset		III
132546117	B62003	09/11/2013	17:35	09/11/2013	18:27	37	1924	52	Unknown				I
132546125	J82116	09/11/2013	17:43	09/11/2013	18:33	1	50	50	Tree related-tree contact	Overhead Service	Repair		VI
132546932	K52400	09/11/2013	19:49	09/11/2013	22:43	28	4872	174	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	V
132546949	Q69926	09/11/2013	20:16	09/11/2013	21:20	1	64	64	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	VI
132546958	U60559	09/11/2013	20:18	09/11/2013	22:20	44	5368	122	Tree related-tree contact	Fuse	Replace - Same Size		II
132546961	P57108	09/11/2013	20:27	09/11/2013	21:32	1	65	65	Overhead equipment	Connector	Repair		VI
132546981	J76804	09/11/2013	20:48	09/12/2013	2:30	1	342	342	Underground equipment	Underground Primary	Repair	Repair	V
132546986	L23146	09/11/2013	20:54	09/11/2013	21:45	1	51	51	Tree related-tree contact	Overhead Service	Repair		III
132547101	X77736	09/11/2013	20:54	09/11/2013	23:21	1	147	147	Overhead equipment	Pole	Repair		IV
132547005	X77736	09/11/2013	20:54	09/11/2013	23:24	1333	199950	150	Overhead equipment				IV
132547107	X42502	09/11/2013	21:04	09/12/2013	12:18	9	8226	914	Overhead equipment	Pole	Replace - Same Size	Replace - Same Size	IV
132547109	X42502	09/11/2013	21:04	09/11/2013	23:36	379	57608	152	Overhead equipment	Pole	Switch/Reset		IV
132547099	D35001	09/11/2013	23:15	09/12/2013	1:15	43	5160	120	Overhead equipment	Fuse	Replace - Same Size		I
132550145	L93149	09/12/2013	0:50	09/12/2013	3:20	39	5850	150	Other	Fuse	Replace - Same Size		VI
132550146	X82576	09/12/2013	0:58	09/12/2013	2:17	1	79	79	Tree related-tree contact	Overhead Service	Repair		IV
132550204	B58001	09/12/2013	2:13	09/12/2013	4:14	128	15488	121	Overhead equipment	Disconnect Switch		Repair	I
132553649	L93149	09/12/2013	3:36	09/12/2013	4:00	102	2448	24	Underground equipment	Underground Primary	Switch/Reset		VI
132553645	P69174	09/12/2013	3:42	09/12/2013	5:20	133	13034	98	Unknown	Recloser	Switch/Reset		III
132553646	V40549	09/12/2013	3:47	09/12/2013	6:20	4	612	153	Overhead equipment	Disconnect Switch	Replace - Same Size	Replace - Same Size	II
132553661	S01511	09/12/2013	4:19	09/12/2013	15:40	26	17706	681	Underground equipment	Underground Primary			VI
132553671	R06209	09/12/2013	5:13	09/12/2013	6:11	20	1160	58	Weather	Fuse	Replace - Same Size	No Work Required	II
132553760	P69174	09/12/2013	5:36	09/12/2013	6:45	25	1725	69	Underground equipment	Underground Primary	Switch/Reset		III
132553704	A45003	09/12/2013	6:07	09/12/2013	10:50	2	566	283	Overhead equipment	Disconnect Switch	Replace - Same Size		I
132553678	P69174	09/12/2013	6:19	09/12/2013	7:45	13	1118	86	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	III

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
132553718	K08909	09/12/2013	6:26	09/12/2013	9:23	2	354	177	Tree related-tree contact	Overhead Primary	Repair	Repair	VI
132553739	X12002	09/12/2013	6:53	09/12/2013	7:39	1	46	46	Overhead equipment	Substation Breaker	Patrol/Test/Inspect	Advise Customer	IV
132553773	R84148	09/12/2013	7:13	09/12/2013	8:15	1	62	62	Animal related	Fuse	Patrol/Test/Inspect	Replace - Same Size	I
132553802	K89141	09/12/2013	7:19	09/12/2013	7:44	1	25	25	Overhead equipment	Fuse	Replace - Same Size		III
132553853	G30001	09/12/2013	7:46	09/12/2013	8:40	1	54	54	Overhead equipment	Transformer Fuse	Replace - Same Size		III
132553864	Z11506	09/12/2013	7:49	09/12/2013	9:03	2	148	74	Overhead equipment	Transformer Fuse	Replace - Same Size	No Work Required	IV
132553884	B76003	09/12/2013	7:57	09/12/2013	9:44	1	107	107	Unknown	Fuse	Replace - Same Size		I
132554026	H01190	09/12/2013	8:30	09/12/2013	9:50	23	1840	80	Unknown	Fuse	Replace - Same Size		III
132554721	D90004	09/12/2013	8:39	09/12/2013	10:55	90	12240	136	Tree related-tree contact	Other	Patrol/Test/Inspect	Patrol/Test/Inspect	III
132554111	V77543	09/12/2013	8:53	09/12/2013	9:32	4	156	39	Animal related	Transformer Fuse	Replace - Same Size		II
132554137	302004	09/12/2013	8:55	09/12/2013	10:22	4	348	87	Tree related-tree broken	Tree	Remove		VI
132554195	N70330	09/12/2013	9:15	09/12/2013	9:58	21	903	43	Animal related	Transformer Fuse	Replace - Same Size		I
132554261	L82187	09/12/2013	9:26	09/12/2013	12:09	1	163	163	Animal related	Overhead Transformer			IV
132554280	Q69926	09/12/2013	9:29	09/12/2013	9:42	1	13	13	Animal related	Fuse	Replace - Same Size	Replace - Same Size	VI
132554333	U84587	09/12/2013	9:39	09/12/2013	15:53	1	374	374	Underground equipment	Underground Primary	Replace - Same Size		II
132554340	X88510	09/12/2013	9:41	09/12/2013	11:02	1	81	81	Animal related	Transformer Fuse	Replace - Same Size		IV
132554385	U33509	09/12/2013	9:43	09/12/2013	16:37	53	21942	414	Underground equipment	Underground Primary	Repair	Repair	II
132554410	Y35515	09/12/2013	9:54	09/12/2013	10:30	1	36	36	Animal related	Transformer Fuse	Replace - Same Size		IV
132554480	S31529	09/12/2013	9:57	09/12/2013	11:36	22	2178	99	Public	Overhead Service	Replace - Same Size		VI
132554479	B45005	09/12/2013	10:01	09/12/2013	13:36	31	6665	215	Tree related-tree broken	Tree	Repair	Repair	I
132554483	Y37592	09/12/2013	10:06	09/12/2013	10:47	10	410	41	Animal related	Transformer Fuse	Replace - Same Size		IV
132554511	Q36410	09/12/2013	10:07	09/12/2013	11:05	33	1914	58	Animal related	Fuse	Replace - Same Size	Repair	I
132554548	A80001	09/12/2013	10:13	09/12/2013	16:25	1	372	372	Underground equipment	Underground Primary		Repair	I
132554735	M36189	09/12/2013	10:39	09/12/2013	11:44	1	65	65	Underground equipment	Underground Service	No Work Required		I
132554740	J88165	09/12/2013	10:40	09/12/2013	11:53	1	73	73	Overhead equipment				VI
132554924	U37579	09/12/2013	11:18	09/12/2013	14:00	1	162	162	Overhead equipment	Transformer Fuse	Replace - Same Size		II
132554981	R07382	09/12/2013	11:28	09/12/2013	12:44	1	76	76	Overhead equipment	Connector	Replace - Same Size	Repair	I
132555157	D89002	09/12/2013	12:01	09/12/2013	13:40	1	99	99	Overhead equipment	Connector	Repair		I
132555578		09/12/2013	12:14	09/12/2013	13:01	306	14382	47	Animal related				III
132555485		09/12/2013	12:14	09/12/2013	13:01	178	8366	47	Animal related				III
132555703	Q09370	09/12/2013	12:14	09/12/2013	13:01	3137	147439	47	Animal related				III
132555694	Q09377	09/12/2013	12:14	09/12/2013	13:01	5067	238149	47	Animal related				III
132555391	Y68581	09/12/2013	12:20	09/12/2013	13:52	1	92	92	Overhead equipment	Disconnect Switch		Install	IV
132555522	L17101	09/12/2013	12:22	09/12/2013	13:04	1	42	42	Overhead equipment	Overhead Service	No Work Required		III
132555679	B68004	09/12/2013	12:36	09/12/2013	13:40	1	64	64	Other	Other	Patrol/Test/Inspect	Patrol/Test/Inspect	III
132555846	B93002	09/12/2013	12:53	09/12/2013	13:41	5	240	48	Unknown	Fuse	Replace - Same Size		I
132555777	U99593	09/12/2013	12:54	09/12/2013	14:06	1	72	72	Animal related	Transformer Fuse	Replace - Same Size		II
132555787	X66582	09/12/2013	12:57	09/12/2013	13:54	1	57	57	Animal related	Transformer Fuse	Replace - Same Size		IV
132556096	S04545	09/12/2013	13:50	09/12/2013	15:53	1	123	123	Overhead equipment	Fuse	Patrol/Test/Inspect	Repair	VI
132556372	U84566	09/12/2013	14:29	09/12/2013	14:57	2	56	28	Animal related	Transformer Fuse	Replace - Same Size		II
132556359	N35852	09/12/2013	14:37	09/12/2013	16:35	5	590	118	Overhead equipment	Overhead Primary			V
132556770	Q64939	09/12/2013	14:52	09/12/2013	16:16	2	168	84	Animal related	Fuse	Replace - Same Size		VI
132556478	U41596	09/12/2013	14:59	09/12/2013	18:00	1	181	181	Jurisdictional	Underground Primary	Repair		II
132556576	Q82906	09/12/2013	15:18	09/12/2013	16:47	1	89	89	Overhead equipment	Fuse			VI
132556687	B25002	09/12/2013	15:24	09/12/2013	16:50	39	3354	86	Overhead equipment	Fuse	Replace - Same Size	No Work Required	I
132556612	M18131	09/12/2013	15:26	09/12/2013	20:40	15	4710	314	Public	Pole		Replace - Same Size	III
132556646	U60518	09/12/2013	15:34	09/12/2013	16:39	2	130	65	Animal related	Transformer Fuse	Replace - Same Size		II
132556706	S25552	09/12/2013	15:48	09/12/2013	17:45	1	117	117	Tree related-tree broken	Overhead Primary	Patrol/Test/Inspect	Repair	VI
132556881	U02597	09/12/2013	16:28	09/12/2013	17:25	2	114	57	Animal related	Animal Guard	Install		II
132557009	L95110	09/12/2013	17:05	09/12/2013	18:29	7	588	84	Animal related	Fuse	Repair		III
132557043	K89144	09/12/2013	17:11	09/12/2013	18:15	34	2176	64	Unknown	Fuse	Replace - Same Size		III
132557194	D31016	09/12/2013	18:15	09/12/2013	19:46	1	91	91	Overhead equipment	Overhead Service	Replace - New Size	Repair	III
132557232	B73002	09/12/2013	18:28	09/13/2013	2:18	2	940	470	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
132557328	X86543	09/12/2013	18:41	09/12/2013	20:26	10	1050	105	Tree related-tree broken	Overhead Primary		Patrol/Test/Inspect	IV
132558006	U33509	09/12/2013	19:42	09/12/2013	21:17	944	89680	95	Unknown				II
132558040	D31018	09/12/2013	19:52	09/12/2013	20:30	2	76	38	Overhead equipment	Fuse	Replace - Same Size	No Work Required	III

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
132558043	E10001	09/12/2013	19:59	09/13/2013	0:31	302	82144	272	Overhead equipment	Jumper			III
132558143	K08909	09/12/2013	22:29	09/13/2013	0:35	10	1260	126	Overhead equipment	Fuse	Replace - Same Size	Patrol/Test/Inspect	VI
132558159	P69173	09/12/2013	22:58	09/12/2013	23:54	4	224	56	Animal related	Transformer Fuse	Replace - Same Size		III
132560113	D92002	09/13/2013	0:14	09/13/2013	5:15	24	7224	301	Overhead equipment	Overhead Transformer		Repair	I
132565211	R93351	09/13/2013	1:27	09/13/2013	6:34	35	10745	307	Overhead equipment	Jumper	Patrol/Test/Inspect	Repair	V
132560126	Q11517	09/13/2013	1:33	09/13/2013	3:11	1	98	98	Overhead equipment	Overhead Service	Repair		I
132560130	U44568	09/13/2013	1:44	09/13/2013	3:37	1	113	113	Overhead equipment				II
132560188	S36570	09/13/2013	2:07	09/13/2013	3:48	1	101	101	Animal related	Disconnect Switch	Repair		VI
132565223	N58144	09/13/2013	4:10	09/13/2013	5:21	1	71	71	Overhead equipment	Connector	Tie/Tighten		I
132565970	B76001	09/13/2013	4:45	09/13/2013	13:08	11	5533	503	Underground equipment	Underground Transformer	Replace - Urgent		I
132565588	D72001	09/13/2013	6:47	09/13/2013	11:33	5	1430	286	Underground equipment	Underground Primary		Repair	I
132565278	Y11555	09/13/2013	6:48	09/13/2013	8:15	4	348	87	Overhead equipment	Disconnect Switch		Replace - Same Size	IV
132565301	J99127	09/13/2013	7:04	09/13/2013	8:08	1	64	64	Animal related	Fuse	Replace - Same Size		VI
132565322	J30203	09/13/2013	7:13	09/13/2013	9:12	1	119	119	Animal related	Transformer Fuse	Patrol/Test/Inspect		VI
132565317	J99127	09/13/2013	7:14	09/13/2013	8:27	1	73	73	Animal related	Fuse	Replace - Same Size		VI
132565325	A26006	09/13/2013	7:15	09/13/2013	9:32	1	137	137	Tree related-tree broken	Overhead Service	Raise	No Work Required	I
132565350	B93003	09/13/2013	7:27	09/13/2013	8:59	1	92	92	Animal related	Fuse	Replace - Same Size		I
132565355	M47802	09/13/2013	7:30	09/13/2013	7:59	6	174	29	Animal related	Fuse	Repair	Repair	V
132565389	P17108	09/13/2013	7:39	09/13/2013	8:50	1	71	71	Underground equipment	Underground Primary	Switch/Reset	Repair	IV
132565416	N93260	09/13/2013	7:44	09/13/2013	11:10	1	206	206	Overhead equipment	Lightning Arrestor			III
132565503	K01239	09/13/2013	8:01	09/13/2013	8:49	1	48	48	Overhead equipment				VI
132565556		09/13/2013	8:11	09/13/2013	11:45	1	214	214	Overhead equipment	Disconnect Switch		Replace - Same Size	V
132565333	M81403	09/13/2013	8:12	09/13/2013	13:47	8	2680	335	Overhead equipment	Pole	Replace - Same Size	Repair	V
132565651	S88503	09/13/2013	8:29	09/13/2013	10:25	6	696	116	Animal related	Disconnect Switch	Repair		VI
132565712	N60181	09/13/2013	8:40	09/13/2013	10:25	1	105	105	Underground equipment	Underground Service	No Work Required		I
132565745	R49263	09/13/2013	8:47	09/13/2013	11:15	1	148	148	Overhead equipment	Fuse		Repair	VI
132565826	U60559	09/13/2013	9:06	09/13/2013	10:15	1	69	69	Animal related	Fuse	Replace - Same Size		II
132565849	R05114	09/13/2013	9:09	09/13/2013	9:57	1	48	48	Animal related	Overhead Transformer	Switch/Reset		I
132565871	Z11536	09/13/2013	9:14	09/13/2013	10:21	2	134	67	Animal related	Transformer Fuse	Replace - Same Size	No Work Required	IV
132565925	B76003	09/13/2013	9:20	09/13/2013	10:25	1	65	65	Animal related	Fuse	Replace - Same Size		I
132565935	S83533	09/13/2013	9:22	09/13/2013	10:04	1	42	42	Animal related	Overhead Transformer	Switch/Reset		VI
132566054	P47169	09/13/2013	9:45	09/13/2013	10:50	47	3055	65	Animal related	Fuse	Repair	Replace - Same Size	I
132566092	L74193	09/13/2013	9:57	09/13/2013	10:32	1	35	35	Public				IV
132566197	R10903	09/13/2013	10:21	09/13/2013	11:31	1	70	70	Overhead equipment	Fuse	Repair	No Work Required	VI
132566203	H01192	09/13/2013	10:22	09/13/2013	11:17	1	55	55	Underground equipment	Underground Service	Repair		III
132566231	B58001	09/13/2013	10:27	09/13/2013	11:52	1	85	85	Animal related	Transformer Fuse	Replace - Same Size		I
132566314	X02547	09/13/2013	10:44	09/13/2013	11:39	3	165	55	Animal related	Transformer Fuse	Replace - Same Size		IV
132566329	N05172	09/13/2013	10:46	09/13/2013	12:10	1	84	84	Overhead equipment	Disconnect Switch	Replace - Same Size		I
132566331	M37192	09/13/2013	10:47	09/13/2013	12:17	1	90	90	Overhead equipment	Overhead Transformer	Switch/Reset		I
132566367	X02547	09/13/2013	10:52	09/13/2013	11:39	1	47	47	Animal related	Transformer Fuse	Replace - Same Size		IV
132566419	S47537	09/13/2013	11:02	09/13/2013	11:16	1	14	14	Overhead equipment	Fuse	Replace - Same Size		VI
132566500	D70003	09/13/2013	11:17	09/13/2013	13:10	9	1017	113	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
132566480	K65221	09/13/2013	11:18	09/13/2013	12:08	1	50	50	Tree related-tree broken	Overhead Service			III
132566553	R60552	09/13/2013	11:36	09/13/2013	13:53	1	137	137	Overhead equipment	Overhead Transformer		Repair	IV
132566774	P20930	09/13/2013	12:25	09/13/2013	13:56	5	455	91	Animal related	Fuse	Replace - Same Size		VI
132567054	V75205	09/13/2013	12:27	09/13/2013	15:29	1207	219674	182	Animal related				II
132566842	K71822	09/13/2013	12:35	09/13/2013	13:05	1	30	30	Animal related	Transformer Fuse	Replace - Same Size		IV
132566859	J06167	09/13/2013	12:37	09/13/2013	14:54	1	137	137	Overhead equipment	Overhead Transformer	Switch/Reset		I
132566901	P82290	09/13/2013	12:41	09/13/2013	13:45	1	64	64	Animal related	Animal Guard	Install	Replace - Same Size	VI
132566976	H06135	09/13/2013	12:53	09/13/2013	13:35	1	42	42	Animal related	Transformer Fuse	Replace - Same Size		IV
132567652	U33586	09/13/2013	13:01	09/13/2013	14:40	19	1881	99	Overhead equipment	Fuse	Replace - Same Size		II
132567033	P47169	09/13/2013	13:05	09/13/2013	14:17	49	3528	72	Unknown	Fuse	Repair	Replace - Same Size	I
132567215	X09594	09/13/2013	13:21	09/13/2013	15:12	1	111	111	Unknown	Animal Guard			IV
132567229	U93507	09/13/2013	13:24	09/13/2013	14:38	1	74	74	Overhead equipment	Overhead Service	Repair		II
132567352	R10903	09/13/2013	13:49	09/13/2013	14:35	1	46	46	Overhead equipment	Overhead Service	Repair	No Work Required	VI
132567372	B73002	09/13/2013	13:53	09/13/2013	15:30	1	97	97	Public	Overhead Service	Raise	No Work Required	I

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
132567440	B58002	09/13/2013	13:55	09/13/2013	15:30	8	760	95	Unknown	Fuse	Replace - Same Size		I
132567409	Q95249	09/13/2013	13:58	09/13/2013	14:55	1	57	57	Animal related	Fuse			VI
132567481	Q64919	09/13/2013	14:11	09/13/2013	19:36	1	325	325	Overhead equipment	Overhead Transformer	Replace - Same Size	Replace - Same Size	VI
132567548	Q11517	09/13/2013	14:24	09/13/2013	15:50	1	86	86	Overhead equipment	Fuse	Replace - Same Size		I
132567577	J34377	09/13/2013	14:24	09/13/2013	15:02	20	760	38	Underground equipment	Underground Primary			V
132567594		09/13/2013	14:33	09/13/2013	15:02	1	29	29	Underground equipment	Underground Primary			V
132567620	D36001	09/13/2013	14:40	09/13/2013	16:38	1	118	118	Tree related-tree broken	Overhead Service	Raise	No Work Required	I
132567633	D35002	09/13/2013	14:40	09/13/2013	16:25	44	4620	105	Overhead equipment	Fuse	Replace - Same Size		I
132567631	R50910	09/13/2013	14:42	09/13/2013	17:20	2	316	158	Overhead equipment	Overhead Service	Repair		I
132567766	P49183	09/13/2013	15:20	09/13/2013	16:47	1	87	87	Animal related	Transformer Fuse	Replace - Same Size		I
132567840	A68001	09/13/2013	15:38	09/13/2013	16:45	1	67	67	Animal related	Fuse	Replace - Same Size		I
132567856	V10545	09/13/2013	15:42	09/13/2013	17:20	12	1176	98	Underground equipment	Underground Primary	Switch/Reset	Repair	II
132567852	D88001	09/13/2013	15:43	09/13/2013	16:45	17	1054	62	Animal related	Fuse	Replace - Same Size		I
132568240	R16511	09/13/2013	15:59	09/13/2013	22:45	16	6496	406	Underground equipment	Underground Primary	Repair	No Work Required	I
132567954	V39001	09/13/2013	16:16	09/13/2013	17:25	1	69	69	Tree related-tree broken	Tree			II
132568316	K30204	09/13/2013	17:06	09/13/2013	22:49	14	4802	343	Public	Pole	Replace - Same Size		III
132568159	K30204	09/13/2013	17:06	09/13/2013	18:56	63	6930	110	Public	Recloser	Replace - Same Size	Replace - Same Size	III
132568112	J15303	09/13/2013	17:30	09/13/2013	18:22	1	52	52	Animal related	Fuse	Replace - Same Size	Replace - Same Size	I
132568169	B81002	09/13/2013	18:01	09/13/2013	19:45	7	728	104	Animal related	Animal Guard	Install		I
132568170	D32211	09/13/2013	18:02	09/13/2013	18:54	1	52	52	Overhead equipment	Fuse	Replace - Same Size		I
132568172	J58380	09/13/2013	18:02	09/14/2013	1:28	1	446	446	Underground equipment	Underground Primary	Repair	Repair	III
132568175	P77235	09/13/2013	18:04	09/13/2013	20:09	5	625	125	Animal related	Fuse	Replace - Same Size		VI
132569027	S60581	09/13/2013	18:28	09/14/2013	2:18	9	4230	470	Tree related-tree broken	Crossarm	Replace - New Size	Repair	VI
132569024	S60581	09/13/2013	18:28	09/13/2013	20:20	81	9072	112	Tree related-tree broken	Overhead Primary			VI
132568418	K01238	09/13/2013	18:33	09/13/2013	19:20	34	1598	47	Underground equipment	Underground Primary			VI
132569006	J88163	09/13/2013	19:49	09/13/2013	22:00	18	2358	131	Underground equipment	Underground Primary			VI
132569042	N70330	09/13/2013	20:52	09/14/2013	7:26	1	634	634	Overhead equipment	Overhead Service			I
132569177	J08207	09/13/2013	21:19	09/13/2013	23:30	125	16375	131	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	I
132569195	Y24523	09/13/2013	22:20	09/13/2013	23:45	3	255	85	Animal related	Transformer Fuse	Replace - Same Size	Replace - Same Size	IV
132569205	B77001	09/13/2013	22:45	09/14/2013	1:42	8	1416	177	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
132569223	A97001	09/13/2013	23:10	09/14/2013	0:18	6	408	68	Animal related	Disconnect Switch	Replace - Same Size		I
132570030	K27150	09/14/2013	2:36	09/14/2013	8:20	1	344	344	Overhead equipment	Overhead Secondary	Patrol/Test/Inspect	Replace - Same Size	VI
132570064	K27122	09/14/2013	3:21	09/14/2013	6:27	7	1302	186	Overhead equipment	Jumper	Patrol/Test/Inspect	Repair	VI
132570063	K27122	09/14/2013	3:21	09/14/2013	5:40	210	29190	139	Overhead equipment				VI
132570048	346003	09/14/2013	3:54	09/14/2013	4:52	7	406	58	Public	Other	Patrol/Test/Inspect		VI
132570061	R23332	09/14/2013	5:02	09/14/2013	6:19	1	77	77	Animal related	Transformer Fuse	Replace - Same Size		V
132570070	L46810	09/14/2013	6:27	09/14/2013	10:58	8	2168	271	Overhead equipment	Overhead Transformer	Replace - Same Size	Replace - Same Size	V
132570082	B58001	09/14/2013	6:42	09/14/2013	9:13	84	12684	151	Overhead equipment	Overhead Primary	Patrol/Test/Inspect	Replace - Urgent	I
132570089	L11242	09/14/2013	7:01	09/14/2013	8:31	1	90	90	Overhead equipment	Overhead Service	Repair		III
132570095	R66470	09/14/2013	7:05	09/14/2013	7:42	11	407	37	Overhead equipment	Transformer Fuse			IV
132570094	S55535	09/14/2013	7:05	09/14/2013	7:42	10	370	37	Animal related	Overhead Transformer	Switch/Reset		VI
132570125	K09864	09/14/2013	7:34	09/14/2013	9:20	27	2862	106	Animal related	Fuse	Remove	Replace - Same Size	V
132570126	J13108	09/14/2013	7:36	09/14/2013	8:15	1	39	39	Animal related	Transformer Fuse	Replace - Same Size		I
132570130	J89126	09/14/2013	7:41	09/14/2013	8:20	1	39	39	Animal related	Fuse	Replace - Same Size		VI
132570131	M36185	09/14/2013	7:42	09/14/2013	8:20	8	304	38	Animal related	Transformer Fuse	Replace - Same Size		I
132570148	V95586	09/14/2013	7:57	09/14/2013	9:27	7	630	90	Animal related	Transformer Fuse	Replace - Same Size		II
132570189	Q06132	09/14/2013	8:45	09/14/2013	9:52	33	2211	67	Animal related	Fuse			IV
132570194	HB6283	09/14/2013	8:49	09/14/2013	10:24	6	570	95	Animal related	Fuse	Replace - Same Size		VI
132570232	J83138	09/14/2013	8:54	09/14/2013	9:25	7	217	31	Animal related	Fuse	Replace - Same Size		VI
132570216	D37001	09/14/2013	9:04	09/14/2013	9:55	1	51	51	Overhead equipment	Connector	Replace - Same Size		I
132570246	V58507	09/14/2013	9:23	09/14/2013	11:24	1	121	121	Overhead equipment	Overhead Service	Repair		II
132570248	N35852	09/14/2013	9:23	09/14/2013	10:31	4	272	68	Animal related	Transformer Fuse	Replace - Same Size		V
132570257	J86118	09/14/2013	9:28	09/14/2013	11:20	1	112	112	Jurisdictional	Tree			VI
132570260	J89126	09/14/2013	9:31	09/14/2013	11:14	1	103	103	Animal related	Fuse	Replace - Same Size		VI
132570267	V22555	09/14/2013	9:39	09/14/2013	11:37	1	118	118	Animal related	Transformer Fuse	Replace - Same Size	No Work Required	II
132570334	D55002	09/14/2013	10:39	09/14/2013	12:29	1	110	110	Tree related-tree contact	Overhead Service		Replace - Same Size	I

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
132570337	M09175	09/14/2013	10:40	09/14/2013	11:20	1	40	40	Overhead equipment	Connector	Replace - Same Size	Repair	VI
132570339	U66524	09/14/2013	10:41	09/14/2013	13:20	1	159	159	Overhead equipment	Transformer Fuse	Replace - Same Size	No Work Required	II
132570354	P71830	09/14/2013	10:53	09/14/2013	13:04	1	131	131	Overhead equipment	Overhead Transformer		Repair	V
132570385	S22595	09/14/2013	11:24	09/14/2013	13:11	1	107	107	Animal related	Overhead Transformer			VI
132570458	S88503	09/14/2013	12:43	09/14/2013	13:50	1	67	67	Animal related	Transformer Fuse	Replace - Same Size		VI
132570462	J06168	09/14/2013	12:47	09/14/2013	15:00	1	133	133	Other				I
132570466	N60181	09/14/2013	12:52	09/14/2013	14:10	1	78	78	Tree related-tree contact	Overhead Primary	Patrol/Test/Inspect	Tie/Tighten	I
132570473	Y45003	09/14/2013	12:59	09/14/2013	13:50	6	306	51	Animal related	Transformer Fuse	Repair	Replace - Same Size	IV
132570483	L70127	09/14/2013	12:59	09/14/2013	14:36	42	4074	97	Underground equipment	Underground Primary		Repair	IV
132570600	U10547	09/14/2013	14:17	09/14/2013	16:15	6	708	118	Animal related	Transformer Fuse	Replace - Same Size	Replace - Same Size	II
132570617	R33126	09/14/2013	14:40	09/14/2013	16:20	1	100	100	Weather	Transformer Fuse	Replace - Same Size		I
132570637	X96002	09/14/2013	15:11	09/14/2013	17:47	1	156	156	Overhead equipment	Overhead Service			IV
132570655	H06135	09/14/2013	15:32	09/14/2013	16:23	5	255	51	Overhead equipment	Transformer Fuse			IV
132570674	A50001	09/14/2013	15:57	09/14/2013	17:00	10	630	63	Animal related	Transformer Fuse	Replace - Same Size		I
132570706		09/14/2013	16:53	09/14/2013	19:07	1	134	134	Animal related	Fuse	Patrol/Test/Inspect		III
132570716	K30205	09/14/2013	17:01	09/14/2013	17:45	6	264	44	Animal related	Fuse	Replace - Same Size		III
132570776	D89002	09/14/2013	17:54	09/14/2013	20:00	647	81522	126	Overhead equipment	Overhead Primary	Repair	Repair	I
132570750	L35137	09/14/2013	17:58	09/14/2013	20:17	1	139	139	Unknown	Other			III
132570797	R01152	09/14/2013	18:08	09/14/2013	18:55	2	94	47	Animal related	Fuse	Patrol/Test/Inspect		III
132570771	K46388	09/14/2013	18:11	09/14/2013	18:57	1	46	46	Animal related	Transformer Fuse	Replace - Same Size		V
132570779	X77586	09/14/2013	18:26	09/14/2013	19:24	1	58	58	Animal related	Transformer Fuse	Replace - Same Size	Patrol/Test/Inspect	IV
132570785	J88163	09/14/2013	18:48	09/14/2013	20:06	1	78	78	Animal related	Fuse	Replace - Same Size		VI
132570789	S88503	09/14/2013	18:53	09/14/2013	19:45	1	52	52	Animal related	Transformer Fuse	Replace - Same Size		VI
132570793	Z21564	09/14/2013	18:56	09/14/2013	19:55	1	59	59	Animal related	Fuse	Repair	Replace - Same Size	IV
132570812	B93002	09/14/2013	19:48	09/14/2013	22:10	1	142	142	Animal related	Fuse	Replace - Same Size		I
132570840	V69546	09/14/2013	20:53	09/14/2013	23:40	33	5511	167	Underground equipment	Underground Primary		Repair	II
132570889	Q18245	09/14/2013	21:23	09/14/2013	23:34	8	1048	131	Underground equipment	Underground Primary	Switch/Reset		VI
132570851	Q18245	09/14/2013	21:23	09/15/2013	6:03	8	4160	520	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	VI
132570872	B57001	09/14/2013	22:21	09/14/2013	23:55	4	376	94	Animal related	Transformer Fuse	Replace - Same Size		I
132580006	J79304	09/14/2013	23:39	09/15/2013	1:30	3	333	111	Underground equipment	Underground Primary	Switch/Reset	Repair	I
132580021	V24583	09/15/2013	4:04	09/15/2013	5:40	1	96	96	Animal related	Fuse	Replace - Same Size		II
132580022	Q32170	09/15/2013	4:18	09/15/2013	6:20	1	122	122	Animal related	Transformer Fuse	Replace - Same Size		I
132580043	M05368	09/15/2013	6:48	09/15/2013	7:42	57	3078	54	Animal related	Fuse	Replace - Same Size	Replace - Same Size	V
132580045	P58154	09/15/2013	7:08	09/15/2013	11:40	1	272	272	Animal related	Disconnect Switch	Repair	Replace - Same Size	VI
132580048	S60581	09/15/2013	7:19	09/15/2013	7:22	1	3	3	Overhead equipment	Disconnect Switch	Repair		VI
132580057	K80381	09/15/2013	7:24	09/15/2013	9:57	22	3366	153	Underground equipment	Underground Primary		Patrol/Test/Inspect	IV
132580061	T15570	09/15/2013	7:36	09/15/2013	8:35	4	236	59	Animal related	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
132580070	A85001	09/15/2013	7:37	09/15/2013	9:00	44	3652	83	Animal related	Fuse	Replace - Same Size		I
132580072	M26164	09/15/2013	7:50	09/15/2013	8:40	11	550	50	Animal related	Transformer Fuse			III
132580084	310124	09/15/2013	7:58	09/15/2013	8:51	44	2332	53	Animal related	Fuse	Replace - Same Size	No Work Required	V
132580081	S22595	09/15/2013	7:58	09/15/2013	9:38	29	2900	100	Animal related	Fuse	Replace - Same Size		VI
132580101	N54213	09/15/2013	8:12	09/15/2013	9:32	32	2560	80	Overhead equipment	Fuse	Replace - Same Size	No Work Required	II
132580098	S86582	09/15/2013	8:13	09/15/2013	9:08	1	55	55	Animal related	Transformer Fuse	Replace - Same Size		VI
132580104	M26164	09/15/2013	8:17	09/15/2013	8:42	1	25	25	Animal related	Transformer Fuse			III
132580106	S93507	09/15/2013	8:18	09/15/2013	9:56	1	98	98	Overhead equipment	Overhead Service	Replace - Same Size	Advise Customer	VI
132580118	J79305	09/15/2013	8:26	09/15/2013	9:55	32	2848	89	Overhead equipment	Fuse	Replace - Same Size		I
132580115	C15002	09/15/2013	8:35	09/15/2013	9:47	3	216	72	Animal related	Fuse	Replace - Same Size	No Work Required	III
132580116	J34357	09/15/2013	8:35	09/15/2013	9:30	1	55	55	Animal related	Transformer Fuse	Replace - Same Size	Replace - Same Size	V
132580128	R95520	09/15/2013	8:54	09/15/2013	10:38	1	104	104	Other	Connector	Repair		I
132580132	B93002	09/15/2013	8:57	09/15/2013	10:45	1	108	108	Underground equipment	Underground Transformer	Patrol/Test/Inspect	Replace - Same Size	I
132580131	K32915	09/15/2013	8:57	09/15/2013	9:40	1	43	43	Animal related	Fuse			VI
132580153	P49187	09/15/2013	9:28	09/15/2013	10:22	18	972	54	Tree related-tree broken	Fuse	Replace - Same Size		I
132580154	Y54587	09/15/2013	9:32	09/15/2013	10:04	4	128	32	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
132580246	M26161	09/15/2013	9:35	09/15/2013	11:10	10	950	95	Unknown				III
132580183	L17104	09/15/2013	9:44	09/15/2013	12:10	184	26864	146	Overhead equipment	Recloser	Replace - Same Size	Replace - Same Size	III
132580191	R33127	09/15/2013	9:51	09/15/2013	11:10	1	79	79	Overhead equipment	Overhead Service	Repair		I

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
132580192	S86582	09/15/2013	9:51	09/15/2013	11:00	1	69	69	Animal related	Transformer Fuse	Replace - Same Size		VI
132580211	M26164	09/15/2013	9:54	09/15/2013	11:20	116	9976	86	Animal related	Fuse	Repair		III
132580176	M26161	09/15/2013	9:56	09/15/2013	11:10	2	148	74	Unknown			No Work Required	III
132580208	M26164	09/15/2013	9:57	09/15/2013	11:21	1	84	84	Animal related	Fuse	Repair		III
132580224	B81002	09/15/2013	10:01	09/15/2013	10:46	54	2430	45	Animal related	Fuse	Replace - Same Size		I
132580222	N35851	09/15/2013	10:03	09/15/2013	11:09	1	66	66	Animal related	Underground Primary	Replace - Same Size		V
132580225	S86582	09/15/2013	10:05	09/15/2013	10:58	1	53	53	Animal related	Transformer Fuse	Replace - Same Size		VI
132580244	L79180	09/15/2013	10:14	09/15/2013	11:08	30	1620	54	Animal related	Fuse			IV
132580252	L93133	09/15/2013	10:38	09/15/2013	11:57	12	948	79	Animal related	Fuse	Replace - Same Size		VI
132580268	P07179	09/15/2013	11:05	09/15/2013	11:50	1	45	45	Animal related	Transformer Fuse	Replace - Same Size		I
132580417	Y63527	09/15/2013	12:03	09/15/2013	16:30	20	5340	267	Underground equipment	Other	Repair	Patrol/Test/Inspect	IV
132580292	Y63527	09/15/2013	12:05	09/15/2013	13:30	2	170	85	Underground equipment				IV
132580314	D35002	09/15/2013	12:08	09/15/2013	13:38	42	3780	90	Overhead equipment	Fuse	Replace - Same Size	Patrol/Test/Inspect	I
132580318	A81001	09/15/2013	12:09	09/15/2013	18:45	31	12276	396	Underground equipment	Insulator	Patrol/Test/Inspect	Repair	I
132580304	A81001	09/15/2013	12:12	09/15/2013	18:45	16	6288	393	Underground equipment	Underground Primary	Switch/Reset		I
132580309	M26164	09/15/2013	12:14	09/15/2013	12:54	23	920	40	Animal related	Fuse	Replace - Same Size		III
132580308	L17104	09/15/2013	12:15	09/15/2013	12:59	1	44	44	Other	Other			III
132580327	K71821	09/15/2013	12:35	09/15/2013	14:45	8	1040	130	Underground equipment	Underground Primary		Patrol/Test/Inspect	IV
132580361	B21002	09/15/2013	13:06	09/15/2013	17:38	1	272	272	Overhead equipment	Fuse	Repair		I
132580456	B76001	09/15/2013	13:35	09/15/2013	16:40	9	1665	185	Underground equipment	Underground Primary	Patrol/Test/Inspect	Switch/Reset	I
132580383	B76001	09/15/2013	13:35	09/15/2013	22:59	32	18048	564	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
132580402	M26164	09/15/2013	14:07	09/15/2013	14:33	1	26	26	Animal related	Transformer Fuse			III
132580418	Q11517	09/15/2013	14:36	09/15/2013	15:50	1	74	74	Animal related	Transformer Fuse	Replace - Same Size	No Work Required	I
132580425	N05172	09/15/2013	14:52	09/15/2013	21:30	2	796	398	Public	Pole	Replace - Same Size		I
132580431	P26284	09/15/2013	15:06	09/15/2013	17:30	1	144	144	Animal related	Fuse	Replace - Same Size	Replace - Same Size	I
132580473	P49180	09/15/2013	16:56	09/15/2013	17:55	1	59	59	Animal related	Transformer Fuse	Replace - Same Size		I
132580488	A81001	09/15/2013	17:24	09/15/2013	18:03	116	4524	39	Overhead equipment	Other	Patrol/Test/Inspect	Replace - New Size	I
132580490	B93002	09/15/2013	17:25	09/15/2013	19:00	1	95	95	Overhead equipment				I
132580492		09/15/2013	17:29	09/15/2013	19:55	1	146	146	Overhead equipment	Disconnect Switch	Repair		II
132580496	K95208	09/15/2013	17:36	09/15/2013	18:15	1	39	39	Overhead equipment	Overhead Service			III
132580497	H01192	09/15/2013	17:37	09/15/2013	18:54	1	77	77	Animal related	Transformer Fuse			III
132580503	342001	09/15/2013	17:52	09/15/2013	18:20	1	28	28	Overhead equipment	Overhead Service	Repair		VI
132580532	D36002	09/15/2013	18:15	09/15/2013	21:20	9	1665	185	Tree related-tree broken	Overhead Primary	Repair		I
132580524	U12001	09/15/2013	18:15	09/15/2013	19:55	1	100	100	Overhead equipment	Disconnect Switch	Repair		II
132580580	Q32170	09/15/2013	20:20	09/15/2013	21:50	1	90	90	Animal related	Transformer Fuse	Replace - Same Size		I
132590086	E10002	09/15/2013	20:39	09/16/2013	4:08	2	898	449	Underground equipment	Underground Primary	Repair		III
132580591	L46811	09/15/2013	20:59	09/15/2013	21:47	1	48	48	Overhead equipment	Fuse	Replace - Same Size	No Work Required	V
132580596	L95110	09/15/2013	21:07	09/15/2013	22:34	1	87	87	Overhead equipment	Overhead Service			III
132580627	E10002	09/15/2013	21:08	09/15/2013	23:57	2	338	169	Underground equipment	Underground Primary	Switch/Reset		III
132580602	E10002	09/15/2013	21:12	09/15/2013	22:45	54	5022	93	Underground equipment	Underground Primary	Switch/Reset		III
132580603	310122	09/15/2013	21:13	09/15/2013	21:38	1	25	25	Overhead equipment	Overhead Transformer	Repair		V
132580607	U13551	09/15/2013	21:31	09/16/2013	4:20	1	409	409	Underground equipment	Underground Primary	Repair	Patrol/Test/Inspect	II
132580608	C36001	09/15/2013	21:36	09/15/2013	22:42	1	66	66	Animal related	Fuse	Replace - Same Size	No Work Required	III
132590087	M09143	09/16/2013	0:19	09/16/2013	1:35	1	76	76	Overhead equipment	Connector	Replace - Same Size	Repair	VI
132590118	A36001	09/16/2013	1:31	09/16/2013	4:45	9	1746	194	Underground equipment	Underground Primary	Patrol/Test/Inspect	Replace - Urgent	I
132590102	R01153	09/16/2013	1:32	09/16/2013	7:17	78	26910	345	Underground equipment				III
132590123	Q18242	09/16/2013	2:54	09/16/2013	7:16	26	6812	262	Underground equipment	Underground Primary		Repair	VI
132590119	X86546	09/16/2013	3:04	09/16/2013	5:10	1	126	126	Animal related	Transformer Fuse	Repair	Patrol/Test/Inspect	IV
132593678	R94269	09/16/2013	3:06	09/16/2013	5:11	38	4750	125	Overhead equipment	Recloser	Patrol/Test/Inspect	Switch/Reset	VI
132593679	V61563	09/16/2013	3:51	09/16/2013	11:40	1	469	469	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	II
132593706	U68581	09/16/2013	4:01	09/16/2013	6:42	8	1288	161	Underground equipment	Underground Primary	Switch/Reset	Repair	II
132593683	U68581	09/16/2013	4:02	09/16/2013	6:39	1	157	157	Underground equipment				II
132593688	H06135	09/16/2013	5:01	09/16/2013	6:20	4	316	79	Animal related	Fuse	Replace - Same Size		IV
132593729	R94269	09/16/2013	6:11	09/16/2013	8:08	38	4446	117	Overhead equipment				VI
132594597	D87001	09/16/2013	6:52	09/16/2013	11:51	2	598	299	Underground equipment	Underground Primary	Repair	Repair	I
132594147	D87001	09/16/2013	6:52	09/16/2013	11:50	5	1490	298	Underground equipment	Underground Primary		Replace - Same Size	I

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
132593744	M31203	09/16/2013	6:52	09/16/2013	9:16	8	1152	144	Overhead equipment	Overhead Transformer	Replace - Same Size	Replace - Same Size	I
132593748	V18582	09/16/2013	6:52	09/16/2013	8:35	1	103	103	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	II
132593749	D88001	09/16/2013	6:53	09/16/2013	7:48	1	55	55	Animal related	Fuse	Replace - Same Size		I
132593759	J88163	09/16/2013	7:06	09/16/2013	16:02	20	10720	536	Underground equipment	Underground Primary		Replace - Same Size	VI
132593792	R39934	09/16/2013	7:16	09/16/2013	8:51	1	95	95	Overhead equipment	Transformer Fuse	Replace - Same Size	No Work Required	VI
132593800	Z08509	09/16/2013	7:17	09/16/2013	14:10	1	413	413	Underground equipment	Underground Primary	Repair	Replace - Same Size	IV
132593858	X42502	09/16/2013	7:36	09/16/2013	8:10	1	34	34	Overhead equipment				IV
132593862	K74168	09/16/2013	7:38	09/16/2013	8:20	8	336	42	Animal related	Transformer Fuse	Replace - Same Size	No Work Required	IV
132593927	Q74150	09/16/2013	7:54	09/16/2013	8:45	1	51	51	Unknown	Transformer Fuse	Replace - Same Size		IV
132593958	U60518	09/16/2013	8:03	09/16/2013	9:56	1	113	113	Overhead equipment	Transformer Fuse	Replace - Same Size		II
132593973	N60181	09/16/2013	8:08	09/16/2013	8:48	1	40	40	Overhead equipment	Overhead Service	No Work Required		I
132594010	X39530	09/16/2013	8:18	09/16/2013	11:21	1	183	183	Animal related	Overhead Primary	Repair		IV
132594023	B00008	09/16/2013	8:23	09/16/2013	9:04	1	41	41	Overhead equipment	Connector	Replace - Same Size		I
132593949	J83138	09/16/2013	8:26	09/16/2013	10:43	1	137	137	Overhead equipment	Overhead Service		Repair	VI
132594166	B80004	09/16/2013	8:54	09/16/2013	9:21	1	27	27	Overhead equipment	Connector	Patrol/Test/Inspect	Replace - New Size	I
132594218	S62521	09/16/2013	9:05	09/16/2013	9:24	1	19	19	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	VI
132594280	K39154	09/16/2013	9:13	09/16/2013	10:05	38	1976	52	Animal related	Fuse	Replace - Same Size		III
132594262	E10003	09/16/2013	9:14	09/16/2013	10:20	1	66	66	Overhead equipment	Overhead Service	Replace - Same Size	Repair	III
132594350	R65452	09/16/2013	9:31	09/16/2013	10:24	1	53	53	Animal related	Transformer Fuse	Replace - Same Size	No Work Required	IV
132594378	U60518	09/16/2013	9:36	09/16/2013	10:18	1	42	42	Overhead equipment	Transformer Fuse	Replace - Same Size		II
132594533	K57211	09/16/2013	10:05	09/16/2013	10:43	1	38	38	Animal related	Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
132594620		09/16/2013	10:17	09/16/2013	11:07	1	50	50	Overhead equipment	Fuse	Repair	Repair	VI
132594688	P49180	09/16/2013	10:29	09/16/2013	14:39	7	1750	250	Underground equipment	Underground Transformer	Replace - Same Size		I
132594756	K71811	09/16/2013	10:40	09/16/2013	12:08	7	616	88	Public	Fuse	Replace - Same Size	No Work Required	IV
132594757		09/16/2013	10:40	09/16/2013	11:07	1	27	27	Overhead equipment	Fuse	Repair	Repair	VI
132594839	U06524	09/16/2013	10:56	09/16/2013	11:45	1	49	49	Animal related	Animal Guard			II
132594888	S04512	09/16/2013	11:07	09/16/2013	11:22	1	15	15	Overhead equipment				VI
132594958	K15205	09/16/2013	11:21	09/16/2013	12:51	1	90	90	Overhead equipment			No Work Required	VI
132595440	R10903	09/16/2013	11:33	09/16/2013	18:28	10	4150	415	Underground equipment	Underground Primary	Patrol/Test/Inspect		VI
132595173	R34920	09/16/2013	12:05	09/16/2013	12:48	1	43	43	Overhead equipment	Transformer Fuse	Replace - Same Size	No Work Required	VI
132595262	A80001	09/16/2013	12:25	09/16/2013	13:00	1	35	35	Overhead equipment	Fuse	Repair		I
132595469	J83140	09/16/2013	13:08	09/16/2013	14:09	1	61	61	Other	Overhead Service	Repair		VI
132595560	J63173	09/16/2013	13:24	09/16/2013	14:32	53	3604	68	Animal related	Fuse	Repair	Repair	III
132595761	Q95249	09/16/2013	14:02	09/16/2013	15:50	1	108	108	Overhead equipment	Lightning Arrestor	Replace - Same Size		VI
132595774	R95520	09/16/2013	14:06	09/16/2013	14:26	1	20	20	Other	Other	No Work Required	No Work Required	I
132595807	L79159	09/16/2013	14:12	09/16/2013	15:06	9	486	54	Animal related	Transformer Fuse	Replace - Same Size		IV
132595946	Q32170	09/16/2013	14:34	09/16/2013	15:56	1	82	82	Unknown	Fuse			I
132595983	P83705	09/16/2013	14:34	09/16/2013	15:50	96	7296	76	Animal related	Disconnect Switch	Repair	Repair	I
132596040	K76546	09/16/2013	14:50	09/16/2013	15:30	22	880	40	Animal related	Fuse	Replace - Same Size	No Work Required	IV
132596033	B58001	09/16/2013	14:51	09/16/2013	15:48	2	114	57	Public	Underground Primary	Patrol/Test/Inspect	Repair	I
132596034	S13549	09/16/2013	14:51	09/16/2013	15:57	1	66	66	Overhead equipment	Overhead Secondary	Repair		VI
132596041	X64003	09/16/2013	14:53	09/16/2013	16:25	1	92	92	Tree related-tree broken	Overhead Service	Repair		IV
132596154	B62003	09/16/2013	15:01	09/16/2013	17:03	633	77226	122	Underground equipment	Underground Primary			I
132596595	B62003	09/16/2013	15:04	09/16/2013	18:15	26	4966	191	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
132596266	R10903	09/16/2013	15:07	09/16/2013	17:22	13	1755	135	Underground equipment	Underground Primary	Cut in Clear	Patrol/Test/Inspect	VI
132596226	S61530	09/16/2013	15:24	09/16/2013	22:20	1	416	416	Overhead equipment	Underground Primary			VI
132596325	Y55594	09/16/2013	15:50	09/16/2013	17:00	1	70	70	Overhead equipment	Animal Guard	Install		IV
132596404	Y07577	09/16/2013	16:14	09/16/2013	18:00	4	424	106	Animal related	Disconnect Switch	Replace - New Size		IV
132596464	B58001	09/16/2013	16:32	09/17/2013	5:50	1	798	798	Public	Underground Primary	Repair		I
132596469	P57108	09/16/2013	16:34	09/16/2013	17:05	1	31	31	Animal related	Transformer Fuse	Replace - Same Size		VI
132596529	307004	09/16/2013	16:51	09/16/2013	18:25	1	94	94	Tree related-tree contact	Overhead Service	Repair	Replace - New Size	VI
132596581	Z11506	09/16/2013	17:07	09/16/2013	18:52	6	630	105	Animal related	Animal Guard	Cover		IV
132596579	J86108	09/16/2013	17:07	09/16/2013	17:21	1	14	14	Animal related	Transformer Fuse	Replace - Same Size		VI
132596659	Y96564	09/16/2013	17:31	09/17/2013	0:30	7	2933	419	Underground equipment	Underground Primary	Repair	Repair	IV
132596651	K31124	09/16/2013	17:37	09/16/2013	19:52	1	135	135	Animal related	Transformer Fuse	Replace - Same Size		I
132596671	U62521	09/16/2013	17:49	09/16/2013	18:50	1	61	61	Other				II

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
132596762		09/16/2013	18:54	09/16/2013	20:18	1	84	84	Public	Overhead Service	Repair		V
132596772	X02546	09/16/2013	19:03	09/16/2013	20:08	1	65	65	Animal related	Transformer Fuse	Replace - Same Size		IV
132596797	N95859	09/16/2013	19:30	09/16/2013	20:21	1	51	51	Public				V
132596809	B80004	09/16/2013	19:46	09/16/2013	20:06	1	20	20	Overhead equipment	Overhead Service	Repair		I
132597874	J01119	09/16/2013	22:46	09/17/2013	1:20	15	2310	154	Underground equipment	Underground Primary	Switch/Reset	Repair	I
132600154	V27250	09/17/2013	0:32	09/17/2013	5:40	7	2156	308	Animal related	Substation Transformer	Replace - Same Size		II
132600137	N48101	09/17/2013	1:22	09/17/2013	2:35	62	4526	73	Overhead equipment	Fuse	Repair		II
132604381	B80003	09/17/2013	1:31	09/17/2013	7:25	1	354	354	Underground equipment	Underground Primary	Repair		I
132600933	B80003	09/17/2013	1:31	09/17/2013	4:08	3	471	157	Underground equipment	Underground Primary	Switch/Reset		I
132600288	N05172	09/17/2013	2:41	09/17/2013	3:26	1	45	45	Unknown	Transformer Fuse	Replace - Same Size		I
132604423	Q95247	09/17/2013	5:54	09/17/2013	11:45	1	351	351	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - New Size	VI
132604824	K80381	09/17/2013	8:41	09/17/2013	9:15	66	2244	34	Animal related	Fuse	Replace - Same Size	No Work Required	IV
132604866	K80381	09/17/2013	8:49	09/17/2013	9:15	7	182	26	Animal related	Fuse	Replace - Same Size	No Work Required	IV
132604891	Y51505	09/17/2013	9:03	09/17/2013	9:22	2	38	19	Animal related	Transformer Fuse	Replace - Same Size		IV
132604960	P25150	09/17/2013	9:16	09/17/2013	10:14	2	116	58	Overhead equipment	Jumper	Repair		III
132605097	X60598	09/17/2013	9:44	09/17/2013	11:10	1	86	86	Animal related	Transformer Fuse	Replace - Same Size		IV
132605186	M07235	09/17/2013	9:59	09/17/2013	14:15	1	256	256	Overhead equipment	Overhead Transformer			III
132605447	J80807	09/17/2013	10:47	09/17/2013	11:52	1	65	65	Animal related	Underground Primary	Repair	Repair	V
132605708	R04409	09/17/2013	11:26	09/17/2013	12:35	10	690	69	Underground equipment	Underground Primary		Repair	V
132605823		09/17/2013	11:52	09/17/2013	14:27	1	155	155	Overhead equipment	Overhead Service	Repair	Repair	I
132606007	B93001	09/17/2013	12:28	09/17/2013	14:00	1	92	92	Overhead equipment	Overhead Service	Repair		I
132606207	U99578	09/17/2013	13:00	09/17/2013	13:54	1	54	54	Animal related	Fuse	Replace - Same Size		II
132606235	K39154	09/17/2013	13:01	09/17/2013	14:17	72	5472	76	Unknown	Fuse	Replace - Same Size		III
132606350	349001	09/17/2013	13:29	09/17/2013	14:06	1	37	37	Overhead equipment	Overhead Service	Patrol/Test/Inspect		VI
132606403	A17021	09/17/2013	13:38	09/17/2013	17:40	1	242	242	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
132606431	H00163	09/17/2013	13:43	09/17/2013	14:54	1	71	71	Unknown				III
132606527	P69173	09/17/2013	14:03	09/17/2013	14:45	1	42	42	Overhead equipment	Transformer Fuse	Replace - Same Size		III
132606575	L12127	09/17/2013	14:14	09/17/2013	15:00	1	46	46	Other	Other			III
132606793		09/17/2013	15:00	09/17/2013	16:54	1	114	114	Animal related	Fuse	Replace - Same Size		V
132606863	J67132	09/17/2013	15:10	09/17/2013	16:00	1	50	50	Unknown				III
132607071	Q18244	09/17/2013	16:02	09/17/2013	18:22	15	2100	140	Underground equipment	Underground Primary			VI
132607057	S61531	09/17/2013	16:04	09/17/2013	16:30	1	26	26	Overhead equipment				VI
132607097	X75573	09/17/2013	16:16	09/17/2013	16:45	1	29	29	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
132607118	H01190	09/17/2013	16:25	09/17/2013	17:47	1	82	82	Animal related	Transformer Fuse	Replace - Same Size		III
132607327	P73157	09/17/2013	17:45	09/17/2013	21:42	4	948	237	Animal related	Overhead Transformer		Replace - Same Size	VI
132607336	U66524	09/17/2013	17:53	09/17/2013	19:10	1	77	77	Animal related	Transformer Fuse	Replace - Same Size		II
132607348	B58001	09/17/2013	17:58	09/17/2013	22:58	1	300	300	Public	Underground Primary		Repair	I
132607379	S53541	09/17/2013	17:58	09/17/2013	18:40	517	21714	42	Public	Guy Wire	No Work Required		VI
132607400	L43153	09/17/2013	18:09	09/17/2013	19:41	1	92	92	Overhead equipment	Disconnect Switch	Replace - Same Size		I
132608195	V36001	09/17/2013	18:51	09/17/2013	22:29	8	1744	218	Underground equipment	Underground Primary			II
132608243	B10001	09/17/2013	19:47	09/18/2013	10:44	4	3588	897	Underground equipment				I
132608269	C40001	09/17/2013	20:13	09/17/2013	22:52	62	9858	159	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
132608292	B73001	09/17/2013	20:57	09/18/2013	5:58	1	541	541	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
132608307	K80388	09/17/2013	21:27	09/17/2013	23:29	64	7808	122	Public	Underground Transformer	Move	No Work Required	IV
132608435	T16526	09/17/2013	23:41	09/18/2013	0:55	1126	83324	74	Overhead equipment				VI
132617268	S48272	09/17/2013	23:51	09/18/2013	1:18	493	42891	87	Substation equipment				VI
132610094	R06212	09/17/2013	23:55	09/18/2013	2:18	66	9438	143	Underground equipment	Underground Primary	Switch/Reset	Repair	II
132610166	K58213	09/18/2013	1:59	09/18/2013	4:16	1	137	137	Overhead equipment	Connector	Repair		VI
132613796	R84148	09/18/2013	5:33	09/18/2013	6:45	1	72	72	Unknown	Fuse	Patrol/Test/Inspect	Replace - Same Size	I
132613805	Q63835	09/18/2013	5:49	09/18/2013	9:04	115	22425	195	Underground equipment				V
132613824	J18268	09/18/2013	6:08	09/18/2013	7:40	1	92	92	Animal related	Fuse	Replace - Same Size		VI
132613842	T23528	09/18/2013	6:31	09/18/2013	11:40	1	309	309	Overhead equipment	Underground Primary			VI
132613881	S57518	09/18/2013	7:03	09/18/2013	19:28	1	745	745	Underground equipment	Underground Primary	Repair	Repair	VI
132613942	P62138	09/18/2013	7:11	09/18/2013	8:30	456	36024	79	Overhead equipment				VI
132613989	S62520	09/18/2013	7:27	09/18/2013	8:12	1	45	45	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	VI
132614003	S62520	09/18/2013	7:30	09/18/2013	8:00	1	30	30	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	VI

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
132615060	308003	09/18/2013	7:41	09/18/2013	12:45	5	1520	304	Tree related-tree contact	Overhead Transformer			VI
132614048	308003	09/18/2013	7:44	09/18/2013	11:20	17	3672	216	Tree related-tree contact	Overhead Primary	Patrol/Test/Inspect	Replace - Same Size	VI
132614095	Y98532	09/18/2013	7:56	09/18/2013	9:05	1	69	69	Animal related	Animal Guard	Install		IV
132614156	N95824	09/18/2013	8:19	09/18/2013	9:11	1	52	52	Animal related	Transformer Fuse	Replace - Same Size		V
132614153	S60581	09/18/2013	8:19	09/18/2013	9:23	1	64	64	Animal related	Transformer Fuse	Replace - Same Size		VI
132614279	K07322	09/18/2013	8:44	09/18/2013	9:44	32	1920	60	Animal related	Fuse	Replace - Same Size		I
132614262	D28124	09/18/2013	8:45	09/18/2013	10:05	1	80	80	Animal related	Transformer Fuse	Replace - Same Size	No Work Required	I
132615510	307003	09/18/2013	8:45	09/18/2013	17:15	4	2040	510	Tree related-tree broken	Pole		Replace - Same Size	VI
132614269	307003	09/18/2013	8:45	09/18/2013	12:53	13	3224	248	Tree related-tree broken	Pole	Patrol/Test/Inspect	Replace - New Size	VI
132614664	D69008	09/18/2013	8:46	09/18/2013	12:15	1	209	209	Public	Underground Primary		Repair	I
132614278	D69008	09/18/2013	8:46	09/18/2013	10:17	107	9737	91	Public	Underground Primary	Switch/Reset	Repair	I
132614437	B19002	09/18/2013	9:25	09/18/2013	10:11	1	46	46	Overhead equipment	Transformer Fuse	Replace - Same Size	No Work Required	I
132614496	C37002	09/18/2013	9:35	09/18/2013	12:15	1	160	160	Underground equipment	Underground Primary			III
132614551	P20913	09/18/2013	9:45	09/18/2013	11:18	1	93	93	Public	Overhead Service	Repair	Repair	VI
132614595	Q32170	09/18/2013	9:54	09/18/2013	11:48	1	114	114	Other	Connector	Replace - Same Size	Patrol/Test/Inspect	I
132614642	J79305	09/18/2013	10:03	09/18/2013	10:54	1	51	51	Animal related	Transformer Fuse	Replace - Same Size		I
132614698	V31003	09/18/2013	10:13	09/18/2013	11:36	1	83	83	Overhead equipment	Overhead Transformer			II
132614681	N86228	09/18/2013	10:19	09/18/2013	11:50	2	182	91	Overhead equipment	Fuse		Patrol/Test/Inspect	VI
132614807	J86108	09/18/2013	10:30	09/18/2013	11:25	15	825	55	Tree related-tree broken	Fuse	Replace - Same Size		VI
132614833	E10001	09/18/2013	10:36	09/18/2013	11:20	1	44	44	Other	Other			III
132614876	V76001	09/18/2013	10:44	09/18/2013	12:24	4	400	100	Tree related-tree contact	Transformer Fuse	Replace - Same Size		II
132614978	D66004	09/18/2013	11:03	09/18/2013	12:10	1	67	67	Overhead equipment	Fuse			IV
132615055	X19561	09/18/2013	11:17	09/18/2013	12:51	1	94	94	Animal related	Disconnect Switch		Install	IV
132615078	R05114	09/18/2013	11:21	09/18/2013	11:39	1	18	18	Overhead equipment	Overhead Service	No Work Required		I
132615162	J67133	09/18/2013	11:36	09/18/2013	15:07	1	211	211	Overhead equipment	Overhead Service			III
132615236	P98191	09/18/2013	11:51	09/18/2013	14:01	66	8580	130	Underground equipment	Underground Primary	Repair	Repair	III
132615372	P98191	09/18/2013	12:25	09/18/2013	14:20	1	115	115	Underground equipment	Underground Primary	Switch/Reset		III
132615772	B84002	09/18/2013	13:37	09/18/2013	17:30	1	233	233	Overhead equipment	Overhead Service	Repair		I
132616689	301053	09/18/2013	14:02	09/18/2013	16:30	2	296	148	Animal related	Fuse	Repair		VI
132616438	K31124	09/18/2013	14:17	09/18/2013	15:08	5	255	51	Weather	Fuse	Replace - Same Size		I
132616556	N88480	09/18/2013	14:19	09/18/2013	16:40	2183	307803	141	Overhead equipment				VI
132616583	Q18242	09/18/2013	14:19	09/18/2013	15:28	970	66930	69	Unknown				VI
132616174	Q18244	09/18/2013	14:19	09/18/2013	15:28	1334	92046	69	Unknown				VI
132616035	Q18245	09/18/2013	14:19	09/18/2013	15:28	971	66999	69	Unknown				VI
132616063	Q23255	09/18/2013	14:19	09/18/2013	15:07	565	27120	48	Jurisdictional				VI
132616180	Q23256	09/18/2013	14:19	09/18/2013	15:07	1156	55488	48	Unknown				VI
132616257	Q18243	09/18/2013	14:20	09/18/2013	15:28	564	38352	68	Unknown				VI
132616486	Q23258	09/18/2013	14:20	09/18/2013	15:07	1112	52264	47	Unknown				VI
132616324	R49263	09/18/2013	14:26	09/18/2013	18:35	1	249	249	Tree related-tree contact	Transformer Fuse		Patrol/Test/Inspect	VI
132616695	Q24313	09/18/2013	15:05	09/18/2013	15:07	2	4	2	Unknown				VI
132616769	342002	09/18/2013	15:15	09/18/2013	15:56	1	41	41	Overhead equipment	Overhead Transformer	Switch/Reset		VI
132617064	Q36410	09/18/2013	15:27	09/18/2013	18:05	10	1580	158	Weather	Fuse	Replace - Same Size	Replace - Same Size	I
132616854	P83710	09/18/2013	15:39	09/18/2013	17:05	1	86	86	Weather	Fuse	Patrol/Test/Inspect		I
132616967	Q14392	09/18/2013	15:44	09/18/2013	18:47	8	1464	183	Weather	Lightning Arrestor	Replace - Same Size	Repair	I
132616913	A49003	09/18/2013	15:52	09/18/2013	21:12	1	320	320	Underground equipment	Underground Secondary	Patrol/Test/Inspect	Repair	I
132616924	P26283	09/18/2013	15:54	09/18/2013	18:49	1	175	175	Weather	Overhead Transformer	Replace - Same Size		I
132616936	P83710	09/18/2013	15:57	09/18/2013	17:05	1	68	68	Weather	Fuse	Patrol/Test/Inspect		I
132617112	P83705	09/18/2013	15:59	09/18/2013	18:00	6	726	121	Weather	Fuse	Patrol/Test/Inspect		I
132616961	HA5430	09/18/2013	16:01	09/18/2013	17:14	1	73	73	Tree related-tree broken	Overhead Service	Repair		V
132617131	Q93522	09/18/2013	16:41	09/18/2013	21:30	1	289	289	Weather	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	I
132617219	P39298	09/18/2013	17:14	09/18/2013	17:43	1	29	29	Weather	Transformer Fuse		Patrol/Test/Inspect	VI
132617283	S83532	09/18/2013	17:46	09/18/2013	19:06	1	80	80	Weather	Overhead Transformer	Switch/Reset		VI
132617318	R50910	09/18/2013	18:02	09/18/2013	20:15	1	133	133	Weather	Transformer Fuse	Replace - Same Size		I
132618111	M61302	09/18/2013	18:27	09/19/2013	1:04	2	794	397	Animal related	Overhead Transformer	Replace - Same Size		V
132618057	M61302	09/18/2013	18:27	09/18/2013	19:46	87	6873	79	Animal related	Overhead Transformer	Switch/Reset		V
132618105	K80382	09/18/2013	19:32	09/18/2013	21:50	53	7314	138	Underground equipment	Underground Primary		Move	IV

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
132618132	X75573	09/18/2013	20:08	09/18/2013	21:40	1	92	92	Animal related	Animal Guard	Install		IV
132618137	B73001	09/18/2013	20:13	09/18/2013	22:12	1	119	119	Animal related	Fuse	Replace - Same Size		I
132618141	M19222	09/18/2013	20:16	09/18/2013	21:50	1	94	94	Overhead equipment	Transformer Fuse	Replace - Same Size		VI
132618168	L93133	09/18/2013	20:47	09/18/2013	21:40	1	53	53	Animal related	Transformer Fuse			VI
132618171	N48104	09/18/2013	21:01	09/18/2013	22:22	7	567	81	Overhead equipment	Fuse	Repair		II
132618231	S64502	09/18/2013	21:34	09/18/2013	22:05	1	31	31	Overhead equipment	Fuse	Replace - Same Size		VI
132618251	K15207	09/18/2013	22:11	09/18/2013	23:42	7	637	91	Tree related-tree contact	Tree	Remove		VI
132618256	X02548	09/18/2013	22:24	09/18/2013	23:09	1	45	45	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
132618267	R20502	09/18/2013	23:09	09/19/2013	0:46	34	3298	97	Underground equipment	Underground Primary		Repair	IV
132618270	C36002	09/18/2013	23:15	09/19/2013	0:40	1	85	85	Overhead equipment	Fuse	Replace - Same Size	No Work Required	III
132618300	L90359	09/18/2013	23:45	09/19/2013	1:33	22	2376	108	Weather	Lightning Arrestor	Replace - Same Size		V
132623956	U99706	09/19/2013	3:16	09/19/2013	5:04	613	66204	108	Jurisdictional				II
132623955	U99706	09/19/2013	3:16	09/19/2013	5:04	1127	121716	108	Jurisdictional				II
132623967	V44504	09/19/2013	4:46	09/19/2013	9:23	40	11080	277	Underground equipment	Underground Primary		Repair	II
132623970	D87001	09/19/2013	5:02	09/19/2013	10:47	1	345	345	Underground equipment	Underground Primary		Repair	I
132623987	L35137	09/19/2013	6:06	09/19/2013	8:11	23	2875	125	Underground equipment	Underground Primary	Switch/Reset		III
132624022	P58154	09/19/2013	6:48	09/19/2013	12:58	11	4070	370	Underground equipment	Underground Primary	Repair	Repair	VI
132624087	J79305	09/19/2013	7:30	09/19/2013	9:03	1	93	93	Animal related	Transformer Fuse	Replace - Same Size		I
132624220	N54213	09/19/2013	8:15	09/19/2013	9:26	32	2272	71	Animal related	Overhead Transformer	Replace - Same Size	Replace - Same Size	II
132624231	M83408	09/19/2013	8:25	09/19/2013	11:55	1	210	210	Overhead equipment	Connector	Replace - Same Size	Repair	V
132624409	Y79500	09/19/2013	9:02	09/19/2013	10:20	1	78	78	Tree related-tree contact	Overhead Service	Repair		IV
132624422	Y07576	09/19/2013	9:04	09/19/2013	9:33	1	29	29	Animal related	Transformer Fuse	Replace - Same Size	No Work Required	IV
132624450	R16510	09/19/2013	9:09	09/19/2013	9:55	1	46	46	Other	Other	Patrol/Test/Inspect		I
132624601	Q47833	09/19/2013	9:39	09/19/2013	12:00	1	141	141	Public	Overhead Primary	Repair		V
132624649	H01192	09/19/2013	9:50	09/19/2013	10:48	1	58	58	Animal related	Transformer Fuse	Repair		III
132624664	X83541	09/19/2013	9:51	09/19/2013	11:47	1	116	116	Animal related	Animal Guard		Install	IV
132624973	J87111	09/19/2013	10:00	09/19/2013	11:31	16	1456	91	Underground equipment	Underground Primary		Repair	VI
132624890	K30205	09/19/2013	10:33	09/19/2013	16:19	1	346	346	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	III
132624928	J87120	09/19/2013	10:39	09/19/2013	11:20	1	41	41	Overhead equipment				VI
132624999	Y20522	09/19/2013	10:52	09/19/2013	12:11	1	79	79	Overhead equipment	Disconnect Switch	Replace - Same Size		IV
132625009	J01118	09/19/2013	10:53	09/19/2013	12:24	1	91	91	Overhead equipment	Fuse	Replace - Same Size		I
132625155	J99128	09/19/2013	11:23	09/19/2013	12:42	13	1027	79	Overhead equipment	Transformer Fuse			VI
132625230	D66001	09/19/2013	11:40	09/19/2013	13:24	1	104	104	Tree related-tree contact	Overhead Secondary	Repair		IV
132625277	M31201	09/19/2013	11:48	09/19/2013	12:34	1	46	46	Overhead equipment	Lightning Arrestor	Replace - Same Size	Replace - Same Size	I
132625289	L74197	09/19/2013	11:50	09/19/2013	12:21	1	31	31	Overhead equipment	Capacitor			IV
132625462	R49275	09/19/2013	12:31	09/19/2013	14:47	1	136	136	Tree related-tree contact	Overhead Secondary		Repair	VI
132625589	H01190	09/19/2013	12:44	09/19/2013	13:43	421	24839	59	Public	Overhead Primary	Repair		III
132626000	L82188	09/19/2013	13:43	09/19/2013	15:20	3	260	97	Underground equipment	Underground Primary	Switch/Reset	Switch/Reset	IV
132625939	B81001	09/19/2013	13:44	09/19/2013	14:57	31	2263	73	Overhead equipment	Jumper	Repair	No Work Required	I
132625977	H01190	09/19/2013	13:44	09/19/2013	14:19	143	5005	35	Public	Overhead Primary	Repair		III
132626243	L12127	09/19/2013	14:52	09/19/2013	15:50	418	24244	58	Overhead equipment	Jumper	Repair		III
132626223	P98193	09/19/2013	14:55	09/19/2013	15:26	5	155	31	Unknown	Other			III
132626240	J46180	09/19/2013	14:58	09/19/2013	17:02	1	124	124	Unknown	Other			III
132626353	R73839	09/19/2013	15:17	09/19/2013	18:00	1	163	163	Tree related-tree contact	Tree	Trim		V
132626441	P98193	09/19/2013	15:41	09/19/2013	16:48	5	335	67	Overhead equipment	Other			III
132626513	B25001	09/19/2013	15:53	09/19/2013	21:31	1	338	338	Underground equipment	Underground Transformer	Patrol/Test/Inspect	Repair	I
132626623	V65549	09/19/2013	16:26	09/19/2013	18:17	5	555	111	Underground equipment	Underground Primary	Replace - Same Size		II
132626690	J05139	09/19/2013	16:48	09/19/2013	18:10	1	82	82	Unknown	Transformer Fuse	Replace - Same Size		I
132626705	V61563	09/19/2013	16:52	09/19/2013	17:33	5	205	41	Tree related-tree broken	Fuse	Replace - Same Size		II
132626707	M18131	09/19/2013	16:53	09/19/2013	17:55	1	62	62	Overhead equipment	Connector	Repair		III
132626714	P98193	09/19/2013	16:55	09/19/2013	20:36	1	221	221	Underground equipment	Underground Primary			III
132627742	U13551	09/19/2013	20:29	09/19/2013	22:00	7	637	91	Overhead equipment	Fuse	Replace - Same Size	Patrol/Test/Inspect	II
132627749	M26164	09/19/2013	20:38	09/19/2013	21:10	1	32	32	Unknown	Fuse	Replace - Same Size		III
132627767	U42512	09/19/2013	20:55	09/19/2013	22:51	1	116	116	Overhead equipment	Disconnect Switch			II
132628056	U42512	09/19/2013	20:55	09/19/2013	22:50	59	6785	115	Overhead equipment	Disconnect Switch	Repair		II
132628080	V92543	09/19/2013	21:17	09/19/2013	23:00	1	103	103	Overhead equipment	Disconnect Switch	Replace - Same Size	Patrol/Test/Inspect	II

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
132628091	J01118	09/19/2013	21:29	09/19/2013	23:25	1	116	116	Tree related-tree broken	Tree	Cut in Clear		I
132628128	S47576	09/19/2013	21:50	09/19/2013	23:25	12	1140	95	Overhead equipment	Fuse	Replace - Same Size		VI
132628137	V49541	09/19/2013	22:13	09/19/2013	23:42	1	89	89	Weather	Fuse	Patrol/Test/Inspect	Replace - Same Size	II
132628214	R99180	09/19/2013	22:16	09/20/2013	0:57	24	3864	161	Overhead equipment	Jumper		Repair	IV
132631316	A81004	09/19/2013	23:11	09/20/2013	7:16	78	37830	485	Overhead equipment	Fuse	Patrol/Test/Inspect	Replace - Same Size	I
132628199	A81004	09/19/2013	23:11	09/20/2013	1:24	43	5719	133	Overhead equipment	Pole	Switch/Reset		I
132628162	A85001	09/19/2013	23:11	09/20/2013	14:27	55	50380	916	Tree related-tree broken	Pole	Patrol/Test/Inspect	Replace - Same Size	I
132628169	D16003	09/19/2013	23:12	09/20/2013	0:35	72	5976	83	Overhead equipment	Fuse	Replace - Same Size		I
132635518	A81001	09/19/2013	23:13	09/20/2013	5:40	2	774	387	Tree related-tree broken	Tree		Replace - Same Size	I
132631219	A81001	09/19/2013	23:13	09/20/2013	4:24	26	8086	311	Tree related-tree broken	Crossarm		Replace - Same Size	I
132628181	B00005	09/19/2013	23:18	09/20/2013	4:22	17	5168	304	Overhead equipment	Fuse	Replace - Same Size		I
132628197	D36003	09/19/2013	23:29	09/20/2013	3:08	76	16644	219	Overhead equipment	Fuse	Replace - Same Size		I
132628215		09/19/2013	23:41	09/19/2013	23:46	1	5	5	Weather	Substation Breaker	Switch/Reset		I
132631340	P49183	09/19/2013	23:45	09/20/2013	8:20	5	2575	515	Underground equipment	Underground Primary	Repair		I
132628220	P49183	09/19/2013	23:45	09/20/2013	1:45	8	960	120	Underground equipment	Underground Primary	Switch/Reset	Repair	I
132631188	Q01282	09/20/2013	0:05	09/20/2013	5:19	16	5024	314	Tree related-tree contact	Overhead Primary			III
132631309		09/20/2013	0:08	09/20/2013	1:28	470	37600	80	Weather				III
132631190		09/20/2013	0:08	09/20/2013	1:28	455	36400	80	Weather				III
132631268	U33509	09/20/2013	0:18	09/20/2013	1:53	942	89490	95	Tree related-tree broken	Substation Breaker	Repair	Repair	II
132631275	V92542	09/20/2013	0:37	09/20/2013	2:00	1	83	83	Overhead equipment	Disconnect Switch	Replace - Same Size		II
132631300	D31016	09/20/2013	0:50	09/20/2013	5:45	1	295	295	Overhead equipment	Fuse	Replace - Same Size		III
132631319	M51275	09/20/2013	0:51	09/20/2013	8:15	5	2220	444	Weather	Overhead Primary			III
132631312	J56342	09/20/2013	1:24	09/20/2013	3:49	7	1015	145	Overhead equipment	Transformer Fuse	Repair	Repair	III
132631314	H00163	09/20/2013	1:26	09/20/2013	6:45	1	319	319	Tree related-tree contact	Overhead Secondary	Repair	Repair	III
132631360	L86175	09/20/2013	2:06	09/20/2013	4:54	114	19152	168	Underground equipment	Underground Primary	Switch/Reset	Switch/Reset	IV
132631359	A85002	09/20/2013	2:09	09/20/2013	4:33	12	1728	144	Underground equipment	Underground Primary		Repair	I
132631638	J80807	09/20/2013	2:25	09/20/2013	6:20	82	19270	235	Overhead equipment	Overhead Primary	Repair	Repair	V
132631582	S28227	09/20/2013	2:33	09/20/2013	4:30	1501	175617	117	Weather				VI
132631592	S28229	09/20/2013	2:33	09/20/2013	4:35	2475	301950	122	Weather				VI
132631620	S28552	09/20/2013	2:35	09/20/2013	4:53	819	113022	138	Substation equipment				VI
132631624	S28551	09/20/2013	2:36	09/20/2013	5:02	187	27302	146	Substation equipment				VI
132635566		09/20/2013	2:37	09/20/2013	5:31	455	79170	174	Weather				III
132635570	J67131	09/20/2013	2:37	09/20/2013	5:37	629	113220	180	Weather				III
132635568	J67133	09/20/2013	2:37	09/20/2013	5:33	689	121264	176	Weather				III
132635577	J67134	09/20/2013	2:37	09/20/2013	5:39	470	85540	182	Weather				III
132634365	Q06141	09/20/2013	3:45	09/20/2013	8:00	1	255	255	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	IV
132635507	A85001	09/20/2013	3:55	09/20/2013	5:55	1	120	120	Tree related-tree broken	Overhead Service	Trim		I
132635516	IP9009	09/20/2013	4:25	09/20/2013	6:25	1	120	120	Tree related-tree broken	Tree	Remove		VI
132635541	P05826	09/20/2013	4:35	09/20/2013	6:00	5	425	85	Weather	Transformer Fuse	Replace - Same Size		V
132635525	L81141	09/20/2013	4:40	09/20/2013	5:34	1	54	54	Tree related-tree contact	Transformer Fuse	Replace - Same Size		IV
132635546	J47178	09/20/2013	4:55	09/20/2013	7:00	52	6500	125	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	III
132635556	L99392	09/20/2013	5:20	09/20/2013	8:10	1	170	170	Overhead equipment	Overhead Transformer			V
132635569	L95211	09/20/2013	5:36	09/20/2013	9:27	3	693	231	Overhead equipment	Overhead Transformer			III
132635585	J84123	09/20/2013	5:52	09/20/2013	9:27	27	5805	215	Tree related-tree contact	Overhead Primary		Replace - Same Size	VI
132635668	G50002	09/20/2013	6:00	09/20/2013	7:18	26	2028	78	Weather	Fuse	Patrol/Test/Inspect	Replace - Same Size	IV
132635723	D39002	09/20/2013	6:41	09/20/2013	9:30	1	169	169	Underground equipment	Underground Transformer	Replace - Same Size		I
132635728	N72240	09/20/2013	6:45	09/20/2013	9:29	76	12464	164	Overhead equipment	Tree		Remove	III
132635776	P18104	09/20/2013	7:03	09/20/2013	8:30	29	2523	87	Underground equipment	Underground Primary	Switch/Reset	Repair	IV
132635792	B19002	09/20/2013	7:07	09/20/2013	11:02	72	16920	235	Weather	Pole	Patrol/Test/Inspect	Repair	I
132635781	C10001	09/20/2013	7:10	09/20/2013	7:40	1	30	30	Overhead equipment	Transformer Fuse	Replace - Same Size		III
132636069	P53341	09/20/2013	7:20	09/20/2013	9:21	5	605	121	Weather	Fuse	Replace - Same Size		IV
132636385	S86580	09/20/2013	7:25	09/20/2013	8:43	785	61230	78	Animal related				VI
132636274	P18104	09/20/2013	7:26	09/20/2013	8:30	31	1984	64	Underground equipment	Underground Primary	Switch/Reset	Repair	IV
132635971	S11761	09/20/2013	7:27	09/20/2013	9:00	790	73470	93	Animal related				VI
132636391	S86581	09/20/2013	7:27	09/20/2013	8:53	283	24338	86	Animal related				VI
132635889	L95110	09/20/2013	7:31	09/20/2013	8:00	1	29	29	Unknown	Fuse	Replace - Same Size		III

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
132635970	331152	09/20/2013	7:32	09/20/2013	8:20	644	30912	48	Overhead equipment	Overhead Primary			V
132635973	L50215	09/20/2013	7:39	09/20/2013	9:28	1	109	109	Overhead equipment	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
132636050	D39002	09/20/2013	7:59	09/20/2013	14:10	1	371	371	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Repair	I
132636077	J61115	09/20/2013	8:04	09/20/2013	10:58	12	2088	174	Tree related-tree contact	Overhead Secondary	Repair	Repair	III
132636081	S04545	09/20/2013	8:05	09/20/2013	10:12	1	127	127	Tree related-tree contact	Overhead Primary	Repair		VI
132636291	S04545	09/20/2013	8:10	09/20/2013	10:12	7	854	122	Tree related-tree contact	Overhead Primary	Repair	Patrol/Test/Inspect	VI
132636286	L11244	09/20/2013	8:11	09/20/2013	9:08	59	3363	57	Overhead equipment	Overhead Primary	Repair		III
132636211	D69006	09/20/2013	8:15	09/20/2013	9:43	1	88	88	Overhead equipment				I
132636242	D39002	09/20/2013	8:19	09/20/2013	10:15	1	116	116	Weather	Underground Transformer	Replace - Same Size		I
132636337	M07236	09/20/2013	8:37	09/20/2013	9:20	57	2451	43	Unknown	Fuse	Replace - Same Size		III
132636421	U97520	09/20/2013	8:56	09/20/2013	12:10	1	194	194	Overhead equipment	Overhead Transformer	Replace - Same Size	Replace - Same Size	II
132636464	D96001	09/20/2013	9:06	09/20/2013	10:10	1	64	64	Animal related	Fuse	Replace - Same Size		I
132636508	J76804	09/20/2013	9:16	09/20/2013	13:27	7	1757	251	Overhead equipment	Overhead Secondary	Repair	Repair	V
132636519	X39530	09/20/2013	9:19	09/20/2013	11:41	1	142	142	Animal related	Disconnect Switch	Replace - Same Size		IV
132636554	V45526	09/20/2013	9:26	09/20/2013	14:58	1	332	332	Underground equipment	Underground Primary		Repair	II
132636571	Y79500	09/20/2013	9:29	09/20/2013	10:22	38	2014	53	Overhead equipment	Fuse	Replace - Same Size		IV
132636733	B73002	09/20/2013	10:05	09/20/2013	11:37	1	92	92	Overhead equipment	Disconnect Switch	Replace - Same Size	No Work Required	I
132636737	K80386	09/20/2013	10:06	09/20/2013	12:05	1	119	119	Tree related-tree broken	Overhead Service	Repair		IV
132636856	M36189	09/20/2013	10:28	09/20/2013	13:32	1	184	184	Overhead equipment	Overhead Transformer	No Work Required	Repair	I
132636855	Q82906	09/20/2013	10:28	09/20/2013	11:34	1	66	66	Animal related	Fuse	Replace - Same Size		VI
132636883	Y79500	09/20/2013	10:35	09/20/2013	11:50	7	525	75	Animal related	Transformer Fuse	Replace - Same Size		IV
132636992	H22348	09/20/2013	11:00	09/20/2013	12:12	1	72	72	Jurisdictional				V
132637002	F10003	09/20/2013	11:02	09/20/2013	11:35	1	33	33	Unknown	Fuse	Replace - Same Size	Repair	III
132637099	J83138	09/20/2013	11:21	09/20/2013	11:44	1	23	23	Animal related	Transformer Fuse	Replace - Same Size		VI
132637115	M47802	09/20/2013	11:25	09/20/2013	12:10	1	45	45	Animal related	Fuse	Repair	Repair	V
132637140	N44216	09/20/2013	11:28	09/20/2013	14:23	1	175	175	Overhead equipment	Overhead Transformer		Replace - Same Size	III
132637163	J34357	09/20/2013	11:31	09/20/2013	13:50	14	1946	139	Underground equipment	Underground Primary	Switch/Reset	Repair	V
132637172	S01511	09/20/2013	11:35	09/20/2013	12:17	7	294	42	Overhead equipment	Fuse	Repair	Replace - Same Size	VI
132637222	V42586	09/20/2013	11:45	09/20/2013	12:25	1	40	40	Animal related	Transformer Fuse	Replace - Same Size		II
132637234	M45212	09/20/2013	11:49	09/20/2013	12:17	1	28	28	Unknown	Transformer Fuse	Replace - Same Size		IV
132637293	X75512	09/20/2013	12:02	09/20/2013	12:30	1	28	28	Overhead equipment	Overhead Service	Repair		IV
132637360	J01119	09/20/2013	12:21	09/20/2013	13:22	1	61	61	Overhead equipment	Overhead Service	No Work Required		I
132637389	F10003	09/20/2013	12:27	09/20/2013	13:25	1	58	58	Animal related	Fuse	Replace - Same Size	Repair	III
132637415	N67312	09/20/2013	12:33	09/20/2013	13:35	48	2976	62	Overhead equipment	Overhead Primary	Repair	Repair	I
132637430	N67312	09/20/2013	12:36	09/20/2013	12:44	1	8	8	Overhead equipment	Overhead Primary	Replace - Same Size	Replace - Same Size	I
132637524	P73158	09/20/2013	13:01	09/20/2013	13:24	1	23	23	Animal related	Fuse	Replace - Same Size		VI
132637557	B68001	09/20/2013	13:07	09/20/2013	14:20	1	73	73	Public	Underground Transformer	No Work Required	Repair	III
132637678	S64502	09/20/2013	13:38	09/20/2013	14:54	1	76	76	Animal related	Disconnect Switch	Replace - Same Size		VI
132637739	K31124	09/20/2013	13:47	09/20/2013	17:29	1	222	222	Weather	Overhead Transformer	Replace - Same Size	Replace - Same Size	I
132637783	Y89535	09/20/2013	13:54	09/20/2013	14:20	1	26	26	Overhead equipment	Transformer Fuse	Repair	Replace - Same Size	IV
132637862	J84146	09/20/2013	14:09	09/20/2013	15:04	13	715	55	Animal related	Fuse	Replace - Same Size		VI
132637872	H10843	09/20/2013	14:11	09/20/2013	14:55	1	44	44	Weather	Transformer Fuse	Replace - Same Size		V
132637876	K76541	09/20/2013	14:12	09/20/2013	15:50	1	98	98	Animal related	Fuse	Replace - Same Size	No Work Required	IV
132637958	B19002	09/20/2013	14:34	09/20/2013	15:50	1	76	76	Overhead equipment	Transformer Fuse	Replace - Same Size	No Work Required	I
132638060	N13861	09/20/2013	14:58	09/20/2013	15:48	1	50	50	Overhead equipment	Lightning Arrestor	Replace - Same Size	No Work Required	V
132638489	K48380	09/20/2013	15:37	09/20/2013	18:55	2	396	198	Tree related-tree broken	Tree	Remove		V
132638201	K48380	09/20/2013	15:37	09/20/2013	16:22	6	270	45	Tree related-tree contact	Tree	Patrol/Test/Inspect	Trim	V
132638203	F03003	09/20/2013	15:40	09/20/2013	21:37	1	357	357	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	III
132638249	R29343	09/20/2013	15:47	09/21/2013	2:12	5	3125	625	Overhead equipment	Pole	Replace - Same Size		VI
132638272	K58210	09/20/2013	16:05	09/20/2013	18:20	5	675	135	Animal related	Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
132638300	Y28597	09/20/2013	16:16	09/20/2013	18:10	3	342	114	Overhead equipment	Fuse	Patrol/Test/Inspect	Replace - Same Size	IV
132638305	K74162	09/20/2013	16:17	09/20/2013	18:20	1	123	123	Other	Meter	Replace - Same Size	No Work Required	IV
132638313	303006	09/20/2013	16:20	09/20/2013	17:20	1	60	60	Public	Meter	Replace - Same Size		VI
132638354	B73003	09/20/2013	16:38	09/20/2013	17:22	2	88	44	Animal related	Fuse	Replace - Same Size		I
132638396	309139	09/20/2013	16:52	09/20/2013	17:46	1	54	54	Jurisdictional	Meter	Reconnect		V
132638424	B21004	09/20/2013	17:00	09/20/2013	20:20	1	200	200	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
132638446	J47178	09/20/2013	17:05	09/20/2013	20:51	52	11752	226	Underground equipment	Underground Primary			III
132638466	P80145	09/20/2013	17:20	09/20/2013	18:16	6	336	56	Tree related-tree contact	Transformer Fuse	Replace - Same Size		I
132638476	D39002	09/20/2013	17:24	09/20/2013	19:03	1	99	99	Overhead equipment	Fuse	Replace - Same Size		I
132638494	J99127	09/20/2013	17:39	09/20/2013	21:45	1	246	246	Tree related-tree broken	Overhead Service		Replace - Same Size	VI
132638504	V10545	09/20/2013	17:47	09/20/2013	20:00	5	665	133	Underground equipment	Underground Primary	Patrol/Test/Inspect	Switch/Reset	II
132638560	K89142	09/20/2013	18:17	09/20/2013	19:48	1	91	91	Underground equipment	Underground Service		Repair	III
132638687	A17025	09/20/2013	18:30	09/20/2013	19:13	1	43	43	Overhead equipment	Fuse	Replace - Same Size		I
132639381	D93001	09/20/2013	20:02	09/20/2013	21:26	9	756	84	Overhead equipment	Disconnect Switch		Replace - New Size	IV
132639460	B71001	09/20/2013	20:41	09/20/2013	22:00	27	2133	79	Tree related-tree broken	Fuse	Replace - Same Size		I
132639420	K01240	09/20/2013	20:45	09/20/2013	21:25	1	40	40	Overhead equipment	Connector	Tie/Tighten		VI
132639453	338002	09/20/2013	21:16	09/20/2013	22:50	34	3196	94	Public	Overhead Primary	Repair		VI
132639461	Y64011	09/20/2013	21:27	09/20/2013	23:15	1	108	108	Overhead equipment	Overhead Service	Repair		IV
132639484	S66579	09/20/2013	22:07	09/20/2013	22:57	1	50	50	Overhead equipment	Fuse	Replace - Same Size		VI
132639489	R01153	09/20/2013	23:02	09/21/2013	2:43	1	221	221	Other	Pole			III
132639499	V49535	09/20/2013	23:21	09/21/2013	5:15	1	354	354	Underground equipment	Underground Primary		Repair	II
132639508	T05539	09/20/2013	23:41	09/21/2013	0:44	15	945	63	Overhead equipment	Fuse	Repair	Replace - Same Size	VI
132640013	N05172	09/21/2013	0:07	09/21/2013	1:20	109	7957	73	Overhead equipment	Fuse	Replace - Same Size		I
132640020		09/21/2013	0:57	09/21/2013	3:00	1	123	123	Overhead equipment	Lightning Arrestor	Cut in Clear		I
132640026	P80145	09/21/2013	1:31	09/21/2013	10:30	35	18865	539	Public	Pole	Patrol/Test/Inspect	Replace - Same Size	I
132640039	V18541	09/21/2013	2:24	09/21/2013	7:23	20	5980	299	Underground equipment	Underground Primary		Switch/Reset	II
132640058	D96001	09/21/2013	2:51	09/21/2013	8:00	17	5253	309	Overhead equipment	Pole		Repair	I
132640074	A68001	09/21/2013	3:22	09/21/2013	6:25	15	2745	183	Overhead equipment	Recloser	No Work Required	No Work Required	I
132640073	303002	09/21/2013	4:09	09/21/2013	6:20	1	131	131	Public	Overhead Service	Advise Customer		VI
132640084	D89001	09/21/2013	5:06	09/21/2013	11:30	5	1920	384	Underground equipment	Underground Primary	Patrol/Test/Inspect	Replace - Urgent	I
132640086	V49535	09/21/2013	5:25	09/21/2013	6:25	1	60	60	Animal related	Fuse	Replace - Same Size		II
132640104	C52002	09/21/2013	7:00	09/21/2013	8:20	30	2400	80	Animal related	Fuse	Replace - Same Size	No Work Required	III
132640126	S78551	09/21/2013	7:42	09/21/2013	9:00	5	390	78	Animal related	Transformer Fuse			VI
132640166	P83710	09/21/2013	7:52	09/21/2013	9:19	141	12267	87	Animal related	Fuse	Patrol/Test/Inspect		I
132640164	K46388	09/21/2013	7:55	09/21/2013	9:50	22	2530	115	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	V
132640188	K46388	09/21/2013	8:02	09/21/2013	9:00	9	522	58	Underground equipment	Underground Primary	Patrol/Test/Inspect		V
132640153	M09175	09/21/2013	8:06	09/21/2013	12:47	9	2529	281	Overhead equipment	Overhead Secondary	Replace - Same Size	Repair	VI
132640157	V46563	09/21/2013	8:07	09/21/2013	9:18	11	781	71	Animal related	Transformer Fuse	Replace - Same Size		II
132640193	J79305	09/21/2013	8:25	09/21/2013	11:58	1	213	213	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	I
132640203	T12527	09/21/2013	8:36	09/21/2013	10:00	1	84	84	Overhead equipment	Disconnect Switch	Patrol/Test/Inspect	Replace - Same Size	VI
132640284	A56014	09/21/2013	8:56	09/21/2013	9:22	1	26	26	Overhead equipment				I
132640304	N67309	09/21/2013	9:09	09/21/2013	11:02	4	452	113	Overhead equipment	Overhead Secondary	Replace - Same Size	Replace - Same Size	I
132640308	J07135	09/21/2013	9:16	09/21/2013	10:13	1	57	57	Overhead equipment				I
132640327	M09144	09/21/2013	9:19	09/21/2013	12:46	151	31257	207	Overhead equipment	Fuse	Replace - Same Size	Repair	VI
132640321	M81403	09/21/2013	9:26	09/21/2013	11:12	1	106	106	Overhead equipment	Overhead Service	Replace - Same Size	Repair	V
132640326	T15570	09/21/2013	9:31	09/21/2013	11:00	1	89	89	Overhead equipment	Overhead Service	Patrol/Test/Inspect	Repair	VI
132640340	C52001	09/21/2013	9:44	09/21/2013	10:35	1	51	51	Animal related	Fuse	Replace - Same Size	No Work Required	III
132640351	341003	09/21/2013	9:57	09/21/2013	10:30	1	33	33	Overhead equipment	Fuse	Repair		VI
132640365	K46388	09/21/2013	10:10	09/21/2013	16:28	12	4536	378	Underground equipment	Underground Transformer	Replace - Same Size		V
132640473	D36001	09/21/2013	11:21	09/21/2013	12:24	93	5859	63	Animal related	Fuse	Replace - Same Size		I
132640457	D87001	09/21/2013	11:23	09/21/2013	16:34	1	311	311	Underground equipment	Underground Primary		Repair	I
132640455	K27150	09/21/2013	11:24	09/21/2013	14:10	1	166	166	Animal related	Transformer Fuse	Replace - Same Size	Replace - Same Size	VI
132640493	L59929	09/21/2013	11:49	09/21/2013	13:50	1	121	121	Tree related-tree broken	Overhead Service	Repair		VI
132640508	X69555	09/21/2013	12:06	09/21/2013	13:09	1	63	63	Animal related	Transformer Fuse			IV
132640595	N44216	09/21/2013	12:24	09/21/2013	15:25	1	181	181	Overhead equipment	Overhead Transformer	Replace - Urgent		III
132640552	N44216	09/21/2013	12:24	09/21/2013	13:39	428	32100	75	Animal related	Recloser	Switch/Reset		III
132640601	P18104	09/21/2013	13:34	09/21/2013	15:00	24	2064	86	Underground equipment	Underground Primary	Switch/Reset	Repair	IV
132640596	S36570	09/21/2013	13:39	09/21/2013	16:55	1	196	196	Animal related	Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
132640613	350103	09/21/2013	13:58	09/21/2013	14:55	1	57	57	Tree related-tree broken	Tree	Trim	Replace - New Size	V
132640629	C30002	09/21/2013	14:20	09/21/2013	16:30	1	130	130	Overhead equipment	Underground Primary	Replace - Same Size		III
132640641	Z33507	09/21/2013	14:49	09/21/2013	15:39	1	50	50	Overhead equipment	Overhead Service	Repair	Replace - Same Size	IV
132640677	R95520	09/21/2013	15:38	09/21/2013	16:59	20	1620	81	Tree related-tree broken	Fuse	Replace - Same Size		I

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
132640702	D60001	09/21/2013	16:38	09/21/2013	17:51	1	73	73	Overhead equipment	Overhead Secondary	Cut in Clear	Repair	III
132640709	J06168	09/21/2013	16:42	09/21/2013	17:49	9	603	67	Public	Guy Wire	Cut in Clear		I
132640748	J06168	09/21/2013	16:42	09/21/2013	17:49	58	3886	67	Public	Guy Wire	Cut in Clear		I
132640718	U64521	09/21/2013	16:49	09/21/2013	17:50	1	61	61	Animal related	Fuse	Replace - Same Size		II
132640760	R74862	09/21/2013	17:49	09/22/2013	2:00	1	491	491	Underground equipment	Underground Primary	Repair	Repair	V
132640773	L59929	09/21/2013	18:26	09/21/2013	20:10	1	104	104	Overhead equipment	Overhead Service	Repair	Repair	VI
132640785	N90248	09/21/2013	18:55	09/21/2013	21:17	1	142	142	Overhead equipment	Overhead Secondary			III
132640778	S13547	09/21/2013	19:09	09/21/2013	22:16	1	187	187	Overhead equipment				VI
132640792	Q16867	09/21/2013	19:23	09/21/2013	22:51	1	208	208	Other	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	V
132640823	J15303	09/21/2013	20:16	09/21/2013	22:13	1	117	117	Overhead equipment	Overhead Service	Reconnect		I
132640838	L23146	09/21/2013	21:25	09/21/2013	22:17	1	52	52	Overhead equipment	Connector	Replace - New Size		III
132640841	C52001	09/21/2013	21:33	09/22/2013	0:01	1	148	148	Overhead equipment	Overhead Service	Repair	No Work Required	III
132640845	U37001	09/21/2013	21:48	09/21/2013	22:55	8	536	67	Overhead equipment	Transformer Fuse	Replace - Same Size	Patrol/Test/Inspect	II
132650008	Y06573	09/22/2013	0:56	09/22/2013	3:20	21	3024	144	Underground equipment	Underground Primary	Repair	Repair	IV
132650022	N95859	09/22/2013	3:39	09/22/2013	4:33	1	54	54	Overhead equipment	Overhead Primary	No Work Required		V
132650031	A81004	09/22/2013	4:18	09/22/2013	7:41	23	4669	203	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
132650034	B77003	09/22/2013	4:55	09/22/2013	9:54	107	31993	299	Public	Pole		Repair	I
132650048	N18211	09/22/2013	6:09	09/22/2013	8:15	1	126	126	Animal related	Fuse	Replace - Same Size		III
132650052	P57108	09/22/2013	6:46	09/22/2013	8:55	1	129	129	Animal related	Transformer Fuse	Replace - Same Size		VI
132650076	Q95249	09/22/2013	6:48	09/22/2013	10:17	1229	256861	209	Overhead equipment	Recloser	Switch/Reset	Repair	VI
132650087	374069	09/22/2013	7:08	09/22/2013	11:10	1	242	242	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	VI
132650094	X60598	09/22/2013	7:13	09/22/2013	9:00	18	1926	107	Animal related	Fuse	Replace - Same Size		IV
132650116	P49188	09/22/2013	7:44	09/22/2013	9:37	5	565	113	Animal related	Transformer Fuse	Replace - Same Size		I
132650125	P49188	09/22/2013	7:55	09/22/2013	9:35	1	100	100	Animal related	Transformer Fuse	Replace - Same Size		I
132650124	D37003	09/22/2013	7:55	09/22/2013	12:15	1	260	260	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
132650128	R04407	09/22/2013	7:56	09/22/2013	8:10	1	14	14	Animal related	Transformer Fuse	Replace - Same Size	Replace - Same Size	V
132650130	K78352	09/22/2013	7:59	09/22/2013	9:24	4	340	85	Animal related	Fuse	Replace - Same Size		IV
132650136	J14142	09/22/2013	8:08	09/22/2013	12:17	1	249	249	Overhead equipment	Overhead Transformer	Replace - Same Size	Replace - Same Size	VI
132650140	K52401	09/22/2013	8:14	09/22/2013	9:03	1	49	49	Animal related	Transformer Fuse	Replace - Same Size	Replace - Same Size	V
132650141	M36185	09/22/2013	8:15	09/22/2013	8:59	11	484	44	Animal related	Transformer Fuse	Replace - Same Size		I
132650159	K78352	09/22/2013	8:21	09/22/2013	9:22	5	305	61	Animal related	Fuse	Replace - Same Size		IV
132650161	Q95248	09/22/2013	8:30	09/22/2013	9:55	1	85	85	Overhead equipment				VI
132650170	P49188	09/22/2013	8:35	09/22/2013	9:55	1	80	80	Overhead equipment	Transformer Fuse	Replace - Same Size		I
132650173	M09144	09/22/2013	8:38	09/22/2013	10:11	1	93	93	Animal related	Fuse	Replace - Same Size	Repair	VI
132650211	S15566	09/22/2013	9:15	09/22/2013	10:55	1	100	100	Overhead equipment	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
132650238	U13551	09/22/2013	9:38	09/22/2013	10:35	1	57	57	Animal related	Transformer Fuse	Replace - Same Size	Patrol/Test/Inspect	II
132650239	L99392	09/22/2013	9:38	09/22/2013	10:57	1	79	79	Overhead equipment	Connector	Repair	Repair	V
132650248	U99593	09/22/2013	9:58	09/22/2013	11:25	3	261	87	Animal related	Disconnect Switch	Replace - Same Size		II
132650291	L24123	09/22/2013	10:26	09/22/2013	11:15	16	784	49	Animal related	Fuse	Repair		III
132650269	R53416	09/22/2013	10:31	09/22/2013	12:17	12	1272	106	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	V
132650274	S93504	09/22/2013	10:36	09/22/2013	11:51	1	75	75	Animal related	Fuse	Replace - Same Size	Replace - Same Size	VI
132650290	B62003	09/22/2013	11:04	09/22/2013	12:15	55	3905	71	Animal related	Disconnect Switch	Replace - Same Size		I
132650288	B93003	09/22/2013	11:06	09/22/2013	13:35	1	149	149	Animal related	Animal Guard			I
132650295	D93002	09/22/2013	11:14	09/22/2013	11:43	1	29	29	Jurisdictional	Overhead Service	Reconnect	Advise Customer	IV
132650306	L24123	09/22/2013	11:15	09/22/2013	11:51	90	3240	36	Animal related	Fuse	Repair		III
132650301	S79510	09/22/2013	11:18	09/22/2013	12:31	1	73	73	Animal related	Transformer Fuse			VI
132650317	X60595	09/22/2013	11:23	09/22/2013	13:00	19	1843	97	Unknown	Fuse	Replace - Same Size		IV
132650329	U02597	09/22/2013	11:46	09/22/2013	12:45	2	118	59	Animal related	Transformer Fuse	Replace - Same Size	Patrol/Test/Inspect	II
132650335	Q64939	09/22/2013	11:59	09/22/2013	13:00	1	61	61	Animal related	Fuse	Replace - Same Size	Replace - Same Size	VI
132650336	X88510	09/22/2013	12:00	09/22/2013	13:44	2	208	104	Animal related	Transformer Fuse	Replace - Same Size	Replace - Same Size	IV
132650340	R34920	09/22/2013	12:05	09/22/2013	13:50	1	105	105	Animal related	Fuse	Replace - Same Size	Replace - Same Size	VI
132650425	S83503	09/22/2013	13:15	09/22/2013	14:55	22	2200	100	Overhead equipment	Fuse	Replace - Same Size		VI
132650437	T17582	09/22/2013	13:47	09/22/2013	17:11	37	7548	204	Animal related	Disconnect Switch	Repair	Replace - Same Size	VI
132650439	A97001	09/22/2013	13:49	09/22/2013	14:55	1	66	66	Animal related	Fuse	Replace - Same Size		I
132650449	F03004	09/22/2013	14:19	09/22/2013	15:41	5	410	82	Animal related	Fuse	Replace - Same Size	No Work Required	III
132650463	U99593	09/22/2013	15:02	09/22/2013	16:12	2	140	70	Animal related	Animal Guard			II

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
132650464	V46552	09/22/2013	15:03	09/22/2013	18:30	1	207	207	Underground equipment	Underground Primary	Repair	Repair	II
132650523	S83503	09/22/2013	15:06	09/22/2013	17:15	22	2838	129	Overhead equipment	Overhead Primary		Repair	VI
132650485	U97520	09/22/2013	16:02	09/22/2013	17:10	1	68	68	Overhead equipment	Connector	Repair	Repair	II
132650493	B80004	09/22/2013	16:06	09/22/2013	23:30	3	1332	444	Overhead equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
132650490	D93002	09/22/2013	16:13	09/22/2013	17:54	1	101	101	Animal related	Animal Guard	Install	Replace - New Size	IV
132650496	S49549	09/22/2013	16:25	09/22/2013	17:05	1	40	40	Overhead equipment				VI
132650520	U64518	09/22/2013	17:05	09/22/2013	18:16	2	142	71	Animal related	Overhead Primary	Replace - Same Size	Replace - Same Size	II
132650555	Q34365	09/22/2013	18:47	09/22/2013	20:20	1	93	93	Tree related-tree contact	Fuse	Replace - Same Size	Replace - Same Size	I
132650594	N18211	09/22/2013	19:52	09/22/2013	21:35	1	103	103	Animal related	Transformer Fuse	Replace - Same Size		III
132650601	J61114	09/22/2013	20:06	09/22/2013	23:45	1	219	219	Unknown	Overhead Service			III
132650641	T17582	09/22/2013	22:08	09/23/2013	0:02	1	114	114	Overhead equipment	Fuse	Repair	Replace - Same Size	VI
132650645	J87111	09/22/2013	22:21	09/23/2013	0:08	1	107	107	Tree related-tree contact	Tree	Remove		VI
132660119	A28001	09/22/2013	23:50	09/23/2013	4:09	437	113183	259	Underground equipment	Underground Primary	Switch/Reset		I
132660120	A28002	09/22/2013	23:50	09/23/2013	4:09	318	82362	259	Underground equipment	Underground Primary	Switch/Reset	Repair	I
132660114	A97002	09/22/2013	23:50	09/23/2013	4:09	871	225589	259	Underground equipment	Underground Primary	Switch/Reset		I
132660099	M78325	09/22/2013	23:59	09/23/2013	5:40	17	5797	341	Underground equipment	Underground Primary			V
132660122	K74162	09/23/2013	0:22	09/23/2013	1:11	1	49	49	Animal related	Transformer Fuse	Replace - Same Size		IV
132664805	B81003	09/23/2013	3:45	09/23/2013	3:50	1043	5215	5	Underground equipment	Underground Primary	Switch/Reset		I
132664813	D39002	09/23/2013	4:54	09/23/2013	7:47	1	173	173	Weather	Fuse	Replace - Same Size		I
132664818	U44529	09/23/2013	5:33	09/23/2013	6:40	1	67	67	Overhead equipment	Transformer Fuse	Repair	Repair	II
132664840	B84002	09/23/2013	6:13	09/23/2013	9:52	86	18834	219	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
132664851		09/23/2013	6:32	09/23/2013	9:13	1	161	161	Overhead equipment	Jumper	Repair		IV
132664857	A73002	09/23/2013	6:42	09/23/2013	9:52	1	190	190	Animal related	Disconnect Switch	Replace - Same Size	No Work Required	I
132664867	P98193	09/23/2013	6:52	09/23/2013	9:53	1	181	181	Unknown	Fuse	Repair	Repair	III
132664884	Y39521	09/23/2013	7:06	09/23/2013	8:09	1	63	63	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
132664910	M47802	09/23/2013	7:19	09/23/2013	7:35	1	16	16	Animal related	Fuse	Repair	Repair	V
132664933	V17574	09/23/2013	7:25	09/23/2013	8:22	1	57	57	Unknown	Fuse	Replace - Same Size		II
132665073	V17574	09/23/2013	8:08	09/23/2013	12:55	1	287	287	Underground equipment	Underground Primary	Repair	Repair	II
132665146	L68114	09/23/2013	8:19	09/23/2013	9:13	10	540	54	Overhead equipment	Jumper	Repair	No Work Required	IV
132665120	A85002	09/23/2013	8:21	09/23/2013	15:00	1	399	399	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
132665118		09/23/2013	8:21	09/23/2013	11:16	1	175	175	Overhead equipment	Transformer Fuse	Repair	Repair	V
132665143	V03562	09/23/2013	8:28	09/23/2013	10:05	1	97	97	Animal related	Fuse	Replace - Same Size	No Work Required	II
132665171	S86581	09/23/2013	8:32	09/23/2013	14:55	1	383	383	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	VI
132665207	F10001	09/23/2013	8:40	09/23/2013	13:20	1	280	280	Overhead equipment	Overhead Primary			III
132665236	F10002	09/23/2013	8:48	09/23/2013	9:30	1	42	42	Overhead equipment	Fuse	Replace - Same Size	Repair	III
132665270	D31016	09/23/2013	8:57	09/23/2013	9:55	1	58	58	Animal related	Transformer Fuse	Replace - Same Size		III
132665376	X88510	09/23/2013	9:15	09/23/2013	10:10	1	55	55	Animal related	Transformer Fuse	Replace - Same Size		IV
132665614	P42229	09/23/2013	9:33	09/23/2013	10:35	19	1178	62	Animal related	Fuse	Switch/Reset		VI
132665480	U05595	09/23/2013	9:35	09/23/2013	11:00	1	85	85	Overhead equipment	Transformer Fuse	Replace - Same Size		II
132665537	R48167	09/23/2013	9:38	09/23/2013	10:46	45	3060	68	Overhead equipment	Fuse			IV
132665501	K01241	09/23/2013	9:39	09/23/2013	10:47	1	68	68	Underground equipment	Underground Service	Repair		VI
132665613	K89141	09/23/2013	9:54	09/23/2013	10:34	1	40	40	Animal related	Fuse	Replace - Same Size		III
132665641	C50003	09/23/2013	10:00	09/23/2013	11:00	1	60	60	Overhead equipment	Fuse	Replace - Same Size		III
132665700	B00002	09/23/2013	10:10	09/23/2013	11:00	36	1800	50	Animal related	Fuse	Replace - Same Size		I
132665752	R73841	09/23/2013	10:22	09/23/2013	12:55	12	1836	153	Animal related	Fuse	Replace - Same Size		V
132665854	310123	09/23/2013	10:31	09/23/2013	11:12	14	574	41	Animal related	Fuse	Replace - Same Size		V
132665813	344003	09/23/2013	10:32	09/23/2013	12:05	1	93	93	Public	Overhead Service	Repair		VI
132665905		09/23/2013	10:45	09/23/2013	11:17	1	32	32	Other	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
132666249	Z17503	09/23/2013	10:51	09/23/2013	14:44	9	2097	233	Public	Underground Primary	Repair	Repair	IV
132666092	H10843	09/23/2013	11:14	09/23/2013	12:53	1	99	99	Weather	Transformer Fuse	Replace - Same Size		V
132666130	J01118	09/23/2013	11:20	09/23/2013	12:22	1	62	62	Overhead equipment	Fuse	Replace - Same Size		I
132666247	B93002	09/23/2013	11:40	09/23/2013	12:49	1	69	69	Overhead equipment	Disconnect Switch	Replace - Same Size		I
132666422	P42229	09/23/2013	12:09	09/23/2013	13:20	1	71	71	Animal related	Fuse	Replace - Same Size		VI
132666321	K76543	09/23/2013	12:32	09/23/2013	14:10	1	98	98	Overhead equipment	Overhead Transformer	Replace - Same Size		IV
132669229	K57211	09/23/2013	13:04	09/23/2013	22:55	7	4137	591	Underground equipment	Underground Primary	Repair	Repair	VI
132666738	K57211	09/23/2013	13:05	09/23/2013	15:00	37	4255	115	Unknown	Fuse	Patrol/Test/Inspect	Replace - Same Size	VI

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
132666721	Q32170	09/23/2013	13:07	09/23/2013	18:17	1	310	310	Underground equipment	Underground Service	Repair	Patrol/Test/Inspect	I
132666977	M40132	09/23/2013	13:50	09/23/2013	14:07	1	17	17	Overhead equipment	Overhead Service	No Work Required		I
132667235	Y63541	09/23/2013	14:33	09/23/2013	15:06	1	33	33	Animal related	Transformer Fuse	Replace - Same Size		IV
132667400	X69554	09/23/2013	15:04	09/23/2013	16:42	2	196	98	Overhead equipment	Overhead Service	Repair		IV
132668207	X75512	09/23/2013	15:23	09/23/2013	22:10	19	7733	407	Underground equipment	Underground Primary	Repair	Repair	IV
132667816	P44324	09/23/2013	15:29	09/23/2013	16:20	14	714	51	Public				I
132667589	X75512	09/23/2013	15:45	09/23/2013	18:41	28	4928	176	Underground equipment	Underground Primary	Repair	Repair	IV
132667535	K57211	09/23/2013	16:01	09/23/2013	17:32	8	728	91	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	VI
132667804	Q64919	09/23/2013	16:17	09/23/2013	17:30	12	876	73	Animal related	Overhead Primary	Patrol/Test/Inspect	Repair	VI
132667805	N44216	09/23/2013	16:23	09/23/2013	17:09	1	46	46	Unknown				III
132667874	J85161	09/23/2013	16:42	09/23/2013	17:41	1	59	59	Tree related-tree contact	Transformer Fuse	Replace - Same Size		VI
132667973	H06135	09/23/2013	17:19	09/23/2013	18:00	1	41	41	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
132668089	P54828	09/23/2013	17:22	09/23/2013	18:45	5	415	83	Animal related	Lightning Arrestor	Replace - Same Size		V
132668002	J80807	09/23/2013	17:26	09/23/2013	18:37	61	4331	71	Animal related	Overhead Primary	Repair	Repair	V
132668087	S43512	09/23/2013	17:57	09/23/2013	18:54	1	57	57	Overhead equipment				VI
132668115	S43512	09/23/2013	18:05	09/23/2013	19:31	1	86	86	Overhead equipment	Transformer Fuse	Repair	Replace - Same Size	VI
132668224	V74003	09/23/2013	19:14	09/24/2013	0:18	3	912	304	Underground equipment	Underground Primary	Repair		II
132668421	K48381	09/23/2013	19:50	09/23/2013	20:48	1	58	58	Overhead equipment	Connector	Replace - Same Size		V
132669158	C10002	09/23/2013	20:31	09/23/2013	21:35	1	64	64	Unknown	Other	No Work Required	No Work Required	III
132672615	M40132	09/24/2013	2:56	09/24/2013	6:00	57	10488	184	Other	Underground Primary	Repair	Repair	I
132674233	S15558	09/24/2013	3:38	09/24/2013	21:33	49	52675	1075	Underground equipment	Underground Primary		Replace - Same Size	VI
132674238	B80003	09/24/2013	4:31	09/24/2013	8:59	2	536	268	Underground equipment	Underground Primary	Replace - Same Size	Repair	I
132674242	B80003	09/24/2013	4:31	09/24/2013	6:05	17	1598	94	Overhead equipment	Fuse	Replace - Same Size		I
132675182	B93003	09/24/2013	5:43	09/24/2013	13:48	1	485	485	Underground equipment	Underground Primary	Repair	Repair	I
132674258	B93003	09/24/2013	5:43	09/24/2013	10:19	18	4968	276	Underground equipment				I
132674252	L82187	09/24/2013	5:54	09/24/2013	6:54	1	60	60	Animal related	Transformer Fuse	Replace - Same Size		IV
132674263	J05139	09/24/2013	6:17	09/24/2013	7:05	1	48	48	Animal related	Transformer Fuse	Replace - Same Size		I
132674278	B08001	09/24/2013	6:47	09/24/2013	7:45	116	6728	58	Tree related-tree broken	Overhead Primary	Remove		I
132674349	D16001	09/24/2013	7:15	09/24/2013	8:53	140	13720	98	Overhead equipment				I
132674833	B08001	09/24/2013	8:10	09/24/2013	9:27	13	1001	77	Animal related	Fuse	Patrol/Test/Inspect		I
132674551	Q27185	09/24/2013	8:19	09/24/2013	9:11	1	52	52	Animal related	Fuse	Replace - Same Size		VI
132674589		09/24/2013	8:38	09/24/2013	12:23	1	225	225	Overhead equipment	Overhead Primary	Patrol/Test/Inspect	Replace - New Size	VI
132674622	X87576	09/24/2013	8:48	09/24/2013	10:09	1	81	81	Animal related	Disconnect Switch	Replace - Same Size		IV
132674656	L23145	09/24/2013	8:56	09/24/2013	9:42	1	46	46	Animal related	Fuse	Replace - Same Size	Repair	III
132674725	A26005	09/24/2013	9:13	09/24/2013	10:26	1	73	73	Tree related-tree contact	Overhead Service			I
132674876	D16001	09/24/2013	9:20	09/24/2013	11:02	12	1224	102	Underground equipment	Underground Primary		Repair	I
132674928	M05362	09/24/2013	9:52	09/24/2013	11:16	50	4200	84	Overhead equipment	Fuse	Replace - Same Size		V
132674949	N35851	09/24/2013	9:58	09/24/2013	11:05	1	67	67	Animal related	Transformer Fuse	Replace - Same Size		V
132674997	N35851	09/24/2013	10:01	09/24/2013	11:05	8	512	64	Animal related	Transformer Fuse	Replace - Same Size		V
132675084	D90003	09/24/2013	10:12	09/24/2013	11:13	18	1098	61	Animal related	Other	Patrol/Test/Inspect	Patrol/Test/Inspect	III
132675286	R95520	09/24/2013	10:48	09/24/2013	12:31	1	103	103	Other	Overhead Service	Repair	Disconnect	I
132675306	M05360	09/24/2013	10:51	09/24/2013	11:59	1	68	68	Overhead equipment	Tree	Remove		V
132675371	L93133	09/24/2013	11:09	09/24/2013	13:18	1	129	129	Jurisdictional				VI
132676266	B19002	09/24/2013	11:12	09/24/2013	16:48	8	2688	336	Underground equipment	Underground Primary	Repair	Repair	I
132675631	P39298	09/24/2013	12:01	09/24/2013	13:06	1	65	65	Overhead equipment	Transformer Fuse		Repair	VI
132676002	H01190	09/24/2013	13:14	09/24/2013	14:18	1	64	64	Overhead equipment	Overhead Secondary	Repair		III
132676088	S86580	09/24/2013	13:27	09/24/2013	14:09	5	210	42	Animal related	Fuse	Replace - Same Size		VI
132676117	R09226	09/24/2013	13:30	09/24/2013	14:14	1	44	44	Animal related	Fuse			III
132676341	V84531	09/24/2013	14:10	09/24/2013	14:23	1	13	13	Overhead equipment	Fuse	Replace - Same Size		II
132676631	H14342	09/24/2013	15:06	09/24/2013	16:11	1	65	65	Other				V
132676679	L42158	09/24/2013	15:13	09/24/2013	16:16	1	63	63	Unknown	Lightning Arrestor	Replace - Same Size		III
132676720	V01002	09/24/2013	15:22	09/24/2013	16:40	1	78	78	Overhead equipment				II
132676763	M37191	09/24/2013	15:35	09/24/2013	16:36	5	305	61	Animal related	Transformer Fuse	Replace - Same Size		I
132676811	V40549	09/24/2013	15:46	09/24/2013	16:46	1	60	60	Animal related	Overhead Transformer	Repair		II
132676916	R20501	09/24/2013	16:14	09/24/2013	17:54	20	2000	100	Underground equipment	Underground Primary		Repair	IV
132677062	T11509	09/24/2013	17:00	09/24/2013	18:00	1	60	60	Animal related	Transformer Fuse			VI

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
132677152	K01240	09/24/2013	17:26	09/24/2013	18:23	16	912	57	Animal related	Fuse			VI
132677145	S93504	09/24/2013	17:32	09/24/2013	19:11	1	99	99	Overhead equipment	Overhead Service	Repair		VI
132677342	M21133	09/24/2013	19:24	09/24/2013	20:27	1	63	63	Animal related	Disconnect Switch	Replace - Same Size	No Work Required	VI
132677735	A49001	09/24/2013	19:37	09/25/2013	4:43	8	4368	546	Underground equipment	Underground Primary	Repair	Repair	I
132677355	D87001	09/24/2013	19:41	09/25/2013	5:52	1	611	611	Underground equipment	Underground Primary	Repair		I
132677733	L73184	09/24/2013	20:23	09/24/2013	22:30	1	127	127	Overhead equipment	Overhead Transformer		Replace - New Size	IV
132677757	R33126	09/24/2013	21:06	09/24/2013	21:51	1	45	45	Animal related	Transformer Fuse	Replace - Same Size	Patrol/Test/Inspect	I
132678328	U33586	09/24/2013	21:48	09/24/2013	22:51	1	63	63	Overhead equipment	Transformer Fuse	Repair	Repair	II
132678327	G10002	09/24/2013	21:49	09/24/2013	23:20	1	91	91	Tree related-tree contact	Tree	Cut in Clear		I
132678332	J76804	09/24/2013	22:17	09/25/2013	6:14	13	6201	477	Overhead equipment				V
132678383	R06211	09/24/2013	23:19	09/25/2013	0:35	1	76	76	Overhead equipment	Recloser	Patrol/Test/Inspect		II
132678386	R73841	09/24/2013	23:24	09/25/2013	4:50	1	326	326	Overhead equipment	Overhead Transformer	Replace - Same Size	Replace - Same Size	V
132678396	M18131	09/24/2013	23:44	09/25/2013	0:10	1	26	26	Overhead equipment	Jumper	Repair		III
132682443	S22592	09/25/2013	2:23	09/25/2013	3:40	1	77	77	Overhead equipment	Transformer Fuse	Replace - Same Size	Replace - Same Size	VI
132683842	S66593	09/25/2013	3:35	09/25/2013	8:20	9	2565	285	Underground equipment	Underground Primary	Repair	Repair	VI
132683838	M07235	09/25/2013	5:56	09/25/2013	9:15	1	199	199	Overhead equipment	Transformer Fuse			III
132683841	B45005	09/25/2013	6:04	09/25/2013	11:16	1	312	312	Underground equipment	Underground Primary		Repair	I
132684019	R68903	09/25/2013	7:44	09/25/2013	9:09	117	9945	85	Animal related	Regulator	Patrol/Test/Inspect	Repair	I
132684819	J12166	09/25/2013	8:35	09/25/2013	13:38	5	1515	303	Overhead equipment	Other			III
132684269	Q36412	09/25/2013	8:54	09/25/2013	10:15	1	81	81	Animal related	Fuse	Replace - Same Size	Repair	I
132684727	B80002	09/25/2013	8:59	09/25/2013	12:23	3	612	204	Public	Tree	Remove	Repair	I
132684319	B80002	09/25/2013	8:59	09/25/2013	10:10	82	5822	71	Public	Tree	Remove		I
132684334	U60559	09/25/2013	9:05	09/25/2013	9:58	1	53	53	Animal related	Fuse			II
132684358	S07536	09/25/2013	9:08	09/25/2013	11:15	1	127	127	Overhead equipment	Overhead Primary	Repair	Repair	VI
132684381	N83989	09/25/2013	9:11	09/25/2013	10:54	1	103	103	Animal related				I
132684445	Q27185	09/25/2013	9:22	09/25/2013	10:36	7	518	74	Animal related	Fuse	Replace - Same Size		VI
132684486	L74194	09/25/2013	9:22	09/25/2013	9:44	48	1056	22	Jurisdictional				IV
132684483	S43512	09/25/2013	9:29	09/25/2013	10:00	1	31	31	Overhead equipment	Lightning Arrestor	Replace - Same Size	No Work Required	VI
132684499	K71812	09/25/2013	9:33	09/25/2013	9:51	12	216	18	Animal related	Transformer Fuse	Replace - Same Size	No Work Required	IV
132685198	D93002	09/25/2013	9:45	09/25/2013	13:55	1	250	250	Underground equipment	Underground Primary	Repair		IV
132684818	D93002	09/25/2013	9:45	09/25/2013	11:15	16	1440	90	Underground equipment	Underground Primary	Switch/Reset		IV
132684921	D35001	09/25/2013	10:49	09/25/2013	17:13	1	384	384	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
132685042	K11373	09/25/2013	11:22	09/25/2013	11:52	1	30	30	Animal related	Fuse	Replace - Same Size		V
132685128	R73841	09/25/2013	11:46	09/25/2013	12:26	1	40	40	Animal related	Fuse	Replace - Same Size		V
132685463	Q83152	09/25/2013	12:43	09/25/2013	13:25	161	6762	42	Jurisdictional				VI
132685586	R34920	09/25/2013	13:07	09/25/2013	15:09	1	122	122	Animal related	Fuse	Replace - Same Size		VI
132685599	D28124	09/25/2013	13:10	09/25/2013	14:33	1	83	83	Public	Overhead Service	Repair		I
132685656	J07135	09/25/2013	13:20	09/25/2013	13:51	1	31	31	Overhead equipment	Transformer Fuse	Replace - Same Size		I
132685711	N58144	09/25/2013	13:30	09/25/2013	14:20	1	50	50	Unknown	Transformer Fuse	Replace - Same Size		I
132685766	S68512	09/25/2013	13:39	09/25/2013	14:30	1	51	51	Overhead equipment	Fuse	Replace - Same Size		VI
132686304	C00002	09/25/2013	15:38	09/25/2013	16:00	1	22	22	Underground equipment	Underground Transformer	Repair		I
132686458	D96001	09/25/2013	16:22	09/25/2013	18:48	1	146	146	Jurisdictional	Underground Service			I
132686561	R04415	09/25/2013	17:02	09/25/2013	20:43	1	221	221	Overhead equipment	Fuse	Replace - Same Size		V
132686585	B27009	09/25/2013	17:09	09/25/2013	18:21	1	72	72	Overhead equipment	Connector	Replace - Same Size		I
132686615	E10001	09/25/2013	17:16	09/26/2013	0:04	1	408	408	Underground equipment	Underground Primary	Repair		III
132686638	T15571	09/25/2013	17:23	09/25/2013	22:42	10	3190	319	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	VI
132686854	S88502	09/25/2013	18:34	09/25/2013	20:20	338	35828	106	Overhead equipment				VI
132687420	Z20543	09/25/2013	19:04	09/25/2013	21:40	1	156	156	Animal related	Animal Guard	Install	No Work Required	IV
132687451	N19371	09/25/2013	19:29	09/25/2013	20:08	1	39	39	Overhead equipment	Transformer Fuse	Replace - Same Size		V
132687453	N18211	09/25/2013	19:30	09/25/2013	20:25	1	55	55	Animal related	Transformer Fuse	Replace - Same Size		III
132687457	V45526	09/25/2013	19:34	09/25/2013	21:15	1	101	101	Overhead equipment				II
132687513	C10002	09/25/2013	20:30	09/25/2013	21:11	1	41	41	Overhead equipment	Transformer Fuse	Replace - Same Size		III
132690182	X02548	09/26/2013	1:38	09/26/2013	2:55	42	3234	77	Overhead equipment				IV
132690179	Q82906	09/26/2013	2:13	09/26/2013	3:25	4	288	72	Overhead equipment	Lightning Arrestor	Replace - Same Size	Replace - Same Size	VI
132693823	L00134	09/26/2013	3:21	09/26/2013	6:42	37	7437	201	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	III
132693832	R61242	09/26/2013	3:44	09/26/2013	7:00	16	3136	196	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	IV

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
132693908	B19001	09/26/2013	7:05	09/26/2013	9:49	5	820	164	Underground equipment	Fuse		Repair	I
132694079		09/26/2013	7:31	09/26/2013	8:38	1347	90249	67	Transmission outage				I
132693981	R84148	09/26/2013	7:33	09/26/2013	9:14	1	101	101	Unknown	Fuse	Patrol/Test/Inspect	Replace - Same Size	I
132694025	G30001	09/26/2013	7:38	09/26/2013	14:15	1	397	397	Overhead equipment	Overhead Transformer			III
132694050	J88163	09/26/2013	7:39	09/26/2013	9:24	1	105	105	Animal related	Fuse	Replace - Same Size		VI
132694123	P54827	09/26/2013	7:52	09/26/2013	9:19	1	87	87	Animal related	Transformer Fuse	Replace - Same Size		V
132694890	F03003	09/26/2013	7:58	09/26/2013	12:29	6	1626	271	Underground equipment	Underground Primary	Switch/Reset	Repair	III
132694749	F03003	09/26/2013	7:58	09/26/2013	9:24	4	344	86	Underground equipment	Underground Primary	Switch/Reset	Repair	III
132694185	P17107	09/26/2013	8:04	09/26/2013	9:24	1	80	80	Animal related	Transformer Fuse	Replace - Same Size		IV
132694806	HD0574	09/26/2013	8:53	09/26/2013	10:14	4	324	81	Animal related	Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
132694565	R99180	09/26/2013	9:21	09/26/2013	11:00	1	99	99	Underground equipment	Underground Primary	Switch/Reset	Repair	IV
132694588	P69174	09/26/2013	9:25	09/26/2013	10:26	1	61	61	Animal related	Fuse	Replace - Same Size		III
132694617	M19222	09/26/2013	9:30	09/26/2013	10:14	1	44	44	Animal related	Fuse	Replace - Same Size		VI
132694641	N94180	09/26/2013	9:36	09/26/2013	11:10	1	94	94	Animal related	Transformer Fuse	Replace - Same Size		I
132694689	T06505	09/26/2013	9:45	09/26/2013	10:54	1	69	69	Animal related	Fuse	Patrol/Test/Inspect	Repair	VI
132694721	U99593	09/26/2013	9:48	09/26/2013	11:35	154	16478	107	Public				II
132694713	J75271	09/26/2013	9:49	09/26/2013	11:32	1	103	103	Public	Underground Service	Patrol/Test/Inspect	Repair	IV
132694726	B19001	09/26/2013	9:51	09/26/2013	12:00	1	129	129	Underground equipment	Underground Primary			I
132694866	R06212	09/26/2013	10:12	09/26/2013	12:50	1	158	158	Underground equipment	Underground Secondary	Repair		II
132694907	Q04411	09/26/2013	10:19	09/26/2013	12:13	22	2508	114	Underground equipment	Underground Primary	Repair	Repair	III
132695039	K35308	09/26/2013	10:48	09/26/2013	11:40	1	52	52	Overhead equipment	Other			III
132695151	R50910	09/26/2013	11:12	09/26/2013	12:20	1	68	68	Unknown	Transformer Fuse	Replace - Same Size		I
132695212	P77233	09/26/2013	11:28	09/26/2013	13:51	1	143	143	Animal related	Transformer Fuse			VI
132695233	Q04411	09/26/2013	11:30	09/26/2013	12:16	29	1334	46	Underground equipment	Underground Primary	Repair	Repair	III
132695749	Q75146	09/26/2013	12:59	09/26/2013	16:40	8	1768	221	Overhead equipment	Pole	Replace - Same Size	Repair	VI
132695932	R04413	09/26/2013	13:55	09/26/2013	16:05	1	130	130	Underground equipment	Underground Service			V
132696051	F03004	09/26/2013	14:22	09/26/2013	15:59	1	97	97	Animal related	Fuse	Replace - Same Size		III
132696262	H01194	09/26/2013	15:06	09/26/2013	15:35	141	4089	29	Animal related	Recloser	Switch/Reset		III
132696327	H01194	09/26/2013	15:22	09/26/2013	15:35	1	13	13	Animal related	Recloser	Switch/Reset		III
132696336	H01194	09/26/2013	15:24	09/26/2013	15:35	1	11	11	Animal related	Recloser	Switch/Reset		III
132696354	P47169	09/26/2013	15:28	09/26/2013	17:20	1	112	112	Overhead equipment	Meter	Patrol/Test/Inspect		I
132696367	H01194	09/26/2013	15:32	09/26/2013	15:35	1	3	3	Animal related	Recloser	Switch/Reset		III
132696454	M45211	09/26/2013	15:50	09/26/2013	20:30	1	280	280	Overhead equipment	Overhead Transformer		Replace - Same Size	IV
132696565	Y84526	09/26/2013	16:18	09/26/2013	18:03	5	525	105	Animal related	Transformer Fuse	Replace - Same Size		IV
132696705	B93002	09/26/2013	17:08	09/26/2013	18:25	1	77	77	Unknown	Fuse	Replace - Same Size		I
132696707	J46184	09/26/2013	17:09	09/26/2013	17:45	1	36	36	Unknown				III
132696911	B84006	09/26/2013	17:17	09/26/2013	20:37	568	113600	200	Animal related	Substation Breaker	Switch/Reset		I
132696786	M21134	09/26/2013	17:29	09/26/2013	18:26	16	912	57	Animal related	Fuse	Replace - Same Size	No Work Required	VI
132696773	U28510	09/26/2013	17:31	09/27/2013	7:00	1	809	809	Underground equipment	Underground Primary	Repair	Repair	II
132697716	M18131	09/26/2013	17:32	09/26/2013	18:12	5	200	40	Underground equipment	Underground Primary	Switch/Reset		III
132696782	M18131	09/26/2013	17:32	09/26/2013	19:30	18	2124	118	Underground equipment	Underground Primary		Repair	III
132696923	U97528	09/26/2013	18:15	09/27/2013	4:15	4	2400	600	Underground equipment	Underground Primary	Repair	Repair	II
132697713	A49001	09/26/2013	18:33	09/26/2013	21:25	8	1376	172	Overhead equipment	Jumper	Repair		I
132697747	D28124	09/26/2013	19:34	09/26/2013	22:44	1	190	190	Animal related	Transformer Fuse	Replace - Same Size		I
132697799	G50002	09/26/2013	20:46	09/26/2013	22:42	3	348	116	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
132698111	J88164	09/26/2013	23:10	09/27/2013	0:32	1	82	82	Animal related	Transformer Fuse	Replace - Same Size		VI
132698114	M54316	09/26/2013	23:10	09/27/2013	5:24	18	6732	374	Overhead equipment				V
132698116	J87111	09/26/2013	23:51	09/27/2013	0:53	3	186	62	Animal related	Transformer Fuse	Replace - Same Size		VI
132700130	B76001	09/27/2013	0:30	09/27/2013	6:06	1	336	336	Underground equipment	Underground Primary		Repair	I
132700151	A73002	09/27/2013	0:54	09/27/2013	3:06	133	17556	132	Overhead equipment	Recloser			I
132700154	U95001	09/27/2013	1:01	09/27/2013	5:31	7	1890	270	Overhead equipment	Transformer Fuse	Repair		II
132700185	L35139	09/27/2013	2:23	09/27/2013	3:26	1	63	63	Public	Overhead Transformer		Replace - Same Size	III
132704010	J89126	09/27/2013	3:36	09/27/2013	5:10	1	94	94	Tree related-tree contact	Transformer Fuse			VI
132704032	J67134	09/27/2013	5:46	09/27/2013	7:39	1	113	113	Underground equipment	Underground Transformer	Repair	Repair	III
132704123	N70330	09/27/2013	7:10	09/27/2013	8:03	1	53	53	Overhead equipment	Transformer Fuse	Replace - Same Size		I
132704186	L17102	09/27/2013	7:34	09/27/2013	9:20	25	2650	106	Overhead equipment	Disconnect Switch	Replace - Same Size		III

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
132704202		09/27/2013	7:47	09/27/2013	9:53	1	126	126	Underground equipment	Underground Transformer	Replace - Same Size		I
132704211	D88002	09/27/2013	7:49	09/27/2013	9:11	25	2050	82	Animal related	Fuse	Replace - Same Size	No Work Required	I
132704320	K08909	09/27/2013	8:23	09/27/2013	10:08	1	105	105	Overhead equipment	Overhead Secondary	Repair	No Work Required	VI
132704363	K43385	09/27/2013	8:34	09/27/2013	8:58	1	24	24	Animal related	Fuse	Replace - Same Size		V
132704366	X60597	09/27/2013	8:35	09/27/2013	8:54	1	19	19	Animal related	Fuse	Replace - Same Size		IV
132704493		09/27/2013	9:03	09/27/2013	10:07	1	64	64	Overhead equipment	Transformer Fuse	Replace - Same Size		II
132704532	H01190	09/27/2013	9:11	09/27/2013	12:40	1	209	209	Public	Underground Transformer	Repair	Replace - Same Size	III
132704552	P52305	09/27/2013	9:16	09/27/2013	10:32	1	76	76	Animal related	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	IV
132704561	K11376	09/27/2013	9:17	09/27/2013	16:41	4	1776	444	Underground equipment	Underground Primary	Switch/Reset	Repair	V
132704651	Q83171	09/27/2013	9:36	09/27/2013	10:35	17	1003	59	Public	Underground Primary	Repair		VI
132704835	B25001	09/27/2013	10:15	09/27/2013	11:18	1	63	63	Overhead equipment	Transformer Fuse	Replace - Same Size	No Work Required	I
132704952		09/27/2013	10:35	09/27/2013	13:23	1	168	168	Overhead equipment	Transformer Fuse	Replace - Same Size	Repair	V
132704969	R41131	09/27/2013	10:37	09/27/2013	11:47	1	70	70	Animal related	Fuse	Repair		VI
132705074	S22595	09/27/2013	11:00	09/27/2013	11:49	1	49	49	Overhead equipment	Fuse	Replace - Same Size		VI
132705186	M18131	09/27/2013	11:22	09/27/2013	12:20	1	58	58	Overhead equipment	Disconnect Switch	Replace - Same Size		III
132705264	V29001	09/27/2013	11:39	09/27/2013	12:30	1	51	51	Tree related-tree broken	Overhead Service	Repair		II
132705318	J99128	09/27/2013	11:53	09/27/2013	12:00	1	7	7	Overhead equipment	Meter	No Work Required		VI
132705384	D01002	09/27/2013	12:11	09/27/2013	13:10	1	59	59	Overhead equipment	Fuse	Replace - Same Size		I
132705447	K19115	09/27/2013	12:28	09/27/2013	12:59	6	186	31	Overhead equipment	Fuse	Repair	Repair	VI
132705598	R50910	09/27/2013	13:02	09/27/2013	14:41	40	3960	99	Animal related	Fuse	Replace - Same Size	No Work Required	I
132706111	M22812	09/27/2013	15:35	09/27/2013	17:52	1	137	137	Overhead equipment	Overhead Transformer	Trim		V
132706216	Z04520	09/27/2013	16:20	09/27/2013	23:05	1	405	405	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	IV
132706252	P57104	09/27/2013	16:45	09/27/2013	17:25	1	40	40	Overhead equipment	Transformer Fuse	Replace - Same Size		VI
132706302	A49003	09/27/2013	17:21	09/27/2013	20:38	28	5516	197	Underground equipment	Underground Primary	Replace - Same Size	Repair	I
132706322	U68581	09/27/2013	17:28	09/27/2013	18:05	3	111	37	Animal related	Transformer Fuse	Replace - Same Size		II
132706447	D90002	09/27/2013	18:03	09/27/2013	20:25	77	10934	142	Overhead equipment	Other	Patrol/Test/Inspect	Patrol/Test/Inspect	III
132706638	M05362	09/27/2013	18:22	09/27/2013	19:55	1	93	93	Animal related	Transformer Fuse	Replace - Same Size		V
132707275	K30205	09/27/2013	18:50	09/27/2013	21:15	1	145	145	Overhead equipment	Overhead Secondary			III
132707285	R33126	09/27/2013	19:02	09/27/2013	20:14	1	72	72	Overhead equipment	Fuse	Replace - Same Size	Patrol/Test/Inspect	I
132707344	J15303	09/27/2013	20:20	09/27/2013	21:01	1	41	41	Unknown	Transformer Fuse	Replace - Same Size		I
132707419	U93563	09/27/2013	22:03	09/27/2013	23:15	1	72	72	Animal related	Transformer Fuse	Repair		II
132710009	M26164	09/28/2013	0:08	09/28/2013	4:10	47	11374	242	Unknown	Fuse	Replace - Same Size		III
132710050	E10001	09/28/2013	3:59	09/28/2013	5:36	1	97	97	Other	Overhead Service	Repair		III
132710132	Q23255	09/28/2013	4:47	09/28/2013	11:15	3	1164	388	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	VI
132710056	Q23255	09/28/2013	4:47	09/28/2013	7:22	1	155	155	Underground equipment	Underground Primary	Cut in Clear	Repair	VI
132710123	S43512	09/28/2013	6:05	09/28/2013	12:38	4	1572	393	Underground equipment	Underground Primary	Repair	Replace - Same Size	VI
132710112	B38001	09/28/2013	6:40	09/28/2013	7:53	1	73	73	Unknown				I
132710140	J83138	09/28/2013	7:30	09/28/2013	8:23	22	1166	53	Animal related	Fuse	Replace - Same Size		VI
132710156	M37191	09/28/2013	7:36	09/28/2013	8:16	11	440	40	Animal related	Fuse	Replace - Same Size		I
132710147	B21002	09/28/2013	7:45	09/28/2013	8:36	13	663	51	Animal related	Fuse	Replace - Same Size		I
132710173	N67309	09/28/2013	8:16	09/28/2013	9:19	1	63	63	Other	Fuse	Replace - Same Size		I
132710181	B58001	09/28/2013	8:28	09/28/2013	9:13	1	45	45	Animal related	Transformer Fuse	Replace - Same Size	No Work Required	I
132710188	K27150	09/28/2013	8:42	09/28/2013	9:35	1	53	53	Animal related	Fuse	Repair	Repair	VI
132710200	A91004	09/28/2013	8:58	09/28/2013	10:39	82	8282	101	Tree related-tree broken	Fuse	Replace - Same Size		I
132710209	Y11555	09/28/2013	9:09	09/28/2013	10:12	1	63	63	Animal related	Transformer Fuse	Replace - Same Size	No Work Required	IV
132710215	P60161	09/28/2013	9:13	09/28/2013	10:39	10	860	86	Animal related	Fuse	Replace - Same Size		VI
132710270	P26283	09/28/2013	9:34	09/28/2013	13:24	368	84640	230	Public	Pole	Replace - Same Size		I
132710236	342004	09/28/2013	9:39	09/28/2013	10:10	1	31	31	Tree related-tree contact	Overhead Service	Repair		VI
132710320	X92508	09/28/2013	10:33	09/28/2013	11:55	1	82	82	Overhead equipment	Overhead Secondary	Raise		IV
132710322	V69546	09/28/2013	10:36	09/28/2013	12:12	1	96	96	Overhead equipment	Transformer Fuse	Replace - Same Size		II
132710384	K62102	09/28/2013	11:18	09/28/2013	13:11	2	226	113	Animal related	Animal Guard	Repair		II
132710402	M78323	09/28/2013	11:36	09/28/2013	16:17	1	281	281	Tree related-tree contact	Transformer Fuse	Replace - Same Size		V
132710409	F10003	09/28/2013	11:42	09/28/2013	12:45	4	252	63	Weather	Other	Patrol/Test/Inspect	Patrol/Test/Inspect	III
132710477	N78243	09/28/2013	12:24	09/28/2013	17:34	1	310	310	Tree related-tree contact	Overhead Service	Repair	No Work Required	I
132710478	329145	09/28/2013	12:26	09/28/2013	13:03	1	37	37	Jurisdictional	Overhead Service	Reconnect		V
132710494	B21002	09/28/2013	12:27	09/28/2013	13:40	163	11899	73	Tree related-tree broken	Fuse	Replace - Same Size		I

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
132710512	R50910	09/28/2013	12:32	09/28/2013	14:53	259	36519	141	Tree related-tree contact	Overhead Primary	Repair		I
132710519	D90004	09/28/2013	12:35	09/28/2013	13:51	59	4484	76	Tree related-tree contact	Other	Patrol/Test/Inspect	Patrol/Test/Inspect	III
132710525	B21002	09/28/2013	12:39	09/28/2013	13:42	1	63	63	Tree related-tree broken				I
132710559	R50910	09/28/2013	12:52	09/28/2013	15:42	1	170	170	Tree related-tree broken	Other	Patrol/Test/Inspect	No Work Required	I
132710580	S22594	09/28/2013	12:58	09/28/2013	14:00	1	62	62	Animal related	Transformer Fuse	Replace - Same Size	Replace - Same Size	VI
132710575	L14232	09/28/2013	13:00	09/28/2013	15:30	1	150	150	Tree related-tree broken	Overhead Service	Raise		III
132710624	P26280	09/28/2013	13:30	09/28/2013	14:24	1	54	54	Overhead equipment	Connector	Repair		I
132710627	N15849	09/28/2013	13:32	09/28/2013	14:19	1	47	47	Overhead equipment	Jumper	Repair	No Work Required	V
132710638	V49541	09/28/2013	13:33	09/28/2013	16:45	2	384	192	Underground equipment	Underground Primary	Repair	Repair	II
132710640	L46811	09/28/2013	13:43	09/28/2013	15:18	1	95	95	Tree related-tree broken	Overhead Secondary	Repair	No Work Required	V
132710643	Y28598	09/28/2013	13:46	09/28/2013	15:33	1	107	107	Unknown	Transformer Fuse	Replace - Same Size		IV
132710647	X92508	09/28/2013	13:50	09/28/2013	15:10	4	320	80	Animal related	Disconnect Switch	Repair	Replace - Same Size	IV
132710684	V18582	09/28/2013	14:12	09/28/2013	16:30	8	1104	138	Animal related	Overhead Primary	Replace - Same Size		II
132710668	J83137	09/28/2013	14:13	09/28/2013	18:15	64	15488	242	Tree related-tree broken	Overhead Primary		Repair	VI
132710683	D53002	09/28/2013	14:32	09/28/2013	15:54	5	410	82	Overhead equipment	Transformer Fuse	Replace - Same Size	No Work Required	I
132710688	N05170	09/28/2013	14:36	09/28/2013	19:11	1	275	275	Overhead equipment	Overhead Service	Repair	No Work Required	I
132710706	H11338	09/28/2013	14:51	09/28/2013	16:01	8	560	70	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	V
132710712	Z11506	09/28/2013	14:55	09/28/2013	16:24	5	445	89	Animal related	Transformer Fuse	Replace - Same Size	No Work Required	IV
132710748	D28123	09/28/2013	16:01	09/28/2013	17:00	1	59	59	Overhead equipment	Connector	Repair		I
132710768	N78243	09/28/2013	16:17	09/28/2013	18:00	1	103	103	Tree related-tree contact	Overhead Service	Repair	No Work Required	I
132710776	M41111	09/28/2013	16:26	09/28/2013	17:11	1	45	45	Animal related	Overhead Transformer	Repair		I
132710799	V49541	09/28/2013	16:51	09/28/2013	17:35	1	44	44	Overhead equipment	Transformer Fuse	Repair	Repair	II
132710806	M04364	09/28/2013	16:59	09/28/2013	18:23	5	420	84	Public	Overhead Transformer	Switch/Reset		V
132710810	S83533	09/28/2013	17:04	09/28/2013	18:22	1	78	78	Overhead equipment				VI
132710812	P49183	09/28/2013	17:06	09/28/2013	18:15	1	69	69	Animal related	Transformer Fuse	Replace - Same Size		I
132710827	R84148	09/28/2013	17:20	09/28/2013	19:40	1	140	140	Animal related	Fuse	Replace - Same Size		I
132710846	S20555	09/28/2013	17:57	09/28/2013	19:38	1	101	101	Animal related	Fuse	Replace - Same Size	Advise Customer	VI
132710847	S20555	09/28/2013	18:00	09/28/2013	19:39	1	99	99	Animal related	Other	Patrol/Test/Inspect		VI
132710862	V39002	09/28/2013	18:47	09/28/2013	20:00	1	73	73	Overhead equipment	Overhead Service	Repair	Trim	II
132710906	D36002	09/28/2013	21:03	09/28/2013	22:49	38	4028	106	Overhead equipment	Transformer Fuse	Replace - Same Size		I
132710934	A73002	09/28/2013	21:17	09/29/2013	2:47	6	1980	330	Overhead equipment	Disconnect Switch			I
132710921	B93002	09/28/2013	21:34	09/29/2013	7:30	46	27416	596	Tree related-tree broken	Overhead Primary	Patrol/Test/Inspect	Repair	I
132710933	D72003	09/28/2013	21:50	09/29/2013	2:03	1	253	253	Tree related-tree broken	Overhead Primary			I
132710938	B80003	09/28/2013	21:52	09/29/2013	1:56	17	4148	244	Overhead equipment	Lightning Arrestor	Replace - Same Size		I
132711026	Y63527	09/28/2013	22:11	09/29/2013	2:00	2	458	229	Tree related-tree broken	Overhead Primary	Repair		IV
132711004	Y63527	09/28/2013	22:11	09/28/2013	23:20	513	35397	69	Tree related-tree broken	Overhead Primary	Repair		IV
132720233	V92543	09/28/2013	22:28	09/29/2013	8:48	7	4340	620	Public	Pole	Replace - Same Size	Replace - Same Size	II
132711007	V92543	09/28/2013	22:28	09/29/2013	2:31	22	5346	243	Public	Pole	Replace - Same Size		II
132720133	B28006	09/28/2013	22:35	09/29/2013	4:35	8	2880	360	Underground equipment	Underground Primary	Replace - Same Size	Replace - Same Size	I
132711010	B28006	09/28/2013	22:35	09/29/2013	1:30	230	40250	175	Underground equipment	Underground Primary	Replace - Same Size		I
132711015	D16001	09/28/2013	23:07	09/29/2013	1:04	1	117	117	Overhead equipment	Crossarm	Repair		I
132711018	B62003	09/28/2013	23:10	09/29/2013	6:15	1	425	425	Overhead equipment	Fuse	Replace - Same Size		I
132711019	P83705	09/28/2013	23:12	09/29/2013	4:40	1	328	328	Overhead equipment	Overhead Transformer	Replace - Same Size	Replace - Same Size	I
132711037	A81001	09/28/2013	23:31	09/29/2013	7:45	31	15314	494	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
132720263	61078	09/28/2013	23:55	09/29/2013	2:58	2	366	183	Overhead equipment				VI
132720290	61078	09/28/2013	23:55	09/29/2013	6:16	1662	633222	381	Overhead equipment				VI
132720264	61078	09/28/2013	23:55	09/29/2013	4:17	1371	359202	262	Overhead equipment				VI
132720259	61078	09/28/2013	23:55	09/29/2013	2:58	848	155184	183	Overhead equipment				VI
132720124	Q21321	09/29/2013	0:12	09/29/2013	3:15	28	5124	183	Underground equipment	Underground Primary		Replace - Same Size	VI
132720106	Q04411	09/29/2013	0:16	09/29/2013	4:15	28	6692	239	Underground equipment	Underground Primary			III
132720125	J82117	09/29/2013	1:00	09/29/2013	6:27	1	327	327	Overhead equipment	Overhead Transformer	Disconnect	Replace - Same Size	VI
132720152	B57002	09/29/2013	2:18	09/29/2013	4:11	155	17515	113	Unknown	Fuse	Replace - Same Size		I
132720200	R53390	09/29/2013	2:50	09/29/2013	4:00	6	420	70	Tree related-tree broken	Transformer Fuse	Replace - Same Size		V
132720212	M19222	09/29/2013	2:55	09/29/2013	4:10	26	1950	75	Overhead equipment	Fuse	Replace - Same Size		VI
132720243	79073	09/29/2013	3:02	09/29/2013	9:18	450	169200	376	Unknown				V
132720251	B45005	09/29/2013	3:43	09/29/2013	6:01	1	138	138	Tree related-tree broken	Overhead Primary			I

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
132720258		09/29/2013	4:13	09/29/2013	6:50	1	157	157	Overhead equipment	Fuse	Replace - Same Size		VI
132720404	X85724	09/29/2013	4:30	09/29/2013	8:09	338	74022	219	Overhead equipment				IV
132720345	Y55716	09/29/2013	4:45	09/29/2013	7:15	469	70350	150	Animal related				IV
132720343	Y55716	09/29/2013	4:48	09/29/2013	7:15	489	71883	147	Animal related				IV
132720346	Y55716	09/29/2013	4:53	09/29/2013	6:55	304	37088	122	Animal related				IV
132720348	L14232	09/29/2013	5:29	09/29/2013	8:25	1	176	176	Tree related-tree contact	Overhead Service	Repair		III
132720358	C70004	09/29/2013	6:29	09/29/2013	7:27	4	232	58	Animal related	Fuse	Replace - Same Size		III
132720365	P77237	09/29/2013	7:02	09/29/2013	9:09	1	127	127	Tree related-tree contact	Tree	Remove		VI
132720436	S86582	09/29/2013	7:12	09/29/2013	16:57	15	8775	585	Underground equipment				VI
132720419	R10902	09/29/2013	7:40	09/29/2013	9:00	35	2800	80	Overhead equipment	Fuse	Replace - Same Size	Patrol/Test/Inspect	VI
132720427	B10001	09/29/2013	7:52	09/29/2013	9:15	30	2490	83	Animal related	Overhead Primary			I
132720430	P20930	09/29/2013	7:58	09/29/2013	13:18	1	320	320	Tree related-tree contact	Tree	Cut in Clear	Trim	VI
132720444	X02546	09/29/2013	8:15	09/29/2013	9:35	3	240	80	Animal related	Fuse	Replace - Same Size		IV
132720447	B00004	09/29/2013	8:17	09/29/2013	13:55	1	338	338	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
132720455	U62510	09/29/2013	8:27	09/29/2013	10:22	1	115	115	Overhead equipment	Disconnect Switch	Repair		II
132720499	341001	09/29/2013	8:27	09/29/2013	9:03	429	15444	36	Jurisdictional				VI
132720524	341002	09/29/2013	8:28	09/29/2013	9:04	366	13176	36	Jurisdictional				VI
132720528	341003	09/29/2013	8:30	09/29/2013	9:03	152	5016	33	Jurisdictional				VI
132720529	M19222	09/29/2013	8:43	09/29/2013	10:49	1	126	126	Overhead equipment	Lightning Arrestor	Patrol/Test/Inspect	Replace - Same Size	VI
132720542	A36001	09/29/2013	8:48	09/29/2013	9:50	226	14012	62	Animal related	Overhead Primary	Replace - Same Size		I
132720537	V22555	09/29/2013	8:54	09/29/2013	11:14	3	420	140	Animal related	Fuse	Replace - Same Size		II
132720550	Q34360	09/29/2013	8:56	09/29/2013	14:29	29	9657	333	Overhead equipment	Pole	Replace - Same Size	Replace - Same Size	I
132720546	X57545	09/29/2013	8:57	09/29/2013	10:05	1	68	68	Animal related	Transformer Fuse	Replace - Same Size		IV
132720596	J14140	09/29/2013	8:59	09/29/2013	10:06	2	134	67	Overhead equipment	Fuse	Replace - Same Size		VI
132720557	P19395	09/29/2013	9:01	09/29/2013	10:06	1	65	65	Animal related	Fuse	Replace - Same Size	Replace - Same Size	V
132720560	K89144	09/29/2013	9:02	09/29/2013	10:20	27	2106	78	Animal related	Fuse	Replace - Same Size		III
132720561	R10902	09/29/2013	9:03	09/29/2013	9:33	1	30	30	Overhead equipment	Fuse	Replace - Same Size	Patrol/Test/Inspect	VI
132720572	B62004	09/29/2013	9:15	09/29/2013	10:42	14	1218	87	Animal related	Animal Guard			I
132720592	M47802	09/29/2013	9:36	09/29/2013	10:20	1	44	44	Animal related	Fuse	Repair	Repair	V
132720605	S41562	09/29/2013	9:51	09/29/2013	17:56	1	485	485	Overhead equipment	Overhead Transformer	Repair	Replace - Same Size	VI
132720615	HB6251	09/29/2013	9:56	09/29/2013	11:24	9	792	88	Animal related	Fuse	Replace - Same Size		VI
132720647	X57566	09/29/2013	10:40	09/29/2013	15:29	1	289	289	Underground equipment	Underground Primary	Repair	Replace - Same Size	IV
132720663	M51275	09/29/2013	10:56	09/29/2013	14:32	12	2592	216	Overhead equipment	Overhead Transformer			III
132720705	N70330	09/29/2013	11:40	09/29/2013	13:38	1	118	118	Other	Other	No Work Required		I
132720868	Y92237	09/29/2013	12:05	09/29/2013	14:44	1	159	159	Overhead equipment	Other	Repair		IV
132720730	V34003	09/29/2013	12:13	09/29/2013	14:10	1	117	117	Overhead equipment	Overhead Service	Repair		II
132720731	U80564	09/29/2013	12:14	09/29/2013	13:27	1	73	73	Animal related	Transformer Fuse	Replace - Same Size		II
132720862	X69555	09/29/2013	12:15	09/29/2013	15:00	4	660	165	Overhead equipment				IV
132720746	B35002	09/29/2013	12:54	09/29/2013	14:20	49	4214	86	Overhead equipment	Disconnect Switch	Replace - Same Size		I
132720748	B81002	09/29/2013	12:59	09/29/2013	13:40	1	41	41	Animal related	Animal Guard			I
132720824	S28552	09/29/2013	13:20	09/29/2013	14:22	1	62	62	Animal related	Transformer Fuse	Replace - Same Size	Replace - Same Size	VI
132720831	J13108	09/29/2013	13:25	09/29/2013	14:28	1	63	63	Unknown	Transformer Fuse	Replace - Same Size		I
132720833	C36002	09/29/2013	13:29	09/29/2013	14:38	1	69	69	Animal related	Fuse	Replace - Same Size		III
132720837	X12526	09/29/2013	13:32	09/29/2013	16:48	1	196	196	Underground equipment	Underground Primary	Repair		IV
132720839	V74513	09/29/2013	13:38	09/29/2013	14:08	3	90	30	Animal related	Transformer Fuse	Replace - Same Size		II
132720847	K01238	09/29/2013	13:48	09/29/2013	15:13	1	85	85	Overhead equipment	Fuse	Replace - Same Size		VI
132720853	HD0574	09/29/2013	13:57	09/29/2013	15:02	1	65	65	Overhead equipment	Transformer Fuse	Replace - Same Size	Replace - Same Size	VI
132720865	S83533	09/29/2013	14:22	09/29/2013	16:01	1	99	99	Overhead equipment	Fuse	Repair	Replace - Same Size	VI
132720873	K28180	09/29/2013	14:29	09/29/2013	15:45	1	76	76	Unknown	Fuse	Replace - Same Size		III
132720892	Q74148	09/29/2013	15:18	09/29/2013	16:27	7	483	69	Animal related	Fuse	Replace - Same Size		IV
132720898	A85001	09/29/2013	15:19	09/29/2013	21:23	3	1092	364	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
132720902	G50002	09/29/2013	15:36	09/29/2013	17:18	1	102	102	Overhead equipment	Tree	Trim		IV
132720906	L50215	09/29/2013	15:52	09/29/2013	16:54	6	372	62	Animal related	Transformer Fuse	Replace - Same Size		VI
132720924		09/29/2013	16:46	09/29/2013	17:45	1	59	59	Overhead equipment				II
132720926	D39002	09/29/2013	16:51	09/29/2013	22:04	1	313	313	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Repair	I
132720929	B81003	09/29/2013	16:56	09/29/2013	17:50	1	54	54	Animal related	Disconnect Switch	Replace - Same Size		I

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
132720931	S60581	09/29/2013	16:57	09/29/2013	17:30	1	33	33	Animal related	Transformer Fuse	Replace - Same Size		VI
132720985	P25150	09/29/2013	17:30	09/29/2013	19:55	1	145	145	Animal related	Transformer Fuse	Replace - Same Size		III
132720995	P19395	09/29/2013	17:46	09/29/2013	19:24	5	490	98	Animal related	Disconnect Switch	Patrol/Test/Inspect	Repair	V
132721063	R20502	09/29/2013	18:03	09/29/2013	23:31	2	656	328	Public	Pole	Patrol/Test/Inspect	Replace - New Size	IV
132720998		09/29/2013	18:05	09/29/2013	21:42	1	217	217	Animal related	Overhead Primary	Patrol/Test/Inspect		III
132721094	U64518	09/29/2013	18:13	09/29/2013	21:00	1	167	167	Public	Tree	Cut in Clear		II
132721084	U64518	09/29/2013	18:13	09/29/2013	20:08	252	28980	115	Public	Substation Breaker	Switch/Reset		II
132721119	Y97513	09/29/2013	22:42	09/30/2013	5:51	3	1287	429	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	IV
132730081	D70006	09/30/2013	0:27	09/30/2013	3:03	71	11076	156	Underground equipment	Underground Primary		Repair	I
132733829	D70006	09/30/2013	3:15	09/30/2013	7:03	28	6384	228	Underground equipment	Underground Primary		Repair	I
132733835	P98191	09/30/2013	3:52	09/30/2013	7:11	34	6766	199	Underground equipment	Underground Primary	Repair	Repair	III
132733843	A91004	09/30/2013	3:55	09/30/2013	5:37	19	1938	102	Overhead equipment				I
132733836	J79304	09/30/2013	4:07	09/30/2013	5:38	1	91	91	Animal related	Fuse	Replace - Same Size		I
132733855	R04407	09/30/2013	5:47	09/30/2013	8:25	28	4424	158	Underground equipment	Underground Primary	Repair	Repair	V
132733999	N22295	09/30/2013	6:25	09/30/2013	7:49	13	1092	84	Unknown	Fuse			VI
132733911	K91117	09/30/2013	6:56	09/30/2013	7:26	1	30	30	Other	Other			III
132733917	V55524	09/30/2013	6:59	09/30/2013	8:00	1	61	61	Animal related	Transformer Fuse	Replace - Same Size		II
132734173	B58001	09/30/2013	8:20	09/30/2013	11:20	1	180	180	Public	Underground Primary	Repair	Repair	I
132734253	D66002	09/30/2013	8:37	09/30/2013	9:35	1	58	58	Weather	Transformer Fuse	Replace - Same Size		IV
132734430	R10925	09/30/2013	9:12	09/30/2013	11:14	1	122	122	Animal related	Fuse	Replace - Same Size		VI
132734533	L24124	09/30/2013	9:29	09/30/2013	14:13	1	284	284	Tree related-tree contact	Overhead Service	Repair		III
132734534	V61563	09/30/2013	9:30	09/30/2013	10:15	2	90	45	Unknown	Transformer Fuse	Replace - Same Size		II
132734630	L23146	09/30/2013	9:47	09/30/2013	10:05	1	18	18	Overhead equipment	Overhead Service	Repair		III
132734784	Q16867	09/30/2013	10:11	09/30/2013	11:10	3	177	59	Animal related	Transformer Fuse	Replace - Same Size		V
132734834	Q64919	09/30/2013	10:19	09/30/2013	11:20	1	61	61	Animal related	Fuse	Replace - Same Size		VI
132734889	M54315	09/30/2013	10:27	09/30/2013	11:50	1	83	83	Overhead equipment	Transformer Fuse	Replace - Same Size	Replace - Same Size	V
132735067	P17107	09/30/2013	10:37	09/30/2013	13:10	16	2448	153	Public	Underground Primary		Repair	IV
132735059	P17107	09/30/2013	10:51	09/30/2013	12:22	1	91	91	Public	Underground Primary	Switch/Reset		IV
132735209	B19002	09/30/2013	11:06	09/30/2013	12:50	56	5824	104	Animal related	Fuse	Replace - Same Size	No Work Required	I
132735207	M07235	09/30/2013	11:13	09/30/2013	11:45	1	32	32	Animal related	Fuse	Replace - Same Size	Replace - Same Size	III
132735287	K89142	09/30/2013	11:26	09/30/2013	12:00	94	3196	34	Animal related	Fuse	Repair		III
132735431	N18210	09/30/2013	12:00	09/30/2013	12:30	1	30	30	Unknown	Fuse	Replace - Same Size	Replace - Same Size	III
132735551	P26281	09/30/2013	12:30	09/30/2013	13:31	1	61	61	Animal related	Animal Guard			I
132735669	D36002	09/30/2013	12:58	09/30/2013	13:59	11	671	61	Overhead equipment	Fuse	Repair		I
132735691	J06168	09/30/2013	13:03	09/30/2013	13:56	1	53	53	Overhead equipment	Overhead Service	No Work Required		I
132735689	B81002	09/30/2013	13:03	09/30/2013	14:30	1	87	87	Animal related	Animal Guard			I
132735796	Y36559	09/30/2013	13:14	09/30/2013	14:10	43	2408	56	Underground equipment	Underground Primary		Repair	IV
132735867	F10001	09/30/2013	13:26	09/30/2013	16:45	1	199	199	Overhead equipment	Overhead Transformer			III
132735910	Y06544	09/30/2013	13:33	09/30/2013	16:21	1	168	168	Overhead equipment	Animal Guard	Replace - New Size		IV
132736012	L59933	09/30/2013	13:54	09/30/2013	17:06	1	192	192	Overhead equipment	Fuse	Replace - Same Size		VI
132736088	D70007	09/30/2013	14:06	09/30/2013	18:50	1	284	284	Public	Underground Primary	Patrol/Test/Inspect	Repair	I
132736120	P57108	09/30/2013	14:11	09/30/2013	14:35	1	24	24	Animal related	Transformer Fuse	Replace - Same Size		VI
132736269	X81555	09/30/2013	14:36	09/30/2013	15:05	1	29	29	Public	Underground Service	Patrol/Test/Inspect	Repair	IV
132736715		09/30/2013	16:18	09/30/2013	17:02	1	44	44	Weather	Transformer Fuse	Replace - Same Size	Patrol/Test/Inspect	I
132736949	R49261	09/30/2013	17:52	09/30/2013	19:00	1	68	68	Public				VI
132737009	R49261	09/30/2013	18:03	09/30/2013	19:10	45	3015	67	Public	Pole	Replace - Same Size		VI
132737179	D01002	09/30/2013	18:46	09/30/2013	21:45	1	179	179	Overhead equipment	Fuse	Replace - Same Size		I
132738036	R95520	09/30/2013	19:49	09/30/2013	21:05	1	76	76	Weather	Transformer Fuse	Replace - Same Size		I
132738126	C15002	09/30/2013	21:08	10/01/2013	3:30	1	382	382	Underground equipment	Underground Primary	Patrol/Test/Inspect		III
132738139	J34377	09/30/2013	21:57	09/30/2013	22:37	4	160	40	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - New Size	V
132740001	B81003	09/30/2013	23:50	10/01/2013	5:42	27	9504	352	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
132742122	B21004	10/01/2013	0:36	10/01/2013	4:15	66	14454	219	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
132744639	B19002	10/01/2013	3:27	10/01/2013	9:30	1	363	363	Underground equipment	Underground Primary		Repair	I
132744902	C70001	10/01/2013	5:18	10/01/2013	10:50	1	332	332	Underground equipment	Underground Primary		Repair	III
132744926	U11531	10/01/2013	6:24	10/01/2013	7:50	1	86	86	Overhead equipment	Overhead Service	Repair	Repair	II
132744947	J58380	10/01/2013	6:50	10/01/2013	8:28	25	2450	98	Underground equipment	Underground Primary	Repair	Repair	III

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
132745342	D36001	10/01/2013	7:10	10/01/2013	8:35	2	170	85	Unknown	Fuse	Repair		I
132745150	H06135	10/01/2013	7:58	10/01/2013	9:30	1	92	92	Unknown	Transformer Fuse	Replace - Same Size		IV
132745311		10/01/2013	8:19	10/01/2013	9:13	1	54	54	Overhead equipment	Transformer Fuse	Repair	Replace - Same Size	IV
132745315	R59415	10/01/2013	8:20	10/01/2013	8:47	1	27	27	Animal related	Transformer Fuse	Repair		IV
132745408	J80806	10/01/2013	8:36	10/01/2013	9:51	1	75	75	Overhead equipment				V
132745486	R61241	10/01/2013	8:36	10/01/2013	10:55	28	3892	139	Underground equipment	Underground Primary	Switch/Reset	Repair	IV
132745439	N44216	10/01/2013	8:44	10/01/2013	9:29	1	45	45	Other	Overhead Primary	Repair		III
132745582	L12125	10/01/2013	9:02	10/01/2013	10:20	19	1482	78	Unknown	Fuse	Replace - Same Size		III
132745642	K07322	10/01/2013	9:18	10/01/2013	10:13	1	55	55	Overhead equipment	Transformer Fuse	Replace - Same Size	Replace - Same Size	I
132745697	M42614	10/01/2013	9:27	10/01/2013	15:30	1	363	363	Overhead equipment	Overhead Transformer	Replace - Same Size	Replace - Same Size	I
132745705	H10843	10/01/2013	9:28	10/01/2013	13:48	1	260	260	Overhead equipment	Overhead Transformer			V
132745731	A45001	10/01/2013	9:30	10/01/2013	10:49	16	1264	79	Tree related-tree broken	Tree	No Work Required	No Work Required	I
132745732	D28124	10/01/2013	9:30	10/01/2013	11:50	11	1540	140	Public	Overhead Primary	Patrol/Test/Inspect	Repair	I
132745843	K71812	10/01/2013	9:48	10/01/2013	10:11	1	23	23	Animal related	Transformer Fuse	Replace - Same Size	No Work Required	IV
132746210	A17021	10/01/2013	10:45	10/01/2013	11:17	1	32	32	Overhead equipment				I
132746326	B00002	10/01/2013	10:51	10/01/2013	14:25	75	16050	214	Animal related	Fuse	Replace - Same Size		I
132746377	B93002	10/01/2013	11:03	10/01/2013	12:52	11	1199	109	Overhead equipment	Fuse	Replace - Same Size		I
132746402	B84002	10/01/2013	11:13	10/01/2013	12:24	145	10295	71	Overhead equipment	Fuse	Repair	Replace - Same Size	I
132746513	D53002	10/01/2013	11:35	10/01/2013	12:28	4	212	53	Unknown	Transformer Fuse	Replace - Same Size		I
132746992	Q54908	10/01/2013	12:18	10/01/2013	13:24	2	132	66	Overhead equipment	Fuse	Repair	No Work Required	VI
132746817	D28123	10/01/2013	12:30	10/01/2013	13:44	1	74	74	Unknown	Fuse	Replace - Same Size		I
132747019	M81405	10/01/2013	12:30	10/01/2013	13:28	53	3074	58	Overhead equipment				V
132746890	R01152	10/01/2013	12:44	10/01/2013	13:07	2	46	23	Animal related	Transformer Fuse	Repair	Repair	III
132746944	U64521	10/01/2013	12:52	10/01/2013	13:50	1	58	58	Animal related	Fuse	Replace - Same Size		II
132746980	U64521	10/01/2013	12:59	10/01/2013	13:50	1	51	51	Animal related	Transformer Fuse	Replace - Same Size		II
132746994	G10001	10/01/2013	13:02	10/01/2013	13:30	1	28	28	Unknown	Fuse	Replace - Same Size		I
132747057	Q15844	10/01/2013	13:13	10/01/2013	13:40	144	3888	27	Overhead equipment	Overhead Primary			V
132747062	R23334	10/01/2013	13:20	10/01/2013	13:41	1	21	21	Unknown				V
132747273	D31018	10/01/2013	13:57	10/01/2013	15:07	1	70	70	Public	Other	Patrol/Test/Inspect	Patrol/Test/Inspect	III
132747299	Q15844	10/01/2013	14:03	10/01/2013	14:10	1	7	7	Overhead equipment	Overhead Primary			V
132747476	L81141	10/01/2013	14:38	10/01/2013	15:09	1	31	31	Tree related-tree contact	Tree			IV
132747568	V03562	10/01/2013	14:57	10/01/2013	16:56	1	119	119	Animal related	Animal Guard	Replace - New Size		II
132747692	R84148	10/01/2013	15:20	10/01/2013	16:15	1	55	55	Unknown	Transformer Fuse	Replace - Same Size		I
132747766	J67132	10/01/2013	15:39	10/01/2013	15:50	1	11	11	Unknown	Other			III
132747772	L95209	10/01/2013	15:44	10/01/2013	16:13	1	29	29	Overhead equipment	Transformer Fuse	Replace - Same Size		III
132747944	T16526	10/01/2013	15:46	10/01/2013	16:30	26	1144	44	Overhead equipment	Jumper	Repair	Repair	VI
132747884	S47589	10/01/2013	16:15	10/01/2013	17:15	1	60	60	Overhead equipment	Meter			VI
132747923	K80386	10/01/2013	16:21	10/01/2013	17:33	48	3456	72	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	IV
132747932	C70004	10/01/2013	16:27	10/01/2013	21:25	1	298	298	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	III
132747941	B65003	10/01/2013	16:31	10/01/2013	18:43	1	132	132	Other	Overhead Service			I
132747951	B44001	10/01/2013	16:34	10/01/2013	18:37	1	123	123	Tree related-tree broken	Overhead Service			I
132747969	K28180	10/01/2013	16:41	10/01/2013	17:09	1	28	28	Animal related	Transformer Fuse	Replace - Same Size		III
132747987	J18268	10/01/2013	16:46	10/01/2013	23:37	1	411	411	Underground equipment	Underground Primary		Patrol/Test/Inspect	VI
132748010	L68114	10/01/2013	16:55	10/01/2013	17:25	1	30	30	Overhead equipment	Overhead Service			IV
132748070	H00162	10/01/2013	17:24	10/01/2013	18:02	1	38	38	Unknown	Other			III
132748924	D53002	10/01/2013	18:56	10/01/2013	21:14	12	1656	138	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
132749036	P52305	10/01/2013	19:47	10/01/2013	21:09	1	82	82	Animal related	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	IV
132749094	R68903	10/01/2013	21:12	10/01/2013	22:20	2	136	68	Animal related	Transformer Fuse	Replace - Same Size	Replace - Same Size	I
132750166	A56017	10/02/2013	1:53	10/02/2013	8:47	83	34362	414	Underground equipment	Underground Primary		Repair	I
132753799	Q11517	10/02/2013	5:19	10/02/2013	10:14	30	8850	295	Underground equipment	Underground Primary	Repair		I
132753841	Q11516	10/02/2013	6:59	10/02/2013	11:11	1	252	252	Underground equipment	Underground Primary	Repair	No Work Required	I
132753907		10/02/2013	7:23	10/02/2013	9:08	1	105	105	Animal related	Transformer Fuse	Replace - Same Size	No Work Required	VI
132753938	R93701	10/02/2013	7:28	10/02/2013	8:38	1	70	70	Animal related				V
132753922	X96543	10/02/2013	7:34	10/02/2013	8:46	1	72	72	Animal related	Transformer Fuse	Repair	Patrol/Test/Inspect	IV
132753921		10/02/2013	7:34	10/02/2013	9:55	1	141	141	Animal related	Underground Transformer	Patrol/Test/Inspect		V
132753972	Y98518	10/02/2013	7:51	10/02/2013	12:00	25	6225	249	Public	Underground Primary	Repair	Repair	IV

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
132753986	C70002	10/02/2013	8:00	10/02/2013	9:13	2	146	73	Overhead equipment	Fuse	Replace - Same Size		III
132753999	N90248	10/02/2013	8:04	10/02/2013	9:23	1	79	79	Other	Other			III
132754043	T04512	10/02/2013	8:23	10/02/2013	9:23	1	60	60	Animal related	Transformer Fuse	Replace - Same Size	No Work Required	VI
132754162	N70331	10/02/2013	9:03	10/02/2013	9:53	1	50	50	Other	Other	No Work Required	No Work Required	I
132754240	Y45001	10/02/2013	9:21	10/02/2013	10:16	1	55	55	Overhead equipment	Overhead Service	Repair	Replace - Same Size	IV
132754255	P60161	10/02/2013	9:23	10/02/2013	11:45	86	12212	142	Underground equipment	Underground Primary	Repair	Repair	VI
132754491	J50186	10/02/2013	10:00	10/02/2013	13:30	1	210	210	Underground equipment	Underground Service			III
132754572	A85001	10/02/2013	10:17	10/02/2013	12:40	1	143	143	Underground equipment	Underground Primary	Repair	Repair	I
132754617	D70004	10/02/2013	10:22	10/02/2013	11:52	1	90	90	Animal related	Fuse	Replace - Same Size		I
132754679	S04513	10/02/2013	10:34	10/02/2013	11:00	56	1456	26	Overhead equipment	Disconnect Switch	Replace - Same Size		VI
132754866	K65221	10/02/2013	11:13	10/02/2013	11:52	1	39	39	Animal related	Transformer Fuse			III
132755124	F10001	10/02/2013	11:18	10/02/2013	12:13	30	1650	55	Unknown	Other	No Work Required	No Work Required	III
132754940	X22001	10/02/2013	11:25	10/02/2013	14:00	4	620	155	Overhead equipment	Overhead Transformer	Replace - Same Size	Replace - Same Size	IV
132754994	T16527	10/02/2013	11:36	10/02/2013	19:00	2	888	444	Public	Underground Primary	Repair	Repair	VI
132755027	N18210	10/02/2013	11:42	10/02/2013	12:37	1	55	55	Other	Transformer Fuse			III
132755065	P60161	10/02/2013	11:49	10/02/2013	13:30	1	101	101	Underground equipment	Underground Primary	Repair	Repair	VI
132755080	S04513	10/02/2013	11:52	10/02/2013	14:00	1	128	128	Tree related-tree broken	Overhead Service	Repair		VI
132755337	S04513	10/02/2013	12:42	10/02/2013	14:12	56	5040	90	Tree related-tree broken	Overhead Primary	Repair		VI
132755441	R34921	10/02/2013	13:05	10/02/2013	13:48	1	43	43	Overhead equipment	Transformer Fuse	Replace - Same Size	No Work Required	VI
132755512	M49411	10/02/2013	13:20	10/02/2013	15:37	4	548	137	Public	Underground Secondary	Patrol/Test/Inspect	Repair	V
132755561	Y68582	10/02/2013	13:29	10/02/2013	17:09	1	220	220	Animal related	Disconnect Switch		Install	IV
132755800	Q69926	10/02/2013	14:12	10/02/2013	14:35	1	23	23	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	VI
132756308		10/02/2013	14:22	10/02/2013	15:24	29	1798	62	Substation equipment				IV
132756302		10/02/2013	14:22	10/02/2013	15:17	960	52800	55	Substation equipment				IV
132755954	Z17705	10/02/2013	14:22	10/02/2013	15:27	195	12675	65	Substation equipment				IV
132755892	S04513	10/02/2013	14:26	10/02/2013	14:50	1	24	24	Overhead equipment	Transformer Fuse	Replace - Same Size		VI
132756018	Z17714	10/02/2013	14:30	10/02/2013	14:32	3943	7886	2	Substation equipment				IV
132755645	Q69926	10/02/2013	15:02	10/02/2013	17:21	1	139	139	Tree related-tree contact	Overhead Primary	Patrol/Test/Inspect	Repair	VI
132756261	S27598	10/02/2013	15:20	10/02/2013	18:43	1	203	203	Overhead equipment	Overhead Primary	Repair	Replace - Same Size	VI
132756342	T02543	10/02/2013	15:32	10/02/2013	17:13	1	101	101	Tree related-tree broken	Tree	Remove	Tie/Tighten	VI
132756478	R68900	10/02/2013	15:58	10/02/2013	17:39	1	101	101	Other	Other	No Work Required		I
132756545	N95859	10/02/2013	16:17	10/02/2013	18:43	1	146	146	Overhead equipment	Meter	Reconnect		V
132756547	H01194	10/02/2013	16:18	10/02/2013	18:24	1	126	126	Overhead equipment	Connector	Replace - Same Size		III
132756579	M25143	10/02/2013	16:29	10/02/2013	21:14	1	285	285	Underground equipment	Underground Secondary		Repair	IV
132756606	R10903	10/02/2013	16:38	10/02/2013	17:42	1	64	64	Animal related	Fuse	Replace - Same Size	Patrol/Test/Inspect	VI
132756648	J83140	10/02/2013	16:51	10/02/2013	17:30	1	39	39	Animal related	Transformer Fuse	Replace - Same Size		VI
132756720	R42914	10/02/2013	17:16	10/02/2013	18:45	1	89	89	Overhead equipment	Transformer Fuse	Repair		VI
132756725	L35138	10/02/2013	17:18	10/02/2013	19:25	1	127	127	Tree related-tree contact	Tree	Trim		III
132756743	L35282	10/02/2013	17:24	10/02/2013	19:49	1	145	145	Overhead equipment	Overhead Service	Repair		III
132756760	L35138	10/02/2013	17:32	10/02/2013	19:38	1	126	126	Tree related-tree contact	Tree	Trim		III
132756777	P60161	10/02/2013	17:32	10/02/2013	18:00	84	2352	28	Underground equipment				VI
132756836	Q06131	10/02/2013	18:04	10/02/2013	19:50	17	1802	106	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	IV
132757642	L43153	10/02/2013	18:41	10/02/2013	23:22	7	1967	281	Public	Overhead Primary	Repair	Repair	I
132757037	K58210	10/02/2013	18:57	10/02/2013	20:45	1	108	108	Underground equipment	Underground Service	Patrol/Test/Inspect	Repair	VI
132757763	M37191	10/02/2013	19:42	10/02/2013	21:50	1	128	128	Underground equipment	Underground Primary	Repair		I
132757661	M37191	10/02/2013	19:42	10/02/2013	21:32	9	990	110	Underground equipment	Underground Primary	Switch/Reset		I
132757754	S61580	10/02/2013	21:29	10/02/2013	23:08	1	99	99	Overhead equipment	Overhead Service	Repair		VI
132757773	S86582	10/02/2013	22:14	10/03/2013	1:03	1	169	169	Tree related-tree contact	Overhead Secondary	Repair		VI
132757790	U09557	10/02/2013	23:15	10/03/2013	0:51	51	4896	96	Underground equipment	Fuse	Replace - Same Size		II
132761493	U09557	10/03/2013	1:17	10/03/2013	6:43	11	3586	326	Underground equipment	Underground Primary	Replace - Same Size	Replace - Same Size	II
132761495	B84002	10/03/2013	1:56	10/03/2013	5:55	86	20554	239	Underground equipment	Underground Primary	Switch/Reset	Repair	I
132761534	R34920	10/03/2013	3:09	10/03/2013	4:36	1	87	87	Overhead equipment	Overhead Service	Replace - Same Size	No Work Required	VI
132763552	U33509	10/03/2013	4:31	10/03/2013	5:35	1	64	64	Weather	Fuse	Replace - Same Size		II
132763556	U33509	10/03/2013	4:47	10/03/2013	9:45	1	298	298	Weather	Pole	Repair	Repair	II
132763558	D72001	10/03/2013	5:01	10/03/2013	14:15	9	4986	554	Weather	Overhead Transformer	Patrol/Test/Inspect	Repair	I
132764071	D69006	10/03/2013	5:02	10/03/2013	11:19	2	754	377	Underground equipment	Underground Primary	Repair	Repair	I

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
132763565	D69006	10/03/2013	5:02	10/03/2013	8:15	9	1737	193	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
132763561	B00003	10/03/2013	5:05	10/03/2013	6:48	10	1030	103	Weather	Transformer Fuse	Replace - Same Size		I
132763577	J80807	10/03/2013	5:15	10/03/2013	6:40	82	6970	85	Animal related	Overhead Primary	Repair	Repair	V
132763568	A17025	10/03/2013	5:23	10/03/2013	8:00	8	1256	157	Weather	Overhead Transformer	Patrol/Test/Inspect		I
132763570	A26006	10/03/2013	5:25	10/03/2013	6:20	1	55	55	Weather	Fuse			I
132763583	D87001	10/03/2013	5:38	10/03/2013	9:26	9	2052	228	Weather	Fuse	Replace - Same Size		I
132763581	B71001	10/03/2013	5:38	10/03/2013	9:43	8	1960	245	Overhead equipment	Transformer Fuse	Replace - Same Size	Repair	I
132763584	D36002	10/03/2013	5:39	10/03/2013	8:44	1	185	185	Tree related-tree contact	Overhead Service	Replace - New Size		I
132763585	U54503	10/03/2013	5:43	10/03/2013	8:00	2	274	137	Overhead equipment	Disconnect Switch			II
132763599	N95823	10/03/2013	5:47	10/03/2013	7:00	1	73	73	Overhead equipment	Connector	Tie/Tighten		V
132763779	B21004	10/03/2013	5:49	10/03/2013	7:41	5	560	112	Overhead equipment	Overhead Secondary	Repair		I
132763624	B21004	10/03/2013	5:52	10/03/2013	7:30	46	4508	98	Overhead equipment	Fuse	Repair	Replace - Same Size	I
132763777	D35002	10/03/2013	5:56	10/03/2013	8:37	63	10143	161	Weather	Fuse			I
132763646	D35001	10/03/2013	6:09	10/03/2013	9:44	1	215	215	Weather	Fuse			I
132763647		10/03/2013	6:11	10/03/2013	9:46	1	215	215	Weather	Fuse			I
132763653	D35002	10/03/2013	6:12	10/03/2013	8:39	18	2646	147	Weather	Fuse			I
132763656		10/03/2013	6:19	10/03/2013	8:20	1	121	121	Weather	Fuse	Replace - Same Size		I
132763673	V10533	10/03/2013	6:19	10/03/2013	9:16	19	3363	177	Weather	Disconnect Switch	Patrol/Test/Inspect	Repair	II
132763666	D35002	10/03/2013	6:20	10/03/2013	8:15	23	2645	115	Weather	Fuse	Replace - Same Size		I
132763664	J01119	10/03/2013	6:23	10/03/2013	7:29	29	1914	66	Overhead equipment	Fuse	Replace - Same Size		I
132763690	J01118	10/03/2013	6:41	10/03/2013	8:20	67	6633	99	Overhead equipment	Pole		Repair	I
132763700	K30204	10/03/2013	6:45	10/03/2013	8:30	17	1785	105	Weather	Fuse	Replace - Same Size		III
132763694	B00004	10/03/2013	6:49	10/03/2013	8:40	1	111	111	Weather	Underground Service	Advise Customer		I
132763689	J01118	10/03/2013	6:49	10/03/2013	9:04	1	135	135	Overhead equipment				I
132763860	D32211	10/03/2013	6:54	10/03/2013	8:55	5	605	121	Weather	Fuse	Replace - Same Size		I
132763768	B25002	10/03/2013	6:54	10/03/2013	8:33	67	6633	99	Tree related-tree broken	Tree	Remove		I
132763723	N60181	10/03/2013	7:04	10/03/2013	9:40	2	312	156	Overhead equipment	Transformer Fuse	Replace - Same Size		I
132763803	V69558	10/03/2013	7:34	10/03/2013	9:55	1	141	141	Overhead equipment	Overhead Service	Repair		II
132763825	M31203	10/03/2013	7:42	10/03/2013	8:56	1	74	74	Weather	Transformer Fuse	Replace - Same Size		I
132763827	U54503	10/03/2013	7:44	10/03/2013	8:05	1	21	21	Overhead equipment	Disconnect Switch			II
132763857	B57002	10/03/2013	7:45	10/03/2013	9:09	278	23352	84	Overhead equipment	Insulator	Switch/Reset		I
132764314	B57002	10/03/2013	7:47	10/03/2013	10:54	890	166430	187	Overhead equipment	Insulator	Replace - Same Size		I
132763881	J01119	10/03/2013	7:54	10/03/2013	9:06	1	72	72	Overhead equipment				I
132764069	P45383	10/03/2013	7:58	10/03/2013	13:44	1445	499970	346	Weather				I
132763922	J74125	10/03/2013	8:04	10/03/2013	8:57	1	53	53	Animal related	Transformer Fuse	Replace - Same Size		VI
132764419	D01001	10/03/2013	8:10	10/03/2013	10:10	24	2880	120	Overhead equipment	Fuse	Replace - Same Size	Patrol/Test/Inspect	I
132765158	N67309	10/03/2013	8:19	10/03/2013	11:59	8	1760	220	Overhead equipment	Connector	Replace - New Size		I
132764098	N05172	10/03/2013	8:29	10/03/2013	10:35	2	252	126	Weather	Fuse	Replace - Same Size	No Work Required	I
132764214	J63172	10/03/2013	8:47	10/03/2013	9:21	1	34	34	Overhead equipment	Jumper	Repair	Repair	III
132764236	G50001	10/03/2013	8:47	10/03/2013	10:35	24	2592	108	Unknown	Fuse	Replace - Same Size		IV
132764243	B19002	10/03/2013	8:50	10/03/2013	12:10	1	200	200	Weather	Overhead Transformer		Repair	I
132764252	C10001	10/03/2013	8:51	10/03/2013	9:35	8	352	44	Overhead equipment	Transformer Fuse	Replace - Same Size		III
132764289	D35002	10/03/2013	8:55	10/03/2013	13:15	1	260	260	Weather	Underground Transformer		Repair	I
132764347	R07382	10/03/2013	9:10	10/03/2013	10:07	1	57	57	Weather	Transformer Fuse	Replace - Same Size	Repair	I
132764381	B76003	10/03/2013	9:14	10/03/2013	12:30	67	13132	196	Public	Underground Transformer	Patrol/Test/Inspect	Replace - Same Size	I
132764405	B84005	10/03/2013	9:22	10/03/2013	17:33	1	491	491	Underground equipment	Underground Primary	Patrol/Test/Inspect	Reconnect	I
132764519	V61563	10/03/2013	9:42	10/03/2013	9:45	1	3	3	Public	Underground Secondary	Repair	Repair	II
132764631	D88001	10/03/2013	10:03	10/03/2013	11:05	1	62	62	Overhead equipment	Fuse	Replace - Same Size		I
132764646	B19002	10/03/2013	10:05	10/03/2013	10:45	1	40	40	Weather	Fuse	Replace - Same Size		I
132765255	F22001	10/03/2013	10:12	10/03/2013	14:13	2	482	241	Underground equipment	Underground Primary	Switch/Reset		IV
132765602	F22001	10/03/2013	10:12	10/03/2013	12:41	30	4470	149	Underground equipment	Underground Primary	Switch/Reset		IV
132765256	F22001	10/03/2013	10:12	10/03/2013	11:40	19	1672	88	Underground equipment	Underground Primary	Switch/Reset		IV
132764737	K01239	10/03/2013	10:19	10/03/2013	10:48	2	58	29	Other	Transformer Fuse	Replace - Same Size		VI
132765030	X02547	10/03/2013	10:33	10/03/2013	12:48	66	8910	135	Overhead equipment	Fuse	Repair		IV
132764867	R58961	10/03/2013	10:35	10/03/2013	13:01	1	146	146	Overhead equipment				IV
132764930	G50001	10/03/2013	10:46	10/03/2013	14:20	9	1926	214	Underground equipment	Underground Primary			IV

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
132765116	V82551	10/03/2013	11:15	10/03/2013	13:39	1	144	144	Weather	Transformer Fuse	Replace - Same Size		II
132765124	D01001	10/03/2013	11:17	10/03/2013	13:35	1	138	138	Weather	Fuse	Replace - Same Size		I
132765125	K08909	10/03/2013	11:17	10/03/2013	14:35	1	198	198	Overhead equipment	Overhead Transformer		Replace - Same Size	VI
132765246	E10001	10/03/2013	11:37	10/03/2013	14:45	1	188	188	Overhead equipment	Overhead Transformer			III
132765250		10/03/2013	11:38	10/03/2013	12:45	1	67	67	Animal related	Overhead Primary	Repair		III
132765406	303007	10/03/2013	12:06	10/03/2013	13:55	26	2834	109	Public	Pole	Cut in Clear	Replace - New Size	VI
132765390	B19002	10/03/2013	12:07	10/03/2013	13:46	1	99	99	Weather	Lightning Arrestor	Replace - Same Size		I
132765478	B73001	10/03/2013	12:24	10/03/2013	13:00	1	36	36	Weather	Fuse	Replace - Same Size		I
132765510	K89141	10/03/2013	12:31	10/03/2013	13:14	5	215	43	Animal related	Fuse	Replace - Same Size	Repair	III
132765850	J05138	10/03/2013	12:40	10/03/2013	13:40	7	420	60	Overhead equipment	Fuse	Patrol/Test/Inspect	Replace - Same Size	I
132765576	J20931	10/03/2013	12:42	10/03/2013	13:22	1	40	40	Unknown	Fuse	Replace - Same Size	Replace - Same Size	VI
132765794	329147	10/03/2013	12:42	10/03/2013	13:50	28	1904	68	Overhead equipment	Fuse	Replace - Same Size		V
132766246	M22812	10/03/2013	12:49	10/03/2013	15:00	79	10349	131	Overhead equipment	Overhead Primary	Repair		V
132765989	B25002	10/03/2013	12:50	10/03/2013	16:00	14	2660	190	Tree related-tree broken	Overhead Primary	Remove		I
132765706	K82202	10/03/2013	13:05	10/03/2013	13:45	1	40	40	Other	Transformer Fuse			III
132765817	J15303	10/03/2013	13:24	10/03/2013	13:32	1	8	8	Weather				I
132765880	Q21292	10/03/2013	13:35	10/03/2013	14:42	1	67	67	Animal related	Transformer Fuse			VI
132765906	A56013	10/03/2013	13:39	10/03/2013	14:47	1	68	68	Overhead equipment	Connector	Replace - New Size		I
132766050	U99515	10/03/2013	13:43	10/03/2013	15:00	27	2079	77	Tree related-tree broken	Overhead Primary	Repair		II
132766092	A45003	10/03/2013	13:49	10/03/2013	15:03	19	1406	74	Underground equipment	Underground Transformer	Replace - Same Size		I
132766550	D53001	10/03/2013	14:20	10/03/2013	15:15	23	1265	55	Unknown	Recloser	Switch/Reset		I
132766236	N86228	10/03/2013	14:38	10/03/2013	16:07	1	89	89	Tree related-tree broken	Overhead Service			VI
132766646	J61393	10/03/2013	14:41	10/03/2013	15:15	1775	60350	34	Substation equipment				III
132766643	J61393	10/03/2013	14:41	10/03/2013	15:15	635	21590	34	Substation equipment				III
132766386	J61112	10/03/2013	14:55	10/03/2013	15:43	1	48	48	Weather	Other			III
132766414	L35283	10/03/2013	14:59	10/03/2013	15:50	1	51	51	Overhead equipment	Overhead Service	Disconnect	Repair	III
132766431	J46184	10/03/2013	15:01	10/03/2013	15:18	1	17	17	Weather	Other			III
132766445	P26283	10/03/2013	15:04	10/03/2013	17:10	1	126	126	Unknown	Fuse	Patrol/Test/Inspect	Repair	I
132766690	J06168	10/03/2013	15:04	10/03/2013	17:05	34	4114	121	Public	Overhead Primary	Repair		I
132766495	D36002	10/03/2013	15:09	10/03/2013	15:45	1	36	36	Weather	Fuse	Replace - Same Size		I
132766613	B21002	10/03/2013	15:20	10/03/2013	18:16	2	352	176	Overhead equipment	Fuse	Replace - Same Size		I
132766662	K65221	10/03/2013	15:41	10/03/2013	18:55	1	194	194	Tree related-tree broken				III
132766659	X78536	10/03/2013	15:41	10/03/2013	15:55	1	14	14	Tree related-tree broken	Fuse	Repair		IV
132766678	K82202	10/03/2013	15:44	10/03/2013	16:35	1	51	51	Weather	Fuse			III
132766756	V40549	10/03/2013	15:49	10/03/2013	17:50	20	2420	121	Overhead equipment				II
132766731	U97001	10/03/2013	15:55	10/03/2013	18:29	11	1694	154	Tree related-tree broken	Customer Equipment	Switch/Reset		II
132766761	D35003	10/03/2013	16:01	10/03/2013	17:17	1	76	76	Weather	Fuse	Replace - Same Size		I
132766770	X73003	10/03/2013	16:04	10/03/2013	18:03	1	119	119	Weather	Disconnect Switch	Replace - Same Size		IV
132767034	U12540	10/03/2013	16:06	10/03/2013	17:58	185	20720	112	Tree related-tree broken	Overhead Primary	Repair		II
132766801	K73366	10/03/2013	16:12	10/03/2013	20:45	7	1911	273	Public	Overhead Service	Repair		IV
132766847	D88002	10/03/2013	16:14	10/03/2013	17:00	40	1840	46	Overhead equipment	Fuse	Patrol/Test/Inspect	Reconnect	I
132766931	M04364	10/03/2013	16:32	10/03/2013	17:46	552	40848	74	Tree related-tree contact				V
132766951	M05362	10/03/2013	16:32	10/03/2013	17:46	523	38702	74	Jurisdictional				V
132766989	M04364	10/03/2013	16:33	10/03/2013	17:46	217	15841	73	Tree related-tree contact				V
132766897	R60552	10/03/2013	16:34	10/03/2013	18:18	1	104	104	Overhead equipment	Transformer Fuse	Replace - Same Size	No Work Required	IV
132766959		10/03/2013	16:39	10/03/2013	17:48	1	69	69	Unknown				V
132766977	M04364	10/03/2013	16:47	10/03/2013	16:57	1	10	10	Tree related-tree contact				V
132767007	A68001	10/03/2013	16:55	10/03/2013	21:14	1	259	259	Overhead equipment	Overhead Transformer	Repair		I
132767011	Q04411	10/03/2013	16:57	10/03/2013	17:35	1	38	38	Tree related-tree contact	Overhead Service			III
132767010	M04365	10/03/2013	16:57	10/03/2013	17:48	1	51	51	Tree related-tree contact				V
132767031	U68581	10/03/2013	16:59	10/03/2013	19:19	30	4200	140	Tree related-tree broken	Overhead Primary	Raise		II
132767053	U64518	10/03/2013	17:11	10/03/2013	19:18	1	127	127	Tree related-tree broken	Overhead Service	Repair		II
132767190	M04364	10/03/2013	17:14	10/04/2013	0:28	13	5642	434	Tree related-tree broken	Tree	Patrol/Test/Inspect	Cut in Clear	V
132767133	R60554	10/03/2013	17:29	10/03/2013	20:35	4	744	186	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	IV
132767115	R84148	10/03/2013	17:32	10/03/2013	19:22	1	110	110	Animal related	Transformer Fuse	Replace - Same Size		I
132767136	K76542	10/03/2013	17:40	10/03/2013	20:00	1	140	140	Tree related-tree contact	Overhead Service	Repair	No Work Required	IV

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
132767157	H00163	10/03/2013	17:45	10/03/2013	18:17	9	288	32	Animal related	Other			III
132767161	K76542	10/03/2013	17:46	10/03/2013	18:56	8	560	70	Animal related	Transformer Fuse	Replace - Same Size	No Work Required	IV
132767168	A85001	10/03/2013	17:47	10/03/2013	18:59	1	72	72	Overhead equipment	Fuse	Replace - Same Size		I
132767169	L23145	10/03/2013	17:49	10/03/2013	19:00	1	71	71	Tree related-tree contact	Overhead Service	Repair		III
132767210	B93002	10/03/2013	17:56	10/03/2013	20:23	4	588	147	Overhead equipment	Fuse	Replace - Same Size		I
132767191	B21002	10/03/2013	17:57	10/03/2013	20:03	5	630	126	Weather	Transformer Fuse	Replace - Same Size		I
132768228	D48001	10/03/2013	18:03	10/03/2013	19:07	20	1280	64	Weather	Fuse	Replace - Same Size		I
132767215	K76542	10/03/2013	18:06	10/03/2013	18:57	1	51	51	Animal related	Transformer Fuse	Replace - Same Size	No Work Required	IV
132767474	A36002	10/03/2013	18:10	10/03/2013	19:27	56	4312	77	Weather	Fuse	Replace - Same Size		I
132767249	A36001	10/03/2013	18:11	10/03/2013	21:10	13	2327	179	Weather	Overhead Primary	Raise	Raise	I
132767257	D48001	10/03/2013	18:17	10/03/2013	19:09	1	52	52	Weather	Fuse	Replace - Same Size		I
132767525	D32211	10/03/2013	18:19	10/03/2013	21:41	32	6464	202	Tree related-tree broken	Overhead Primary	Repair	Repair	I
132767284	U64521	10/03/2013	18:23	10/03/2013	19:51	3	264	88	Weather	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	II
132767534	U35554	10/03/2013	18:24	10/03/2013	20:03	9	891	99	Weather	Fuse	Replace - Same Size		II
132767540	A56014	10/03/2013	18:44	10/04/2013	7:39	1	775	775	Weather	Overhead Transformer	Replace - Same Size		I
132767544	N44217	10/03/2013	18:46	10/03/2013	20:50	6	744	124	Weather	Overhead Primary			III
132767595	B68002	10/03/2013	18:50	10/03/2013	19:12	1	22	22	Other	Other			III
132768075	K22173	10/03/2013	18:53	10/03/2013	19:50	1	57	57	Overhead equipment	Overhead Secondary	Repair		VI
132768206	D96001	10/03/2013	18:55	10/04/2013	1:43	1	408	408	Overhead equipment	Overhead Transformer	Replace - Same Size	Repair	I
132768221	A68001	10/03/2013	18:58	10/03/2013	21:45	1	167	167	Weather	Pole	Patrol/Test/Inspect	Replace - Same Size	I
132768229	H01194	10/03/2013	19:05	10/03/2013	22:50	1	225	225	Overhead equipment	Overhead Transformer		Replace - Same Size	III
132768260	V21500	10/03/2013	19:31	10/03/2013	20:45	3	222	74	Animal related	Transformer Fuse	Replace - Same Size		II
132768603	L17104	10/03/2013	19:33	10/03/2013	20:49	3	228	76	Weather	Recloser	Switch/Reset		III
132768271	B38001	10/03/2013	19:40	10/03/2013	22:47	1	187	187	Tree related-tree broken	Overhead Service			I
132768287	U03001	10/03/2013	19:51	10/03/2013	21:17	1	86	86	Weather	Transformer Fuse	Replace - Same Size		II
132768840	Q82907	10/03/2013	19:58	10/03/2013	23:55	76	18012	237	Overhead equipment	Overhead Primary	Replace - Same Size	Repair	VI
132768675	R10332	10/03/2013	19:58	10/03/2013	21:28	2259	203310	90	Overhead equipment				VI
132768673	R10460	10/03/2013	19:58	10/03/2013	21:26	549	48312	88	Overhead equipment				VI
132768676	R10467	10/03/2013	19:58	10/03/2013	20:12	1466	20524	14	Overhead equipment				VI
132768310	K67912	10/03/2013	20:00	10/03/2013	20:10	2	20	10	Overhead equipment	Substation Transformer	Switch/Reset		VI
132768652	D35003	10/03/2013	20:02	10/03/2013	22:20	2	276	138	Overhead equipment	Fuse	Replace - Same Size		I
132768674	J68402	10/03/2013	20:06	10/03/2013	23:15	5	945	189	Overhead equipment	Jumper	Replace - Same Size		III
132768630	K67911	10/03/2013	20:10	10/03/2013	20:15	3	15	5	Overhead equipment	Substation Transformer	Switch/Reset		VI
132768656	Q93522	10/03/2013	20:17	10/03/2013	22:15	3	354	118	Weather	Transformer Fuse	Patrol/Test/Inspect	Repair	I
132770151	U35511	10/03/2013	20:24	10/04/2013	2:50	11	4246	386	Underground equipment	Underground Primary	Repair		II
132768659	U35511	10/03/2013	20:24	10/04/2013	1:35	13	4043	311	Underground equipment	Underground Primary			II
132768671	C10002	10/03/2013	20:29	10/03/2013	20:36	15	105	7	Overhead equipment	Other			III
132768666	U01514	10/03/2013	20:33	10/03/2013	22:56	1	143	143	Overhead equipment	Overhead Transformer	Replace - Same Size	Replace - Same Size	II
132768672		10/03/2013	20:37	10/03/2013	22:23	1	106	106	Overhead equipment	Fuse	Replace - Same Size		III
132768892	H07106	10/03/2013	20:56	10/03/2013	23:15	764	106196	139	Overhead equipment	Overhead Primary	Tie/Tighten		IV
132768687	D66002	10/03/2013	20:58	10/03/2013	23:28	1	150	150	Tree related-tree broken	Fuse	Replace - Same Size		IV
132768850	C10001	10/03/2013	21:59	10/03/2013	22:41	1	42	42	Overhead equipment	Connector	Replace - Same Size		III
132768853	Q74149	10/03/2013	22:05	10/03/2013	23:54	1	109	109	Tree related-tree contact	Overhead Secondary	Repair		IV
132768899	N54108	10/03/2013	23:20	10/04/2013	0:11	1	51	51	Animal related	Fuse	Replace - Same Size		II
132768909	308003	10/03/2013	23:38	10/04/2013	0:28	1	50	50	Overhead equipment	Fuse	Replace - Same Size	Repair	VI
132770121	J80807	10/04/2013	0:21	10/04/2013	2:51	71	10650	150	Overhead equipment				V
132770117	K30205	10/04/2013	0:24	10/04/2013	1:19	1	55	55	Weather	Overhead Transformer			III
132770136	M04364	10/04/2013	1:18	10/04/2013	1:35	1	17	17	Tree related-tree contact				V
132773653	Y55002	10/04/2013	4:03	10/04/2013	5:42	1	99	99	Overhead equipment	Overhead Service	Repair		IV
132773654	U73599	10/04/2013	4:05	10/04/2013	10:02	1	357	357	Underground equipment	Overhead Primary		Repair	II
132773655	N15850	10/04/2013	4:20	10/04/2013	7:30	1	190	190	Overhead equipment	Overhead Transformer	Cut in Clear	Replace - Same Size	V
132773661	L68113	10/04/2013	4:37	10/04/2013	5:45	1	68	68	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
132773667	V59561	10/04/2013	4:40	10/04/2013	6:00	8	640	80	Overhead equipment	Pole	Switch/Reset		II
132773752	V59561	10/04/2013	5:26	10/04/2013	11:17	8	2808	351	Overhead equipment	Pole	Switch/Reset		II
132773745	U97002	10/04/2013	7:07	10/04/2013	9:15	1	128	128	Tree related-tree broken	Overhead Service	Repair		II
132773746	V20502	10/04/2013	7:08	10/04/2013	7:42	1	34	34	Weather				II

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
132774421	J68427	10/04/2013	7:13	10/04/2013	8:15	113	7006	62	Animal related				III
132773822	N67315	10/04/2013	7:35	10/04/2013	9:09	1	94	94	Tree related-tree contact	Overhead Service	Repair		I
132773831	J01119	10/04/2013	7:37	10/04/2013	8:59	1	82	82	Overhead equipment	Transformer Fuse	Replace - Same Size		I
132773863	P52305	10/04/2013	7:44	10/04/2013	9:29	1	105	105	Overhead equipment	Connector	Tie/Tighten		IV
132773947	B21004	10/04/2013	8:00	10/04/2013	11:11	136	25976	191	Unknown	Fuse	Patrol/Test/Inspect	Replace - Same Size	I
132773968	X69555	10/04/2013	8:06	10/04/2013	10:20	1	134	134	Overhead equipment	Fuse	Replace - Same Size		IV
132774092	A68001	10/04/2013	8:28	10/04/2013	9:50	1	82	82	Unknown	Fuse	Replace - Same Size		I
132774155	U15003	10/04/2013	8:40	10/04/2013	10:01	1	81	81	Overhead equipment	Jumper	Repair		II
132774368	X42502	10/04/2013	9:22	10/04/2013	11:28	1	126	126	Overhead equipment	Overhead Service	Repair		IV
132774508	D88001	10/04/2013	9:46	10/04/2013	10:30	1	44	44	Overhead equipment	Disconnect Switch	Replace - Same Size		I
132774534	A56014	10/04/2013	9:51	10/05/2013	12:00	1	1569	1569	Overhead equipment	Overhead Transformer	Replace - New Size		I
132774574	M36189	10/04/2013	10:00	10/04/2013	13:59	1	239	239	Overhead equipment	Overhead Transformer	Replace - Same Size	Replace - Same Size	I
132774627	B21003	10/04/2013	10:09	10/04/2013	13:10	1	181	181	Weather	Disconnect Switch	Replace - Same Size	Repair	I
132774630	L24121	10/04/2013	10:10	10/04/2013	10:51	1	41	41	Overhead equipment	Transformer Fuse	Switch/Reset		III
132774880	D01002	10/04/2013	11:09	10/04/2013	13:56	1	167	167	Overhead equipment	Overhead Transformer		Repair	I
132775107	L11242	10/04/2013	12:02	10/04/2013	12:52	1	50	50	Tree related-tree contact	Overhead Service	Repair		III
132775116	K01238	10/04/2013	12:04	10/04/2013	12:51	1	47	47	Underground equipment			No Work Required	VI
132775236	V65549	10/04/2013	12:32	10/04/2013	15:05	49	7497	153	Overhead equipment	Overhead Primary	Raise		II
132775240	B25002	10/04/2013	12:36	10/04/2013	15:13	1	157	157	Overhead equipment	Fuse	Replace - Same Size		I
132775259	C50003	10/04/2013	12:40	10/04/2013	13:30	1	50	50	Overhead equipment	Fuse	Replace - Same Size	Repair	III
132775358	Y23513	10/04/2013	12:54	10/04/2013	13:55	21	1281	61	Public	Underground Primary	Repair	Replace - Same Size	IV
132775360	G10002	10/04/2013	13:05	10/04/2013	14:38	4	372	93	Unknown	Transformer Fuse	Replace - Same Size		I
132775468	Y91501	10/04/2013	13:34	10/04/2013	14:20	7	322	46	Animal related	Transformer Fuse	Repair	Replace - Same Size	IV
132775623	J05139	10/04/2013	14:15	10/04/2013	15:10	1	55	55	Unknown	Transformer Fuse	Replace - Same Size		I
132776096	Y27740	10/04/2013	14:30	10/04/2013	14:49	1015	19285	19	Jurisdictional				IV
132775689	Y26520	10/04/2013	14:34	10/04/2013	14:44	378	3780	10	Jurisdictional				IV
132775695	D55002	10/04/2013	14:35	10/04/2013	15:16	1	41	41	Unknown	Meter	Reconnect		I
132775862	J83138	10/04/2013	14:52	10/04/2013	16:28	1	96	96	Animal related	Fuse			VI
132775927	D69005	10/04/2013	14:52	10/04/2013	16:35	37	3811	103	Underground equipment	Other		Repair	I
132775977	U60559	10/04/2013	14:56	10/04/2013	18:57	56	13496	241	Underground equipment	Underground Primary	Switch/Reset		II
132776054	V36002	10/04/2013	15:04	10/04/2013	16:44	10	1000	100	Underground equipment	Underground Primary	Switch/Reset		II
132775933	N67309	10/04/2013	15:10	10/04/2013	17:24	6	804	134	Overhead equipment	Other	No Work Required	No Work Required	I
132775935	M18131	10/04/2013	15:10	10/04/2013	15:38	1	28	28	Overhead equipment	Overhead Transformer	Remove		III
132775956	339160	10/04/2013	15:18	10/04/2013	16:00	8	336	42	Overhead equipment	Overhead Transformer	Repair		V
132776037	M45211	10/04/2013	15:42	10/04/2013	17:39	1	117	117	Animal related	Fuse	Replace - Same Size		IV
132776092	C70004	10/04/2013	16:01	10/04/2013	17:26	85	7225	85	Tree related-tree broken	Overhead Primary	Patrol/Test/Inspect	Repair	III
132776116	B84002	10/04/2013	16:09	10/04/2013	16:51	86	3612	42	Underground equipment	Underground Primary	Repair		I
132776121	L35139	10/04/2013	16:11	10/04/2013	17:16	6	390	65	Animal related	Transformer Fuse	Replace - Same Size		III
132776120	M78325	10/04/2013	16:11	10/04/2013	16:45	3	102	34	Animal related	Transformer Fuse	Replace - Same Size		V
132776144	B84002	10/04/2013	16:17	10/04/2013	16:40	1	23	23	Underground equipment	Underground Primary	Replace - Same Size		I
132776183	A26006	10/04/2013	16:27	10/04/2013	18:22	1	115	115	Overhead equipment	Connector	Replace - Same Size		I
132776198	U31002	10/04/2013	16:30	10/04/2013	17:05	1	35	35	Overhead equipment	Connector	Repair		II
132776264	S27598	10/04/2013	16:56	10/04/2013	18:20	1	84	84	Tree related-tree broken				VI
132776278	S27598	10/04/2013	16:57	10/04/2013	19:35	20	3160	158	Tree related-tree broken	Overhead Primary			VI
132776291	L11244	10/04/2013	17:07	10/04/2013	20:16	8	1512	189	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	III
132776366	S60581	10/04/2013	17:11	10/04/2013	19:24	80	10640	133	Tree related-tree broken	Tree	Repair		VI
132776344	S15560	10/04/2013	17:27	10/04/2013	21:09	1	222	222	Tree related-tree broken	Overhead Service	Patrol/Test/Inspect	Repair	VI
132776347	L35139	10/04/2013	17:29	10/04/2013	17:48	1	19	19	Animal related	Transformer Fuse	Replace - Same Size		III
132776360	S03526	10/04/2013	17:29	10/04/2013	20:35	19	3534	186	Overhead equipment	Fuse	Patrol/Test/Inspect	Repair	VI
132776357	S88503	10/04/2013	17:31	10/05/2013	0:35	1	424	424	Tree related-tree broken	Overhead Primary	Repair	Replace - Same Size	VI
132776373	Y55505	10/04/2013	17:38	10/04/2013	21:42	1	244	244	Underground equipment	Underground Secondary	Repair	Repair	IV
132776412	S22595	10/04/2013	17:41	10/04/2013	19:55	63	8442	134	Weather	Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
132776451	S09520	10/04/2013	17:59	10/04/2013	22:10	4	1004	251	Overhead equipment				VI
132776427	L23148	10/04/2013	18:04	10/04/2013	22:09	1	245	245	Tree related-tree broken	Tree	Remove		III
132776460	M81404	10/04/2013	18:12	10/04/2013	19:15	29	1827	63	Public	Fuse	Replace - Same Size		V
132776465	P62138	10/04/2013	18:14	10/05/2013	2:10	8	3808	476	Underground equipment	Underground Primary	Repair	Repair	VI

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
132776467	N67315	10/04/2013	18:15	10/04/2013	18:41	1	26	26	Overhead equipment	Connector	Replace - New Size		I
132776471	D89002	10/04/2013	18:18	10/04/2013	19:07	1	49	49	Tree related-tree contact	Overhead Service	Patrol/Test/Inspect	Reconnect	I
132776512	C30001	10/04/2013	18:38	10/04/2013	20:49	1	131	131	Tree related-tree contact	Fuse		Repair	III
132776635	H00163	10/04/2013	19:16	10/04/2013	22:07	18	3078	171	Underground equipment	Underground Primary			III
132777334	M37191	10/04/2013	20:40	10/04/2013	21:30	7	350	50	Overhead equipment	Disconnect Switch	Replace - Same Size		I
132780015	S86582	10/05/2013	0:15	10/05/2013	5:30	58	18270	315	Tree related-tree broken				VI
132780012		10/05/2013	0:19	10/05/2013	5:34	1	315	315	Tree related-tree broken	Overhead Primary	Repair	Replace - Same Size	VI
132780046	S14510	10/05/2013	2:17	10/05/2013	3:21	13	832	64	Other	Underground Transformer			VI
132780048	M09175	10/05/2013	2:25	10/05/2013	3:12	1	47	47	Overhead equipment	Connector	Replace - Same Size	Repair	VI
132780078	S25552	10/05/2013	5:20	10/05/2013	6:45	1	85	85	Overhead equipment	Transformer Fuse	Replace - Same Size		VI
132780261	J61113	10/05/2013	6:45	10/05/2013	7:36	8	408	51	Animal related	Transformer Fuse			III
132780266	U10569	10/05/2013	7:03	10/05/2013	8:30	1	87	87	Animal related	Transformer Fuse	Replace - Same Size		II
132780269	N35852	10/05/2013	7:08	10/05/2013	10:26	4	792	198	Overhead equipment	Overhead Transformer	Replace - Same Size	Replace - Same Size	V
132780331	Z17503	10/05/2013	7:20	10/05/2013	9:15	10	1150	115	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	IV
132780284	S47576	10/05/2013	7:21	10/05/2013	8:53	1	92	92	Animal related	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
132780319	M40131	10/05/2013	8:12	10/05/2013	11:47	1	215	215	Public	Underground Secondary	Repair	Repair	I
132780334	U80511	10/05/2013	8:28	10/05/2013	9:33	1	65	65	Animal related	Transformer Fuse	Replace - Same Size	No Work Required	II
132780409	V44511	10/05/2013	8:36	10/05/2013	10:35	2	238	119	Animal related	Disconnect Switch	Replace - Urgent		II
132780356	V44511	10/05/2013	8:36	10/05/2013	9:39	518	32634	63	Animal related	Substation Breaker	Switch/Reset		II
132780395	K69117	10/05/2013	9:06	10/05/2013	10:13	63	4221	67	Animal related	Fuse	Replace - Same Size		IV
132780385	T04514	10/05/2013	9:14	10/05/2013	11:41	1	147	147	Overhead equipment	Lightning Arrestor	Repair		VI
132780386	L50214	10/05/2013	9:17	10/05/2013	13:11	3	702	234	Overhead equipment	Overhead Transformer	Replace - Same Size	Replace - Same Size	VI
132780393	T03582	10/05/2013	9:20	10/05/2013	13:02	5	1110	222	Weather	Overhead Transformer	Replace - Same Size		VI
132780394		10/05/2013	9:21	10/05/2013	12:55	1	214	214	Weather	Overhead Transformer	Replace - Same Size		VI
132780422	Q01281	10/05/2013	9:48	10/05/2013	10:11	1	23	23	Animal related	Fuse			III
132780426	J12166	10/05/2013	9:51	10/05/2013	11:33	1	102	102	Tree related-tree contact	Overhead Service	Trim		III
132780441	A49003	10/05/2013	10:09	10/05/2013	10:52	1	43	43	Overhead equipment	Overhead Service	Repair		I
132780449	Q34360	10/05/2013	10:14	10/05/2013	11:46	11	1012	92	Weather	Fuse	Replace - Same Size	Replace - Same Size	I
132780461	307002	10/05/2013	10:23	10/05/2013	10:40	1	17	17	Overhead equipment	Overhead Service	Repair		VI
132780565	R41131	10/05/2013	10:39	10/05/2013	12:11	1	92	92	Overhead equipment	Fuse	Repair		VI
132780571	Z16547	10/05/2013	10:47	10/05/2013	12:00	1	73	73	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
132780607	K08909	10/05/2013	11:33	10/05/2013	19:18	1	465	465	Tree related-tree contact	Overhead Service	Repair	Repair	VI
132780685	J20931	10/05/2013	12:23	10/05/2013	13:54	361	32851	91	Overhead equipment				VI
132780669	J20931	10/05/2013	12:27	10/05/2013	18:08	3	1023	341	Tree related-tree broken	Tree			VI
132780699	M09144	10/05/2013	12:39	10/05/2013	14:17	10	980	98	Animal related	Fuse	Replace - Same Size	Repair	VI
132780711	R49275	10/05/2013	12:54	10/05/2013	16:59	1	245	245	Tree related-tree broken	Overhead Primary		Repair	VI
132780716	P18103	10/05/2013	12:55	10/05/2013	14:30	68	6460	95	Weather	Transformer Fuse	Repair		IV
132780736	P25150	10/05/2013	13:03	10/05/2013	14:25	1	82	82	Weather	Fuse	Replace - Same Size		III
132780737	R01153	10/05/2013	13:03	10/05/2013	14:40	77	7469	97	Underground equipment	Underground Primary	Switch/Reset	No Work Required	III
132780772	Q27186	10/05/2013	13:06	10/05/2013	14:11	8	520	65	Weather	Fuse	Replace - Same Size		VI
132780747	Q47833	10/05/2013	13:11	10/05/2013	15:20	1	129	129	Weather	Transformer Fuse	Replace - Same Size		V
132780755		10/05/2013	13:15	10/05/2013	15:24	1	129	129	Weather	Overhead Transformer	Replace - Same Size		VI
132780762	R59412	10/05/2013	13:26	10/05/2013	13:59	12	396	33	Weather	Fuse	Replace - Same Size		IV
132780763	K89142	10/05/2013	13:27	10/05/2013	14:00	1	33	33	Unknown	Fuse	Replace - Same Size		III
132780782		10/05/2013	13:39	10/05/2013	15:13	1	94	94	Overhead equipment			Patrol/Test/Inspect	VI
132780850	K17119	10/05/2013	13:55	10/05/2013	17:06	32	6112	191	Overhead equipment				VI
132780799	R20502	10/05/2013	14:03	10/05/2013	14:28	1	25	25	Overhead equipment	Fuse	Replace - Same Size		IV
132781279	X66582	10/05/2013	14:07	10/05/2013	17:55	1	228	228	Weather	Overhead Transformer	Replace - Same Size	Replace - Same Size	IV
132780872	X66582	10/05/2013	14:07	10/05/2013	15:30	255	21165	83	Weather	Substation Breaker	Replace - Same Size		IV
132780809	R20501	10/05/2013	14:12	10/05/2013	15:09	1	57	57	Weather	Fuse	Replace - Same Size		IV
132780818	R34921	10/05/2013	14:16	10/05/2013	15:15	1	59	59	Tree related-tree contact	Overhead Service	Raise		VI
132780829	Y23521	10/05/2013	14:18	10/05/2013	17:30	5	960	192	Underground equipment	Underground Transformer	Repair	Replace - Same Size	IV
132780834	J30201	10/05/2013	14:20	10/05/2013	15:29	1	69	69	Weather	Fuse	Replace - New Size		VI
132780843	J30201	10/05/2013	14:27	10/05/2013	14:45	16	288	18	Tree related-tree broken	Overhead Primary			VI
132780876	J15302	10/05/2013	14:43	10/05/2013	15:47	8	512	64	Animal related	Transformer Fuse	Replace - Same Size		I
132781369	Q64919	10/05/2013	14:46	10/05/2013	17:57	3	573	191	Weather	Fuse	Repair	Replace - Same Size	VI

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
132780884	P20913	10/05/2013	14:52	10/05/2013	15:50	1	58	58	Tree related-tree contact	Tree			VI
132780885	P54828	10/05/2013	14:53	10/05/2013	17:10	1	137	137	Weather	Transformer Fuse	Replace - Same Size		V
132781228	M25144	10/05/2013	15:08	10/05/2013	16:10	2	124	62	Overhead equipment	Fuse			IV
132781213	F22001	10/05/2013	15:11	10/05/2013	15:59	21	1008	48	Weather	Fuse	Replace - Same Size		IV
132781224	L62927	10/05/2013	15:19	10/05/2013	16:25	14	924	66	Overhead equipment	Jumper	Repair		VI
132781242	M25144	10/05/2013	15:32	10/05/2013	16:42	1	70	70	Weather	Fuse			IV
132781265	R20502	10/05/2013	15:46	10/05/2013	16:32	1	46	46	Weather	Lightning Arrestor	Replace - Same Size		IV
132781267	U99515	10/05/2013	15:52	10/05/2013	17:19	1	87	87	Animal related	Animal Guard	Install		II
132781386	K25166	10/05/2013	16:07	10/05/2013	17:44	17	1649	97	Tree related-tree broken	Fuse	Repair		VI
132781440	S55566	10/05/2013	16:07	10/05/2013	19:05	90	16020	178	Overhead equipment	Disconnect Switch			VI
132781435	S55566	10/05/2013	16:07	10/05/2013	18:54	204	34068	167	Overhead equipment	Disconnect Switch			VI
132781434	S55566	10/05/2013	16:07	10/05/2013	18:28	109	15369	141	Overhead equipment	Disconnect Switch			VI
132781431	S55566	10/05/2013	16:08	10/05/2013	18:28	25	3500	140	Overhead equipment	Disconnect Switch			VI
132781282	S55566	10/05/2013	16:10	10/05/2013	18:10	40	4800	120	Overhead equipment	Disconnect Switch			VI
132781336	M19222	10/05/2013	16:23	10/05/2013	23:11	1	408	408	Overhead equipment	Lightning Arrestor	Patrol/Test/Inspect	Replace - Same Size	VI
132781415	M25144	10/05/2013	17:35	10/05/2013	19:22	1	107	107	Overhead equipment	Overhead Transformer			IV
132781419	R49275	10/05/2013	17:47	10/05/2013	19:29	1	102	102	Overhead equipment	Jumper	Repair	Repair	VI
132781432	S62521	10/05/2013	18:17	10/05/2013	19:00	3	129	43	Animal related	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
132781496	M25143	10/05/2013	18:39	10/05/2013	21:40	2	362	181	Overhead equipment	Overhead Transformer	Replace - Same Size		IV
132781446	339162	10/05/2013	18:47	10/05/2013	22:40	49	11417	233	Tree related-tree broken	Overhead Primary	Patrol/Test/Inspect	Repair	V
132781453	H01194	10/05/2013	19:01	10/05/2013	20:32	1	91	91	Weather	Fuse	Replace - Same Size		III
132781469	Z17503	10/05/2013	19:16	10/05/2013	21:45	1	149	149	Weather	Transformer Fuse	Replace - Same Size		IV
132781479	D28123	10/05/2013	19:35	10/06/2013	2:00	1	385	385	Underground equipment	Underground Service	Patrol/Test/Inspect	Repair	I
132781486	S55566	10/05/2013	19:46	10/05/2013	20:27	1	41	41	Overhead equipment	Fuse	Repair	Replace - New Size	VI
132781488	A50002	10/05/2013	19:47	10/06/2013	10:30	1	883	883	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
132781490	U80564	10/05/2013	19:51	10/05/2013	22:39	1	168	168	Tree related-tree broken	Overhead Service	Repair		II
132781494	D41002	10/05/2013	19:56	10/05/2013	20:38	2	84	42	Unknown	Fuse	Repair		I
132781515	J20931	10/05/2013	20:38	10/05/2013	22:03	1	85	85	Tree related-tree contact	Overhead Secondary		Cut in Clear	VI
132781521	S13549	10/05/2013	20:50	10/05/2013	22:43	1	113	113	Tree related-tree broken	Overhead Service			VI
132781520	S83503	10/05/2013	20:50	10/05/2013	22:29	1	99	99	Tree related-tree broken	Overhead Service	Repair	Replace - Same Size	VI
132781528	S31532	10/05/2013	21:11	10/05/2013	23:18	1	127	127	Weather	Disconnect Switch	Repair		VI
132781530	V23592	10/05/2013	21:18	10/05/2013	22:10	1	52	52	Animal related	Transformer Fuse	Replace - Same Size		II
132781543	S55534	10/05/2013	21:46	10/06/2013	6:00	28	13832	494	Overhead equipment	Pole		Repair	VI
132781556	D16004	10/05/2013	22:40	10/06/2013	11:30	33	25410	770	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
132790005	M45212	10/06/2013	0:22	10/06/2013	1:24	21	1302	62	Underground equipment	Underground Primary	Switch/Reset	Switch/Reset	IV
132790010	B81003	10/06/2013	0:57	10/06/2013	7:10	43	16039	373	Public				I
132790047	K46388	10/06/2013	7:08	10/06/2013	10:53	16	3600	225	Animal related	Fuse	Replace - Same Size	Replace - Same Size	V
132790292	L93135	10/06/2013	7:54	10/06/2013	13:25	244	80764	331	Animal related	Overhead Primary	Patrol/Test/Inspect	Repair	VI
132790048	L93135	10/06/2013	7:54	10/06/2013	9:50	696	80736	116	Overhead equipment	Overhead Primary	Repair		VI
132790056	S07536	10/06/2013	8:26	10/06/2013	11:05	1	159	159	Overhead equipment	Overhead Secondary	Repair		VI
132790083	M36185	10/06/2013	8:35	10/06/2013	11:47	3	576	192	Animal related	Underground Primary	Repair	Repair	I
132790070	S07536	10/06/2013	8:36	10/06/2013	11:05	1	149	149	Overhead equipment	Overhead Secondary	Repair		VI
132790081	S14510	10/06/2013	8:40	10/06/2013	10:25	13	1365	105	Tree related-tree contact	Tree			VI
132790085	Q28141	10/06/2013	8:45	10/06/2013	10:23	1	98	98	Animal related	Fuse	Replace - Same Size	Repair	VI
132790314	S34528	10/06/2013	8:50	10/06/2013	11:00	3	390	130	Animal related	Fuse			VI
132790091	K52400	10/06/2013	8:53	10/06/2013	11:10	4	548	137	Animal related	Transformer Fuse	Replace - Same Size		V
132790094	L24123	10/06/2013	9:01	10/06/2013	13:10	2	498	249	Weather	Fuse	Repair		III
132790095	Q64917	10/06/2013	9:02	10/06/2013	10:25	1	83	83	Animal related	Lightning Arrestor	Replace - Same Size		VI
132790099	C10002	10/06/2013	9:03	10/06/2013	10:40	1	97	97	Underground equipment	Fuse	Replace - New Size	Repair	III
132790338	S49550	10/06/2013	9:07	10/06/2013	10:39	4	368	92	Animal related	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
132790117	S61531	10/06/2013	9:26	10/06/2013	9:58	1	32	32	Animal related	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
132790258		10/06/2013	9:30	10/06/2013	10:17	3471	163137	47	Animal related				VI
132790287	349002	10/06/2013	9:41	10/06/2013	10:10	1	29	29	Tree related-tree broken	Tree	Remove		VI
132790293	303006	10/06/2013	9:48	10/06/2013	10:07	1	19	19	Tree related-tree broken	Tree	Remove		VI
132790298	Q18242	10/06/2013	9:48	10/06/2013	15:34	26	8996	346	Underground equipment	Underground Primary	Repair	Replace - Same Size	VI
132790316	X24536	10/06/2013	10:18	10/06/2013	11:20	1	62	62	Tree related-tree broken	Overhead Service	Patrol/Test/Inspect		IV

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
132790329	A81004	10/06/2013	10:22	10/06/2013	12:40	13	1794	138	Overhead equipment	Lightning Arrestor	Replace - Same Size		I
132790335	Q18242	10/06/2013	10:29	10/06/2013	18:33	59	28556	484	Animal related	Fuse	Repair	Replace - Same Size	VI
132790343	S88503	10/06/2013	10:37	10/06/2013	14:22	1	225	225	Animal related	Overhead Transformer	Repair		VI
132790345	Y69553	10/06/2013	10:38	10/06/2013	12:10	2	184	92	Tree related-tree broken	Overhead Service	Repair		IV
132790347	Y60548	10/06/2013	10:39	10/06/2013	12:31	1	112	112	Animal related	Disconnect Switch	Replace - Same Size		IV
132790360	S49550	10/06/2013	10:55	10/06/2013	11:22	2	54	27	Animal related	Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
132790651	M61302	10/06/2013	11:01	10/06/2013	15:30	33	8877	269	Tree related-tree contact	Overhead Secondary	Patrol/Test/Inspect	Replace - Same Size	V
132790367	X75512	10/06/2013	11:06	10/06/2013	18:32	5	2230	446	Underground equipment	Overhead Primary	Repair	Repair	IV
132790369	K39153	10/06/2013	11:06	10/06/2013	12:36	11	990	90	Animal related	Fuse	Replace - Same Size		III
132790372	K67924	10/06/2013	11:07	10/06/2013	12:44	1	97	97	Overhead equipment	Fuse			VI
132790402	Y97514	10/06/2013	11:10	10/06/2013	17:39	6	2334	389	Underground equipment	Underground Primary	Repair		IV
132790377	D66002	10/06/2013	11:12	10/06/2013	12:19	10	670	67	Animal related	Transformer Fuse			IV
132790380	Q11517	10/06/2013	11:18	10/06/2013	16:55	1	337	337	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	I
132790383	K52401	10/06/2013	11:22	10/06/2013	12:22	1	60	60	Tree related-tree contact	Overhead Transformer		Replace - Same Size	V
132790399	Q11516	10/06/2013	11:28	10/06/2013	15:20	18	4176	232	Animal related	Overhead Transformer	Replace - Same Size	Replace - Same Size	I
132790634	X86543	10/06/2013	11:32	10/06/2013	16:09	5	1385	277	Overhead equipment	Crossarm	Replace - New Size		IV
132790477	X86543	10/06/2013	11:32	10/06/2013	13:40	528	67584	128	Tree related-tree broken	Tree	Remove	Repair	IV
132790458	R20501	10/06/2013	12:05	10/06/2013	16:13	1	248	248	Overhead equipment	Overhead Transformer	Replace - Same Size	Replace - Same Size	IV
132790460	S28552	10/06/2013	12:06	10/06/2013	13:05	1	59	59	Animal related	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
132790473	X64501	10/06/2013	12:18	10/06/2013	14:30	1	132	132	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
132790498	S47575	10/06/2013	12:35	10/06/2013	13:25	1	50	50	Animal related	Transformer Fuse			VI
132790500	P71830	10/06/2013	12:37	10/06/2013	14:00	6	498	83	Tree related-tree broken	Transformer Fuse	Replace - Same Size	No Work Required	V
132790507	B73002	10/06/2013	12:59	10/06/2013	18:20	1	321	321	Underground equipment	Underground Primary		Repair	I
132790562	P26281	10/06/2013	13:13	10/06/2013	14:35	1	82	82	Animal related	Transformer Fuse	Repair		I
132790576	X02548	10/06/2013	13:27	10/06/2013	15:11	1	104	104	Overhead equipment	Transformer Fuse			IV
132790578	D53002	10/06/2013	13:29	10/06/2013	14:50	1	81	81	Underground equipment	Underground Primary	Switch/Reset	Repair	I
132790577	Q74150	10/06/2013	13:29	10/06/2013	15:10	1	101	101	Unknown	Transformer Fuse	Replace - Same Size		IV
132790584	Y13043	10/06/2013	13:33	10/06/2013	15:15	2	204	102	Tree related-tree broken	Overhead Service	Raise		IV
132790599	Q23258	10/06/2013	14:03	10/06/2013	14:24	31	651	21	Overhead equipment	Fuse		Replace - Same Size	VI
132790603	D72002	10/06/2013	14:09	10/06/2013	20:45	1	396	396	Underground equipment	Underground Service		Repair	I
132790635	R34920	10/06/2013	14:59	10/06/2013	15:42	1	43	43	Animal related	Transformer Fuse	Replace - Same Size		VI
132790646	J84146	10/06/2013	15:14	10/06/2013	17:03	1	109	109	Overhead equipment	Connector	Replace - Same Size		VI
132790653	X86543	10/06/2013	15:25	10/06/2013	16:45	1	80	80	Tree related-tree broken	Overhead Secondary	Repair	No Work Required	IV
132790690	V28597	10/06/2013	16:18	10/06/2013	17:51	1	93	93	Tree related-tree contact	Overhead Service	Repair	Repair	II
132790727	U52516	10/06/2013	17:28	10/06/2013	18:35	1	67	67	Overhead equipment	Connector	Repair	Repair	II
132790790	F03003	10/06/2013	17:40	10/06/2013	19:52	1	132	132	Underground equipment	Underground Primary	Switch/Reset		III
132790737	F03003	10/06/2013	17:40	10/06/2013	21:15	6	1290	215	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	III
132790749	P25150	10/06/2013	18:22	10/06/2013	20:10	1	108	108	Overhead equipment	Other	Replace - Same Size		III
132790776	B21002	10/06/2013	19:24	10/06/2013	22:57	5	1065	213	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	I
132790782	L81141	10/06/2013	19:39	10/06/2013	22:30	1	171	171	Overhead equipment	Overhead Transformer			IV
132790801	D53001	10/06/2013	20:19	10/06/2013	20:45	496	12896	26	Overhead equipment	Crossarm	Replace - Same Size		I
132800084	Q04411	10/06/2013	23:22	10/07/2013	0:33	12	852	71	Underground equipment	Underground Primary	Switch/Reset		III
132790866	Q04411	10/06/2013	23:22	10/07/2013	2:04	29	4698	162	Underground equipment	Underground Primary	Switch/Reset		III
132800076	X42502	10/07/2013	0:19	10/07/2013	2:26	1	127	127	Tree related-tree broken	Overhead Service	Repair		IV
132800080	M78323	10/07/2013	0:50	10/07/2013	4:40	1	230	230	Public	Meter		Repair	V
132800105	L95110	10/07/2013	1:17	10/07/2013	3:03	4	424	106	Underground equipment	Underground Primary	Switch/Reset		III
132800087	L95110	10/07/2013	1:26	10/07/2013	4:55	24	5016	209	Underground equipment	Underground Primary	Switch/Reset	Repair	III
132800097	P18104	10/07/2013	1:35	10/07/2013	5:50	23	5865	255	Underground equipment	Underground Primary	Switch/Reset	Repair	IV
132803581	X69556	10/07/2013	3:39	10/07/2013	5:10	1	91	91	Overhead equipment	Jumper	Repair		IV
132803584	U93507	10/07/2013	4:09	10/07/2013	5:44	1	95	95	Animal related	Transformer Fuse	Repair		II
132803600	R84148	10/07/2013	4:56	10/07/2013	7:35	16	2544	159	Underground equipment	Underground Primary	Repair	Repair	I
132803604	S25552	10/07/2013	5:35	10/07/2013	9:30	15	3525	235	Underground equipment	Underground Primary	Repair		VI
132803607	B45005	10/07/2013	5:50	10/07/2013	10:10	1	260	260	Underground equipment	Underground Primary		Repair	I
132803711	L95110	10/07/2013	6:00	10/07/2013	11:10	3	930	310	Underground equipment	Underground Primary	Replace - Same Size		III
132803614	L95110	10/07/2013	6:00	10/07/2013	7:12	25	1800	72	Underground equipment	Underground Primary	Replace - Same Size		III
132803629	Q04411	10/07/2013	6:20	10/07/2013	7:03	1	43	43	Animal related	Transformer Fuse	Repair	Repair	III

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
132803660	M25144	10/07/2013	6:48	10/07/2013	12:27	1	339	339	Weather	Overhead Transformer			IV
132803678	M25144	10/07/2013	7:02	10/07/2013	7:59	1	57	57	Unknown	Transformer Fuse	Replace - Same Size		IV
132803838	Q71846	10/07/2013	7:47	10/07/2013	9:30	1	103	103	Animal related	Transformer Fuse	Replace - Same Size		V
132803844	B58001	10/07/2013	7:49	10/07/2013	8:55	1	66	66	Animal related	Fuse	Replace - Same Size		I
132803876	Y37592	10/07/2013	8:02	10/07/2013	9:32	1	90	90	Overhead equipment	Fuse	Repair		IV
132803882	X96524	10/07/2013	8:04	10/07/2013	9:43	1	99	99	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
132804016	U09517	10/07/2013	8:24	10/07/2013	9:57	2	186	93	Weather	Lightning Arrestor			II
132804049	J15302	10/07/2013	8:28	10/07/2013	10:00	1	92	92	Overhead equipment	Transformer Fuse	Replace - New Size		I
132804093	Q10702	10/07/2013	8:37	10/07/2013	9:32	1	55	55	Animal related	Transformer Fuse	Replace - Same Size		V
132804111	J07173	10/07/2013	8:39	10/07/2013	9:05	1	26	26	Overhead equipment	Overhead Service	No Work Required		I
132804117	L24121	10/07/2013	8:41	10/07/2013	11:44	8	1464	183	Overhead equipment	Overhead Transformer		Replace - Same Size	III
132804167	L74196	10/07/2013	8:50	10/07/2013	9:55	12	780	65	Overhead equipment	Overhead Primary	Repair	Repair	IV
132804194	Q16867	10/07/2013	8:59	10/07/2013	10:10	1	71	71	Animal related	Transformer Fuse	Replace - Same Size		V
132804252	Q10702	10/07/2013	9:10	10/07/2013	10:41	1	91	91	Animal related	Overhead Primary			V
132804367	B08003	10/07/2013	9:31	10/07/2013	11:57	1	146	146	Jurisdictional	Underground Service		Repair	I
132804412	P47169	10/07/2013	9:37	10/07/2013	10:30	49	2597	53	Animal related	Fuse	Replace - Same Size		I
132804550	M81404	10/07/2013	9:55	10/07/2013	10:54	25	1475	59	Animal related	Fuse	Replace - Same Size		V
132804763	M49424	10/07/2013	10:37	10/07/2013	11:40	1	63	63	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	V
132804894	S93553	10/07/2013	10:52	10/07/2013	11:20	394	11032	28	Overhead equipment	Lightning Arrestor			VI
132807526	C76002	10/07/2013	11:12	10/07/2013	20:47	2	1150	575	Underground equipment	Underground Primary	Patrol/Test/Inspect	Reconnect	I
132805078	X39530	10/07/2013	11:31	10/07/2013	18:00	12	4668	389	Underground equipment	Underground Primary	Repair	Repair	IV
132805118	D69003	10/07/2013	11:37	10/07/2013	13:01	36	3024	84	Unknown	Fuse	Repair	Replace - Same Size	I
132805159	A56014	10/07/2013	11:47	10/07/2013	12:40	1	53	53	Tree related-tree contact	Overhead Service		Repair	I
132805244	S07536	10/07/2013	12:04	10/07/2013	13:16	1	72	72	Animal related	Disconnect Switch	Replace - Same Size		VI
132805248	A91002	10/07/2013	12:06	10/07/2013	17:20	1	314	314	Overhead equipment	Overhead Transformer	Repair	Repair	I
132805345	M25144	10/07/2013	12:26	10/07/2013	13:03	1	37	37	Animal related	Transformer Fuse			IV
132805482	U06551	10/07/2013	12:54	10/07/2013	13:15	5	105	21	Animal related	Transformer Fuse	Replace - Same Size		II
132805547	D88001	10/07/2013	13:02	10/07/2013	14:00	29	1682	58	Animal related	Fuse	Replace - Same Size		I
132805620	J80807	10/07/2013	13:17	10/07/2013	14:35	1	78	78	Animal related	Overhead Transformer	Repair	Repair	V
132805682	X64503	10/07/2013	13:29	10/07/2013	14:48	1	79	79	Tree related-tree contact	Overhead Service	Repair		IV
132805688	N22295	10/07/2013	13:30	10/07/2013	15:24	1	114	114	Overhead equipment	Fuse	Replace - Same Size		VI
132805714	S62520	10/07/2013	13:36	10/07/2013	13:56	1	20	20	Animal related	Transformer Fuse	Replace - Same Size		VI
132805735	A45003	10/07/2013	13:39	10/07/2013	16:59	1	200	200	Underground equipment	Underground Primary		Repair	I
132805766		10/07/2013	13:47	10/07/2013	13:58	1	11	11	Animal related				VI
132805831	J06167	10/07/2013	13:59	10/07/2013	15:54	1	115	115	Overhead equipment	Transformer Fuse	Replace - Same Size		I
132805867	P47123	10/07/2013	14:06	10/07/2013	14:47	1	41	41	Overhead equipment	Transformer Fuse	Replace - Same Size		I
132805937	D35001	10/07/2013	14:15	10/07/2013	14:30	6	90	15	Animal related	Fuse	Repair		I
132805998	K76542	10/07/2013	14:19	10/07/2013	15:50	26	2366	91	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	IV
132806160	H10843	10/07/2013	15:03	10/07/2013	16:15	1	72	72	Tree related-tree contact	Overhead Service	Repair		V
132806685	K46388	10/07/2013	15:10	10/07/2013	21:00	5	1750	350	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	V
132806230	A50001	10/07/2013	15:12	10/07/2013	17:19	27	3429	127	Underground equipment	Underground Primary	Replace - Same Size		I
132806368	V20502	10/07/2013	15:47	10/07/2013	19:25	1	218	218	Animal related	Transformer Fuse	Replace - Same Size		II
132806424	K09855	10/07/2013	16:04	10/07/2013	19:00	8	1408	176	Tree related-tree broken	Overhead Service	Repair	Repair	V
132806514	K76541	10/07/2013	16:26	10/07/2013	18:04	1	98	98	Tree related-tree contact	Overhead Secondary	Repair		IV
132806526	J20931	10/07/2013	16:29	10/07/2013	17:24	1	55	55	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	VI
132806552	Q34366	10/07/2013	16:36	10/07/2013	17:44	1	68	68	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	I
132806600	P20930	10/07/2013	16:52	10/07/2013	18:00	1	68	68	Overhead equipment	Fuse	Replace - Same Size	Patrol/Test/Inspect	VI
132806705	R42914	10/07/2013	17:22	10/07/2013	18:41	27	2133	79	Overhead equipment	Fuse	Replace - Same Size	Patrol/Test/Inspect	VI
132806734	P98191	10/07/2013	17:29	10/07/2013	18:00	10	310	31	Animal related	Other			III
132806826	A50001	10/07/2013	18:11	10/07/2013	20:04	22	2486	113	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
132806868	H11338	10/07/2013	18:30	10/07/2013	19:22	1	52	52	Overhead equipment	Overhead Transformer	Repair		V
132807080	334004	10/07/2013	18:54	10/07/2013	19:58	10	640	64	Overhead equipment	Overhead Secondary	Repair		VI
132807957	P05825	10/07/2013	19:05	10/07/2013	21:20	1	135	135	Overhead equipment	Lightning Arrestor			V
132807903	A49002	10/07/2013	19:43	10/07/2013	21:19	1	96	96	Overhead equipment	Overhead Service	Repair		I
132807947	B80002	10/07/2013	20:57	10/07/2013	22:55	48	5664	118	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
132807969	D28123	10/07/2013	22:04	10/08/2013	5:28	3	1332	444	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
132811850	K80381	10/08/2013	1:48	10/08/2013	6:30	20	5640	282	Underground equipment	Underground Service		Replace - Same Size	IV
132813774	S14510	10/08/2013	3:07	10/08/2013	8:15	24	7392	308	Overhead equipment	Disconnect Switch	Repair	Repair	VI
132811846	S60245	10/08/2013	3:36	10/08/2013	5:03	2903	252561	87	Overhead equipment				VI
132813851	L12126	10/08/2013	4:22	10/08/2013	10:27	28	10220	365	Underground equipment	Underground Primary			III
132813745	L12126	10/08/2013	4:24	10/08/2013	6:55	66	9966	151	Underground equipment	Underground Primary			III
132813752	P18104	10/08/2013	5:28	10/08/2013	7:13	24	2520	105	Underground equipment	Underground Primary	Switch/Reset	Repair	IV
132813756	U99578	10/08/2013	5:57	10/08/2013	7:40	3	309	103	Animal related	Lightning Arrestor			II
132813759	M18131	10/08/2013	6:01	10/08/2013	8:40	1	159	159	Underground equipment	Underground Service	Patrol/Test/Inspect	Repair	III
132813804	P12290	10/08/2013	6:20	10/08/2013	6:22	1083	2166	2	Substation equipment				V
132813856	C10002	10/08/2013	6:57	10/08/2013	11:00	1	243	243	Underground equipment	Underground Transformer			III
132813885	S14510	10/08/2013	7:13	10/08/2013	8:15	160	9920	62	Overhead equipment	Disconnect Switch	Repair	Repair	VI
132813929	X02548	10/08/2013	7:30	10/08/2013	9:18	1	108	108	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
132813974	B21003	10/08/2013	7:40	10/08/2013	15:25	1	465	465	Underground equipment	Underground Primary	Repair	Repair	I
132813990	P12290	10/08/2013	7:46	10/08/2013	9:20	1	94	94	Overhead equipment	Overhead Service	Repair		V
132814016	J05139	10/08/2013	7:56	10/08/2013	10:05	1	129	129	Animal related	Fuse	Replace - Same Size		I
132814351	Q32170	10/08/2013	8:41	10/08/2013	11:20	13	2067	159	Animal related	Overhead Transformer	Replace - Same Size		I
132814198	J15303	10/08/2013	8:45	10/08/2013	9:42	1	57	57	Overhead equipment	Connector	Replace - New Size		I
132814443	374069	10/08/2013	9:12	10/08/2013	10:27	7	525	75	Overhead equipment	Jumper	Repair		VI
132814491	J34377	10/08/2013	9:41	10/08/2013	11:20	1	99	99	Animal related	Fuse	Replace - Same Size		V
132814501	J89126	10/08/2013	9:43	10/08/2013	12:36	6	1038	173	Overhead equipment	Overhead Transformer		Replace - Same Size	VI
132814517	Q15845	10/08/2013	9:46	10/08/2013	11:53	1	127	127	Public	Underground Service	Repair		V
132814530		10/08/2013	9:48	10/08/2013	14:30	1	282	282	Overhead equipment	Disconnect Switch	Patrol/Test/Inspect	Replace - New Size	VI
132814635	L17105	10/08/2013	9:55	10/08/2013	10:50	34	1870	55	Unknown	Fuse	Replace - Same Size		III
132814583	A26002	10/08/2013	9:58	10/08/2013	12:14	1	136	136	Underground equipment	Underground Service		Repair	I
132814589	J18268	10/08/2013	9:59	10/08/2013	10:40	12	492	41	Animal related	Transformer Fuse	Replace - Same Size	Patrol/Test/Inspect	VI
132814602	S15558	10/08/2013	10:01	10/08/2013	11:05	1	64	64	Animal related				VI
132814618	T11509	10/08/2013	10:05	10/08/2013	10:45	2	80	40	Animal related	Transformer Fuse			VI
132814657	P17107	10/08/2013	10:10	10/08/2013	13:49	1	219	219	Public	Underground Service		Repair	IV
132814711	R39934	10/08/2013	10:21	10/08/2013	14:05	1	224	224	Overhead equipment	Transformer Fuse	Replace - Same Size		VI
132814750	U45536	10/08/2013	10:29	10/08/2013	19:05	6	3096	516	Public	Pole	Disconnect	Replace - New Size	II
132814929	U73599	10/08/2013	10:54	10/08/2013	11:37	1	43	43	Unknown	Fuse	Replace - Same Size		II
132814946	M37192	10/08/2013	10:54	10/08/2013	11:55	37	2257	61	Unknown	Fuse	Repair	Replace - Same Size	I
132815778	R99180	10/08/2013	11:01	10/08/2013	13:30	5	745	149	Underground equipment	Underground Primary	Switch/Reset		IV
132815014	R99180	10/08/2013	11:01	10/08/2013	15:45	19	5396	284	Underground equipment	Underground Primary	Switch/Reset	Repair	IV
132815012	X64001	10/08/2013	11:06	10/08/2013	11:45	1	39	39	Unknown	Fuse	Repair		IV
132815059	Q74148	10/08/2013	11:14	10/08/2013	14:00	1	166	166	Overhead equipment	Overhead Transformer			IV
132815353	341003	10/08/2013	12:04	10/08/2013	12:40	1	36	36	Public	Other			VI
132815419	S79510	10/08/2013	12:19	10/08/2013	13:25	1	66	66	Animal related	Overhead Transformer	Switch/Reset		VI
132815641	M37192	10/08/2013	13:07	10/08/2013	14:00	1	53	53	Weather	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	I
132815701	V03529	10/08/2013	13:17	10/08/2013	14:00	1	43	43	Animal related	Transformer Fuse	Replace - Same Size	No Work Required	II
132815827	S84535	10/08/2013	13:38	10/08/2013	15:44	1	126	126	Public	Underground Primary	Repair	Replace - Same Size	VI
132815861	N93260	10/08/2013	13:41	10/08/2013	15:10	70	6230	89	Overhead equipment	Overhead Primary		Replace - Same Size	III
132815851	L81141	10/08/2013	13:44	10/08/2013	14:25	1	41	41	Tree related-tree contact	Tree			IV
132816294	X86543	10/08/2013	14:51	10/08/2013	17:15	1	144	144	Animal related	Transformer Fuse	Repair	Patrol/Test/Inspect	IV
132816616	X91510	10/08/2013	16:07	10/08/2013	16:50	1	43	43	Overhead equipment	Transformer Fuse	Repair	Replace - Same Size	IV
132816678	J86118	10/08/2013	16:20	10/08/2013	18:30	71	9230	130	Overhead equipment	Fuse	Replace - Same Size		VI
132816688	J86118	10/08/2013	16:21	10/08/2013	19:18	23	4071	177	Overhead equipment	Fuse			VI
132816980	J86118	10/08/2013	16:26	10/08/2013	20:46	39	10140	260	Overhead equipment	Crossarm		Replace - Same Size	VI
132816757	J86118	10/08/2013	16:27	10/08/2013	17:51	12	1008	84	Overhead equipment				VI
132816716	S04545	10/08/2013	16:30	10/08/2013	17:20	1	50	50	Animal related	Transformer Fuse	Replace - Same Size		VI
132816736	S78551	10/08/2013	16:37	10/08/2013	19:15	1	158	158	Overhead equipment	Overhead Secondary	Repair	Repair	VI
132816803	B62004	10/08/2013	16:57	10/08/2013	17:42	1	45	45	Overhead equipment	Transformer Fuse	Replace - Urgent		I
132816800	H01190	10/08/2013	16:57	10/08/2013	17:57	1	60	60	Unknown	Transformer Fuse	Replace - Same Size		III
132816804	Q93522	10/08/2013	16:58	10/08/2013	19:06	1	128	128	Animal related	Transformer Fuse	Repair		I
132816839	J82312	10/08/2013	17:05	10/08/2013	18:33	1	88	88	Overhead equipment	Crossarm	Switch/Reset		VI
132816859		10/08/2013	17:18	10/08/2013	20:56	1	218	218	Overhead equipment				VI

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
132817125	S47575	10/08/2013	18:25	10/08/2013	20:22	1	117	117	Animal related	Fuse			VI
132817135	S47575	10/08/2013	18:31	10/08/2013	20:22	3	333	111	Animal related				VI
132817842	Y93002	10/08/2013	18:52	10/08/2013	19:20	1	28	28	Overhead equipment	Overhead Service	Repair	Replace - Same Size	IV
132817883	J86118	10/08/2013	19:18	10/08/2013	19:29	1	11	11	Overhead equipment				VI
132817909	M41112	10/08/2013	19:49	10/08/2013	21:20	1	91	91	Public	Overhead Service	Repair		I
132817938	E10001	10/08/2013	20:24	10/08/2013	21:38	1	74	74	Overhead equipment	Transformer Fuse	Replace - Same Size		III
132818038	J86118	10/08/2013	21:10	10/08/2013	21:40	1	30	30	Overhead equipment	Fuse	Replace - Same Size		VI
132818042		10/08/2013	21:20	10/09/2013	4:55	1	455	455	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
132818063	B00003	10/08/2013	22:08	10/08/2013	22:36	10	280	28	Unknown	Fuse	Replace - Same Size		I
132818086	B00003	10/08/2013	23:34	10/09/2013	1:22	10	1080	108	Tree related-tree broken	Fuse	Trim		I
132820001	J86118	10/08/2013	23:59	10/09/2013	3:36	1	217	217	Overhead equipment	Transformer Fuse	Replace - Same Size		VI
132820127	A56017	10/09/2013	0:53	10/09/2013	3:58	71	13135	185	Underground equipment	Underground Primary	Switch/Reset	Repair	I
132820134	B61001	10/09/2013	1:31	10/09/2013	5:50	1	259	259	Underground equipment	Underground Primary		Repair	I
132823818	A50001	10/09/2013	5:32	10/09/2013	10:16	7	1988	284	Underground equipment	Underground Connector	Repair	Repair	I
132823662	A50001	10/09/2013	5:33	10/09/2013	7:20	18	1926	107	Underground equipment	Underground Connector	Switch/Reset		I
132823716	HD0574	10/09/2013	6:58	10/09/2013	7:02	61	244	4	Overhead equipment				VI
132823730	M09143	10/09/2013	7:02	10/09/2013	8:02	1	60	60	Animal related	Fuse	Replace - Same Size	Repair	VI
132823758	F10001	10/09/2013	7:10	10/09/2013	9:13	1	123	123	Overhead equipment	Fuse	Replace - Same Size		III
132823876	R07382	10/09/2013	7:39	10/09/2013	12:43	12	3648	304	Underground equipment	Fuse	Replace - Same Size	Repair	I
132823904	L42158	10/09/2013	7:59	10/09/2013	8:59	1	60	60	Unknown	Fuse	Repair		III
132824003		10/09/2013	8:26	10/09/2013	10:14	1	108	108	Animal related	Transformer Fuse			II
132824161	J15303	10/09/2013	8:59	10/09/2013	10:09	1	70	70	Animal related	Transformer Fuse	Replace - Same Size		I
132824220	Y98561	10/09/2013	9:10	10/09/2013	10:13	1	63	63	Animal related	Animal Guard		Replace - Same Size	IV
132824473	Q80354	10/09/2013	9:43	10/09/2013	10:17	20	680	34	Overhead equipment				V
132824462	Q80354	10/09/2013	9:44	10/09/2013	10:17	367	12111	33	Overhead equipment				V
132824526	S86582	10/09/2013	9:50	10/09/2013	10:19	771	22359	29	Overhead equipment	Overhead Primary			VI
132824812	X02548	10/09/2013	9:59	10/09/2013	11:05	44	2904	66	Overhead equipment	Recloser			IV
132824953	K82202	10/09/2013	10:09	10/09/2013	11:10	57	3477	61	Overhead equipment	Fuse		Replace - Same Size	III
132824702	X96002	10/09/2013	10:23	10/09/2013	11:00	1	37	37	Overhead equipment	Transformer Fuse			IV
132824718	L43153	10/09/2013	10:24	10/09/2013	11:30	1	66	66	Overhead equipment	Transformer Fuse	Repair		I
132824774	Y55594	10/09/2013	10:33	10/09/2013	11:57	1	84	84	Animal related	Disconnect Switch	Replace - Same Size		IV
132824840	A50001	10/09/2013	10:37	10/09/2013	10:55	24	432	18	Overhead equipment	Fuse	Repair		I
132824859	B93003	10/09/2013	10:45	10/09/2013	12:10	1	85	85	Overhead equipment	Lightning Arrestor	Replace - Same Size		I
132825028	N05172	10/09/2013	10:53	10/09/2013	11:21	36	1008	28	Animal related	Fuse	Replace - Same Size		I
132824960	Q18243	10/09/2013	10:58	10/09/2013	12:37	1	99	99	Overhead equipment	Transformer Fuse	Replace - Same Size		VI
132825135	J13108	10/09/2013	11:05	10/09/2013	11:55	7	350	50	Public	Recloser	Patrol/Test/Inspect	Switch/Reset	I
132825013	Z06538	10/09/2013	11:08	10/09/2013	12:12	3	192	64	Animal related	Transformer Fuse	Replace - Same Size		IV
132825084	L23145	10/09/2013	11:22	10/09/2013	12:29	1	67	67	Tree related-tree contact	Overhead Service	Repair		III
132825160	T04512	10/09/2013	11:34	10/09/2013	12:18	1	44	44	Animal related	Fuse	Replace - Same Size		VI
132825175	351002	10/09/2013	11:36	10/09/2013	12:26	1	50	50	Tree related-tree broken	Tree	Cut in Clear		VI
132825304	P54828	10/09/2013	11:46	10/09/2013	12:32	10	460	46	Overhead equipment	Fuse	Replace - Same Size		V
132825276	M37192	10/09/2013	11:55	10/09/2013	13:32	1	97	97	Overhead equipment				I
132825280	X66582	10/09/2013	11:55	10/09/2013	13:16	5	405	81	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
132825354	N35852	10/09/2013	12:08	10/09/2013	18:30	1	382	382	Underground equipment	Underground Primary	Repair		V
132825383	B28004	10/09/2013	12:14	10/09/2013	12:51	23	851	37	Unknown	Fuse	Replace - Same Size		I
132825643	C10002	10/09/2013	13:03	10/09/2013	13:25	1	22	22	Overhead equipment	Fuse	Replace - Same Size	Repair	III
132825714	B84002	10/09/2013	13:18	10/09/2013	15:00	12	1224	102	Animal related	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	I
132825743	J86118	10/09/2013	13:23	10/09/2013	14:28	1	65	65	Overhead equipment	Connector	Repair		VI
132825740	R16511	10/09/2013	13:23	10/09/2013	13:44	15	315	21	Animal related	Transformer Fuse	Replace - Same Size		I
132825839	K62102	10/09/2013	13:30	10/09/2013	14:50	12	960	80	Underground equipment	Underground Primary	Switch/Reset	Repair	II
132825867	N67312	10/09/2013	13:48	10/09/2013	15:13	1	85	85	Overhead equipment	Connector	Replace - Same Size	Replace - Same Size	I
132825923	J18267	10/09/2013	13:56	10/09/2013	17:45	2	458	229	Overhead equipment	Overhead Transformer		Patrol/Test/Inspect	VI
132826187	U62510	10/09/2013	14:51	10/09/2013	16:20	1	89	89	Animal related	Animal Guard			II
132826199		10/09/2013	14:56	10/09/2013	16:34	1	98	98	Overhead equipment	Overhead Transformer		Replace - Same Size	IV
132826297	R66470	10/09/2013	15:11	10/09/2013	16:24	1	73	73	Overhead equipment	Tree	Remove	No Work Required	IV
132826327	T16526	10/09/2013	15:15	10/09/2013	21:00	26	8970	345	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	VI

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
132826330	B21004	10/09/2013	15:19	10/09/2013	16:26	1	67	67	Unknown	Transformer Fuse	Replace - Same Size		I
132826447	X69554	10/09/2013	15:51	10/09/2013	17:06	1	75	75	Animal related	Transformer Fuse			IV
132826466	J79306	10/09/2013	15:54	10/09/2013	16:55	1	61	61	Animal related	Transformer Fuse	Replace - Same Size	Replace - Same Size	I
132826679	Z04001	10/09/2013	17:11	10/09/2013	19:27	8	1088	136	Overhead equipment	Animal Guard		Replace - Same Size	IV
132826755	P18104	10/09/2013	17:33	10/09/2013	19:05	15	1380	92	Public	Overhead Primary	Repair		IV
132826881	B21004	10/09/2013	17:57	10/09/2013	21:15	24	4752	198	Underground equipment	Underground Primary			I
132826798	K71811	10/09/2013	18:07	10/09/2013	18:44	3	111	37	Animal related	Fuse	Replace - Same Size	No Work Required	IV
132826877	P57108	10/09/2013	20:03	10/09/2013	23:03	7	1260	180	Overhead equipment	Overhead Transformer		Replace - Same Size	VI
132827853		10/09/2013	20:16	10/09/2013	22:40	1	144	144	Substation equipment				II
132827833		10/09/2013	20:16	10/09/2013	21:26	481	33670	70	Substation equipment				II
132827788		10/09/2013	20:16	10/09/2013	22:34	426	58788	138	Substation equipment				II
132827776	M41111	10/09/2013	20:28	10/09/2013	22:00	1	92	92	Underground equipment	Underground Service	Patrol/Test/Inspect	Replace - Same Size	I
132827865	J63171	10/09/2013	22:35	10/10/2013	1:36	92	16652	181	Underground equipment	Underground Primary		Repair	III
132832009	D01002	10/10/2013	0:57	10/10/2013	1:50	3	159	53	Overhead equipment	Fuse	Replace - Same Size		I
132833472	B00003	10/10/2013	3:59	10/10/2013	4:45	10	460	46	Unknown	Transformer Fuse	Replace - Same Size	Replace - Same Size	I
132833480	B00003	10/10/2013	4:51	10/10/2013	8:07	10	1960	196	Overhead equipment	Overhead Secondary	Tie/Tighten	Repair	I
132833599	R33126	10/10/2013	7:31	10/10/2013	9:20	1	109	109	Public	Overhead Service	Repair	Patrol/Test/Inspect	I
132833605	R58951	10/10/2013	7:31	10/10/2013	8:24	31	1643	53	Animal related	Fuse	Replace - Same Size		IV
132833693	R10460	10/10/2013	7:40	10/10/2013	8:25	550	24750	45	Public				VI
132833657		10/10/2013	7:44	10/10/2013	8:30	1	46	46	Public	Crossarm	Replace - New Size	Repair	VI
132833717	R23334	10/10/2013	8:04	10/10/2013	12:20	1	256	256	Overhead equipment	Overhead Transformer		Replace - Same Size	V
132833721		10/10/2013	8:05	10/11/2013	8:13	1	1448	1448	Public				VI
132833757	Q27185	10/10/2013	8:13	10/10/2013	13:17	1	304	304	Overhead equipment	Overhead Transformer		Replace - Same Size	VI
132833811	Y54587	10/10/2013	8:29	10/10/2013	9:20	17	867	51	Animal related	Transformer Fuse	Replace - Same Size		IV
132833949	J39392	10/10/2013	8:39	10/10/2013	9:09	4	120	30	Overhead equipment	Fuse		Replace - Same Size	III
132833890	S49549	10/10/2013	8:45	10/10/2013	10:59	1	134	134	Overhead equipment	Connector			VI
132833955	M21134	10/10/2013	8:55	10/10/2013	9:44	1	49	49	Animal related	Fuse	Repair	Repair	VI
132834202	N54108	10/10/2013	9:44	10/10/2013	10:46	1	62	62	Weather	Transformer Fuse	Replace - Same Size		II
132834209	Q27185	10/10/2013	9:45	10/10/2013	10:31	1	46	46	Animal related	Fuse	Replace - Same Size		VI
132834244	L73156	10/10/2013	9:54	10/10/2013	11:01	1	67	67	Overhead equipment	Transformer Fuse	Replace - Same Size	Replace - Same Size	IV
132834353	J47176	10/10/2013	10:11	10/10/2013	13:20	1	189	189	Tree related-tree contact	Overhead Service			III
132834401	Q64919	10/10/2013	10:19	10/10/2013	11:20	1	61	61	Overhead equipment	Fuse	Replace - Same Size		VI
132834403	B00003	10/10/2013	10:19	10/10/2013	14:30	10	2510	251	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Repair	I
132834415	J58380	10/10/2013	10:21	10/10/2013	11:29	1	68	68	Overhead equipment	Fuse		Replace - Same Size	III
132835017	L73155	10/10/2013	12:08	10/10/2013	13:29	1	81	81	Tree related-tree contact	Overhead Service	Repair	Repair	IV
132835395		10/10/2013	13:32	10/10/2013	15:25	1	113	113	Jurisdictional				V
132835937	307001	10/10/2013	14:40	10/10/2013	17:56	110	21560	196	Public	Crossarm	Repair	Replace - New Size	VI
132835820	307001	10/10/2013	14:40	10/10/2013	15:18	496	18848	38	Public	Crossarm	Switch/Reset		VI
132836100	B58001	10/10/2013	15:49	10/10/2013	17:40	5	555	111	Animal related	Transformer Fuse	Replace - Same Size		I
132836295	N54214	10/10/2013	16:38	10/10/2013	17:48	51	3570	70	Animal related	Fuse	Replace - Same Size		II
132836304	U02597	10/10/2013	16:47	10/10/2013	18:45	1	118	118	Overhead equipment	Tree	Trim	Patrol/Test/Inspect	II
132836375	C52001	10/10/2013	17:05	10/10/2013	17:57	33	1716	52	Overhead equipment	Fuse	Replace - Same Size	No Work Required	III
132836411	L93149	10/10/2013	17:17	10/10/2013	18:32	18	1350	75	Underground equipment	Underground Primary	Switch/Reset	Repair	VI
132836404	L59929	10/10/2013	17:27	10/10/2013	17:56	1	29	29	Animal related	Fuse	Replace - Same Size		VI
132837441	A45002	10/10/2013	17:59	10/11/2013	0:01	9	3258	362	Underground equipment	Underground Primary	Repair	Repair	I
132836562	Y60593	10/10/2013	18:30	10/10/2013	20:10	1	100	100	Animal related	Animal Guard	Install		IV
132836601	R99180	10/10/2013	18:46	10/10/2013	20:45	1	119	119	Animal related	Disconnect Switch	Replace - Same Size	Replace - Same Size	IV
132837410	S25552	10/10/2013	19:53	10/10/2013	21:00	9	603	67	Overhead equipment	Other	Patrol/Test/Inspect	Repair	VI
132837429	B68002	10/10/2013	20:24	10/11/2013	4:10	2	932	466	Underground equipment	Underground Primary	Repair		III
132837658	L24123	10/10/2013	21:42	10/11/2013	3:30	6	2088	348	Tree related-tree broken	Overhead Primary	Repair		III
132837646	P77233	10/10/2013	21:51	10/10/2013	22:31	1	40	40	Overhead equipment	Transformer Fuse	Replace - Same Size		VI
132837649	L24123	10/10/2013	22:11	10/10/2013	22:40	51	1479	29	Tree related-tree broken				III
132843010	D96001	10/11/2013	1:42	10/11/2013	6:58	5	1580	316	Underground equipment	Underground Primary	Repair		I
132841458	D96001	10/11/2013	1:42	10/11/2013	3:03	4	324	81	Underground equipment	Underground Primary	Switch/Reset		I
132843023	HA5430	10/11/2013	3:24	10/11/2013	5:00	10	960	96	Underground equipment				V
132843005	HA5430	10/11/2013	3:26	10/11/2013	6:30	47	8648	184	Underground equipment				V

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
132843009	M36189	10/11/2013	3:27	10/11/2013	7:55	70	18760	268	Underground equipment	Underground Primary	Repair	Repair	I
132843007	HA5430	10/11/2013	3:28	10/11/2013	5:22	8	912	114	Underground equipment				V
132843036	K46388	10/11/2013	6:00	10/11/2013	7:58	17	2006	118	Underground equipment				V
132843048	D89002	10/11/2013	6:08	10/11/2013	10:21	24	6072	253	Underground equipment				I
132843065	Q83172	10/11/2013	6:57	10/11/2013	7:35	1	38	38	Animal related	Fuse	Repair	Repair	VI
132843095	Q16867	10/11/2013	7:10	10/11/2013	9:25	66	8910	135	Animal related	Fuse	Replace - Same Size		V
132843144	X02548	10/11/2013	7:25	10/11/2013	8:29	1	64	64	Animal related	Fuse	Replace - Same Size		IV
132843323	B21004	10/11/2013	8:37	10/11/2013	11:05	34	5032	148	Public	Overhead Primary	Raise		I
132843369	Z17503	10/11/2013	8:45	10/11/2013	9:40	5	275	55	Animal related	Transformer Fuse	Replace - Same Size		IV
132843372	P07179	10/11/2013	8:47	10/11/2013	10:38	1	111	111	Weather	Fuse	Replace - Same Size	Patrol/Test/Inspect	I
132843555	K76547	10/11/2013	9:23	10/11/2013	9:53	1	30	30	Animal related	Transformer Fuse	Replace - Same Size	No Work Required	IV
132843635	B80002	10/11/2013	9:45	10/11/2013	11:11	1	86	86	Animal related	Fuse	Patrol/Test/Inspect	Replace - Same Size	I
132843778	D89003	10/11/2013	10:16	10/11/2013	11:44	10	880	88	Animal related	Fuse	Replace - Same Size		I
132844019	B00008	10/11/2013	11:11	10/11/2013	11:47	7	252	36	Tree related-tree broken	Other			I
132844031	P83705	10/11/2013	11:14	10/11/2013	12:26	1	72	72	Animal related	Fuse	Replace - Same Size		I
132844191	M41111	10/11/2013	11:49	10/11/2013	14:00	28	3668	131	Underground equipment	Underground Primary	Repair	Repair	I
132844224	Q32170	10/11/2013	11:56	10/11/2013	13:55	97	11543	119	Animal related	Fuse	Replace - Same Size	Patrol/Test/Inspect	I
132844384	L12125	10/11/2013	12:55	10/11/2013	14:23	1	88	88	Tree related-tree broken	Overhead Primary	Repair		III
132844846	U99515	10/11/2013	13:57	10/11/2013	15:20	46	3818	83	Overhead equipment	Recloser	Switch/Reset		II
132844684	L70128	10/11/2013	14:07	10/11/2013	16:50	1	163	163	Animal related	Fuse	Replace - Same Size		IV
132844823	Q16867	10/11/2013	14:50	10/11/2013	15:50	1	60	60	Animal related	Fuse	Replace - Same Size		V
132845383	Q93522	10/11/2013	15:14	10/11/2013	20:18	2	608	304	Public	Overhead Transformer	Repair		I
132844895	Q93522	10/11/2013	15:14	10/11/2013	19:00	248	56048	226	Public	Overhead Primary	Patrol/Test/Inspect	Repair	I
132844943	N44216	10/11/2013	15:27	10/11/2013	19:04	1	217	217	Overhead equipment	Overhead Transformer			III
132844952	M81404	10/11/2013	15:30	10/11/2013	16:20	1	50	50	Animal related	Fuse	Repair		V
132844966	L99392	10/11/2013	15:35	10/11/2013	16:55	1	80	80	Animal related	Fuse			V
132845011	329148	10/11/2013	15:49	10/11/2013	15:53	1	4	4	Overhead equipment	Overhead Service	Replace - Same Size		V
132845021	B76003	10/11/2013	15:51	10/11/2013	17:08	1	77	77	Animal related	Transformer Fuse	Replace - Same Size		I
132845049	N35851	10/11/2013	15:55	10/11/2013	17:05	3	210	70	Public	Fuse	Patrol/Test/Inspect		V
132845071	A80001	10/11/2013	16:11	10/11/2013	17:17	1	66	66	Overhead equipment	Disconnect Switch	Replace - Same Size	Replace - Same Size	I
132845134	N35851	10/11/2013	16:15	10/11/2013	16:55	14	560	40	Public	Fuse	Patrol/Test/Inspect		V
132845161	T23528	10/11/2013	16:56	10/11/2013	17:56	2	120	60	Tree related-tree broken	Overhead Secondary	Repair	Repair	VI
132845183	N35851	10/11/2013	17:10	10/11/2013	17:27	1	17	17	Public	Meter	Patrol/Test/Inspect		V
132845251	Y37592	10/11/2013	18:07	10/11/2013	18:37	6	180	30	Animal related	Transformer Fuse	Replace - Same Size		IV
132845258	K67912	10/11/2013	18:10	10/11/2013	19:19	1	69	69	Overhead equipment	Fuse		Patrol/Test/Inspect	VI
132845382	S62521	10/11/2013	18:46	10/11/2013	19:50	1	64	64	Overhead equipment	Overhead Service	Repair		VI
132846052	R28870	10/11/2013	19:18	10/11/2013	20:40	1	82	82	Jurisdictional	Overhead Service	No Work Required	No Work Required	V
132846078	U14528	10/11/2013	20:02	10/11/2013	21:17	1	75	75	Overhead equipment	Transformer Fuse	Replace - Same Size		II
132846089	L95110	10/11/2013	20:39	10/11/2013	22:34	1	115	115	Public	Overhead Service	Repair		III
132846124	J12166	10/11/2013	22:29	10/11/2013	23:28	1	59	59	Unknown	Fuse	Replace - Same Size		III
132846128	D36001	10/11/2013	22:41	10/12/2013	5:30	1	409	409	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
132850049	R93350	10/12/2013	4:58	10/12/2013	6:46	6	648	108	Unknown	Fuse			V
132850043	T23527	10/12/2013	5:46	10/12/2013	7:25	1	99	99	Overhead equipment	Overhead Service	Patrol/Test/Inspect	Repair	VI
132850077	M26164	10/12/2013	7:17	10/12/2013	8:27	1	70	70	Overhead equipment	Overhead Transformer	Repair		III
132850094	B93003	10/12/2013	7:18	10/12/2013	17:30	12	7344	612	Underground equipment	Underground Primary	Patrol/Test/Inspect	Reconnect	I
132850083	C00001	10/12/2013	7:20	10/12/2013	14:23	1	423	423	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
132850104	Z18553	10/12/2013	7:42	10/12/2013	8:35	1	53	53	Animal related	Transformer Fuse	Replace - Same Size		IV
132850118	342004	10/12/2013	7:45	10/12/2013	9:15	21	1890	90	Overhead equipment	Overhead Transformer		Install	VI
132850110	S09520	10/12/2013	7:46	10/12/2013	8:30	1	44	44	Overhead equipment			Replace - New Size	VI
132850103	308003	10/12/2013	7:50	10/12/2013	16:19	7	3563	509	Public	Pole	Patrol/Test/Inspect	Replace - Same Size	VI
132850129	U02597	10/12/2013	8:10	10/12/2013	11:13	1	183	183	Overhead equipment	Fuse	Replace - Same Size		II
132850390	Q95249	10/12/2013	8:12	10/12/2013	12:37	289	76585	265	Overhead equipment	Overhead Primary	Patrol/Test/Inspect	Repair	VI
132850154	Q95249	10/12/2013	8:14	10/12/2013	10:26	520	68640	132	Overhead equipment	Overhead Primary	Patrol/Test/Inspect	Repair	VI
132850162	P20930	10/12/2013	8:23	10/12/2013	10:00	1	97	97	Weather	Fuse	Replace - Same Size		VI
132850167	N22295	10/12/2013	8:25	10/12/2013	11:31	1	186	186	Overhead equipment	Disconnect Switch	Replace - Same Size		VI
132850179	B77003	10/12/2013	8:31	10/12/2013	8:55	5	120	24	Weather	Transformer Fuse	Replace - Same Size	Replace - Same Size	I

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
132850180	S28552	10/12/2013	8:37	10/12/2013	9:15	1	38	38	Animal related	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
132850200	L17102	10/12/2013	8:50	10/12/2013	11:29	53	8427	159	Overhead equipment	Fuse	Replace - Same Size		III
132850239	D72001	10/12/2013	9:24	10/12/2013	10:35	6	426	71	Weather	Transformer Fuse	Replace - Same Size	Replace - Same Size	I
132850241	Y37009	10/12/2013	9:27	10/12/2013	10:39	1	72	72	Overhead equipment	Overhead Service	Repair		IV
132850249	Y35515	10/12/2013	9:31	10/12/2013	10:10	1	39	39	Animal related	Transformer Fuse	Replace - Same Size		IV
132850262	P20930	10/12/2013	9:45	10/12/2013	10:44	6	354	59	Animal related	Fuse	Replace - Same Size		VI
132850261	S86582	10/12/2013	9:45	10/12/2013	10:27	1	42	42	Animal related	Fuse	Replace - Same Size		VI
132850266	P39298	10/12/2013	9:47	10/12/2013	12:13	7	1022	146	Animal related	Fuse	Replace - Same Size	Patrol/Test/Inspect	VI
132850282	J99151	10/12/2013	10:06	10/12/2013	11:56	1	110	110	Animal related	Transformer Fuse	Replace - Same Size		VI
132850373	K57212	10/12/2013	10:25	10/12/2013	12:31	1	126	126	Underground equipment	Underground Secondary	Repair		VI
132850380	D36002	10/12/2013	10:32	10/12/2013	10:57	1	25	25	Animal related	Fuse	Repair	Replace - Same Size	I
132850443	R60552	10/12/2013	10:35	10/12/2013	13:20	4	660	165	Animal related	Overhead Transformer		Repair	IV
132850388	R60552	10/12/2013	10:35	10/12/2013	11:34	34	2006	59	Animal related	Fuse	Replace - Same Size		IV
132850389	X75512	10/12/2013	10:38	10/12/2013	12:03	3	255	85	Animal related	Transformer Fuse	Repair		IV
132850417	B21002	10/12/2013	11:00	10/12/2013	12:49	1	109	109	Overhead equipment	Fuse	Replace - Same Size		I
132850430	K27150	10/12/2013	11:09	10/12/2013	12:52	14	1442	103	Animal related	Fuse	Replace - Same Size	No Work Required	VI
132850440	P26283	10/12/2013	11:29	10/12/2013	12:55	1	86	86	Weather	Fuse	Patrol/Test/Inspect		I
132850444	V45526	10/12/2013	11:37	10/12/2013	14:15	11	1738	158	Overhead equipment	Lightning Arrestor	Replace - Same Size	Replace - Same Size	II
132850453	V23530	10/12/2013	11:50	10/12/2013	18:25	1	395	395	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	II
132850462	Y54591	10/12/2013	11:59	10/12/2013	15:20	1	201	201	Tree related-tree contact	Overhead Service	Repair		IV
132850466	V69558	10/12/2013	12:05	10/12/2013	13:00	1	55	55	Animal related	Fuse	Replace - Same Size		II
132850545	Q95249	10/12/2013	13:15	10/12/2013	15:22	1	127	127	Overhead equipment	Overhead Service	Repair		VI
132850567	N70330	10/12/2013	13:31	10/12/2013	15:35	1	124	124	Unknown	Fuse	Replace - Same Size		I
132850598	U84566	10/12/2013	14:26	10/12/2013	16:02	2	192	96	Animal related	Transformer Fuse	Replace - Same Size		II
132850619	V80002	10/12/2013	14:57	10/12/2013	16:55	1	118	118	Overhead equipment	Connector	Repair		II
132850632	C30002	10/12/2013	15:29	10/12/2013	17:31	1	122	122	Overhead equipment	Disconnect Switch	Patrol/Test/Inspect	Patrol/Test/Inspect	III
132850631	R02121	10/12/2013	15:29	10/12/2013	17:11	1	102	102	Overhead equipment	Connector	Repair	No Work Required	VI
132850638	Y97513	10/12/2013	15:45	10/12/2013	17:30	1	105	105	Overhead equipment	Overhead Secondary	Repair	Repair	IV
132850645	N50331	10/12/2013	16:18	10/12/2013	18:13	1	115	115	Underground equipment	Underground Service			II
132850648	Q18242	10/12/2013	16:20	10/12/2013	16:57	9	333	37	Animal related	Fuse	Replace - Same Size		VI
132850659	M37191	10/12/2013	16:35	10/12/2013	18:25	1	110	110	Animal related	Fuse	Repair	Replace - Same Size	I
132850661	C10002	10/12/2013	16:37	10/12/2013	18:00	1	83	83	Animal related	Transformer Fuse	Patrol/Test/Inspect	Patrol/Test/Inspect	III
132850676	L93132	10/12/2013	16:43	10/12/2013	18:00	241	18557	77	Animal related	Fuse	Replace - Same Size		VI
132850696	M30301	10/12/2013	16:45	10/12/2013	17:48	18	1134	63	Animal related	Fuse			VI
132850698	M30301	10/12/2013	17:01	10/12/2013	17:51	4	200	50	Animal related	Fuse			VI
132850705	S88502	10/12/2013	17:08	10/12/2013	18:29	29	2349	81	Overhead equipment	Fuse	Repair	Replace - Same Size	VI
132850673	K94223	10/12/2013	17:48	10/13/2013	8:17	25	21725	869	Public	Pole		Repair	III
132850789	B19002	10/12/2013	18:33	10/13/2013	0:35	2	724	362	Underground equipment	Underground Primary	Replace - Same Size	Replace - Same Size	I
132850739	S88502	10/12/2013	18:50	10/12/2013	19:02	6	72	12	Overhead equipment	Fuse	Repair	Replace - Same Size	VI
132850744	M22812	10/12/2013	18:54	10/12/2013	20:12	1	78	78	Overhead equipment	Transformer Fuse	Replace - Same Size		V
132850760	D35002	10/12/2013	19:33	10/12/2013	20:59	1	86	86	Weather	Transformer Fuse	Replace - Same Size	Replace - Same Size	I
132850780	S64502	10/12/2013	20:21	10/12/2013	23:00	15	2385	159	Underground equipment	Underground Primary	Repair	Repair	VI
132850778	S64502	10/12/2013	20:29	10/12/2013	23:00	9	1359	151	Underground equipment				VI
132860008	Q10703	10/12/2013	20:39	10/13/2013	4:21	4	1848	462	Overhead equipment	Pole	Replace - New Size	Replace - New Size	V
132850791	Q10703	10/12/2013	20:39	10/13/2013	2:40	38	13718	361	Public	Pole	Repair		V
132850812	X69554	10/12/2013	22:18	10/12/2013	23:24	1	66	66	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
132850818	K74162	10/12/2013	22:39	10/12/2013	23:43	1	64	64	Animal related	Fuse	Replace - Same Size	No Work Required	IV
132850823	B76003	10/12/2013	22:53	10/13/2013	1:08	32	4320	135	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
132860005	J89125	10/13/2013	1:07	10/13/2013	2:41	6	564	94	Overhead equipment	Fuse			VI
132860021		10/13/2013	5:35	10/13/2013	10:15	1	280	280	Animal related	Fuse	Replace - Same Size		II
132860028	L12127	10/13/2013	5:58	10/13/2013	8:08	31	4030	130	Underground equipment	Underground Primary		Repair	III
132860086	L93135	10/13/2013	7:35	10/13/2013	8:07	48	1536	32	Animal related	Fuse			VI
132860087	X72535	10/13/2013	7:53	10/13/2013	8:40	1	47	47	Animal related	Animal Guard	Install		IV
132860091	B08004	10/13/2013	8:02	10/13/2013	8:31	18	522	29	Unknown	Transformer Fuse	Replace - Same Size	Replace - Same Size	I
132860117	P53341	10/13/2013	8:13	10/13/2013	9:40	25	2175	87	Animal related	Fuse	Replace - Same Size		IV
132860106	341002	10/13/2013	8:24	10/13/2013	9:25	1	61	61	Overhead equipment	Overhead Transformer	Repair		VI

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
132860115	C70004	10/13/2013	8:35	10/13/2013	9:44	1	69	69	Animal related	Fuse	Replace - Same Size		III
132860124	K43385	10/13/2013	8:47	10/13/2013	10:04	33	2541	77	Animal related	Fuse	Replace - Same Size	Replace - Same Size	V
132860133	L50214	10/13/2013	8:56	10/13/2013	10:20	1	84	84	Animal related	Transformer Fuse			VI
132860170	Q83171	10/13/2013	8:58	10/13/2013	10:29	6	546	91	Animal related	Underground Primary	Repair	No Work Required	VI
132860137	L17101	10/13/2013	9:01	10/13/2013	11:15	5	670	134	Animal related	Fuse	Replace - Same Size		III
132860136	Q64919	10/13/2013	9:01	10/13/2013	9:55	1	54	54	Animal related	Fuse	Replace - Same Size		VI
132860163	S42579	10/13/2013	9:09	10/13/2013	10:12	13	819	63	Animal related	Fuse	Replace - Same Size	No Work Required	VI
132860155		10/13/2013	9:13	10/13/2013	9:21	1	8	8	Public	Overhead Primary			III
132860189	M09175	10/13/2013	9:13	10/13/2013	10:52	4	396	99	Animal related	Fuse			VI
132860157		10/13/2013	9:14	10/13/2013	9:21	1	7	7	Public				III
132860159	A45001	10/13/2013	9:15	10/13/2013	10:02	1	47	47	Overhead equipment	Connector	Replace - Same Size	Replace - Same Size	I
132860223	R58951	10/13/2013	9:15	10/13/2013	13:30	10	2550	255	Animal related	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	IV
132860166	R58951	10/13/2013	9:18	10/13/2013	10:15	23	1311	57	Animal related	Fuse	Replace - Same Size	No Work Required	IV
132860188	V92542	10/13/2013	9:50	10/13/2013	10:55	1	65	65	Animal related	Lightning Arrestor	Replace - Same Size	Patrol/Test/Inspect	II
132860190	P77235	10/13/2013	9:54	10/13/2013	11:17	1	83	83	Animal related	Transformer Fuse			VI
132860205	L35139	10/13/2013	10:07	10/13/2013	10:52	43	1935	45	Animal related	Fuse	Replace - Same Size		III
132860218	S49550	10/13/2013	10:29	10/13/2013	14:00	15	3165	211	Public	Underground Primary	Repair	Repair	VI
132860227	B10001	10/13/2013	11:01	10/13/2013	14:11	1	190	190	Tree related-tree broken	Overhead Secondary	Cut in Clear		I
132860239	P62113	10/13/2013	11:24	10/13/2013	14:27	3	549	183	Tree related-tree broken	Overhead Primary		Raise	VI
132860242	N67309	10/13/2013	11:28	10/13/2013	12:36	1	68	68	Unknown	Fuse	Replace - Same Size		I
132860247	J08207	10/13/2013	11:48	10/13/2013	13:17	1	89	89	Animal related	Fuse	Replace - Same Size		I
132860267	U16500	10/13/2013	12:08	10/13/2013	13:15	4	268	67	Animal related	Transformer Fuse	Replace - Same Size		II
132860281	K30204	10/13/2013	12:36	10/13/2013	14:40	1	124	124	Overhead equipment	Transformer Fuse		Replace - Same Size	III
132860290	Y26520	10/13/2013	12:41	10/13/2013	14:15	3	282	94	Overhead equipment	Fuse	Replace - Same Size		IV
132860291		10/13/2013	12:44	10/13/2013	14:09	1	85	85	Overhead equipment	Transformer Fuse	Replace - Same Size	No Work Required	IV
132860299	M48815	10/13/2013	12:56	10/13/2013	13:30	1	34	34	Overhead equipment	Overhead Service			V
132860370	Q32171	10/13/2013	13:09	10/13/2013	16:30	1	201	201	Overhead equipment	Overhead Transformer	Replace - Same Size	Patrol/Test/Inspect	I
132860354	R73841	10/13/2013	13:17	10/13/2013	14:34	1	77	77	Animal related	Transformer Fuse	Replace - Same Size	No Work Required	V
132860427	B84003	10/13/2013	15:50	10/13/2013	20:30	1	280	280	Animal related	Overhead Primary	Replace - Same Size		I
132860404	B84003	10/13/2013	15:54	10/13/2013	16:46	548	28496	52	Animal related	Overhead Primary	Switch/Reset		I
132860414	U09557	10/13/2013	16:08	10/13/2013	18:33	1	145	145	Animal related	Transformer Fuse	Replace - Same Size		II
132860434	Q18242	10/13/2013	16:22	10/13/2013	21:45	9	2907	323	Animal related	Underground Primary		Replace - Same Size	VI
132860423	R60551	10/13/2013	16:39	10/13/2013	18:55	49	6664	136	Underground equipment				IV
132860449	L71171	10/13/2013	17:28	10/13/2013	18:12	1	44	44	Animal related	Transformer Fuse	Replace - Same Size	No Work Required	IV
132860456	J80807	10/13/2013	17:42	10/13/2013	19:15	1	93	93	Tree related-tree broken	Overhead Service			V
132860468	P82291	10/13/2013	18:06	10/13/2013	19:50	1	104	104	Jurisdictional	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
132860500	L86176	10/13/2013	19:17	10/13/2013	19:44	1	27	27	Animal related	Transformer Fuse	Replace - Same Size	No Work Required	IV
132860505	H06135	10/13/2013	19:30	10/13/2013	20:29	1	59	59	Animal related	Transformer Fuse	Replace - Same Size	No Work Required	IV
132860543	N35851	10/13/2013	21:05	10/14/2013	0:46	3	663	221	Overhead equipment	Pole	Repair	Repair	V
132860536	P12290	10/13/2013	21:12	10/13/2013	22:50	8	784	98	Animal related	Fuse			V
132860532	T05540	10/13/2013	21:18	10/13/2013	21:33	1	15	15	Overhead equipment				VI
132860545	Q32170	10/13/2013	22:17	10/13/2013	23:05	1	48	48	Overhead equipment	Transformer Fuse	Replace - Same Size	Patrol/Test/Inspect	I
132860550	S61531	10/13/2013	22:36	10/13/2013	23:20	1	44	44	Overhead equipment	Disconnect Switch			VI
132873728	Q82907	10/14/2013	3:27	10/14/2013	4:44	1	77	77	Animal related	Fuse	Replace - Same Size	Replace - Same Size	VI
132873731	K80381	10/14/2013	4:42	10/14/2013	6:19	20	1940	97	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	IV
132873903	V76526	10/14/2013	7:57	10/14/2013	9:50	1	113	113	Overhead equipment	Fuse	Replace - Same Size		II
132873917	S93504	10/14/2013	8:02	10/14/2013	9:05	1	63	63	Animal related	Disconnect Switch	Replace - Same Size	Advise Customer	VI
132873923	Q80354	10/14/2013	8:03	10/14/2013	9:04	1	61	61	Animal related	Fuse	Replace - Same Size		V
132873974	L99392	10/14/2013	8:16	10/14/2013	8:51	1	35	35	Animal related	Fuse	Replace - Same Size	Replace - Same Size	V
132873976	346004	10/14/2013	8:16	10/14/2013	9:20	1	64	64	Public	Other			VI
132874002	R99180	10/14/2013	8:22	10/14/2013	9:45	1	83	83	Underground equipment	Underground Primary	Switch/Reset	Replace - Same Size	IV
132874074	M05360	10/14/2013	8:42	10/14/2013	9:35	1	53	53	Animal related	Fuse	Replace - Same Size		V
132874076	K09863	10/14/2013	8:43	10/14/2013	10:02	1	79	79	Animal related	Transformer Fuse	Replace - Same Size	Repair	V
132874179	K11376	10/14/2013	8:55	10/14/2013	10:05	3	210	70	Animal related	Fuse	Replace - Same Size	Replace - Same Size	V
132874181	J83140	10/14/2013	8:55	10/14/2013	9:41	5	230	46	Animal related	Fuse	Replace - Same Size		VI
132874246	R10903	10/14/2013	9:04	10/14/2013	13:05	1	241	241	Overhead equipment	Overhead Transformer		Replace - New Size	VI

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
132874740	310122	10/14/2013	9:07	10/14/2013	10:48	26	2626	101	Jurisdictional	Underground Primary			V
132874293	J85160	10/14/2013	9:14	10/14/2013	10:13	1	59	59	Overhead equipment	Transformer Fuse	Repair	Repair	VI
132874321	R93351	10/14/2013	9:18	10/14/2013	10:06	1	48	48	Other	Meter	Reconnect	Advise Customer	V
132874405	A85001	10/14/2013	9:28	10/14/2013	13:26	9	2142	238	Overhead equipment	Overhead Primary	Repair	Repair	I
132874394	R33127	10/14/2013	9:30	10/14/2013	11:02	1	92	92	Underground equipment	Underground Primary	Patrol/Test/Inspect	Patrol/Test/Inspect	I
132874404	D81001	10/14/2013	9:31	10/14/2013	10:27	69	3864	56	Animal related	Fuse	Replace - Same Size		I
132874452	J14140	10/14/2013	9:42	10/14/2013	10:22	1	40	40	Animal related	Fuse	Replace - Same Size		VI
132874459	T06503	10/14/2013	9:43	10/14/2013	10:35	1	52	52	Animal related	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
132874489	B28006	10/14/2013	9:48	10/14/2013	11:14	1	86	86	Overhead equipment	Fuse	Repair	Replace - Same Size	I
132875098	F10001	10/14/2013	10:21	10/14/2013	12:05	1	104	104	Overhead equipment	Overhead Primary	Repair		III
132874653	B00003	10/14/2013	10:21	10/14/2013	10:31	10	100	10	Animal related	Animal Guard	No Work Required		I
132874671	F10001	10/14/2013	10:21	10/14/2013	11:26	10	650	65	Overhead equipment	Overhead Primary			III
132874768	D41003	10/14/2013	10:28	10/14/2013	13:10	129	20898	162	Overhead equipment	Overhead Primary	Repair	Repair	I
132875077	307002	10/14/2013	11:34	10/14/2013	13:10	1	96	96	Tree related-tree broken	Overhead Service	Repair		VI
132875225	P49187	10/14/2013	11:57	10/14/2013	12:48	6	306	51	Animal related	Fuse	Replace - Same Size		I
132875373	Y98561	10/14/2013	12:12	10/14/2013	16:03	119	27489	231	Underground equipment	Underground Primary	Repair		IV
132875307	J80806	10/14/2013	12:19	10/14/2013	12:56	1	37	37	Animal related	Transformer Fuse	Replace - Same Size		V
132875554	B73002	10/14/2013	13:02	10/14/2013	13:13	36	396	11	Overhead equipment	Overhead Primary			I
132875614		10/14/2013	13:20	10/14/2013	14:19	1	59	59	Animal related				I
132875688	B61001	10/14/2013	13:23	10/14/2013	14:12	20	980	49	Animal related	Fuse	Replace - Same Size	No Work Required	I
132875698	L81141	10/14/2013	13:28	10/14/2013	14:15	24	1128	47	Animal related	Fuse	Repair		IV
132875845	A49001	10/14/2013	14:00	10/14/2013	18:00	1	240	240	Overhead equipment	Overhead Transformer	Repair	Replace - Same Size	I
132875862	S25552	10/14/2013	14:04	10/14/2013	14:49	2	90	45	Animal related	Transformer Fuse	Repair	Repair	VI
132876038	K07322	10/14/2013	14:44	10/14/2013	17:06	1	142	142	Overhead equipment	Overhead Transformer			I
132876067	N44217	10/14/2013	14:49	10/14/2013	17:56	6	1122	187	Overhead equipment	Overhead Transformer			III
132876108	L93132	10/14/2013	14:58	10/14/2013	15:22	1	24	24	Animal related	Fuse			VI
132876127	Q64919	10/14/2013	15:03	10/14/2013	15:48	1	45	45	Animal related	Transformer Fuse	Repair	No Work Required	VI
132876156	C52002	10/14/2013	15:10	10/14/2013	15:50	1	40	40	Overhead equipment	Fuse	Replace - Same Size		III
132876202	Q23255	10/14/2013	15:21	10/14/2013	16:00	1	39	39	Animal related	Transformer Fuse			VI
132876223	Q34360	10/14/2013	15:22	10/14/2013	15:55	31	1023	33	Animal related	Fuse	Replace - Same Size	Repair	I
132876323	M26164	10/14/2013	15:56	10/14/2013	16:25	1	29	29	Animal related	Transformer Fuse	Replace - Same Size		III
132876437	P26284	10/14/2013	16:34	10/14/2013	22:45	9	3339	371	Overhead equipment	Pole	Replace - Same Size	Replace - Same Size	I
132876463	J80807	10/14/2013	16:44	10/14/2013	18:17	1	93	93	Tree related-tree broken	Overhead Service	Repair	Repair	V
132876531	S42579	10/14/2013	17:15	10/14/2013	18:06	1	51	51	Animal related	Transformer Fuse	Replace - Same Size	Replace - Same Size	VI
132876601	R06212	10/14/2013	17:57	10/14/2013	19:40	31	3193	103	Animal related	Fuse	Replace - Same Size		II
132876602	M54292	10/14/2013	17:59	10/14/2013	18:56	13	741	57	Animal related	Transformer Fuse	Repair		V
132876606	D88002	10/14/2013	18:01	10/14/2013	19:29	1	88	88	Overhead equipment				I
132876612	J99128	10/14/2013	18:05	10/14/2013	18:45	3	120	40	Animal related	Transformer Fuse			VI
132876616	K08909	10/14/2013	18:08	10/14/2013	19:00	1	52	52	Public	Overhead Service	Cut in Clear		VI
132876617	R06212	10/14/2013	18:09	10/14/2013	19:44	1	95	95	Animal related	Fuse	Switch/Reset		II
132876645	R28870	10/14/2013	18:21	10/14/2013	19:46	1	85	85	Overhead equipment	Overhead Service	Tie/Tighten	Tie/Tighten	V
132877586	Y51505	10/14/2013	19:26	10/14/2013	20:14	1	48	48	Unknown	Transformer Fuse			IV
132877671	J86118	10/14/2013	20:10	10/15/2013	0:25	5	1275	255	Overhead equipment	Overhead Transformer		Replace - Same Size	VI
132877679	N05170	10/14/2013	21:20	10/14/2013	22:36	1	76	76	Weather	Fuse	Replace - Same Size		I
132877682	D87001	10/14/2013	21:29	10/14/2013	22:18	1	49	49	Overhead equipment				I
132877685	D35003	10/14/2013	21:41	10/15/2013	4:28	1	407	407	Underground equipment	Underground Primary		Repair	I
132880112	V04716	10/14/2013	22:44	10/15/2013	1:25	1123	180803	161	Animal related				II
132877789	V49008	10/14/2013	23:52	10/15/2013	0:40	1	48	48	Overhead equipment	Overhead Service	Repair	Repair	II
132883693	P18104	10/15/2013	3:58	10/15/2013	9:12	6	1884	314	Underground equipment	Underground Primary		Replace - Same Size	IV
132883631	X75571	10/15/2013	4:09	10/15/2013	9:50	1	341	341	Underground equipment	Underground Primary	Repair	Repair	IV
132883647	V31001	10/15/2013	5:31	10/15/2013	7:46	1	135	135	Tree related-tree contact	Overhead Service	Repair	Repair	II
132883663	Q32171	10/15/2013	5:46	10/15/2013	8:50	48	8832	184	Tree related-tree broken	Fuse	Replace - Same Size	Patrol/Test/Inspect	I
132883665	X69555	10/15/2013	5:55	10/15/2013	7:40	1	105	105	Animal related	Transformer Fuse			IV
132883708	Q32170	10/15/2013	6:44	10/15/2013	9:45	1	181	181	Tree related-tree contact	Overhead Service	Repair		I
132884108	B84006	10/15/2013	7:00	10/15/2013	14:17	6	2622	437	Underground equipment	Underground Primary	Patrol/Test/Inspect	Replace - Urgent	I
132883745	B84006	10/15/2013	7:00	10/15/2013	9:00	18	2160	120	Underground equipment	Underground Primary	Patrol/Test/Inspect	Replace - Urgent	I

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
132883774		10/15/2013	7:17	10/15/2013	8:31	1	74	74	Overhead equipment	Transformer Fuse	Replace - Same Size		I
132883941	A45003	10/15/2013	7:35	10/15/2013	10:03	16	2368	148	Overhead equipment	Fuse	Replace - Same Size		I
132883910	S03529	10/15/2013	8:20	10/15/2013	9:45	1	85	85	Overhead equipment	Overhead Service	Repair	Repair	VI
132883937	J47178	10/15/2013	8:22	10/15/2013	9:50	97	8536	88	Overhead equipment	Fuse		Repair	III
132884583	P54828	10/15/2013	9:14	10/15/2013	10:35	332	26892	81	Overhead equipment	Substation Breaker		Switch/Reset	V
132884124	V21500	10/15/2013	9:16	10/15/2013	10:34	1	78	78	Overhead equipment	Disconnect Switch	Repair		II
132884576		10/15/2013	9:29	10/15/2013	10:13	870	38280	44	Animal related				III
132884460	R01432	10/15/2013	9:29	10/15/2013	10:42	206	15038	73	Animal related				III
132884303	R05186	10/15/2013	9:36	10/15/2013	10:55	1	79	79	Overhead equipment				I
132884349	X29547	10/15/2013	9:41	10/15/2013	10:30	1	49	49	Animal related	Transformer Fuse	Replace - New Size		IV
132884360	X75512	10/15/2013	9:42	10/15/2013	11:30	5	540	108	Animal related	Disconnect Switch	Repair		IV
132884480	342003	10/15/2013	10:02	10/15/2013	12:10	13	1664	128	Overhead equipment	Fuse	Replace - Same Size		VI
132884555	J80807	10/15/2013	10:16	10/15/2013	10:40	82	1968	24	Overhead equipment	Overhead Primary	Repair	Repair	V
132884643	A73002	10/15/2013	10:36	10/15/2013	11:54	51	3978	78	Overhead equipment	Fuse	Replace - Same Size		I
132884644	K05253	10/15/2013	10:37	10/15/2013	11:42	92	5980	65	Overhead equipment				VI
132884765	J05139	10/15/2013	10:59	10/15/2013	12:15	1	76	76	Animal related	Jumper	Replace - Same Size		I
132884791	L50214	10/15/2013	11:05	10/15/2013	12:21	1	76	76	Tree related-tree contact	Overhead Service	Patrol/Test/Inspect	Repair	VI
132884916	V41527	10/15/2013	11:26	10/15/2013	12:25	1	59	59	Animal related	Fuse	Replace - Same Size		II
132884920	Y35515	10/15/2013	11:27	10/15/2013	11:53	1	26	26	Animal related	Fuse			IV
132884963	S64501	10/15/2013	11:40	10/15/2013	12:29	1	49	49	Underground equipment	Underground Secondary			VI
132884998	R50910	10/15/2013	11:49	10/15/2013	12:57	1	68	68	Animal related	Fuse	Replace - Same Size	No Work Required	I
132885061	B73003	10/15/2013	12:05	10/15/2013	16:50	1	285	285	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
132885078	K67912	10/15/2013	12:10	10/15/2013	12:55	1	45	45	Overhead equipment	Fuse	Repair		VI
132885132	S47589	10/15/2013	12:10	10/15/2013	12:48	42	1596	38	Overhead equipment	Overhead Primary	Repair		VI
132885111	P73182	10/15/2013	12:19	10/15/2013	13:24	1	65	65	Overhead equipment	Fuse	Replace - Same Size		VI
132885151	U01514	10/15/2013	12:27	10/15/2013	13:35	1	68	68	Overhead equipment	Overhead Service	Repair		II
132885175	K71812	10/15/2013	12:35	10/15/2013	13:12	7	259	37	Animal related	Transformer Fuse	Replace - Same Size		IV
132885198	B62003	10/15/2013	12:39	10/15/2013	13:13	1	34	34	Unknown	Transformer Fuse	Replace - Same Size	No Work Required	I
132884971		10/15/2013	12:39	10/15/2013	14:07	1	88	88	Public	Underground Secondary	Patrol/Test/Inspect	Repair	I
132885309	J15302	10/15/2013	13:01	10/15/2013	13:56	1	55	55	Overhead equipment	Transformer Fuse	Replace - New Size		I
132885319	J20931	10/15/2013	13:04	10/15/2013	14:04	1	60	60	Overhead equipment	Fuse	Replace - Same Size		VI
132885351	B73003	10/15/2013	13:09	10/15/2013	13:23	15	210	14	Overhead equipment	Fuse	Replace - Same Size	No Work Required	I
132885400	X92507	10/15/2013	13:17	10/15/2013	14:00	13	559	43	Overhead equipment	Fuse	Repair	Replace - Same Size	IV
132885437	P69173	10/15/2013	13:21	10/15/2013	13:42	130	2730	21	Overhead equipment	Other			III
132885429	P69174	10/15/2013	13:22	10/15/2013	13:44	3	66	22	Overhead equipment	Other			III
132885463	K46388	10/15/2013	13:30	10/15/2013	13:57	1	27	27	Animal related	Fuse	Replace - Same Size	No Work Required	V
132885582	J87150	10/15/2013	13:57	10/15/2013	14:37	1	40	40	Animal related	Transformer Fuse			VI
132885599	B61001	10/15/2013	13:57	10/15/2013	20:40	14	5642	403	Underground equipment	Underground Primary	Repair	Repair	I
132885591	Q83152	10/15/2013	13:59	10/15/2013	15:10	1	71	71	Overhead equipment	Jumper	Repair		VI
132885247	J97113	10/15/2013	14:08	10/15/2013	15:12	12	768	64	Tree related-tree contact	Tree	Trim		VI
132885843	C52001	10/15/2013	15:04	10/15/2013	16:02	1	58	58	Overhead equipment	Disconnect Switch			III
132885846	S86580	10/15/2013	15:05	10/15/2013	15:41	1	36	36	Animal related	Fuse	Replace - Same Size		VI
132885852	309139	10/15/2013	15:06	10/15/2013	15:29	1	23	23	Tree related-tree broken	Overhead Service	Repair		V
132885962	U04589	10/15/2013	15:35	10/15/2013	16:41	1	66	66	Overhead equipment	Fuse	Replace - Same Size		II
132886077	X66582	10/15/2013	16:12	10/15/2013	18:30	1	138	138	Overhead equipment	Disconnect Switch	Replace - Same Size		IV
132886240	H11338	10/15/2013	16:48	10/15/2013	19:07	22	3058	139	Animal related	Fuse	Replace - Same Size	Replace - Same Size	V
132886208	H11338	10/15/2013	16:57	10/15/2013	18:59	1	122	122	Animal related	Fuse	Replace - Same Size	Replace - Same Size	V
132886210	Z57516	10/15/2013	16:58	10/15/2013	18:23	1	85	85	Animal related	Transformer Fuse			IV
132886222	J83137	10/15/2013	17:03	10/15/2013	17:49	1	46	46	Animal related	Transformer Fuse			VI
132886254	L86175	10/15/2013	17:21	10/15/2013	18:52	1	91	91	Tree related-tree contact	Overhead Service	Repair		IV
132886419	X75571	10/15/2013	17:25	10/15/2013	19:46	597	84177	141	Overhead equipment	Pole	Replace - Same Size		IV
132886269	Q16867	10/15/2013	17:27	10/15/2013	20:20	1	173	173	Tree related-tree contact	Overhead Service	Repair	Repair	V
132886360	B77001	10/15/2013	17:44	10/15/2013	18:18	43	1462	34	Animal related	Fuse	Replace - Same Size	Patrol/Test/Inspect	I
132886387	N03298	10/15/2013	18:02	10/15/2013	19:37	44	4180	95	Overhead equipment	Fuse	Repair		V
132886405	Y13043	10/15/2013	18:10	10/15/2013	22:18	1	248	248	Tree related-tree contact	Overhead Service	Repair		IV
132886418	H14342	10/15/2013	18:17	10/15/2013	19:17	1	60	60	Animal related	Fuse	Replace - Same Size	Replace - Same Size	V

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
132886483	P20930	10/15/2013	18:25	10/15/2013	19:30	1	65	65	Overhead equipment	Fuse	Replace - Same Size	Patrol/Test/Inspect	VI
132886541	Y82587	10/15/2013	18:27	10/15/2013	20:40	1	133	133	Animal related	Animal Guard	Install		IV
132890154	D37003	10/15/2013	19:03	10/16/2013	5:18	17	10455	615	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	I
132887251	Y11556	10/15/2013	19:05	10/15/2013	20:36	1	91	91	Tree related-tree contact	Overhead Service	Repair		IV
132887295	D37003	10/15/2013	20:13	10/16/2013	1:00	9	2583	287	Overhead equipment	Overhead Secondary		Repair	I
132887402	F22001	10/15/2013	20:14	10/15/2013	21:21	21	1407	67	Overhead equipment	Pole	Switch/Reset		IV
132887384	F22001	10/15/2013	20:14	10/16/2013	4:58	721	377804	524	Overhead equipment	Pole	Replace - Same Size		IV
132887350	F22001	10/15/2013	20:14	10/15/2013	21:21	572	38324	67	Overhead equipment	Pole	Replace - Same Size		IV
132887376	Q91175	10/15/2013	21:08	10/15/2013	22:25	1	77	77	Animal related	Transformer Fuse	Replace - Same Size		I
132890187	M09175	10/16/2013	1:21	10/16/2013	5:27	21	5166	246	Overhead equipment	Overhead Primary	Replace - Same Size	Repair	VI
132890193	P57108	10/16/2013	1:31	10/16/2013	6:11	2	560	280	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	VI
132890166	P57108	10/16/2013	1:31	10/16/2013	3:04	75	6975	93	Overhead equipment	Overhead Transformer			VI
132894311	Q04411	10/16/2013	3:29	10/16/2013	9:00	9	2979	331	Underground equipment	Underground Primary	Repair	Repair	III
132894041	Q04411	10/16/2013	3:29	10/16/2013	7:20	32	7392	231	Underground equipment	Underground Primary	Repair	Repair	III
132894061		10/16/2013	5:02	10/16/2013	6:45	1	103	103	Animal related	Transformer Fuse	Replace - Same Size		IV
132894392	S25552	10/16/2013	8:30	10/16/2013	9:33	1	63	63	Animal related	Transformer Fuse	Patrol/Test/Inspect	Repair	VI
132894417	T06504	10/16/2013	8:37	10/16/2013	9:46	7	483	69	Animal related	Fuse	Patrol/Test/Inspect	Repair	VI
132894451	S28552	10/16/2013	8:44	10/16/2013	10:08	1	84	84	Animal related	Disconnect Switch	Replace - New Size		VI
132894479	S14509	10/16/2013	8:50	10/16/2013	9:49	1	59	59	Animal related				VI
132894492	A16001	10/16/2013	8:51	10/16/2013	10:58	1	127	127	Public	Underground Transformer	Patrol/Test/Inspect	Straighten	I
132894513	P17107	10/16/2013	8:55	10/16/2013	9:50	1	55	55	Animal related	Transformer Fuse		Replace - Same Size	IV
132894524	S86580	10/16/2013	8:59	10/16/2013	9:45	3	138	46	Animal related	Fuse	Replace - Same Size		VI
132895561	B62003	10/16/2013	9:30	10/16/2013	17:42	1	492	492	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
132894707	B62003	10/16/2013	9:30	10/16/2013	11:37	658	83566	127	Overhead equipment	Lightning Arrestor	Cut in Clear		I
132894927	X82576	10/16/2013	10:07	10/16/2013	11:10	1	63	63	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
132895074	X96543	10/16/2013	10:33	10/16/2013	11:15	10	420	42	Overhead equipment	Fuse			IV
132895150	HA5430	10/16/2013	10:50	10/16/2013	12:22	1	92	92	Tree related-tree broken	Overhead Secondary	Cut in Clear	Repair	V
132895192	S60581	10/16/2013	10:59	10/16/2013	11:34	1	35	35	Animal related	Transformer Fuse	Replace - Same Size		VI
132895261	Q32170	10/16/2013	11:11	10/16/2013	11:41	1	30	30	Tree related-tree contact	Overhead Service	No Work Required	No Work Required	I
132895296	X22001	10/16/2013	11:18	10/16/2013	11:55	1	37	37	Jurisdictional	Overhead Service			IV
132895308		10/16/2013	11:20	10/16/2013	15:43	1	263	263	Underground equipment	Underground Service		Repair	I
132895459	U99593	10/16/2013	11:51	10/16/2013	12:50	1	59	59	Overhead equipment	Transformer Fuse	Replace - Same Size		II
132895461	U80511	10/16/2013	11:52	10/16/2013	12:17	1	25	25	Other	Other			II
132895501	J80807	10/16/2013	12:02	10/16/2013	12:49	35	1645	47	Animal related	Overhead Primary	Repair	Repair	V
132895600	B38002	10/16/2013	12:27	10/16/2013	14:05	4	392	98	Animal related	Disconnect Switch	Replace - Same Size	No Work Required	I
132895636	X49568	10/16/2013	12:35	10/16/2013	13:31	1	56	56	Animal related	Transformer Fuse	Replace - Same Size		IV
132895713	Q01281	10/16/2013	12:45	10/16/2013	14:27	55	5610	102	Underground equipment	Underground Primary	Repair	Repair	III
132895740	D37004	10/16/2013	12:55	10/16/2013	13:19	7	168	24	Animal related	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	I
132895834	X19561	10/16/2013	13:08	10/16/2013	14:11	104	6552	63	Animal related	Overhead Primary	Patrol/Test/Inspect		IV
132895880	J01119	10/16/2013	13:22	10/16/2013	13:52	40	1200	30	Animal related	Fuse	Replace - Same Size		I
132895951	L59929	10/16/2013	13:37	10/16/2013	15:50	1	133	133	Tree related-tree broken	Overhead Primary		Repair	VI
132895972	Q14390	10/16/2013	13:40	10/16/2013	14:43	50	3150	63	Animal related	Fuse	Replace - Same Size	Repair	I
132895977	R42914	10/16/2013	13:44	10/16/2013	14:01	1	17	17	Jurisdictional	Other	No Work Required		VI
132896030	K67912	10/16/2013	13:55	10/16/2013	15:15	1	80	80	Animal related	Fuse	Replace - Same Size	Patrol/Test/Inspect	VI
132896200	V18541	10/16/2013	14:27	10/16/2013	15:20	3	159	53	Animal related	Animal Guard	Install		II
132896245	J98114	10/16/2013	14:37	10/16/2013	15:33	1	56	56	Overhead equipment	Overhead Service			VI
132896418	M07236	10/16/2013	15:01	10/16/2013	16:02	50	3050	61	Animal related	Fuse			III
132896431	L70125	10/16/2013	15:21	10/16/2013	17:38	1	137	137	Tree related-tree contact	Overhead Service	Repair		IV
132897663	P52305	10/16/2013	15:51	10/16/2013	18:41	2	340	170	Underground equipment	Underground Primary	Switch/Reset		IV
132896844	P52305	10/16/2013	15:51	10/16/2013	21:11	1	320	320	Underground equipment	Underground Primary		Repair	IV
132896843	P52305	10/16/2013	15:51	10/16/2013	17:52	2	242	121	Underground equipment	Underground Primary	Repair		IV
132896554	D89001	10/16/2013	15:51	10/16/2013	16:49	35	2030	58	Unknown				I
132896542	Y34597	10/16/2013	15:52	10/16/2013	17:59	1	127	127	Animal related	Other	Repair	Patrol/Test/Inspect	IV
132896579	J01119	10/16/2013	16:03	10/16/2013	17:05	1	62	62	Tree related-tree contact	Tree	Trim		I
132896593	R68900	10/16/2013	16:08	10/16/2013	18:29	2	282	141	Animal related	Fuse	Replace - Same Size		I
132896667	Y34597	10/16/2013	16:26	10/16/2013	17:56	3	270	90	Animal related	Other	Repair	Patrol/Test/Inspect	IV

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
132896662	H00163	10/16/2013	16:26	10/16/2013	17:05	11	429	39	Animal related	Other			III
132896688	Q91175	10/16/2013	16:29	10/16/2013	17:55	1	86	86	Animal related	Transformer Fuse	Replace - Same Size		I
132896714	T12528	10/16/2013	16:41	10/16/2013	17:34	1	53	53	Animal related	Transformer Fuse	Patrol/Test/Inspect	Repair	VI
132896732	348117	10/16/2013	16:44	10/16/2013	17:52	24	1632	68	Overhead equipment	Fuse	Repair		V
132896845	K39153	10/16/2013	17:32	10/16/2013	19:00	1	88	88	Tree related-tree broken	Overhead Service	Repair		III
132896973	Q54908	10/16/2013	17:47	10/16/2013	18:41	5	270	54	Public	Pole	Switch/Reset		VI
132896870	Q54908	10/16/2013	17:47	10/17/2013	2:29	10	5220	522	Public	Pole	Patrol/Test/Inspect	Repair	VI
132896971	D55002	10/16/2013	17:49	10/16/2013	19:04	18	1350	75	Animal related	Fuse	Replace - Same Size		I
132896892	B81002	10/16/2013	18:00	10/16/2013	19:09	1	69	69	Underground equipment				I
132897114	M09143	10/16/2013	19:04	10/16/2013	21:21	1	137	137	Animal related	Fuse	Replace - Same Size	Repair	VI
132897670	N54214	10/16/2013	19:22	10/16/2013	22:20	82	14596	178	Underground equipment	Underground Primary	Switch/Reset	Repair	II
132897811	B28006	10/16/2013	21:23	10/17/2013	5:00	1	457	457	Underground equipment	Overhead Primary		Repair	I
132897821	Q23255	10/16/2013	21:57	10/16/2013	23:13	1	76	76	Animal related	Transformer Fuse			VI
132897839	L12128	10/16/2013	23:16	10/17/2013	3:20	56	13664	244	Underground equipment	Underground Primary	Repair		III
132903707	K80382	10/17/2013	4:57	10/17/2013	6:25	10	880	88	Underground equipment	Underground Primary	Switch/Reset		IV
132903702	T16526	10/17/2013	4:58	10/17/2013	6:30	3	276	92	Overhead equipment				VI
132903778	D28123	10/17/2013	5:08	10/17/2013	12:57	1	469	469	Underground equipment	Underground Primary	Repair		I
132903741	D28123	10/17/2013	5:08	10/17/2013	7:27	5	695	139	Underground equipment	Underground Primary	Switch/Reset	Repair	I
132903714	B57003	10/17/2013	5:47	10/17/2013	9:37	4	920	230	Overhead equipment	Disconnect Switch	Patrol/Test/Inspect	Replace - Same Size	I
132904289	P77233	10/17/2013	6:37	10/17/2013	14:23	4	1864	466	Overhead equipment	Pole	Replace - Same Size	Replace - Same Size	VI
132903905	B81002	10/17/2013	8:14	10/17/2013	14:21	1	367	367	Underground equipment	Underground Service	Patrol/Test/Inspect	Reconnect	I
132903904	U84566	10/17/2013	8:14	10/17/2013	8:50	4	144	36	Unknown	Transformer Fuse	Replace - Same Size	No Work Required	II
132903967	Q64919	10/17/2013	8:36	10/17/2013	9:36	1	60	60	Overhead equipment	Transformer Fuse	Replace - Same Size	No Work Required	VI
132903966	S52515	10/17/2013	8:36	10/17/2013	13:15	1	279	279	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Repair	VI
132904246	R33126	10/17/2013	9:27	10/17/2013	10:29	1	62	62	Tree related-tree contact	Transformer Fuse	Replace - Same Size	Patrol/Test/Inspect	I
132904358	K57211	10/17/2013	9:34	10/17/2013	10:30	135	7560	56	Animal related	Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
132904333	Q80352	10/17/2013	9:38	10/17/2013	10:45	1	67	67	Overhead equipment	Fuse	Replace - Same Size		V
132904386	R61241	10/17/2013	9:49	10/17/2013	10:00	1	11	11	Other				IV
132904406	L12126	10/17/2013	9:52	10/17/2013	10:35	2	86	43	Unknown	Transformer Fuse	Replace - Same Size		III
132904453	P47169	10/17/2013	9:55	10/17/2013	10:32	32	1184	37	Animal related	Fuse	Replace - Same Size		I
132904536	Y97513	10/17/2013	10:21	10/17/2013	11:45	4	336	84	Animal related	Transformer Fuse	Replace - Same Size	Replace - Same Size	IV
132904780	K57211	10/17/2013	10:45	10/17/2013	12:05	11	880	80	Animal related	Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
132904719	N70332	10/17/2013	10:57	10/17/2013	12:00	1	63	63	Overhead equipment	Transformer Fuse	Replace - Same Size	Replace - Same Size	I
132904742	D48001	10/17/2013	11:03	10/17/2013	11:35	56	1792	32	Animal related	Fuse	Repair	Replace - Same Size	I
132904775	D48001	10/17/2013	11:09	10/17/2013	11:39	1	30	30	Animal related	Fuse	Repair	Replace - Same Size	I
132904815	J84146	10/17/2013	11:16	10/17/2013	12:00	29	1276	44	Animal related	Fuse	Replace - Same Size		VI
132905008	Y98532	10/17/2013	12:03	10/17/2013	14:15	1	132	132	Public	Overhead Service	Repair		IV
132905037	L59929	10/17/2013	12:10	10/17/2013	13:01	1	51	51	Animal related	Transformer Fuse	Replace - Same Size		VI
132905121	B62003	10/17/2013	12:33	10/17/2013	13:25	1	52	52	Unknown	Fuse	Patrol/Test/Inspect		I
132905197	J58380	10/17/2013	12:49	10/17/2013	13:51	1	62	62	Overhead equipment	Disconnect Switch		Replace - Same Size	III
132905469	U12001	10/17/2013	13:08	10/17/2013	14:41	38	3534	93	Overhead equipment	Fuse	Repair	Replace - Same Size	II
132905379	D36001	10/17/2013	13:21	10/17/2013	14:40	6	474	79	Animal related	Fuse	Replace - Same Size		I
132905445	H01194	10/17/2013	13:34	10/17/2013	14:30	1	56	56	Jurisdictional	Other			III
132905466	U12001	10/17/2013	13:41	10/17/2013	14:44	1	63	63	Overhead equipment	Fuse	Replace - Same Size		II
132905507	M45211	10/17/2013	13:49	10/17/2013	14:43	1	54	54	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
132905536	J87111	10/17/2013	13:58	10/17/2013	14:47	1	49	49	Animal related	Transformer Fuse			VI
132905801	U12001	10/17/2013	14:55	10/17/2013	15:15	1	20	20	Overhead equipment	Lightning Arrestor	Replace - Same Size		II
132905817	C00001	10/17/2013	15:00	10/17/2013	16:22	1	82	82	Animal related	Fuse	Replace - Same Size		I
132905825	Q70160	10/17/2013	15:03	10/17/2013	15:36	1	33	33	Overhead equipment	Connector	Repair		I
132905859	X02548	10/17/2013	15:09	10/17/2013	15:37	1	28	28	Animal related	Transformer Fuse	Replace - Same Size		IV
132905927	S61530	10/17/2013	15:26	10/17/2013	16:38	1	72	72	Overhead equipment	Disconnect Switch	Replace - New Size		VI
132906180	R16511	10/17/2013	16:44	10/17/2013	18:00	1	76	76	Animal related	Transformer Fuse	Replace - Same Size	Replace - Same Size	I
132906189	V92543	10/17/2013	16:48	10/17/2013	17:37	3	147	49	Animal related	Transformer Fuse	Replace - Same Size	Patrol/Test/Inspect	II
132906206	P42230	10/17/2013	16:59	10/17/2013	18:13	1	74	74	Animal related	Transformer Fuse			VI
132906227	K76541	10/17/2013	17:07	10/17/2013	18:46	6	594	99	Animal related	Transformer Fuse	Replace - Same Size	No Work Required	IV
132906234	J99141	10/17/2013	17:08	10/17/2013	20:01	130	22490	173	Overhead equipment	Overhead Primary	Patrol/Test/Inspect	Repair	VI

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
132906249	R10902	10/17/2013	17:16	10/17/2013	17:30	1	14	14	Jurisdictional				VI
132906266	M05360	10/17/2013	17:22	10/17/2013	19:35	1	133	133	Other				V
132906283	S93504	10/17/2013	17:24	10/17/2013	18:47	36	2988	83	Animal related	Transformer Fuse	Replace - Same Size		VI
132906281	M05361	10/17/2013	17:31	10/17/2013	19:08	2	194	97	Animal related	Transformer Fuse	Replace - Same Size		V
132906315	T08502	10/17/2013	17:45	10/17/2013	18:40	1	55	55	Overhead equipment	Transformer Fuse	Patrol/Test/Inspect	Repair	VI
132906345	D67001	10/17/2013	18:03	10/17/2013	19:19	2	152	76	Overhead equipment	Fuse	Repair		IV
132906430	374052	10/17/2013	18:34	10/17/2013	19:15	1	41	41	Animal related	Fuse	Replace - Same Size		VI
132906554	R61241	10/17/2013	19:03	10/17/2013	19:50	1	47	47	Overhead equipment	Transformer Fuse	Replace - Same Size	No Work Required	IV
132906732	306003	10/17/2013	19:30	10/17/2013	21:05	1	95	95	Tree related-tree broken	Overhead Service	Repair		VI
132907408	K30204	10/17/2013	23:28	10/18/2013	1:48	14	1960	140	Animal related	Fuse			III
132914504	R20501	10/18/2013	3:21	10/18/2013	5:03	17	1734	102	Overhead equipment	Overhead Primary	Repair		IV
132914682	Q18244	10/18/2013	6:15	10/18/2013	9:45	15	3150	210	Underground equipment	Underground Primary		Repair	VI
132914700	R07382	10/18/2013	6:25	10/18/2013	12:48	11	4213	383	Underground equipment	Underground Primary	Repair	Repair	I
132914736	R58961	10/18/2013	7:22	10/18/2013	8:05	15	645	43	Animal related				IV
132914777	R58961	10/18/2013	7:39	10/18/2013	8:10	1	31	31	Animal related			Repair	IV
132914806	J99127	10/18/2013	7:49	10/18/2013	8:53	33	2112	64	Animal related	Fuse	Replace - Same Size		VI
132915405	B81002	10/18/2013	8:04	10/18/2013	9:51	1	107	107	Underground equipment	Underground Primary	Repair		I
132914955	B81002	10/18/2013	8:08	10/18/2013	14:25	1	377	377	Underground equipment	Underground Primary	Patrol/Test/Inspect	Reconnect	I
132914925	310123	10/18/2013	8:15	10/18/2013	8:46	27	837	31	Animal related	Fuse	Replace - Same Size		V
132915085	R61241	10/18/2013	8:51	10/18/2013	9:38	1	47	47	Animal related			Repair	IV
132915150	K89141	10/18/2013	9:07	10/18/2013	10:35	1	88	88	Animal related	Overhead Primary	Tie/Tighten		III
132915154	N50331	10/18/2013	9:10	10/18/2013	10:16	1	66	66	Animal related	Overhead Service	Tie/Tighten		II
132915435	P58155	10/18/2013	9:42	10/18/2013	10:24	48	2016	42	Animal related	Fuse	Repair	Repair	VI
132915603	R94269	10/18/2013	10:15	10/18/2013	14:57	306	86292	282	Overhead equipment	Pole	Patrol/Test/Inspect	Replace - Same Size	VI
132915565	Y28598	10/18/2013	10:31	10/18/2013	12:04	1	93	93	Animal related	Disconnect Switch	Repair	Repair	IV
132915577	S62522	10/18/2013	10:33	10/18/2013	11:26	1	53	53	Animal related	Disconnect Switch	Replace - New Size		VI
132915713	K09864	10/18/2013	11:02	10/18/2013	12:30	1	88	88	Overhead equipment	Transformer Fuse	Replace - Same Size		V
132915787	R99180	10/18/2013	11:19	10/18/2013	12:40	1	81	81	Overhead equipment	Disconnect Switch		Replace - Same Size	IV
132915822	K89142	10/18/2013	11:20	10/18/2013	11:48	38	1064	28	Unknown	Fuse	Replace - Same Size		III
132915799	N72240	10/18/2013	11:21	10/18/2013	12:24	1	63	63	Overhead equipment	Tree		Repair	III
132915962	S86580	10/18/2013	11:52	10/18/2013	12:35	1	43	43	Animal related	Fuse	Replace - Same Size		VI
132916115	Q74149	10/18/2013	12:27	10/18/2013	13:30	1	63	63	Animal related	Fuse	Repair		IV
132916149	M26161	10/18/2013	12:35	10/18/2013	13:38	1	63	63	Animal related	Transformer Fuse	Replace - Same Size		III
132916367	V49541	10/18/2013	13:24	10/18/2013	14:42	1	78	78	Overhead equipment	Transformer Fuse	Repair	Repair	II
132916419	L70127	10/18/2013	13:41	10/18/2013	15:23	12	1224	102	Animal related	Transformer Fuse	Replace - Same Size	Replace - Same Size	IV
132916450	J87150	10/18/2013	13:49	10/18/2013	14:34	1	45	45	Animal related	Transformer Fuse			VI
132916627	338007	10/18/2013	14:36	10/18/2013	15:45	1	69	69	Overhead equipment	Fuse	Replace - Same Size		VI
132916665	K71822	10/18/2013	14:47	10/18/2013	15:31	1	44	44	Animal related	Transformer Fuse	Repair		IV
132916838	K25166	10/18/2013	15:52	10/18/2013	16:32	1	40	40	Animal related	Fuse	Replace - Same Size	Replace - Same Size	VI
132916871	K25166	10/18/2013	15:53	10/18/2013	16:20	15	405	27	Animal related	Fuse	Replace - Same Size	Replace - Same Size	VI
132916885	S30518	10/18/2013	16:11	10/18/2013	17:00	1	49	49	Animal related				VI
132916925	Z10501	10/18/2013	16:27	10/18/2013	17:04	1	37	37	Overhead equipment	Overhead Service			IV
132916924	M19222	10/18/2013	16:27	10/18/2013	17:50	4	332	83	Underground equipment	Underground Primary		Repair	VI
132916931	D55003	10/18/2013	16:29	10/18/2013	17:25	11	616	56	Animal related	Fuse	Replace - Same Size		I
132917016	Y61004	10/18/2013	17:06	10/18/2013	18:00	1	54	54	Overhead equipment	Connector			IV
132917065	U52516	10/18/2013	17:26	10/18/2013	18:31	1	65	65	Animal related	Other			II
132917085	X82576	10/18/2013	17:42	10/18/2013	18:15	1	33	33	Unknown	Fuse	Replace - Same Size	Replace - Same Size	IV
132917196	T05539	10/18/2013	18:06	10/18/2013	19:19	1	73	73	Overhead equipment	Transformer Fuse	Repair	Replace - Same Size	VI
132917233	R66470	10/18/2013	18:35	10/18/2013	19:03	19	532	28	Animal related	Transformer Fuse			IV
132917590	M78325	10/18/2013	21:58	10/18/2013	23:10	1	72	72	Animal related	Fuse	Repair		V
132917606	N93260	10/18/2013	23:15	10/19/2013	0:03	3	144	48	Overhead equipment				III
132917607	N93260	10/18/2013	23:16	10/19/2013	0:01	8	360	45	Overhead equipment	Overhead Transformer			III
132920027	K46389	10/18/2013	23:50	10/19/2013	2:09	53	7367	139	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	V
132920074	M54317	10/19/2013	1:49	10/19/2013	3:42	1	113	113	Tree related-tree contact	Overhead Service	Repair		V
132920082	K19117	10/19/2013	2:52	10/19/2013	4:20	1	88	88	Overhead equipment	Overhead Secondary	Repair	Repair	VI
132920090	K19115	10/19/2013	3:37	10/19/2013	5:00	1	83	83	Public	Pole	Repair		VI

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
132920115	U60559	10/19/2013	6:04	10/19/2013	9:30	1	206	206	Overhead equipment	Disconnect Switch	Replace - Same Size		II
132920175	J15303	10/19/2013	8:20	10/19/2013	9:14	1	54	54	Animal related	Fuse	Replace - Same Size		I
132920325	S60581	10/19/2013	8:22	10/19/2013	10:15	139	15707	113	Overhead equipment	Disconnect Switch	Patrol/Test/Inspect	Replace - Same Size	VI
132920182	P57104	10/19/2013	8:27	10/19/2013	11:45	1	198	198	Overhead equipment				VI
132920188	Q32171	10/19/2013	8:36	10/19/2013	10:17	1	101	101	Tree related-tree contact	Overhead Service	Repair	Patrol/Test/Inspect	I
132920191	Y23513	10/19/2013	8:39	10/19/2013	10:45	5	630	126	Animal related	Transformer Fuse	Repair	Replace - Same Size	IV
132920215		10/19/2013	8:54	10/19/2013	10:15	1	81	81	Animal related	Transformer Fuse	Replace - Same Size	Replace - Same Size	VI
132920222	J06168	10/19/2013	8:59	10/19/2013	10:45	5	530	106	Unknown	Fuse	Replace - Same Size	Repair	I
132920277	J15302	10/19/2013	9:35	10/19/2013	10:21	2	92	46	Animal related	Fuse	Replace - Same Size		I
132920289	J07135	10/19/2013	9:43	10/19/2013	14:30	1	287	287	Underground equipment	Underground Service	Repair	Replace - Same Size	I
132920312	X77543	10/19/2013	10:04	10/19/2013	11:06	1	62	62	Overhead equipment	Jumper	Repair		IV
132920327	P82290	10/19/2013	10:16	10/19/2013	12:28	1	132	132	Underground equipment	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
132920369	Y08552	10/19/2013	10:48	10/19/2013	12:24	1	96	96	Unknown	Transformer Fuse	Replace - Same Size		IV
132920371	Y82587	10/19/2013	10:51	10/19/2013	12:05	5	370	74	Animal related	Animal Guard	Install		IV
132920383	J14140	10/19/2013	11:11	10/19/2013	13:09	1	118	118	Tree related-tree broken	Overhead Service	Repair	Repair	VI
132920471	S47537	10/19/2013	11:39	10/19/2013	12:15	24	864	36	Overhead equipment	Overhead Service	Replace - New Size		VI
132920408	X64503	10/19/2013	11:48	10/19/2013	13:51	9	1107	123	Animal related	Transformer Fuse	Replace - Same Size		IV
132920407	N22295	10/19/2013	11:48	10/19/2013	12:50	1	62	62	Overhead equipment	Fuse	Repair		VI
132920479	HB6281	10/19/2013	12:11	10/19/2013	13:26	1	75	75	Animal related	Fuse	Replace - Same Size		VI
132920492	X13001	10/19/2013	12:33	10/19/2013	14:24	1	111	111	Tree related-tree contact	Overhead Service	Repair	Replace - Same Size	IV
132920609	J34377	10/19/2013	12:48	10/19/2013	18:40	4	1408	352	Public	Overhead Primary			V
132920501		10/19/2013	12:50	10/19/2013	14:55	1	125	125	Underground equipment	Underground Secondary	Replace - Same Size	Replace - Same Size	I
132920525	D01001	10/19/2013	12:57	10/19/2013	13:55	13	754	58	Overhead equipment	Disconnect Switch	Replace - Same Size	Replace - Same Size	I
132920543	D32212	10/19/2013	13:42	10/19/2013	15:30	1	108	108	Unknown	Disconnect Switch	Replace - Same Size	Replace - Same Size	I
132920603	K32915	10/19/2013	14:42	10/19/2013	15:47	5	325	65	Animal related	Fuse	Replace - Same Size		VI
132920587	D37003	10/19/2013	14:45	10/19/2013	15:30	25	1125	45	Animal related	Fuse	Replace - Same Size		I
132920583	M09144	10/19/2013	14:48	10/19/2013	15:26	6	228	38	Overhead equipment	Overhead Primary	Replace - Same Size	Repair	VI
132920597	Y79500	10/19/2013	14:56	10/19/2013	16:10	1	74	74	Tree related-tree contact	Overhead Service	Repair	Replace - Same Size	IV
132920619	L46810	10/19/2013	15:20	10/19/2013	16:28	5	340	68	Overhead equipment	Overhead Transformer	Repair		V
132920643	M07236	10/19/2013	15:54	10/19/2013	17:16	192	15744	82	Overhead equipment	Jumper			III
132920638	J68402	10/19/2013	15:55	10/19/2013	17:10	1	75	75	Overhead equipment	Fuse	Repair		III
132920628	N67309	10/19/2013	16:10	10/19/2013	17:27	2	154	77	Tree related-tree broken	Fuse	Replace - Same Size		I
132920680	B28006	10/19/2013	16:54	10/19/2013	18:10	1	76	76	Overhead equipment	Overhead Service	Repair	Replace - Same Size	I
132920698	F10002	10/19/2013	17:16	10/19/2013	19:19	31	3813	123	Unknown	Overhead Primary		Repair	III
132920693	J56342	10/19/2013	17:19	10/19/2013	17:55	1	36	36	Animal related	Transformer Fuse			III
132920697	R50910	10/19/2013	17:21	10/19/2013	20:00	1	159	159	Overhead equipment	Overhead Transformer	Replace - Same Size		I
132920699	Q95247	10/19/2013	17:21	10/19/2013	21:16	1	235	235	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	VI
132920705	306001	10/19/2013	17:30	10/19/2013	18:41	1	71	71	Tree related-tree contact	Overhead Service	Repair		VI
132920707	Y68581	10/19/2013	17:32	10/19/2013	19:32	1	120	120	Animal related	Disconnect Switch	Replace - Same Size		IV
132920757	D31018	10/19/2013	17:59	10/19/2013	20:48	3	507	169	Overhead equipment	Overhead Primary		Repair	III
132920816	J20931	10/19/2013	18:20	10/19/2013	22:27	11	2717	247	Overhead equipment	Disconnect Switch	Replace - New Size	Repair	VI
132920749	P47120	10/19/2013	18:54	10/19/2013	23:15	1	261	261	Overhead equipment	Pole	Repair	Replace - Same Size	I
132920772	D92002	10/19/2013	19:24	10/19/2013	20:35	28	1988	71	Overhead equipment	Fuse	Repair	Replace - Same Size	I
132920825	Y66557	10/19/2013	23:40	10/20/2013	0:52	2	144	72	Animal related	Transformer Fuse			IV
132930027	A85002	10/20/2013	4:20	10/20/2013	12:14	1	474	474	Underground equipment	Underground Primary	Patrol/Test/Inspect	Replace - Urgent	I
132930033	J34356	10/20/2013	5:41	10/20/2013	9:36	1	235	235	Overhead equipment	Overhead Service	Patrol/Test/Inspect		V
132930044	B19001	10/20/2013	6:30	10/20/2013	15:20	4	2120	530	Underground equipment	Underground Transformer	Replace - Same Size	Replace - Same Size	I
132930074	S47576	10/20/2013	7:24	10/20/2013	8:30	10	660	66	Animal related	Fuse	Replace - New Size		VI
132930058	N58144	10/20/2013	7:29	10/20/2013	8:29	1	60	60	Overhead equipment	Jumper	Repair	Reconnect	I
132930065	H11340	10/20/2013	7:41	10/20/2013	8:33	5	260	52	Animal related	Fuse	Replace - Same Size		V
132930080	K15205	10/20/2013	7:47	10/20/2013	9:10	20	1660	83	Animal related	Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
132930090	Q32170	10/20/2013	8:15	10/20/2013	9:41	8	688	86	Animal related	Fuse	Replace - Same Size	Patrol/Test/Inspect	I
132930102	M81403	10/20/2013	8:39	10/20/2013	9:29	1	50	50	Animal related	Fuse	Replace - Same Size		V
132930104	T06503	10/20/2013	8:45	10/20/2013	9:33	1	48	48	Animal related	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
132930108	A91004	10/20/2013	8:46	10/20/2013	10:17	70	6370	91	Overhead equipment	Lightning Arrestor			I
132930119	Y79500	10/20/2013	9:17	10/20/2013	11:10	1	113	113	Animal related	Disconnect Switch	Repair	Replace - Same Size	IV

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
132930122	330125	10/20/2013	9:23	10/20/2013	10:05	1	42	42	Animal related	Overhead Service	Repair		V
132930128	Q32170	10/20/2013	9:24	10/20/2013	10:15	6	306	51	Animal related	Fuse	Replace - Same Size	Patrol/Test/Inspect	I
132930124	U32594	10/20/2013	9:24	10/20/2013	10:02	1	38	38	Overhead equipment	Transformer Fuse	Repair	Repair	II
132930126		10/20/2013	9:30	10/20/2013	10:15	1	45	45	Animal related	Fuse	Replace - Same Size	Patrol/Test/Inspect	I
132930135	K69117	10/20/2013	9:31	10/20/2013	11:20	41	4469	109	Animal related				IV
132930143	M48815	10/20/2013	10:12	10/20/2013	11:30	1	78	78	Overhead equipment	Overhead Service			V
132930176	X86546	10/20/2013	11:46	10/20/2013	16:09	1	263	263	Overhead equipment	Overhead Transformer	Replace - New Size	Replace - New Size	IV
132930187	M05360	10/20/2013	11:54	10/20/2013	12:56	1	62	62	Tree related-tree contact	Transformer Fuse	Replace - Same Size	Replace - Same Size	V
132930195	331152	10/20/2013	12:06	10/20/2013	12:20	1	14	14	Jurisdictional	Overhead Service	Reconnect		V
132930196	Q32170	10/20/2013	12:14	10/20/2013	15:50	1	216	216	Overhead equipment	Overhead Transformer	Replace - Same Size	Patrol/Test/Inspect	I
132930201	J07135	10/20/2013	12:30	10/20/2013	15:25	1	175	175	Overhead equipment	Overhead Service	Repair	Replace - Same Size	I
132930208	J07173	10/20/2013	12:44	10/20/2013	14:45	14	1694	121	Overhead equipment	Overhead Primary	Repair	Replace - Same Size	I
132930210	A97001	10/20/2013	12:49	10/20/2013	15:57	1	188	188	Public	Overhead Service	Remove		I
132930291	U60559	10/20/2013	13:36	10/20/2013	14:50	1	74	74	Animal related	Transformer Fuse	Replace - Same Size	No Work Required	II
132930297	K94223	10/20/2013	13:58	10/20/2013	14:45	1	47	47	Tree related-tree contact	Overhead Secondary	Repair		III
132930299	K32932	10/20/2013	14:00	10/20/2013	15:00	1	60	60	Tree related-tree broken	Fuse	Replace - Same Size		VI
132930369	X65540	10/20/2013	14:47	10/20/2013	17:54	5	935	187	Animal related	Overhead Transformer	Replace - New Size	Replace - Same Size	IV
132930359	J15303	10/20/2013	15:26	10/20/2013	16:12	1	46	46	Unknown	Fuse	Replace - Same Size		I
132930377	Z29579	10/20/2013	15:46	10/20/2013	17:09	10	830	83	Unknown	Fuse	Replace - Same Size	Replace - Same Size	IV
132930394	K91117	10/20/2013	16:35	10/20/2013	20:09	6	1284	214	Overhead equipment	Overhead Secondary	Patrol/Test/Inspect	Repair	III
132930409	L23145	10/20/2013	16:39	10/20/2013	17:45	4	264	66	Overhead equipment	Overhead Primary	Repair		III
132930414	V69532	10/20/2013	16:56	10/20/2013	17:45	1	49	49	Overhead equipment	Fuse	Replace - Same Size		II
132930413	M45212	10/20/2013	16:56	10/20/2013	18:01	1	65	65	Animal related	Transformer Fuse	Replace - Same Size		IV
132930431	N54107	10/20/2013	17:16	10/20/2013	18:14	117	6786	58	Public	Overhead Primary	Repair		II
132930437	K09864	10/20/2013	17:25	10/20/2013	19:14	1	109	109	Animal related	Overhead Transformer	Repair		V
132930445	D90004	10/20/2013	17:34	10/20/2013	18:05	61	1891	31	Overhead equipment	Fuse	Replace - Same Size	Repair	III
132930448	K28180	10/20/2013	17:43	10/20/2013	18:48	1	65	65	Animal related	Fuse	Replace - Same Size	No Work Required	III
132930454	K28180	10/20/2013	17:45	10/20/2013	18:48	36	2268	63	Animal related	Fuse	Replace - Same Size	No Work Required	III
132930397	L23146	10/20/2013	17:55	10/20/2013	19:30	1	95	95	Overhead equipment	Overhead Service	Replace - Same Size		III
132930474	L79159	10/20/2013	18:27	10/20/2013	20:17	1	110	110	Tree related-tree broken	Overhead Service	Repair	No Work Required	IV
132930478	X82004	10/20/2013	18:36	10/20/2013	20:23	2	214	107	Jurisdictional	Overhead Service		Repair	IV
132930481	L35137	10/20/2013	18:50	10/20/2013	19:51	1	61	61	Overhead equipment	Overhead Service	Repair	No Work Required	III
132930494	U29001	10/20/2013	19:22	10/20/2013	21:52	1	150	150	Tree related-tree contact	Overhead Secondary	Repair		II
132930531	M09143	10/20/2013	21:18	10/21/2013	0:59	4	884	221	Animal related	Overhead Primary	Replace - Same Size	Repair	VI
132940090	X75512	10/21/2013	0:23	10/21/2013	2:36	2	266	133	Overhead equipment	Disconnect Switch	Replace - Same Size		IV
132944521	D39001	10/21/2013	1:43	10/21/2013	7:40	236	84252	357	Overhead equipment	Crossarm	Replace - Urgent	Replace - Same Size	I
132940149	D39001	10/21/2013	1:47	10/21/2013	5:35	295	67260	228	Overhead equipment				I
132944523	J76804	10/21/2013	5:27	10/21/2013	6:54	1	87	87	Overhead equipment	Overhead Transformer	Repair	Repair	V
132944556	Y10015	10/21/2013	6:35	10/21/2013	8:20	1	105	105	Unknown	Fuse	Replace - Same Size		IV
132944561	K46389	10/21/2013	6:40	10/21/2013	7:36	1	56	56	Animal related	Fuse	Replace - Same Size		V
132944684	D35003	10/21/2013	7:37	10/21/2013	8:15	1	38	38	Unknown	Fuse	Repair	Replace - Same Size	I
132944763	B45005	10/21/2013	7:57	10/21/2013	10:06	30	3870	129	Unknown	Overhead Primary	No Work Required		I
132944789	T16526	10/21/2013	8:07	10/21/2013	9:10	1	63	63	Overhead equipment	Overhead Primary	Repair		VI
132944818	M04364	10/21/2013	8:14	10/21/2013	9:29	1	75	75	Other	Meter	Reconnect	Advise Customer	V
132944863	Z17503	10/21/2013	8:24	10/21/2013	9:28	1	64	64	Overhead equipment	Fuse	Replace - Same Size		IV
132944939	Y82587	10/21/2013	8:41	10/21/2013	11:29	1	168	168	Overhead equipment	Animal Guard	Install		IV
132945017	N78243	10/21/2013	9:00	10/21/2013	10:43	1	103	103	Tree related-tree contact	Overhead Service	Repair	Replace - New Size	I
132945103	J67132	10/21/2013	9:17	10/21/2013	11:55	1	158	158	Overhead equipment	Overhead Transformer	Repair	Repair	III
132945112	P17108	10/21/2013	9:18	10/21/2013	10:36	1	78	78	Overhead equipment	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	IV
132945111		10/21/2013	9:18	10/21/2013	10:02	1	44	44	Animal related	Fuse	Replace - Same Size		IV
132945148	K08909	10/21/2013	9:27	10/21/2013	11:05	1	98	98	Animal related	Jumper	Replace - Same Size	No Work Required	VI
132945169	D32212	10/21/2013	9:32	10/21/2013	20:30	1	658	658	Underground equipment	Underground Primary	Patrol/Test/Inspect	Replace - Same Size	I
132945190	L59933	10/21/2013	9:37	10/21/2013	10:40	1	63	63	Animal related	Transformer Fuse	Replace - Same Size		VI
132945257	P82290	10/21/2013	9:52	10/21/2013	12:34	1	162	162	Overhead equipment	Fuse			VI
132945263	Q23255	10/21/2013	9:54	10/21/2013	12:25	1	151	151	Animal related	Lightning Arrestor	Replace - Same Size		VI
132945418	L00133	10/21/2013	10:26	10/21/2013	11:30	1	64	64	Unknown	Fuse	Replace - Same Size		III

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
132945417	L00133	10/21/2013	10:26	10/21/2013	11:34	1	68	68	Unknown	Fuse	Replace - Same Size		III
132945459	K35308	10/21/2013	10:33	10/21/2013	12:56	1	143	143	Overhead equipment	Overhead Transformer	Repair		III
132945488	B08002	10/21/2013	10:36	10/21/2013	11:52	1	76	76	Overhead equipment	Disconnect Switch	Replace - Same Size		I
132945617	C40001	10/21/2013	10:50	10/21/2013	14:01	48	9168	191	Underground equipment	Underground Primary		Repair	I
132945795	R48167	10/21/2013	11:35	10/21/2013	13:39	1	124	124	Overhead equipment	Overhead Service	Replace - Same Size		IV
132945851	S42579	10/21/2013	11:43	10/21/2013	13:00	5	385	77	Animal related	Transformer Fuse	Replace - Same Size	No Work Required	VI
132945910	R16511	10/21/2013	11:51	10/21/2013	12:48	5	285	57	Animal related	Fuse	Replace - Same Size		I
132946047	D93002	10/21/2013	12:35	10/21/2013	13:28	1	53	53	Animal related	Animal Guard		Replace - Same Size	IV
132946231	L35138	10/21/2013	13:16	10/21/2013	13:46	1	30	30	Unknown	Fuse	Replace - Same Size		III
132946386	V18582	10/21/2013	13:52	10/21/2013	14:57	4	260	65	Animal related	Transformer Fuse	Replace - Same Size		II
132946401	C36002	10/21/2013	13:54	10/21/2013	14:50	1	56	56	Animal related	Fuse	Replace - Same Size		III
132946494	Z21564	10/21/2013	13:55	10/21/2013	15:11	90	6840	76	Overhead equipment	Overhead Primary	Repair	Replace - Same Size	IV
132946473	U06551	10/21/2013	14:05	10/21/2013	15:04	1	59	59	Overhead equipment	Fuse	Replace - Same Size		II
132946484	R01152	10/21/2013	14:07	10/21/2013	15:07	1	60	60	Animal related	Fuse			III
132946594	J07135	10/21/2013	14:21	10/21/2013	15:53	6	552	92	Animal related	Fuse	Replace - Same Size		I
132946554	A97006	10/21/2013	14:23	10/21/2013	15:35	1	72	72	Underground equipment	Street Light Cable	Patrol/Test/Inspect	Reconnect	I
132946646	P49187	10/21/2013	14:36	10/21/2013	15:30	26	1404	54	Animal related	Fuse	Replace - Same Size		I
132946640	R58961	10/21/2013	14:40	10/21/2013	15:31	5	255	51	Animal related	Transformer Fuse	Replace - Same Size		IV
132946777	K69117	10/21/2013	15:02	10/21/2013	16:55	49	5537	113	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	IV
132947182	K27150	10/21/2013	17:05	10/21/2013	18:20	17	1275	75	Overhead equipment	Fuse	Repair		VI
132947194	C70004	10/21/2013	17:10	10/21/2013	18:11	1	61	61	Animal related	Transformer Fuse	Replace - Same Size	No Work Required	III
132947210	S25552	10/21/2013	17:17	10/21/2013	18:10	4	212	53	Animal related	Transformer Fuse	Patrol/Test/Inspect	Repair	VI
132947221	D32211	10/21/2013	17:19	10/22/2013	1:20	1	481	481	Underground equipment	Underground Primary		Repair	I
132947253	M78325	10/21/2013	17:33	10/21/2013	18:38	1	65	65	Animal related	Transformer Fuse	Repair		V
132947542	R23334	10/21/2013	18:28	10/21/2013	19:27	1	59	59	Animal related	Transformer Fuse	Repair		V
132948294	X82576	10/21/2013	20:35	10/21/2013	23:10	7	1085	155	Overhead equipment	Overhead Primary	Repair	Repair	IV
132948316	G50001	10/21/2013	20:50	10/21/2013	22:40	1	110	110	Overhead equipment	Overhead Service	Replace - New Size	Replace - New Size	IV
132948488	B10001	10/21/2013	23:46	10/22/2013	1:11	27	2295	85	Underground equipment	Underground Primary	Patrol/Test/Inspect		I
132950101	U84587	10/21/2013	23:46	10/22/2013	1:40	32	3648	114	Overhead equipment	Overhead Primary	Repair		II
132950097	R33126	10/22/2013	0:09	10/22/2013	5:50	1	341	341	Overhead equipment	Overhead Primary	Repair	Patrol/Test/Inspect	I
132950135	B19002	10/22/2013	0:56	10/22/2013	5:00	1	244	244	Overhead equipment	Overhead Primary		Repair	I
132954663	D60001	10/22/2013	4:17	10/22/2013	6:52	36	5580	155	Underground equipment	Underground Primary	Patrol/Test/Inspect	Patrol/Test/Inspect	III
132954668	P58155	10/22/2013	4:33	10/22/2013	8:02	6	1254	209	Animal related	Overhead Transformer			VI
132954693	U19534	10/22/2013	4:37	10/22/2013	9:19	18	5076	282	Underground equipment	Underground Primary	Repair	Repair	II
132954697	U84587	10/22/2013	4:59	10/22/2013	7:46	5	835	167	Underground equipment	Underground Primary			II
132954699	B10001	10/22/2013	5:08	10/22/2013	7:33	27	3915	145	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
132956343	B81003	10/22/2013	5:27	10/22/2013	17:26	2	1438	719	Substation equipment	Other	Patrol/Test/Inspect	Repair	I
132954727	L59933	10/22/2013	5:28	10/22/2013	9:28	190	45600	240	Overhead equipment	Overhead Primary			VI
132954717	L59933	10/22/2013	5:36	10/22/2013	6:22	202	9292	46	Overhead equipment	Overhead Primary			VI
132954860	M18131	10/22/2013	7:38	10/22/2013	8:35	1	57	57	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect		III
132954988	Z61524	10/22/2013	8:16	10/22/2013	10:12	1	116	116	Overhead equipment	Animal Guard	Install		IV
132955042	K28180	10/22/2013	8:36	10/22/2013	11:45	1	189	189	Overhead equipment	Overhead Transformer	Replace - Same Size		III
132955175	S07536	10/22/2013	9:09	10/22/2013	9:35	1	26	26	Overhead equipment				VI
132955217	S07536	10/22/2013	9:15	10/22/2013	9:40	1	25	25	Overhead equipment				VI
132955371	K46388	10/22/2013	9:46	10/22/2013	10:06	1	20	20	Tree related-tree contact				V
132955414	J15303	10/22/2013	9:54	10/22/2013	10:27	2	66	33	Animal related	Transformer Fuse	Replace - Same Size		I
132955443	M81404	10/22/2013	10:00	10/22/2013	11:10	26	1820	70	Unknown				V
132955500	P58156	10/22/2013	10:13	10/22/2013	10:48	1	35	35	Animal related	Fuse	Repair	Repair	VI
132955610	U68581	10/22/2013	10:35	10/22/2013	11:15	4	160	40	Animal related	Transformer Fuse	Replace - Same Size		II
132955641	328119	10/22/2013	10:40	10/22/2013	11:26	1	46	46	Overhead equipment	Fuse	Patrol/Test/Inspect		V
132955796	L35139	10/22/2013	11:08	10/22/2013	11:40	11	352	32	Animal related	Transformer Fuse	Replace - Same Size		III
132955938	B71002	10/22/2013	11:38	10/22/2013	12:58	25	2000	80	Public	Overhead Primary	Patrol/Test/Inspect	Repair	I
132955945	V42572	10/22/2013	11:42	10/22/2013	12:44	7	434	62	Overhead equipment	Jumper	Repair	Repair	II
132955953	A45002	10/22/2013	11:44	10/22/2013	14:18	1	154	154	Overhead equipment	Disconnect Switch	Patrol/Test/Inspect	Repair	I
132955951	U32579	10/22/2013	11:44	10/22/2013	12:14	1	30	30	Animal related	Transformer Fuse	Replace - Same Size		II
132956096	Q80353	10/22/2013	12:09	10/22/2013	15:42	106	22578	213	Overhead equipment	Overhead Primary	Cut in Clear	Repair	V

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
132956176	B57001	10/22/2013	12:15	10/22/2013	13:48	15	1395	93	Overhead equipment	Disconnect Switch	Patrol/Test/Inspect	Replace - Same Size	I
132956146	B71002	10/22/2013	12:23	10/22/2013	13:53	4	360	90	Public	Overhead Primary	Repair		I
132956147	B28006	10/22/2013	12:24	10/22/2013	13:10	1	46	46	Animal related	Transformer Fuse	Replace - Same Size		I
132956273	D36002	10/22/2013	12:49	10/22/2013	13:44	48	2640	55	Overhead equipment	Fuse	Repair	Replace - New Size	I
132956259	A97002	10/22/2013	12:50	10/22/2013	14:50	146	17520	120	Overhead equipment	Disconnect Switch	Replace - Same Size		I
132956292	N67309	10/22/2013	13:00	10/22/2013	13:30	1	30	30	Tree related-tree broken	Overhead Secondary	Reconnect		I
132956402	Q32170	10/22/2013	13:01	10/22/2013	14:33	16	1472	92	Animal related	Fuse	No Work Required		I
132956314	Q15845	10/22/2013	13:05	10/22/2013	13:48	1	43	43	Overhead equipment	Overhead Service			V
132956345	U93001	10/22/2013	13:12	10/22/2013	14:39	1	87	87	Tree related-tree broken	Overhead Service	Repair	Repair	II
132956369	N67309	10/22/2013	13:14	10/22/2013	14:19	157	10205	65	Tree related-tree contact	Overhead Primary	Patrol/Test/Inspect	No Work Required	I
132956391	L74193	10/22/2013	13:21	10/22/2013	13:58	4	148	37	Overhead equipment	Fuse	Replace - Same Size		IV
132956443	A97002	10/22/2013	13:35	10/22/2013	14:55	1	80	80	Overhead equipment	Disconnect Switch	Replace - Same Size		I
132956531	K43385	10/22/2013	13:49	10/22/2013	14:30	62	2542	41	Animal related	Fuse	Replace - Same Size		V
132957453	J07135	10/22/2013	13:58	10/22/2013	19:15	7	2219	317	Overhead equipment	Disconnect Switch	Cut in Clear	Repair	I
132956553	D88001	10/22/2013	13:58	10/22/2013	14:27	8	232	29	Overhead equipment	Other		Repair	I
132956568	N93260	10/22/2013	14:00	10/22/2013	14:38	4	152	38	Animal related	Other			III
132957139	K76546	10/22/2013	14:04	10/22/2013	16:24	48	6720	140	Animal related	Overhead Primary	Repair		IV
132956607	K09864	10/22/2013	14:08	10/22/2013	15:27	1	79	79	Overhead equipment				V
132956611	N67315	10/22/2013	14:09	10/22/2013	14:22	1	13	13	Overhead equipment	Recloser	Reconnect		I
132956711	M04365	10/22/2013	14:30	10/22/2013	16:05	1	95	95	Animal related	Fuse	Replace - Same Size		V
132956734	D31016	10/22/2013	14:33	10/22/2013	15:58	2	170	85	Underground equipment	Underground Connector	Replace - Same Size		III
132956791	P83710	10/22/2013	14:33	10/22/2013	17:42	302	57078	189	Tree related-tree broken	Overhead Primary	Patrol/Test/Inspect		I
132956885	U11531	10/22/2013	15:00	10/22/2013	16:24	1	84	84	Overhead equipment	Fuse	Repair	Repair	II
132956963	K28180	10/22/2013	15:14	10/22/2013	16:14	1	60	60	Unknown	Transformer Fuse	Replace - Same Size		III
132956994	K22173	10/22/2013	15:14	10/22/2013	17:00	17	1802	106	Overhead equipment	Overhead Primary	Repair	Repair	VI
132957000	K76543	10/22/2013	15:21	10/22/2013	18:06	1	165	165	Tree related-tree contact	Overhead Secondary	Repair	No Work Required	IV
132957002	L23148	10/22/2013	15:22	10/22/2013	16:50	1	88	88	Tree related-tree contact	Tree	Trim		III
132957018	V92555	10/22/2013	15:26	10/22/2013	16:49	1	83	83	Tree related-tree contact	Tree	Trim		II
132957048	A48004	10/22/2013	15:35	10/22/2013	17:10	1	95	95	Overhead equipment	Disconnect Switch	Replace - Same Size		I
132957061	Y98001	10/22/2013	15:40	10/22/2013	16:45	2	130	65	Overhead equipment	Animal Guard	Install	Replace - Same Size	IV
132957095	M36189	10/22/2013	15:46	10/22/2013	17:15	46	4094	89	Underground equipment	Underground Primary	Switch/Reset	Repair	I
132957094	J07135	10/22/2013	15:49	10/22/2013	19:30	1	221	221	Overhead equipment	Fuse	Replace - Same Size		I
132957058	V39003	10/22/2013	15:53	10/22/2013	16:45	1	52	52	Tree related-tree broken	Overhead Service	Repair	Repair	II
132957137	K76546	10/22/2013	16:00	10/22/2013	16:20	1110	22200	20	Animal related	Disconnect Switch	No Work Required		IV
132957158	L82187	10/22/2013	16:07	10/22/2013	18:20	1	133	133	Overhead equipment	Overhead Transformer	Replace - Same Size	No Work Required	IV
132957204	S79510	10/22/2013	16:24	10/22/2013	18:05	1	101	101	Animal related	Transformer Fuse			VI
132957283	D53002	10/22/2013	16:46	10/22/2013	18:12	1	86	86	Overhead equipment	Disconnect Switch	Repair		I
132957333	K28183	10/22/2013	17:00	10/22/2013	17:46	1	46	46	Unknown	Transformer Fuse	Replace - Same Size		III
132957352	Q28141	10/22/2013	17:07	10/22/2013	18:06	1	59	59	Animal related	Transformer Fuse	Replace - Same Size		VI
132957439	H31128	10/22/2013	17:34	10/22/2013	18:58	1	84	84	Public	Transformer Fuse	Replace - Same Size		VI
132957467	K09864	10/22/2013	17:44	10/22/2013	18:49	1	65	65	Animal related	Transformer Fuse	Replace - Same Size	Repair	V
132957489	J88163	10/22/2013	17:52	10/22/2013	21:19	1	207	207	Weather	Overhead Transformer		Replace - Same Size	VI
132957549	S14511	10/22/2013	18:19	10/22/2013	21:09	1	170	170	Overhead equipment	Overhead Secondary	Patrol/Test/Inspect	Repair	VI
132957623	M21134	10/22/2013	18:34	10/22/2013	20:02	37	3256	88	Overhead equipment	Fuse	Repair		VI
132957613	D55003	10/22/2013	18:37	10/22/2013	23:21	1	284	284	Tree related-tree broken	Tree			I
132958067	P77233	10/22/2013	19:31	10/22/2013	23:52	1	261	261	Overhead equipment	Overhead Transformer	Disconnect	Replace - Same Size	VI
132958211	J86108	10/22/2013	21:21	10/22/2013	22:20	7	413	59	Tree related-tree contact	Transformer Fuse	Replace - Same Size		VI
132958217	K55397	10/22/2013	21:23	10/23/2013	6:10	20	10540	527	Tree related-tree broken	Tree	Patrol/Test/Inspect	Trim	V
132958219	S49550	10/22/2013	21:27	10/22/2013	22:35	1	68	68	Tree related-tree contact	Fuse	Replace - Same Size		VI
132958220	307004	10/22/2013	21:29	10/22/2013	22:24	1	55	55	Tree related-tree contact	Overhead Service	Repair		VI
132958316	K71812	10/22/2013	21:55	10/23/2013	4:30	1	395	395	Tree related-tree contact	Tree	Patrol/Test/Inspect	Trim	IV
132958337	X88510	10/22/2013	22:41	10/22/2013	23:35	1	54	54	Tree related-tree contact	Transformer Fuse	Replace - Same Size		IV
132958343	B21004	10/22/2013	22:58	10/23/2013	4:22	1	324	324	Overhead equipment	Transformer Fuse	Replace - Same Size	Replace - Same Size	I
132960122	Y06544	10/23/2013	0:36	10/23/2013	1:49	138	10074	73	Overhead equipment	Lightning Arrestor	Replace - Same Size		IV
132964133	M04365	10/23/2013	6:05	10/23/2013	9:15	7	1330	190	Overhead equipment	Overhead Primary	Patrol/Test/Inspect	Repair	V
132964147	R65451	10/23/2013	6:23	10/23/2013	7:58	24	2280	95	Underground equipment	Underground Primary		Repair	IV