Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
143106810	L86176	11/06/2014	20:05	11/06/2014	23:56	1	231	231	Animal related	Fuse			IV
143106811	M19222	11/06/2014	20:06	11/07/2014	1:10	1	304	304	Overhead equipment	Overhead Transformer	Disconnect	Replace - Same Size	VI
143106870	M17374	11/06/2014	22:16	11/07/2014	7:43	1	567	567	Overhead equipment	Fuse		Repair	V
143114059	Y24737	11/07/2014	3:47	11/07/2014	5:26	805	79695	99	Animal related	Substation Misc.			IV
143114066	P98191	11/07/2014	3:55	11/07/2014	7:32	66	14322	217	Underground equipment	Underground Primary			III
143114080	P98191	11/07/2014	5:08	11/07/2014	6:48	14	1400	100	Underground equipment	Other			III
143114162	K09863	11/07/2014	6:55	11/07/2014	9:40	1	165	165	Animal related	Transformer Fuse	Replace - Same Size	Repair	V
143114175	D33143	11/07/2014	7:11	11/07/2014	8:45	1	94	94	Overhead equipment	Overhead Service	Repair		I
143114237	K07322	11/07/2014	7:33	11/07/2014	8:24	1	51	51	Unknown	Customer Equipment			I
143114265	N03299	11/07/2014	7:41	11/07/2014	9:30	1	109	109	Overhead equipment	Overhead Primary	Replace - Same Size	Repair	V
143114372	B44002	11/07/2014	8:04	11/07/2014	9:15	30	2130	71	Overhead equipment				I
143114343	U80511	11/07/2014	8:04	11/07/2014	9:30	1	86	86	Overhead equipment	Fuse	Replace - Same Size		II
143114476	L24124	11/07/2014	8:27	11/07/2014	9:11	21	924	44	Animal related	Fuse	Replace - Same Size		III
143114435	B81002	11/07/2014	8:27	11/07/2014	15:29	1	422	422	Underground equipment	Overhead Primary	Patrol/Test/Inspect	Repair	I
143114474	Y96564	11/07/2014	8:35	11/07/2014	9:18	1	43	43	Animal related	Transformer Fuse	Replace - Same Size		IV
143114491	A45003	11/07/2014	8:41	11/07/2014	9:49	1	68	68	Animal related	Other	Replace - Same Size		I
143114517	R04409	11/07/2014	8:46	11/07/2014	9:47	1	61	61	Overhead equipment	Fuse	Replace - New Size		V
143114533	Q11516	11/07/2014	8:48	11/07/2014	9:30	1	42	42	Overhead equipment	Connector	Replace - Same Size		I
143114591	A68002	11/07/2014	9:03	11/07/2014	10:52	5	545	109	Animal related	Transformer Fuse	Replace - Same Size		I
143114640	S42579	11/07/2014	9:11	11/07/2014	9:47	1	36	36	Animal related	Fuse	Replace - Same Size	Replace - Same Size	VI
143114650	Y45503	11/07/2014	9:15	11/07/2014	9:45	1	30	30	Overhead equipment	Transformer Fuse	Repair	Replace - Same Size	IV
143114677	HB5891	11/07/2014	9:19	11/07/2014	10:11	1	52	52	Animal related	Transformer Fuse	Replace - Same Size		I
143114688	Q75146	11/07/2014	9:21	11/07/2014	10:24	1	63	63	Overhead equipment	Transformer Fuse	Replace - Same Size		VI
143114687	Y93544	11/07/2014	9:21	11/07/2014	9:40	1	19	19	Overhead equipment	Transformer Fuse	Repair	Replace - Same Size	IV
143114706	P69175	11/07/2014	9:24	11/07/2014	9:49	1	25	25	Animal related	Fuse	Replace - Same Size		III
143114739	P58155	11/07/2014	9:29	11/07/2014	10:00	8	248	31	Overhead equipment	Transformer Fuse			VI
143114773	P60170	11/07/2014	9:33	11/07/2014	10:13	1	40	40	Animal related	Fuse	Repair	Repair	VI
143114781	K89143	11/07/2014	9:34	11/07/2014	10:16	27	1134	42	Animal related	Fuse	Replace - Same Size	Repair	III
143114838	U05595	11/07/2014	9:49	11/07/2014	14:30	1	281	281	Underground equipment	Underground Primary	Repair		II
143115042	B77003	11/07/2014	10:32	11/07/2014	12:00	108	9504	88	Overhead equipment	Overhead Primary			I
143116098	B77003	11/07/2014	10:32	11/07/2014	15:56	7	2268	324	Underground equipment	Underground Primary	Repair	Repair	I
143115098	J85160	11/07/2014	10:40	11/07/2014	11:46	30	1980	66	Animal related	Jumper	Replace - Same Size		VI
143115263	B93002	11/07/2014	10:47	11/07/2014	12:38	7	777	111	Animal related	Fuse	Replace - Same Size		I
143115131	D53001	11/07/2014	10:53	11/07/2014	11:48	1	55	55	Animal related	Transformer Fuse	Replace - Same Size	No Work Required	I
143115132	B00002	11/07/2014	10:54	11/07/2014	12:27	19	1767	93	Animal related	Transformer Fuse			I
143115211	H00163	11/07/2014	11:12	11/07/2014	11:44	68	2176	32	Animal related	Fuse			III
143115202	335003	11/07/2014	11:12	11/07/2014	13:00	1	108	108	Overhead equipment	Overhead Service	Repair		VI
143115454	B77003	11/07/2014	11:15	11/07/2014	13:50	7	1085	155	Underground equipment	Underground Primary	Repair	Repair	I
143115266	B84002	11/07/2014	11:25	11/07/2014	12:55	6	540	90	Overhead equipment	Fuse	Replace - Same Size		I
143115280	R07381	11/07/2014	11:26	11/07/2014	12:58	1	92	92	Animal related	Transformer Fuse	Replace - Same Size	Repair	I
143115326	B57001	11/07/2014	11:36	11/07/2014	12:26	1	50	50	Overhead equipment	Connector	Patrol/Test/Inspect	Replace - New Size	I
143115351	B77003	11/07/2014	11:42	11/07/2014	12:35	1	53	53	Underground equipment	Underground Primary		Repair	I
143115511	X75512	11/07/2014	11:44	11/07/2014	13:39	43	4945	115	Animal related	Disconnect Switch	Replace - Same Size		IV
143115363	J01119	11/07/2014	11:46	11/07/2014	13:45	1	119	119	Animal related	Connector	Replace - Same Size	Patrol/Test/Inspect	I
143115385	B77003	11/07/2014	11:49	11/07/2014	12:37	1	48	48	Underground equipment	Underground Primary		Repair	I
143115425	K43385	11/07/2014	12:01	11/07/2014	12:50	1	49	49	Animal related	Transformer Fuse	Replace - Same Size		V
143115432	H10843	11/07/2014	12:03	11/07/2014	13:13	1	70	70	Overhead equipment	Overhead Service	Repair		V
143115555	J79304	11/07/2014	12:38	11/07/2014	13:43	5	325	65	Animal related	Transformer Fuse	Replace - Same Size		I
143115580	B68002	11/07/2014	12:43	11/07/2014	13:05	4	88	22	Animal related	Transformer Fuse	Patrol/Test/Inspect	Patrol/Test/Inspect	III
143115615	B19002	11/07/2014	12:51	11/07/2014	14:10	1	79	79	Animal related	Transformer Fuse	Replace - Same Size	No Work Required	I
143115697	HB6283	11/07/2014	13:07	11/07/2014	17:36	1	269	269	Overhead equipment	Overhead Transformer		Replace - Same Size	VI
143115888	D48001	11/07/2014	13:20	11/07/2014	14:32	20	1440	72	Animal related	Fuse	Replace - Same Size		I
143115777	D28124	11/07/2014	13:23	11/07/2014	14:14	1	51	51	Unknown	Fuse	Replace - Same Size		I
143115803	J89125	11/07/2014	13:28	11/07/2014	14:42	4	296	74	Animal related	Fuse	Replace - Same Size		VI
143115824	L59929	11/07/2014	13:32	11/07/2014	15:38	1	126	126	Overhead equipment	Connector	Replace - New Size		VI
143115826	X09594	11/07/2014	13:33	11/07/2014	14:18	1	45	45	Overhead equipment	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	IV

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
143115907	X86546	11/07/2014	13:49	11/07/2014	14:10	1	21	21	Animal related	Transformer Fuse	Replace - Same Size		IV
143115963	U42512	11/07/2014	14:04	11/07/2014	16:45	1	161	161	Overhead equipment				II
143115981	S42579	11/07/2014	14:08	11/07/2014	14:45	1	37	37	Animal related	Transformer Fuse	Replace - Same Size	Replace - Same Size	VI
143115987	R41131	11/07/2014	14:13	11/07/2014	14:50	1	37	37	Animal related	Transformer Fuse	Replace - Same Size	No Work Required	VI
143116161	C70004	11/07/2014	14:54	11/07/2014	15:54	1	60	60	Animal related	Transformer Fuse	Replace - Same Size	No Work Required	III
143116194	M07236	11/07/2014	15:01	11/07/2014	16:36	1	95	95	Unknown	Transformer Fuse	Replace - Same Size		III
143116230	D55001	11/07/2014	15:11	11/07/2014	16:11	11	660	60	Animal related	Transformer Fuse	Replace - Same Size		I
143116340	Q74149	11/07/2014	15:50	11/07/2014	17:16	1	86	86	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
143116360	U91584	11/07/2014	15:57	11/07/2014	18:10	1	133	133	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Tie/Tighten	II
143116405	Z21564	11/07/2014	16:02	11/07/2014	17:07	59	3835	65	Animal related	Fuse	Repair	Replace - Same Size	IV
143116427	R60551	11/07/2014	16:35	11/07/2014	17:32	1	57	57	Overhead equipment	Jumper	Repair		IV
143116439	303004	11/07/2014	16:39	11/07/2014	16:49	1	10	10	Overhead equipment	Connector	Repair		VI
143116517	Q70161	11/07/2014	17:29	11/07/2014	18:50	1	81	81	Animal related	Transformer Fuse	Replace - Same Size		I
143116530	Z08509	11/07/2014	17:37	11/07/2014	18:55	1	78	78	Underground equipment	Lightning Arrestor	Repair	Replace - Same Size	IV
143116693	T06504	11/07/2014	17:47	11/07/2014	20:17	207	31050	150	Overhead equipment	Other	Repair	Repair	VI
143116668	H02256	11/07/2014	17:57	11/07/2014	22:25	1	268	268	Unknown	Other			III
143116719	D66001	11/07/2014	18:46	11/08/2014	0:45	1	359	359	Underground equipment	Underground Secondary		Repair	IV
143117149	M05360	11/07/2014	20:47	11/07/2014	21:11	1	24	24	Animal related	Transformer Fuse	Replace - Same Size		V
143117184	T12528	11/07/2014	22:08	11/07/2014	23:24	1	76	76	Overhead equipment	Transformer Fuse	Repair	Repair	VI
143120127	U90566	11/08/2014	7:08	11/08/2014	11:19	315	79065	251	Overhead equipment	Pole	Repair	Repair	II
143120094		11/08/2014	7:09	11/08/2014	11:21	1	252	252	Overhead equipment				II
143120119	V55524	11/08/2014	7:26	11/08/2014	9:30	1	124	124	Animal related	Transformer Fuse	Replace - Same Size		II
143120129	P77235	11/08/2014	7:39	11/08/2014	8:32	1	53	53	Animal related	Fuse	Replace - Same Size		VI
143120143	S49549	11/08/2014	7:50	11/08/2014	8:55	12	780	65	Animal related	Fuse	Replace - Same Size	Replace - Same Size	VI
143120148	B81002	11/08/2014	8:07	11/08/2014	8:59	34	1768	52	Overhead equipment	Fuse	Replace - Same Size		I
143120146	S25552	11/08/2014	8:07	11/08/2014	9:15	4	272	68	Animal related	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
143120161	R20502	11/08/2014	8:18	11/08/2014	11:38	1	200	200	Public	Overhead Transformer		Replace - Same Size	IV
143120173	Y41559	11/08/2014	8:24	11/08/2014	9:30	5	330	66	Animal related	Transformer Fuse	Repair	Patrol/Test/Inspect	IV
143120180	J99127	11/08/2014	8:39	11/08/2014	9:11	5	160	32	Animal related	Transformer Fuse	Replace - Same Size		VI
143120186	337002	11/08/2014	8:48	11/08/2014	10:30	1	102	102	Jurisdictional	Tree	Cut in Clear		VI
143120203	A80002	11/08/2014	9:06	11/08/2014	9:51	1	45	45	Animal related	Disconnect Switch	Replace - Same Size	Replace - Same Size	I
143120270	U01514	11/08/2014	9:24	11/08/2014	10:16	1	52	52	Overhead equipment	Transformer Fuse	Replace - Same Size	Replace - Same Size	II
143120271	B38002	11/08/2014	9:27	11/08/2014	10:50	1	83	83	Overhead equipment	Overhead Primary	Replace - Same Size	Replace - Same Size	I
143120278	A49001	11/08/2014	9:32	11/08/2014	10:03	1	31	31	Overhead equipment	Fuse	Replace - Same Size		I
143120290	N54214	11/08/2014	9:41	11/08/2014	13:42	52	12532	241	Underground equipment	Underground Primary	Switch/Reset	Repair	II
143120291	D70004	11/08/2014	9:44	11/08/2014	12:21	1	157	157	Tree related-tree broken	Overhead Service	Repair		I
143120308	V84531	11/08/2014	9:55	11/08/2014	10:53	6	348	58	Animal related	Transformer Fuse	Replace - Same Size		II
143120335	M36185	11/08/2014	10:12	11/08/2014	11:15	31	1953	63	Animal related	Fuse	Replace - Same Size		I
143120359	U05595	11/08/2014	10:46	11/08/2014	13:20	1	154	154	Tree related-tree broken	Overhead Primary	Repair		II
143120366	C50003	11/08/2014	10:57	11/08/2014	12:45	1	108	108	Public	Overhead Primary	Switch/Reset		III
143120474	C50003	11/08/2014	10:58	11/08/2014	13:42	5	820	164	Public	Overhead Primary	Repair		III
143120404	C50003	11/08/2014	10:59	11/08/2014	12:27	68	5984	88	Public	Overhead Primary	Repair		III
143120386	M21133	11/08/2014	11:10	11/08/2014	11:58	1	48	48	Animal related	Transformer Fuse	Replace - Same Size	No Work Required	VI
143120397	D48001	11/08/2014	11:15	11/08/2014	16:19	83	25232	304	Underground equipment	Underground Primary	Patrol/Test/Inspect	Reconnect	I
143120402	J83139	11/08/2014	11:20	11/08/2014	12:04	49	2156	44	Animal related	Fuse	Replace - Same Size		VI
143120419	M37191	11/08/2014	11:34	11/08/2014	12:25	15	765	51	Overhead equipment	Jumper	Repair		I
143120434	U33509	11/08/2014	11:57	11/08/2014	13:07	1	70	70	Animal related	Transformer Fuse	Replace - Same Size		II
143120439	D81001	11/08/2014	12:00	11/08/2014	13:46	39	4134	106	Animal related	Fuse	Replace - Same Size		I
143120504	Q95248	11/08/2014	12:10	11/08/2014	14:43	7	1071	153	Overhead equipment	Jumper		Repair	VI
143120472		11/08/2014	12:37	11/08/2014	13:48	1	71	71	Animal related	Fuse	Replace - Same Size		I
143120492	N50331	11/08/2014	13:09	11/08/2014	14:43	9	846	94	Animal related	Fuse	Replace - Same Size	No Work Required	II
143120493	R68903	11/08/2014	13:10	11/08/2014	14:20	1	70	70	Animal related	Transformer Fuse	Replace - Same Size		I
143120524	B38002	11/08/2014	13:35	11/08/2014	14:34	11	649	59	Overhead equipment	Overhead Secondary	Replace - Same Size	Replace - Same Size	I
143120531	U06551	11/08/2014	13:46	11/08/2014	16:52	12	2232	186	Animal related	Fuse	Replace - Same Size	No Work Required	II
143120560	M37191	11/08/2014	14:16	11/08/2014	15:00	15	660	44	Animal related	Fuse	Replace - Same Size		I
143120573	P18103	11/08/2014	14:35	11/08/2014	15:37	2	124	62	Animal related	Fuse		Replace - Same Size	IV

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
143120642	M05360	11/08/2014	14:46	11/09/2014	2:53	9	6543	727	Tree related-tree broken	Tree	Patrol/Test/Inspect		V
143120594	K28180	11/08/2014	14:55	11/08/2014	16:04	6	414	69	Unknown	Fuse	Replace - Same Size		III
143120599	S41564	11/08/2014	14:57	11/08/2014	16:31	1	94	94	Overhead equipment	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
143120603	K28180	11/08/2014	14:58	11/08/2014	16:02	30	1920	64	Unknown	Fuse	Replace - Same Size		III
143120609	R60551	11/08/2014	14:59	11/08/2014	17:55	32	5632	176	Underground equipment	Underground Primary	Replace - Same Size	Replace - Same Size	IV
143120608	J82116	11/08/2014	15:00	11/08/2014	15:53	1	53	53	Overhead equipment	Overhead Service	Replace - Same Size		VI
143120643	K09855	11/08/2014	15:23	11/08/2014	16:32	645	44505	69	Public	Overhead Primary		Repair	V
143120663	D48001	11/08/2014	15:30	11/08/2014	16:19	72	3528	49	Overhead equipment	Overhead Primary			I
143120694	S66590	11/08/2014	16:34	11/08/2014	17:14	1	40	40	Overhead equipment				VI
143120702	Q32170	11/08/2014	16:45	11/08/2014	19:06	1	141	141	Tree related-tree contact	Overhead Service	Repair	Repair	I
143120703	K48380	11/08/2014	16:52	11/08/2014	19:13	1	141	141	Animal related	Overhead Service		Replace - Same Size	V
143120716	B53001	11/08/2014	17:05	11/08/2014	17:50	8	360	45	Unknown	Fuse	Replace - Same Size		III
143120719	K09864	11/08/2014	17:08	11/08/2014	18:32	1	84	84	Overhead equipment	Connector	Replace - Same Size	Repair	V
143120721	S61581	11/08/2014	17:18	11/08/2014	17:25	1	7	7	Overhead equipment				VI
143120746	K32916	11/08/2014	18:15	11/08/2014	20:07	6	672	112	Animal related	Fuse	Replace - Same Size		VI
143120752	R28870	11/08/2014	18:25	11/08/2014	21:10	1	165	165	Overhead equipment	Overhead Secondary			V
143120773	P18103	11/08/2014	18:55	11/08/2014	22:42	2	454	227	Overhead equipment	Overhead Transformer		Replace - Same Size	IV
143120809	N03299	11/08/2014	20:42	11/08/2014	23:52	2	380	190	Overhead equipment	Overhead Service		Advise Customer	V
143120827	J85160	11/08/2014	23:17	11/09/2014	2:10	1	173	173	Underground equipment	Underground Service	Repair	Repair	VI
143120848	Q82907	11/08/2014	23:45	11/09/2014	0:45	1	60	60	Animal related	Fuse	Replace - Same Size		VI
143130023	S13549	11/09/2014	1:44	11/09/2014	4:20	1	156	156	Overhead equipment	Overhead Service	Patrol/Test/Inspect	Repair	VI
143130042	K39153	11/09/2014	5:49	11/09/2014	8:55	1	186	186	Overhead equipment	Overhead Transformer	Replace - New Size	Replace - New Size	III
143130053	P58156	11/09/2014	6:52	11/09/2014	8:09	1	77	77	Animal related	Fuse	Replace - Same Size		VI
143130059	K26136	11/09/2014	7:06	11/09/2014	8:45	2	198	99	Animal related	Transformer Fuse	Replace - Same Size	No Work Required	VI
143130071	J89125	11/09/2014	7:24	11/09/2014	9:30	17	2142	126	Animal related	Transformer Fuse	Replace - Same Size		VI
143130101	Y98532	11/09/2014	7:27	11/09/2014	9:24	8	936	117	Animal related	Animal Guard	Patrol/Test/Inspect	Replace - Same Size	IV
143130098	J89126	11/09/2014	7:55	11/09/2014	8:50	46	2530	55	Overhead equipment	Fuse	Replace - Same Size		VI
143130107	R10903	11/09/2014	8:03	11/09/2014	8:36	6	198	33	Overhead equipment	Overhead Transformer	Replace - Same Size		VI
143130110	D31016	11/09/2014	8:09	11/09/2014	8:54	6	270	45	Animal related	Fuse	Replace - Same Size		III
143130308	Q70161	11/09/2014	8:20	11/09/2014	10:09	300	32700	109	Overhead equipment	Overhead Primary			I
143130133	U92593	11/09/2014	8:22	11/09/2014	9:33	1	71	71	Overhead equipment	Transformer Fuse	Replace - Same Size	Replace - Same Size	II
143130148	Z21564	11/09/2014	8:29	11/09/2014	9:18	1	49	49	Animal related	Fuse	Repair	Replace - Same Size	IV
143130151	X57566	11/09/2014	8:30	11/09/2014	9:36	3	198	66	Animal related	Transformer Fuse	Replace - Same Size		IV
143130165	K89143	11/09/2014	8:40	11/09/2014	10:10	116	10440	90	Animal related	Fuse	Replace - Same Size		III
143130218	V26290	11/09/2014	8:42	11/09/2014	9:56	459	33966	74	Animal related	Substation Transformer	Switch/Reset		II
143130303		11/09/2014	8:42	11/09/2014	9:52	814	56980	70	Animal related	Substation Transformer	Switch/Reset		II
143130219	X96543	11/09/2014	8:47	11/09/2014	9:45	1	58	58	Animal related	Transformer Fuse	Repair	Patrol/Test/Inspect	IV
143130226	L99392	11/09/2014	8:53	11/09/2014	9:36	11	473	43	Animal related	Fuse	Replace - Same Size	Replace - Same Size	V
143130250	R05186	11/09/2014	9:03	11/09/2014	9:46	63	2709	43	Animal related	Fuse			I
143130239	V37583	11/09/2014	9:05	11/09/2014	11:37	1	152	152	Overhead equipment	Transformer Fuse	Repair	Repair	II
143130247	B19002	11/09/2014	9:12	11/09/2014	9:44	1	32	32	Unknown	Disconnect Switch	Replace - Same Size	Replace - Same Size	I
143130255	M26164	11/09/2014	9:16	11/09/2014	9:48	1	32	32	Animal related	Fuse	Replace - Same Size		III
143130271	M26164	11/09/2014	9:16	11/09/2014	9:48	23	736	32	Animal related	Fuse	Replace - Same Size		III
143130275	K69117	11/09/2014	9:37	11/09/2014	11:15	1	98	98	Animal related	Transformer Fuse	Repair	Repair	IV
143130295	C76002	11/09/2014	9:47	11/09/2014	11:10	80	6640	83	Animal related	Fuse	Replace - Same Size		I
143130291	J18268	11/09/2014	9:51	11/09/2014	10:35	4	176	44	Animal related	Transformer Fuse	Replace - Same Size		VI
143130299	X66580	11/09/2014	9:54	11/09/2014	10:50	1	56	56	Animal related	Transformer Fuse	Replace - Same Size		IV
143130300	A85002	11/09/2014	9:55	11/09/2014	15:20	1	325	325	Animal related	Transformer Fuse	Replace - Same Size		I
143130302	E10001	11/09/2014	9:56	11/09/2014	17:42	1	466	466	Underground equipment	Underground Primary			III
143130384	B81003	11/09/2014	10:14	11/09/2014	12:32	7	966	138	Underground equipment	Underground Primary	Switch/Reset		I
143130280	Q91141	11/09/2014	10:16	11/09/2014	14:37	1	261	261	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	I
143130313	B81003	11/09/2014	10:19	11/09/2014	13:00	4	644	161	Underground equipment	Underground Primary	Switch/Reset		I
143130332	M42107	11/09/2014	10:54	11/09/2014	12:35	7	707	101	Animal related	Transformer Fuse	Replace - Same Size		I
143130342	Q93522	11/09/2014	11:11	11/09/2014	13:20	1	129	129	Animal related	Transformer Fuse	Replace - Same Size		I
143130344	C66001	11/09/2014	11:13	11/09/2014	12:57	1	104	104	Overhead equipment	Overhead Service	Tie/Tighten	No Work Required	III
143130346	D41002	11/09/2014	11:16	11/09/2014	12:23	1	67	67	Animal related	Disconnect Switch	Replace - Same Size	Replace - Same Size	I

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
143130350	X92508	11/09/2014	11:26	11/09/2014	12:50	1	84	84	Animal related	Animal Guard	Repair	Replace - Same Size	IV
143130351	L63936	11/09/2014	11:31	11/09/2014	12:43	8	576	72	Animal related	Fuse	Replace - Same Size		VI
143130358	Q93522	11/09/2014	11:32	11/09/2014	15:23	18	4158	231	Overhead equipment	Overhead Primary	Repair		I
143130361	R84148	11/09/2014	11:52	11/09/2014	13:20	1	88	88	Animal related	Fuse	Replace - Same Size	Replace - Same Size	I
143130370	P20930	11/09/2014	12:20	11/09/2014	13:54	1	94	94	Animal related	Fuse	Replace - Same Size		VI
143130376	B84002	11/09/2014	12:30	11/09/2014	13:50	42	3360	80	Animal related	Fuse	Replace - Same Size		I
143130378		11/09/2014	12:31	11/09/2014	13:34	1	63	63	Animal related	Transformer Fuse	Replace - Same Size	Replace - Same Size	V
143130524	D72002	11/09/2014	13:04	11/09/2014	13:38	12	408	34	Unknown	Transformer Fuse	Replace - Same Size	Replace - Same Size	I
143130534	A49001	11/09/2014	13:37	11/09/2014	14:25	5	240	48	Animal related	Transformer Fuse	Replace - Same Size		I
143130541	V89523	11/09/2014	13:49	11/09/2014	15:56	2	254	127	Animal related	Transformer Fuse	Replace - Same Size		II
143130549	310124	11/09/2014	14:11	11/09/2014	14:43	7	224	32	Animal related	Fuse	Replace - Same Size	No Work Required	V
143130554	M09175	11/09/2014	14:20	11/09/2014	16:05	1	105	105	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	VI
143130557	J79304	11/09/2014	14:36	11/09/2014	15:54	1	78	78	Animal related	Fuse	Replace - Same Size		I
143130563	V10551	11/09/2014	14:52	11/09/2014	15:28	1	36	36	Animal related	Transformer Fuse	Replace - Same Size		II
143130581	B84004	11/09/2014	15:31	11/09/2014	16:41	1	70	70	Overhead equipment	Fuse	Replace - Same Size		I
143130582	J50185	11/09/2014	15:35	11/09/2014	21:07	1	332	332	Underground equipment	Underground Service			III
143130597	Q04411	11/09/2014	15:54	11/09/2014	16:40	11	506	46	Animal related	Fuse			III
143130606	M04364	11/09/2014	16:31	11/09/2014	17:27	12	672	56	Animal related	Transformer Fuse	Replace - Same Size	Replace - Same Size	V
143130652	K01239	11/09/2014	17:11	11/09/2014	19:03	5	560	112	Overhead equipment	Transformer Fuse	Replace - Same Size		VI
143130654	J88166	11/09/2014	17:11	11/09/2014	19:50	1	159	159	Overhead equipment	Fuse	Replace - Same Size		VI
143130667	V92542	11/09/2014	17:37	11/09/2014	19:51	1	134	134	Overhead equipment	Transformer Fuse	Replace - Same Size	Replace - Same Size	II
143130670	F03003	11/09/2014	17:43	11/09/2014	19:14	1	91	91	Public	Fuse	Replace - Same Size	No Work Required	III
143130695	D69006	11/09/2014	18:41	11/09/2014	19:24	1	43	43	Unknown	Fuse	Repair		I
143130711	B73002	11/09/2014	19:13	11/09/2014	19:50	1	37	37	Unknown	Fuse	Repair		I
143130728	L18261	11/09/2014	20:16	11/09/2014	20:55	1	39	39	Unknown	Transformer Fuse	Replace - Same Size		III
143140130	L99392	11/10/2014	0:29	11/10/2014	2:19	1	110	110	Animal related	Transformer Fuse	Replace - New Size		V
143140143	B38001	11/10/2014	2:14	11/10/2014	5:22	1	188	188	Overhead equipment	Connector	Replace - Same Size		I
143143382	K65221	11/10/2014	5:05	11/10/2014	7:27	2	284	142	Animal related	Transformer Fuse	Repair	Repair	III
143143390	N13861	11/10/2014	5:58	11/10/2014	7:31	1	93	93	Overhead equipment	Transformer Fuse	Replace - Same Size		V
143143406	Z61565	11/10/2014	6:05	11/10/2014	7:44	1	99	99	Animal related	Transformer Fuse	Replace - Same Size		IV
143143427	E10001	11/10/2014	6:08	11/10/2014	6:44	220	7920	36	Overhead equipment	Recloser			III
143143428	A36001	11/10/2014	6:28	11/10/2014	12:28	1	360	360	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
143143430	E10001	11/10/2014	6:30	11/10/2014	7:10	1	40	40	Overhead equipment	Recloser	Patrol/Test/Inspect	Patrol/Test/Inspect	III
143143432	S62520	11/10/2014	6:32	11/10/2014	7:20	1	48	48	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	VI
143143488	T06504	11/10/2014	7:12	11/10/2014	8:30	1	78	78	Overhead equipment	Overhead Primary	Repair	Repair	VI
143143524	A36001	11/10/2014	7:19	11/10/2014	8:04	35	1575	45	Overhead equipment	Fuse	Repair		I
143143510	C50002	11/10/2014	7:22	11/10/2014	7:50	1	28	28	Animal related	Fuse	Replace - Same Size	Repair	III
143143542	K58213	11/10/2014	7:30	11/10/2014	8:30	1	60	60	Overhead equipment	Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
143143554	Q74148	11/10/2014	7:33	11/10/2014	8:30	1	57	57	Animal related	Fuse	Repair		IV
143143658	J06168	11/10/2014	8:02	11/10/2014	9:25	1	83	83	Overhead equipment	Disconnect Switch	Replace - Same Size		I
143143704	HB5891	11/10/2014	8:12	11/10/2014	9:09	1	57	57	Overhead equipment	Fuse	Replace - Same Size		I
143143763	L71171	11/10/2014	8:17	11/10/2014	9:11	24	1296	54	Animal related	Fuse	Replace - Same Size		IV
143143731	P98190	11/10/2014	8:18	11/10/2014	9:32	4	296	74	Animal related	Transformer Fuse	Repair	Repair	III
143143808	D36001	11/10/2014	8:36	11/10/2014	10:04	1	88	88	Overhead equipment	Overhead Service	Repair		I
143143810	X86543	11/10/2014	8:36	11/10/2014	10:15	1	99	99	Animal related	Transformer Fuse	Replace - Same Size		IV
143143846	B45004	11/10/2014	8:45	11/10/2014	11:17	10	1520	152	Overhead equipment	Overhead Primary		Repair	I
143143890	R66470	11/10/2014	8:46	11/10/2014	9:53	36	2412	67	Animal related	Fuse			IV
143143855	B45004	11/10/2014	8:48	11/10/2014	9:00	1	12	12	Overhead equipment				I
143143892	P77235	11/10/2014	8:53	11/10/2014	9:41	1	48	48	Animal related	Fuse	Switch/Reset		VI
143143992	K95204	11/10/2014	9:12	11/10/2014	10:14	1	62	62	Tree related-tree contact	Overhead Service	Repair		III
143144009	P47120	11/10/2014	9:14	11/10/2014	13:24	1	250	250	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	I
143144080	J80807	11/10/2014	9:23	11/10/2014	10:14	35	1785	51	Animal related	Fuse	Replace - Same Size	Replace - Same Size	V
143144106	A56013	11/10/2014	9:34	11/10/2014	10:20	10	460	46	Animal related	Transformer Fuse	Replace - Same Size		I
143144145	HB6283	11/10/2014	9:41	11/10/2014	10:17	1	36	36	Overhead equipment	Fuse			VI
143144144	Q74148	11/10/2014	9:41	11/10/2014	10:28	1	47	47	Overhead equipment	Transformer Fuse	Repair		IV
143144192	A45002	11/10/2014	9:44	11/10/2014	11:21	75	7275	97	Overhead equipment				I

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
143144344	Q70160	11/10/2014	10:20	11/10/2014	11:22	1	62	62	Animal related	Transformer Fuse	Replace - Same Size		I
143144351	Y23521	11/10/2014	10:21	11/10/2014	10:48	1	27	27	Overhead equipment	Fuse	Repair		IV
143144439	R59422	11/10/2014	10:37	11/10/2014	11:41	1	64	64	Animal related	Overhead Service		Replace - Urgent	IV
143144452	M41113	11/10/2014	10:40	11/10/2014	11:20	1	40	40	Animal related	Fuse	Replace - Same Size		I
143144524	Q01281	11/10/2014	10:51	11/10/2014	11:48	47	2679	57	Overhead equipment	Jumper	Repair	Repair	III
143144541	S25551	11/10/2014	11:02	11/10/2014	12:10	1	68	68	Overhead equipment	Fuse	Repair	Repair	VI
143144584	A17025	11/10/2014	11:12	11/10/2014	12:21	1	69	69	Overhead equipment	Fuse	Replace - Same Size		I
143144588	P54828	11/10/2014	11:13	11/10/2014	12:16	1	63	63	Animal related	Fuse	Replace - Same Size		V
143144656	L35282	11/10/2014	11:27	11/10/2014	13:38	1	131	131	Tree related-tree contact	Overhead Service	Repair		III
143144739	K94223	11/10/2014	11:47	11/10/2014	12:28	1	41	41	Tree related-tree contact	Overhead Service	Repair		III
143144841	J84145	11/10/2014	12:13	11/10/2014	12:52	138	5382	39	Overhead equipment	Fuse	Repair	Repair	VI
143144842	U33509	11/10/2014	12:14	11/10/2014	13:15	1	61	61	Animal related	Transformer Fuse	Replace - Same Size		II
143144864		11/10/2014	12:20	11/10/2014	13:09	1	49	49	Overhead equipment	Fuse	Repair	Repair	VI
143144926	J84146	11/10/2014	12:33	11/10/2014	13:52	1	79	79	Overhead equipment				VI
143144931	J84146	11/10/2014	12:33	11/10/2014	13:40	10	670	67	Overhead equipment	Connector	Repair		VI
143144982	U06524	11/10/2014	12:47	11/10/2014	15:15	1	148	148	Underground equipment	Underground Service	Repair		II
143145024	341002	11/10/2014	12:57	11/10/2014	14:07	1	70	70	Tree related-tree broken	Overhead Transformer	Repair		VI
143145050	K67911	11/10/2014	13:01	11/10/2014	14:14	1	73	73	Tree related-tree broken	Overhead Service		Repair	VI
143145058	329147	11/10/2014	13:02	11/10/2014	15:20	1	138	138	Tree related-tree broken	Overhead Secondary	Patrol/Test/Inspect		V
143145197	K43386	11/10/2014	13:07	11/10/2014	14:45	43	4214	98	Tree related-tree broken	Fuse	Replace - Same Size	Replace - Same Size	V
143145371	P09304	11/10/2014	13:16	11/10/2014	17:00	4	896	224	Tree related-tree broken	Overhead Primary	Repair		V
143145150	N70330	11/10/2014	13:19	11/10/2014	13:59	1	40	40	Animal related	Transformer Fuse	Replace - Same Size	Replace - Same Size	I
143145166	A85001	11/10/2014	13:22	11/10/2014	14:12	1	50	50	Animal related	Transformer Fuse	Replace - Same Size	No Work Required	I
143145200	V20502	11/10/2014	13:29	11/10/2014	14:07	5	190	38	Animal related	Transformer Fuse			II
143145219	U60559	11/10/2014	13:31	11/10/2014	16:11	1	160	160	Tree related-tree broken	Overhead Service	Repair	Reconnect	II
143145226	J71128	11/10/2014	13:32	11/10/2014	15:35	1	123	123	Overhead equipment	Overhead Service	Repair	Repair	I
143145302	S60581	11/10/2014	13:37	11/10/2014	14:30	382	20246	53	Public				VI
143145244	P47120	11/10/2014	13:37	11/10/2014	14:33	1	56	56	Animal related	Transformer Fuse	Replace - Same Size		I
143145421	P98193	11/10/2014	14:03	11/10/2014	14:32	1	29	29	Animal related	Fuse			III
143145821	K11372	11/10/2014	14:15	11/10/2014	18:24	1	249	249	Tree related-tree broken	Tree	Remove		V
143145492	J99141	11/10/2014	14:17	11/10/2014	15:08	1	51	51	Tree related-tree broken	Tree			VI
143145534	P98190	11/10/2014	14:24	11/10/2014	14:50	1	26	26	Overhead equipment	Overhead Service			III
143145563	N13860	11/10/2014	14:31	11/10/2014	15:57	1	86	86	Overhead equipment	Jumper	Repair		V
143145575	S04545	11/10/2014	14:31	11/10/2014	16:25	1	114	114	Overhead equipment	Overhead Service	Patrol/Test/Inspect	Repair	VI
143145576	S60581	11/10/2014	14:32	11/10/2014	18:25	2	466	233	Public	Overhead Secondary	Repair		VI
143145665	P26284	11/10/2014	14:43	11/10/2014	17:40	2	354	177	Tree related-tree contact	Overhead Primary	Replace - Same Size	Repair	I
143145672	L62928	11/10/2014	14:44	11/10/2014	16:27	1	103	103	Overhead equipment	Connector	Repair		VI
143145675	P98192	11/10/2014	14:46	11/10/2014	15:11	1	25	25	Animal related	Fuse			III
143145739	V65549	11/10/2014	14:58	11/10/2014	19:16	10	2580	258	Overhead equipment	Pole			II
143145731	X88502	11/10/2014	14:58	11/10/2014	15:42	1	44	44	Animal related	Transformer Fuse	Replace - Same Size		IV
143145853	S60581	11/10/2014	15:30	11/10/2014	16:56	1	86	86	Tree related-tree broken	Tree	Patrol/Test/Inspect	Remove	VI
143145928	Q82906	11/10/2014	15:52	11/10/2014	17:36	1	104	104	Overhead equipment	Overhead Service	Repair		VI
143145950	L99392	11/10/2014	16:01	11/10/2014	18:58	24	4248	177	Overhead equipment	Overhead Primary	Patrol/Test/Inspect		V
143146000	J86118	11/10/2014	16:15	11/10/2014	17:24	1	69	69	Tree related-tree broken	Overhead Service	Repair		VI
143146002	D55001	11/10/2014	16:17	11/10/2014	21:18	1	301	301	Underground equipment	Underground Primary	Repair	Repair	I
143146030	N86227	11/10/2014	16:29	11/10/2014	18:06	1	97	97	Tree related-tree broken	Tree	Remove		VI
143146035	P26284	11/10/2014	16:32	11/10/2014	18:55	1	143	143	Overhead equipment	Jumper	Replace - Same Size	Repair	I
143146066	P98192	11/10/2014	16:47	11/10/2014	18:25	10	980	98	Animal related	Fuse			III
143146276	N05172	11/10/2014	17:25	11/10/2014	18:42	1	77	77	Overhead equipment	Fuse	Repair	Repair	I
143146280	N44217	11/10/2014	17:27	11/10/2014	19:07	1	100	100	Overhead equipment	Overhead Transformer			III
143146396	V23592	11/10/2014	18:56	11/10/2014	20:05	1	69	69	Animal related	Transformer Fuse	Repair		II
143146641	Q54908	11/10/2014	19:15	11/10/2014	23:45	1	270	270	Tree related-tree broken	Overhead Service		Replace - Same Size	VI
143146944	334004	11/10/2014	21:22	11/10/2014	22:25	29	1827	63	Overhead equipment	Disconnect Switch	Cut in Clear	Replace - Same Size	VI
143146981	U06524	11/10/2014	22:56	11/11/2014	4:13	45	14265	317	Underground equipment	Underground Primary		Switch/Reset	II
143150065	D32211	11/10/2014	23:24	11/11/2014	5:29	36	13140	365	Overhead equipment	Overhead Primary		Repair	I
143147004	D32211	11/10/2014	23:42	11/11/2014	2:19	27	4239	157	Overhead equipment	Overhead Primary		Repair	I

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
143150092	B79002	11/11/2014	3:07	11/11/2014	4:32	1	85	85	Overhead equipment				I
143150122	P54827	11/11/2014	4:52	11/11/2014	7:12	1	140	140	Overhead equipment	Overhead Secondary	Repair		V
143150144	Q16867	11/11/2014	5:50	11/11/2014	7:53	16	1968	123	Animal related	Fuse	Replace - Same Size	No Work Required	V
143150264	X02546	11/11/2014	6:43	11/11/2014	8:57	1	134	134	Overhead equipment	Fuse			IV
143150265	M09144	11/11/2014	6:43	11/11/2014	7:29	1	46	46	Animal related	Fuse	Replace - Same Size	Repair	VI
143150280	S47575	11/11/2014	7:03	11/11/2014	8:00	1	57	57	Overhead equipment	Fuse	Replace - Same Size		VI
143150303	Q54908	11/11/2014	7:42	11/11/2014	12:45	1	303	303	Tree related-tree broken	Overhead Service	Replace - New Size	Repair	VI
143150472	A68001	11/11/2014	8:11	11/11/2014	13:23	7	2184	312	Public	Pole	Replace - Same Size	No Work Required	I
143150335	A68001	11/11/2014	8:11	11/11/2014	9:29	19	1482	78	Public	Pole	Switch/Reset	No Work Required	I
143150346	M41111	11/11/2014	8:13	11/11/2014	9:10	32	1824	57	Animal related	Fuse	Replace - Same Size		I
143150331	T08501	11/11/2014	8:15	11/11/2014	9:45	1	90	90	Animal related	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
143150363	D55002	11/11/2014	8:33	11/11/2014	11:38	1	185	185	Overhead equipment	Disconnect Switch	Replace - New Size	No Work Required	I
143150395	X69555	11/11/2014	8:56	11/11/2014	12:20	1	204	204	Overhead equipment	Transformer Fuse			IV
143150407	X49568	11/11/2014	9:05	11/11/2014	10:25	1	80	80	Overhead equipment	Transformer Fuse			IV
143150438	M26164	11/11/2014	9:16	11/11/2014	11:19	1	123	123	Underground equipment	Underground Transformer	Replace - Same Size		III
143150436	B58001	11/11/2014	9:17	11/11/2014	11:14	1	117	117	Overhead equipment	Transformer Fuse	Replace - Same Size	No Work Required	I
143150460	L99392	11/11/2014	9:29	11/11/2014	11:50	1	141	141	Overhead equipment	Fuse	Repair		V
143150473	S92559	11/11/2014	9:42	11/11/2014	11:17	1	95	95	Overhead equipment	Connector	Replace - Same Size		VI
143150510	P57108	11/11/2014	10:07	11/11/2014	10:35	26	728	28	Animal related	Fuse	Repair	Repair	VI
143150511	D92001	11/11/2014	10:08	11/11/2014	11:56	1	108	108	Animal related	Transformer Fuse	Replace - Same Size	No Work Required	I
143150525	B21002	11/11/2014	10:14	11/11/2014	12:52	1	158	158	Public				I
143150543	X60598	11/11/2014	10:28	11/11/2014	12:25	1	117	117	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
143150551	S36570	11/11/2014	10:35	11/11/2014	12:46	1	131	131	Animal related	Fuse	Repair		VI
143150605	M36189	11/11/2014	11:10	11/11/2014	12:00	1	50	50	Overhead equipment	Transformer Fuse			I
143150603	Y24523	11/11/2014	11:11	11/11/2014	13:30	1	139	139	Animal related	Disconnect Switch	Replace - Same Size		IV
143150611	M25144	11/11/2014	11:13	11/11/2014	11:39	1	26	26	Overhead equipment	Fuse	Replace - Same Size	No Work Required	IV
143150635	R93351	11/11/2014	11:38	11/11/2014	16:20	1	282	282	Overhead equipment	Overhead Transformer	Cut in Clear	Replace - Same Size	V
143150783	S01501	11/11/2014	11:46	11/11/2014	13:19	587	54591	93	Overhead equipment	Disconnect Switch	Repair		VI
143150700	J58381	11/11/2014	12:14	11/11/2014	13:02	1	48	48	Overhead equipment	Jumper	Repair	Repair	III
143150724	F22001	11/11/2014	12:36	11/11/2014	13:23	1	47	47	Overhead equipment	Transformer Fuse	Repair		IV
143150796	K31124	11/11/2014	13:33	11/11/2014	15:20	1	107	107	Overhead equipment	Connector	Repair		I
143150974	J61117	11/11/2014	13:45	11/11/2014	16:40	89	15575	175	Overhead equipment	Overhead Primary	Repair	Repair	III
143150824	M42107	11/11/2014	13:56	11/11/2014	15:46	1	110	110	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	I
143150834	K76545	11/11/2014	14:05	11/11/2014	15:11	1	66	66	Overhead equipment		No Work Required	No Work Required	IV
143150886	B00004	11/11/2014	14:15	11/11/2014	15:18	27	1701	63	Overhead equipment	Fuse	Repair	Replace - New Size	I
143150870	P17108	11/11/2014	14:32	11/11/2014	17:16	5	820	164	Tree related-tree broken	Overhead Primary		Repair	IV
143150884	B65004	11/11/2014	14:47	11/11/2014	22:57	1	490	490	Underground equipment	Underground Primary	Patrol/Test/Inspect	Patrol/Test/Inspect	I
143150894	S15567	11/11/2014	14:56	11/11/2014	16:17	1	81	81	Animal related	Overhead Transformer			VI
143150945	U90566	11/11/2014	15:51	11/11/2014	16:30	1	39	39	Overhead equipment	Connector	Repair		II
143150951	Z61524	11/11/2014	15:56	11/11/2014	17:26	1	90	90	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
143150985	Y20522	11/11/2014	16:28	11/11/2014	18:30	1	122	122	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
143150997	K71812	11/11/2014	16:55	11/11/2014	18:35	1	100	100	Tree related-tree broken	Overhead Service	Patrol/Test/Inspect	Repair	IV
143151010	R60552	11/11/2014	17:13	11/11/2014	20:39	1	206	206	Underground equipment	Underground Service	Patrol/Test/Inspect	Repair	IV
143151016	Y26520	11/11/2014	17:14	11/11/2014	18:30	19	1444	76	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	IV
143151171	X64001	11/11/2014	17:33	11/12/2014	2:22	7	3703	529	Overhead equipment	Pole			IV
143151059	M61302	11/11/2014	17:39	11/11/2014	18:29	1	50	50	Overhead equipment	Transformer Fuse	Repair		V
143151063	M04364	11/11/2014	17:42	11/11/2014	18:24	1	42	42	Overhead equipment	Overhead Service	Repair		V
143151113	X64001	11/11/2014	18:14	11/11/2014	19:21	190	12730	67	Overhead equipment				IV
143151150	R10925	11/11/2014	19:02	11/11/2014	20:45	4	412	103	Animal related	Fuse	Replace - Same Size	Replace - Same Size	VI
143151195	V84531	11/11/2014	20:10	11/11/2014	22:00	1	110	110	Other				II
143151205	V55524	11/11/2014	20:34	11/11/2014	21:27	1	53	53	Animal related	Transformer Fuse	Replace - Same Size		II
143151236	K76543	11/11/2014	21:32	11/11/2014	22:18	1273	58558	46	Public	Overhead Primary	Patrol/Test/Inspect		IV
143151247	S47576	11/11/2014	21:54	11/11/2014	23:00	1	66	66	Overhead equipment	Fuse	Replace - Same Size		VI
143151259	N67309	11/11/2014	23:24	11/12/2014	0:26	1	62	62	Overhead equipment	Connector	Replace - Same Size	Replace - Same Size	I
143160132	S86580	11/12/2014	0:32	11/12/2014	5:35	1	303	303	Overhead equipment	Overhead Transformer	Replace - Same Size		VI
143160163	342003	11/12/2014	2:03	11/12/2014	2:54	1	51	51	Overhead equipment	Overhead Transformer	Switch/Reset		VI

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
143160162	342003	11/12/2014	2:04	11/12/2014	2:54	1	50	50	Overhead equipment	Overhead Transformer	Switch/Reset		VI
143163460	K15205	11/12/2014	4:43	11/12/2014	6:04	1	81	81	Overhead equipment	Customer Equipment	Repair	Repair	VI
143163474	S63291	11/12/2014	5:45	11/12/2014	6:17	1324	42368	32	Substation equipment				VI
143163806	N60181	11/12/2014	7:06	11/12/2014	8:10	772	49408	64	Overhead equipment	Jumper	Repair		I
143163691	N72240	11/12/2014	7:09	11/12/2014	8:07	1	58	58	Overhead equipment	Transformer Fuse		Replace - Same Size	III
143163746	S15558	11/12/2014	7:17	11/12/2014	8:20	1	63	63	Animal related	Transformer Fuse		Replace - Same Size	VI
143163792	K28180	11/12/2014	7:23	11/12/2014	9:27	1	124	124	Overhead equipment	Connector	Repair		III
143163978	X60596	11/12/2014	8:22	11/12/2014	9:15	1	53	53	Animal related	Transformer Fuse	Replace - Same Size		IV
143163990	Y11556	11/12/2014	8:25	11/12/2014	9:32	7	469	67	Animal related	Transformer Fuse	Repair	Replace - Same Size	IV
143164100	L16212	11/12/2014	8:47	11/12/2014	10:59	1	132	132	Tree related-tree contact	Overhead Service	Repair		III
143164230	M36184	11/12/2014	9:12	11/12/2014	9:47	1	35	35	Animal related	Overhead Transformer	Switch/Reset		I
143164273	L81141	11/12/2014	9:22	11/12/2014	10:16	26	1404	54	Overhead equipment	Overhead Primary			IV
143164401	X09534	11/12/2014	9:47	11/12/2014	10:43	1	56	56	Animal related	Disconnect Switch	Replace - Same Size		IV
143164551	V39002	11/12/2014	10:14	11/12/2014	11:02	1	48	48	Overhead equipment	Overhead Service	Replace - Same Size	Replace - Same Size	II
143164649	M26161	11/12/2014	10:35	11/12/2014	11:07	1	32	32	Overhead equipment	Overhead Service	Repair		III
143164715	Y31589	11/12/2014	10:45	11/12/2014	11:49	1	64	64	Overhead equipment	Overhead Secondary	Repair		IV
143164867	H00162	11/12/2014	11:09	11/12/2014	12:03	1	54	54	Overhead equipment	Connector	Repair	Repair	III
143165505	H22346	11/12/2014	13:43	11/12/2014	16:50	1	187	187	Tree related-tree contact	Overhead Service	Patrol/Test/Inspect	Repair	V
143165638	Y51506	11/12/2014	14:10	11/12/2014	14:29	1	19	19	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
143165667	V28597	11/12/2014	14:17	11/12/2014	14:57	1	40	40	Overhead equipment	Transformer Fuse	Replace - Same Size		II
143165925	349001	11/12/2014	15:23	11/12/2014	17:40	1	137	137	Overhead equipment	Overhead Primary	Patrol/Test/Inspect	Replace - Same Size	VI
143165965	K46388	11/12/2014	15:39	11/12/2014	17:20	1	101	101	Overhead equipment	Disconnect Switch	Cut in Clear	Repair	V
143166005	K69117	11/12/2014	15:51	11/12/2014	20:13	1	262	262	Underground equipment	Underground Service	Patrol/Test/Inspect	Repair	IV
143166488	X92508	11/12/2014	18:47	11/12/2014	21:48	11	1991	181	Overhead equipment	Overhead Transformer	Repair	Replace - Same Size	IV
143166500	J80806	11/12/2014	18:55	11/12/2014	20:32	1	97	97	Overhead equipment	Meter	Repair	Repair	V
143166869	X74776	11/12/2014	20:07	11/12/2014	20:39	1	32	32	Overhead equipment	High Line Switch	Repair	Repair	IV
143166900	A81004	11/12/2014	20:22	11/12/2014	23:40	10	1980	198	Overhead equipment	Overhead Primary	Repair		I
143166892	P12290	11/12/2014	20:55	11/12/2014	22:23	1	88	88	Overhead equipment	Connector	Repair		V
143166913	K73362	11/12/2014	21:22	11/12/2014	22:55	12	1116	93	Public				IV
143166937	J61113	11/12/2014	22:49	11/13/2014	0:01	1	72	72	Overhead equipment	Overhead Service			III
143166939	R60551	11/12/2014	23:15	11/13/2014	0:03	4	192	48	Overhead equipment	Transformer Fuse	Replace - Same Size	No Work Required	IV
143170157	T08501	11/13/2014	2:25	11/13/2014	3:00	1	35	35	Public				VI
143174508	R94269	11/13/2014	7:21	11/13/2014	8:45	1	84	84	Animal related	Animal Guard	Patrol/Test/Inspect	Replace - Same Size	VI
143174605	M04364	11/13/2014	7:59	11/13/2014	8:38	1	39	39	Animal related	Fuse	Replace - Same Size		V
143174637	R59422	11/13/2014	8:08	11/13/2014	8:38	1	30	30	Animal related	Transformer Fuse	Replace - Same Size	No Work Required	IV
143174665	V20502	11/13/2014	8:17	11/13/2014	11:27	1	190	190	Unknown	Overhead Service	Repair		II
143174740	D90004	11/13/2014	8:38	11/13/2014	9:19	54	2214	41	Jurisdictional	Overhead Primary	Repair	Patrol/Test/Inspect	III
143174766	P09307	11/13/2014	8:43	11/13/2014	12:30	3	681	227	Overhead equipment	Disconnect Switch	Replace - Same Size	Replace - Same Size	V
143174941	V20502	11/13/2014	9:24	11/13/2014	10:31	3	201	67	Animal related	Transformer Fuse	Replace - Same Size		II
143175051	H06135	11/13/2014	9:43	11/13/2014	11:48	13	1625	125	Tree related-tree broken	Overhead Primary	Repair	No Work Required	IV
143175045	N44215	11/13/2014	9:43	11/13/2014	10:15	1	32	32	Overhead equipment	Fuse	Repair	Repair	III
143175272	J08206	11/13/2014	10:29	11/13/2014	11:28	1	59	59	Animal related	Transformer Fuse	Replace - Same Size		I
143175338	R07382	11/13/2014	10:43	11/13/2014	11:17	1	34	34	Animal related	Fuse	Replace - Same Size	Replace - Same Size	I
143175477	S27598	11/13/2014	11:15	11/13/2014	11:47	1	32	32	Animal related	Transformer Fuse			VI
143175482	T02534	11/13/2014	11:17	11/13/2014	12:30	1	73	73	Overhead equipment	Overhead Service	Tie/Tighten	Tie/Tighten	VI
143175565	J14140	11/13/2014	11:37	11/13/2014	12:32	1	55	55	Overhead equipment	Fuse			VI
143175627	J85161	11/13/2014	11:56	11/13/2014	12:27	1	31	31	Animal related	Transformer Fuse			VI
143175667	K15205	11/13/2014	12:06	11/13/2014	12:48	1	42	42	Animal related	Transformer Fuse	Replace - Same Size		VI
143176048	M19222	11/13/2014	12:48	11/13/2014	15:25	15	2355	157	Overhead equipment	Jumper	Replace - Same Size		VI
143175798	K52400	11/13/2014	12:49	11/13/2014	14:38	1	109	109	Underground equipment	Underground Secondary	Reconnect		V
143175990	326168	11/13/2014	13:32	11/13/2014	15:15	411	42333	103	Overhead equipment	Overhead Primary			V
143176348	309143	11/13/2014	13:32	11/13/2014	16:54	560	113120	202	Overhead equipment	Overhead Primary			V
143176052	Q82907	11/13/2014	13:49	11/13/2014	14:43	1	54	54	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	VI
143176182	A32001	11/13/2014	13:51	11/13/2014	14:55	2	128	64	Overhead equipment	Jumper	Replace - Same Size		I
143176221	A36001	11/13/2014	14:23	11/13/2014	16:15	7	784	112	Animal related	Fuse	Replace - Same Size		I
143176309	326168	11/13/2014	14:52	11/13/2014	16:30	1	98	98	Jurisdictional				V

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
143176312	J34357	11/13/2014	14:52	11/13/2014	15:58	1	66	66	Public	Overhead Service	Repair		V
143176443	A49002	11/13/2014	15:16	11/13/2014	15:54	16	608	38	Overhead equipment	Transformer Fuse	Switch/Reset		I
143176489	K62102	11/13/2014	15:28	11/13/2014	17:17	1	109	109	Overhead equipment	Lightning Arrestor	Replace - Same Size	No Work Required	II
143176528	326168	11/13/2014	15:40	11/13/2014	16:24	1	44	44	Jurisdictional				V
143176557	K27153	11/13/2014	15:49	11/13/2014	17:00	48	3408	71	Animal related	Transformer Fuse	Replace - Same Size	No Work Required	VI
143176589	S50541	11/13/2014	16:09	11/13/2014	16:32	1	23	23	Overhead equipment				VI
143176608	U16003	11/13/2014	16:19	11/13/2014	16:48	1	29	29	Overhead equipment	Connector	Replace - Same Size		II
143176798	E05001	11/13/2014	17:18	11/13/2014	18:32	40	2960	74	Overhead equipment	Crossarm		Repair	IV
143176962	61072	11/13/2014	17:54	11/13/2014	18:23	949	27521	29	Substation equipment	Substation Breaker			VI
143176939	M45211	11/13/2014	18:19	11/13/2014	20:28	1	129	129	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
143176983	D96001	11/13/2014	18:39	11/14/2014	3:00	1	501	501	Public	Pole		Repair	I
143176990	J87111	11/13/2014	18:43	11/14/2014	0:04	1	321	321	Underground equipment	Underground Service		Repair	VI
143177414	S21529	11/13/2014	21:41	11/13/2014	22:24	1	43	43	Overhead equipment	Transformer Fuse	Replace - Same Size	Replace - Same Size	VI
143177435	K67924	11/13/2014	22:28	11/14/2014	0:11	1	103	103	Animal related	Fuse	Replace - Same Size	Patrol/Test/Inspect	VI
143180195	J14140	11/14/2014	2:24	11/14/2014	5:45	1	201	201	Underground equipment	Fuse		Replace - Same Size	VI
143183702	S86582	11/14/2014	4:48	11/14/2014	7:30	13	2106	162	Overhead equipment	Overhead Primary	Repair		VI
143183841	G10001	11/14/2014	7:19	11/14/2014	12:38	1	319	319	Tree related-tree contact	Overhead Service	Disconnect	Repair	I
143183870	P57101	11/14/2014	7:31	11/14/2014	8:23	1	52	52	Overhead equipment				VI
143184049	P82290	11/14/2014	7:43	11/14/2014	9:58	9	1215	135	Animal related	Fuse			VI
143183943	D41003	11/14/2014	8:00	11/14/2014	9:20	1	80	80	Unknown	Fuse	Patrol/Test/Inspect	Replace - Same Size	I
143183972	L81141	11/14/2014	8:12	11/14/2014	13:14	3	906	302	Underground equipment	Underground Primary	Repair		IV
143184261	S07536	11/14/2014	9:06	11/14/2014	9:26	35	700	20	Animal related	Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
143184235	D70007	11/14/2014	9:12	11/14/2014	11:11	5	595	119	Underground equipment	Underground Primary	Repair	Repair	I
143184362	K15205	11/14/2014	9:42	11/14/2014	10:07	10	250	25	Overhead equipment	Fuse	Replace - Same Size		VI
143184368	V20502	11/14/2014	9:44	11/14/2014	11:41	1	117	117	Overhead equipment	Overhead Primary	Repair		II
143184378	N50332	11/14/2014	9:47	11/14/2014	11:12	1	85	85	Animal related	Fuse	Replace - Same Size	No Work Required	II
143184392	Y45503	11/14/2014	9:50	11/14/2014	10:24	1	34	34	Overhead equipment	Transformer Fuse	Repair	Replace - Same Size	IV
143184423	K80386	11/14/2014	9:54	11/14/2014	14:19	6	1590	265	Underground equipment	Underground Transformer	Patrol/Test/Inspect	Replace - Same Size	IV
143184455	K28180	11/14/2014	9:58	11/14/2014	11:20	36	2952	82	Animal related	Fuse	Replace - Same Size		III
143184545	B61001	11/14/2014	10:04	11/14/2014	10:50	124	5704	46	Overhead equipment	Fuse	Replace - Same Size	No Work Required	I
143184539	J18268	11/14/2014	10:17	11/14/2014	11:40	1	83	83	Animal related	Transformer Fuse	Replace - Same Size		VI
143184568	U73583	11/14/2014	10:24	11/14/2014	10:42	1	18	18	Other	Customer Equipment	Advise Customer		II
143184720	V61584	11/14/2014	10:59	11/14/2014	16:27	1	328	328	Public	Underground Transformer	Replace - Same Size	Replace - Same Size	II
143184785	K27150	11/14/2014	11:15	11/14/2014	12:53	1	98	98	Overhead equipment	Overhead Primary			VI
143184830	C65001	11/14/2014	11:27	11/14/2014	12:17	1	50	50	Animal related	Fuse	Replace - Same Size		III
143184906	V20512	11/14/2014	11:31	11/14/2014	11:39	422	3376	8	Overhead equipment	Overhead Primary	Switch/Reset		II
143184859	L86175	11/14/2014	11:32	11/14/2014	12:33	5	305	61	Overhead equipment	Overhead Transformer	Switch/Reset		IV
143184937	L17105	11/14/2014	11:53	11/14/2014	13:33	1	100	100	Overhead equipment	Overhead Service			III
143184958	R49265	11/14/2014	12:00	11/14/2014	13:11	1	71	71	Overhead equipment	Transformer Fuse	Replace - Same Size		VI
143184968	D36003	11/14/2014	12:01	11/14/2014	14:25	1	144	144	Overhead equipment	Overhead Service	Replace - Same Size		I
143184995	K09864	11/14/2014	12:08	11/14/2014	14:18	51	6630	130	Overhead equipment	Fuse		Replace - New Size	V
143185050	M26161	11/14/2014	12:23	11/14/2014	12:46	12	276	23	Unknown	Fuse	Replace - Same Size		III
143185106	A26005	11/14/2014	12:37	11/14/2014	13:50	1	73	73	Overhead equipment	Connector	Replace - Same Size	No Work Required	I
143185244	HD5254	11/14/2014	13:03	11/14/2014	14:20	44	3388	77	Animal related	Fuse	Replace - Same Size		VI
143185247	C10002	11/14/2014	13:14	11/14/2014	13:50	1	36	36	Animal related	Transformer Fuse	Replace - Same Size		III
143185331	X42502	11/14/2014	13:37	11/14/2014	14:28	1	51	51	Animal related	Transformer Fuse	Replace - Same Size	Patrol/Test/Inspect	IV
143185352	C30001	11/14/2014	13:43	11/14/2014	14:30	1	47	47	Underground equipment	Underground Secondary	Replace - Same Size		III
143185583	P54827	11/14/2014	14:19	11/14/2014	15:46	18	1566	87	Animal related	Fuse	Replace - Same Size		V
143185524	K36151	11/14/2014	14:29	11/14/2014	15:15	1	46	46	Animal related	Transformer Fuse	Replace - Same Size		III
143185546	Y89535	11/14/2014	14:30	11/14/2014	15:45	67	5025	75	Animal related	Transformer Fuse	Replace - Same Size		IV
143185686	B68002	11/14/2014	15:03	11/14/2014	15:23	54	1080	20	Animal related	Fuse	Replace - Same Size		III
143185652	Q28141	11/14/2014	15:04	11/14/2014	16:14	1	70	70	Animal related	Fuse	Replace - Same Size	Repair	VI
143185903	J76804	11/14/2014	15:16	11/14/2014	15:39	57	1311	23	Animal related	Fuse	Replace - Same Size	Replace - Same Size	V
143185902	A56013	11/14/2014	15:21	11/14/2014	16:32	76	5396	71	Animal related	Fuse	Replace - Same Size		I
143186712	V20512	11/14/2014	15:47	11/14/2014	16:54	1	67	67	Overhead equipment	Overhead Service	Repair		II
143186727	N35852	11/14/2014	15:51	11/14/2014	18:05	3	402	134	Overhead equipment	Overhead Transformer	Replace - Same Size	Replace - Same Size	V

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
143186785	Q32170	11/14/2014	16:16	11/14/2014	17:50	1	94	94	Overhead equipment	Overhead Service	Repair		I
143186839	S42578	11/14/2014	16:45	11/14/2014	18:04	1	79	79	Overhead equipment	Overhead Service	Repair	Repair	VI
143186917	M45212	11/14/2014	17:34	11/14/2014	19:25	6	666	111	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
143186932		11/14/2014	17:49	11/14/2014	19:50	3	363	121	Unknown	Fuse	Replace - Same Size		I
143186944	A50001	11/14/2014	17:50	11/14/2014	19:50	105	12600	120	Unknown	Fuse	Replace - Same Size		I
143187242		11/14/2014	19:43	11/15/2014	2:12	1	389	389	Public				I
143187288	F03002	11/14/2014	20:27	11/15/2014	1:00	2	546	273	Underground equipment	Underground Primary	Repair	Repair	III
143190013	B21004	11/14/2014	21:30	11/15/2014	14:36	19	19494	1026	Public	Pole	Replace - Same Size	Replace - Same Size	I
143187424	M45211	11/14/2014	21:56	11/15/2014	0:40	1	164	164	Overhead equipment	Overhead Transformer	Replace - New Size		IV
143187811	T22507	11/14/2014	22:49	11/15/2014	0:20	1	91	91	Overhead equipment	Overhead Service	Repair		VI
143190012	S61575	11/15/2014	0:55	11/15/2014	1:36	1	41	41	Overhead equipment				VI
143190025	350104	11/15/2014	3:19	11/15/2014	4:04	1	45	45	Underground equipment	Underground Transformer	Switch/Reset	Replace - New Size	V
143190093	D32211	11/15/2014	5:32	11/15/2014	7:57	81	11745	145	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	I
143190124	S30518	11/15/2014	6:40	11/15/2014	8:53	28	3724	133	Animal related	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
143190083	D81001	11/15/2014	7:31	11/15/2014	11:10	212	46428	219	Animal related	Fuse	Replace - Same Size		I
143190095	K25166	11/15/2014	7:41	11/15/2014	9:00	1	79	79	Animal related	Fuse	Repair	Repair	VI
143190110	J87150	11/15/2014	7:46	11/15/2014	8:20	26	884	34	Animal related	Fuse	Replace - Same Size		VI
143190126	K11372	11/15/2014	8:00	11/15/2014	8:25	1	25	25	Animal related	Fuse	Replace - Same Size		V
143190147	M81403	11/15/2014	8:26	11/15/2014	9:10	1	44	44	Animal related	Transformer Fuse	Replace - Same Size		V
143190150	M81403	11/15/2014	8:27	11/15/2014	9:05	1	38	38	Animal related	Transformer Fuse	Replace - Same Size	Repair	V
143190159	T16527	11/15/2014	8:38	11/15/2014	9:22	1	44	44	Overhead equipment	Fuse	Replace - Same Size		VI
143190166	Q74149	11/15/2014	8:49	11/15/2014	9:40	1	51	51	Overhead equipment	Transformer Fuse			IV
143190433	D37001	11/15/2014	9:09	11/15/2014	16:53	3	1392	464	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
143190188	N42856	11/15/2014	9:15	11/15/2014	11:59	1	164	164	Animal related	Transformer Fuse	Replace - Same Size		V
143190226	R39934	11/15/2014	9:33	11/15/2014	10:51	7	546	78	Animal related	Fuse	Replace - Same Size		VI
143190222	P07179	11/15/2014	9:49	11/15/2014	12:10	28	3948	141	Public	Transformer Fuse	Replace - Same Size		I
143190232	N44217	11/15/2014	10:04	11/15/2014	10:57	1	53	53	Overhead equipment	Overhead Service			III
143190269	K36151	11/15/2014	10:25	11/15/2014	12:13	1	108	108	Animal related	Transformer Fuse	Replace - Same Size		III
143190308	K89144	11/15/2014	10:25	11/15/2014	11:07	6	252	42	Animal related	Fuse	Replace - Same Size		III
143190318	R99180	11/15/2014	11:00	11/15/2014	12:18	1	78	78	Overhead equipment	Overhead Service	Repair		IV
143190316	Q34362	11/15/2014	11:00	11/15/2014	12:29	6	534	89	Overhead equipment	Connector	Repair	Repair	I
143190361	M36185	11/15/2014	11:44	11/15/2014	13:30	9	954	106	Animal related	Transformer Fuse	Replace - Same Size		I
143190374	Y28597	11/15/2014	11:53	11/15/2014	13:22	1	89	89	Animal related	Transformer Fuse	Replace - Same Size		IV
143190406	P54827	11/15/2014	12:17	11/15/2014	13:26	1	69	69	Animal related	Transformer Fuse	Replace - Same Size		V
143190517	B21004	11/15/2014	12:38	11/15/2014	12:48	1637	16370	10	Public				I
143190446	D81001	11/15/2014	12:39	11/15/2014	14:55	101	13736	136	Overhead equipment	Overhead Transformer	Replace - Same Size		I
143190544	L00133	11/15/2014	13:21	11/15/2014	17:32	65	16315	251	Overhead equipment	Overhead Primary	Repair		III
143190613	Q01282	11/15/2014	14:48	11/15/2014	15:31	7	301	43	Animal related	Fuse			III
143190630	B21002	11/15/2014	15:16	11/15/2014	16:15	1	59	59	Unknown	Fuse	Replace - Same Size		I
143190638	Y89535	11/15/2014	15:33	11/15/2014	16:52	1	79	79	Animal related	Transformer Fuse	Repair		IV
143190653	Q01282	11/15/2014	15:56	11/15/2014	19:05	1	189	189	Animal related	Transformer Fuse			III
143190663	J83140	11/15/2014	16:13	11/15/2014	17:36	2	166	83	Animal related	Fuse	Replace - Same Size		VI
143190667	J74125	11/15/2014	16:32	11/15/2014	17:55	1	83	83	Animal related	Transformer Fuse	Replace - Same Size	Replace - Same Size	VI
143190727	N60181	11/15/2014	18:11	11/15/2014	20:00	1	109	109	Tree related-tree broken	Overhead Service	Repair		I
143190837	Y28597	11/15/2014	21:31	11/16/2014	0:51	17	3400	200	Animal related	Lightning Arrestor	Replace - Same Size		IV
143190849	D89002	11/15/2014	22:21	11/16/2014	0:49	49	7252	148	Overhead equipment	Disconnect Switch	Replace - Same Size		I
143200020	A97003	11/16/2014	2:09	11/16/2014	4:33	52	7488	144	Public	Pole	Replace - Same Size		I
143200038	M81403	11/16/2014	6:33	11/16/2014	8:20	1	107	107	Animal related	Transformer Fuse		Replace - Same Size	V
143200055	S86582	11/16/2014	7:18	11/16/2014	9:42	1	144	144	Animal related	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
143200094	J99128	11/16/2014	7:55	11/16/2014	10:32	47	7379	157	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	VI
143200108	H11339	11/16/2014	8:20	11/16/2014	8:56	6	216	36	Animal related	Transformer Fuse	Replace - Same Size	Replace - Same Size	V
143200130	Q64919	11/16/2014	8:48	11/16/2014	14:03	7	2205	315	Overhead equipment	Overhead Transformer	Replace - Same Size	Repair	VI
143200133	X96524	11/16/2014	8:53	11/16/2014	9:56	1	63	63	Animal related	Transformer Fuse	Replace - Same Size		IV
143200140	Q85162	11/16/2014	9:01	11/16/2014	9:32	1	31	31	Animal related	Fuse	Repair	Repair	VI
143200171	B93002	11/16/2014	9:51	11/16/2014	10:45	1	54	54	Animal related	Transformer Fuse	Replace - Same Size		I
143200182	L17102	11/16/2014	10:21	11/16/2014	10:46	1	25	25	Animal related	Transformer Fuse	Repair		III

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
143200195	P17109	11/16/2014	10:36	11/16/2014	11:40	31	1984	64	Animal related	Fuse	Replace - Same Size		IV
143200199		11/16/2014	10:43	11/16/2014	11:35	1	52	52	Animal related	Other	Patrol/Test/Inspect	Patrol/Test/Inspect	III
143200218	C37001	11/16/2014	10:53	11/16/2014	12:41	1	108	108	Animal related	Fuse	Replace - Same Size	No Work Required	III
143200233	S61531	11/16/2014	11:23	11/16/2014	12:00	1	37	37	Overhead equipment	Fuse	Replace - Same Size		VI
143200232	N50332	11/16/2014	11:23	11/16/2014	12:42	1	79	79	Overhead equipment	Overhead Service	Repair	No Work Required	II
143200236	M20221	11/16/2014	11:28	11/16/2014	12:15	1	47	47	Animal related	Transformer Fuse			VI
143200250	P54827	11/16/2014	11:39	11/16/2014	12:48	51	3519	69	Animal related	Fuse	Replace - Same Size		V
143200266	M54292	11/16/2014	12:08	11/16/2014	12:32	1	24	24	Animal related	Transformer Fuse	Replace - Same Size	Replace - Same Size	V
143200444	R16511	11/16/2014	14:01	11/16/2014	15:00	1	59	59	Animal related	Fuse	Replace - Same Size		I
143200435	K30204	11/16/2014	14:02	11/16/2014	16:12	4	520	130	Overhead equipment	Overhead Primary			III
143200461	J86108	11/16/2014	14:31	11/16/2014	15:00	1	29	29	Animal related	Transformer Fuse			VI
143200492	K30204	11/16/2014	15:18	11/16/2014	16:12	85	4590	54	Overhead equipment	Overhead Primary			III
143200488	B76003	11/16/2014	15:26	11/16/2014	18:56	1	210	210	Underground equipment	Underground Service	Patrol/Test/Inspect	Repair	I
143200521	A97001	11/16/2014	16:44	11/16/2014	17:46	1	62	62	Overhead equipment	Overhead Service	Reconnect		I
143200557	P61111	11/16/2014	17:21	11/16/2014	20:29	1	188	188	Overhead equipment	Overhead Primary	Repair	Repair	VI
143200569	D66001	11/16/2014	17:33	11/16/2014	19:43	17	2210	130	Overhead equipment	Disconnect Switch			IV
143200575	Y28598	11/16/2014	17:51	11/16/2014	19:50	1	119	119	Overhead equipment	Overhead Service	Patrol/Test/Inspect	Reconnect	IV
143200598	M09143	11/16/2014	18:57	11/16/2014	19:34	1	37	37	Overhead equipment	Connector	Replace - Same Size	No Work Required	VI
143200751	P83705	11/16/2014	20:22	11/16/2014	22:09	1	107	107	Overhead equipment	Connector	Replace - Same Size		I
143200765	C50003	11/16/2014	20:56	11/17/2014	0:21	1	205	205	Overhead equipment	Overhead Transformer	No Work Required	No Work Required	III
143200773	F03004	11/16/2014	21:55	11/17/2014	1:12	1	197	197	Underground equipment	Underground Service	Repair	No Work Required	III
143200778	M04365	11/16/2014	22:23	11/16/2014	22:43	1	20	20	Overhead equipment	Overhead Service	Repair		V
143200809	J79304	11/16/2014	22:41	11/17/2014	2:55	177	44958	254	Overhead equipment	Overhead Primary	Repair		I
143200792	J79304	11/16/2014	22:47	11/17/2014	2:55	1	248	248	Overhead equipment	Overhead Primary	Repair		I
143200806	M09175	11/16/2014	23:24	11/17/2014	0:25	17	1037	61	Overhead equipment	Disconnect Switch	Repair		VI
143200812	N54108	11/16/2014	23:46	11/17/2014	0:37	1	51	51	Unknown	Transformer Fuse	Replace - Same Size	No Work Required	II
143213527	T28562	11/17/2014	2:54	11/17/2014	5:21	6	882	147	Overhead equipment	Fuse			VI
143213548	D35003	11/17/2014	3:05	11/17/2014	5:07	120	14640	122	Overhead equipment	Jumper	Repair		I
143213517	D35003	11/17/2014	3:10	11/17/2014	5:07	1	117	117	Overhead equipment	Jumper	Repair		I
143213542	328120	11/17/2014	4:25	11/17/2014	6:40	1	135	135	Overhead equipment	Transformer Fuse	Replace - Same Size		V
143213550	J01118	11/17/2014	4:59	11/17/2014	6:30	1	91	91	Overhead equipment	Overhead Secondary	Repair		I
143213779	N03297	11/17/2014	8:03	11/17/2014	9:33	1	90	90	Overhead equipment	Eye	Replace - Same Size		V
143213820	Q91175	11/17/2014	8:17	11/17/2014	10:00	1	103	103	Overhead equipment	Overhead Transformer	Switch/Reset		I
143214054	D41003	11/17/2014	8:58	11/17/2014	10:50	129	14448	112	Overhead equipment	Overhead Primary		Repair	I
143214122	Q16868	11/17/2014	9:16	11/17/2014	14:00	1	284	284	Underground equipment	Underground Service	Patrol/Test/Inspect	Repair	V
143214161	P52302	11/17/2014	9:25	11/17/2014	10:28	1	63	63	Overhead equipment	Overhead Secondary	Patrol/Test/Inspect	Replace - Same Size	IV
143214175	Q93522	11/17/2014	9:29	11/17/2014	13:05	1	216	216	Overhead equipment	Jumper			I
143214261		11/17/2014	9:49	11/17/2014	10:39	1	50	50	Overhead equipment	Overhead Service	Repair		V
143214336		11/17/2014	10:08	11/17/2014	10:46	1	38	38	Overhead equipment		Patrol/Test/Inspect		V
143214373	S13549	11/17/2014	10:14	11/17/2014	12:29	1	135	135	Underground equipment	Underground Service			VI
143214500	J58381	11/17/2014	10:40	11/17/2014	11:58	1	78	78	Animal related	Transformer Fuse		Replace - Same Size	III
143214638	H01190	11/17/2014	11:12	11/17/2014	12:35	1	83	83	Overhead equipment	Jumper	Repair		III
143214670	D36001	11/17/2014	11:18	11/17/2014	12:09	31	1581	51	Unknown	Fuse	Repair		I
143214727	C70002	11/17/2014	11:29	11/17/2014	14:58	1	209	209	Underground equipment	Underground Service	Cut in Clear	Repair	III
143215015	U31002	11/17/2014	11:47	11/17/2014	12:40	15	795	53	Tree related-tree broken	Tree			II
143214782	P82290	11/17/2014	11:48	11/17/2014	12:18	1	30	30	Overhead equipment	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
143214832	R78300	11/17/2014	12:03	11/17/2014	13:50	1	107	107	Overhead equipment	Overhead Primary	Patrol/Test/Inspect		V
143214986	Z11536	11/17/2014	12:26	11/17/2014	12:50	7	168	24	Animal related	Transformer Fuse	Replace - Same Size	Replace - Same Size	IV
143215006	P77233	11/17/2014	12:29	11/17/2014	13:26	1	57	57	Overhead equipment	Jumper			VI
143215159	P19395	11/17/2014	13:04	11/18/2014	9:20	1	1216	1216	Weather	Fuse	Replace - Same Size	Replace - Same Size	V
143215160	K76542	11/17/2014	13:05	11/17/2014	17:20	1	255	255	Overhead equipment	Overhead Primary		Repair	IV
143215163	R58921	11/17/2014	13:06	11/17/2014	13:26	15	300	20	Overhead equipment	Transformer Fuse	Replace - New Size	No Work Required	IV
143215238	L81141	11/17/2014	13:22	11/17/2014	15:50	1	148	148	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
143215330	V65549	11/17/2014	13:30	11/17/2014	16:34	1	184	184	Overhead equipment	Overhead Service	Repair		II
143215318	A26006	11/17/2014	13:40	11/17/2014	16:30	1	170	170	Overhead equipment				I
143215407	B71001	11/17/2014	13:59	11/17/2014	14:48	11	539	49	Animal related	Fuse	Replace - Same Size		I

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
143215434		11/17/2014	14:03	11/17/2014	15:45	2	204	102	Overhead equipment	Jumper	Replace - Same Size		II
143215477	B73001	11/17/2014	14:11	11/17/2014	16:15	1	124	124	Overhead equipment	Overhead Transformer	Repair		I
143215537	K69116	11/17/2014	14:13	11/17/2014	14:45	13	416	32	Overhead equipment	Jumper	Patrol/Test/Inspect	Repair	IV
143215515	K01240	11/17/2014	14:20	11/17/2014	15:35	1	75	75	Overhead equipment	Transformer Fuse	Replace - Same Size		VI
143215520	Y34596	11/17/2014	14:22	11/17/2014	15:37	1	75	75	Overhead equipment	Overhead Service	Repair		IV
143215761	P14392	11/17/2014	15:06	11/17/2014	20:38	3	996	332	Overhead equipment	Overhead Primary	Patrol/Test/Inspect	Cut in Clear	V
143215762	B77003	11/17/2014	15:26	11/17/2014	17:53	1	147	147	Tree related-tree broken	Tree	Remove		I
143215828	X99538	11/17/2014	15:49	11/17/2014	16:55	1	66	66	Overhead equipment	Overhead Primary			IV
143215884	Y79503	11/17/2014	16:04	11/17/2014	16:55	1	51	51	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
143215976	D60002	11/17/2014	16:45	11/17/2014	19:45	1	180	180	Overhead equipment	Connector	Replace - Same Size	No Work Required	III
143216038	X73002	11/17/2014	17:01	11/17/2014	18:05	1	64	64	Public	Overhead Service	Replace - New Size	Replace - New Size	IV
143216377	S09520	11/17/2014	17:35	11/17/2014	22:06	1	271	271	Overhead equipment	Overhead Transformer			VI
143216449	R78300	11/17/2014	18:10	11/17/2014	23:26	37	11692	316	Overhead equipment	Overhead Primary	Patrol/Test/Inspect	Repair	V
143217010	Q82907	11/17/2014	18:12	11/17/2014	20:10	2	236	118	Overhead equipment	Fuse	Replace - Same Size		VI
143216475	R58932	11/17/2014	18:30	11/17/2014	18:50	1	20	20	Jurisdictional	Meter	Repair	No Work Required	IV
143217011	Q82907	11/17/2014	18:39	11/17/2014	20:10	1	91	91	Overhead equipment	Fuse	Replace - Same Size		VI
143216526	K76542	11/17/2014	19:04	11/17/2014	20:15	1	71	71	Overhead equipment	Connector	Repair	No Work Required	IV
143223822	Q21423	11/17/2014	19:13	11/18/2014	5:15	36	21672	602	Other	Fuse			VI
143216983	Q21423	11/17/2014	19:14	11/18/2014	5:50	80	50880	636	Underground equipment	Disconnect Switch			VI
143217035	A68002	11/17/2014	20:45	11/18/2014	4:56	1	491	491	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	I
143217084	A49003	11/17/2014	22:48	11/18/2014	6:22	1	454	454	Underground equipment	Underground Service	Patrol/Test/Inspect	Repair	I
143220084	D70006	11/18/2014	0:48	11/18/2014	1:38	1	50	50	Overhead equipment	Fuse	Replace - Same Size		I
143220110	S79772	11/18/2014	1:25	11/18/2014	1:53	1	28	28	Weather				VI
143223866	Y54002	11/18/2014	6:29	11/18/2014	7:12	1	43	43	Overhead equipment	Overhead Secondary	Repair		IV
143223973	K80388	11/18/2014	6:34	11/18/2014	9:12	287	45346	158	Overhead equipment	Guy Wire			IV
143223910	J01119	11/18/2014	6:46	11/18/2014	7:10	71	1704	24	Overhead equipment	Fuse	Replace - Same Size		I
143223900	Q21423	11/18/2014	6:46	11/18/2014	9:26	10	1600	160	Other	Transformer Fuse	Replace - Same Size	Replace - Same Size	VI
143223992	K80388	11/18/2014	7:33	11/18/2014	9:09	1	96	96	Overhead equipment		Patrol/Test/Inspect		IV
143224011	P17109	11/18/2014	7:37	11/18/2014	8:58	1	81	81	Overhead equipment	Connector	Repair		IV
143224088	M81404	11/18/2014	7:56	11/18/2014	10:00	19	2356	124	Overhead equipment	Fuse	Replace - Same Size	Repair	V
143224080	M81404	11/18/2014	8:00	11/18/2014	9:50	1	110	110	Overhead equipment	Fuse	Replace - Same Size	Repair	V
143224094	Q32171	11/18/2014	8:02	11/18/2014	9:24	1	82	82	Overhead equipment	Transformer Fuse	Replace - Same Size	Repair	I
143224107	Q28141	11/18/2014	8:06	11/18/2014	9:54	1	108	108	Tree related-tree broken	Fuse	Replace - Same Size		VI
143224233	K39154	11/18/2014	8:48	11/18/2014	10:04	1	76	76	Animal related	Transformer Fuse	Repair		III
143224426	U45536	11/18/2014	8:51	11/18/2014	11:02	17	2227	131	Overhead equipment	Ground Wire	Repair		II
143224252	V79769	11/18/2014	8:51	11/18/2014	9:51	433	25980	60	Overhead equipment	Ground Wire	Switch/Reset		II
143224425	V79769	11/18/2014	8:51	11/18/2014	9:38	1083	50901	47	Overhead equipment	Ground Wire	Switch/Reset		II
143224352	R07382	11/18/2014	9:16	11/18/2014	10:15	28	1652	59	Animal related	Fuse	Replace - Same Size	Repair	I
143224366	L23146	11/18/2014	9:16	11/18/2014	10:32	24	1824	76	Tree related-tree contact	Tree			III
143224710	Z43549	11/18/2014	10:54	11/18/2014	12:08	1	74	74	Animal related	Disconnect Switch	Replace - Same Size		IV
143224721	U35511	11/18/2014	10:55	11/18/2014	13:20	1	145	145	Overhead equipment	Overhead Service	Tie/Tighten		II
143224736	J01118	11/18/2014	10:58	11/18/2014	13:12	1	134	134	Overhead equipment	Overhead Service	Tie/Tighten		I
143224861	R33126	11/18/2014	11:32	11/18/2014	13:07	1	95	95	Overhead equipment	Transformer Fuse	Replace - Same Size	Repair	I
143224912	V45526	11/18/2014	11:48	11/18/2014	12:35	10	470	47	Animal related	Transformer Fuse	Replace - Same Size		II
143225206	V99562	11/18/2014	13:13	11/18/2014	14:47	1	94	94	Animal related	Fuse	Replace - Same Size		II
143225233	A17025	11/18/2014	13:21	11/18/2014	14:33	1	72	72	Overhead equipment	Overhead Service	Repair	Repair	I
143225618	K09864	11/18/2014	15:29	11/18/2014	18:22	1	173	173	Overhead equipment	Overhead Transformer	Replace - Same Size		V
143225679	V40556	11/18/2014	15:54	11/18/2014	16:37	4	172	43	Animal related	Transformer Fuse	Replace - Same Size	Replace - Same Size	II
143225769	B93002	11/18/2014	16:53	11/18/2014	18:29	1	96	96	Overhead equipment	Connector	Replace - Same Size		I
143225793	Q85162	11/18/2014	17:14	11/18/2014	20:19	1	185	185	Underground equipment	Underground Service	Patrol/Test/Inspect	Repair	VI
143225913	C10001	11/18/2014	18:03	11/18/2014	18:37	1	34	34	Other	Other	Patrol/Test/Inspect	Patrol/Test/Inspect	III
143225921	V76526	11/18/2014	18:11	11/18/2014	19:53	1	102	102	Animal related	Transformer Fuse	Replace - Same Size		II
143225938	B62003	11/18/2014	18:14	11/18/2014	19:48	1	94	94	Unknown	Fuse	Replace - Same Size		I
143225973	S37533	11/18/2014	18:19	11/18/2014	19:30	1	71	71	Overhead equipment	Transformer Fuse	Replace - Same Size		VI
143225974	R34920	11/18/2014	18:20	11/18/2014	18:56	4	144	36	Overhead equipment				VI
143225989		11/18/2014	18:31	11/18/2014	19:30	1	59	59	Overhead equipment	Transformer Fuse	Replace - Same Size		VI

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
143225861	M49424	11/18/2014	18:34	11/18/2014	22:22	1	228	228	Underground equipment	Overhead Service			V
143226012	T09530	11/18/2014	18:55	11/18/2014	20:45	1	110	110	Overhead equipment	Overhead Service	Patrol/Test/Inspect	Cut in Clear	VI
143226352	L11244	11/18/2014	19:39	11/18/2014	20:49	1	70	70	Tree related-tree contact	Overhead Service	Repair		III
143226353	K69117	11/18/2014	19:42	11/19/2014	1:41	1	359	359	Underground equipment	Underground Service	Patrol/Test/Inspect	Repair	IV
143226356	L93135	11/18/2014	19:49	11/18/2014	21:27	17	1666	98	Underground equipment	Underground Service		Repair	VI
143226372	S53541	11/18/2014	20:20	11/19/2014	0:46	1	266	266	Underground equipment	Underground Service			VI
143226380	R49275	11/18/2014	20:34	11/19/2014	0:15	1	221	221	Underground equipment	Underground Service			VI
143226425	S32550	11/18/2014	22:55	11/19/2014	0:40	1	105	105	Overhead equipment	Transformer Fuse	Replace - Same Size	No Work Required	VI
143230185	C66001	11/19/2014	2:32	11/19/2014	4:48	30	4080	136	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	III
143230187	V69558	11/19/2014	2:36	11/19/2014	3:41	2	130	65	Animal related	Transformer Fuse	Replace - Same Size	Replace - Same Size	II
143233129	M36189	11/19/2014	6:21	11/19/2014	8:48	1	147	147	Overhead equipment	Jumper	Repair		I
143233153	N15849	11/19/2014	6:49	11/19/2014	7:25	2	72	36	Animal related	Transformer Fuse	Replace - Same Size	No Work Required	V
143233159	J87111	11/19/2014	7:01	11/19/2014	7:26	2	50	25	Animal related	Transformer Fuse			VI
143233218	D69006	11/19/2014	7:16	11/19/2014	13:12	198	70488	356	Public	Pole		Replace - Same Size	I
143233228	J82117	11/19/2014	7:24	11/19/2014	7:55	7	217	31	Overhead equipment	Transformer Fuse			VI
143233309	Q74149	11/19/2014	7:54	11/19/2014	10:37	1	163	163	Overhead equipment	Overhead Transformer			IV
143233338	S32550	11/19/2014	8:06	11/19/2014	8:47	1	41	41	Overhead equipment	Transformer Fuse	Replace - Same Size	No Work Required	VI
143233508	Q14392	11/19/2014	8:30	11/19/2014	9:12	17	714	42	Animal related	Fuse	Replace - Same Size	Repair	I
143233596	S43502	11/19/2014	9:12	11/19/2014	9:20	1	8	8	Overhead equipment	Transformer Fuse	Replace - Same Size	No Work Required	VI
143233606	B19002	11/19/2014	9:13	11/19/2014	10:50	1	97	97	Animal related	Fuse	Replace - Same Size	Replace - Urgent	I
143233699	U54503	11/19/2014	9:33	11/19/2014	13:22	1	229	229	Underground equipment	Underground Transformer			II
143233724	V35003	11/19/2014	9:33	11/19/2014	10:30	34	1938	57	Tree related-tree broken	Overhead Primary	Repair	Repair	II
143234103	61078	11/19/2014	10:51	11/19/2014	13:10	1	139	139	Overhead equipment	Insulator	Patrol/Test/Inspect		VI
143234279	J06168	11/19/2014	11:44	11/19/2014	12:30	1	46	46	Overhead equipment	Jumper	Repair		I
143234393	K30204	11/19/2014	12:11	11/19/2014	14:25	1	134	134	Overhead equipment	Overhead Primary	Patrol/Test/Inspect	Repair	III
143234406	K76542	11/19/2014	12:17	11/19/2014	12:20	1	3	3	Overhead equipment	Jumper	Repair		IV
143234411	C70004	11/19/2014	12:19	11/19/2014	12:45	1	26	26	Animal related	Fuse	Replace - Same Size		III
143234464	S88503	11/19/2014	12:35	11/19/2014	14:12	1	97	97	Overhead equipment	Disconnect Switch	Patrol/Test/Inspect	Replace - Same Size	VI
143234514	Z43549	11/19/2014	12:47	11/19/2014	13:19	1	32	32	Animal related	Transformer Fuse	Replace - Same Size	Replace - Same Size	IV
143234539	Y50004	11/19/2014	12:52	11/19/2014	13:24	1	32	32	Overhead equipment	Overhead Secondary	Repair		IV
143234586	V41568	11/19/2014	13:02	11/19/2014	13:36	5	170	34	Animal related	Transformer Fuse	Replace - Same Size		II
143234867	P57108	11/19/2014	13:40	11/19/2014	14:35	13	715	55	Animal related	Fuse	Replace - Same Size		VI
143234836	K39154	11/19/2014	14:00	11/19/2014	15:15	1	75	75	Overhead equipment	Connector	Repair		III
143234850	L35138	11/19/2014	14:01	11/19/2014	14:24	79	1817	23	Tree related-tree broken	Fuse	Replace - Same Size		III
143234875	R16511	11/19/2014	14:09	11/19/2014	15:00	1	51	51	Overhead equipment	Overhead Service	Repair		I
143234913	J07135	11/19/2014	14:19	11/19/2014	16:05	1	106	106	Overhead equipment	Jumper	Repair	Tie/Tighten	I
143234918	A36002	11/19/2014	14:20	11/19/2014	15:06	1	46	46	Animal related	Fuse	Replace - Same Size		I
143234950	D66004	11/19/2014	14:28	11/19/2014	15:55	1	87	87	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
143234963	B93003	11/19/2014	14:30	11/19/2014	18:00	1	210	210	Overhead equipment	Overhead Primary	Patrol/Test/Inspect	Repair	I
143234993	D53002	11/19/2014	14:38	11/19/2014	15:53	1	75	75	Tree related-tree broken	Overhead Service	Raise	No Work Required	I
143235033		11/19/2014	14:52	11/19/2014	16:30	1	98	98	Overhead equipment				I
143235059	U06551	11/19/2014	14:58	11/19/2014	16:05	1	67	67	Tree related-tree contact	Overhead Service	Repair		II
143235190	T06503	11/19/2014	15:35	11/19/2014	16:32	29	1653	57	Animal related	Fuse	Patrol/Test/Inspect	Patrol/Test/Inspect	VI
143235194	B38001	11/19/2014	15:38	11/19/2014	17:34	8	928	116	Overhead equipment	Overhead Primary	Repair		I
143235354	H22349	11/19/2014	16:55	11/19/2014	17:26	5	155	31	Animal related	Transformer Fuse	Replace - Same Size		V
143235387	Q23256	11/19/2014	17:16	11/19/2014	18:22	1	66	66	Overhead equipment	Transformer Fuse	Replace - Same Size		VI
143235467	Q75146	11/19/2014	18:31	11/19/2014	19:41	1	70	70	Overhead equipment	Overhead Primary	Replace - Same Size		VI
143236090	Q32170	11/19/2014	22:12	11/20/2014	0:50	399	63042	158	Overhead equipment	Overhead Primary			I
143240118	Q32170	11/19/2014	22:12	11/20/2014	1:52	1	220	220	Overhead equipment	Overhead Transformer	Replace - Same Size		I
143236104	M22812	11/19/2014	22:40	11/20/2014	1:45	1	185	185	Animal related	Transformer Fuse	Repair	Repair	V
143243259	V74513	11/19/2014	23:26	11/20/2014	5:30	15	5460	364	Underground equipment	Underground Primary	Repair	Repair	II
143243292	P62138	11/20/2014	6:26	11/20/2014	9:52	1	206	206	Overhead equipment	Overhead Transformer			VI
143243326	K43382	11/20/2014	6:40	11/20/2014	10:07	40	8280	207	Overhead equipment	Overhead Primary	Patrol/Test/Inspect	Replace - Same Size	V
143243549	Q04411	11/20/2014	8:39	11/20/2014	9:42	1	63	63	Overhead equipment	Jumper	Repair	Repair	III
143243551	V50001	11/20/2014	8:41	11/20/2014	9:38	5	285	57	Animal related	Transformer Fuse	Replace - Same Size	Replace - Same Size	II
143243591	K58210	11/20/2014	8:52	11/20/2014	9:30	1	38	38	Animal related	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	VI

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
143243597	A50002	11/20/2014	8:54	11/20/2014	14:45	1	351	351	Underground equipment	Underground Primary	Repair		I
143243647	P26280	11/20/2014	8:58	11/20/2014	10:25	107	9309	87	Animal related	Fuse	Replace - Same Size	Switch/Reset	I
143243666	B19002	11/20/2014	9:11	11/20/2014	9:46	1	35	35	Animal related	Fuse	Replace - Same Size		I
143243707	J56341	11/20/2014	9:13	11/20/2014	10:24	41	2911	71	Animal related	Fuse	Repair	Repair	III
143243771	S31532	11/20/2014	9:34	11/20/2014	10:20	1	46	46	Animal related	Fuse	Replace - Same Size		VI
143243847	K73361	11/20/2014	9:53	11/20/2014	12:40	379	63293	167	Underground equipment	Underground Primary	Patrol/Test/Inspect		IV
143243873	N93260	11/20/2014	9:57	11/20/2014	10:24	1	27	27	Overhead equipment	Transformer Fuse		Replace - Same Size	III
143243976	L93132	11/20/2014	10:15	11/20/2014	10:50	47	1645	35	Animal related	Fuse			VI
143244232	D66004	11/20/2014	11:04	11/20/2014	11:54	33	1650	50	Animal related	Fuse	Replace - Same Size	No Work Required	IV
143244305	K89143	11/20/2014	11:29	11/20/2014	12:02	1	33	33	Animal related	Fuse	Replace - Same Size	Repair	III
143244370	D41003	11/20/2014	11:41	11/20/2014	12:10	3	87	29	Overhead equipment		No Work Required		I
143244496	D41003	11/20/2014	12:30	11/20/2014	12:45	3	45	15	Animal related	Fuse	Replace - Same Size		I
143244567	S47538	11/20/2014	12:49	11/20/2014	13:30	1	41	41	Overhead equipment	Overhead Service	Patrol/Test/Inspect	Repair	VI
143244598	F03003	11/20/2014	12:56	11/20/2014	14:13	1	77	77	Animal related	Transformer Fuse	Replace - Same Size	No Work Required	III
143245338	M61302	11/20/2014	13:01	11/20/2014	16:00	264	47256	179	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect		V
143244668	Q14392	11/20/2014	13:10	11/20/2014	14:02	1	52	52	Overhead equipment	Connector	Tie/Tighten	Tie/Tighten	I
143244924	L43153	11/20/2014	13:19	11/20/2014	17:40	1	261	261	Weather	Overhead Primary	Repair		I
143245019	R61241	11/20/2014	13:40	11/20/2014	14:20	1	40	40	Animal related	Transformer Fuse	Replace - Same Size		IV
143245444	M09144	11/20/2014	15:27	11/20/2014	16:46	17	1343	79	Animal related	Fuse	Replace - Same Size	Repair	VI
143245663	H14342	11/20/2014	16:22	11/20/2014	17:50	1	88	88	Animal related	Fuse	Replace - Same Size		V
143245702	L23145	11/20/2014	16:35	11/20/2014	17:30	1	55	55	Unknown	Transformer Fuse	Replace - Same Size		III
143245771	P73158	11/20/2014	17:08	11/20/2014	18:20	1	72	72	Animal related	Transformer Fuse	Replace - Same Size	Replace - Same Size	VI
143245799	Q32170	11/20/2014	17:28	11/20/2014	18:11	1	43	43	Overhead equipment	Overhead Service	No Work Required	No Work Required	I
143245844	J34357	11/20/2014	18:06	11/20/2014	19:29	1	83	83	Overhead equipment	Tree	Patrol/Test/Inspect		V
143245922	B19002	11/20/2014	19:36	11/21/2014	2:50	1	434	434	Underground equipment	Underground Secondary	Patrol/Test/Inspect	Repair	I
143245941	P20930	11/20/2014	19:58	11/20/2014	21:20	9	738	82	Overhead equipment	Fuse	Replace - Same Size		VI
143246450	M37191	11/20/2014	22:24	11/21/2014	0:52	12	1776	148	Overhead equipment	Overhead Primary	Repair		I
143246456	J75272	11/20/2014	23:30	11/21/2014	7:10	1	460	460	Underground equipment	Underground Secondary	Repair		IV
143250089	R39934	11/20/2014	23:54	11/21/2014	2:13	21	2919	139	Overhead equipment	Jumper	Repair		VI
143253293	D90002	11/21/2014	3:27	11/21/2014	6:30	1	183	183	Overhead equipment	Overhead Transformer			III
143253320	X75558	11/21/2014	6:05	11/21/2014	7:43	1	98	98	Animal related	Transformer Fuse	Replace - Same Size		IV
143253663	Y97514	11/21/2014	6:26	11/21/2014	8:48	12	1704	142	Underground equipment	Underground Primary	Switch/Reset		IV
143253655	Y97514	11/21/2014	6:32	11/21/2014	9:08	4	624	156	Underground equipment	Underground Primary	Repair	Repair	IV
143253402	S61530	11/21/2014	7:12	11/21/2014	8:03	20	1020	51	Animal related	Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
143253409	X22001	11/21/2014	7:18	11/21/2014	8:22	1	64	64	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
143253492	J01118	11/21/2014	7:56	11/21/2014	10:30	1	154	154	Unknown	Transformer Fuse	Replace - Same Size		I
143253504	Z10501	11/21/2014	7:59	11/21/2014	9:34	1	95	95	Animal related	Transformer Fuse	Replace - Same Size		IV
143253790	P69175	11/21/2014	9:25	11/21/2014	10:41	1	76	76	Animal related	Animal Guard	Replace - Same Size	Repair	III
143253800	Y51505	11/21/2014	9:29	11/21/2014	9:52	1	23	23	Animal related	Transformer Fuse	Replace - Same Size		IV
143253862	X88502	11/21/2014	9:43	11/21/2014	10:35	1	52	52	Animal related	Transformer Fuse	Replace - Same Size		IV
143254046	P83710	11/21/2014	10:36	11/21/2014	12:35	3	357	119	Overhead equipment	Fuse	Repair	Repair	I
143254274	J50186	11/21/2014	11:49	11/21/2014	13:57	1	128	128	Underground equipment	Underground Service	Replace - Same Size		III
143254415	K39154	11/21/2014	12:15	11/21/2014	13:06	11	561	51	Animal related	Fuse	Replace - Same Size		III
143254624	U57561	11/21/2014	13:35	11/21/2014	14:19	6	264	44	Animal related	Transformer Fuse	Replace - Same Size		II
143254716	P98190	11/21/2014	14:04	11/21/2014	16:53	1	169	169	Animal related	Fuse			III
143254734	P57102	11/21/2014	14:13	11/21/2014	15:10	1	57	57	Jurisdictional				VI
143254738	Q80352	11/21/2014	14:16	11/21/2014	15:23	9	603	67	Animal related	Fuse	Replace - Same Size		V
143254741	Q15844	11/21/2014	14:17	11/21/2014	16:07	1	110	110	Animal related	Transformer Fuse	Replace - Same Size		V
143254809	303006	11/21/2014	14:38	11/21/2014	15:18	9	360	40	Public	Overhead Primary	Repair		VI
143254834	J34377	11/21/2014	14:48	11/21/2014	15:55	1	67	67	Overhead equipment	Connector	Replace - Same Size		V
143254868	X69554	11/21/2014	14:57	11/21/2014	15:58	1	61	61	Animal related	Transformer Fuse	Replace - Same Size		IV
143254974	302004	11/21/2014	15:32	11/21/2014	16:12	1	40	40	Public	Tree			VI
143255077	T22507	11/21/2014	16:36	11/21/2014	18:00	3	252	84	Animal related	Transformer Fuse	Replace - Same Size	Repair	VI
143255320	U86500	11/21/2014	17:09	11/21/2014	18:20	80	5680	71	Overhead equipment	Disconnect Switch	Replace - New Size		II
143255314	S43512	11/21/2014	17:56	11/21/2014	19:41	1	105	105	Overhead equipment	Connector	Tie/Tighten	No Work Required	VI
143255338	C00001	11/21/2014	18:27	11/21/2014	21:50	1	203	203	Overhead equipment	Overhead Service	Repair		I

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
143255729	S53542	11/21/2014	20:09	11/22/2014	0:19	14	3500	250	Overhead equipment	Disconnect Switch	Replace - Same Size	Replace - New Size	VI
143255717	K39154	11/21/2014	20:18	11/21/2014	21:00	1	42	42	Animal related	Transformer Fuse	Replace - Same Size		III
143255727	L99392	11/21/2014	20:47	11/21/2014	23:30	1	163	163	Overhead equipment	Disconnect Switch	Replace - Same Size		V
143255738	R33126	11/21/2014	21:40	11/21/2014	22:43	1	63	63	Overhead equipment	Connector	Repair	Repair	I
143255741	C70001	11/21/2014	21:53	11/21/2014	23:00	1	67	67	Animal related	Fuse	Replace - Same Size		III
143255756	D87001	11/21/2014	23:01	11/22/2014	0:43	185	18870	102	Overhead equipment				I
143255750	M22812	11/21/2014	23:01	11/22/2014	2:57	1	236	236	Overhead equipment	Overhead Transformer	Replace - Same Size	Patrol/Test/Inspect	V
143260009	N67312	11/22/2014	1:00	11/22/2014	5:13	1	253	253	Public	Pole	Replace - Same Size		I
143260010	J79304	11/22/2014	1:25	11/22/2014	3:49	1	144	144	Overhead equipment	Overhead Service	Reconnect		I
143260030	M17374	11/22/2014	5:01	11/22/2014	7:28	1	147	147	Animal related	Fuse	Replace - Same Size		V
143260040	U04571	11/22/2014	5:32	11/22/2014	7:49	1	137	137	Overhead equipment	Overhead Service	Repair	Repair	II
143260090	Q74148	11/22/2014	7:08	11/22/2014	8:12	1	64	64	Animal related	Fuse			IV
143260108	K01240	11/22/2014	7:25	11/22/2014	8:04	1	39	39	Animal related	Fuse	Replace - Same Size		VI
143260112	M04365	11/22/2014	7:29	11/22/2014	8:42	1	73	73	Animal related	Fuse	Replace - Same Size		V
143260145	S25552	11/22/2014	8:05	11/22/2014	10:25	5	700	140	Animal related	Transformer Fuse	Replace - Same Size		VI
143260192	R53416	11/22/2014	8:07	11/22/2014	8:50	4	172	43	Animal related	Fuse	Replace - Same Size		V
143260153	J56341	11/22/2014	8:12	11/22/2014	8:50	1	38	38	Animal related	Transformer Fuse			III
143260158	V99562	11/22/2014	8:13	11/22/2014	9:35	1	82	82	Overhead equipment	Transformer Fuse	Replace - Same Size	Repair	II
143260175	S31532	11/22/2014	8:27	11/22/2014	9:30	1	63	63	Animal related	Transformer Fuse	Replace - Same Size		VI
143260283	X34531	11/22/2014	9:17	11/22/2014	10:00	16	688	43	Overhead equipment	Fuse	Replace - Same Size		IV
143260276	Q82906	11/22/2014	9:19	11/22/2014	10:57	1	98	98	Animal related	Fuse	Replace - Same Size		VI
143260307	L35139	11/22/2014	9:57	11/22/2014	11:56	101	12019	119	Underground equipment	Underground Primary		Repair	III
143260324	Q32170	11/22/2014	10:17	11/22/2014	12:28	2	262	131	Animal related	Transformer Fuse	Replace - Same Size	Patrol/Test/Inspect	I
143260349	Q24313	11/22/2014	10:18	11/22/2014	11:45	44	3828	87	Overhead equipment	Fuse	Patrol/Test/Inspect		VI
143260391	F10001	11/22/2014	10:26	11/22/2014	12:02	41	3936	96	Overhead equipment	Overhead Primary	Repair		III
143260350	R41131	11/22/2014	10:32	11/22/2014	11:52	2	160	80	Animal related	Transformer Fuse	Repair	Repair	VI
143260407	Q91141	11/22/2014	11:32	11/22/2014	15:30	1	238	238	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	I
143260437	328120	11/22/2014	12:01	11/22/2014	14:00	21	2499	119	Underground equipment	Underground Primary	Cut in Clear	Repair	V
143260466	V10533	11/22/2014	12:58	11/22/2014	14:10	6	432	72	Tree related-tree broken	Fuse	Replace - Same Size		II
143260474	R48166	11/22/2014	13:11	11/22/2014	14:12	4	244	61	Overhead equipment	Jumper	Repair		IV
143260486	P69173	11/22/2014	13:28	11/22/2014	14:24	1	56	56	Animal related	Fuse	Replace - Same Size		III
143260558	D31016	11/22/2014	15:24	11/22/2014	16:15	1	51	51	Animal related	Fuse	Replace - Same Size	Repair	III
143260562	Y06544	11/22/2014	15:29	11/22/2014	16:56	1	87	87	Animal related	Transformer Fuse	Replace - Same Size		IV
143260580	S27599	11/22/2014	15:59	11/22/2014	17:59	1	120	120	Animal related	Transformer Fuse	Replace - Same Size		VI
143260590	M17374	11/22/2014	16:24	11/22/2014	19:55	1	211	211	Public	Pole	Cut in Clear	Replace - Same Size	V
143260594	P42230	11/22/2014	16:31	11/22/2014	17:30	1	59	59	Animal related	Fuse	Replace - Same Size		VI
143260597	U37001	11/22/2014	16:44	11/22/2014	19:13	1	149	149	Overhead equipment	Overhead Service	Repair		II
143260615	X69555	11/22/2014	17:19	11/22/2014	18:06	1	47	47	Animal related	Transformer Fuse	Replace - Same Size		IV
143260631	Z30584	11/22/2014	17:55	11/22/2014	19:15	2	160	80	Animal related	Transformer Fuse	Replace - Same Size		IV
143260639	K07322	11/22/2014	18:23	11/22/2014	20:00	1	97	97	Animal related	Fuse	Replace - Same Size		I
143260650	L59933	11/22/2014	18:54	11/22/2014	23:23	1	269	269	Underground equipment	Overhead Service		Repair	VI
143260659	U37001	11/22/2014	19:43	11/22/2014	21:21	1	98	98	Overhead equipment	Overhead Service	Repair		II
143260727	L81142	11/22/2014	19:51	11/22/2014	22:17	68	9928	146	Overhead equipment	Recloser			IV
143260673	D60001	11/22/2014	20:03	11/23/2014	0:18	1	255	255	Underground equipment	Underground Primary	Repair	Repair	III
143260715	L35138	11/22/2014	22:17	11/23/2014	0:35	1	138	138	Animal related	Transformer Fuse	Replace - Same Size		III
143260751	L81142	11/22/2014	22:53	11/23/2014	2:06	13	2509	193	Overhead equipment	Pole	Replace - Same Size		IV
143260758	H07106	11/22/2014	23:13	11/23/2014	0:24	1	71	71	Weather	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	IV
143270019	J50186	11/23/2014	4:21	11/23/2014	10:15	291	103014	354	Underground equipment	Underground Primary			III
143270040	P73157	11/23/2014	7:09	11/23/2014	8:33	1	84	84	Overhead equipment	Transformer Fuse			VI
143270063	L95110	11/23/2014	7:10	11/23/2014	8:14	66	4224	64	Animal related	Fuse	Replace - Same Size		III
143270057	D32211	11/23/2014	7:18	11/23/2014	8:00	13	546	42	Animal related	Fuse			I
143270054	J30201	11/23/2014	7:19	11/23/2014	8:27	1	68	68	Animal related	Transformer Fuse	Replace - Same Size		VI
143270076	S07535	11/23/2014	7:19	11/23/2014	8:35	35	2660	76	Animal related	Overhead Primary	Replace - Same Size		VI
143270060	V44504	11/23/2014	7:33	11/23/2014	8:44	1	71	71	Animal related	Fuse	Replace - Same Size		II
143270067	S28552	11/23/2014	7:37	11/23/2014	8:42	25	1625	65	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	VI
143270069	L95110	11/23/2014	7:46	11/23/2014	8:30	1	44	44	Unknown	Fuse	Replace - Same Size		III

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
143270077	S47576	11/23/2014	8:03	11/23/2014	9:23	1	80	80	Animal related	Transformer Fuse	Replace - New Size		VI
143270095	S61530	11/23/2014	8:14	11/23/2014	8:26	172	2064	12	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	VI
143270092	U93563	11/23/2014	8:19	11/23/2014	14:45	1	386	386	Overhead equipment	Overhead Transformer			II
143270103	S42579	11/23/2014	8:33	11/23/2014	9:30	1	57	57	Animal related	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
143270108	M05360	11/23/2014	8:37	11/23/2014	10:11	1	94	94	Animal related	Fuse	Replace - Same Size		V
143270114	J75272	11/23/2014	8:37	11/23/2014	9:56	28	2212	79	Animal related	Fuse	Replace - Same Size	No Work Required	IV
143270131	Q23258	11/23/2014	8:45	11/23/2014	11:38	2	346	173	Animal related	Fuse	Replace - Same Size		VI
143270121	M04364	11/23/2014	8:48	11/23/2014	10:27	1	99	99	Animal related	Fuse	Replace - Same Size		V
143270148	B28006	11/23/2014	9:29	11/23/2014	18:00	1	511	511	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
143270155	M07235	11/23/2014	9:33	11/23/2014	11:17	7	728	104	Overhead equipment	Other			III
143270150	L24124	11/23/2014	9:34	11/23/2014	10:20	12	552	46	Animal related	Fuse	Replace - Same Size		III
143270245	N70331	11/23/2014	9:44	11/23/2014	11:07	1383	114789	83	Overhead equipment	Jumper	Repair		I
143270354	N70331	11/23/2014	9:44	11/23/2014	12:30	1	166	166	Animal related	Jumper	Repair		I
143270160	N67310	11/23/2014	9:45	11/23/2014	11:07	29	2378	82	Overhead equipment	Jumper	Repair		I
143270162	Y97512	11/23/2014	9:45	11/23/2014	12:10	1	145	145	Animal related	Disconnect Switch	Replace - Same Size		IV
143270206	N67311	11/23/2014	9:46	11/23/2014	11:07	460	37260	81	Overhead equipment	Jumper	Repair		I
143270277	J63172	11/23/2014	10:03	11/23/2014	10:30	20	540	27	Animal related	Transformer Fuse			III
143270302	V03562	11/23/2014	10:12	11/23/2014	12:21	20	2580	129	Weather	Fuse	Replace - Same Size		II
143270321	L93132	11/23/2014	10:40	11/23/2014	12:11	47	4277	91	Overhead equipment	Fuse	Replace - Same Size		VI
143270334	L17102	11/23/2014	10:53	11/23/2014	12:54	36	4356	121	Underground equipment	Underground Primary		Repair	III
143270357	V55524	11/23/2014	11:16	11/23/2014	12:52	1	96	96	Tree related-tree broken	Overhead Primary	Repair		II
143270367	N70330	11/23/2014	11:18	11/23/2014	11:45	46	1242	27	Animal related	Fuse	Replace - Same Size		I
143270371	L17101	11/23/2014	11:33	11/23/2014	14:24	1	171	171	Animal related	Fuse	Replace - Same Size		III
143270373	X09557	11/23/2014	11:37	11/23/2014	13:00	1	83	83	Animal related	Transformer Fuse		Replace - Same Size	IV
143270376	N70331	11/23/2014	11:43	11/23/2014	12:12	1	29	29	Overhead equipment	Overhead Service	No Work Required		I
143270377	N67310	11/23/2014	11:45	11/23/2014	12:18	1	33	33	Overhead equipment	Overhead Service	No Work Required		I
143320031	Q87319	11/23/2014	11:50	11/23/2014	12:22	3432	109824	32	Overhead equipment	High Line Switch	Repair	Repair	V
143270546	X09594	11/23/2014	12:17	11/23/2014	13:50	3	279	93	Animal related	Transformer Fuse		Replace - Same Size	IV
143270560	Z08509	11/23/2014	12:41	11/23/2014	13:42	1	61	61	Overhead equipment	Transformer Fuse	Repair	Replace - Same Size	IV
143270567	Y37592	11/23/2014	12:53	11/23/2014	14:01	1	68	68	Animal related	Fuse			IV
143270710	U91599	11/23/2014	13:08	11/23/2014	18:00	1	292	292	Overhead equipment	Crossarm	Replace - Same Size	Replace - Same Size	II
143270712	K07322	11/23/2014	13:09	11/23/2014	13:30	1	21	21	Animal related	Fuse	Replace - Same Size		I
143270717	L86175	11/23/2014	13:16	11/23/2014	14:45	1	89	89	Animal related	Fuse	Replace - Same Size	No Work Required	IV
143270745	M07235	11/23/2014	13:29	11/23/2014	14:52	7	581	83	Overhead equipment	Other			III
143270725	S62523	11/23/2014	13:30	11/23/2014	15:59	27	4023	149	Underground equipment	Underground Primary			VI
143270921	D96002	11/23/2014	13:47	11/23/2014	20:14	15	5805	387	Overhead equipment	Pole	Replace - Same Size		I
143270758	D96002	11/23/2014	13:47	11/23/2014	18:48	44	13244	301	Overhead equipment	Pole	Switch/Reset	Repair	I
143270734	H10843	11/23/2014	13:51	11/23/2014	14:46	1	55	55	Animal related	Transformer Fuse	Replace - Same Size		V
143270735	U04538	11/23/2014	13:55	11/23/2014	17:47	1	232	232	Underground equipment	Underground Secondary			II
143270749	V03529	11/23/2014	14:09	11/23/2014	18:40	1	271	271	Overhead equipment	Crossarm	Repair		II
143270762	J56342	11/23/2014	14:20	11/23/2014	17:30	7	1330	190	Overhead equipment	Crossarm			III
143270763	X96543	11/23/2014	14:34	11/23/2014	15:51	1	77	77	Animal related	Transformer Fuse	Replace - Same Size		IV
143270770	Y89541	11/23/2014	14:42	11/23/2014	16:00	2	156	78	Tree related-tree broken	Tree			IV
143270811	Y20002	11/23/2014	15:08	11/23/2014	17:15	1	127	127	Tree related-tree contact	Overhead Service	Repair		IV
143270810	B00005	11/23/2014	15:08	11/23/2014	15:48	6	240	40	Animal related	Fuse	Replace - Same Size		I
143270839	K58213	11/23/2014	15:57	11/23/2014	20:00	1	243	243	Tree related-tree broken	Overhead Transformer		Repair	VI
143270910	D90002	11/23/2014	16:25	11/23/2014	23:00	2	790	395	Overhead equipment	Pole	Replace - Same Size		III
143270857	D90002	11/23/2014	16:25	11/23/2014	18:00	12	1140	95	Overhead equipment	Pole		Repair	III
143270866	Q36410	11/23/2014	16:52	11/23/2014	19:04	38	5016	132	Tree related-tree contact	Fuse	Replace - Same Size	Replace - Same Size	I
143270895	A48005	11/23/2014	17:37	11/23/2014	18:48	1	71	71	Tree related-tree contact	Overhead Service	Repair		I
143270938	L59929	11/23/2014	18:47	11/23/2014	20:32	27	2835	105	Animal related	Fuse	Replace - Same Size		VI
143270947	Y50003	11/23/2014	19:11	11/23/2014	20:01	2	100	50	Overhead equipment	Overhead Service	Replace - Same Size		IV
143271048	R60552	11/23/2014	19:25	11/23/2014	23:01	285	61560	216	Overhead equipment	Capacitor	Disconnect	No Work Required	IV
143271023	S21529	11/23/2014	19:49	11/23/2014	22:00	1	131	131	Overhead equipment	Disconnect Switch	Patrol/Test/Inspect	Replace - Same Size	VI
143271027	Y26520	11/23/2014	19:55	11/23/2014	21:50	1	115	115	Overhead equipment	Tree			IV
143271057	U68001	11/23/2014	20:34	11/24/2014	0:05	7	1477	211	Unknown	Transformer Fuse	Replace - Same Size	Replace - Same Size	II

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
143271072	Q10702	11/23/2014	21:08	11/23/2014	22:22	3	222	74	Tree related-tree broken	Fuse	Replace - Same Size		V
143271077	B73002	11/23/2014	21:46	11/23/2014	22:44	1	58	58	Overhead equipment	Fuse	Repair		I
143271084	P12290	11/23/2014	22:16	11/23/2014	22:58	1	42	42	Overhead equipment	Connector	Repair		V
143280100	A26005	11/24/2014	0:40	11/24/2014	1:32	266	13832	52	Tree related-tree broken	Fuse	Cut in Clear		I
143280143	A91004	11/24/2014	0:50	11/24/2014	2:54	1	124	124	Tree related-tree broken	Fuse	Cut in Clear		I
143280158	B00003	11/24/2014	1:10	11/24/2014	6:08	1	298	298	Underground equipment	Underground Transformer			I
143280164	R23332	11/24/2014	1:13	11/24/2014	9:27	43	21242	494	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	V
143280163	D28123	11/24/2014	1:17	11/24/2014	4:46	1	209	209	Overhead equipment	Disconnect Switch	Replace - Same Size	No Work Required	I
143280321	P60170	11/24/2014	2:14	11/24/2014	3:48	82	7708	94	Overhead equipment	Overhead Primary	Repair	Repair	VI
143280377	M40679	11/24/2014	2:15	11/24/2014	4:22	1437	182499	127	Substation equipment	Substation Misc.			I
143280477	M40679	11/24/2014	2:15	11/24/2014	6:29	1221	310134	254	Animal related	Fuse	Replace - Same Size		I
143280432	J05624	11/24/2014	2:15	11/24/2014	4:20	1668	208500	125	Substation equipment	Substation Misc.	Switch/Reset		I
143280332	N60181	11/24/2014	2:21	11/24/2014	4:00	1	99	99	Overhead equipment	Substation Transformer	Switch/Reset		I
143280427	J76804	11/24/2014	2:42	11/24/2014	5:40	1	178	178	Overhead equipment	Overhead Primary	Remove	Replace - Same Size	V
143280434	J06168	11/24/2014	2:44	11/24/2014	6:29	3	675	225	Animal related				I
143280455	M47802	11/24/2014	2:55	11/24/2014	5:10	1	135	135	Overhead equipment	Jumper	Tie/Tighten		V
143283103	J86118	11/24/2014	3:17	11/24/2014	8:40	1	323	323	Tree related-tree contact	Overhead Transformer	Patrol/Test/Inspect	Trim	VI
143283229	U10002	11/24/2014	3:23	11/24/2014	6:00	13	2041	157	Overhead equipment	Jumper	Repair	Repair	II
143283123	J87150	11/24/2014	3:42	11/24/2014	5:27	4	420	105	Weather	Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
143283182	P60170	11/24/2014	4:06	11/24/2014	8:15	61	15189	249	Tree related-tree broken	Overhead Primary	Repair	Repair	VI
143283255	V99562	11/24/2014	4:25	11/24/2014	6:40	7	945	135	Unknown	Fuse	Replace - Same Size		II
143283167	341003	11/24/2014	4:27	11/24/2014	5:48	126	10206	81	Public				VI
143283169	X96543	11/24/2014	4:27	11/24/2014	6:45	1	138	138	Tree related-tree broken	Tree			IV
143283230	341003	11/24/2014	4:27	11/24/2014	11:22	22	9130	415	Public	Pole	Patrol/Test/Inspect	Replace - New Size	VI
143283193	J87150	11/24/2014	4:49	11/24/2014	5:30	1	41	41	Weather	Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
143283215	P77233	11/24/2014	4:50	11/24/2014	7:19	6	894	149	Tree related-tree broken	Overhead Primary		Replace - Same Size	VI
143283199	S83533	11/24/2014	4:55	11/24/2014	7:24	1	149	149	Overhead equipment				VI
143283212	M47802	11/24/2014	5:10	11/24/2014	6:30	1	80	80	Overhead equipment	Overhead Service			V
143283219	D69006	11/24/2014	5:13	11/24/2014	6:29	2	152	76	Overhead equipment	Fuse		Replace - Same Size	I
143283303	D69006	11/24/2014	5:16	11/24/2014	8:00	17	2788	164	Overhead equipment	Fuse		Repair	I
143283257	Y37009	11/24/2014	5:23	11/24/2014	6:50	36	3132	87	Overhead equipment	Overhead Primary			IV
143283231	B65003	11/24/2014	5:27	11/24/2014	7:25	2	236	118	Tree related-tree contact	Other	Cut in Clear		I
143283238	K69112	11/24/2014	5:40	11/24/2014	8:44	1	184	184	Overhead equipment	Overhead Primary			IV
143283247	D69006	11/24/2014	5:47	11/24/2014	6:25	1	38	38	Overhead equipment	Other	Replace - Same Size		I
143283249	D69006	11/24/2014	5:50	11/24/2014	6:27	1	37	37	Overhead equipment	Fuse		Replace - Same Size	I
143283270	Q34363	11/24/2014	5:58	11/24/2014	7:00	2	124	62	Tree related-tree broken	Overhead Secondary	Repair	Repair	I
143283272	L23145	11/24/2014	5:59	11/24/2014	6:59	6	360	60	Tree related-tree contact	Tree	Remove		III
143283273	M49411	11/24/2014	6:01	11/24/2014	8:00	1	119	119	Tree related-tree broken	Overhead Service	Cut in Clear	Cut in Clear	V
143283289	P57104	11/24/2014	6:12	11/24/2014	7:56	2	208	104	Tree related-tree broken	Overhead Secondary	Repair	Repair	VI
143283298	S83533	11/24/2014	6:17	11/24/2014	8:24	1	127	127	Overhead equipment				VI
143283316	J71128	11/24/2014	6:26	11/24/2014	8:46	1	140	140	Overhead equipment	Transformer Fuse	Replace - Same Size	Patrol/Test/Inspect	I
143283324	N58144	11/24/2014	6:33	11/24/2014	8:40	2	254	127	Overhead equipment	Overhead Primary	Repair		I
143283332	Q83172	11/24/2014	6:39	11/24/2014	8:40	1	121	121	Tree related-tree broken	Overhead Service	Replace - Same Size	Replace - Same Size	VI
143283402	L00133	11/24/2014	6:47	11/24/2014	8:27	5	500	100	Overhead equipment	Jumper	Repair		III
143283341	X30506	11/24/2014	6:52	11/24/2014	8:20	1	88	88	Overhead equipment	Jumper	Replace - Same Size		IV
143283343	Y69565	11/24/2014	6:54	11/24/2014	8:30	1	96	96	Tree related-tree broken	Overhead Service	Repair		IV
143283775	D53002	11/24/2014	7:16	11/24/2014	10:05	4	676	169	Overhead equipment	Overhead Primary	Patrol/Test/Inspect	Raise	I
143283473	D53002	11/24/2014	7:16	11/24/2014	8:48	8	736	92	Overhead equipment	Overhead Primary	Patrol/Test/Inspect	Repair	I
143283423	R33127	11/24/2014	7:22	11/24/2014	8:23	1	61	61	Overhead equipment	Overhead Transformer	Replace - Same Size	Patrol/Test/Inspect	I
143283477	J20931	11/24/2014	7:27	11/24/2014	8:16	373	18277	49	Animal related	Recloser	Repair		VI
143283448	U04550	11/24/2014	7:29	11/24/2014	8:50	1	81	81	Overhead equipment	Other	Replace - Same Size	Repair	II
143283480	U92588	11/24/2014	7:36	11/24/2014	9:49	1	133	133	Overhead equipment	Disconnect Switch	Repair		II
143283634	R33127	11/24/2014	7:37	11/24/2014	10:24	8	1336	167	Overhead equipment	Fuse	Repair	Patrol/Test/Inspect	I
143283502	B44002	11/24/2014	7:42	11/24/2014	9:47	1	125	125	Overhead equipment				I
143283506	D39001	11/24/2014	7:43	11/24/2014	9:19	15	1440	96	Tree related-tree broken	Other	Cut in Clear		I
143283577	A45003	11/24/2014	7:49	11/24/2014	11:54	9	2205	245	Underground equipment	Other	Repair	Repair	I

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
143284788	A45003	11/24/2014	7:49	11/24/2014	14:24	2	790	395	Underground equipment	Underground Primary	Replace - Same Size	Replace - Same Size	I
143283531	R10903	11/24/2014	7:51	11/24/2014	8:17	1	26	26	Animal related	Recloser	Repair		VI
143283532	J71128	11/24/2014	7:51	11/24/2014	10:37	1	166	166	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Switch/Reset	I
143283542	P77235	11/24/2014	7:52	11/24/2014	8:57	1	65	65	Animal related	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
143283541	B58001	11/24/2014	7:53	11/24/2014	9:37	1	104	104	Overhead equipment	Fuse	Replace - Same Size	No Work Required	I
143283547	B58001	11/24/2014	7:54	11/24/2014	9:37	1	103	103	Overhead equipment	Fuse	Replace - Same Size	No Work Required	I
143283552	R33127	11/24/2014	7:56	11/24/2014	10:34	1	158	158	Overhead equipment	Fuse	Replace - Same Size	Patrol/Test/Inspect	I
143283557	Q47833	11/24/2014	7:58	11/24/2014	8:40	1	42	42	Animal related	Fuse	Repair	Repair	V
143283559		11/24/2014	8:00	11/24/2014	11:39	1	219	219	Underground equipment	Meter	Patrol/Test/Inspect		I
143283581	X62031	11/24/2014	8:05	11/24/2014	9:10	1	65	65	Tree related-tree broken	Overhead Service	Repair		IV
143283606	X34531	11/24/2014	8:05	11/24/2014	11:40	7	1505	215	Underground equipment	Disconnect Switch	Replace - Same Size		IV
143283617	U44529	11/24/2014	8:13	11/24/2014	9:24	48	3408	71	Overhead equipment	Overhead Primary	No Work Required		II
143283629	R33127	11/24/2014	8:16	11/24/2014	10:30	1	134	134	Overhead equipment	Fuse	Replace - Same Size	Patrol/Test/Inspect	I
143283645	J71128	11/24/2014	8:19	11/24/2014	10:30	1	131	131	Overhead equipment	Transformer Fuse	Replace - Same Size	Patrol/Test/Inspect	I
143283807	M51275	11/24/2014	8:20	11/24/2014	12:23	734	178362	243	Overhead equipment	Overhead Primary	Patrol/Test/Inspect		III
143283676	Q11516	11/24/2014	8:23	11/24/2014	9:09	1	46	46	Overhead equipment	Overhead Service	Repair		I
143283518	U44568	11/24/2014	8:25	11/24/2014	10:44	70	9730	139	Tree related-tree contact	Recloser	Switch/Reset		II
143283856	K82202	11/24/2014	8:28	11/24/2014	11:15	14	2338	167	Tree related-tree contact	Fuse	Replace - Same Size		III
143283792	N03297	11/24/2014	8:36	11/24/2014	10:46	1	130	130	Overhead equipment	Overhead Secondary	Repair		V
143283804	N58144	11/24/2014	8:39	11/24/2014	8:47	1	8	8	Overhead equipment	Overhead Primary	Repair		I
143283832	M05360	11/24/2014	8:45	11/24/2014	9:26	1	41	41	Overhead equipment	Transformer Fuse	Replace - Same Size		V
143283842	310123	11/24/2014	8:46	11/24/2014	10:35	5	545	109	Overhead equipment	Overhead Secondary	Repair		V
143283855	303007	11/24/2014	8:46	11/24/2014	10:46	20	2400	120	Overhead equipment	Overhead Primary	Patrol/Test/Inspect	Repair	VI
143283858	M25143	11/24/2014	8:47	11/24/2014	10:15	1	88	88	Overhead equipment	Transformer Fuse	Replace - Same Size	No Work Required	IV
143283879	D32212	11/24/2014	8:51	11/24/2014	11:35	1	164	164	Overhead equipment	Crossarm	Patrol/Test/Inspect	Repair	I
143283898	J71128	11/24/2014	8:55	11/24/2014	11:23	1	148	148	Overhead equipment	Overhead Primary	Patrol/Test/Inspect	Patrol/Test/Inspect	I
143283907	R33127	11/24/2014	8:56	11/24/2014	10:27	1	91	91	Overhead equipment	Fuse	Replace - Same Size	Repair	I
143283921	L35137	11/24/2014	8:59	11/24/2014	10:58	1	119	119	Tree related-tree contact	Overhead Service	Repair		III
143284461	K30204	11/24/2014	8:59	11/24/2014	11:42	11	1793	163	Overhead equipment	Fuse	Replace - Same Size		III
143283939	H11339	11/24/2014	9:01	11/24/2014	10:05	1	64	64	Tree related-tree contact	Overhead Service	Replace - Same Size		V
143283932	L79157	11/24/2014	9:02	11/24/2014	10:33	1	91	91	Overhead equipment	Overhead Service	Repair		IV
143283948	H07106	11/24/2014	9:03	11/24/2014	10:20	1	77	77	Underground equipment	Underground Service	Patrol/Test/Inspect	Repair	IV
143283955	K31120	11/24/2014	9:04	11/24/2014	10:11	1	67	67	Overhead equipment	Overhead Secondary	Repair		I
143283997	N18210	11/24/2014	9:11	11/24/2014	10:50	1	99	99	Overhead equipment	Fuse	Replace - Same Size		III
143284062	X69555	11/24/2014	9:23	11/24/2014	9:37	1	14	14	Animal related	Transformer Fuse	Replace - Same Size		IV
143284121	X96543	11/24/2014	9:35	11/24/2014	10:15	1	40	40	Overhead equipment	Transformer Fuse			IV
143284132	Q27185	11/24/2014	9:37	11/24/2014	10:42	1	65	65	Tree related-tree broken	Overhead Service			VI
143284157	R23332	11/24/2014	9:42	11/24/2014	11:46	1	124	124	Underground equipment	Underground Service		Repair	V
143284170	Y97512	11/24/2014	9:44	11/24/2014	10:30	1	46	46	Overhead equipment	Overhead Service	Repair	Repair	IV
143284278	V21548	11/24/2014	9:50	11/24/2014	10:22	23	736	32	Animal related	Fuse	Repair		II
143284321	J20931	11/24/2014	9:59	11/24/2014	10:38	9	351	39	Overhead equipment				VI
143284293	K09864	11/24/2014	9:59	11/24/2014	13:30	1	211	211	Animal related	Transformer Fuse	Replace - Same Size	Replace - Same Size	V
143284338	D89001	11/24/2014	10:05	11/24/2014	10:30	1	25	25	Overhead equipment	Jumper	Repair		I
143284349	J06167	11/24/2014	10:07	11/24/2014	13:30	1	203	203	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	I
143284370	Q91175	11/24/2014	10:11	11/24/2014	11:07	1	56	56	Overhead equipment	Pole	Replace - Same Size	Replace - Same Size	I
143284377	S28552	11/24/2014	10:13	11/24/2014	11:27	3	222	74	Animal related	Transformer Fuse	Replace - Same Size		VI
143284468	V65549	11/24/2014	10:31	11/24/2014	11:35	3	192	64	Tree related-tree broken	Overhead Primary	Repair		II
143284508	P26280	11/24/2014	10:38	11/24/2014	12:01	128	10624	83	Overhead equipment	Fuse	Replace - Same Size		I
143284664	K69116	11/24/2014	11:19	11/24/2014	13:13	1	114	114	Overhead equipment	Jumper		Repair	IV
143284702	Q06131	11/24/2014	11:30	11/24/2014	13:39	1	129	129	Overhead equipment	Jumper			IV
143284714	K91115	11/24/2014	11:32	11/24/2014	12:33	1	61	61	Tree related-tree contact	Overhead Service	Repair		III
143284725	V21500	11/24/2014	11:36	11/24/2014	12:17	4	164	41	Animal related	Transformer Fuse	Repair		II
143284736	H02256	11/24/2014	11:37	11/24/2014	14:00	1	143	143	Tree related-tree contact	Overhead Secondary			III
143284756		11/24/2014	11:44	11/24/2014	13:22	1	98	98	Overhead equipment	Jumper	Repair		IV
143284826	J12166	11/24/2014	12:03	11/24/2014	13:23	1	80	80	Unknown	Fuse	Replace - Same Size		III
143284881		11/24/2014	12:20	11/24/2014	14:00	1	100	100	Overhead equipment	High Line Switch	Switch/Reset		VI

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
143284893	M45211	11/24/2014	12:22	11/24/2014	13:54	1	92	92	Tree related-tree broken	Overhead Service	Repair		IV
143285020	Q83172	11/24/2014	12:56	11/24/2014	13:50	1	54	54	Tree related-tree broken	Overhead Service	Replace - Same Size	Replace - Same Size	VI
143285075	D70004	11/24/2014	13:07	11/24/2014	13:45	1	38	38	Overhead equipment	Connector	Repair		I
143285081	K30205	11/24/2014	13:08	11/24/2014	13:40	1	32	32	Overhead equipment	Fuse	Replace - Same Size		III
143285085	V23592	11/24/2014	13:08	11/24/2014	13:55	1	47	47	Animal related	Transformer Fuse	Repair	Replace - Same Size	II
143285090	N44215	11/24/2014	13:09	11/24/2014	15:00	1	111	111	Overhead equipment	Fuse	Replace - Same Size		III
143285125	A45001	11/24/2014	13:14	11/24/2014	14:07	1	53	53	Overhead equipment	Overhead Service			I
143285134	M25143	11/24/2014	13:15	11/24/2014	14:05	1	50	50	Overhead equipment				IV
143285160	J75271	11/24/2014	13:23	11/24/2014	13:46	1	23	23	Overhead equipment	Overhead Service	Patrol/Test/Inspect	Repair	IV
143285417	M41111	11/24/2014	13:25	11/24/2014	14:35	348	24360	70	Overhead equipment	Overhead Primary	No Work Required	No Work Required	I
143285340	U35554	11/24/2014	14:01	11/24/2014	19:04	10	3030	303	Public				II
143285395	J71128	11/24/2014	14:14	11/24/2014	16:00	1	106	106	Overhead equipment	Fuse	Replace - Same Size	Patrol/Test/Inspect	I
143285473	J58380	11/24/2014	14:35	11/24/2014	16:35	1	120	120	Overhead equipment	Overhead Primary			III
143285470	M41111	11/24/2014	14:35	11/24/2014	15:35	1	60	60	Overhead equipment	Overhead Service	No Work Required	No Work Required	I
143285721	A50002	11/24/2014	15:06	11/24/2014	17:40	40	6160	154	Overhead equipment	Overhead Primary	Patrol/Test/Inspect	Reconnect	I
143285598	P83710	11/24/2014	15:09	11/24/2014	20:26	12	3804	317	Tree related-tree broken	Overhead Primary	Patrol/Test/Inspect	Repair	I
143285685	D90003	11/24/2014	15:44	11/24/2014	16:54	1	70	70	Underground equipment	Underground Service	Replace - Same Size	Repair	III
143285708	Q74150	11/24/2014	15:55	11/24/2014	18:00	1	125	125	Tree related-tree contact	Overhead Service	Repair		IV
143285753	K11376	11/24/2014	16:15	11/24/2014	18:51	1	156	156	Overhead equipment	Overhead Service	Repair		V
143285760	303004	11/24/2014	16:20	11/24/2014	17:13	1	53	53	Overhead equipment	Other	Patrol/Test/Inspect		VI
143285768	X23516	11/24/2014	16:24	11/24/2014	17:50	1	86	86	Overhead equipment	Transformer Fuse			IV
143285853	X75558	11/24/2014	17:22	11/24/2014	20:11	1	169	169	Overhead equipment	Overhead Primary	Replace - Same Size		IV
143285991	M51275	11/24/2014	18:34	11/24/2014	19:38	1	64	64	Overhead equipment	Connector			III
143286006	L82187	11/24/2014	18:55	11/24/2014	19:57	2	124	62	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
143286460	H00162	11/24/2014	20:07	11/24/2014	21:09	1	62	62	Overhead equipment	Overhead Service			III
143285776	Q11517	11/24/2014	20:38	11/24/2014	22:40	3	366	122	Public	Pole	Repair		I
143286475	J07173	11/24/2014	20:47	11/25/2014	1:50	1	303	303	Overhead equipment	Overhead Secondary	Repair	Repair	I
143286492	M09144	11/24/2014	21:25	11/24/2014	22:03	1	38	38	Overhead equipment	Connector	Replace - Same Size	No Work Required	VI
143286580	N05170	11/24/2014	22:24	11/25/2014	5:15	1	411	411	Animal related	Underground Service			I
143290133	H07106	11/24/2014	23:25	11/25/2014	1:30	8	1000	125	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	IV
143286761	T14576	11/24/2014	23:33	11/25/2014	0:25	1	52	52	Animal related	Transformer Fuse	Repair	Repair	VI
143290153	Q91175	11/25/2014	0:31	11/25/2014	4:20	233	53357	229	Overhead equipment	Recloser	Repair		I
143290145	L68115	11/25/2014	0:41	11/25/2014	1:17	1	36	36	Overhead equipment	Connector	Replace - Same Size		IV
143290269	Q91175	11/25/2014	2:55	11/25/2014	4:32	1	97	97	Overhead equipment				I
143293260	P47169	11/25/2014	4:42	11/25/2014	8:08	5	1030	206	Overhead equipment	Overhead Transformer	Replace - Same Size		I
143293275	Q91175	11/25/2014	5:13	11/25/2014	8:37	1	204	204	Overhead equipment				I
143293273	Q91175	11/25/2014	5:13	11/25/2014	7:34	1	141	141	Overhead equipment	Recloser	Switch/Reset		I
143293277	R07381	11/25/2014	5:36	11/25/2014	12:12	1	396	396	Underground equipment	Underground Service	Repair	Repair	I
143293408	Q91175	11/25/2014	6:00	11/25/2014	10:20	7	1820	260	Overhead equipment	Overhead Transformer	Repair	Replace - Same Size	I
143293297	Q91175	11/25/2014	6:23	11/25/2014	9:24	1	181	181	Overhead equipment				I
143293304	Q91175	11/25/2014	6:31	11/25/2014	9:16	1	165	165	Overhead equipment				I
143293305	Q91175	11/25/2014	6:32	11/25/2014	7:55	1	83	83	Unknown	Fuse	Repair	Replace - Same Size	I
143293315	M45212	11/25/2014	6:46	11/25/2014	10:28	1	222	222	Underground equipment	Underground Service			IV
143293336	S55535	11/25/2014	6:57	11/25/2014	8:00	1	63	63	Animal related	Transformer Fuse			VI
143293338	J46182	11/25/2014	6:59	11/25/2014	8:12	1	73	73	Overhead equipment	Connector			III
143293348	Y07001	11/25/2014	7:05	11/25/2014	8:03	1	58	58	Overhead equipment	Overhead Service			IV
143293366	D81001	11/25/2014	7:13	11/25/2014	8:07	1	54	54	Overhead equipment	Connector	Replace - Same Size		I
143293401	Q91175	11/25/2014	7:26	11/25/2014	13:00	1	334	334	Overhead equipment	Overhead Transformer	Repair	Replace - Same Size	I
143293437	R10902	11/25/2014	7:41	11/25/2014	8:48	1	67	67	Animal related	Fuse	Replace - Same Size		VI
143293439	S43512	11/25/2014	7:41	11/25/2014	8:24	1	43	43	Animal related	Fuse	Replace - Same Size	No Work Required	VI
143293440	A49003	11/25/2014	7:42	11/25/2014	10:15	1	153	153	Underground equipment	Underground Service	Patrol/Test/Inspect	Reconnect	I
143293446	Q83171	11/25/2014	7:46	11/25/2014	9:00	1	74	74	Overhead equipment	Overhead Transformer	Switch/Reset	Switch/Reset	VI
143293455	Q91175	11/25/2014	7:49	11/25/2014	8:26	1	37	37	Unknown	Fuse	Repair	Replace - Same Size	I
143293717	M09143	11/25/2014	8:31	11/25/2014	9:19	6	288	48	Animal related	Fuse	Replace - Same Size	No Work Required	VI
143293721	J87150	11/25/2014	8:39	11/25/2014	8:56	1	17	17	Animal related	Transformer Fuse	Replace - Same Size		VI
143293756	R65451	11/25/2014	8:50	11/25/2014	10:13	6	498	83	Overhead equipment	Overhead Transformer		Repair	IV

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
143293789	R94269	11/25/2014	8:56	11/25/2014	10:39	1	103	103	Animal related	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
143293873	X34532	11/25/2014	8:58	11/25/2014	9:40	3	126	42	Animal related	Transformer Fuse	Replace - Same Size		IV
143294010	H22346	11/25/2014	10:02	11/25/2014	10:05	1	3	3	Underground equipment	Underground Service		Repair	V
143294026	Z29579	11/25/2014	10:06	11/25/2014	14:16	1	250	250	Overhead equipment	Disconnect Switch	Replace - Same Size		IV
143294039	V49541	11/25/2014	10:10	11/25/2014	10:46	1	36	36	Overhead equipment	Overhead Service	Repair	Repair	II
143294041	V44504	11/25/2014	10:11	11/25/2014	10:39	2	56	28	Animal related	Transformer Fuse	Replace - Same Size		II
143294198	L79157	11/25/2014	11:00	11/25/2014	14:30	1	210	210	Underground equipment	Underground Service	Repair		IV
143294304	M04365	11/25/2014	11:23	11/25/2014	12:49	1	86	86	Underground equipment	Underground Primary		Repair	V
143294308	P85141	11/25/2014	11:24	11/25/2014	15:45	1	261	261	Underground equipment	Underground Service			III
143294359	K43386	11/25/2014	11:40	11/25/2014	12:17	1	37	37	Overhead equipment	Connector	Repair		V
143294444	311001	11/25/2014	12:18	11/25/2014	13:10	1	52	52	Overhead equipment	Overhead Transformer	Switch/Reset		VI
143294459	311001	11/25/2014	12:24	11/25/2014	12:56	1	32	32	Overhead equipment	Overhead Transformer	Switch/Reset		VI
143294465	J58380	11/25/2014	12:26	11/25/2014	13:03	1	37	37	Overhead equipment	Fuse		Replace - Same Size	III
143294572	T12527	11/25/2014	13:00	11/25/2014	13:54	1	54	54	Animal related	Transformer Fuse	Replace - Same Size		VI
143294616	R60551	11/25/2014	13:10	11/25/2014	13:33	25	575	23	Animal related	Underground Primary			IV
143294644		11/25/2014	13:19	11/25/2014	13:54	1	35	35	Animal related	Transformer Fuse	Replace - Same Size		VI
143294727	R93701	11/25/2014	13:41	11/25/2014	14:20	1	39	39	Animal related	Substation Breaker	Replace - Same Size		V
143294767	P05826	11/25/2014	13:55	11/25/2014	14:37	1	42	42	Animal related	Transformer Fuse	Replace - Same Size		V
143294779	Q34360	11/25/2014	13:59	11/25/2014	15:25	1	86	86	Animal related	Fuse	Replace - Same Size	Replace - Same Size	I
143294791	S52515	11/25/2014	14:02	11/25/2014	15:24	1	82	82	Animal related	Transformer Fuse	Replace - Same Size		VI
143294811	P05826	11/25/2014	14:08	11/25/2014	14:41	1	33	33	Animal related	Transformer Fuse	Replace - Same Size		V
143294853	J58381	11/25/2014	14:23	11/25/2014	14:39	1	16	16	Animal related	Transformer Fuse		Replace - Same Size	III
143294908	S27598	11/25/2014	14:43	11/25/2014	18:46	2	486	243	Underground equipment	Underground Primary			VI
143294963	Q80353	11/25/2014	14:54	11/25/2014	15:20	106	2756	26	Animal related	Fuse	Replace - Same Size		V
143294987	S01511	11/25/2014	15:04	11/25/2014	16:10	1	66	66	Overhead equipment	Overhead Service			VI
143295128	B19001	11/25/2014	15:15	11/25/2014	17:42	10	1470	147	Public	Underground Primary	Repair	Repair	I
143295035	N22295	11/25/2014	15:16	11/25/2014	16:10	1	54	54	Animal related	Transformer Fuse	Replace - Same Size		VI
143295104	N05172	11/25/2014	15:38	11/25/2014	16:06	1	28	28	Overhead equipment	Transformer Fuse	Replace - Same Size		I
143295120	M73329	11/25/2014	15:43	11/25/2014	16:06	1	23	23	Overhead equipment	Connector	Replace - Same Size	Replace - Same Size	V
143295151	N94182	11/25/2014	15:58	11/25/2014	22:13	1	375	375	Public	Pole	Replace - Same Size		I
143295206	V25513	11/25/2014	16:24	11/25/2014	17:24	6	360	60	Public	Underground Transformer			II
143295219	N90246	11/25/2014	16:38	11/25/2014	17:23	1	45	45	Overhead equipment	Connector			III
143295230	P62138	11/25/2014	16:41	11/25/2014	17:36	1	55	55	Animal related	Fuse	Replace - Same Size		VI
143295240	P82290	11/25/2014	16:49	11/25/2014	18:37	1	108	108	Animal related	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
143295300	M09175	11/25/2014	17:00	11/25/2014	17:33	10	330	33	Animal related	Fuse	Replace - Same Size	No Work Required	VI
143295280	R08910	11/25/2014	17:05	11/25/2014	18:20	1	75	75	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	VI
143295298	S47576	11/25/2014	17:22	11/25/2014	19:30	1	128	128	Animal related	Transformer Fuse	Repair	Repair	VI
143295305	K58213	11/25/2014	17:26	11/25/2014	20:00	1	154	154	Underground equipment	Underground Service	Patrol/Test/Inspect	Repair	VI
143295436	349002	11/25/2014	17:38	11/26/2014	0:17	184	73416	399	Public	Pole	Patrol/Test/Inspect	Replace - Same Size	VI
143295388	349002	11/25/2014	17:40	11/25/2014	18:32	107	5564	52	Public				VI
143295350	349002	11/25/2014	17:42	11/25/2014	19:59	82	11234	137	Public	Pole	Patrol/Test/Inspect	Replace - Same Size	VI
143295379	R07381	11/25/2014	18:25	11/25/2014	20:36	1	131	131	Underground equipment	Underground Connector	Repair	Repair	I
143295396	J47175	11/25/2014	18:48	11/25/2014	22:56	9	2232	248	Overhead equipment	Overhead Transformer			III
143295399	B79005	11/25/2014	18:54	11/25/2014	21:01	1	127	127	Overhead equipment	Connector	Replace - Same Size		I
143295424	N18211	11/25/2014	18:57	11/25/2014	20:55	175	20650	118	Overhead equipment	Overhead Primary			III
143295432	J63173	11/25/2014	19:24	11/26/2014	0:27	1	303	303	Underground equipment	Underground Service			III
143295574	Y37009	11/25/2014	21:06	11/25/2014	22:10	6	384	64	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
143295843	P52305	11/25/2014	22:35	11/26/2014	0:34	1	119	119	Overhead equipment	Disconnect Switch	Patrol/Test/Inspect	Replace - Same Size	IV
143295844	Q32170	11/25/2014	22:36	11/25/2014	23:44	1	68	68	Animal related	Transformer Fuse	Replace - Same Size	Patrol/Test/Inspect	I
143300122	X69555	11/26/2014	1:15	11/26/2014	2:20	1	65	65	Overhead equipment	Overhead Service	Patrol/Test/Inspect		IV
143300134	U62510	11/26/2014	1:18	11/26/2014	4:30	29	5568	192	Overhead equipment	Jumper	Repair		II
143302869	R10925	11/26/2014	4:43	11/26/2014	6:02	1	79	79	Animal related	Fuse	Replace - Same Size		VI
143302892	Y37009	11/26/2014	6:44	11/26/2014	9:50	6	1116	186	Overhead equipment	Overhead Transformer		Replace - Same Size	IV
143302980	V18541	11/26/2014	7:30	11/26/2014	11:21	1	231	231	Underground equipment	Underground Service		Repair	II
143303155	J39392	11/26/2014	7:57	11/26/2014	9:03	4	264	66	Animal related	Fuse		Replace - Same Size	III
143303211	J79305	11/26/2014	8:59	11/26/2014	10:10	1	71	71	Unknown	Overhead Transformer	Replace - Same Size		I

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
143303227	J87150	11/26/2014	9:05	11/26/2014	10:01	5	280	56	Animal related	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
143303314	R01152	11/26/2014	9:31	11/26/2014	12:15	1	164	164	Underground equipment	Underground Service			III
143303345	Q71846	11/26/2014	9:38	11/26/2014	12:18	1	160	160	Jurisdictional	Meter	Reconnect		V
143303472	J13108	11/26/2014	10:10	11/26/2014	11:15	1	65	65	Overhead equipment	Fuse	Replace - Same Size		I
143303540	B73003	11/26/2014	10:28	11/26/2014	14:06	1	218	218	Underground equipment	Underground Service	Repair	Repair	I
143303596	S50544	11/26/2014	10:49	11/26/2014	11:15	1	26	26	Overhead equipment	Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
143303647	D92001	11/26/2014	11:04	11/26/2014	15:19	10	2550	255	Underground equipment	Underground Secondary	Patrol/Test/Inspect	Repair	I
143304366	P26281	11/26/2014	12:19	11/26/2014	13:26	1	67	67	Animal related	Transformer Fuse	Patrol/Test/Inspect	Repair	I
143304376	J47175	11/26/2014	12:23	11/26/2014	12:54	1	31	31	Animal related	Transformer Fuse			III
143304402	P12290	11/26/2014	12:36	11/26/2014	12:54	1	18	18	Jurisdictional	Overhead Service	Reconnect		V
143304428	B81003	11/26/2014	12:46	11/26/2014	13:53	9	603	67	Animal related	Transformer Fuse	Replace - Same Size	No Work Required	I
143304467	P54827	11/26/2014	12:52	11/26/2014	14:09	38	2926	77	Animal related	Fuse	Replace - Same Size		V
143304457	P54827	11/26/2014	12:53	11/26/2014	14:13	7	560	80	Animal related	Fuse	Replace - Same Size		V
143304768	K19118	11/26/2014	14:56	11/26/2014	15:56	26	1560	60	Animal related	Fuse	Replace - Same Size	No Work Required	VI
143304827	J89126	11/26/2014	15:19	11/26/2014	15:46	1	27	27	Overhead equipment	Fuse	Replace - Same Size	No Work Required	VI
143304938	M26161	11/26/2014	15:59	11/26/2014	16:35	4	144	36	Unknown	Fuse	Replace - Same Size		III
143304982	U30001	11/26/2014	16:59	11/26/2014	21:00	1	241	241	Public	Pole	Repair	Repair	II
143305048	S04545	11/26/2014	17:21	11/26/2014	20:00	1	159	159	Tree related-tree broken	Overhead Service	Repair	Repair	VI
143305087	K31124	11/26/2014	17:30	11/26/2014	21:30	1	240	240	Overhead equipment	Recloser	Repair		I
143305096	V92540	11/26/2014	17:44	11/26/2014	19:30	1	106	106	Animal related	Transformer Fuse	Replace - Same Size	Replace - Same Size	II
143305122	L00134	11/26/2014	18:09	11/26/2014	20:00	60	6660	111	Underground equipment	Underground Primary	Switch/Reset	Repair	III
143305136	L99392	11/26/2014	18:24	11/26/2014	20:07	1	103	103	Overhead equipment	Connector	Replace - Same Size		V
143305609	R73840	11/26/2014	22:09	11/27/2014	0:23	1	134	134	Overhead equipment	Overhead Secondary	Repair		V
143305628	S27599	11/26/2014	22:29	11/27/2014	0:09	18	1800	100	Overhead equipment	Fuse	Replace - Same Size		VI
143305636	M41111	11/26/2014	22:42	11/27/2014	0:25	76	7828	103	Overhead equipment	Overhead Primary	Repair	Replace - Same Size	I
143305643	X92508	11/26/2014	23:14	11/27/2014	1:30	1	136	136	Overhead equipment	Overhead Service	Repair	Replace - Same Size	IV
143310006	V51002	11/27/2014	0:40	11/27/2014	4:22	1	222	222	Underground equipment	Underground Service	Repair	Repair	II
143310037	A26006	11/27/2014	5:28	11/27/2014	6:06	6	228	38	Tree related-tree broken	Fuse	Replace - Same Size		I
143310096	S15560	11/27/2014	7:05	11/27/2014	7:50	1	45	45	Animal related	Fuse	Replace - Same Size		VI
143310115	Q23255	11/27/2014	7:57	11/27/2014	8:44	1	47	47	Animal related	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
143310116	P26283	11/27/2014	7:58	11/27/2014	8:54	1	56	56	Overhead equipment	Jumper	Repair		I
143310124	J86108	11/27/2014	8:18	11/27/2014	10:34	1	136	136	Tree related-tree broken	Overhead Service	Patrol/Test/Inspect	Replace - Same Size	VI
143310127	K91117	11/27/2014	8:23	11/27/2014	9:03	37	1480	40	Animal related	Fuse	Replace - Same Size		III
143310133	S86582	11/27/2014	8:41	11/27/2014	9:35	1	54	54	Animal related	Fuse	Replace - Same Size		VI
143310137	S47575	11/27/2014	8:49	11/27/2014	9:40	1	51	51	Animal related	Transformer Fuse	Replace - Same Size		VI
143310141	L86175	11/27/2014	8:56	11/27/2014	10:39	5	515	103	Overhead equipment	Overhead Transformer	Replace - Same Size	No Work Required	IV
143310153	D53002	11/27/2014	8:56	11/27/2014	10:30	5	470	94	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
143310156	N70330	11/27/2014	9:00	11/27/2014	10:19	1	79	79	Animal related	Transformer Fuse	Replace - Same Size		I
143310172	A49003	11/27/2014	9:12	11/27/2014	12:40	1	208	208	Animal related	Transformer Fuse	Replace - Same Size		I
143310176	M20221	11/27/2014	9:13	11/27/2014	9:46	1	33	33	Overhead equipment	Transformer Fuse			VI
143310175	X75571	11/27/2014	9:13	11/27/2014	10:40	6	522	87	Animal related	Animal Guard	Replace - Same Size		IV
143310183	X75571	11/27/2014	9:20	11/27/2014	10:54	1	94	94	Animal related				IV
143310187	B73001	11/27/2014	9:31	11/27/2014	13:45	1	254	254	Underground equipment	Vault	Patrol/Test/Inspect	Repair	I
143310209	V22555	11/27/2014	10:42	11/27/2014	12:53	18	2358	131	Overhead equipment	Overhead Primary	Repair	No Work Required	II
143310210	T08502	11/27/2014	10:52	11/27/2014	12:26	1	94	94	Animal related	Transformer Fuse	Replace - Same Size		VI
143310214	T06503	11/27/2014	11:03	11/27/2014	13:00	1	117	117	Overhead equipment	Transformer Fuse	Replace - Same Size		VI
143310241	B93003	11/27/2014	12:19	11/27/2014	13:40	1	81	81	Overhead equipment	Transformer Fuse	Replace - Same Size		I
143310261	Z16547	11/27/2014	12:33	11/27/2014	14:20	78	8346	107	Overhead equipment	Recloser	Switch/Reset		IV
143310255	R68900	11/27/2014	12:44	11/27/2014	13:40	1	56	56	Animal related	Transformer Fuse	Replace - Same Size		I
143310274	R07382	11/27/2014	13:37	11/27/2014	14:45	28	1904	68	Animal related	Fuse	Replace - Same Size	Repair	I
143310277	Y55004	11/27/2014	13:43	11/27/2014	14:55	4	288	72	Overhead equipment	Fuse	Replace - Same Size		IV
143310352	S52515	11/27/2014	17:35	11/27/2014	19:05	1	90	90	Animal related	Transformer Fuse	Replace - Same Size		VI
143310355	R49275	11/27/2014	18:02	11/27/2014	19:12	1	70	70	Underground equipment	Underground Secondary			VI
143310375	R93351	11/27/2014	20:00	11/27/2014	20:40	2	80	40	Animal related	Fuse	Replace - Same Size		V
143310427	S41562	11/27/2014	22:44	11/27/2014	23:42	1	58	58	Overhead equipment	Transformer Fuse	Replace - Same Size	No Work Required	VI
143310428	342001	11/27/2014	22:51	11/27/2014	23:54	1	63	63	Overhead equipment	Other	Patrol/Test/Inspect		VI

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
143321999	J87120	11/28/2014	3:12	11/28/2014	6:39	1	207	207	Underground equipment	Underground Secondary		Repair	VI
143322033	A49001	11/28/2014	7:12	11/28/2014	12:23	1	311	311	Underground equipment	Underground Service	Patrol/Test/Inspect	Replace - Urgent	I
143322137	X02549	11/28/2014	7:20	11/28/2014	9:15	10	1150	115	Overhead equipment	Disconnect Switch	Repair		IV
143322058	P05825	11/28/2014	7:59	11/28/2014	8:58	1	59	59	Overhead equipment	Transformer Fuse	Replace - Same Size		V
143322106	310124	11/28/2014	8:40	11/28/2014	10:01	9	729	81	Overhead equipment	Fuse	Replace - Same Size		V
143322127	X19561	11/28/2014	9:01	11/28/2014	10:38	1	97	97	Animal related	Transformer Fuse	Replace - Same Size		IV
143322154	J79305	11/28/2014	9:14	11/28/2014	11:06	1	112	112	Overhead equipment	Overhead Service	Reconnect		I
143322148	Q75145	11/28/2014	9:14	11/28/2014	11:00	8	848	106	Animal related	Fuse	Replace - Same Size	No Work Required	VI
143322253	T22508	11/28/2014	10:10	11/28/2014	11:14	10	640	64	Animal related	Transformer Fuse	Replace - Same Size		VI
143322270	B57001	11/28/2014	10:12	11/28/2014	11:00	1	48	48	Overhead equipment	Connector	Patrol/Test/Inspect	Replace - New Size	I
143322289	K58213	11/28/2014	10:23	11/28/2014	11:55	1	92	92	Animal related	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
143322311	339158	11/28/2014	10:34	11/28/2014	11:44	1	70	70	Overhead equipment	Overhead Service	Repair		V
143322319	K71822	11/28/2014	10:36	11/28/2014	16:06	1	330	330	Underground equipment	Underground Service		Repair	IV
143322324	HB5891	11/28/2014	10:42	11/28/2014	11:38	1	56	56	Unknown	Transformer Fuse	Replace - Same Size		I
143322335	M18131	11/28/2014	10:51	11/28/2014	11:31	1	40	40	Animal related	Fuse	Replace - Same Size		III
143322448	L24124	11/28/2014	11:53	11/28/2014	13:02	30	2070	69	Unknown	Fuse	Replace - Same Size		III
143322479	V40556	11/28/2014	12:24	11/28/2014	13:45	18	1458	81	Animal related	Fuse	Replace - Same Size		II
143322475	N35851	11/28/2014	12:25	11/28/2014	14:53	4	592	148	Animal related	Transformer Fuse	Switch/Reset	Switch/Reset	V
143322481	U06551	11/28/2014	12:29	11/28/2014	15:57	5	1040	208	Animal related	Transformer Fuse	Replace - Same Size		II
143322528	B65003	11/28/2014	13:00	11/28/2014	16:40	6	1320	220	Animal related	Fuse	Replace - Same Size		I
143322555	K67924	11/28/2014	13:17	11/28/2014	14:24	1	67	67	Animal related	Fuse	Replace - Same Size		VI
143322716	B19001	11/28/2014	13:44	11/28/2014	15:41	140	16380	117	Overhead equipment		No Work Required		I
143322592	P58155	11/28/2014	13:45	11/28/2014	16:31	1	166	166	Animal related	Fuse	Replace - Same Size		VI
143322766	A32003	11/28/2014	13:45	11/28/2014	21:05	9	3960	440	Public	Other		Repair	I
143322591	B19001	11/28/2014	13:50	11/28/2014	15:57	98	12446	127	Overhead equipment	Disconnect Switch	Patrol/Test/Inspect		I
143322664	U10001	11/28/2014	14:46	11/28/2014	16:05	1	79	79	Overhead equipment	Overhead Service	Repair	Repair	II
143322771	U84587	11/28/2014	16:25	11/28/2014	18:40	1	135	135	Overhead equipment	Connector	Repair		II
143322787	B21002	11/28/2014	16:49	11/28/2014	18:55	2	252	126	Overhead equipment	Overhead Primary	Patrol/Test/Inspect	Remove	I
143322899	R08910	11/28/2014	17:46	11/28/2014	19:46	1	120	120	Animal related	Fuse	Replace - Same Size	Patrol/Test/Inspect	VI
143322905	P47123	11/28/2014	17:56	11/28/2014	21:59	17	4131	243	Overhead equipment	Fuse	No Work Required	Repair	I
143323232	P47123	11/28/2014	19:55	11/28/2014	21:53	1	118	118	Overhead equipment	Overhead Transformer	Switch/Reset		I
143330016	S30518	11/28/2014	20:51	11/29/2014	2:45	52	18408	354	Underground equipment	Fuse			VI
143330023	S30518	11/28/2014	20:51	11/29/2014	7:30	9	5751	639	Underground equipment	Underground Primary	Switch/Reset		VI
143323256	R66470	11/28/2014	21:35	11/29/2014	0:01	12	1752	146	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Repair	IV
143330060	Q47833	11/29/2014	7:30	11/29/2014	8:40	2	140	70	Overhead equipment	Fuse	Repair	Repair	V
143330071	L17102	11/29/2014	7:43	11/29/2014	8:20	32	1184	37	Overhead equipment	Fuse	Replace - Same Size		III
143330072	P77235	11/29/2014	7:46	11/29/2014	8:46	1	60	60	Animal related	Fuse	Replace - Same Size	No Work Required	VI
143330094	P17107	11/29/2014	8:14	11/29/2014	9:45	36	3276	91	Animal related	Fuse		Replace - Same Size	IV
143330145	N58144	11/29/2014	8:25	11/29/2014	9:38	1	73	73	Unknown	Fuse	Repair	Replace - Same Size	I
143330159	X69555	11/29/2014	8:43	11/29/2014	9:44	1	61	61	Overhead equipment	Fuse			IV
143330170	HB5891	11/29/2014	8:58	11/29/2014	12:45	1	227	227	Overhead equipment	Jumper	Repair		I
143330174	R73841	11/29/2014	9:11	11/29/2014	11:08	1	117	117	Animal related	Transformer Fuse	Switch/Reset	Switch/Reset	V
143330210	B93001	11/29/2014	10:01	11/29/2014	11:20	1	79	79	Overhead equipment	Connector	Repair		I
143330228	Y07576	11/29/2014	10:25	11/29/2014	11:34	1	69	69	Animal related	Transformer Fuse	Replace - Same Size		IV
143330250	R06211	11/29/2014	10:58	11/29/2014	13:35	1	157	157	Underground equipment	Underground Service	Switch/Reset	Repair	II
143330461	D41002	11/29/2014	11:06	11/29/2014	17:44	2	796	398	Underground equipment	Underground Primary	Repair		I
143330318	D41002	11/29/2014	11:06	11/29/2014	14:06	1	180	180	Underground equipment	Underground Primary	Switch/Reset	Switch/Reset	I
143330256	J75271	11/29/2014	11:11	11/29/2014	14:33	1	202	202	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	IV
143330261	R48165	11/29/2014	11:15	11/29/2014	12:08	1	53	53	Overhead equipment	Disconnect Switch			IV
143330291	Q91141	11/29/2014	11:28	11/29/2014	13:50	559	79378	142	Animal related	Recloser	Repair	Switch/Reset	I
143330292	Q91141	11/29/2014	11:36	11/29/2014	14:00	2	288	144	Animal related	Fuse	Repair	Replace - Same Size	I
143330296	Y36541	11/29/2014	11:42	11/29/2014	12:37	1	55	55	Tree related-tree broken	Fuse			IV
143330300	B65003	11/29/2014	11:42	11/29/2014	12:46	51	3264	64	Unknown	Disconnect Switch	Replace - Same Size	Replace - Same Size	I
143330310	L24123	11/29/2014	11:55	11/29/2014	17:12	17	5389	317	Overhead equipment	Pole	Replace - Same Size		III
143330317	P58154	11/29/2014	12:02	11/29/2014	13:06	1	64	64	Public	Pole	Patrol/Test/Inspect		VI
143330330	Y51505	11/29/2014	12:18	11/29/2014	13:03	6	270	45	Animal related	Transformer Fuse	Replace - Same Size		IV

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
143330331	V49541	11/29/2014	12:24	11/29/2014	13:02	3	114	38	Animal related	Transformer Fuse	Replace - Same Size		II
143330350	Q36410	11/29/2014	12:45	11/29/2014	13:31	1	46	46	Overhead equipment	Transformer Fuse	Replace - Same Size	Repair	I
143330366	X60595	11/29/2014	12:56	11/29/2014	13:40	607	26708	44	Overhead equipment	Connector			IV
143330363	P58155	11/29/2014	12:59	11/29/2014	15:05	1	126	126	Tree related-tree broken	Overhead Service	Repair	Repair	VI
143330371	L43153	11/29/2014	12:59	11/29/2014	17:07	1	248	248	Overhead equipment	Overhead Transformer	Switch/Reset	Replace - Same Size	I
143330436	N50332	11/29/2014	13:29	11/29/2014	16:25	79	13904	176	Tree related-tree broken	Overhead Primary	Repair	No Work Required	II
143330446	Q64919	11/29/2014	13:52	11/29/2014	15:47	1	115	115	Animal related	Transformer Fuse	Replace - Same Size		VI
143330468	H01190	11/29/2014	14:25	11/29/2014	15:51	1	86	86	Overhead equipment	Overhead Secondary	Repair		III
143330475	P58155	11/29/2014	14:47	11/29/2014	15:51	1	64	64	Tree related-tree broken	Overhead Service	Repair		VI
143330476	Q91141	11/29/2014	14:51	11/29/2014	16:13	1	82	82	Animal related	Fuse	Repair	Replace - Same Size	I
143330491	IP9009	11/29/2014	15:09	11/29/2014	17:01	1	112	112	Overhead equipment	Overhead Service		Replace - New Size	VI
143330522	M47816	11/29/2014	16:10	11/29/2014	16:49	1	39	39	Overhead equipment	Connector	Repair	Repair	V
143330580	B27009	11/29/2014	16:26	11/29/2014	20:51	6	1590	265	Overhead equipment	Crossarm	Repair		I
143332884	N50332	11/29/2014	18:43	11/29/2014	20:02	1	79	79	Tree related-tree broken	Overhead Service	Patrol/Test/Inspect		II
143332951	J89126	11/29/2014	18:45	11/29/2014	19:49	1	64	64	Overhead equipment	Connector	Tie/Tighten		VI
143333982	M36189	11/29/2014	19:10	11/29/2014	19:54	1	44	44	Unknown	Fuse	Repair	Replace - Same Size	I
143338592	Q11517	11/29/2014	19:59	11/29/2014	23:48	2	458	229	Overhead equipment	Overhead Secondary			I
143338581	K58210	11/29/2014	21:30	11/30/2014	2:16	1	286	286	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	VI
143338612	R53391	11/29/2014	23:36	11/30/2014	0:16	1	40	40	Underground equipment	Underground Service	Patrol/Test/Inspect	Repair	V
143340011	L93133	11/30/2014	0:24	11/30/2014	1:58	33	3102	94	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	VI
143340014	M09144	11/30/2014	0:41	11/30/2014	2:12	11	1001	91	Overhead equipment	Overhead Secondary	Replace - Same Size	No Work Required	VI
143340050	T06505	11/30/2014	7:07	11/30/2014	8:25	1	78	78	Animal related	Transformer Fuse	Replace - Same Size		VI
143340194	U32245	11/30/2014	7:48	11/30/2014	13:12	841	272484	324	Overhead equipment	Connector	Switch/Reset	Replace - Same Size	II
143340138	310122	11/30/2014	8:17	11/30/2014	8:50	1	33	33	Animal related	Fuse	Replace - Same Size		V
143340154	V99562	11/30/2014	8:26	11/30/2014	9:50	1	84	84	Animal related	Transformer Fuse	Replace - Same Size	Patrol/Test/Inspect	II
143340160	K39156	11/30/2014	8:31	11/30/2014	9:29	1	58	58	Animal related	Fuse	Replace - Same Size		III
143340162	N35852	11/30/2014	8:36	11/30/2014	9:23	3	141	47	Animal related	Transformer Fuse	Replace - Same Size		V
143340187	A36001	11/30/2014	8:50	11/30/2014	9:25	7	245	35	Animal related	Fuse	Replace - Same Size		I
143340197	M45212	11/30/2014	9:14	11/30/2014	10:25	1	71	71	Overhead equipment	Jumper	Repair		IV
143340247	E05001	11/30/2014	9:28	11/30/2014	12:56	1	208	208	Underground equipment	Underground Service	Patrol/Test/Inspect	Repair	IV
143340268	P73157	11/30/2014	9:48	11/30/2014	11:28	14	1400	100	Overhead equipment	Fuse	Replace - New Size		VI
143340258	R16511	11/30/2014	9:53	11/30/2014	11:26	1	93	93	Overhead equipment	Fuse	Replace - Same Size		I
143340278	HD0574	11/30/2014	10:33	11/30/2014	15:15	2	564	282	Overhead equipment	Fuse	Replace - Same Size	Repair	VI
143340290	P42230	11/30/2014	11:04	11/30/2014	12:05	1	61	61	Animal related	Transformer Fuse	Replace - Same Size	No Work Required	VI
143340302	P53341	11/30/2014	11:27	11/30/2014	12:59	1	92	92	Animal related	Transformer Fuse	Replace - Same Size	No Work Required	IV
143340314	S92559	11/30/2014	12:03	11/30/2014	13:17	1	74	74	Animal related	Transformer Fuse	Replace - Same Size		VI
143340318	V74513	11/30/2014	12:09	11/30/2014	13:15	8	528	66	Animal related	Transformer Fuse		Replace - Same Size	II
143340320	K31124	11/30/2014	12:13	11/30/2014	14:05	1	112	112	Tree related-tree contact	Transformer Fuse	Replace - Same Size		I
143340325	L59929	11/30/2014	12:25	11/30/2014	15:07	1	162	162	Tree related-tree broken	Overhead Service	Cut in Clear		VI
143340418	J34377	11/30/2014	12:57	11/30/2014	17:21	179	47256	264	Overhead equipment	Overhead Primary	Patrol/Test/Inspect	Repair	V
143340513	T16527	11/30/2014	13:36	11/30/2014	14:45	1	69	69	Animal related	Fuse	Replace - New Size		VI
143340514	R60551	11/30/2014	13:38	11/30/2014	17:00	8	1616	202	Underground equipment	Underground Service	Patrol/Test/Inspect	Repair	IV
143340541	H06135	11/30/2014	13:43	11/30/2014	15:29	105	11130	106	Overhead equipment	Overhead Primary	Repair		IV
143340524	A16002	11/30/2014	13:46	11/30/2014	14:55	1	69	69	Overhead equipment	Connector	Repair		I
143340625	Y98561	11/30/2014	14:00	11/30/2014	16:25	12	1740	145	Underground equipment	Underground Primary	Switch/Reset		IV
143340551	S60581	11/30/2014	14:22	11/30/2014	15:00	1	38	38	Animal related	Transformer Fuse	Replace - Same Size		VI
143340555	B65003	11/30/2014	14:29	11/30/2014	15:15	98	4508	46	Unknown	Disconnect Switch	Replace - Same Size	Replace - Same Size	I
143340562	M21134	11/30/2014	14:44	11/30/2014	16:39	3	345	115	Animal related	Transformer Fuse	Replace - Same Size	Replace - Same Size	VI
143340567	325010	11/30/2014	14:48	11/30/2014	17:20	6	912	152	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	VI
143340570	S60581	11/30/2014	14:50	11/30/2014	15:30	1	40	40	Animal related	Transformer Fuse	Replace - Same Size		VI
143340583	B00002	11/30/2014	14:56	11/30/2014	15:48	36	1872	52	Unknown	Disconnect Switch	Replace - Same Size	Replace - Same Size	I
143340595	HD0574	11/30/2014	15:37	11/30/2014	18:55	1	198	198	Underground equipment	Underground Primary			VI
143340635	U06524	11/30/2014	16:34	11/30/2014	17:11	5	185	37	Overhead equipment	Transformer Fuse	Replace - Same Size		II
143340664	J18268	11/30/2014	17:08	12/01/2014	2:35	2	1134	567	Tree related-tree broken	Pole	Patrol/Test/Inspect	Replace - Same Size	VI
143340686	K78352	11/30/2014	18:27	11/30/2014	20:41	1	134	134	Underground equipment	Underground Service	Patrol/Test/Inspect	Repair	IV
143341694	L71170	11/30/2014	19:21	11/30/2014	20:13	1	52	52	Overhead equipment	Fuse			IV

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
143342415	S47589	11/30/2014	19:34	11/30/2014	21:08	19	1786	94	Tree related-tree broken	Fuse	Replace - Same Size		VI
143353107	L99392	12/01/2014	6:12	12/01/2014	7:22	1	70	70	Overhead equipment	Connector	Replace - Same Size	Replace - Same Size	V
143353111	M04365	12/01/2014	6:14	12/01/2014	7:24	3	210	70	Overhead equipment	Overhead Primary	Repair		V
143353129	V23592	12/01/2014	6:50	12/01/2014	8:44	1	114	114	Overhead equipment	Overhead Primary	Reconnect	Replace - Same Size	II
143353134	N50334	12/01/2014	6:54	12/01/2014	9:00	1	126	126	Overhead equipment	Overhead Secondary	Repair		II
143353148	R01152	12/01/2014	7:07	12/01/2014	8:06	1	59	59	Animal related	Transformer Fuse	Repair	Repair	III
143353187	303001	12/01/2014	7:19	12/01/2014	10:34	1	195	195	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	VI
143353544	J50185	12/01/2014	7:56	12/01/2014	9:25	39	3471	89	Animal related	Fuse	Replace - Same Size		III
143353340	J82117	12/01/2014	8:10	12/01/2014	9:29	6	474	79	Public	Overhead Primary	Patrol/Test/Inspect	Repair	VI
143353458	J84124	12/01/2014	8:38	12/01/2014	9:20	1	42	42	Animal related	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
143353515	M25143	12/01/2014	8:45	12/01/2014	12:00	1	195	195	Underground equipment	Underground Service	Repair	Repair	IV
143353521	J84123	12/01/2014	8:47	12/01/2014	19:20	1	633	633	Underground equipment	Underground Secondary	Patrol/Test/Inspect	Repair	VI
143353578	H22347	12/01/2014	9:01	12/01/2014	11:01	1	120	120	Animal related	Fuse	Replace - Same Size		V
143353616	M22812	12/01/2014	9:13	12/01/2014	10:16	1	63	63	Public	Transformer Fuse	Repair		V
143353619	A16001	12/01/2014	9:15	12/01/2014	10:14	1	59	59	Overhead equipment	Connector	Patrol/Test/Inspect	Replace - New Size	I
143353829	V77543	12/01/2014	9:56	12/01/2014	10:35	6	234	39	Animal related	Fuse	Replace - Same Size		II
143353877	Q74148	12/01/2014	10:14	12/01/2014	10:36	1	22	22	Overhead equipment	Jumper	Repair		IV
143353896	J15303	12/01/2014	10:17	12/01/2014	12:10	1	113	113	Tree related-tree contact	Overhead Service	Replace - New Size		I
143354130	Q74150	12/01/2014	11:09	12/01/2014	12:24	1	75	75	Overhead equipment	Jumper	Repair		IV
143354142	P73158	12/01/2014	11:12	12/01/2014	13:30	1	138	138	Overhead equipment	Overhead Service	Repair		VI
143354280	V23522	12/01/2014	11:16	12/01/2014	12:18	12	744	62	Unknown	Fuse	Repair	Replace - Same Size	II
143354163	A17025	12/01/2014	11:20	12/01/2014	12:34	1	74	74	Overhead equipment	Connector	Replace - Same Size		I
143354208	Y13043	12/01/2014	11:32	12/01/2014	11:56	1	24	24	Overhead equipment	Overhead Service	Repair	Repair	IV
143354297	P69174	12/01/2014	12:01	12/01/2014	12:57	1	56	56	Overhead equipment	Overhead Service	Repair		III
143354312	N05170	12/01/2014	12:01	12/01/2014	14:20	1	139	139	Overhead equipment	Overhead Service	Repair	Repair	I
143354447	U99515	12/01/2014	12:35	12/01/2014	13:24	425	20825	49	Unknown				II
143354629	Q16868	12/01/2014	13:15	12/01/2014	20:15	1	420	420	Underground equipment	Underground Service	Patrol/Test/Inspect	Repair	V
143354639		12/01/2014	13:18	12/01/2014	15:05	1	107	107	Tree related-tree broken	Overhead Secondary	Patrol/Test/Inspect	Repair	VI
143354750	Y07576	12/01/2014	13:26	12/01/2014	14:45	493	38947	79	Overhead equipment	Disconnect Switch	Replace - Same Size	Replace - Same Size	IV
143354742	P25152	12/01/2014	13:33	12/01/2014	14:45	1	72	72	Overhead equipment	Connector	Replace - Same Size		III
143354955	Q83171	12/01/2014	14:25	12/01/2014	18:39	1	254	254	Public	Overhead Service		Replace - Same Size	VI
143354978	Q91175	12/01/2014	14:32	12/01/2014	15:31	1	59	59	Overhead equipment	Fuse	No Work Required		I
143355030	C70001	12/01/2014	14:44	12/01/2014	15:55	1	71	71	Underground equipment	Underground Service	Cut in Clear	Repair	III
143355033	Q82907	12/01/2014	14:45	12/01/2014	17:44	1	179	179	Tree related-tree broken	Tree		Remove	VI
143355097	U39541	12/01/2014	15:02	12/01/2014	16:40	1	98	98	Other	Overhead Service	Reconnect		II
143355230	303005	12/01/2014	15:36	12/01/2014	16:30	1	54	54	Overhead equipment	Fuse	Replace - Same Size		VI
143355234	M26161	12/01/2014	15:37	12/01/2014	17:06	24	2136	89	Animal related	Fuse	Replace - Same Size		III
143355244	342003	12/01/2014	15:42	12/01/2014	16:30	1	48	48	Public	Pole	Patrol/Test/Inspect	Replace - Same Size	VI
143355335	T41540	12/01/2014	16:15	12/01/2014	17:15	1	60	60	Overhead equipment	Overhead Service	Repair		IV
143355448	342003	12/01/2014	17:20	12/01/2014	17:55	1	35	35	Overhead equipment	Fuse	Replace - Same Size		VI
143355456	M09143	12/01/2014	17:35	12/01/2014	18:06	1	31	31	Overhead equipment	Connector	Replace - Same Size	No Work Required	VI
143355608	L24124	12/01/2014	18:34	12/01/2014	19:54	1	80	80	Underground equipment	Underground Service		Repair	III
143355629	J87111	12/01/2014	19:05	12/01/2014	20:15	1	70	70	Overhead equipment	Transformer Fuse	Replace - Same Size		VI
143355633	P18103	12/01/2014	19:08	12/01/2014	20:20	1	72	72	Animal related	Transformer Fuse	Replace - Same Size		IV
143356182	D60001	12/01/2014	19:50	12/02/2014	0:09	1	259	259	Underground equipment	Underground Secondary	Repair		III
143356198	T09530	12/01/2014	20:49	12/01/2014	21:48	6	354	59	Overhead equipment	Transformer Fuse	Repair	Repair	VI
143356211	M26161	12/01/2014	21:51	12/01/2014	22:20	1	29	29	Overhead equipment	Jumper	Repair		III
143360205	N67316	12/02/2014	2:18	12/02/2014	3:28	9	630	70	Overhead equipment	Jumper	Repair		I
143362924	P54828	12/02/2014	5:03	12/02/2014	7:55	1	172	172	Overhead equipment	Overhead Transformer	Replace - New Size	Replace - New Size	V
143362921	C60001	12/02/2014	5:48	12/02/2014	11:39	1	351	351	Public	Pole	Replace - Same Size		III
143363054	B80002	12/02/2014	7:15	12/02/2014	9:07	1	112	112	Overhead equipment	Connector	Patrol/Test/Inspect	Replace - New Size	I
143363059	J71129	12/02/2014	7:17	12/02/2014	8:48	1	91	91	Overhead equipment	Fuse	Replace - Same Size		I
143363153	N05172	12/02/2014	7:48	12/02/2014	8:48	1	60	60	Unknown	Transformer Fuse	Replace - Same Size		I
143363196	X22001	12/02/2014	7:59	12/02/2014	9:05	1	66	66	Overhead equipment	Overhead Service	Repair	Patrol/Test/Inspect	IV
143365249	K57211	12/02/2014	8:10	12/02/2014	13:10	11	3300	300	Underground equipment	Underground Transformer	Switch/Reset		VI
143363281	K57211	12/02/2014	8:10	12/02/2014	20:05	42	30030	715	Underground equipment	Underground Transformer	Replace - Same Size	Replace - Same Size	VI

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
143363323	R06212	12/02/2014	8:26	12/02/2014	12:38	1	252	252	Public	Underground Transformer	Repair	Repair	II
143363497	310123	12/02/2014	9:14	12/02/2014	10:22	1	68	68	Overhead equipment	Fuse	Replace - Same Size		V
143363500	Q34366	12/02/2014	9:16	12/02/2014	10:00	1	44	44	Animal related	Fuse	Replace - Same Size	Repair	I
143363506	K43385	12/02/2014	9:18	12/02/2014	10:02	1	44	44	Underground equipment	Underground Service	Cut in Clear	Repair	V
143363658	U41545	12/02/2014	9:57	12/02/2014	10:51	1	54	54	Animal related	Transformer Fuse	Replace - Same Size		II
143363718	K76546	12/02/2014	10:11	12/02/2014	11:58	1	107	107	Overhead equipment	Overhead Service	Repair		IV
143363783	N60181	12/02/2014	10:16	12/02/2014	11:11	11	605	55	Animal related	Fuse	Replace - Same Size		I
143363782	HB6283	12/02/2014	10:25	12/02/2014	11:00	1	35	35	Animal related	Fuse	Repair		VI
143363995	Q11516	12/02/2014	10:31	12/02/2014	12:12	9	909	101	Animal related	Fuse	Replace - Same Size		I
143363970		12/02/2014	11:06	12/02/2014	11:42	1	36	36	Overhead equipment	Overhead Service	Repair		VI
143363985	V49008	12/02/2014	11:12	12/02/2014	12:00	1	48	48	Jurisdictional				II
143364030	N73122	12/02/2014	11:24	12/02/2014	13:30	1	126	126	Overhead equipment	Overhead Primary			IV
143364204	F10002	12/02/2014	11:38	12/02/2014	13:32	452	51528	114	Overhead equipment	Overhead Primary	Repair		III
143364395	HB6283	12/02/2014	11:39	12/02/2014	12:30	10	510	51	Overhead equipment	Overhead Primary			VI
143364450	HB6283	12/02/2014	11:39	12/02/2014	13:40	379	45859	121	Overhead equipment	Overhead Primary			VI
143364501	HB6283	12/02/2014	11:39	12/02/2014	14:45	578	107508	186	Overhead equipment	Overhead Primary			VI
143364113	Q27185	12/02/2014	11:44	12/02/2014	12:36	1	52	52	Overhead equipment	Transformer Fuse	Replace - Same Size		VI
143364120	M05360	12/02/2014	11:45	12/02/2014	12:50	1	65	65	Overhead equipment	Overhead Transformer	Replace - Same Size		V
143364124	X69556	12/02/2014	11:46	12/02/2014	12:08	1	22	22	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
143364139	M21133	12/02/2014	11:46	12/02/2014	12:45	1	59	59	Animal related	Transformer Fuse	Repair	Repair	VI
143364209	X02548	12/02/2014	12:10	12/02/2014	12:53	1	43	43	Overhead equipment	Disconnect Switch			IV
143364514		12/02/2014	13:17	12/02/2014	14:30	1	73	73	Animal related	Fuse	Repair		VI
143364797	HB6283	12/02/2014	13:55	12/02/2014	15:22	472	41064	87	Overhead equipment	Substation Breaker	Switch/Reset		VI
143365003	HB6283	12/02/2014	13:55	12/03/2014	3:00	3	2355	785	Underground equipment	Underground Transformer	Replace - Same Size	Replace - Same Size	VI
143364689	HB6283	12/02/2014	14:00	12/02/2014	15:24	1	84	84	Overhead equipment				VI
143364709	HB6283	12/02/2014	14:05	12/02/2014	16:00	1	115	115	Overhead equipment				VI
143365000	HB6283	12/02/2014	14:16	12/02/2014	16:00	2	208	104	Overhead equipment				VI
143364987	K95208	12/02/2014	15:38	12/02/2014	16:00	1	22	22	Overhead equipment	Connector	Replace - Same Size		III
143365035	J80806	12/02/2014	15:50	12/02/2014	17:22	1	92	92	Animal related	Overhead Transformer	Repair	Repair	V
143365036	HB6283	12/02/2014	15:51	12/02/2014	16:02	1	11	11	Overhead equipment				VI
143365051	HB6283	12/02/2014	15:54	12/03/2014	6:28	1	874	874	Overhead equipment				VI
143365052	HB6283	12/02/2014	15:54	12/02/2014	16:02	1	8	8	Overhead equipment				VI
143365059	P77235	12/02/2014	15:59	12/02/2014	17:00	1	61	61	Animal related	Transformer Fuse	Replace - Same Size		VI
143365080	K58213	12/02/2014	16:08	12/02/2014	17:34	13	1118	86	Overhead equipment	Fuse	Replace - Same Size		VI
143365124	D31016	12/02/2014	16:27	12/02/2014	18:40	1	133	133	Overhead equipment	Overhead Transformer			III
143365149	N95823	12/02/2014	16:38	12/02/2014	17:50	1	72	72	Overhead equipment	Transformer Fuse	Replace - Same Size		V
143365237	B81001	12/02/2014	17:40	12/02/2014	22:52	1	312	312	Overhead equipment	Overhead Transformer	Replace - Same Size		I
143365260	Q91175	12/02/2014	18:04	12/02/2014	19:08	1	64	64	Unknown	Fuse	Repair	Replace - Same Size	I
143365266	P17107	12/02/2014	18:16	12/02/2014	19:16	1	60	60	Overhead equipment	Connector	Repair	No Work Required	IV
143365294	S47576	12/02/2014	18:53	12/02/2014	19:55	1	62	62	Overhead equipment	Overhead Service	Patrol/Test/Inspect	Repair	VI
143365671	J63173	12/02/2014	19:25	12/03/2014	6:56	10	6910	691	Underground equipment	Underground Primary			III
143365315	J63173	12/02/2014	19:28	12/02/2014	21:05	18	1746	97	Underground equipment	Underground Primary	Switch/Reset		III
143365319	M81403	12/02/2014	19:38	12/02/2014	22:35	1	177	177	Underground equipment	Underground Service	Patrol/Test/Inspect	Repair	V
143365639	K57211	12/02/2014	20:20	12/02/2014	21:50	14	1260	90	Overhead equipment	Fuse	Replace - Same Size		VI
143365681	P19395	12/02/2014	21:31	12/02/2014	22:50	1	79	79	Overhead equipment	Connector	Replace - Same Size		V
143365686	K57211	12/02/2014	22:02	12/02/2014	23:26	1	84	84	Overhead equipment	Fuse	Replace - Same Size		VI
143372780	J50185	12/03/2014	7:12	12/03/2014	9:10	104	12272	118	Underground equipment	Underground Primary			III
143372886	R65451	12/03/2014	7:47	12/03/2014	8:50	1	63	63	Overhead equipment	Connector	Repair	No Work Required	IV
143372897	S86582	12/03/2014	7:53	12/03/2014	9:32	1	99	99	Animal related	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
143372926	S47576	12/03/2014	8:02	12/03/2014	9:13	1	71	71	Animal related	Fuse	Replace - Same Size	Patrol/Test/Inspect	VI
143372966	S42579	12/03/2014	8:11	12/03/2014	9:46	1	95	95	Animal related	Transformer Fuse	Repair	Replace - Same Size	VI
143373020	S14510	12/03/2014	8:25	12/03/2014	9:00	3	105	35	Animal related	Fuse	Replace - Same Size		VI
143373043	J75271	12/03/2014	8:30	12/03/2014	9:44	1	74	74	Overhead equipment	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	IV
143373102	U13551	12/03/2014	8:45	12/03/2014	10:48	1	123	123	Animal related	Transformer Fuse	Replace - Same Size		II
143373202	J83140	12/03/2014	8:57	12/03/2014	9:29	22	704	32	Animal related	Fuse	Replace - Same Size		VI
143373162	K25166	12/03/2014	8:59	12/03/2014	9:29	13	390	30	Animal related	Fuse	Repair	Repair	VI

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
143373232	Z18553	12/03/2014	9:12	12/03/2014	11:38	1	146	146	Underground equipment	Underground Secondary	Repair	Repair	IV
143373414	S21529	12/03/2014	9:47	12/03/2014	10:46	1	59	59	Animal related	Transformer Fuse	Repair	Replace - Same Size	VI
143373645	N95824	12/03/2014	10:38	12/03/2014	14:39	1	241	241	Underground equipment	Underground Service	Repair		V
143373656	R50910	12/03/2014	10:41	12/03/2014	12:09	1	88	88	Animal related	Fuse	Repair		I
143373678	B80003	12/03/2014	10:47	12/03/2014	12:05	1	78	78	Animal related	Transformer Fuse	Replace - Same Size	No Work Required	I
143373750	R95520	12/03/2014	11:05	12/03/2014	13:12	1	127	127	Tree related-tree contact	Transformer Fuse	Repair		I
143373800	S27599	12/03/2014	11:07	12/03/2014	11:30	865	19895	23	Overhead equipment				VI
143373820	M45211	12/03/2014	11:18	12/03/2014	11:34	1	16	16	Animal related	Transformer Fuse	Replace - Same Size		IV
143373947	V26276	12/03/2014	11:38	12/03/2014	13:04	1094	94084	86	Transmission outage	Other			II
143373914	K15205	12/03/2014	11:45	12/03/2014	12:23	1	38	38	Animal related	Transformer Fuse	Replace - Same Size		VI
143374008	S14510	12/03/2014	12:03	12/03/2014	14:21	1	138	138	Underground equipment	Overhead Service	Repair	Repair	VI
143374013	Y34597	12/03/2014	12:04	12/03/2014	13:04	1	60	60	Overhead equipment	Overhead Service	Repair		IV
143374046	S78551	12/03/2014	12:16	12/03/2014	13:55	1	99	99	Animal related	Transformer Fuse	Replace - Same Size	Patrol/Test/Inspect	VI
143374092	C66002	12/03/2014	12:31	12/03/2014	13:27	1	56	56	Animal related	Fuse	Replace - Same Size		III
143374131	X75512	12/03/2014	12:45	12/03/2014	13:30	6	270	45	Animal related	Transformer Fuse	Replace - Same Size	Replace - Same Size	IV
143374258	D88001	12/03/2014	12:58	12/03/2014	15:04	13	1638	126	Overhead equipment	Fuse	Replace - Same Size		I
143374241	S47575	12/03/2014	13:15	12/03/2014	13:51	1	36	36	Animal related	Fuse			VI
143374402	H11339	12/03/2014	13:38	12/03/2014	14:30	33	1716	52	Animal related	Transformer Fuse	Replace - Same Size		V
143374393	N05173	12/03/2014	13:54	12/03/2014	15:00	1	66	66	Overhead equipment	Disconnect Switch	Repair	Repair	I
143374431	V84509	12/03/2014	14:03	12/03/2014	15:08	1	65	65	Animal related	Transformer Fuse	Replace - Same Size		II
143374477	J80807	12/03/2014	14:08	12/03/2014	14:55	5	235	47	Animal related	Overhead Primary	Repair	Repair	V
143374559	J12166	12/03/2014	14:37	12/03/2014	15:55	21	1638	78	Unknown	Fuse	Replace - Same Size		III
143374548	P26283	12/03/2014	14:38	12/03/2014	16:04	1	86	86	Animal related	Fuse	Patrol/Test/Inspect	Repair	I
143374629	P54827	12/03/2014	14:59	12/03/2014	16:01	18	1116	62	Animal related	Fuse	Replace - Same Size		V
143374672	T08501	12/03/2014	15:06	12/03/2014	15:22	31	496	16	Overhead equipment	Overhead Primary	Patrol/Test/Inspect	Replace - Same Size	VI
143374754	R20502	12/03/2014	15:09	12/03/2014	16:10	473	28853	61	Public	Pole			IV
143374759	M04365	12/03/2014	15:21	12/03/2014	16:42	28	2268	81	Animal related	Fuse	Replace - Same Size		V
143374852	N93260	12/03/2014	16:02	12/03/2014	16:56	1	54	54	Overhead equipment	Connector			III
143374908	L24122	12/03/2014	16:15	12/03/2014	17:02	7	329	47	Unknown	Fuse	Replace - Same Size		III
143374890	T03582	12/03/2014	16:16	12/03/2014	17:39	1	83	83	Overhead equipment	Transformer Fuse	Repair	Repair	VI
143374902	L62927	12/03/2014	16:18	12/03/2014	17:56	1	98	98	Overhead equipment	Overhead Service	Repair		VI
143374953	M09143	12/03/2014	16:41	12/03/2014	17:14	45	1485	33	Animal related	Fuse	Replace - Same Size	No Work Required	VI
143374963	M21133	12/03/2014	16:43	12/03/2014	17:37	1	54	54	Animal related	Transformer Fuse	Replace - Same Size	No Work Required	VI
143376995	Y54002	12/03/2014	17:00	12/03/2014	21:05	12	2940	245	Overhead equipment	Overhead Primary			IV
143376857	Y54002	12/03/2014	17:00	12/03/2014	17:42	279	11718	42	Overhead equipment	Overhead Primary	Switch/Reset		IV
143376958	Y54002	12/03/2014	17:00	12/03/2014	18:03	146	9198	63	Overhead equipment	Overhead Primary	Switch/Reset		IV
143376960	Y54002	12/03/2014	17:00	12/03/2014	17:57	58	3306	57	Overhead equipment	Overhead Primary	Switch/Reset		IV
143375981	A81004	12/03/2014	17:10	12/03/2014	19:17	1	127	127	Animal related				I
143377433	N35851	12/03/2014	20:35	12/04/2014	4:30	1	475	475	Underground equipment	Underground Service	Repair	Repair	V
143377447	J07135	12/03/2014	20:51	12/03/2014	21:53	1	62	62	Animal related	Fuse	Repair	Replace - Same Size	I
143377479	Q24313	12/03/2014	23:10	12/04/2014	4:50	2	680	340	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	VI
143382455	K74164	12/04/2014	7:26	12/04/2014	7:52	24	624	26	Animal related	Fuse	Repair		IV
143382609	J99128	12/04/2014	7:36	12/04/2014	9:56	16	2240	140	Overhead equipment	Fuse		Replace - New Size	VI
143382541	J99128	12/04/2014	7:36	12/04/2014	8:05	1277	37033	29	Overhead equipment	Fuse		Replace - Same Size	VI
143382603	S14511	12/04/2014	8:02	12/04/2014	8:06	1	4	4	Overhead equipment	Disconnect Switch	Patrol/Test/Inspect	Replace - Same Size	VI
143382662	Y89002	12/04/2014	8:21	12/04/2014	9:52	1	91	91	Overhead equipment	Transformer Fuse	Repair	Replace - Same Size	IV
143382723	N67309	12/04/2014	8:42	12/04/2014	9:19	1	37	37	Overhead equipment	Transformer Fuse	Replace - Same Size		I
143382735	K89142	12/04/2014	8:46	12/04/2014	9:18	25	800	32	Unknown	Fuse	Replace - Same Size		III
143382749	M37192	12/04/2014	8:51	12/04/2014	9:17	1	26	26	Overhead equipment	Overhead Service	Repair		I
143382785	K57212	12/04/2014	9:02	12/04/2014	9:29	1	27	27	Animal related	Fuse	Replace - Same Size	Replace - Same Size	VI
143382797	C52002	12/04/2014	9:03	12/04/2014	9:45	35	1470	42	Animal related	Fuse	Replace - Same Size		III
143382964	M37191	12/04/2014	9:51	12/04/2014	10:03	7	84	12	Underground equipment	Underground Primary	Switch/Reset	Patrol/Test/Inspect	I
143383036	X65540	12/04/2014	10:16	12/04/2014	11:00	1	44	44	Overhead equipment	Overhead Service	Repair		IV
143383117	A36002	12/04/2014	10:29	12/04/2014	11:55	75	6450	86	Animal related	Fuse	Replace - Same Size		I
143383119	K74166	12/04/2014	10:36	12/04/2014	11:15	1	39	39	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
143383138	D89002	12/04/2014	10:40	12/04/2014	12:12	100	9200	92	Unknown	Fuse	Replace - Same Size		I

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
143383238	J34357	12/04/2014	10:53	12/04/2014	12:18	18	1530	85	Animal related	Fuse	Replace - Same Size		V
143383197	J34357	12/04/2014	10:56	12/04/2014	12:08	1	72	72	Animal related	Fuse	Replace - Same Size		V
143383281	A36002	12/04/2014	10:58	12/04/2014	11:55	18	1026	57	Animal related				I
143383225	A97002	12/04/2014	10:59	12/04/2014	11:55	150	8400	56	Animal related	Fuse	Replace - Same Size		I
143383408	Q25802	12/04/2014	11:47	12/04/2014	16:44	1	297	297	Public	Pole			I
143383406	L82187	12/04/2014	11:47	12/04/2014	12:35	1	48	48	Animal related	Fuse	Replace - Same Size		IV
143383524	M18131	12/04/2014	12:12	12/04/2014	14:01	1	109	109	Overhead equipment	Overhead Service	Replace - Same Size		III
143383538	346002	12/04/2014	12:16	12/04/2014	12:36	1	20	20	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect		VI
143383554	X72535	12/04/2014	12:20	12/04/2014	13:50	1	90	90	Overhead equipment	Transformer Fuse	Repair		IV
143383646	A49002	12/04/2014	12:33	12/04/2014	14:31	5	590	118	Underground equipment	Underground Primary			I
143383665	S88503	12/04/2014	12:47	12/04/2014	13:20	1	33	33	Overhead equipment	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
143383695	M47802	12/04/2014	12:54	12/04/2014	13:40	1	46	46	Animal related	Fuse	Repair	Repair	V
143383855	M25144	12/04/2014	13:37	12/04/2014	15:13	1	96	96	Overhead equipment	Connector	Replace - Same Size		IV
143384004	M09143	12/04/2014	14:10	12/04/2014	14:26	1	16	16	Animal related	Fuse	Replace - Same Size	No Work Required	VI
143384203	Q75145	12/04/2014	14:50	12/04/2014	15:31	1	41	41	Overhead equipment	Fuse	Replace - Same Size		VI
143384214	J79306	12/04/2014	14:54	12/04/2014	18:21	1	207	207	Overhead equipment	Transformer Fuse			I
143384331	R71286	12/04/2014	15:11	12/04/2014	16:15	1	64	64	Animal related	Transformer Fuse	Replace - Same Size		VI
143384260	M09144	12/04/2014	15:12	12/04/2014	16:28	599	44840	75	Overhead equipment	Crossarm		Repair	VI
143384401	T08501	12/04/2014	15:22	12/04/2014	17:15	1	113	113	Overhead equipment	Overhead Primary	Patrol/Test/Inspect	Repair	VI
143384467	M09175	12/04/2014	15:43	12/04/2014	16:33	1	50	50	Overhead equipment				VI
143384522	Q82907	12/04/2014	16:03	12/04/2014	18:05	1	122	122	Animal related	Fuse	Replace - Same Size	Patrol/Test/Inspect	VI
143384525	P58155	12/04/2014	16:04	12/04/2014	16:59	1	55	55	Animal related	Transformer Fuse	Replace - Same Size		VI
143384765	Q64919	12/04/2014	18:42	12/04/2014	20:48	1	126	126	Animal related	Fuse	Replace - Same Size		VI
143384772	R02120	12/04/2014	18:49	12/04/2014	20:00	1	71	71	Animal related	Transformer Fuse	Replace - Same Size	No Work Required	VI
143384760	A97002	12/04/2014	19:00	12/04/2014	19:04	1	4	4	Animal related	Fuse	Replace - Same Size		I
143385186	R10903	12/04/2014	21:00	12/04/2014	22:18	6	468	78	Overhead equipment	Jumper	Replace - Same Size		VI
143385202	J20931	12/04/2014	21:00	12/04/2014	22:17	385	29645	77	Overhead equipment	Jumper	Replace - Same Size		VI
143385208	B76001	12/04/2014	21:28	12/05/2014	0:29	1	181	181	Underground equipment	Underground Transformer	Patrol/Test/Inspect	Replace - Same Size	I
143390127	Z16547	12/05/2014	0:33	12/05/2014	3:14	522	84042	161	Overhead equipment	Recloser	Cut in Clear	Cut in Clear	IV
143392391	T04512	12/05/2014	4:04	12/05/2014	6:03	20	2380	119	Overhead equipment	Overhead Primary			VI
143392389		12/05/2014	4:10	12/05/2014	6:05	1	115	115	Overhead equipment	Overhead Primary			VI
143392392		12/05/2014	4:13	12/05/2014	5:50	1	97	97	Overhead equipment	Transformer Fuse	Repair	Repair	VI
143392411	P05826	12/05/2014	5:02	12/05/2014	8:54	1	232	232	Underground equipment	Underground Service			V
143392414	P05826	12/05/2014	5:19	12/05/2014	7:31	1	132	132	Other	Overhead Transformer	Repair	Repair	V
143392416	337002	12/05/2014	5:50	12/05/2014	10:45	1	295	295	Overhead equipment	Overhead Transformer	Advise Customer	Replace - Same Size	VI
143392502	D32211	12/05/2014	7:29	12/05/2014	8:05	1	36	36	Animal related	Transformer Fuse	Replace - Same Size		I
143392518	R41131	12/05/2014	7:40	12/05/2014	8:29	1	49	49	Overhead equipment	Transformer Fuse	Replace - Same Size	Replace - Same Size	VI
143392648	M09144	12/05/2014	7:49	12/05/2014	8:28	18	702	39	Animal related	Overhead Primary		Repair	VI
143392595	M09144	12/05/2014	7:50	12/05/2014	9:02	70	5040	72	Animal related	Overhead Primary		Repair	VI
143392552	R68903	12/05/2014	7:57	12/05/2014	9:11	1	74	74	Animal related	Transformer Fuse	Replace - Same Size		I
143392555	M09144	12/05/2014	8:00	12/05/2014	8:28	9	252	28	Animal related				VI
143392582	328120	12/05/2014	8:02	12/05/2014	9:07	552	35880	65	Public	Substation Breaker		Repair	V
143392725	J58380	12/05/2014	9:01	12/05/2014	10:41	6	600	100	Overhead equipment	Transformer Fuse	Replace - Same Size		III
143392763	J75272	12/05/2014	9:16	12/05/2014	10:58	18	1836	102	Overhead equipment	Transformer Fuse		Replace - Same Size	IV
143392767	K67912	12/05/2014	9:19	12/05/2014	10:02	1	43	43	Overhead equipment	Fuse	Replace - Same Size		VI
143392793	D81003	12/05/2014	9:23	12/05/2014	10:18	122	6710	55	Animal related	Other	Repair	Repair	I
143392862	P62138	12/05/2014	9:48	12/05/2014	11:28	1	100	100	Overhead equipment	Fuse	Replace - Same Size		VI
143392930	V84509	12/05/2014	10:02	12/05/2014	11:38	1	96	96	Overhead equipment	Transformer Fuse	Replace - Same Size		II
143392932	P49188	12/05/2014	10:03	12/05/2014	10:58	1	55	55	Animal related	Overhead Transformer	Switch/Reset		I
143392944	P49188	12/05/2014	10:06	12/05/2014	11:02	1	56	56	Animal related	Overhead Transformer	No Work Required		I
143393013	P77233	12/05/2014	10:14	12/05/2014	11:27	33	2409	73	Overhead equipment	Lightning Arrestor			VI
143393197	P77233	12/05/2014	10:14	12/05/2014	13:35	1	201	201	Overhead equipment	Lightning Arrestor		Replace - Same Size	VI
143393089	S61529	12/05/2014	10:27	12/05/2014	11:07	9	360	40	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	VI
143393022	V41527	12/05/2014	10:32	12/05/2014	11:46	12	888	74	Animal related	Transformer Fuse	Replace - Same Size		II
143393072	Q74149	12/05/2014	10:44	12/05/2014	11:09	2	50	25	Animal related	Transformer Fuse	Replace - Same Size		IV
143393179	D31015	12/05/2014	11:24	12/05/2014	11:58	1	34	34	Overhead equipment	Connector	Replace - Same Size		III

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
143393203	N73122	12/05/2014	11:33	12/05/2014	13:00	2	174	87	Overhead equipment	Fuse	Replace - Same Size		IV
143393358	S93553	12/05/2014	12:36	12/05/2014	13:08	1	32	32	Animal related	Fuse	Replace - Same Size	No Work Required	VI
143393384	Z10501	12/05/2014	12:43	12/05/2014	14:00	1	77	77	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
143393455	J89126	12/05/2014	12:57	12/05/2014	13:54	31	1767	57	Overhead equipment	Lightning Arrestor			VI
143393527	J89126	12/05/2014	12:57	12/05/2014	14:10	5	365	73	Overhead equipment	Lightning Arrestor			VI
143393489	M07236	12/05/2014	13:18	12/05/2014	14:03	74	3330	45	Animal related				III
143393853	Y35001	12/05/2014	15:40	12/05/2014	17:00	1	80	80	Tree related-tree contact	Overhead Service	Raise		IV
143393891	Q16867	12/05/2014	15:43	12/05/2014	17:38	1362	156630	115	Overhead equipment	Disconnect Switch	Switch/Reset	Replace - New Size	V
143393974	Q16868	12/05/2014	15:43	12/05/2014	17:38	473	54395	115	Overhead equipment	Disconnect Switch	Switch/Reset	Replace - New Size	V
143393917	Y36541	12/05/2014	15:55	12/05/2014	18:12	11	1507	137	Overhead equipment	Fuse	Replace - Same Size		IV
143394016	K57212	12/05/2014	16:57	12/05/2014	18:15	1	78	78	Overhead equipment	Fuse	Replace - Same Size		VI
143394033	S31561	12/05/2014	17:08	12/05/2014	18:24	1	76	76	Overhead equipment	Overhead Secondary	Patrol/Test/Inspect	Repair	VI
143394036	B65004	12/05/2014	17:09	12/05/2014	18:10	17	1037	61	Overhead equipment	Overhead Primary	Repair		I
143394080	E10002	12/05/2014	17:36	12/05/2014	18:45	1	69	69	Animal related	Transformer Fuse	Replace - Same Size		III
143394083	351001	12/05/2014	17:37	12/05/2014	18:48	1	71	71	Tree related-tree contact	Overhead Service	Repair		VI
143394098	K39156	12/05/2014	18:04	12/05/2014	19:08	1	64	64	Tree related-tree contact	Overhead Service	Repair		III
143394128	R60551	12/05/2014	18:39	12/05/2014	19:12	1	33	33	Overhead equipment		Replace - Same Size	No Work Required	IV
143394133	Y79006	12/05/2014	18:42	12/05/2014	21:25	39	6357	163	Overhead equipment	Overhead Primary	Repair	Replace - Same Size	IV
143394679	J97136	12/05/2014	21:19	12/05/2014	22:02	527	22661	43	Public				VI
143394695	J89112	12/05/2014	21:20	12/05/2014	22:02	359	15078	42	Public				VI
143394738	S21529	12/05/2014	21:54	12/05/2014	23:10	49	3724	76	Overhead equipment	Recloser	Switch/Reset	No Work Required	VI
143394739	P71830	12/05/2014	22:21	12/05/2014	23:00	8	312	39	Tree related-tree contact	Transformer Fuse	Replace - Same Size	No Work Required	V
143394758	P58155	12/05/2014	23:13	12/06/2014	1:05	36	4032	112	Overhead equipment	Fuse	Replace - Same Size		VI
143400046	C36002	12/06/2014	0:05	12/06/2014	5:29	6	1944	324	Underground equipment	Underground Transformer	Replace - Same Size		III
143400045	C36002	12/06/2014	0:05	12/06/2014	2:04	24	2856	119	Underground equipment	Underground Transformer	Replace - Same Size		III
143400028	L24123	12/06/2014	0:45	12/06/2014	1:48	34	2142	63	Overhead equipment	Transformer Fuse	Replace - Same Size		III
143400098	N95455	12/06/2014	2:00	12/06/2014	3:30	326	29340	90	Public	Pole			V
143400546	S01501	12/06/2014	2:59	12/06/2014	4:21	1	82	82	Underground equipment	Switchgear			VI
143400642	S21529	12/06/2014	4:37	12/06/2014	9:40	1	303	303	Overhead equipment	Overhead Transformer	Repair	Replace - New Size	VI
143400652	T06504	12/06/2014	4:40	12/06/2014	9:20	60	16800	280	Overhead equipment	Fuse	Repair	Repair	VI
143400647	J89126	12/06/2014	5:13	12/06/2014	6:38	1	85	85	Animal related	Transformer Fuse			VI
143400669	S01501	12/06/2014	6:24	12/06/2014	8:08	1	104	104	Underground equipment	Underground Primary			VI
143400767	J39391	12/06/2014	8:11	12/06/2014	8:44	16	528	33	Animal related	Fuse			III
143400777	M04365	12/06/2014	8:23	12/06/2014	9:12	1	49	49	Overhead equipment	Transformer Fuse	Replace - Same Size		V
143400798	J79305	12/06/2014	8:43	12/06/2014	10:25	1	102	102	Animal related	Transformer Fuse	Replace - Same Size		I
143400808	R06212	12/06/2014	8:48	12/06/2014	13:00	1	252	252	Public	Pole	Replace - Same Size	Replace - Same Size	II
143400835	J89126	12/06/2014	9:56	12/06/2014	10:37	1	41	41	Animal related	Transformer Fuse	Replace - Same Size		VI
143400841	K27153	12/06/2014	10:07	12/06/2014	11:46	1	99	99	Overhead equipment	Jumper	Repair	No Work Required	VI
143400858	R34921	12/06/2014	10:34	12/06/2014	13:19	1	165	165	Animal related	Fuse	Replace - Same Size	Repair	VI
143400863	M26164	12/06/2014	10:41	12/06/2014	13:15	1	154	154	Underground equipment	Underground Service	Patrol/Test/Inspect	Repair	III
143400879	P20913	12/06/2014	11:12	12/06/2014	15:13	1	241	241	Tree related-tree broken	Overhead Service			VI
143400896	M25144	12/06/2014	11:20	12/06/2014	12:47	1	87	87	Animal related	Transformer Fuse			IV
143400913	J01118	12/06/2014	11:29	12/06/2014	12:40	15	1065	71	Overhead equipment	Fuse	Replace - Same Size		I
143400919	U90572	12/06/2014	12:00	12/06/2014	12:30	1	30	30	Animal related				II
143400926	X69555	12/06/2014	12:09	12/06/2014	13:20	1	71	71	Overhead equipment	Overhead Service	Repair		IV
143400938	R41131	12/06/2014	12:30	12/06/2014	13:48	1	78	78	Animal related	Transformer Fuse	Replace - Same Size	No Work Required	VI
143400957	K32915	12/06/2014	12:45	12/06/2014	13:57	9	648	72	Overhead equipment	Fuse			VI
143401038	D67001	12/06/2014	12:45	12/06/2014	16:13	6	1248	208	Tree related-tree contact	Overhead Primary		Repair	IV
143400958	U09557	12/06/2014	12:49	12/06/2014	16:00	2	382	191	Animal related	Transformer Fuse	Replace - Same Size		II
143400961	R08910	12/06/2014	13:01	12/06/2014	14:02	1	61	61	Animal related	Fuse	Replace - Same Size		VI
143400968	A17026	12/06/2014	13:10	12/06/2014	14:45	1	95	95	Overhead equipment	Overhead Secondary	Repair		I
143400987	T09559	12/06/2014	13:49	12/06/2014	15:22	1	93	93	Overhead equipment	Overhead Service	Patrol/Test/Inspect	Repair	VI
143401010	K89142	12/06/2014	14:19	12/06/2014	15:52	9	837	93	Animal related	Fuse	Replace - Same Size		III
143401020	K91115	12/06/2014	14:29	12/06/2014	15:15	1	46	46	Animal related	Transformer Fuse	Repair		III
143401064	R84148	12/06/2014	16:10	12/06/2014	17:50	1	100	100	Overhead equipment	Fuse	Replace - Same Size		I
143401152	M26161	12/06/2014	20:15	12/06/2014	20:53	1	38	38	Overhead equipment	Transformer Fuse	Repair		III

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
143401173	C30001	12/06/2014	21:51	12/07/2014	4:23	1	392	392	Underground equipment	Underground Primary		Repair	III
143410042	M09143	12/07/2014	7:21	12/07/2014	8:56	11	1045	95	Animal related	Fuse	Replace - Same Size	No Work Required	VI
143410044	T23527	12/07/2014	7:33	12/07/2014	8:30	1	57	57	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	VI
143410046	R48166	12/07/2014	7:39	12/07/2014	8:30	1	51	51	Overhead equipment	Transformer Fuse			IV
143410049	P77235	12/07/2014	7:53	12/07/2014	9:31	1	98	98	Animal related	Transformer Fuse	Replace - Same Size		VI
143410056	X34531	12/07/2014	7:58	12/07/2014	9:31	9	837	93	Animal related	Transformer Fuse	Replace - Same Size		IV
143410075	Y31589	12/07/2014	9:02	12/07/2014	9:52	1	50	50	Animal related	Transformer Fuse	Replace - Same Size		IV
143410120	X04720	12/07/2014	9:23	12/07/2014	11:44	25	3525	141	Animal related	Substation Misc.	Switch/Reset		IV
143410096	P73157	12/07/2014	9:50	12/07/2014	11:45	14	1610	115	Animal related	Fuse	Replace - Same Size		VI
143410107	K25166	12/07/2014	10:14	12/07/2014	11:48	1	94	94	Tree related-tree broken	Transformer Fuse	Replace - Same Size	No Work Required	VI
143410111	M47802	12/07/2014	10:23	12/07/2014	11:05	1	42	42	Public	Fuse	Repair	Repair	V
143410117	R39934	12/07/2014	10:41	12/07/2014	11:53	1	72	72	Animal related	Fuse	Replace - Same Size		VI
143410133	K46389	12/07/2014	11:22	12/07/2014	12:19	1	57	57	Underground equipment	Underground Secondary		Advise Customer	V
143410141	N67309	12/07/2014	11:32	12/07/2014	13:00	1	88	88	Animal related	Fuse	Replace - Same Size		I
143410163	P47169	12/07/2014	11:59	12/07/2014	13:14	4	300	75	Animal related	Overhead Transformer	Switch/Reset		I
143410178	C66001	12/07/2014	12:11	12/07/2014	13:00	3	147	49	Animal related	Fuse	Replace - Same Size	No Work Required	III
143410172	D69001	12/07/2014	12:12	12/07/2014	15:17	1	185	185	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
143410358	D66004	12/07/2014	13:13	12/07/2014	13:50	11	407	37	Animal related	Transformer Fuse			IV
143410385	U73599	12/07/2014	13:48	12/07/2014	16:17	2	298	149	Animal related	Fuse	Replace - Same Size		II
143410375	B93003	12/07/2014	13:51	12/07/2014	15:45	1	114	114	Animal related	Transformer Fuse	Replace - Same Size		I
143410403	P72319	12/07/2014	14:50	12/07/2014	15:40	1	50	50	Overhead equipment	Overhead Service	Repair		V
143410407	M26164	12/07/2014	14:55	12/07/2014	15:25	1	30	30	Animal related	Transformer Fuse	Replace - Same Size		III
143410422	P73158	12/07/2014	15:17	12/07/2014	17:20	1	123	123	Underground equipment	Meter	Disconnect		VI
143410429	L12126	12/07/2014	15:25	12/07/2014	15:52	21	567	27	Animal related	Underground Primary	Replace - Same Size	Replace - Same Size	III
143410433	K26136	12/07/2014	15:43	12/07/2014	16:54	1	71	71	Animal related	Transformer Fuse	Replace - Same Size	No Work Required	VI
143410513	Q01281	12/07/2014	20:03	12/07/2014	21:43	7	700	100	Overhead equipment				III
143410546	J99141	12/07/2014	20:21	12/08/2014	1:22	5	1505	301	Tree related-tree broken	Overhead Primary			VI
143420134	A80002	12/08/2014	2:13	12/08/2014	3:42	1	89	89	Overhead equipment	Connector	Tie/Tighten		I
143422163	D70006	12/08/2014	4:04	12/08/2014	6:47	73	11899	163	Underground equipment	Underground Primary	Repair	Repair	I
143422183	J01118	12/08/2014	4:27	12/08/2014	7:00	37	5661	153	Unknown	Recloser	Switch/Reset		I
143422192	N70332	12/08/2014	4:54	12/08/2014	9:28	41	11234	274	Overhead equipment	Capacitor	Replace - Same Size		I
143422176	D39001	12/08/2014	5:42	12/08/2014	13:13	1	451	451	Overhead equipment	Pole	Replace - New Size	Repair	I
143422186	K80382	12/08/2014	5:58	12/08/2014	7:10	26	1872	72	Underground equipment	Underground Primary	Switch/Reset	Repair	IV
143422194	N70332	12/08/2014	6:31	12/08/2014	8:53	3	426	142	Overhead equipment	Recloser	Replace - Same Size		I
143422197	J34377	12/08/2014	6:40	12/08/2014	8:08	13	1144	88	Animal related	Transformer Fuse	Replace - Same Size		V
143422387	K67912	12/08/2014	7:42	12/08/2014	8:35	9	477	53	Animal related	Fuse	Replace - Same Size		VI
143422359	K32935	12/08/2014	8:11	12/08/2014	8:25	1	14	14	Animal related	Overhead Transformer			VI
143422534	B00003	12/08/2014	8:34	12/08/2014	14:43	36	13284	369	Underground equipment	Underground Primary	Replace - Same Size	Replace - Same Size	I
143422446	R42914	12/08/2014	8:43	12/08/2014	10:08	1	85	85	Overhead equipment	Fuse	Replace - Same Size		VI
143422464	N70332	12/08/2014	8:47	12/08/2014	8:56	1	9	9	Overhead equipment				I
143422457	K32915	12/08/2014	8:47	12/08/2014	9:15	1	28	28	Animal related	Fuse			VI
143422477	B68003	12/08/2014	8:50	12/08/2014	9:20	1	30	30	Overhead equipment	Transformer Fuse	Replace - Same Size		III
143422896	R04407	12/08/2014	10:19	12/08/2014	10:57	1	38	38	Overhead equipment	Connector	Repair		V
143422905	P25150	12/08/2014	10:23	12/08/2014	12:34	2	262	131	Overhead equipment	Crossarm		Repair	III
143423072	U93563	12/08/2014	11:02	12/08/2014	11:30	1	28	28	Animal related	Transformer Fuse	Replace - Same Size		II
143423155	X88510	12/08/2014	11:27	12/08/2014	12:55	1	88	88	Overhead equipment	Overhead Service	Repair		IV
143423165	V37583	12/08/2014	11:30	12/08/2014	12:02	4	128	32	Animal related	Transformer Fuse	Replace - Same Size		II
143423495	P77233	12/08/2014	13:04	12/08/2014	15:30	2	292	146	Animal related	Transformer Fuse	Replace - Same Size		VI
143423807	D81002	12/08/2014	14:17	12/08/2014	15:09	1	52	52	Unknown	Fuse	Replace - Same Size		I
143423872	S53541	12/08/2014	14:30	12/08/2014	17:10	1	160	160	Overhead equipment	Disconnect Switch	Replace - Same Size	Patrol/Test/Inspect	VI
143423985	M26161	12/08/2014	14:57	12/08/2014	15:25	1	28	28	Animal related	Fuse	Replace - Same Size		III
143424101	D28124	12/08/2014	15:24	12/08/2014	16:34	1	70	70	Overhead equipment	Overhead Service	Patrol/Test/Inspect	Reconnect	I
143424108	J99141	12/08/2014	15:27	12/08/2014	16:36	1	69	69	Overhead equipment	Overhead Service	Repair		VI
143424109	D66001	12/08/2014	15:28	12/08/2014	18:00	1	152	152	Tree related-tree contact	Overhead Secondary	Repair	Repair	IV
143424320	N44217	12/08/2014	17:00	12/08/2014	17:57	1	57	57	Overhead equipment	Connector			III
143424379	X24536	12/08/2014	17:55	12/08/2014	19:05	1	70	70	Animal related	Transformer Fuse	Repair	Patrol/Test/Inspect	IV

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
143424463	J84123	12/08/2014	19:07	12/08/2014	19:55	1	48	48	Overhead equipment	Overhead Service	Repair		VI
143424466	Q16867	12/08/2014	19:10	12/08/2014	21:00	1	110	110	Animal related	Transformer Fuse	Replace - Same Size		V
143424470	T59902	12/08/2014	19:15	12/08/2014	19:57	1	42	42	Overhead equipment	Fuse	Replace - Same Size	Patrol/Test/Inspect	VI
143432287	S61530	12/09/2014	6:59	12/09/2014	7:45	172	7912	46	Overhead equipment	Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
143432412	J01119	12/09/2014	7:38	12/09/2014	8:38	71	4260	60	Underground equipment	Underground Primary	Replace - Same Size	No Work Required	I
143432416	J86118	12/09/2014	8:01	12/09/2014	12:30	1	269	269	Underground equipment	Underground Service	Patrol/Test/Inspect	Replace - Same Size	VI
143432513	J71128	12/09/2014	8:31	12/09/2014	10:30	1	119	119	Overhead equipment	Connector	Replace - Same Size	Replace - Same Size	I
143432516	U13551	12/09/2014	8:33	12/09/2014	10:40	1	127	127	Underground equipment	Overhead Service	Tie/Tighten	Patrol/Test/Inspect	II
143432533	X02547	12/09/2014	8:37	12/09/2014	9:22	1	45	45	Overhead equipment	Fuse			IV
143432553	J01119	12/09/2014	8:38	12/09/2014	9:20	1	42	42	Underground equipment	Underground Primary			I
143432629	K32916	12/09/2014	9:01	12/09/2014	12:28	1	207	207	Tree related-tree broken	Tree			VI
143432783	342003	12/09/2014	9:39	12/09/2014	10:25	65	2990	46	Tree related-tree broken	Fuse			VI
143432812	Q70161	12/09/2014	9:48	12/09/2014	10:18	1	30	30	Animal related	Transformer Fuse	Replace - Same Size		I
143432896	L35282	12/09/2014	10:06	12/09/2014	10:51	1	45	45	Overhead equipment	Overhead Service	Repair		III
143432913	L35137	12/09/2014	10:10	12/09/2014	13:27	1	197	197	Underground equipment	Underground Service		Repair	III
143432924	U32594	12/09/2014	10:11	12/09/2014	11:17	1	66	66	Overhead equipment	Connector	Repair		II
143432962	K08909	12/09/2014	10:20	12/09/2014	11:31	1	71	71	Animal related	Transformer Fuse			VI
143432978	P47123	12/09/2014	10:25	12/09/2014	11:31	4	264	66	Animal related	Overhead Transformer	Switch/Reset		I
143433274	U83746	12/09/2014	10:41	12/09/2014	12:15	936	87984	94	Animal related	Substation Transformer	Switch/Reset		II
143433289	V41527	12/09/2014	11:12	12/09/2014	11:33	12	252	21	Animal related	Transformer Fuse	Replace - Same Size		II
143433324		12/09/2014	11:18	12/09/2014	12:53	2	190	95	Animal related				II
143433352	U73599	12/09/2014	11:27	12/09/2014	12:40	2	146	73	Animal related	Transformer Fuse	Replace - Same Size		II
143433517	348116	12/09/2014	12:14	12/09/2014	13:14	1	60	60	Overhead equipment	Overhead Service	Repair		V
143433686	P47120	12/09/2014	13:04	12/09/2014	14:18	1	74	74	Overhead equipment	Overhead Service	No Work Required		I
143433689	J80807	12/09/2014	13:07	12/09/2014	14:32	1	85	85	Animal related	Overhead Transformer	Repair	Repair	V
143433753	Y55594	12/09/2014	13:27	12/09/2014	14:50	1	83	83	Animal related	Transformer Fuse	Replace - Same Size		IV
143434134	J80806	12/09/2014	15:12	12/09/2014	20:24	1	312	312	Public	Overhead Transformer	Replace - Same Size	Replace - Same Size	V
143434241	J61110	12/09/2014	15:49	12/09/2014	21:11	145	46690	322	Public	Pole			III
143434262	K22173	12/09/2014	16:01	12/09/2014	22:59	1	418	418	Underground equipment	Underground Secondary	Patrol/Test/Inspect	Repair	VI
143434303	K57212	12/09/2014	16:25	12/09/2014	16:58	1	33	33	Animal related	Transformer Fuse	Replace - Same Size		VI
143434338	S93553	12/09/2014	16:40	12/09/2014	17:40	1	60	60	Overhead equipment	Transformer Fuse	Replace - Same Size		VI
143434356	S93553	12/09/2014	16:51	12/09/2014	17:41	1	50	50	Overhead equipment	Transformer Fuse	Replace - Same Size		VI
143434496	M09143	12/09/2014	18:19	12/09/2014	18:47	1	28	28	Overhead equipment	Connector	Replace - Same Size	No Work Required	VI
143434503	B84002	12/09/2014	18:29	12/09/2014	20:15	1	106	106	Overhead equipment	Connector	Replace - New Size		I
143434887	L16213	12/09/2014	20:06	12/09/2014	21:05	1	59	59	Public	Overhead Secondary	Repair		III
143442326	Q24312	12/10/2014	6:47	12/10/2014	7:42	11	605	55	Public				VI
143442327	P49180	12/10/2014	6:55	12/10/2014	8:06	1	71	71	Overhead equipment	Overhead Service	No Work Required		I
143442373	Y07577	12/10/2014	7:12	12/10/2014	16:00	1	528	528	Underground equipment	Underground Primary	Repair	Replace - Same Size	IV
143442420	S16596	12/10/2014	7:31	12/10/2014	8:20	1	49	49	Animal related			Replace - Same Size	VI
143442427	Q80353	12/10/2014	7:36	12/10/2014	8:48	1	72	72	Animal related	Transformer Fuse	Replace - Same Size		V
143442465	P73157	12/10/2014	7:52	12/10/2014	8:24	1	32	32	Overhead equipment	Transformer Fuse	Replace - Same Size		VI
143442520	Q91175	12/10/2014	8:17	12/10/2014	11:58	1	221	221	Overhead equipment	Overhead Transformer	Replace - Same Size	Replace - Same Size	I
143442524	P20930	12/10/2014	8:19	12/10/2014	9:29	1	70	70	Animal related	Fuse	Replace - Same Size		VI
143442550	V03562	12/10/2014	8:24	12/10/2014	9:10	1	46	46	Animal related	Transformer Fuse	Replace - Same Size	No Work Required	II
143442593	P73157	12/10/2014	8:30	12/10/2014	9:20	2	100	50	Overhead equipment	Transformer Fuse	Replace - Same Size		VI
143442580	R10943	12/10/2014	8:32	12/10/2014	8:51	1	19	19	Animal related	Fuse	Replace - Same Size		VI
143442612	D88001	12/10/2014	8:38	12/10/2014	9:11	68	2244	33	Overhead equipment	Fuse	Replace - Same Size		I
143442808	U33586	12/10/2014	8:45	12/10/2014	10:07	22	1804	82	Overhead equipment	Fuse	Replace - Same Size		II
143442710	N05172	12/10/2014	9:04	12/10/2014	11:33	1	149	149	Underground equipment	Overhead Service			I
143443088	K57211	12/10/2014	9:13	12/10/2014	11:25	83	10956	132	Public	Underground Primary	Patrol/Test/Inspect	Repair	VI
143442788	K57211	12/10/2014	9:14	12/10/2014	10:25	228	16188	71	Public	Underground Primary	Patrol/Test/Inspect	Repair	VI
143442843	J99128	12/10/2014	9:30	12/10/2014	9:47	8	136	17	Animal related	Fuse			VI
143443126	R48167	12/10/2014	10:40	12/10/2014	11:13	3	99	33	Overhead equipment	Overhead Service			IV
143443250	V75205	12/10/2014	10:55	12/10/2014	12:43	1139	123012	108	Jurisdictional	High Line Switch			II
143443312	X88507	12/10/2014	11:15	12/10/2014	12:20	1	65	65	Animal related	Transformer Fuse	Replace - Same Size		IV
143443536	P77233	12/10/2014	12:25	12/10/2014	13:09	1	44	44	Animal related	Fuse	Replace - Same Size		VI

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
143443558	V23592	12/10/2014	12:33	12/10/2014	12:52	1	19	19	Animal related	Transformer Fuse	Repair	Replace - Same Size	II
143443584	L93133	12/10/2014	12:40	12/10/2014	13:23	1	43	43	Animal related	Transformer Fuse			VI
143443689	P82290	12/10/2014	13:00	12/10/2014	15:21	85	11985	141	Overhead equipment	Disconnect Switch	Patrol/Test/Inspect	Replace - Same Size	VI
143443741	Y45504	12/10/2014	13:24	12/10/2014	13:37	1	13	13	Animal related	Fuse	Repair	Replace - Same Size	IV
143443796	M47802	12/10/2014	13:37	12/10/2014	14:15	1	38	38	Overhead equipment	Fuse	Repair	Repair	V
143443864	B44002	12/10/2014	13:56	12/10/2014	14:20	1	24	24	Animal related	Transformer Fuse	Replace - Same Size		I
143452547	C70001	12/10/2014	14:00	12/10/2014	15:10	227	15890	70	Underground equipment	Underground Primary			III
143443884	R05186	12/10/2014	14:02	12/10/2014	14:42	1	40	40	Underground equipment	Underground Secondary	Repair	Tie/Tighten	I
143444216	P69175	12/10/2014	15:28	12/10/2014	16:15	1	47	47	Underground equipment	Underground Service		Repair	III
143444325	L17104	12/10/2014	15:32	12/10/2014	16:52	48	3840	80	Overhead equipment	Pole	Replace - Same Size		III
143444237	N44216	12/10/2014	15:36	12/10/2014	16:43	1	67	67	Overhead equipment	Overhead Transformer			III
143444293	P49183	12/10/2014	15:51	12/10/2014	16:48	13	741	57	Overhead equipment	Fuse	Replace - Same Size		I
143444347	R60551	12/10/2014	16:08	12/10/2014	16:50	1	42	42	Animal related	Transformer Fuse	Replace - Same Size	No Work Required	IV
143444403	J18268	12/10/2014	16:37	12/10/2014	17:52	7	525	75	Animal related	Transformer Fuse	Replace - Same Size		VI
143444415	V18553	12/10/2014	16:44	12/10/2014	17:47	5	315	63	Animal related	Transformer Fuse	Replace - Same Size		II
143444436	J18268	12/10/2014	16:51	12/10/2014	18:00	10	690	69	Animal related	Transformer Fuse	Replace - Same Size		VI
143444459	C70001	12/10/2014	17:08	12/10/2014	22:22	1	314	314	Underground equipment	Underground Primary	Repair		III
143444482	L17104	12/10/2014	17:31	12/10/2014	18:40	22	1518	69	Public	Underground Primary	Switch/Reset		III
143444499	Z43549	12/10/2014	17:38	12/10/2014	19:20	1	102	102	Overhead equipment	Transformer Fuse	Repair	Replace - Same Size	IV
143444532	L12128	12/10/2014	17:58	12/10/2014	18:42	1	44	44	Public	Underground Primary	Switch/Reset		III
143444602	P47124	12/10/2014	18:31	12/10/2014	20:08	1	97	97	Overhead equipment	Fuse	Replace - Same Size		I
143444957	M48815	12/10/2014	19:46	12/10/2014	21:35	6	654	109	Overhead equipment	Transformer Fuse	Repair	Repair	V
143444252	Y20522	12/10/2014	20:28	12/10/2014	21:20	1	52	52	Public	Pole			IV
143450182	K52421	12/11/2014	2:56	12/11/2014	6:35	4	876	219	Public	Disconnect Switch			V
143452167	B65001	12/11/2014	5:20	12/11/2014	7:30	58	7540	130	Overhead equipment	Crossarm		Repair	I
143452288	R49261	12/11/2014	7:37	12/11/2014	9:19	7	714	102	Animal related	Transformer Fuse	Replace - Same Size		VI
143452327	P62138	12/11/2014	7:56	12/11/2014	8:27	1	31	31	Animal related	Fuse	Repair	Repair	VI
143452401	L93133	12/11/2014	8:26	12/11/2014	9:00	1	34	34	Animal related	Transformer Fuse			VI
143452432	M47802	12/11/2014	8:36	12/11/2014	8:48	94	1128	12	Animal related	Recloser			V
143452484	J13108	12/11/2014	8:53	12/11/2014	10:58	1	125	125	Animal related	Transformer Fuse	Replace - Same Size		I
143452491	J13108	12/11/2014	8:55	12/11/2014	11:02	1	127	127	Animal related	Other			I
143452530	Z08509	12/11/2014	9:05	12/11/2014	9:37	1	32	32	Animal related	Fuse	Repair	Replace - Same Size	IV
143452556	X83533	12/11/2014	9:15	12/11/2014	10:51	1	96	96	Animal related	Animal Guard		Install	IV
143452661	K46388	12/11/2014	9:29	12/11/2014	10:16	7	329	47	Overhead equipment				V
143452654	N54107	12/11/2014	9:37	12/11/2014	10:13	7	252	36	Animal related	Transformer Fuse	Replace - Same Size	No Work Required	II
143452691	P54827	12/11/2014	9:42	12/11/2014	10:14	38	1216	32	Animal related	Fuse	Replace - Same Size		V
143452673	P54827	12/11/2014	9:44	12/11/2014	10:17	1	33	33	Animal related	Fuse	Replace - Same Size		V
143452677	P54827	12/11/2014	9:45	12/11/2014	10:40	1	55	55	Animal related	Transformer Fuse	Replace - Same Size		V
143452685	P54827	12/11/2014	9:48	12/11/2014	10:29	1	41	41	Animal related	Fuse	Replace - Same Size		V
143452688	L24123	12/11/2014	9:49	12/11/2014	10:45	1	56	56	Animal related	Fuse	Replace - Same Size		III
143452719	C65001	12/11/2014	9:56	12/11/2014	10:55	31	1829	59	Animal related	Fuse	Repair	Replace - Same Size	III
143452779	S47576	12/11/2014	10:20	12/11/2014	10:55	1	35	35	Overhead equipment	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
143453681	X19561	12/11/2014	10:31	12/11/2014	14:53	13	3406	262	Underground equipment	Underground Primary	Repair	Repair	IV
143452817	P20930	12/11/2014	10:32	12/11/2014	11:26	1	54	54	Animal related	Fuse	Replace - Same Size		VI
143452856	R59417	12/11/2014	10:47	12/11/2014	11:13	1	26	26	Animal related	Transformer Fuse	Replace - Same Size	No Work Required	IV
143452962	V92555	12/11/2014	10:49	12/11/2014	11:35	27	1242	46	Overhead equipment	Fuse	Replace - Same Size	Patrol/Test/Inspect	II
143453033	S78551	12/11/2014	11:38	12/11/2014	13:48	1	130	130	Animal related	Transformer Fuse			VI
143453116	B46001	12/11/2014	12:03	12/11/2014	14:12	1	129	129	Overhead equipment	Connector	Replace - Same Size		I
143453129	L23146	12/11/2014	12:09	12/11/2014	13:00	1	51	51	Unknown	Transformer Fuse	Replace - Same Size		III
143453140	J06168	12/11/2014	12:11	12/11/2014	13:17	1	66	66	Animal related	Transformer Fuse	Replace - Same Size		I
143453167	P69175	12/11/2014	12:19	12/11/2014	13:38	7	553	79	Animal related	Transformer Fuse	Replace - Same Size		III
143453183	U10547	12/11/2014	12:25	12/11/2014	13:31	4	264	66	Animal related	Transformer Fuse	Replace - Same Size		II
143453209	Y45504	12/11/2014	12:35	12/11/2014	13:12	1	37	37	Animal related	Fuse	Repair	Replace - Same Size	IV
143453264	H11339	12/11/2014	12:50	12/11/2014	13:47	1	57	57	Animal related	Transformer Fuse	Replace - Same Size		V
143453305	P49183	12/11/2014	13:02	12/11/2014	14:15	1	73	73	Overhead equipment	Overhead Secondary	Repair		I
143453373	N05172	12/11/2014	13:19	12/11/2014	14:13	1	54	54	Animal related	Transformer Fuse	Replace - Same Size		I

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
143453448	M54292	12/11/2014	13:43	12/11/2014	14:30	1	47	47	Animal related	Transformer Fuse	Replace - Same Size	Repair	V
143453668	L82187	12/11/2014	14:44	12/11/2014	16:42	1	118	118	Animal related	Transformer Fuse	Replace - Same Size		IV
143453923	V61563	12/11/2014	16:05	12/11/2014	17:30	1	85	85	Animal related	Transformer Fuse	Replace - Same Size		II
143454013	Z43549	12/11/2014	16:54	12/11/2014	18:53	1	119	119	Animal related	Transformer Fuse	Repair	Replace - Same Size	IV
143454030	V78002	12/11/2014	17:00	12/11/2014	19:30	1	150	150	Underground equipment	Underground Secondary			II
143454137	Q64919	12/11/2014	18:15	12/11/2014	19:52	1	97	97	Tree related-tree contact	Overhead Service	Repair		VI
143454160	Y45003	12/11/2014	18:41	12/11/2014	20:00	1	79	79	Overhead equipment	Overhead Service	Repair	Replace - Same Size	IV
143454163	C52001	12/11/2014	18:46	12/11/2014	21:06	1	140	140	Underground equipment	Underground Service		Repair	III
143454164	T14575	12/11/2014	18:48	12/11/2014	20:35	1	107	107	Overhead equipment	Disconnect Switch	Patrol/Test/Inspect	Replace - Same Size	VI
143454166	K67924	12/11/2014	18:51	12/11/2014	20:30	1	99	99	Overhead equipment	Fuse	Replace - Same Size	Patrol/Test/Inspect	VI
143454600	D66004	12/11/2014	19:39	12/11/2014	22:45	421	78306	186	Overhead equipment	Overhead Primary	Repair		IV
143461200	Y37592	12/12/2014	2:02	12/12/2014	6:00	1	238	238	Underground equipment	Underground Primary	Replace - Same Size	Repair	IV
143462305	N67315	12/12/2014	5:29	12/12/2014	10:28	39	11661	299	Public	Pole	Replace - Urgent		I
143462604	H06135	12/12/2014	7:25	12/12/2014	12:04	3	837	279	Overhead equipment	Pole	Replace - Same Size		IV
143462442	H06135	12/12/2014	7:29	12/12/2014	8:25	14	784	56	Public	Pole	Replace - Same Size	Replace - Same Size	IV
143462513	J87120	12/12/2014	7:50	12/12/2014	8:40	37	1850	50	Animal related	Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
143462526	H11340	12/12/2014	8:00	12/12/2014	9:12	18	1296	72	Animal related	Fuse	Repair		V
143462647		12/12/2014	8:51	12/12/2014	13:06	1	255	255	Public	Underground Transformer		Replace - Same Size	VI
143462968	Q21294	12/12/2014	10:15	12/12/2014	11:15	1	60	60	Animal related	Fuse			VI
143463040	S88553	12/12/2014	10:35	12/12/2014	12:48	1	133	133	Overhead equipment	Other	Patrol/Test/Inspect	No Work Required	VI
143463062	M45212	12/12/2014	10:44	12/12/2014	11:33	1	49	49	Public	Overhead Service	Repair		IV
143463120	Y35515	12/12/2014	11:03	12/12/2014	11:45	1	42	42	Animal related	Fuse	Replace - Same Size		IV
143463160	L79157	12/12/2014	11:17	12/12/2014	12:50	1	93	93	Animal related	Transformer Fuse		Replace - Same Size	IV
143463221	D41003	12/12/2014	11:36	12/12/2014	12:26	14	700	50	Animal related	Fuse	Replace - Same Size		I
143463271	P42229	12/12/2014	11:47	12/12/2014	12:40	12	636	53	Animal related	Fuse	Replace - Same Size		VI
143463262	Q95248	12/12/2014	11:52	12/12/2014	12:30	1	38	38	Animal related	Fuse	Switch/Reset		VI
143463287	J88165	12/12/2014	12:02	12/12/2014	13:20	1	78	78	Public				VI
143463296	Y06544	12/12/2014	12:07	12/12/2014	14:15	1	128	128	Overhead equipment	Lightning Arrestor	Replace - Same Size		IV
143463337	Q18244	12/12/2014	12:26	12/12/2014	13:25	1	59	59	Animal related	Fuse	Switch/Reset		VI
143463414	D69008	12/12/2014	12:54	12/12/2014	13:27	1	33	33	Animal related	Fuse	Replace - Same Size		I
143463854	S93553	12/12/2014	15:03	12/12/2014	15:41	1	38	38	Overhead equipment	Transformer Fuse	Replace - Same Size		VI
143463946	V80506	12/12/2014	15:44	12/12/2014	16:55	12	852	71	Animal related	Transformer Fuse	Replace - Same Size	Repair	II
143463976	L70125	12/12/2014	15:52	12/12/2014	18:19	1	147	147	Overhead equipment	Meter	Reconnect		IV
143464007	X19561	12/12/2014	16:03	12/12/2014	20:31	1	268	268	Underground equipment	Underground Service			IV
143464250	P82291	12/12/2014	17:39	12/12/2014	18:44	1	65	65	Animal related	Fuse	Replace - Same Size		VI
143464269	M41111	12/12/2014	17:57	12/12/2014	21:42	8	1800	225	Overhead equipment	Fuse	Repair	Replace - Same Size	I
143464283	J08207	12/12/2014	18:21	12/12/2014	19:18	1	57	57	Animal related	Transformer Fuse	Replace - Same Size	Replace - Same Size	I
143464300	S25552	12/12/2014	18:32	12/12/2014	20:10	1	98	98	Animal related	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
143470038	L71171	12/12/2014	22:46	12/13/2014	4:03	268	84956	317	Substation equipment	Substation Recloser	Replace - Same Size		IV
143470182	K08909	12/13/2014	7:41	12/13/2014	9:15	35	3290	94	Overhead equipment	Fuse			VI
143470184	Y34596	12/13/2014	7:46	12/13/2014	9:35	1	109	109	Animal related	Transformer Fuse	Repair	Patrol/Test/Inspect	IV
143470188	J83140	12/13/2014	7:57	12/13/2014	8:24	4	108	27	Animal related	Transformer Fuse	Replace - Same Size		VI
143470218	K11372	12/13/2014	8:26	12/13/2014	9:46	27	2160	80	Animal related	Fuse	Replace - Same Size	Replace - Same Size	V
143470238	N60181	12/13/2014	8:54	12/13/2014	10:51	1	117	117	Overhead equipment	Jumper	Tie/Tighten		I
143470251	L79180	12/13/2014	9:12	12/13/2014	9:53	4	164	41	Overhead equipment	Transformer Fuse	Replace - Same Size	No Work Required	IV
143470284	D35001	12/13/2014	9:46	12/13/2014	12:41	1	175	175	Overhead equipment	Connector	Replace - Same Size	Replace - Same Size	I
143470407	H10843	12/13/2014	10:07	12/13/2014	13:25	78	15444	198	Overhead equipment	Overhead Primary			V
143470480	R93701	12/13/2014	11:15	12/13/2014	11:37	1	22	22	Animal related	Substation Breaker	Switch/Reset		V
143470384	Q80352	12/13/2014	11:33	12/13/2014	12:02	1	29	29	Animal related	Transformer Fuse	Replace - Same Size		V
143470389	R20502	12/13/2014	11:40	12/13/2014	15:21	1	221	221	Overhead equipment	Overhead Secondary		Repair	IV
143470392	L71171	12/13/2014	11:42	12/13/2014	12:29	1	47	47	Overhead equipment	Transformer Fuse	Replace - Same Size	No Work Required	IV
143470414	P77235	12/13/2014	12:00	12/13/2014	14:22	51	7242	142	Animal related	Disconnect Switch	Patrol/Test/Inspect	Replace - Same Size	VI
143470432	C10001	12/13/2014	12:39	12/13/2014	13:39	1	60	60	Animal related	Other	Replace - Same Size	Patrol/Test/Inspect	III
143470435	G10002	12/13/2014	12:41	12/13/2014	13:40	58	3422	59	Overhead equipment	Fuse	Replace - Same Size		I
143470457	T06504	12/13/2014	13:11	12/13/2014	13:50	1	39	39	Animal related	Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
143470479	V69546	12/13/2014	13:34	12/13/2014	14:53	1	79	79	Animal related	Transformer Fuse	Replace - Same Size		II

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
143470485	G10002	12/13/2014	13:44	12/13/2014	17:33	1	229	229	Underground equipment	Underground Primary	Patrol/Test/Inspect	Reconnect	I
143470488	B25002	12/13/2014	13:46	12/13/2014	15:18	4	368	92	Animal related	Transformer Fuse	Replace - Same Size		I
143470498	P83705	12/13/2014	13:53	12/13/2014	15:11	1	78	78	Animal related	Transformer Fuse	Replace - Same Size		I
143470514	V79512	12/13/2014	14:39	12/13/2014	16:14	1	95	95	Overhead equipment	Overhead Service	Repair	Repair	II
143470518	Q32170	12/13/2014	14:40	12/13/2014	18:10	8	1680	210	Tree related-tree broken	Overhead Primary			I
143470587	N70330	12/13/2014	14:43	12/13/2014	16:18	273	25935	95	Public	Overhead Primary	Replace - Same Size		I
143470630	N70330	12/13/2014	14:43	12/13/2014	17:40	964	170628	177	Public	Overhead Primary	Replace - Same Size		I
143470634	N70330	12/13/2014	14:43	12/13/2014	16:18	295	28025	95	Public	Overhead Primary	Replace - Same Size		I
143470570	T08501	12/13/2014	14:49	12/13/2014	15:51	2	124	62	Animal related	Transformer Fuse	Repair	Repair	VI
143470602	B19001	12/13/2014	15:24	12/13/2014	19:22	1	238	238	Underground equipment	Underground Service	Replace - Same Size	Replace - Same Size	I
143470608	R34920	12/13/2014	15:32	12/13/2014	17:40	1	128	128	Underground equipment	Underground Service	Repair	Repair	VI
143470638	X92508	12/13/2014	16:24	12/13/2014	17:33	1	69	69	Overhead equipment	Overhead Service	Repair	Replace - Same Size	IV
143470648	D89002	12/13/2014	16:36	12/13/2014	17:45	1	69	69	Animal related	Transformer Fuse	Replace - Same Size		I
143470649	N48101	12/13/2014	16:43	12/13/2014	17:36	1	53	53	Animal related	Fuse	Replace - Same Size	Replace - Same Size	II
143470671	L79157	12/13/2014	17:35	12/13/2014	23:11	52	17472	336	Underground equipment	Underground Primary	Repair	Repair	IV
143470728	Q23258	12/13/2014	19:23	12/13/2014	23:23	1	240	240	Underground equipment	Underground Service			VI
143470756	B21004	12/13/2014	20:27	12/13/2014	22:20	98	11074	113	Underground equipment	Underground Primary	Repair	Repair	I
143470813	B21004	12/13/2014	20:35	12/13/2014	22:55	2	280	140	Underground equipment	Underground Primary	Repair		I
143470814	B21004	12/13/2014	20:35	12/13/2014	22:55	1	140	140	Underground equipment	Underground Primary	Repair		I
143470815	B21004	12/13/2014	20:35	12/14/2014	3:41	1	426	426	Underground equipment	Underground Primary	Repair	Repair	I
143470765	R04413	12/13/2014	20:36	12/14/2014	1:30	18	5292	294	Underground equipment	Underground Primary			V
143480044	R04413	12/13/2014	20:36	12/14/2014	10:26	1	830	830	Underground equipment	Underground Primary			V
143470768	L12126	12/13/2014	20:38	12/14/2014	1:17	23	6417	279	Underground equipment	Underground Primary			III
143470809	L12126	12/13/2014	20:38	12/13/2014	22:17	4	396	99	Underground equipment	Underground Primary			III
143470771	U93507	12/13/2014	20:46	12/13/2014	22:38	1	112	112	Tree related-tree broken	Overhead Service			II
143470796	S93553	12/13/2014	22:03	12/13/2014	22:36	1	33	33	Overhead equipment	Transformer Fuse	Replace - Same Size		VI
143480015	B44002	12/14/2014	1:43	12/14/2014	3:00	36	2772	77	Animal related	Fuse	Replace - Same Size		I
143480022	D36001	12/14/2014	2:36	12/14/2014	4:08	7	644	92	Unknown	Fuse	Patrol/Test/Inspect	Replace - Same Size	I
143480024	Y28598	12/14/2014	2:57	12/14/2014	5:00	1	123	123	Public	Fuse	Patrol/Test/Inspect	Patrol/Test/Inspect	IV
143480025	N50332	12/14/2014	3:04	12/14/2014	4:55	13	1443	111	Overhead equipment	Overhead Primary	Replace - Same Size	Replace - Same Size	II
143480074	S27598	12/14/2014	4:50	12/14/2014	7:32	2	324	162	Overhead equipment	Overhead Primary	Switch/Reset		VI
143480032	S27598	12/14/2014	4:50	12/14/2014	9:32	8	2256	282	Overhead equipment	Overhead Primary		Repair	VI
143480038	D36001	12/14/2014	5:18	12/14/2014	7:36	31	4278	138	Animal related	Fuse	Patrol/Test/Inspect		I
143480069	N50332	12/14/2014	5:53	12/14/2014	8:46	10	1730	173	Underground equipment	Riser	Replace - Same Size	Repair	II
143480067	H11340	12/14/2014	7:24	12/14/2014	8:10	18	828	46	Animal related	Fuse	Replace - Same Size	Replace - Same Size	V
143480063	D36001	12/14/2014	7:25	12/14/2014	8:01	1	36	36	Overhead equipment	Connector	Replace - Same Size		I
143480071	X88510	12/14/2014	7:37	12/14/2014	8:56	1	79	79	Animal related	Transformer Fuse	Replace - Same Size		IV
143480094	K76543	12/14/2014	8:13	12/14/2014	9:38	247	20995	85	Animal related	Fuse	Replace - Same Size		IV
143480082	K01241	12/14/2014	8:17	12/14/2014	12:07	1	230	230	Overhead equipment	Overhead Transformer			VI
143480097	J08205	12/14/2014	8:39	12/14/2014	10:10	1	91	91	Overhead equipment	Transformer Fuse	Replace - Same Size		I
143480110	T15570	12/14/2014	9:13	12/14/2014	10:20	1	67	67	Animal related	Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
143480137	K39153	12/14/2014	9:53	12/14/2014	13:47	18	4212	234	Overhead equipment	Overhead Transformer	Replace - Same Size		III
143480152	B80003	12/14/2014	10:25	12/14/2014	11:22	56	3192	57	Animal related	Fuse	Replace - Same Size		I
143480165	B80003	12/14/2014	10:25	12/14/2014	11:22	4	228	57	Animal related	Transformer Fuse	Replace - Same Size		I
143480163	R07382	12/14/2014	10:55	12/14/2014	13:00	1	125	125	Animal related	Fuse	Replace - Same Size	Replace - Same Size	I
143480179	V28597	12/14/2014	11:21	12/14/2014	12:40	1	79	79	Overhead equipment	Overhead Service	Repair	Repair	II
143480187	N60181	12/14/2014	11:38	12/14/2014	13:08	1	90	90	Overhead equipment	Fuse	Replace - Same Size		I
143480203	P58155	12/14/2014	12:15	12/14/2014	12:51	17	612	36	Animal related	Fuse	Replace - Same Size		VI
143480230	U68581	12/14/2014	13:31	12/14/2014	15:12	6	606	101	Animal related	Transformer Fuse	Replace - Same Size		II
143480234	V34002	12/14/2014	13:50	12/14/2014	15:18	1	88	88	Tree related-tree broken	Overhead Service	Repair		II
143480235	Q32171	12/14/2014	13:52	12/14/2014	19:43	5	1755	351	Overhead equipment	Connector	Replace - Same Size	Patrol/Test/Inspect	I
143480236	Q32171	12/14/2014	13:53	12/14/2014	18:40	1	287	287	Overhead equipment	Jumper	Replace - Same Size	Patrol/Test/Inspect	I
143480245	U97528	12/14/2014	14:08	12/14/2014	15:06	1	58	58	Overhead equipment	Transformer Fuse	Repair		II
143480249	A81001	12/14/2014	14:13	12/14/2014	15:20	1	67	67	Overhead equipment	Connector	Repair		I
143480278	N05172	12/14/2014	14:32	12/14/2014	15:45	1	73	73	Animal related	Transformer Fuse	Replace - Same Size		I
143480286	B27009	12/14/2014	14:54	12/14/2014	15:25	1	31	31	Overhead equipment	Connector	Replace - Same Size	Replace - Same Size	I

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
143480334	B25002	12/14/2014	15:25	12/14/2014	16:38	53	3869	73	Overhead equipment	Pole	Cut in Clear		I
143480389	B84006	12/14/2014	15:44	12/14/2014	20:35	74	21534	291	Overhead equipment	Overhead Primary	Repair		I
143480365	B84006	12/14/2014	15:44	12/14/2014	17:11	16	1392	87	Overhead equipment	Overhead Primary	Patrol/Test/Inspect	Repair	I
143480328	P57108	12/14/2014	15:55	12/14/2014	17:10	1	75	75	Overhead equipment	Overhead Primary			VI
143480373	S09520	12/14/2014	16:45	12/14/2014	21:42	2	594	297	Overhead equipment	Overhead Transformer	Replace - Same Size	Patrol/Test/Inspect	VI
143480460	L35139	12/14/2014	17:55	12/14/2014	19:01	101	6666	66	Unknown	Fuse	Replace - Same Size		III
143480894	P69174	12/14/2014	18:09	12/14/2014	20:08	1	119	119	Animal related	Fuse	Replace - Same Size		III
143483601	302004	12/14/2014	19:23	12/14/2014	19:36	1	13	13	Public	Overhead Service	Disconnect		VI
143485313	B00006	12/14/2014	19:46	12/14/2014	23:32	3	678	226	Underground equipment	Underground Primary	Switch/Reset	Switch/Reset	I
143485266	V45526	12/14/2014	20:05	12/14/2014	21:05	1	60	60	Tree related-tree broken	Overhead Service	Repair		II
143485919	B00007	12/14/2014	20:38	12/14/2014	23:29	1	171	171	Underground equipment				I
143485990	B00002	12/14/2014	20:39	12/14/2014	23:27	1	168	168	Underground equipment				I
143486214	Q01282	12/14/2014	20:44	12/14/2014	21:58	57	4218	74	Underground equipment	Underground Primary	Switch/Reset		III
143488903	Q01282	12/14/2014	20:44	12/14/2014	23:18	30	4620	154	Underground equipment	Underground Primary	Switch/Reset		III
143486724	B84006	12/14/2014	20:57	12/14/2014	21:20	1	23	23	Underground equipment	Underground Transformer	Patrol/Test/Inspect		I
143490149	V31003	12/15/2014	2:31	12/15/2014	3:56	1	85	85	Tree related-tree broken	Overhead Service	Repair		II
143492610	A36001	12/15/2014	3:56	12/15/2014	5:45	16	1744	109	Overhead equipment	Fuse	Replace - Same Size		I
143492633	V01001	12/15/2014	5:42	12/15/2014	7:24	51	5202	102	Overhead equipment	Overhead Primary	Switch/Reset		II
143492649	311001	12/15/2014	6:21	12/15/2014	8:43	1	142	142	Tree related-tree contact	Tree			VI
143492773	P47120	12/15/2014	7:34	12/15/2014	10:14	1	160	160	Tree related-tree contact	Overhead Transformer	Switch/Reset		I
143492823	J63171	12/15/2014	7:52	12/15/2014	10:00	16	2048	128	Underground equipment	Underground Primary	Repair	Repair	III
143492907	K08909	12/15/2014	8:17	12/15/2014	9:18	1	61	61	Animal related	Transformer Fuse	Repair	No Work Required	VI
143492920	M31203	12/15/2014	8:22	12/15/2014	9:05	1	43	43	Animal related	Transformer Fuse	Replace - Same Size		I
143492938	332001	12/15/2014	8:26	12/15/2014	13:55	1	329	329	Tree related-tree contact	Tree	Patrol/Test/Inspect		VI
143492980	J01118	12/15/2014	8:38	12/15/2014	11:45	5	935	187	Overhead equipment	Connector	Replace - Same Size	Patrol/Test/Inspect	I
143493200	J80807	12/15/2014	9:29	12/15/2014	11:45	1	136	136	Overhead equipment	Overhead Service	Repair	Replace - Same Size	V
143493440	V74513	12/15/2014	9:55	12/15/2014	13:07	10	1920	192	Animal related	Underground Primary		Repair	II
143493429	328120	12/15/2014	9:55	12/15/2014	12:22	1	147	147	Tree related-tree broken	Overhead Service	Repair	Replace - Same Size	V
143493523	V18582	12/15/2014	10:12	12/15/2014	11:11	15	885	59	Other	Disconnect Switch	Repair	Replace - Same Size	II
143493765	V46552	12/15/2014	10:51	12/15/2014	11:55	1	64	64	Overhead equipment	Fuse			II
143493838	B58002	12/15/2014	11:10	12/15/2014	13:35	6	870	145	Overhead equipment	Disconnect Switch	Patrol/Test/Inspect	Replace - Same Size	I
143493908	X02547	12/15/2014	11:30	12/15/2014	12:35	1	65	65	Overhead equipment	Fuse			IV
143494074	V61584	12/15/2014	11:32	12/15/2014	12:30	347	20126	58	Tree related-tree broken	Tree	Remove		II
143493967	Y13041	12/15/2014	11:45	12/15/2014	12:30	9	405	45	Overhead equipment	Jumper	Repair	Repair	IV
143494016	N73122	12/15/2014	11:56	12/15/2014	17:12	1	316	316	Overhead equipment	Overhead Transformer		Replace - Same Size	IV
143494166	M09143	12/15/2014	12:40	12/15/2014	13:09	18	522	29	Overhead equipment	Fuse	Replace - Same Size	No Work Required	VI
143495017	337001	12/15/2014	13:16	12/15/2014	15:41	391	56695	145	Substation equipment	Substation Breaker			VI
143494333	J88165	12/15/2014	13:16	12/15/2014	15:37	27	3807	141	Overhead equipment	Tree	Remove		VI
143495021	337002	12/15/2014	13:17	12/15/2014	16:51	418	89452	214	Overhead equipment				VI
143495026	337003	12/15/2014	13:19	12/15/2014	15:57	385	60830	158	Substation equipment	Substation Breaker			VI
143494515	X62032	12/15/2014	13:39	12/15/2014	14:18	1	39	39	Overhead equipment	Overhead Service			IV
143494621	M37191	12/15/2014	14:00	12/15/2014	15:14	1	74	74	Overhead equipment	Overhead Service	Repair	Replace - Same Size	I
143494641	S27599	12/15/2014	14:03	12/15/2014	14:55	1	52	52	Overhead equipment	Transformer Fuse			VI
143494946	B73002	12/15/2014	15:16	12/15/2014	20:40	55	17820	324	Overhead equipment	Crossarm	Replace - Same Size	Repair	I
143494949	U10569	12/15/2014	15:24	12/15/2014	15:51	1	27	27	Public	Overhead Service	Disconnect		II
143494982	R05114	12/15/2014	15:33	12/15/2014	16:51	1	78	78	Animal related	Fuse	Repair	Replace - Same Size	I
143495015	S61531	12/15/2014	15:48	12/15/2014	16:11	1	23	23	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	VI
143495131	S53543	12/15/2014	15:49	12/15/2014	20:16	7	1869	267	Public	Pole			VI
143495123	S53543	12/15/2014	15:49	12/15/2014	16:35	24	1104	46	Public	Pole			VI
143495032	S20555	12/15/2014	15:53	12/15/2014	17:08	1	75	75	Overhead equipment	Overhead Service	Repair	No Work Required	VI
143495105	Q37370	12/15/2014	16:23	12/15/2014	20:23	1	240	240	Overhead equipment	Disconnect Switch	Replace - Same Size	Repair	I
143495122	Q37370	12/15/2014	16:28	12/15/2014	19:42	1	194	194	Tree related-tree contact	Transformer Fuse	Replace - Same Size	Repair	I
143495103	K78351	12/15/2014	16:38	12/15/2014	19:00	49	6958	142	Underground equipment	Underground Primary	Switch/Reset	Repair	IV
143495149	Q16868	12/15/2014	16:49	12/16/2014	1:11	1	502	502	Underground equipment	Underground Service			V
143495160	M81403	12/15/2014	16:52	12/15/2014	19:50	1	178	178	Underground equipment	Underground Service	Patrol/Test/Inspect	Repair	V
143495231	M42107	12/15/2014	17:35	12/15/2014	19:11	1	96	96	Overhead equipment	Overhead Service	Repair	Replace - Same Size	I

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
143495248	P57102	12/15/2014	17:43	12/15/2014	18:24	1	41	41	Public	Meter	Install		VI
143496571	Q54908	12/15/2014	19:20	12/15/2014	23:36	1	256	256	Overhead equipment	Other			VI
143497029	B73001	12/15/2014	19:50	12/16/2014	4:33	59	30857	523	Overhead equipment	Insulator			I
143497054	K19114	12/15/2014	20:38	12/15/2014	21:44	1	66	66	Animal related	Transformer Fuse	Replace - Same Size	No Work Required	VI
143497064	D53001	12/15/2014	20:55	12/15/2014	22:06	1	71	71	Overhead equipment	Transformer Fuse	Replace - Same Size		I
143497081	U06524	12/15/2014	21:48	12/16/2014	4:50	1	422	422	Tree related-tree broken	Fuse	Replace - Same Size		II
143497089	J15302	12/15/2014	22:14	12/15/2014	23:43	1	89	89	Overhead equipment	Transformer Fuse	Replace - Same Size		I
143497092	K76541	12/15/2014	22:19	12/16/2014	0:16	1	117	117	Overhead equipment	Capacitor			IV
143497125	K76542	12/15/2014	22:28	12/16/2014	0:16	1	108	108	Overhead equipment	Capacitor			IV
143499189	V42586	12/15/2014	23:42	12/16/2014	1:25	1	103	103	Tree related-tree broken	Overhead Service	Repair	Repair	II
143502354	J61112	12/16/2014	0:48	12/16/2014	10:21	4	2292	573	Public	Pole			III
143502315	V20512	12/16/2014	3:06	12/16/2014	5:45	101	16059	159	Overhead equipment	Overhead Primary	Patrol/Test/Inspect	Patrol/Test/Inspect	II
143502317	U64518	12/16/2014	3:17	12/16/2014	7:25	1	248	248	Overhead equipment	Disconnect Switch	Repair	Replace - Same Size	II
143502319	V33001	12/16/2014	3:43	12/16/2014	5:47	1	124	124	Overhead equipment	Transformer Fuse	Replace - Same Size		II
143502325	V33001	12/16/2014	3:55	12/16/2014	5:10	14	1050	75	Overhead equipment	Transformer Fuse	Replace - Same Size		II
143502347	D48003	12/16/2014	4:58	12/16/2014	7:50	62	10664	172	Overhead equipment	Crossarm	Patrol/Test/Inspect	Replace - Urgent	I
143502370	B65004	12/16/2014	5:41	12/16/2014	6:39	9	522	58	Tree related-tree broken	Tree	Cut in Clear		I
143502390	M45212	12/16/2014	6:00	12/16/2014	7:50	144	15840	110	Overhead equipment	Overhead Primary	Repair		IV
143502392	B65004	12/16/2014	6:18	12/16/2014	7:52	1	94	94	Tree related-tree broken	Overhead Service			I
143502467	Y51505	12/16/2014	7:08	12/16/2014	9:30	1	142	142	Overhead equipment	Overhead Secondary	Repair		IV
143502508	N03296	12/16/2014	7:32	12/16/2014	13:00	1	328	328	Overhead equipment	Jumper	Repair	Repair	V
143502522	K22173	12/16/2014	7:40	12/16/2014	8:16	1	36	36	Animal related	Transformer Fuse	Repair	Repair	VI
143502578	Z17503	12/16/2014	7:43	12/16/2014	8:14	894	27714	31	Public	Substation Breaker	Switch/Reset		IV
143502880	Z17503	12/16/2014	7:43	12/16/2014	8:20	26	962	37	Public	Pole	Replace - New Size	Replace - New Size	IV
143502624	P82291	12/16/2014	8:00	12/16/2014	10:32	49	7448	152	Tree related-tree broken	Overhead Primary	Patrol/Test/Inspect	Replace - Same Size	VI
143503049	Q18244	12/16/2014	9:03	12/16/2014	10:15	2	144	72	Animal related	Fuse	Replace - Same Size		VI
143503121	N93260	12/16/2014	9:20	12/16/2014	10:07	1	47	47	Overhead equipment				III
143503164	D32212	12/16/2014	9:32	12/16/2014	11:35	2	246	123	Overhead equipment	Pole	Patrol/Test/Inspect	Replace - Same Size	I
143503207	U80511	12/16/2014	9:43	12/16/2014	10:35	1	52	52	Overhead equipment	Jumper	Repair		II
143503223	Q85162	12/16/2014	9:47	12/16/2014	10:07	1	20	20	Tree related-tree broken	Transformer Fuse	Repair	Repair	VI
143503240	Y54587	12/16/2014	9:49	12/16/2014	11:16	2	174	87	Jurisdictional	Underground Primary	Repair	Repair	IV
143503934	Z17503	12/16/2014	9:57	12/16/2014	13:30	26	5538	213	Underground equipment	Underground Primary			IV
143503279	Z17503	12/16/2014	9:58	12/16/2014	15:00	1	302	302	Underground equipment	Underground Primary	Cut in Clear		IV
143503431	Q18244	12/16/2014	10:19	12/16/2014	10:25	1337	8022	6	Other				VI
143503387	A45003	12/16/2014	10:21	12/16/2014	12:05	1	104	104	Tree related-tree contact	Connector	Replace - Same Size		I
143503447	Q18244	12/16/2014	10:30	12/16/2014	10:44	1	14	14	Overhead equipment	Overhead Primary	Switch/Reset		VI
143503722	X15746	12/16/2014	10:44	12/16/2014	12:34	434	47740	110	Animal related	Fuse			IV
143503490	M47802	12/16/2014	10:44	12/16/2014	13:16	1	152	152	Overhead equipment	Overhead Service			V
143503524	L00134	12/16/2014	10:48	12/16/2014	11:46	1	58	58	Overhead equipment	Overhead Primary	Repair		III
143503927	X15746	12/16/2014	11:06	12/16/2014	12:08	348	21576	62	Animal related	Fuse			IV
143503749	R34920	12/16/2014	11:36	12/16/2014	15:04	1	208	208	Tree related-tree broken	Overhead Service		Repair	VI
143503816	L71170	12/16/2014	11:53	12/16/2014	12:48	1	55	55	Overhead equipment	Fuse	Repair		IV
143503889	K71812	12/16/2014	12:18	12/16/2014	13:47	1	89	89	Overhead equipment	Jumper	Repair		IV
143503967	Q18244	12/16/2014	12:35	12/16/2014	13:00	1	25	25	Overhead equipment	Overhead Transformer	Cut in Clear	Replace - Same Size	VI
143504005	Y69553	12/16/2014	12:45	12/16/2014	14:55	1	130	130	Overhead equipment	Overhead Transformer	Replace - Same Size	Replace - Same Size	IV
143504076	B54004	12/16/2014	13:05	12/16/2014	13:53	1	48	48	Overhead equipment	Connector	Patrol/Test/Inspect	Replace - New Size	I
143504188	D96001	12/16/2014	13:38	12/16/2014	14:31	1	53	53	Tree related-tree contact	Other	Cut in Clear		I
143504196	D32211	12/16/2014	13:43	12/16/2014	15:20	1	97	97	Tree related-tree broken	Overhead Primary	Patrol/Test/Inspect	Repair	I
143504201	U73599	12/16/2014	13:46	12/16/2014	15:27	1	101	101	Tree related-tree broken	Overhead Service	Raise		II
143504273	Y59520	12/16/2014	14:04	12/16/2014	15:25	1	81	81	Animal related	Transformer Fuse	Replace - Same Size	Replace - Same Size	IV
143504304	U60559	12/16/2014	14:15	12/16/2014	14:33	1	18	18	Animal related	Transformer Fuse	Replace - Same Size		II
143504359	T06504	12/16/2014	14:33	12/16/2014	15:28	1	55	55	Overhead equipment	Overhead Service	Patrol/Test/Inspect	Repair	VI
143504410	M73330	12/16/2014	14:45	12/16/2014	15:35	5	250	50	Overhead equipment	Overhead Secondary	Raise		V
143504734	J86108	12/16/2014	16:40	12/16/2014	17:40	1	60	60	Animal related	Transformer Fuse	Replace - Same Size		VI
143505386	B84005	12/16/2014	16:43	12/16/2014	17:40	631	35967	57	Jurisdictional	Substation Misc.			I
143505453	B84002	12/16/2014	16:43	12/16/2014	19:47	611	112424	184	Jurisdictional	Substation Misc.			I

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
143505457	B84004	12/16/2014	16:43	12/16/2014	17:45	355	22010	62	Jurisdictional	Substation Misc.			I
143505414	B84006	12/16/2014	16:43	12/16/2014	17:41	598	34684	58	Jurisdictional	Substation Misc.			I
143505754	B84003	12/16/2014	16:43	12/16/2014	17:45	472	29264	62	Jurisdictional	Substation Misc.			I
143505777	B84002	12/16/2014	16:43	12/16/2014	20:25	75	16650	222	Other	Fuse	Replace - New Size		I
143505047	Y69553	12/16/2014	17:15	12/16/2014	23:59	1	404	404	Underground equipment	Underground Primary	Repair	Repair	IV
143505454	P54827	12/16/2014	17:36	12/16/2014	21:50	4	1016	254	Overhead equipment	Overhead Transformer	Repair	No Work Required	V
143505331	R33126	12/16/2014	18:14	12/16/2014	23:34	31	9920	320	Public	Pole	Replace - New Size	Replace - New Size	I
143505352	R50910	12/16/2014	18:28	12/16/2014	18:57	1	29	29	Overhead equipment	Overhead Primary	Repair		I
143505375	R33126	12/16/2014	18:50	12/17/2014	0:10	1	320	320	Public	Pole	Repair	Replace - New Size	I
143505781	V14579	12/16/2014	20:13	12/17/2014	0:13	2	480	240	Overhead equipment	Fuse	Replace - Same Size	Repair	II
143505787	T06540	12/16/2014	20:44	12/16/2014	22:10	1	86	86	Overhead equipment	Overhead Service	Patrol/Test/Inspect	Repair	VI
143505824	J99128	12/16/2014	23:29	12/17/2014	1:24	1	115	115	Overhead equipment	Connector	Replace - Same Size		VI
143512453	D88001	12/17/2014	2:17	12/17/2014	6:38	7	1827	261	Underground equipment	Underground Primary	No Work Required	No Work Required	I
143512442	C66001	12/17/2014	3:09	12/17/2014	5:23	1	134	134	Animal related	Fuse	Replace - Same Size	No Work Required	III
143512564	B08004	12/17/2014	7:26	12/17/2014	11:43	1	257	257	Underground equipment	Underground Transformer	Patrol/Test/Inspect	Patrol/Test/Inspect	I
143512588	Z51551	12/17/2014	7:40	12/17/2014	8:30	7	350	50	Overhead equipment	Overhead Primary			IV
143512608		12/17/2014	7:47	12/17/2014	9:41	1	114	114	Overhead equipment	Transformer Fuse	Repair		I
143512614	K46388	12/17/2014	7:49	12/17/2014	8:30	1	41	41	Animal related	Fuse	Replace - Same Size		V
143512630	U95001	12/17/2014	7:53	12/17/2014	9:05	1	72	72	Overhead equipment	Overhead Service	Repair	Repair	II
143512699	A16002	12/17/2014	8:14	12/17/2014	9:21	1	67	67	Overhead equipment	Connector	Patrol/Test/Inspect	Replace - New Size	I
143512772	P49180	12/17/2014	8:32	12/17/2014	9:45	1	73	73	Animal related	Overhead Transformer	Switch/Reset		I
143513111	B73002	12/17/2014	10:05	12/17/2014	11:15	1	70	70	Overhead equipment	Connector	Replace - Same Size		I
143513138	X91510	12/17/2014	10:15	12/17/2014	11:20	1	65	65	Overhead equipment	Transformer Fuse	Repair	Replace - Same Size	IV
143513257	P42229	12/17/2014	10:51	12/17/2014	11:35	1	44	44	Animal related	Transformer Fuse	Replace - Same Size		VI
143513294	308003	12/17/2014	11:01	12/17/2014	12:24	1	83	83	Overhead equipment	Fuse	Patrol/Test/Inspect		VI
143513324	R95520	12/17/2014	11:07	12/17/2014	13:30	42	6006	143	Overhead equipment	Overhead Primary	Patrol/Test/Inspect	Repair	I
143513361	D92001	12/17/2014	11:17	12/17/2014	21:15	1	598	598	Underground equipment	Underground Service	Patrol/Test/Inspect	Repair	I
143513479	V24583	12/17/2014	12:03	12/17/2014	12:35	5	160	32	Animal related	Transformer Fuse	Repair	Replace - Same Size	II
143513606	R49275	12/17/2014	12:50	12/17/2014	14:38	1	108	108	Public	Fuse	Replace - Same Size		VI
143513707	308003	12/17/2014	13:19	12/17/2014	14:18	1	59	59	Overhead equipment	Fuse	Patrol/Test/Inspect		VI
143513804	L23145	12/17/2014	13:48	12/17/2014	14:27	14	546	39	Overhead equipment	Fuse	Replace - Same Size		III
143514085	K46388	12/17/2014	15:13	12/17/2014	22:03	1	410	410	Underground equipment	Underground Service		Repair	V
143514171	D92002	12/17/2014	15:50	12/17/2014	17:02	1	72	72	Overhead equipment	Connector	No Work Required	Replace - Same Size	I
143514230	R33126	12/17/2014	16:18	12/17/2014	17:15	1	57	57	Overhead equipment	Transformer Fuse	Replace - Same Size	Patrol/Test/Inspect	I
143514366	G10002	12/17/2014	17:39	12/18/2014	2:45	1	546	546	Overhead equipment	Overhead Transformer	Cut in Clear	Replace - Same Size	I
143514397	Q64917	12/17/2014	18:08	12/17/2014	19:36	9	792	88	Overhead equipment	Fuse	Replace - Same Size		VI
143514404	Q64917	12/17/2014	18:22	12/17/2014	19:35	9	657	73	Overhead equipment	Fuse	Replace - Same Size		VI
143514502	310123	12/17/2014	19:34	12/17/2014	21:05	9	819	91	Overhead equipment	Overhead Primary	Repair		V
143520095	B77002	12/18/2014	0:14	12/18/2014	4:55	1	281	281	Underground equipment	Underground Service	Patrol/Test/Inspect	Repair	I
143522462	HB6283	12/18/2014	6:40	12/18/2014	11:30	1	290	290	Underground equipment	Underground Service			VI
143522795	K62102	12/18/2014	7:30	12/18/2014	14:44	5	2170	434	Public	Pole	Replace - Same Size	Repair	II
143522568	Q64919	12/18/2014	7:38	12/18/2014	8:03	1	25	25	Animal related	Fuse	Repair		VI
143522575	K46388	12/18/2014	7:42	12/18/2014	9:05	1	83	83	Underground equipment	Underground Service	Cut in Clear	Repair	V
143522717	Q21423	12/18/2014	8:42	12/18/2014	10:10	5	440	88	Public	Underground Primary	Switch/Reset	Repair	VI
143522745	S37533	12/18/2014	8:53	12/18/2014	10:00	1	67	67	Overhead equipment	Overhead Service	Patrol/Test/Inspect	Repair	VI
143522748	X36001	12/18/2014	8:54	12/18/2014	10:25	1	91	91	Overhead equipment	Overhead Service	Patrol/Test/Inspect	Patrol/Test/Inspect	IV
143522894	Y07558	12/18/2014	9:39	12/18/2014	10:20	1	41	41	Tree related-tree contact	Tree			IV
143522898	F10002	12/18/2014	9:40	12/18/2014	10:15	1	35	35	Animal related	Underground Primary	Replace - Same Size	Patrol/Test/Inspect	III
143522897	M18130	12/18/2014	9:40	12/18/2014	11:56	1	136	136	Underground equipment	Underground Service	Patrol/Test/Inspect	Repair	III
143522941	K46388	12/18/2014	9:55	12/18/2014	10:11	1	16	16	Underground equipment				V
143523036	K46388	12/18/2014	10:25	12/18/2014	10:32	1	7	7	Underground equipment				V
143523102	V74506	12/18/2014	10:28	12/18/2014	10:56	5	140	28	Animal related	Transformer Fuse		Replace - Same Size	II
143523107	B84002	12/18/2014	10:44	12/18/2014	12:27	12	1236	103	Overhead equipment	Overhead Primary	Repair		I
143523114	R23332	12/18/2014	10:46	12/18/2014	11:40	1	54	54	Animal related	Transformer Fuse	Replace - Same Size	Repair	V
143523149	T59902	12/18/2014	10:54	12/18/2014	12:55	1	121	121	Overhead equipment	Overhead Transformer	Replace - Same Size	Repair	VI
143523184	K27150	12/18/2014	11:08	12/18/2014	12:45	1	97	97	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	VI

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
143523204	V77543	12/18/2014	11:15	12/18/2014	13:05	1	110	110	Animal related	Fuse	Replace - Same Size		II
143523209	T16526	12/18/2014	11:18	12/18/2014	11:50	1	32	32	Public	Overhead Primary	Repair	Repair	VI
143523250	J34356	12/18/2014	11:34	12/18/2014	13:21	14	1498	107	Overhead equipment	Fuse	Replace - Same Size		V
143523300	HA5432	12/18/2014	12:01	12/18/2014	12:36	1	35	35	Animal related	Fuse	Replace - Same Size		V
143523328	A49001	12/18/2014	12:12	12/18/2014	14:01	5	545	109	Animal related	Transformer Fuse	Replace - Same Size		I
143523356	L24123	12/18/2014	12:26	12/18/2014	13:04	1	38	38	Animal related	Transformer Fuse	Repair		III
143523430	S92559	12/18/2014	12:55	12/18/2014	13:28	1	33	33	Animal related	Transformer Fuse	Replace - Same Size		VI
143523645	W03570	12/18/2014	14:36	12/18/2014	17:05	2	298	149	Public	Pole	Repair	Patrol/Test/Inspect	II
143523700	343001	12/18/2014	14:39	12/18/2014	16:05	1	86	86	Tree related-tree broken	Overhead Service	Repair		VI
143523725	R93351	12/18/2014	14:49	12/18/2014	17:20	14	2114	151	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	V
143523759	B21003	12/18/2014	15:01	12/18/2014	15:27	1	26	26	Animal related	Transformer Fuse	Replace - Same Size		I
143524234	P57108	12/18/2014	18:47	12/18/2014	19:42	1	55	55	Overhead equipment	Transformer Fuse	Replace - Same Size		VI
143524569	B80002	12/18/2014	19:09	12/18/2014	20:13	1	64	64	Overhead equipment	Connector		Repair	I
143524572	J74125	12/18/2014	19:20	12/18/2014	23:40	1	260	260	Underground equipment	Underground Service		Repair	VI
143524608	Q91141	12/18/2014	20:54	12/18/2014	21:45	1	51	51	Unknown	Transformer Fuse	Replace - Same Size		I
143524624	G30001	12/18/2014	21:39	12/18/2014	21:54	2	30	15	Overhead equipment	Pole	Switch/Reset	Replace - New Size	III
143532516	X65540	12/19/2014	5:45	12/19/2014	11:10	1	325	325	Underground equipment	Underground Service	Repair	Repair	IV
143532548	N54214	12/19/2014	6:56	12/19/2014	13:25	1	389	389	Underground equipment	Underground Service	Patrol/Test/Inspect	Repair	II
143532616	Q15844	12/19/2014	7:36	12/19/2014	8:48	1	72	72	Animal related	Transformer Fuse	Replace - Same Size		V
143532658	Y13041	12/19/2014	8:04	12/19/2014	9:00	1	56	56	Overhead equipment	Transformer Fuse	Replace - New Size	Replace - New Size	IV
143532836	U90572	12/19/2014	8:41	12/19/2014	9:29	4	192	48	Overhead equipment	Transformer Fuse	Repair		II
143532970	M07235	12/19/2014	9:00	12/19/2014	9:19	1	19	19	Unknown	Transformer Fuse	Replace - Same Size		III
143533002	X91510	12/19/2014	9:13	12/19/2014	11:44	1	151	151	Underground equipment	Underground Service	Repair	Replace - Same Size	IV
143533119	J80807	12/19/2014	9:48	12/19/2014	10:35	1	47	47	Animal related	Overhead Transformer	Repair	Repair	V
143533125	Y89540	12/19/2014	9:49	12/19/2014	11:01	1	72	72	Animal related	Fuse	Repair	Replace - Same Size	IV
143533129	D88001	12/19/2014	9:50	12/19/2014	10:59	1	69	69	Underground equipment	Meter	Disconnect	No Work Required	I
143533131	K76547	12/19/2014	9:51	12/19/2014	10:43	1	52	52	Animal related	Transformer Fuse	Replace - Same Size		IV
143533223	A97002	12/19/2014	10:21	12/19/2014	11:40	1	79	79	Overhead equipment	Lightning Arrestor	Patrol/Test/Inspect	Cut in Clear	I
143533286	D96001	12/19/2014	10:43	12/19/2014	11:41	3	174	58	Animal related	Other	Replace - Same Size		I
143533390	N60181	12/19/2014	11:13	12/19/2014	12:00	27	1269	47	Animal related	Fuse	Replace - Same Size		I
143533378	H01190	12/19/2014	11:15	12/19/2014	11:48	1	33	33	Animal related	Transformer Fuse	Replace - Same Size		III
143533571	Q15844	12/19/2014	12:21	12/19/2014	13:53	1	92	92	Overhead equipment	Overhead Transformer		Replace - Same Size	V
143533587	Q06132	12/19/2014	12:26	12/19/2014	14:20	1	114	114	Overhead equipment	Overhead Secondary	Repair		IV
143533722	X02546	12/19/2014	12:56	12/19/2014	13:34	23	874	38	Overhead equipment	Overhead Service			IV
143533698	Q47833	12/19/2014	13:01	12/19/2014	14:10	1	69	69	Overhead equipment	Transformer Fuse	Replace - Same Size	Replace - Same Size	V
143533809	D89002	12/19/2014	13:41	12/19/2014	18:05	1	264	264	Animal related	Underground Primary	Patrol/Test/Inspect	Repair	I
143533853	M25143	12/19/2014	13:58	12/19/2014	15:21	1	83	83	Animal related	Transformer Fuse	Replace - Same Size		IV
143533857	S52515	12/19/2014	14:01	12/19/2014	18:10	1	249	249	Underground equipment	Underground Service	Repair	Repair	VI
143533883	V42572	12/19/2014	14:09	12/19/2014	16:01	1	112	112	Underground equipment	Underground Secondary	Repair		II
143533951	M25144	12/19/2014	14:32	12/19/2014	15:45	1	73	73	Overhead equipment	Transformer Fuse	Replace - Same Size	No Work Required	IV
143533961	F10003	12/19/2014	14:36	12/19/2014	15:08	1	32	32	Animal related	Transformer Fuse	Replace - Same Size		III
143534004	R93350	12/19/2014	14:55	12/19/2014	15:44	1	49	49	Animal related	Transformer Fuse	Replace - Same Size		V
143534165	H02256	12/19/2014	16:04	12/19/2014	18:18	6	804	134	Public	Overhead Service			III
143534145	Q16868	12/19/2014	16:05	12/19/2014	17:17	4	288	72	Animal related	Fuse	Replace - Same Size	No Work Required	V
143534164	M45212	12/19/2014	16:16	12/19/2014	19:30	1	194	194	Overhead equipment	Overhead Service	Replace - New Size		IV
143534201	N22296	12/19/2014	16:40	12/19/2014	19:44	1	184	184	Animal related	Transformer Fuse	Replace - Same Size		VI
143534323	J15303	12/19/2014	17:20	12/19/2014	18:14	1	54	54	Overhead equipment	Connector	Replace - Same Size	Replace - Same Size	I
143534339	R49261	12/19/2014	17:32	12/19/2014	21:16	1	224	224	Overhead equipment	Overhead Service	Replace - Same Size		VI
143534354	R49275	12/19/2014	17:50	12/19/2014	22:40	5	1450	290	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	VI
143534699	R49275	12/19/2014	17:52	12/19/2014	19:58	3	378	126	Underground equipment				VI
143534671	R49275	12/19/2014	17:56	12/19/2014	19:20	2	168	84	Underground equipment				VI
143534361	M09175	12/19/2014	18:07	12/19/2014	18:36	1	29	29	Overhead equipment	Fuse	Replace - Same Size	No Work Required	VI
143534366	K65221	12/19/2014	18:20	12/19/2014	18:49	1	29	29	Overhead equipment	Overhead Service			III
143534709	R49275	12/19/2014	18:20	12/19/2014	20:20	2	240	120	Underground equipment				VI
143534375	L24122	12/19/2014	18:59	12/19/2014	20:06	1	67	67	Overhead equipment	Overhead Service	Repair		III
143534696	R53391	12/19/2014	19:55	12/20/2014	1:52	1	357	357	Underground equipment	Underground Secondary	Patrol/Test/Inspect	Repair	V

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
143534730	B00004	12/19/2014	21:34	12/19/2014	22:45	1	71	71	Overhead equipment	Connector	Replace - Same Size	Replace - Same Size	I
143534737	K46389	12/19/2014	21:53	12/20/2014	3:44	5	1755	351	Underground equipment	Underground Secondary	Patrol/Test/Inspect	Repair	V
143540024	R84148	12/20/2014	1:54	12/20/2014	5:37	7	1561	223	Unknown	Fuse	Repair	Replace - Same Size	I
143540053	347001	12/20/2014	5:02	12/20/2014	6:46	315	32760	104	Public	Pole			VI
143540061	347001	12/20/2014	5:02	12/20/2014	17:54	35	27020	772	Public	Pole		Repair	VI
143540081	J18268	12/20/2014	7:42	12/20/2014	8:48	7	462	66	Animal related	Transformer Fuse	Replace - Same Size		VI
143540167	S15559	12/20/2014	8:12	12/20/2014	10:19	5	635	127	Animal related	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
143540171	J34377	12/20/2014	8:17	12/20/2014	9:13	9	504	56	Animal related	Fuse	Replace - Same Size		V
143540188	U84534	12/20/2014	8:29	12/20/2014	10:05	58	5568	96	Overhead equipment	Fuse	Replace - Same Size		II
143540345	M09143	12/20/2014	8:29	12/20/2014	9:28	3	177	59	Animal related	Fuse	Replace - Same Size		VI
143540348	Q06664	12/20/2014	8:35	12/20/2014	9:48	2535	185055	73	Animal related	Substation Breaker	Repair		IV
143540259	Q18242	12/20/2014	8:39	12/20/2014	9:20	8	328	41	Animal related	Transformer Fuse	Replace - Same Size		VI
143540292	P53341	12/20/2014	8:51	12/20/2014	13:33	5	1410	282	Animal related	Fuse	Repair		IV
143540346	Q06664	12/20/2014	8:51	12/20/2014	9:38	730	34310	47	Animal related	Substation Breaker	Repair		IV
143540604	K79633	12/20/2014	8:51	12/20/2014	12:44	11	2563	233	Underground equipment	Underground Primary	Cut in Clear	Repair	IV
143540617	K79633	12/20/2014	8:51	12/20/2014	12:44	10	2330	233	Underground equipment	Underground Primary	Cut in Clear	Repair	IV
143540661	K79633	12/20/2014	8:51	12/20/2014	13:20	28	7532	269	Underground equipment	Underground Primary	Repair	Repair	IV
143540340	Q06664	12/20/2014	8:51	12/20/2014	9:46	696	38280	55	Underground equipment	Underground Primary	Switch/Reset	Repair	IV
143540379	V46563	12/20/2014	9:45	12/20/2014	13:20	1	215	215	Underground equipment	Underground Service	Repair	Repair	II
143540395	R16511	12/20/2014	10:03	12/20/2014	10:36	1	33	33	Weather	Transformer Fuse	Replace - Same Size		I
143540407	Q64919	12/20/2014	10:14	12/20/2014	11:19	1	65	65	Animal related	Fuse	Replace - Same Size	Repair	VI
143540458	K76541	12/20/2014	10:25	12/20/2014	10:52	797	21519	27	Underground equipment	Underground Primary	Cut in Clear	Repair	IV
143540460	T22507	12/20/2014	10:41	12/20/2014	12:34	1	113	113	Animal related	Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
143540485	S42579	12/20/2014	11:24	12/20/2014	12:44	1	80	80	Animal related	Transformer Fuse	Repair	Replace - Same Size	VI
143540658	R04415	12/20/2014	12:41	12/20/2014	17:45	1	304	304	Underground equipment	Underground Secondary	Patrol/Test/Inspect	Repair	V
143540681	V74513	12/20/2014	13:14	12/20/2014	15:09	1	115	115	Overhead equipment	Overhead Service		Repair	II
143540696	L70127	12/20/2014	13:35	12/20/2014	15:44	1	129	129	Underground equipment	Underground Service			IV
143540730	V41568	12/20/2014	15:20	12/20/2014	15:46	7	182	26	Animal related	Transformer Fuse	Replace - Same Size		II
143540732	B08004	12/20/2014	15:24	12/20/2014	16:32	5	340	68	Animal related	Transformer Fuse	Replace - Same Size		I
143540744	K09863	12/20/2014	15:43	12/20/2014	16:30	1	47	47	Animal related	Fuse	Replace - Same Size	Replace - Same Size	V
143540752	K27153	12/20/2014	15:54	12/20/2014	17:32	1	98	98	Animal related	Transformer Fuse	Replace - Same Size		VI
143540760	R39934	12/20/2014	16:05	12/20/2014	17:03	21	1218	58	Overhead equipment	Jumper	Repair		VI
143540816	M41113	12/20/2014	16:39	12/20/2014	18:06	72	6264	87	Unknown	Fuse	Repair	Replace - Same Size	I
143540836	J85161	12/20/2014	17:23	12/20/2014	22:28	1	305	305	Overhead equipment	Overhead Service	Patrol/Test/Inspect	Repair	VI
143540851	B21004	12/20/2014	18:02	12/20/2014	19:26	1	84	84	Animal related	Fuse	Patrol/Test/Inspect	Replace - Same Size	I
143540852	N94180	12/20/2014	18:07	12/21/2014	1:25	1	438	438	Underground equipment	Underground Primary	Repair		I
143540911	L00133	12/20/2014	22:45	12/20/2014	23:57	21	1512	72	Animal related	Fuse	Replace - Same Size		III
143550034	M26161	12/21/2014	7:12	12/21/2014	11:40	1	268	268	Overhead equipment	Overhead Transformer	Replace - Same Size		III
143550041	K08909	12/21/2014	8:00	12/21/2014	10:50	3	510	170	Animal related	Transformer Fuse	Replace - Same Size		VI
143550061	S47575	12/21/2014	8:17	12/21/2014	10:01	7	728	104	Animal related	Disconnect Switch	Replace - Same Size		VI
143550052	H22346	12/21/2014	8:28	12/21/2014	9:26	1	58	58	Animal related	Fuse	Replace - Same Size		V
143550075	T06505	12/21/2014	8:53	12/21/2014	9:50	1	57	57	Animal related	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
143550083	J18268	12/21/2014	8:58	12/21/2014	11:34	1	156	156	Animal related	Fuse	Replace - Same Size		VI
143550102	T16526	12/21/2014	9:48	12/21/2014	14:30	1	282	282	Underground equipment	Underground Service			VI
143550122	R95520	12/21/2014	10:12	12/21/2014	12:37	42	6090	145	Tree related-tree broken	Tree	Remove		I
143550118	R61241	12/21/2014	10:23	12/21/2014	11:30	1	67	67	Animal related	Transformer Fuse			IV
143550168	R28871	12/21/2014	12:01	12/21/2014	14:31	145	21750	150	Overhead equipment	Jumper		Replace - Same Size	V
143550414	X75571	12/21/2014	12:08	12/21/2014	15:30	7	1414	202	Overhead equipment	Disconnect Switch	Replace - Same Size	Repair	IV
143550187	D36001	12/21/2014	12:45	12/21/2014	13:16	8	248	31	Unknown	Disconnect Switch	Replace - Same Size	Replace - Same Size	I
143550397	J74125	12/21/2014	13:11	12/21/2014	14:10	6	354	59	Animal related	Transformer Fuse	Repair	Repair	VI
143550420	J83138	12/21/2014	13:53	12/21/2014	15:08	37	2775	75	Overhead equipment	Fuse	Replace - Same Size		VI
143550422	P54828	12/21/2014	14:01	12/21/2014	15:20	4	316	79	Animal related	Fuse	Replace - Same Size	No Work Required	V
143550424	R73841	12/21/2014	14:02	12/21/2014	18:30	2	536	268	Animal related	Overhead Transformer	Patrol/Test/Inspect	Repair	V
143550426	M05360	12/21/2014	14:04	12/21/2014	15:00	1	56	56	Animal related	Fuse	Replace - Same Size		V
143550434	Y45503	12/21/2014	14:26	12/21/2014	15:14	1	48	48	Overhead equipment	Fuse	Repair	Replace - Same Size	IV
143550458	M09143	12/21/2014	14:51	12/21/2014	15:37	1	46	46	Overhead equipment	Fuse	Replace - Same Size	No Work Required	VI

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
143550473	328120	12/21/2014	15:16	12/21/2014	15:39	1	23	23	Underground equipment	Underground Transformer	Switch/Reset		V
143550486	T59942	12/21/2014	16:09	12/21/2014	18:30	1	141	141	Overhead equipment	Overhead Service	Repair		VI
143550535	R04415	12/21/2014	18:04	12/22/2014	4:20	102	62832	616	Underground equipment	Underground Primary	Repair	Advise Customer	V
143550578	S01521	12/21/2014	19:46	12/22/2014	1:34	1	348	348	Underground equipment	Underground Primary			VI
143550599	P26281	12/21/2014	21:08	12/21/2014	22:54	1	106	106	Public				I
143562798	L90359	12/22/2014	6:34	12/22/2014	7:22	1	48	48	Animal related	Transformer Fuse	Replace - Same Size		V
143562897	B27006	12/22/2014	7:40	12/22/2014	10:00	1	140	140	Overhead equipment				I
143562955	U57561	12/22/2014	7:46	12/22/2014	10:35	180	30420	169	Weather	Crossarm		Replace - New Size	II
143562973	C66002	12/22/2014	8:15	12/22/2014	9:08	1	53	53	Animal related	Fuse	Replace - Same Size	No Work Required	III
143562993	X20001	12/22/2014	8:22	12/22/2014	9:37	1	75	75	Overhead equipment	Connector	Repair	Replace - New Size	IV
143563082	P82291	12/22/2014	8:57	12/22/2014	14:20	1	323	323	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	VI
143563215	U37579	12/22/2014	9:47	12/22/2014	10:45	1	58	58	Overhead equipment	Disconnect Switch	Replace - Same Size	Patrol/Test/Inspect	II
143563220	Z05001	12/22/2014	9:48	12/22/2014	10:50	8	496	62	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
143563277	M48815	12/22/2014	10:07	12/22/2014	12:35	1	148	148	Overhead equipment	Overhead Transformer	Replace - Same Size	Replace - Same Size	V
143563281	B57002	12/22/2014	10:09	12/22/2014	10:50	1	41	41	Overhead equipment	Connector	Patrol/Test/Inspect	Replace - New Size	I
143563312	K43385	12/22/2014	10:21	12/22/2014	11:00	1	39	39	Overhead equipment	Connector	Replace - Same Size		V
143563404	J75271	12/22/2014	10:32	12/22/2014	13:00	29	4292	148	Public	Underground Primary	Patrol/Test/Inspect	Repair	IV
143563360	J75271	12/22/2014	10:32	12/22/2014	12:46	42	5628	134	Public	Underground Primary	Switch/Reset	Repair	IV
143563396	K31124	12/22/2014	10:48	12/22/2014	11:41	1	53	53	Weather	Transformer Fuse	Replace - Same Size		I
143563479	A91004	12/22/2014	10:57	12/22/2014	12:24	667	58029	87	Unknown				I
143563506	S55535	12/22/2014	11:12	12/22/2014	11:57	1	45	45	Animal related	Fuse	Replace - Same Size		VI
143563571	B73001	12/22/2014	11:37	12/22/2014	14:42	4	740	185	Overhead equipment	Fuse	Replace - Same Size		I
143563603	N03299	12/22/2014	11:51	12/22/2014	12:30	1	39	39	Animal related	Transformer Fuse	Replace - Same Size		V
143563680	Y79500	12/22/2014	12:07	12/22/2014	13:07	32	1920	60	Overhead equipment	Disconnect Switch	Repair	Replace - New Size	IV
143563975	P49187	12/22/2014	12:45	12/22/2014	16:18	1	213	213	Overhead equipment	Pole	Replace - Same Size	Replace - Same Size	I
143563887	B93003	12/22/2014	13:39	12/22/2014	18:44	254	77470	305	Overhead equipment	Disconnect Switch	Repair		I
143564069	M36189	12/22/2014	14:33	12/22/2014	15:02	1	29	29	Overhead equipment	Fuse	Repair	Replace - Same Size	I
143564124	L79180	12/22/2014	14:34	12/22/2014	15:45	31	1810	58	Overhead equipment	Tree		Remove	IV
143564299	Y69565	12/22/2014	14:34	12/22/2014	16:30	25	2900	116	Overhead equipment	Insulator	Replace - Same Size	Replace - Same Size	IV
143564204	J12166	12/22/2014	15:53	12/22/2014	16:32	54	2106	39	Tree related-tree broken	Tree	Cut in Clear		III
143564261	T23527	12/22/2014	15:58	12/22/2014	22:54	5	2080	416	Underground equipment	Underground Transformer			VI
143564225	L17104	12/22/2014	16:04	12/22/2014	16:55	20	1020	51	Animal related	Fuse	Replace - Same Size		III
143564375	S07536	12/22/2014	16:13	12/22/2014	18:45	122	18544	152	Overhead equipment	Crossarm	Patrol/Test/Inspect	Repair	VI
143564300	P73157	12/22/2014	16:29	12/22/2014	21:30	1	301	301	Overhead equipment	Overhead Transformer	Repair	Replace - Same Size	VI
143564553	Q83171	12/22/2014	18:26	12/23/2014	5:00	12	7608	634	Tree related-tree broken	Pole			VI
143564554	K76541	12/22/2014	18:36	12/22/2014	18:49	21	273	13	Jurisdictional				IV
143564571	R04409	12/22/2014	18:59	12/22/2014	21:02	10	1230	123	Overhead equipment	Fuse	Replace - Same Size		V
143565076	332001	12/22/2014	20:43	12/22/2014	23:30	1	167	167	Underground equipment	Underground Service	Patrol/Test/Inspect	Repair	VI
143565099	T15570	12/22/2014	22:08	12/22/2014	23:45	1	97	97	Overhead equipment				VI
143565101	T15570	12/22/2014	22:18	12/22/2014	23:45	1	87	87	Overhead equipment				VI
143565106	P17109	12/22/2014	22:50	12/23/2014	4:37	1	347	347	Underground equipment	Underground Secondary		Repair	IV
143572841	342003	12/23/2014	3:29	12/23/2014	4:59	1	90	90	Overhead equipment	Overhead Transformer	Switch/Reset		VI
143572844	L24121	12/23/2014	3:41	12/23/2014	7:16	1	215	215	Overhead equipment	Overhead Transformer		Replace - Same Size	III
143572960		12/23/2014	7:26	12/23/2014	9:40	1	134	134	Unknown		Patrol/Test/Inspect		VI
143572980	M41111	12/23/2014	7:32	12/23/2014	8:21	1	49	49	Overhead equipment	Overhead Service	No Work Required		I
143573011	B68002	12/23/2014	7:51	12/23/2014	8:51	1	60	60	Overhead equipment	Jumper	Replace - Same Size		III
143573012	R71286	12/23/2014	7:51	12/23/2014	9:30	1	99	99	Animal related	Fuse	Replace - Same Size		VI
143573015	D96001	12/23/2014	7:53	12/23/2014	9:53	1	120	120	Overhead equipment				I
143573021	R71286	12/23/2014	7:53	12/23/2014	9:30	1	97	97	Animal related	Fuse	Replace - Same Size		VI
143573039	R58951	12/23/2014	8:04	12/23/2014	9:28	9	756	84	Animal related	Transformer Fuse	Repair	Repair	IV
143573088	R94269	12/23/2014	8:22	12/23/2014	10:11	1	109	109	Overhead equipment	Fuse	Replace - Same Size		VI
143573151	D37001	12/23/2014	8:49	12/23/2014	11:00	1	131	131	Overhead equipment	Connector	Patrol/Test/Inspect	Replace - New Size	I
143573213	M81403	12/23/2014	9:13	12/23/2014	11:25	1	132	132	Underground equipment	Underground Service		Repair	V
143573409	N18210	12/23/2014	10:17	12/23/2014	11:10	7	371	53	Unknown	Fuse	Replace - Same Size		III
143573424	L17105	12/23/2014	10:20	12/23/2014	10:46	1	26	26	Animal related	Fuse	Replace - Same Size		III
143573463	310124	12/23/2014	10:30	12/23/2014	11:20	1	50	50	Animal related	Fuse			V

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
143573502	X34532	12/23/2014	10:44	12/23/2014	11:38	2	108	54	Animal related	Transformer Fuse			IV
143573520	N60181	12/23/2014	10:46	12/23/2014	11:32	1	46	46	Animal related	Fuse	Replace - Same Size		I
143573562	K76542	12/23/2014	11:02	12/23/2014	11:40	1	38	38	Jurisdictional	Underground Primary	Repair	No Work Required	IV
143573567	K78351	12/23/2014	11:03	12/23/2014	11:38	1	35	35	Underground equipment	Underground Primary	Repair		IV
143573578	D60001	12/23/2014	11:03	12/23/2014	11:37	39	1326	34	Animal related	Fuse	Replace - Same Size	No Work Required	III
143573600	Q91175	12/23/2014	11:17	12/23/2014	14:05	1	168	168	Overhead equipment	Overhead Transformer	Replace - Same Size	Replace - Same Size	I
143573653	K08909	12/23/2014	11:27	12/23/2014	12:28	1	61	61	Animal related	Fuse	Replace - Same Size	Patrol/Test/Inspect	VI
143573674	L93133	12/23/2014	11:29	12/23/2014	12:36	16	1072	67	Animal related	Fuse	Replace - Same Size		VI
143573671	J87120	12/23/2014	11:31	12/23/2014	13:33	14	1708	122	Overhead equipment	Transformer Fuse	Repair	Repair	VI
143573770	D81001	12/23/2014	11:53	12/23/2014	12:40	14	658	47	Animal related	Fuse	Replace - Same Size		I
143573729	328120	12/23/2014	12:02	12/23/2014	12:55	1	53	53	Public	Overhead Service	Repair		V
143573791	J87120	12/23/2014	12:38	12/23/2014	13:15	11	407	37	Overhead equipment	Fuse			VI
143573809	U97001	12/23/2014	12:41	12/23/2014	13:25	1	44	44	Overhead equipment	Overhead Service	Repair		II
143573917	D16001	12/23/2014	13:24	12/23/2014	14:24	15	900	60	Underground equipment	Underground Primary		Repair	I
143573927	S61530	12/23/2014	13:26	12/23/2014	14:42	1	76	76	Underground equipment	Underground Service			VI
143573991	343005	12/23/2014	13:50	12/23/2014	16:14	1	144	144	Overhead equipment	Other	Patrol/Test/Inspect	Replace - Same Size	VI
143574013	J87120	12/23/2014	13:53	12/23/2014	16:03	36	4680	130	Animal related	Fuse	Repair		VI
143574020	U92593	12/23/2014	13:58	12/23/2014	15:29	1	91	91	Animal related	Transformer Fuse			II
143574284	J61115	12/23/2014	15:18	12/23/2014	18:04	893	148238	166	Overhead equipment	Regulator			III
143574323	J18267	12/23/2014	16:04	12/23/2014	18:00	1	116	116	Underground equipment	Underground Service	Patrol/Test/Inspect		VI
143574331	J83139	12/23/2014	16:07	12/23/2014	17:32	1	85	85	Tree related-tree broken	Overhead Service	Repair		VI
143574344	V41533	12/23/2014	16:20	12/23/2014	18:14	1	114	114	Overhead equipment	Overhead Service	Repair	Repair	II
143574397	D35001	12/23/2014	16:51	12/23/2014	22:45	1	354	354	Overhead equipment	Overhead Primary	Repair		I
143574400	D35001	12/23/2014	16:53	12/23/2014	20:09	1	196	196	Overhead equipment	Overhead Service	Repair		I
143574409	R39934	12/23/2014	16:54	12/23/2014	18:08	1	74	74	Animal related	Fuse	Replace - Same Size		VI
143574469	Y63539	12/23/2014	17:35	12/23/2014	18:35	1	60	60	Animal related	Transformer Fuse			IV
143574480	P69173	12/23/2014	17:49	12/23/2014	19:10	3	243	81	Overhead equipment	Fuse	Replace - Same Size		III
143574833	B27009	12/23/2014	20:55	12/23/2014	22:23	1	88	88	Overhead equipment	Disconnect Switch	Replace - Same Size		I
143574856	B08004	12/23/2014	21:55	12/24/2014	3:05	1	310	310	Underground equipment	Underground Primary	Patrol/Test/Inspect	Patrol/Test/Inspect	I
143574872	P44324	12/23/2014	22:43	12/23/2014	23:44	1	61	61	Overhead equipment	Transformer Fuse	Replace - Same Size	Replace - Same Size	I
143575527	S31529	12/23/2014	23:34	12/24/2014	4:08	3	822	274	Overhead equipment	Overhead Service	Patrol/Test/Inspect	Repair	VI
143580021	R34920	12/24/2014	2:00	12/24/2014	3:24	1	84	84	Animal related	Fuse	Replace - Same Size		VI
143580176	K27153	12/24/2014	7:13	12/24/2014	10:38	384	78720	205	Overhead equipment	Overhead Primary	Repair		VI
143580120	L71170	12/24/2014	7:59	12/24/2014	10:20	1	141	141	Overhead equipment				IV
143580119	Q74150	12/24/2014	7:59	12/24/2014	9:50	1	111	111	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
143580137	V77543	12/24/2014	8:25	12/24/2014	10:59	1	154	154	Underground equipment	Underground Service		Repair	II
143580173	X49569	12/24/2014	9:34	12/24/2014	13:15	1	221	221	Overhead equipment	Overhead Service			IV
143580181	J86108	12/24/2014	9:46	12/24/2014	10:51	1	65	65	Overhead equipment	Fuse	Repair	Repair	VI
143580192	H22346	12/24/2014	10:00	12/24/2014	11:22	1	82	82	Animal related	Transformer Fuse	Replace - Same Size		V
143580227	Q74150	12/24/2014	10:28	12/24/2014	11:55	6	522	87	Overhead equipment				IV
143580236	M20221	12/24/2014	11:12	12/24/2014	12:13	1	61	61	Overhead equipment	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
143580250	M18131	12/24/2014	11:29	12/24/2014	12:13	1	44	44	Animal related	Fuse	Replace - Same Size		III
143580255	M26164	12/24/2014	11:43	12/24/2014	12:44	1	61	61	Animal related	Fuse	Replace - Same Size		III
143580300	D93002	12/24/2014	13:14	12/24/2014	14:30	1	76	76	Animal related	Fuse	Replace - Same Size	Repair	IV
143580338	U33586	12/24/2014	13:22	12/24/2014	16:30	3	564	188	Animal related	Fuse	Replace - Same Size		II
143580307	R48165	12/24/2014	13:39	12/24/2014	14:21	10	420	42	Animal related	Fuse			IV
143580310	U11531	12/24/2014	13:43	12/24/2014	15:20	9	873	97	Animal related	Fuse	Replace - Same Size		II
143580375	HA5430	12/24/2014	13:52	12/24/2014	16:51	20	3580	179	Underground equipment	Underground Primary			V
143580328	L81141	12/24/2014	14:27	12/24/2014	17:55	2	416	208	Tree related-tree contact	Overhead Service	Repair		IV
143580339	M37191	12/24/2014	15:02	12/24/2014	19:00	1	238	238	Public	Pole	Repair	Replace - Same Size	I
143580432	J89125	12/24/2014	21:35	12/24/2014	22:10	13	455	35	Overhead equipment				VI
143590008	X88507	12/25/2014	1:41	12/25/2014	4:00	1	139	139	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
143590078	T16526	12/25/2014	8:23	12/25/2014	9:36	1	73	73	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	VI
143590079	M18131	12/25/2014	8:26	12/25/2014	9:42	1	76	76	Overhead equipment	Fuse	Repair		III
143590093	T06504	12/25/2014	9:11	12/25/2014	10:30	1	79	79	Animal related	Transformer Fuse			VI
143590097	S62522	12/25/2014	9:11	12/25/2014	9:59	47	2256	48	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	VI

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
143590103	P69174	12/25/2014	9:37	12/25/2014	10:19	1	42	42	Overhead equipment	Fuse	Replace - Same Size		III
143590106	U73583	12/25/2014	9:41	12/25/2014	11:00	1	79	79	Animal related	Transformer Fuse	Replace - Same Size		II
143590129	J56341	12/25/2014	11:32	12/25/2014	12:52	1	80	80	Animal related	Transformer Fuse	Repair	Repair	III
143590168	B62003	12/25/2014	13:16	12/25/2014	18:06	11	3190	290	Animal related	Pole			I
143590144	B62003	12/25/2014	13:16	12/25/2014	14:27	41	2911	71	Animal related	Pole	Switch/Reset		I
143590157	M31201	12/25/2014	13:32	12/25/2014	14:43	235	16685	71	Animal related	Overhead Transformer	Cut in Clear		I
143590158	N95823	12/25/2014	13:53	12/25/2014	14:52	1	59	59	Animal related	Transformer Fuse	Replace - Same Size		V
143590204	X92507	12/25/2014	17:05	12/25/2014	18:35	1	90	90	Overhead equipment	Meter	Replace - Same Size	Replace - Same Size	IV
143590233	L35139	12/25/2014	19:09	12/25/2014	21:16	19	2413	127	Overhead equipment	Fuse	Replace - Same Size		III
143590267	D31017	12/25/2014	23:31	12/26/2014	4:33	1	302	302	Underground equipment	Underground Primary	Replace - Same Size		III
143600001	K91115	12/26/2014	0:01	12/26/2014	5:38	1	337	337	Public	Pole	Replace - Same Size	Replace - Same Size	III
143602071	D93001	12/26/2014	3:46	12/26/2014	6:10	21	3024	144	Overhead equipment	Recloser	Repair		IV
143602108	N60181	12/26/2014	7:21	12/26/2014	8:16	1	55	55	Animal related	Transformer Fuse	Replace - Same Size		I
143602317	B45005	12/26/2014	7:27	12/26/2014	9:02	1378	130910	95	Public		No Work Required		I
143602160	B45005	12/26/2014	7:31	12/26/2014	14:08	243	96471	397	Public	Pole	Replace - Same Size	Repair	I
143602162	U51539	12/26/2014	7:36	12/26/2014	8:44	1	68	68	Tree related-tree contact	Transformer Fuse	Repair	Replace - Same Size	II
143602209	B00004	12/26/2014	8:04	12/26/2014	9:52	1	108	108	Overhead equipment	Other	Repair	Repair	I
143602294	S66595	12/26/2014	8:45	12/26/2014	9:37	1	52	52	Animal related	Fuse	Replace - Same Size	Patrol/Test/Inspect	VI
143602329	P25150	12/26/2014	9:04	12/26/2014	10:04	1	60	60	Animal related	Fuse	Replace - Same Size		III
143602347	Q82906	12/26/2014	9:08	12/26/2014	9:44	1	36	36	Animal related	Transformer Fuse	Repair	No Work Required	VI
143602404	M19222	12/26/2014	9:30	12/26/2014	10:58	1	88	88	Overhead equipment	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
143602451	T06539	12/26/2014	9:48	12/26/2014	10:28	1	40	40	Overhead equipment	Overhead Service	Patrol/Test/Inspect	Repair	VI
143602510	A36002	12/26/2014	9:58	12/26/2014	10:55	18	1026	57	Animal related				I
143602471	A36002	12/26/2014	9:58	12/26/2014	10:55	34	1938	57	Animal related	Fuse	Replace - Same Size		I
143602617	U99593	12/26/2014	10:52	12/26/2014	12:00	1	68	68	Animal related	Fuse	Replace - Same Size		II
143602651	R93701	12/26/2014	11:13	12/26/2014	12:07	1	54	54	Animal related	Recloser	Replace - Same Size		V
143602666	T22507	12/26/2014	11:17	12/26/2014	12:20	3	189	63	Animal related	Transformer Fuse	Replace - Same Size		VI
143602735	C00001	12/26/2014	11:34	12/26/2014	14:36	12	2184	182	Overhead equipment	Other	Repair	Repair	I
143602781	C36001	12/26/2014	12:02	12/26/2014	12:39	390	14430	37	Overhead equipment	Overhead Primary	Replace - Same Size		III
143602839	C36001	12/26/2014	12:05	12/26/2014	14:13	98	12544	128	Overhead equipment	Overhead Primary	Replace - Same Size		III
143602933	R07382	12/26/2014	12:56	12/26/2014	13:40	38	1672	44	Animal related	Fuse	Replace - Same Size	Repair	I
143602926	D87001	12/26/2014	13:17	12/26/2014	15:00	5	515	103	Animal related	Fuse	Replace - Same Size		I
143602967	J63171	12/26/2014	13:22	12/26/2014	17:10	7	1596	228	Underground equipment	Underground Primary	Repair	Repair	III
143602996	R68903	12/26/2014	13:23	12/26/2014	14:22	25	1475	59	Animal related	Fuse			I
143603035	R68903	12/26/2014	14:05	12/26/2014	14:32	1	27	27	Unknown		No Work Required	No Work Required	I
143603053	D36001	12/26/2014	14:12	12/26/2014	18:35	1	263	263	Overhead equipment	Overhead Service	Repair		I
143603143	M26161	12/26/2014	14:22	12/26/2014	15:22	492	29520	60	Overhead equipment	Recloser	Switch/Reset		III
143603105	X22001	12/26/2014	14:33	12/26/2014	17:45	2	384	192	Public	Pole	Replace - Same Size	Replace - Same Size	IV
143603153	T46001	12/26/2014	14:56	12/26/2014	16:30	1	94	94	Overhead equipment	Overhead Service	Repair		VI
143603203	D69009	12/26/2014	15:23	12/26/2014	17:03	1	100	100	Underground equipment	Underground Service		Repair	I
143603240	Q32170	12/26/2014	16:03	12/26/2014	19:29	1	206	206	Overhead equipment	Fuse	Replace - Same Size		I
143603306	Q93522	12/26/2014	17:20	12/26/2014	18:35	1	75	75	Animal related	Transformer Fuse	Repair		I
143603334	N67309	12/26/2014	18:07	12/26/2014	18:54	1	47	47	Overhead equipment	Transformer Fuse	Replace - Same Size	Replace - Same Size	I
143603502	D87001	12/26/2014	19:21	12/26/2014	20:43	1	82	82	Overhead equipment	Connector			I
143603846	H10843	12/26/2014	19:33	12/26/2014	21:00	1	87	87	Animal related	Transformer Fuse	Replace - Same Size		V
143603851	J74125	12/26/2014	19:51	12/26/2014	23:52	1	241	241	Overhead equipment	Overhead Transformer	Replace - Same Size	Replace - Same Size	VI
143610015	Y35513	12/27/2014	2:07	12/27/2014	3:07	1	60	60	Overhead equipment	Overhead Service			IV
143610032	D53002	12/27/2014	6:55	12/27/2014	12:46	1	351	351	Underground equipment	Underground Primary	Patrol/Test/Inspect	Replace - Urgent	I
143610067	J87150	12/27/2014	7:11	12/27/2014	10:37	405	83430	206	Overhead equipment				VI
143610082	S25552	12/27/2014	7:57	12/27/2014	9:19	1	82	82	Animal related	Fuse	Patrol/Test/Inspect	Repair	VI
143610088	HD0574	12/27/2014	8:15	12/27/2014	8:55	1	40	40	Animal related	Transformer Fuse			VI
143610112	K46389	12/27/2014	8:57	12/27/2014	9:37	1	40	40	Overhead equipment	Fuse	Replace - Same Size		V
143610117	K67912	12/27/2014	9:03	12/27/2014	10:36	1	93	93	Animal related	Fuse	Replace - Same Size		VI
143610122	Q83171	12/27/2014	9:16	12/27/2014	10:45	6	534	89	Overhead equipment	Transformer Fuse	Replace - Same Size		VI
143610124	Y37592	12/27/2014	9:20	12/27/2014	10:10	5	250	50	Overhead equipment	Fuse			IV
143610169	B76001	12/27/2014	10:13	12/27/2014	16:19	1	366	366	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
143610175	Q95248	12/27/2014	10:23	12/27/2014	11:31	1	68	68	Animal related	Fuse	Replace - Same Size		VI
143610190	C52002	12/27/2014	10:53	12/27/2014	12:23	1	90	90	Tree related-tree broken	Overhead Service	Repair	No Work Required	III
143610259	C30001	12/27/2014	12:21	12/27/2014	17:48	18	5886	327	Overhead equipment	Pole	Replace - Same Size	Patrol/Test/Inspect	III
143610257	A49003	12/27/2014	12:33	12/27/2014	19:47	1	434	434	Underground equipment	Underground Secondary	Repair	Replace - Same Size	I
143610272	B57001	12/27/2014	12:50	12/27/2014	14:08	1	78	78	Overhead equipment	Overhead Service	Repair	Replace - Same Size	I
143610275	R42914	12/27/2014	12:53	12/27/2014	17:24	1	271	271	Overhead equipment	Overhead Service	Repair	Repair	VI
143610289	X29002	12/27/2014	13:33	12/27/2014	17:00	1	207	207	Underground equipment	Underground Service	Patrol/Test/Inspect	Patrol/Test/Inspect	IV
143610302	P42229	12/27/2014	13:48	12/27/2014	14:49	1	61	61	Tree related-tree contact	Fuse	Replace - Same Size		VI
143610318	Q67938	12/27/2014	14:19	12/27/2014	16:10	1	111	111	Tree related-tree broken	Fuse	Replace - Same Size	Replace - Same Size	VI
143610317	Q67938	12/27/2014	14:22	12/27/2014	16:02	1	100	100	Tree related-tree broken	Fuse	Replace - Same Size	Replace - Same Size	VI
143610329	S09520	12/27/2014	14:51	12/27/2014	15:00	1	9	9	Overhead equipment	Fuse		Replace - Same Size	VI
143610344	Z57516	12/27/2014	15:43	12/27/2014	18:00	1	137	137	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
143610449	Y79500	12/27/2014	19:00	12/27/2014	23:24	1	264	264	Underground equipment	Overhead Service			IV
143610471	C37001	12/27/2014	20:19	12/27/2014	21:44	13	1105	85	Overhead equipment	Fuse	Replace - Same Size	No Work Required	III
143610487	M09175	12/27/2014	22:02	12/28/2014	0:56	1	174	174	Overhead equipment	Overhead Transformer	Replace - Same Size	Repair	VI
143620024	B77003	12/28/2014	3:48	12/28/2014	7:20	10	2120	212	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect		I
143620036	X86543	12/28/2014	5:44	12/28/2014	7:20	1	96	96	Animal related	Transformer Fuse	Replace - Same Size		IV
143620042	B93003	12/28/2014	6:43	12/28/2014	9:20	1	157	157	Overhead equipment	Connector	Replace - Same Size		I
143620064	J99127	12/28/2014	7:34	12/28/2014	9:50	76	10336	136	Overhead equipment	Fuse	Replace - Same Size		VI
143620068	X60598	12/28/2014	8:21	12/28/2014	10:40	1	139	139	Overhead equipment	Overhead Secondary	Repair		IV
143620070	B08004	12/28/2014	8:26	12/28/2014	9:24	1	58	58	Overhead equipment	Connector	Replace - Same Size		I
143620084	R49261	12/28/2014	8:51	12/28/2014	12:33	62	13764	222	Overhead equipment	Overhead Primary	Patrol/Test/Inspect	Repair	VI
143620098	R60552	12/28/2014	9:18	12/28/2014	13:30	1	252	252	Underground equipment				IV
143620100	Q80353	12/28/2014	9:23	12/28/2014	11:20	1	117	117	Animal related	Transformer Fuse	Replace - Same Size		V
143620113	B57001	12/28/2014	9:36	12/28/2014	11:45	1	129	129	Overhead equipment	Overhead Service	Replace - Same Size		I
143620153	Y50002	12/28/2014	11:52	12/28/2014	12:25	1	33	33	Overhead equipment	Overhead Secondary	Repair		IV
143620432	Y04504	12/28/2014	13:00	12/28/2014	14:45	18	1890	105	Overhead equipment	Fuse	Replace - Same Size		IV
143620447	Y07576	12/28/2014	13:29	12/28/2014	15:39	32	4160	130	Overhead equipment	Lightning Arrestor	Replace - Same Size		IV
143620463	J56341	12/28/2014	13:37	12/28/2014	15:10	10	930	93	Animal related	Underground Primary			III
143620453	J56341	12/28/2014	13:39	12/28/2014	15:11	1	92	92	Animal related	Fuse			III
143620478	L59929	12/28/2014	14:12	12/28/2014	15:56	4	416	104	Animal related	Fuse	Replace - Same Size		VI
143620500	S25552	12/28/2014	14:48	12/28/2014	16:10	1	82	82	Animal related	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
143620546	M09143	12/28/2014	16:31	12/28/2014	18:08	1	97	97	Animal related	Fuse	Replace - Same Size	No Work Required	VI
143620554	P26283	12/28/2014	16:52	12/28/2014	19:55	56	10248	183	Overhead equipment	Disconnect Switch	Replace - Same Size		I
143620590	V40549	12/28/2014	18:29	12/28/2014	22:08	1	219	219	Underground equipment	Underground Service	Repair	Repair	II
143620619	M49410	12/28/2014	19:33	12/28/2014	21:45	71	9372	132	Overhead equipment	Fuse	Replace - Same Size		V
143620622	M49410	12/28/2014	19:44	12/28/2014	21:51	1	127	127	Overhead equipment	Fuse	Replace - Same Size		V
143630099	V77543	12/28/2014	22:46	12/29/2014	2:00	8	1552	194	Overhead equipment	Overhead Secondary	Repair		II
143632423	R60552	12/29/2014	4:07	12/29/2014	8:05	1	238	238	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	IV
143632821	S21529	12/29/2014	7:14	12/29/2014	13:10	7	2492	356	Underground equipment	Underground Primary			VI
143632528	X02546	12/29/2014	7:21	12/29/2014	7:59	1	38	38	Overhead equipment	Jumper	Repair		IV
143632555	B21002	12/29/2014	7:42	12/29/2014	9:00	1	78	78	Overhead equipment	Fuse	Repair	Replace - Same Size	I
143632641	R73840	12/29/2014	8:15	12/29/2014	9:28	1	73	73	Animal related	Transformer Fuse	Replace - Same Size		V
143632849	A81004	12/29/2014	9:05	12/29/2014	11:45	1	160	160	Underground equipment	Underground Transformer	Patrol/Test/Inspect	Replace - Same Size	I
143632875	S19553	12/29/2014	9:13	12/29/2014	10:10	7	399	57	Animal related				VI
143632892	R04412	12/29/2014	9:18	12/29/2014	10:34	1	76	76	Underground equipment	Underground Service	Cut in Clear	Repair	V
143632906	R65451	12/29/2014	9:23	12/29/2014	10:08	1	45	45	Overhead equipment	Fuse			IV
143632911	K69117	12/29/2014	9:24	12/29/2014	12:30	1	186	186	Underground equipment	Underground Secondary	Patrol/Test/Inspect	Repair	IV
143632918	Q32171	12/29/2014	9:30	12/29/2014	10:40	1	70	70	Animal related	Transformer Fuse	Replace - Same Size		I
143633036	T11509	12/29/2014	9:57	12/29/2014	11:50	1	113	113	Overhead equipment	Transformer Fuse			VI
143633052	329149	12/29/2014	10:02	12/29/2014	11:22	1	80	80	Overhead equipment	Fuse	Replace - Same Size	No Work Required	V
143633100	U57561	12/29/2014	10:16	12/29/2014	11:00	1	44	44	Animal related	Transformer Fuse		Replace - Same Size	II
143633124	344003	12/29/2014	10:21	12/29/2014	12:07	1	106	106	Overhead equipment	Disconnect Switch	Patrol/Test/Inspect	Replace - Same Size	VI
143633191	R41132	12/29/2014	10:38	12/29/2014	11:48	8	560	70	Animal related	Fuse	Replace - Same Size	Replace - Same Size	VI
143633304		12/29/2014	11:10	12/29/2014	18:00	3	1230	410	Overhead equipment	Other			VI
143633450	Q74150	12/29/2014	11:27	12/29/2014	12:14	17	799	47	Animal related	Fuse	Replace - Same Size		IV

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
143633443	R58951	12/29/2014	11:49	12/29/2014	12:33	1	44	44	Overhead equipment	Fuse			IV
143633462	N95823	12/29/2014	11:55	12/29/2014	12:53	1	58	58	Jurisdictional	Meter	Advise Customer		V
143633541	S49550	12/29/2014	12:20	12/29/2014	12:55	1	35	35	Animal related	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
143633580	J74125	12/29/2014	12:32	12/29/2014	13:45	1	73	73	Tree related-tree broken	Overhead Service	Repair	Replace - Same Size	VI
143633682	303001	12/29/2014	13:04	12/29/2014	14:40	13	1248	96	Tree related-tree contact	Tree			VI
143633927	X19561	12/29/2014	13:57	12/29/2014	16:10	864	114912	133	Overhead equipment	Disconnect Switch	Replace - Same Size	Replace - Same Size	IV
143634151	Q15844	12/29/2014	15:23	12/29/2014	16:39	1	76	76	Overhead equipment	Meter	Replace - Same Size		V
143634162	P07179	12/29/2014	15:28	12/29/2014	16:05	1	37	37	Animal related	Transformer Fuse	Replace - Same Size		I
143634263	X09534	12/29/2014	16:18	12/29/2014	17:54	1	96	96	Animal related	Fuse	Replace - Same Size		IV
143634279	C52002	12/29/2014	16:27	12/29/2014	17:29	1	62	62	Overhead equipment	Connector	Repair	No Work Required	III
143634286	HD6371	12/29/2014	16:32	12/29/2014	17:20	1	48	48	Animal related	Transformer Fuse	Replace - Same Size	No Work Required	IV
143634317	X09557	12/29/2014	16:57	12/29/2014	18:28	8	728	91	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
143634425	K57211	12/29/2014	17:12	12/29/2014	18:36	1	84	84	Animal related	Transformer Fuse	Replace - Same Size		VI
143634423	HB6283	12/29/2014	17:12	12/29/2014	20:21	1	189	189	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	VI
143634514	B65003	12/29/2014	17:32	12/29/2014	19:03	1	91	91	Overhead equipment	Connector	Tie/Tighten		I
143634535	A26001	12/29/2014	17:44	12/29/2014	19:33	1	109	109	Overhead equipment	Connector	Replace - Same Size		I
143634548	K25166	12/29/2014	17:53	12/29/2014	19:25	1	92	92	Overhead equipment	Overhead Secondary	Repair		VI
143643153	X68506	12/30/2014	7:18	12/30/2014	8:20	1	62	62	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
143643159	S49550	12/30/2014	7:22	12/30/2014	8:05	3	129	43	Overhead equipment	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
143643191	C50001	12/30/2014	7:41	12/30/2014	9:50	1	129	129	Overhead equipment	Other	Repair	Patrol/Test/Inspect	III
143643195	N48110	12/30/2014	7:42	12/30/2014	13:20	1	338	338	Overhead equipment	Overhead Transformer	Replace - Same Size	Repair	II
143643290	K48381	12/30/2014	8:27	12/30/2014	9:37	1	70	70	Overhead equipment	Connector	Repair		V
143643299	J18267	12/30/2014	8:31	12/30/2014	9:25	1	54	54	Overhead equipment	Overhead Service	Tie/Tighten		VI
143643368	M45212	12/30/2014	8:56	12/30/2014	9:23	1	27	27	Overhead equipment	Transformer Fuse	Repair		IV
143643442	X92508	12/30/2014	9:19	12/30/2014	10:15	1	56	56	Overhead equipment	Transformer Fuse	Repair	Replace - Same Size	IV
143643863	Y12559	12/30/2014	11:23	12/30/2014	12:00	1	37	37	Overhead equipment	Transformer Fuse	Repair	Replace - Same Size	IV
143643911	B21002	12/30/2014	11:39	12/30/2014	13:20	1	101	101	Overhead equipment	Connector	Repair		I
143643977	U35554	12/30/2014	11:57	12/30/2014	12:11	464	6496	14	Underground equipment	Underground Primary	Repair		II
143644039	U35554	12/30/2014	11:57	12/30/2014	15:14	14	2758	197	Underground equipment	Underground Primary	Repair		II
143644341	H01190	12/30/2014	13:04	12/30/2014	14:47	120	12360	103	Unknown	Recloser			III
143644371	U09557	12/30/2014	13:50	12/30/2014	15:00	4	280	70	Animal related	Fuse	Replace - Same Size		II
143644531		12/30/2014	14:47	12/30/2014	18:20	1	213	213	Public	Underground Service	Patrol/Test/Inspect		V
143644599	Y97513	12/30/2014	15:07	12/30/2014	17:40	9	1377	153	Underground equipment	Underground Primary	Switch/Reset	Repair	IV
143644622	Y97513	12/30/2014	15:19	12/30/2014	17:18	1	119	119	Underground equipment	Underground Primary	Patrol/Test/Inspect	Switch/Reset	IV
143644655	M31202	12/30/2014	15:38	12/30/2014	18:30	22	3784	172	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	I
143644669	P54827	12/30/2014	15:50	12/30/2014	20:05	1	255	255	Overhead equipment	Overhead Service	Repair		V
143644746	J80807	12/30/2014	16:55	12/30/2014	17:57	1	62	62	Overhead equipment	Connector	Repair	Repair	V
143644803	P18102	12/30/2014	17:37	12/30/2014	19:11	1	94	94	Animal related	Overhead Service			IV
143644828	D93001	12/30/2014	17:58	12/30/2014	19:06	1	68	68	Overhead equipment	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	IV
143644830	R33126	12/30/2014	18:00	12/30/2014	19:15	1	75	75	Unknown	Fuse	Repair	Replace - Same Size	I
143645170	R49275	12/30/2014	19:30	12/30/2014	22:26	1	176	176	Overhead equipment	Regulator	Patrol/Test/Inspect	Replace - Same Size	VI
143645191	A97001	12/30/2014	20:38	12/30/2014	21:40	1	62	62	Overhead equipment	Connector	Replace - Same Size		I
143645309	Q75146	12/30/2014	21:12	12/31/2014	3:20	47	17296	368	Overhead equipment				VI
143645278	Q75146	12/30/2014	21:17	12/30/2014	23:50	48	7344	153	Overhead equipment	Recloser	Repair		VI
143645256	D90004	12/30/2014	21:48	12/30/2014	23:45	129	15093	117	Overhead equipment	Overhead Primary	Repair	Patrol/Test/Inspect	III
143645265	B44001	12/30/2014	22:21	12/30/2014	23:35	1	74	74	Overhead equipment	Connector	Replace - Same Size		I
143645282	Q18244	12/30/2014	22:43	12/31/2014	5:20	1	397	397	Underground equipment	Underground Secondary		Repair	VI
143650066	H10843	12/31/2014	1:04	12/31/2014	2:25	1	81	81	Overhead equipment	Jumper	Repair		V
143650240	R60552	12/31/2014	1:41	12/31/2014	6:10	913	245597	269	Overhead equipment	Overhead Primary	Repair		IV
143650197	R60552	12/31/2014	1:42	12/31/2014	3:10	1047	92136	88	Overhead equipment	Overhead Primary	Switch/Reset		IV
143651914	X02547	12/31/2014	4:10	12/31/2014	5:20	7	490	70	Overhead equipment	Overhead Primary			IV
143652033	R49275	12/31/2014	7:42	12/31/2014	12:15	1	273	273	Overhead equipment	Regulator	Patrol/Test/Inspect	Repair	VI
143652029	B28004	12/31/2014	7:43	12/31/2014	10:05	1	142	142	Overhead equipment	Overhead Service	Patrol/Test/Inspect		I
143652260	M21133	12/31/2014	9:29	12/31/2014	10:01	1	32	32	Overhead equipment	Fuse	Repair	Repair	VI
143652310	K76542	12/31/2014	9:53	12/31/2014	14:05	1	252	252	Underground equipment	Underground Service	Repair		IV
143652309	D90003	12/31/2014	9:54	12/31/2014	10:53	1	59	59	Overhead equipment	Overhead Service	Repair	Patrol/Test/Inspect	III

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
143652387	X57566	12/31/2014	10:26	12/31/2014	11:15	1	49	49	Overhead equipment	Connector	Repair		IV
143652439	B68004	12/31/2014	10:43	12/31/2014	12:19	1	96	96	Overhead equipment	Overhead Secondary	Repair	Patrol/Test/Inspect	III
143652478	S28552	12/31/2014	11:00	12/31/2014	11:45	1	45	45	Animal related	Fuse	Replace - Same Size		VI
143652514	L73160	12/31/2014	11:15	12/31/2014	12:18	1	63	63	Overhead equipment	Overhead Service			IV
143652606	A81001	12/31/2014	11:48	12/31/2014	12:53	1	65	65	Overhead equipment	Overhead Service	Repair		I
143652648	A81001	12/31/2014	12:06	12/31/2014	12:54	1	48	48	Overhead equipment	Overhead Service	Repair		I
143652677	B84002	12/31/2014	12:16	12/31/2014	14:50	1	154	154	Overhead equipment	Overhead Service	Repair		I
143652723	M45211	12/31/2014	12:36	12/31/2014	12:57	1	21	21	Animal related	Fuse	Repair		IV
143653273	Q09377	12/31/2014	14:08	12/31/2014	15:12	4982	318848	64	Substation equipment	Substation Misc.	Cut in Clear		III
143653288	Q09370	12/31/2014	14:08	12/31/2014	15:13	3628	235820	65	Substation equipment	Substation Misc.	Cut in Clear		III
143652893	Y04508	12/31/2014	14:08	12/31/2014	16:37	2	298	149	Overhead equipment	Disconnect Switch	Replace - Same Size		IV
143653000		12/31/2014	14:12	12/31/2014	15:14	6	372	62	Substation equipment	Substation Misc.	Patrol/Test/Inspect		III
143653150	L17101	12/31/2014	14:14	12/31/2014	15:14	11	660	60	Substation equipment	Substation Misc.	Patrol/Test/Inspect		III
143653234	L00133	12/31/2014	14:18	12/31/2014	15:14	2	112	56	Substation equipment	Substation Misc.	Patrol/Test/Inspect		III
143653249	L23145	12/31/2014	14:19	12/31/2014	15:14	3	165	55	Substation equipment	Substation Misc.	Patrol/Test/Inspect		III
143653255	K95202	12/31/2014	14:21	12/31/2014	15:14	1	53	53	Substation equipment	Substation Misc.	Patrol/Test/Inspect		III
143653295	K89141	12/31/2014	14:28	12/31/2014	15:14	1	46	46	Substation equipment	Substation Misc.	Patrol/Test/Inspect		III
143653375	P47123	12/31/2014	15:02	12/31/2014	16:52	16	1760	110	Overhead equipment	Fuse	No Work Required		I
143653369	K08909	12/31/2014	15:15	12/31/2014	16:45	1	90	90	Overhead equipment	Fuse	Replace - Same Size		VI
143653443	M45211	12/31/2014	15:53	12/31/2014	16:58	2	130	65	Animal related	Transformer Fuse	Replace - Same Size		IV
143653450	L12125	12/31/2014	16:16	12/31/2014	16:22	1	6	6	Substation equipment	Substation Misc.	Cut in Clear		III
143653460	H11340	12/31/2014	16:25	12/31/2014	18:40	1	135	135	Overhead equipment	Connector	Repair		V
143653464	L12125	12/31/2014	16:28	12/31/2014	16:38	1	10	10	Substation equipment	Substation Misc.	Cut in Clear		III
143653482	S53543	12/31/2014	17:03	12/31/2014	18:02	1	59	59	Overhead equipment				VI
143653614	M05360	12/31/2014	18:00	12/31/2014	23:18	1	318	318	Other	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	V
150010004	P69173	12/31/2014	23:48	01/01/2015	1:43	46	5290	115	Overhead equipment	Jumper	Repair		III