Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
150010032	303001	01/01/2015	0:12	01/01/2015	4:45	32	8736	272	Overhead equipment	Overhead Secondary	Patrol/Test/Inspect	Repair	VI
150010023	351002	01/01/2015	0:45	01/01/2015	5:46	16	4816	300	Overhead equipment	Overhead Primary	Patrol/Test/Inspect	Repair	VI
150010024	M61302	01/01/2015	0:56	01/01/2015	3:22	1	146	145	Overhead equipment	Overhead Service	Repair		V
150010036	L74193	01/01/2015	1:57	01/01/2015	5:20	1	203	202	Public	Pole			IV
150010046	L74193	01/01/2015	2:02	01/01/2015	5:00	21	3738	178	Public	Overhead Primary			IV
150010356	A56015	01/01/2015	6:50	01/01/2015	8:00	1	70	70	Unknown	Overhead Service	Repair		I
150010380	T17581	01/01/2015	7:52	01/01/2015	8:58	6	396	66	Animal related	Disconnect Switch	Repair	Repair	VI
150010383	310124	01/01/2015	8:46	01/01/2015	9:22	1	36	36	Overhead equipment	Fuse	Replace - Same Size		V
150010394	D61001	01/01/2015	9:16	01/01/2015	14:43	1	327	326	Underground equipment	Underground Primary	Repair	Patrol/Test/Inspect	III
150010432	Y06546	01/01/2015	10:30	01/01/2015	12:15	4	420	104	Overhead equipment	Disconnect Switch	Replace - Same Size		IV
150010434	X78536	01/01/2015	10:39	01/01/2015	11:20	1	41	40	Overhead equipment	Overhead Service			IV
150010437	302002	01/01/2015	10:46	01/01/2015	11:35	5	245	49	Overhead equipment	Overhead Service	Repair		VI
150010442	B68002	01/01/2015	10:53	01/01/2015	12:00	1	67	66	Animal related	Other	Replace - Same Size	Patrol/Test/Inspect	III
150010454	J87120	01/01/2015	11:14	01/01/2015	11:52	1	38	37	Overhead equipment	Transformer Fuse	Repair	Repair	VI
150010461	J87120	01/01/2015	11:33	01/01/2015	12:09	1	36	36	Overhead equipment				VI
150543365	R06209	01/01/2015	11:53	01/01/2015	15:50	88	20856	236	Public				II
150544193	R06209	01/01/2015	11:53	01/01/2015	18:50	2	834	416	Public				II
150010480	R06209	01/01/2015	11:53	01/01/2015	13:50	176	20592	117	Public	Pole	Replace - New Size	Repair	II
150010508	X35501	01/01/2015	12:41	01/01/2015	13:35	4	216	53	Animal related	Transformer Fuse	Replace - Same Size		IV
150010514	H07106	01/01/2015	12:52	01/01/2015	19:04	1	372	371	Underground equipment	Underground Service	Patrol/Test/Inspect	Repair	IV
150010543	V61563	01/01/2015	14:16	01/01/2015	16:11	4	460	114	Animal related	Overhead Service	Advise Customer		II
150010567	P62138	01/01/2015	14:41	01/01/2015	16:04	1	83	82	Other	Overhead Service	Repair	Repair	VI
150010571	J80807	01/01/2015	14:46	01/01/2015	16:04	1	78	78	Animal related	Overhead Transformer	Repair	Repair	V
150010647	H14342	01/01/2015	16:32	01/01/2015	17:00	1	28	28	Animal related	Fuse	Replace - Same Size		V
150010658	R06209	01/01/2015	16:51	01/01/2015	18:50	240	28560	119	Public	Pole	Replace - Same Size		II
150010686	M25144	01/01/2015	18:04	01/01/2015	19:30	1	86	85	Overhead equipment	Jumper	Replace - Same Size		IV
150010693	M45212	01/01/2015	18:15	01/01/2015	20:42	1	147	147	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
5000417	L59923	01/01/2015	18:49	01/01/2015	19:47	1	57	57	Overhead equipment	Overhead Service	Repair		VI
150010719	S43502	01/01/2015	19:33	01/01/2015	21:49	6	816	136	Overhead equipment	Disconnect Switch	Repair	Replace - Same Size	VI
150010723	S43511	01/01/2015	19:49	01/01/2015	21:51	1	122	121	Overhead equipment	Transformer Fuse	Replace - Same Size	Replace - Same Size	VI
150010731	S43502	01/01/2015	20:10	01/01/2015	21:50	1	100	99	Overhead equipment	Disconnect Switch	Repair	Replace - Same Size	VI
150010743	R68900	01/01/2015	20:50	01/02/2015	0:29	174	38106	219	Public	Pole	Repair		I
150010755	M45212	01/01/2015	21:07	01/01/2015	22:04	11	627	56	Underground equipment	Underground Primary		Repair	IV
150022846	K69117	01/02/2015	5:18	01/02/2015	9:52	1	274	274	Underground equipment	Underground Secondary	Patrol/Test/Inspect	Repair	IV
150022852	Q32170	01/02/2015	5:56	01/02/2015	8:00	1	124	124	Unknown	Transformer Fuse	Replace - Same Size		I
150022897	B27009	01/02/2015	7:18	01/02/2015	11:25	1	247	246	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
150022901	H22349	01/02/2015	7:23	01/02/2015	9:05	1	102	101	Animal related				V
150022948	H07106	01/02/2015	7:39	01/02/2015	8:31	1	52	52	Animal related	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	IV
150023145	M47802	01/02/2015	8:40	01/02/2015	9:15	1	35	34	Overhead equipment	Overhead Service			V
150023178	K57212	01/02/2015	8:45	01/02/2015	10:18	10	930	92	Overhead equipment	Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
150023182	Q32170	01/02/2015	8:50	01/02/2015	11:22	1	152	152	Animal related	Transformer Fuse	Replace - Same Size	Repair	I
150023579	Q32170	01/02/2015	8:50	01/02/2015	11:24	7	1078	153	Animal related	Fuse	Replace - Same Size	Repair	I
150023215	D67001	01/02/2015	8:50	01/02/2015	9:30	19	760	40	Underground equipment	Underground Primary		Repair	IV
5000421	K67912	01/02/2015	9:07	01/02/2015	10:03	1	55	55	Animal related	Fuse	Replace - Same Size		VI
150023268	K09863	01/02/2015	9:20	01/02/2015	15:00	1	340	339	Underground equipment	Underground Service		Repair	V
150023329	T22508	01/02/2015	9:41	01/02/2015	10:00	1	19	18	Animal related	Transformer Fuse	Replace - Same Size		VI
150023394	L00133	01/02/2015	9:59	01/02/2015	11:30	1	91	90	Animal related	Fuse	Replace - Same Size		III
150023416	U86500	01/02/2015	10:07	01/02/2015	10:56	1	49	49	Overhead equipment	Transformer Fuse	Repair	Repair	II
150023471	D92002	01/02/2015	10:25	01/02/2015	11:23	14	812	58	Animal related	Transformer Fuse	Replace - Same Size		I
150023493	HA5430	01/02/2015	10:25	01/02/2015	12:00	12	1140	94	Public	Underground Primary	Switch/Reset	Repair	V
150023476	Q80352	01/02/2015	10:26	01/02/2015	11:05	4	156	39	Animal related				V
150023753	V40549	01/02/2015	11:47	01/02/2015	14:00	1	133	133	Overhead equipment	Overhead Service	Repair		II
150023796	P49180	01/02/2015	12:04	01/02/2015	13:43	1	99	98	Overhead equipment	Overhead Transformer	Switch/Reset		I
150023805	J88165	01/02/2015	12:09	01/02/2015	13:11	1	62	62	Underground equipment	Overhead Service	Patrol/Test/Inspect	Repair	VI
150023808	S16596	01/02/2015	12:10	01/02/2015	14:00	1	110	110	Animal related	Transformer Fuse	Replace - Same Size	Replace - Same Size	VI
150023823	H01190	01/02/2015	12:15	01/02/2015	16:07	6	1392	232	Overhead equipment	Overhead Transformer	Replace - Same Size		III

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
150023893	R09226	01/02/2015	12:33	01/02/2015	12:55	12	264	21	Animal related	Fuse			III
150023922	N95823	01/02/2015	12:41	01/02/2015	13:30	1	49	49	Animal related	Fuse	Replace - Same Size		V
150024021	X92508	01/02/2015	13:15	01/02/2015	14:00	1	45	45	Overhead equipment	Transformer Fuse	Repair	Replace - Same Size	IV
150024068	R01152	01/02/2015	13:34	01/02/2015	14:50	1	76	75	Overhead equipment	Overhead Transformer			III
150024069	V33006	01/02/2015	13:36	01/02/2015	14:25	1	49	49	Overhead equipment	Jumper	Replace - Same Size		II
150024094	M40131	01/02/2015	13:45	01/02/2015	14:25	1	40	40	Overhead equipment	Transformer Fuse	Replace - Same Size	Patrol/Test/Inspect	I
150024103	R20502	01/02/2015	13:48	01/02/2015	15:20	1	92	92	Overhead equipment	Overhead Service	Repair		IV
150024162	P18104	01/02/2015	14:02	01/02/2015	17:20	1	198	197	Underground equipment	Underground Service	Patrol/Test/Inspect	Repair	IV
150024270	J79304	01/02/2015	14:37	01/02/2015	15:27	1	50	50	Animal related	Transformer Fuse	Replace - Same Size	Replace - Same Size	I
150024269	Q24313	01/02/2015	14:38	01/02/2015	15:41	1	63	62	Animal related	Transformer Fuse	Replace - Same Size		VI
150024356	C40002	01/02/2015	15:07	01/02/2015	15:39	1	32	31	Animal related	Fuse	Replace - Same Size		I
150024449	H07106	01/02/2015	15:27	01/02/2015	16:27	1	60	59	Animal related	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	IV
150024549	A73002	01/02/2015	16:08	01/02/2015	17:00	1	52	52	Overhead equipment	Overhead Service	Repair		I
150024784	N60181	01/02/2015	18:44	01/02/2015	19:41	1	57	57	Overhead equipment	Overhead Service	Repair	Replace - Same Size	I
150025132	U84534	01/02/2015	23:34	01/03/2015	4:27	122	35746	293	Public	Pole			II
150030016	J85161	01/03/2015	1:10	01/03/2015	2:41	1	91	91	Public	Fuse	Replace - Same Size		VI
150030046	U13551	01/03/2015	3:11	01/03/2015	6:45	15	3210	213	Overhead equipment	Disconnect Switch	Replace - Same Size		II
150030043	M05360	01/03/2015	3:46	01/03/2015	4:44	1	58	58	Animal related	Fuse	Replace - Same Size		V
150030058	T06505	01/03/2015	6:48	01/03/2015	8:30	1	102	101	Weather	Fuse			VI
150030114	D01001	01/03/2015	7:21	01/03/2015	9:07	3	318	105	Public	Pole	Replace - Same Size		I
150030071	D01001	01/03/2015	7:21	01/03/2015	13:01	10	3400	339	Public	Pole	Replace - Same Size	Replace - Same Size	I
150030065	T06505	01/03/2015	7:24	01/03/2015	8:35	1	71	71	Weather	Transformer Fuse			VI
150030074	HB6251	01/03/2015	7:29	01/03/2015	8:45	1	76	76	Animal related	Transformer Fuse	Replace - Same Size		VI
150030086	N35820	01/03/2015	7:56	01/03/2015	10:55	1	179	178	Overhead equipment	Overhead Secondary	Repair		V
150030087	V74513	01/03/2015	7:57	01/03/2015	9:12	3	225	74	Animal related	Transformer Fuse		Replace - Same Size	II
150030095	B61001	01/03/2015	8:21	01/03/2015	10:20	1	119	119	Unknown	Transformer Fuse	Replace - Same Size	Replace - Same Size	I
150030096	S14511	01/03/2015	8:22	01/03/2015	10:29	1	127	126	Overhead equipment	Disconnect Switch	Repair		VI
150030111	K95205	01/03/2015	9:02	01/03/2015	11:10	1	128	128	Overhead equipment	Overhead Primary	Repair		III
150030133	P60170	01/03/2015	9:13	01/03/2015	10:36	13	1079	82	Animal related	Fuse	Repair		VI
150030132	J88163	01/03/2015	9:14	01/03/2015	10:15	1	61	60	Animal related	Transformer Fuse	Replace - Same Size		VI
150030210	K28183	01/03/2015	10:03	01/03/2015	11:28	1	85	85	Overhead equipment	Fuse	Repair		III
150030221	K52400	01/03/2015	10:11	01/03/2015	12:20	1	129	129	Underground equipment	Underground Secondary	Patrol/Test/Inspect	Repair	V
150030222	B82001	01/03/2015	10:12	01/03/2015	12:12	1	120	119	Animal related	Transformer Fuse	Replace - Same Size	Replace - Same Size	I
150030266	C36001	01/03/2015	10:46	01/03/2015	13:49	232	42456	182	Overhead equipment	Overhead Primary	Raise		III
150030285	P82291	01/03/2015	10:57	01/03/2015	12:42	1	105	104	Tree related-tree broken	Fuse	Replace - Same Size		VI
150030313	D55003	01/03/2015	11:46	01/03/2015	14:58	1	192	192	Overhead equipment	Disconnect Switch	Replace - Same Size	Repair	I
150030328	J18268	01/03/2015	12:07	01/03/2015	18:20	1	373	373	Underground equipment	Underground Service	Patrol/Test/Inspect	Repair	VI
150030371	X64501	01/03/2015	12:14	01/03/2015	15:27	105	20265	193	Overhead equipment	Overhead Primary			IV
150030200	C37002	01/03/2015	12:31	01/03/2015	15:45	3	582	194	Overhead equipment	Insulator	Repair		III
150030339	C10002	01/03/2015	12:31	01/03/2015	13:52	15	1215	81	Overhead equipment	Jumper	Repair		III
150030381	R49261	01/03/2015	12:43	01/03/2015	14:44	12	1452	120	Overhead equipment	Crossarm	Patrol/Test/Inspect	Tie/Tighten	VI
150030378	N50331	01/03/2015	13:10	01/03/2015	16:00	14	2380	169	Unknown	Overhead Transformer	Replace - Same Size		II
150030389	343002	01/03/2015	13:29	01/03/2015	14:53	1	84	84	Overhead equipment	Overhead Service	Patrol/Test/Inspect		VI
150030415	P73157	01/03/2015	14:06	01/03/2015	15:01	4	220	55	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	VI
150030410	Y36541	01/03/2015	14:13	01/03/2015	15:05	1	52	51	Overhead equipment	Fuse			IV
150030420	C36001	01/03/2015	14:24	01/03/2015	15:15	33	1683	50	Underground equipment	Fuse	Replace - Same Size		III
150030470	C36001	01/03/2015	15:35	01/03/2015	21:49	2	748	374	Underground equipment	Underground Primary	Repair		III
150030459	F03003	01/03/2015	15:58	01/03/2015	19:09	1	191	191	Overhead equipment	Connector	Repair		III
150030501	J84145	01/03/2015	16:46	01/03/2015	23:28	6	2412	402	Public	Pole		Replace - Same Size	VI
150030543	J84145	01/03/2015	16:46	01/03/2015	18:05	175	13825	78	Public	Pole			VI
150030504	P69173	01/03/2015	17:01	01/03/2015	19:44	1	163	163	Overhead equipment	Transformer Fuse	Repair		III
150030574	K01238	01/03/2015	17:04	01/03/2015	19:15	5	655	131	Underground equipment				VI
150030512	K01238	01/03/2015	17:04	01/03/2015	19:55	15	2565	171	Underground equipment	Underground Primary			VI
150030562	346001	01/03/2015	18:53	01/03/2015	19:50	1	57	56	Overhead equipment	Overhead Service	Repair		VI
150030566	B21001	01/03/2015	19:04	01/03/2015	19:51	1	47	46	Overhead equipment	Fuse	Replace - Same Size		I
150040009	U84534	01/04/2015	1:17	01/04/2015	3:30	58	7714	133	Overhead equipment	Disconnect Switch	Replace - Same Size		II

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
150040025	K89142	01/04/2015	2:38	01/04/2015	3:41	25	1575	62	Tree related-tree broken	Fuse	Repair		III
150040021	V99562	01/04/2015	2:41	01/04/2015	5:40	6	1074	178	Overhead equipment	Fuse	Replace - Same Size		II
150040038	J71128	01/04/2015	3:31	01/04/2015	5:35	1	124	124	Overhead equipment	Fuse	Repair	Replace - Same Size	I
150040039	U80564	01/04/2015	3:33	01/04/2015	5:43	6	780	129	Animal related	Overhead Primary	Repair		II
150040052	D28123	01/04/2015	4:58	01/04/2015	10:28	1	330	330	Underground equipment	Underground Service	Patrol/Test/Inspect	Replace - Urgent	I
150040089	V99562	01/04/2015	7:16	01/04/2015	9:10	6	684	114	Overhead equipment	Fuse	Replace - Same Size	Patrol/Test/Inspect	II
150040127	R49263	01/04/2015	9:15	01/04/2015	10:13	23	1334	58	Animal related	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
150040129	S61531	01/04/2015	9:17	01/04/2015	10:15	1	58	58	Animal related	Transformer Fuse			VI
150040132	J86118	01/04/2015	9:23	01/04/2015	15:20	1	357	357	Tree related-tree contact	Overhead Secondary	Disconnect	Replace - Same Size	VI
150040135	U30006	01/04/2015	9:30	01/04/2015	12:00	1	150	149	Underground equipment	Underground Service	Repair	Repair	II
150040136	E10001	01/04/2015	9:33	01/04/2015	12:28	1	175	174	Animal related	Underground Service			III
150040142	V99562	01/04/2015	9:38	01/04/2015	12:20	6	972	162	Overhead equipment	Fuse	Replace - Same Size	Patrol/Test/Inspect	II
150040148	A45003	01/04/2015	9:56	01/04/2015	11:01	1	65	64	Overhead equipment	Disconnect Switch	Replace - Same Size	Replace - Same Size	I
150040149	N03299	01/04/2015	9:59	01/04/2015	12:36	1	157	156	Overhead equipment	Overhead Primary	Patrol/Test/Inspect	Repair	V
150040156	U37579	01/04/2015	10:06	01/04/2015	14:32	1	266	266	Overhead equipment	Overhead Primary			II
150040172	L24123	01/04/2015	10:12	01/04/2015	12:12	18	2160	119	Overhead equipment	Fuse	Repair		III
150040210	C70001	01/04/2015	10:31	01/04/2015	12:48	1	137	136	Other	Overhead Service	Repair	Repair	III
150040229	K46388	01/04/2015	10:50	01/04/2015	14:59	12	2988	248	Underground equipment	Underground Secondary	Patrol/Test/Inspect	Replace - Urgent	V
150040241	C52002	01/04/2015	11:19	01/04/2015	11:59	1	40	39	Other	Overhead Service	Repair	Repair	III
150040248	P69175	01/04/2015	11:30	01/04/2015	13:17	1	107	107	Underground equipment	Underground Service	Patrol/Test/Inspect		III
150040271	W03570	01/04/2015	11:46	01/04/2015	13:35	1	109	108	Overhead equipment	Overhead Service	Repair	Patrol/Test/Inspect	II
150040285	Q83171	01/04/2015	12:15	01/04/2015	13:39	1	84	84	Tree related-tree broken	Overhead Service	Repair	Repair	VI
150040297	D67001	01/04/2015	12:51	01/04/2015	16:34	1	223	223	Overhead equipment	Overhead Transformer		Repair	IV
150040350	V35002	01/04/2015	13:02	01/04/2015	14:25	1	83	82	Overhead equipment	Overhead Service	Repair		II
150040321	L50215	01/04/2015	13:02	01/04/2015	15:00	1	118	117	Underground equipment	Underground Service	Patrol/Test/Inspect	Repair	VI
150040518	M49410	01/04/2015	13:18	01/04/2015	15:50	1	152	151	Underground equipment	Underground Service	Patrol/Test/Inspect	Repair	V
150040536	B19002	01/04/2015	13:41	01/04/2015	16:00	60	8340	138	Overhead equipment	Overhead Primary		Repair	I
150040542	A36002	01/04/2015	13:59	01/04/2015	20:55	1	416	416	Underground equipment	Underground Service	Patrol/Test/Inspect	Repair	I
150040543	J83138	01/04/2015	14:06	01/04/2015	14:50	1	44	43	Overhead equipment	Disconnect Switch	Replace - Same Size	Replace - Same Size	VI
150040549	A16002	01/04/2015	14:10	01/04/2015	15:58	1	108	107	Overhead equipment	Connector	Repair		I
150040556	N05172	01/04/2015	14:15	01/04/2015	18:40	65	17225	265	Overhead equipment	Jumper	Repair	Repair	I
150040663	B73002	01/04/2015	14:21	01/04/2015	16:45	24	3456	143	Overhead equipment	Fuse	Replace - Same Size		I
150040586	B73002	01/04/2015	14:21	01/04/2015	16:05	17	1768	104	Overhead equipment	Fuse	Replace - Same Size	Repair	I
150040578	Z11506	01/04/2015	14:30	01/04/2015	16:00	1	90	90	Overhead equipment	Jumper	Repair		IV
150040595	U06524	01/04/2015	14:56	01/04/2015	16:10	1	74	74	Overhead equipment	Overhead Service	Repair	Repair	II
150040596	J12166	01/04/2015	14:57	01/04/2015	15:25	1	28	27	Overhead equipment	Connector	Repair		III
150040605	K30204	01/04/2015	15:16	01/04/2015	16:27	1	71	71	Overhead equipment	Jumper	Repair		III
150040632	C66002	01/04/2015	16:08	01/04/2015	17:55	1	107	107	Overhead equipment	Connector	Repair		III
150040634	B65003	01/04/2015	16:13	01/04/2015	21:36	1	323	323	Underground equipment	Underground Service	Patrol/Test/Inspect	Patrol/Test/Inspect	I
150040645	HA5431	01/04/2015	16:24	01/04/2015	19:30	9	1674	185	Tree related-tree broken	Overhead Primary	Patrol/Test/Inspect	Repair	V
150040665	P49183	01/04/2015	17:04	01/04/2015	22:30	1	326	326	Underground equipment	Underground Service	Repair	Replace - Same Size	I
150040669	B84003	01/04/2015	17:19	01/04/2015	18:18	1	59	58	Overhead equipment	Overhead Service	Reconnect		I
150040674	U15004	01/04/2015	17:27	01/04/2015	18:50	1	83	82	Overhead equipment				II
150040692	V41533	01/04/2015	18:05	01/04/2015	19:31	1	86	86	Overhead equipment	Overhead Service	Repair		II
150040704	S88502	01/04/2015	18:15	01/04/2015	18:56	11	451	41	Overhead equipment	Fuse	Repair		VI
150040708	U29001	01/04/2015	18:21	01/04/2015	20:50	1	149	149	Overhead equipment	Overhead Secondary	Reconnect		II
150040738	B57002	01/04/2015	19:08	01/04/2015	20:50	1	102	101	Overhead equipment	Overhead Service	Reconnect		I
150040761	D41003	01/04/2015	20:19	01/04/2015	23:54	1	215	214	Public	Underground Transformer	Replace - Same Size	Replace - Same Size	I
150040763	J06167	01/04/2015	20:21	01/05/2015	0:23	1	242	242	Overhead equipment	Overhead Primary	Repair	Replace - Same Size	I
150040768	J06167	01/04/2015	20:33	01/05/2015	0:23	6	1380	230	Overhead equipment	Overhead Primary	Repair	Replace - Same Size	I
150040781	D16003	01/04/2015	21:05	01/04/2015	22:55	1	110	110	Overhead equipment	Overhead Transformer	Replace - Same Size	Repair	I
150040784	N15850	01/04/2015	21:05	01/05/2015	0:05	7	1260	180	Tree related-tree broken	Overhead Primary	Patrol/Test/Inspect	Repair	V
150040789	K48380	01/04/2015	21:21	01/04/2015	22:22	6	366	60	Overhead equipment				V
150040793	K48380	01/04/2015	21:30	01/04/2015	22:23	1	53	52	Overhead equipment	Overhead Transformer			V
150040797	N86225	01/04/2015	21:40	01/04/2015	23:42	1	122	121	Overhead equipment	Connector	Repair		VI
150040803	332002	01/04/2015	22:13	01/05/2015	6:05	15	7080	471	Public	Pole	Patrol/Test/Inspect	Replace - Same Size	VI

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
150040814	N70332	01/04/2015	22:44	01/05/2015	2:59	20	5100	254	Overhead equipment	Overhead Primary	Repair		I
150040833	C70001	01/04/2015	23:47	01/05/2015	2:28	1	161	161	Other	Overhead Service	Repair	Repair	III
5000445	R08910	01/05/2015	1:30	01/05/2015	1:55	1	24	24	Overhead equipment	Pole		Replace - Same Size	VI
150052443	N60181	01/05/2015	3:19	01/05/2015	5:30	1	131	130	Overhead equipment	Jumper	Repair		I
150052452	N60181	01/05/2015	3:20	01/05/2015	5:30	12	1560	129	Overhead equipment	Jumper	Repair		I
150052445	N60181	01/05/2015	3:31	01/05/2015	5:30	1	119	119	Overhead equipment	Jumper	Repair		I
150052476	R99180	01/05/2015	4:12	01/05/2015	8:10	4	952	238	Overhead equipment	Overhead Primary	Repair		IV
150052466	Q04411	01/05/2015	4:45	01/05/2015	6:27	39	3978	102	Overhead equipment	Jumper	Repair	Repair	III
150052474	K65221	01/05/2015	5:09	01/05/2015	9:00	189	43659	230	Overhead equipment	Overhead Primary			III
150052528	M40132	01/05/2015	6:54	01/05/2015	8:00	1	66	66	Overhead equipment	Fuse	Replace - Same Size	Patrol/Test/Inspect	I
150052545	S86581	01/05/2015	7:08	01/05/2015	9:44	1	156	155	Overhead equipment	Disconnect Switch	Repair		VI
150052668	R58931	01/05/2015	8:00	01/05/2015	8:59	1	59	58	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
150052770	X23516	01/05/2015	8:35	01/05/2015	10:00	1	85	84	Overhead equipment	Overhead Service	Repair	Patrol/Test/Inspect	IV
150052806	Q04410	01/05/2015	8:41	01/05/2015	9:40	1	59	59	Overhead equipment	Jumper	Repair	Repair	III
150052820	U97001	01/05/2015	8:44	01/05/2015	11:38	1	174	174	Overhead equipment	Overhead Service	Repair		II
150052869	X36550	01/05/2015	8:53	01/05/2015	10:51	1	118	117	Overhead equipment	Overhead Primary	Repair		IV
150052884	K79221	01/05/2015	8:57	01/05/2015	10:00	1	63	62	Overhead equipment	Jumper		Repair	IV
150052904	V05001	01/05/2015	9:03	01/05/2015	10:45	1	102	101	Overhead equipment	Overhead Service			II
150052971	Y89541	01/05/2015	9:20	01/05/2015	9:31	1	11	10	Overhead equipment				IV
150052981	V31003	01/05/2015	9:23	01/05/2015	10:40	1	77	76	Overhead equipment	Overhead Service	Repair	Repair	II
150053044	X77543	01/05/2015	9:34	01/05/2015	10:25	1	51	51	Overhead equipment	Fuse	Replace - Same Size		IV
150053113	N54213	01/05/2015	9:46	01/05/2015	11:04	1	78	77	Overhead equipment	Overhead Service	Repair		II
150053161	P58154	01/05/2015	9:56	01/05/2015	11:20	1	84	83	Overhead equipment	Fuse	Replace - New Size		VI
150053214	Y98002	01/05/2015	10:08	01/05/2015	11:00	1	52	52	Overhead equipment	Overhead Service	Patrol/Test/Inspect		IV
150053363	P19395	01/05/2015	10:37	01/05/2015	11:43	1	66	65	Animal related	Fuse	Replace - Same Size		V
150053388	R33126	01/05/2015	10:44	01/05/2015	12:17	1	93	92	Overhead equipment	Jumper	Repair	Patrol/Test/Inspect	I
150053398	Q85162	01/05/2015	10:48	01/05/2015	13:37	1	169	169	Overhead equipment	Overhead Transformer	Replace - Same Size	Replace - Same Size	VI
150053447	D89001	01/05/2015	11:02	01/05/2015	15:15	1	253	252	Underground equipment	Underground Secondary	Repair		I
150053458	Q95247	01/05/2015	11:03	01/05/2015	12:07	1	64	63	Overhead equipment	Transformer Fuse	Repair	Repair	VI
150053617	350103	01/05/2015	11:46	01/05/2015	16:15	6	1614	269	Overhead equipment	Overhead Transformer	Replace - Same Size		V
150053651	L24124	01/05/2015	11:56	01/05/2015	12:55	1	59	59	Overhead equipment	Overhead Secondary	Repair		III
150053654	X34532	01/05/2015	11:57	01/05/2015	13:35	8	784	97	Underground equipment	Fuse	Patrol/Test/Inspect		IV
150053770	B19002	01/05/2015	12:27	01/05/2015	16:18	1	231	230	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Repair	I
150054187	S47586	01/05/2015	14:12	01/05/2015	14:35	1	23	23	Overhead equipment				VI
150054300	R68900	01/05/2015	14:42	01/05/2015	16:05	1	83	82	Overhead equipment	Overhead Primary	Repair		I
150054380	V99562	01/05/2015	15:02	01/05/2015	16:40	1	98	98	Tree related-tree contact	Overhead Service			II
150054488	V21001	01/05/2015	15:32	01/05/2015	16:09	1	37	37	Overhead equipment	Overhead Secondary	Repair	Repair	II
150054594	K31124	01/05/2015	16:02	01/05/2015	20:00	1	238	238	Underground equipment	Underground Service	Repair	Repair	I
150054665	Q71846	01/05/2015	16:42	01/05/2015	20:25	11	2453	223	Overhead equipment	Overhead Transformer	Replace - Same Size	Replace - Same Size	V
150054671	Q80352	01/05/2015	16:47	01/05/2015	17:31	1	44	43	Overhead equipment	Connector	Replace - New Size		V
150054851	T02534	01/05/2015	17:39	01/05/2015	19:10	1	91	90	Overhead equipment	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
150054855	S62521	01/05/2015	17:41	01/05/2015	18:44	4	252	62	Overhead equipment	Transformer Fuse	Replace - Same Size		VI
150054859	K28183	01/05/2015	17:44	01/05/2015	23:21	1	337	336	Overhead equipment	Overhead Primary	Repair		III
150054905	X78002	01/05/2015	18:24	01/05/2015	19:59	1	95	94	Overhead equipment	Overhead Service	Repair		IV
150054922	M09144	01/05/2015	18:47	01/05/2015	19:25	1	38	38	Overhead equipment	Overhead Service	Replace - Same Size		VI
150054925	M18131	01/05/2015	18:49	01/05/2015	20:42	1	113	113	Underground equipment	Underground Service		Repair	III
150054956	B25002	01/05/2015	18:54	01/05/2015	22:10	422	82712	195	Overhead equipment	Overhead Primary	Repair		I
150054931	T06505	01/05/2015	18:54	01/05/2015	20:18	1	84	84	Overhead equipment	Overhead Service	Repair		VI
150054954	P69175	01/05/2015	19:00	01/05/2015	23:21	1	261	261	Underground equipment	Underground Service		Repair	III
150055338	K48379	01/05/2015	19:15	01/05/2015	21:40	1	145	145	Overhead equipment	Connector	Repair		V
150055366	N50333	01/05/2015	20:26	01/05/2015	21:32	1	66	65	Overhead equipment	Connector	Repair		II
150055878	A73002	01/05/2015	21:00	01/05/2015	23:29	1	149	149	Public	Overhead Service	Repair		I
150055927	T05539	01/05/2015	23:34	01/06/2015	0:28	23	1242	53	Overhead equipment	Fuse			VI
150062720	Q16867	01/06/2015	3:24	01/06/2015	7:00	8	1728	215	Overhead equipment	Overhead Transformer		Replace - Same Size	V
150062728	K65220	01/06/2015	5:58	01/06/2015	8:54	11	1936	175	Overhead equipment	Overhead Primary	Repair	Repair	III
150062822	Y86593	01/06/2015	7:41	01/06/2015	8:21	1	40	39	Animal related	Transformer Fuse	Replace - Same Size		IV

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
150062853	V46552	01/06/2015	7:58	01/06/2015	17:32	1	574	574	Underground equipment	Underground Primary	Switch/Reset	Repair	II
150062875	B71002	01/06/2015	8:06	01/06/2015	10:16	1	130	129	Tree related-tree contact	Overhead Service	Repair		I
150063470	U92593	01/06/2015	9:52	01/06/2015	11:30	8	784	97	Public	Pole	Replace - Same Size	Replace - Same Size	II
150063526	J75271	01/06/2015	11:05	01/06/2015	11:12	3	21	7	Underground equipment	Underground Primary			IV
150063564	J75271	01/06/2015	11:16	01/06/2015	11:21	1	5	4	Underground equipment	Underground Primary			IV
150063573	K80381	01/06/2015	11:19	01/06/2015	11:23	1	4	4	Underground equipment	Underground Primary			IV
150064160	J71128	01/06/2015	14:00	01/06/2015	14:23	1	23	23	Overhead equipment	Other			I
150064177	J71128	01/06/2015	14:03	01/06/2015	14:23	1	20	20	Overhead equipment	Other			I
150064324	N58144	01/06/2015	15:00	01/06/2015	16:06	1	66	65	Overhead equipment	Connector	Replace - Same Size	Repair	I
150064325	Y39001	01/06/2015	15:00	01/06/2015	15:40	1	40	40	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
150064493	M45212	01/06/2015	16:14	01/06/2015	17:57	1	103	103	Overhead equipment	Connector	Repair		IV
150064522	H22349	01/06/2015	16:30	01/06/2015	17:18	1	48	47	Intentional	Meter	Reconnect		V
150064537	T08502	01/06/2015	16:41	01/06/2015	19:00	1	139	138	Overhead equipment	Overhead Service	Patrol/Test/Inspect	Repair	VI
150064549	J68402	01/06/2015	16:49	01/06/2015	17:16	2	54	27	Overhead equipment	Overhead Primary			III
150064696	K25166	01/06/2015	18:20	01/06/2015	19:20	1	60	59	Animal related	Disconnect Switch	Replace - New Size		VI
150065090	X64503	01/06/2015	19:45	01/07/2015	2:40	12	4980	415	Overhead equipment	Other		Patrol/Test/Inspect	IV
150065102	R49263	01/06/2015	20:40	01/07/2015	0:12	2	424	211	Overhead equipment	Overhead Secondary	Patrol/Test/Inspect	Repair	VI
150065104	T23528	01/06/2015	20:40	01/06/2015	22:23	166	17098	103	Public				VI
150066005	T23528	01/06/2015	20:41	01/06/2015	22:23	175	17850	101	Public	Pole			VI
150066004	T23528	01/06/2015	20:43	01/07/2015	2:50	49	17983	367	Public	Pole	Switch/Reset	Replace - New Size	VI
150065953	R23332	01/06/2015	21:07	01/06/2015	23:07	1	120	119	Underground equipment	Underground Service	Patrol/Test/Inspect	Repair	V
150065970	S66590	01/06/2015	21:48	01/07/2015	2:20	5	1360	271	Overhead equipment	Overhead Transformer		Replace - New Size	VI
150065997	K36151	01/06/2015	22:17	01/07/2015	2:42	172	45580	265	Overhead equipment	Overhead Primary	Repair		III
150070042	D96001	01/07/2015	0:25	01/07/2015	5:08	2	566	283	Underground equipment	Underground Transformer		Replace - Same Size	I
150070142	Q80353	01/07/2015	2:19	01/07/2015	4:07	2	216	107	Overhead equipment	Jumper	Repair		V
150082138	Y36764	01/07/2015	3:10	01/08/2015	4:50	1	1540	1540	Overhead equipment	Overhead Primary		Repair	IV
150082141	Y36764	01/07/2015	3:10	01/08/2015	4:30	4	6080	1519	Overhead equipment	Overhead Primary		Repair	IV
150072227	P42230	01/07/2015	3:11	01/07/2015	6:24	1	193	193	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	VI
150072243	S09520	01/07/2015	4:16	01/07/2015	6:23	5	635	127	Overhead equipment	Disconnect Switch	Replace - Same Size	Patrol/Test/Inspect	VI
150072403	T15571	01/07/2015	4:29	01/07/2015	7:40	31	5921	191	Overhead equipment	Disconnect Switch	Patrol/Test/Inspect	Repair	VI
150072248	J50185	01/07/2015	4:57	01/07/2015	9:15	73	18834	257	Underground equipment	Underground Primary	Repair	Repair	III
150072261	P72318	01/07/2015	5:26	01/07/2015	7:20	2	228	113	Overhead equipment	Jumper	Repair	Repair	V
150072275	M47802	01/07/2015	5:54	01/07/2015	6:58	1	64	63	Overhead equipment	Overhead Primary			V
150072286	V03562	01/07/2015	6:13	01/07/2015	7:55	1	102	101	Overhead equipment	Disconnect Switch	Repair		II
150072297	N54214	01/07/2015	6:29	01/07/2015	7:30	2	122	60	Overhead equipment	Overhead Primary	Repair		II
150072296	J76804	01/07/2015	6:29	01/07/2015	9:30	1	181	181	Overhead equipment	Overhead Primary		Repair	V
150072624	E10003	01/07/2015	6:38	01/07/2015	10:22	196	43904	223	Overhead equipment	Overhead Primary	Repair		III
150072309	U37579	01/07/2015	6:43	01/07/2015	10:05	1	202	201	Overhead equipment	Overhead Transformer	Replace - New Size	Patrol/Test/Inspect	II
150072432	P14392	01/07/2015	7:34	01/07/2015	11:56	238	62356	261	Overhead equipment	Overhead Primary			V
150072652	P14392	01/07/2015	7:34	01/07/2015	8:30	1223	68488	55	Overhead equipment	Overhead Primary			V
150072926	R78300	01/07/2015	7:34	01/07/2015	11:40	409	100614	245	Overhead equipment	Overhead Primary	Cut in Clear	Repair	V
150072364	P14392	01/07/2015	7:35	01/07/2015	8:52	1	77	76	Overhead equipment	Overhead Primary			V
150072381	P14391	01/07/2015	7:45	01/07/2015	8:30	185	8325	45	Overhead equipment	Overhead Primary			V
150072493	Q06142	01/07/2015	8:13	01/07/2015	8:50	1	37	36	Overhead equipment	Fuse		Replace - Same Size	IV
150072507	N54214	01/07/2015	8:18	01/07/2015	9:11	2	106	53	Unknown	Transformer Fuse	Replace - Same Size		II
150072511	N05172	01/07/2015	8:20	01/07/2015	8:50	1	30	30	Overhead equipment	Jumper	Repair		I
150072515	Y10011	01/07/2015	8:21	01/07/2015	9:07	7	322	46	Animal related	Transformer Fuse	Replace - Same Size		IV
150072616	M25143	01/07/2015	8:37	01/07/2015	9:46	2	138	69	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
150072565	M09143	01/07/2015	8:41	01/07/2015	10:01	1	80	79	Overhead equipment	Connector	Replace - Same Size		VI
150072665	N54214	01/07/2015	9:39	01/07/2015	10:33	2	108	53	Unknown	Transformer Fuse	Replace - New Size		II
150072686	R49275	01/07/2015	9:45	01/07/2015	10:38	1	53	53	Overhead equipment	Overhead Service	Repair		VI
150072743	Q75146	01/07/2015	10:09	01/07/2015	10:57	1	48	47	Overhead equipment	Connector	Replace - Same Size		VI
150072832	R04415	01/07/2015	10:44	01/07/2015	12:54	1	130	129	Underground equipment	Underground Secondary	Disconnect	Repair	V
150072867	Y55505	01/07/2015	11:00	01/07/2015	12:20	1	80	79	Underground equipment	Underground Service			IV
150072985	D39001	01/07/2015	11:39	01/07/2015	13:19	2	200	99	Overhead equipment	Overhead Primary	Repair		I
150072984	P47123	01/07/2015	11:45	01/07/2015	13:33	16	1728	107	Overhead equipment	Fuse	Replace - Same Size		I

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
150073502	M49411	01/07/2015	13:35	01/07/2015	16:48	1	193	193	Overhead equipment	Overhead Service	Repair		V
150073367	P52305	01/07/2015	14:25	01/07/2015	15:24	52	3068	59	Overhead equipment	Jumper	Repair		IV
150073403	N05172	01/07/2015	14:54	01/07/2015	17:30	66	10296	155	Overhead equipment	Overhead Primary	Repair		I
150073404	D28124	01/07/2015	14:56	01/07/2015	16:15	1	79	79	Overhead equipment	Jumper	Repair		I
150073506	J79305	01/07/2015	15:07	01/07/2015	18:09	299	54418	181	Overhead equipment	Overhead Primary			I
150073519		01/07/2015	15:24	01/07/2015	18:20	1	176	175	Overhead equipment	Overhead Primary	Replace - Same Size	Replace - Same Size	I
5000489	Q54908	01/07/2015	15:29	01/07/2015	16:42	1	72	72	Overhead equipment	Transformer Fuse	Patrol/Test/Inspect	Repair	VI
150073544	J08205	01/07/2015	15:38	01/07/2015	17:45	1	127	127	Overhead equipment	Jumper	Repair		I
150073694	M40132	01/07/2015	15:46	01/07/2015	20:25	19	5301	278	Overhead equipment	Overhead Primary	Repair	Repair	I
150073638	B81001	01/07/2015	16:25	01/07/2015	18:33	9	1152	127	Public	Underground Transformer	Repair		I
150073654	B10001	01/07/2015	16:37	01/07/2015	17:15	1	38	37	Overhead equipment	Overhead Primary			I
150073795	S86580	01/07/2015	17:09	01/07/2015	18:10	60	3660	60	Overhead equipment	Fuse	Replace - Same Size		VI
150073691	K28183	01/07/2015	17:13	01/07/2015	17:53	1	40	39	Overhead equipment	Jumper	Repair		III
150073814	P49180	01/07/2015	17:38	01/07/2015	19:24	146	15476	105	Overhead equipment	Fuse	Repair	Replace - Same Size	I
150073829	Y82587	01/07/2015	17:58	01/07/2015	20:40	1	162	161	Overhead equipment	Overhead Primary	Repair		IV
150073835	Y82587	01/07/2015	18:01	01/07/2015	20:40	1	159	158	Overhead equipment	Overhead Primary	Repair		IV
150073841	A80001	01/07/2015	18:05	01/08/2015	0:24	1	379	379	Underground equipment	Underground Primary	Repair	Repair	I
150073863	329148	01/07/2015	18:25	01/07/2015	18:55	10	300	30	Overhead equipment	Transformer Fuse	Replace - Same Size		V
150073872	Q70161	01/07/2015	18:32	01/07/2015	22:30	1	238	238	Overhead equipment	Overhead Primary	Repair		I
150073847	Y82587	01/07/2015	18:49	01/07/2015	19:25	3	108	36	Overhead equipment	Overhead Primary	Repair		IV
150073886	J79305	01/07/2015	18:50	01/07/2015	19:22	1	32	31	Overhead equipment				I
150073888	A17025	01/07/2015	18:51	01/07/2015	20:10	1	79	79	Overhead equipment	Overhead Service	Repair		I
150074280	C50003	01/07/2015	19:34	01/07/2015	21:07	1	93	92	Overhead equipment	Jumper	Repair		III
150074283	R61241	01/07/2015	19:37	01/07/2015	20:23	1	46	46	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
150074290	B19001	01/07/2015	19:44	01/07/2015	21:01	1	77	76	Overhead equipment	Connector	Repair		I
150074292	P77237	01/07/2015	19:45	01/07/2015	21:50	1	125	124	Overhead equipment	Fuse	Replace - Same Size		VI
150074302	Y82587	01/07/2015	20:04	01/07/2015	20:40	1	36	36	Overhead equipment	Overhead Primary	Repair		IV
150074659	B45005	01/07/2015	20:56	01/08/2015	0:03	466	87142	187	Overhead equipment	Overhead Primary			I
150074399	B45005	01/07/2015	20:56	01/07/2015	23:59	1146	209718	182	Overhead equipment				I
150074619	A80001	01/07/2015	21:34	01/08/2015	0:18	126	20664	164	Overhead equipment	Crossarm	Patrol/Test/Inspect		I
150074691	A80001	01/07/2015	21:34	01/08/2015	3:29	65	23075	355	Overhead equipment	Crossarm	Patrol/Test/Inspect		I
150074615	P54828	01/07/2015	21:46	01/07/2015	23:52	6	756	125	Overhead equipment	Overhead Primary	Repair		V
150074632	K28180	01/07/2015	22:01	01/07/2015	23:35	9	846	94	Overhead equipment	Fuse	Replace - Same Size		III
150074636	K80381	01/07/2015	22:05	01/07/2015	23:40	1	95	94	Overhead equipment	Jumper	Repair		IV
150074653	S31532	01/07/2015	22:17	01/08/2015	0:20	1	123	123	Overhead equipment	Disconnect Switch	Patrol/Test/Inspect	Replace - Same Size	VI
150074655	T05539	01/07/2015	22:23	01/07/2015	23:06	1	43	43	Overhead equipment	Transformer Fuse			VI
150074663	P83705	01/07/2015	22:42	01/08/2015	1:13	1	151	150	Overhead equipment	Overhead Primary	Repair	Repair	I
150074665	K39156	01/07/2015	22:50	01/08/2015	0:53	1	123	123	Tree related-tree contact	Overhead Service	Repair		III
5000495	Q82906	01/07/2015	22:59	01/08/2015	2:15	35	6872	196	Overhead equipment	Overhead Primary	Repair	Repair	VI
5000501	Q82906	01/07/2015	23:04	01/08/2015	0:22	22	1702	77	Overhead equipment	Overhead Primary	Repair	Repair	VI
150074686	P47123	01/07/2015	23:30	01/08/2015	1:00	19	1710	90	Overhead equipment	Overhead Primary	Repair	Replace - Same Size	I
150074689	D67002	01/07/2015	23:42	01/08/2015	1:39	1	117	116	Overhead equipment	Fuse	Replace - Same Size		IV
150080202	U73599	01/07/2015	23:53	01/08/2015	5:20	6	1962	326	Overhead equipment	Fuse			II
150080065	Q24312	01/08/2015	0:22	01/08/2015	1:55	1	93	92	Tree related-tree broken	Tree	Trim		VI
150080230	K26136	01/08/2015	0:30	01/08/2015	3:49	166	33034	198	Overhead equipment	Overhead Primary			VI
150082015	K26136	01/08/2015	0:30	01/08/2015	6:02	2	664	331	Overhead equipment	Overhead Primary	Patrol/Test/Inspect	Repair	VI
150080159	A80001	01/08/2015	0:44	01/08/2015	4:25	65	14365	221	Overhead equipment	Overhead Primary	Repair		I
150080155	L00133	01/08/2015	1:16	01/08/2015	3:45	4	596	149	Overhead equipment	Overhead Secondary		Repair	III
150080206	K31120	01/08/2015	1:31	01/08/2015	4:38	5	935	187	Overhead equipment				I
150082066	J14140	01/08/2015	2:36	01/08/2015	6:24	5	1140	228	Overhead equipment	Overhead Primary		Replace - Same Size	VI
150080225	N05172	01/08/2015	2:54	01/08/2015	4:49	1	115	114	Overhead equipment	Overhead Primary	Patrol/Test/Inspect	Repair	I
150082149	Y31591	01/08/2015	3:15	01/08/2015	6:58	87	19401	223	Overhead equipment	Overhead Primary	Switch/Reset	Repair	IV
150082045	Y36764	01/08/2015	3:15	01/08/2015	4:40	495	42075	85	Overhead equipment	Overhead Primary		Repair	IV
150082050	325010	01/08/2015	3:26	01/08/2015	5:34	25	3200	127	Overhead equipment	Fuse	Replace - Same Size		VI
150082070	K48380	01/08/2015	5:33	01/08/2015	7:56	2	286	143	Overhead equipment	Overhead Secondary	Repair	Repair	V
150082100	N44215	01/08/2015	6:15	01/08/2015	7:20	1	65	65	Overhead equipment	Transformer Fuse	Repair	Repair	III

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
150082279	N94180	01/08/2015	7:22	01/08/2015	9:20	7	826	118	Overhead equipment	Fuse	Replace - Same Size		I
150082206	V99562	01/08/2015	7:52	01/08/2015	9:18	1	86	85	Overhead equipment	Transformer Fuse			II
150082210	N44215	01/08/2015	7:52	01/08/2015	8:59	1	67	66	Overhead equipment	Overhead Transformer			III
150082341	R73841	01/08/2015	8:39	01/08/2015	10:21	1	102	101	Overhead equipment	Fuse	Replace - Same Size		V
150082371	J75271	01/08/2015	8:39	01/08/2015	11:13	63	9702	153	Overhead equipment	Overhead Primary	Patrol/Test/Inspect	Repair	IV
150082401	J83138	01/08/2015	8:58	01/08/2015	12:32	1	214	213	Underground equipment	Underground Secondary	Patrol/Test/Inspect	Repair	VI
150082450	M19222	01/08/2015	9:19	01/08/2015	10:40	1	81	81	Overhead equipment	Overhead Service	Repair	Repair	VI
150082457	B79003	01/08/2015	9:22	01/08/2015	10:20	1	58	58	Overhead equipment				I
150082525	Z43549	01/08/2015	9:49	01/08/2015	11:47	2	236	117	Overhead equipment	Animal Guard	Install		IV
150082742	N05170	01/08/2015	9:55	01/08/2015	11:15	5	400	79	Overhead equipment	Transformer Fuse	Replace - Same Size		I
150082650	R71286	01/08/2015	10:40	01/08/2015	11:31	1	51	50	Overhead equipment	Connector	Repair		VI
150082681	D66001	01/08/2015	10:49	01/08/2015	11:34	1	45	45	Overhead equipment	Overhead Service	Repair		IV
150082786	C70001	01/08/2015	11:14	01/08/2015	12:10	2	112	56	Overhead equipment	Connector	Repair		III
150082767	L35283	01/08/2015	11:16	01/08/2015	12:06	1	50	49	Overhead equipment	Overhead Service	Repair		III
150082806	Q21321	01/08/2015	11:27	01/08/2015	14:30	1	183	182	Underground equipment	Underground Secondary	Patrol/Test/Inspect	Repair	VI
150082834	S55566	01/08/2015	11:36	01/08/2015	13:15	1	99	99	Overhead equipment	Overhead Service	Repair	Replace - Same Size	VI
150082849	339162	01/08/2015	11:42	01/08/2015	12:05	1	23	22	Jurisdictional	Overhead Service	Reconnect		V
150082859	K71821	01/08/2015	11:45	01/08/2015	13:15	1	90	90	Overhead equipment	Jumper	Patrol/Test/Inspect	Repair	IV
150083397	X23516	01/08/2015	12:07	01/08/2015	14:22	269	36315	135	Substation equipment	Overhead Primary	Switch/Reset		IV
150083381	X23516	01/08/2015	12:07	01/08/2015	14:17	175	22750	129	Substation equipment	Substation Breaker			IV
150083377	X23516	01/08/2015	12:07	01/08/2015	14:11	165	20460	123	Substation equipment	Substation Breaker	Switch/Reset		IV
150083068	J15303	01/08/2015	12:09	01/08/2015	13:41	52	4784	92	Overhead equipment				I
150082979	P71830	01/08/2015	12:14	01/08/2015	14:58	1	164	164	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	V
150082994	N95859	01/08/2015	12:21	01/08/2015	13:13	1	52	52	Overhead equipment	Connector	Replace - New Size		V
150083018	J79306	01/08/2015	12:22	01/08/2015	15:04	374	60588	162	Overhead equipment	Overhead Primary	Repair		I
150083028	N78244	01/08/2015	12:30	01/08/2015	12:55	1	25	24	Overhead equipment	Jumper	Repair		I
150083128	B62003	01/08/2015	13:05	01/08/2015	14:13	1	68	68	Overhead equipment	Overhead Secondary	Repair		I
150083284	337002	01/08/2015	13:38	01/08/2015	15:01	290	24070	82	Substation equipment	Substation Breaker	Repair		VI
150083561	337002	01/08/2015	13:39	01/08/2015	16:52	101	19493	193	Substation equipment	Substation Breaker	Repair		VI
150083774	337002	01/08/2015	13:39	01/08/2015	16:36	13	2301	177	Substation equipment	Substation Breaker	Repair		VI
150083281	R23333	01/08/2015	13:40	01/08/2015	14:40	24	1440	59	Overhead equipment	Overhead Primary	Replace - Same Size	Repair	V
150083194	C50001	01/08/2015	13:40	01/08/2015	15:23	71	7313	103	Overhead equipment	Overhead Primary			III
150083258	J85161	01/08/2015	13:42	01/08/2015	17:08	1	206	206	Overhead equipment	Other			VI
150083351	E10003	01/08/2015	13:49	01/08/2015	16:01	196	25872	132	Overhead equipment	Overhead Primary	Patrol/Test/Inspect	Tie/Tighten	III
150083333	B25002	01/08/2015	13:57	01/08/2015	14:42	1	45	45	Overhead equipment	Jumper	Replace - Same Size		I
150083370	L08226	01/08/2015	14:09	01/08/2015	15:20	2	142	71	Overhead equipment	Jumper	Repair		III
150083549	Q74149	01/08/2015	14:57	01/08/2015	15:25	1	28	27	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
150083604	J79306	01/08/2015	15:07	01/08/2015	15:15	1	8	7	Overhead equipment	Overhead Primary	Replace - Same Size	Replace - Same Size	I
150083651	308001	01/08/2015	15:21	01/08/2015	19:12	1	231	231	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	VI
150083754	U13551	01/08/2015	16:12	01/08/2015	17:30	1	78	77	Underground equipment	Underground Secondary	Repair		II
150083757	337001	01/08/2015	16:13	01/08/2015	17:22	1	69	69	Overhead equipment				VI
150083968	M41111	01/08/2015	16:47	01/08/2015	18:19	3	276	91	Unknown	Fuse	Repair	Replace - Same Size	I
150083812	T06504	01/08/2015	16:58	01/08/2015	18:30	46	4232	92	Overhead equipment	Overhead Primary	Repair	Repair	VI
150083960	N05172	01/08/2015	17:43	01/08/2015	19:55	2	264	132	Overhead equipment	Overhead Primary	Repair		I
150083953	K62102	01/08/2015	17:47	01/08/2015	19:00	1	73	72	Unknown	Fuse	Replace - Same Size		II
150083982	L17102	01/08/2015	18:33	01/08/2015	19:30	1	57	56	Overhead equipment	Overhead Service	Repair		III
150083994	L23145	01/08/2015	18:44	01/08/2015	19:10	1	26	26	Overhead equipment	Jumper	Repair		III
150083997	M31203	01/08/2015	18:47	01/08/2015	20:50	1	123	123	Overhead equipment	Overhead Transformer	Replace - Same Size		I
150084311	A50001	01/08/2015	19:07	01/08/2015	20:00	1	53	53	Overhead equipment	Connector	Patrol/Test/Inspect	Replace - New Size	I
150084321	S03531	01/08/2015	19:20	01/08/2015	22:50	1	210	210	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Repair	VI
150084330	P47123	01/08/2015	19:29	01/08/2015	21:45	17	2312	136	Unknown	Fuse	Repair	Replace - Same Size	I
150084336	J12166	01/08/2015	19:36	01/09/2015	0:30	38	11172	294	Public	Pole	Replace - Same Size	Replace - Same Size	III
150084367	J15302	01/08/2015	20:33	01/08/2015	21:59	1	86	86	Overhead equipment	Fuse	Replace - Same Size		I
150084372	J15302	01/08/2015	20:40	01/08/2015	21:53	1	73	73	Overhead equipment	Fuse	Replace - Same Size		I
150084374	U90566	01/08/2015	20:43	01/08/2015	21:15	1	32	31	Overhead equipment	Overhead Primary			II
150084381	B65004	01/08/2015	20:56	01/08/2015	21:32	1	36	36	Overhead equipment	Connector	Replace - Same Size		I

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
150084490	U32258	01/08/2015	21:18	01/08/2015	22:07	443	21707	49	Overhead equipment	Overhead Primary	Switch/Reset		II
150084553	N70331	01/08/2015	22:03	01/08/2015	22:50	50	2350	47	Overhead equipment	Overhead Primary	Replace - Same Size	Replace - Same Size	I
150084562	T09530	01/08/2015	22:46	01/09/2015	3:35	1	289	288	Underground equipment	Underground Service	Repair	Repair	VI
150084564	N48106	01/08/2015	22:53	01/09/2015	1:30	7	1099	156	Overhead equipment	Overhead Transformer	Replace - Same Size		II
150084567	U41545	01/08/2015	23:00	01/09/2015	0:32	4	368	91	Overhead equipment	Transformer Fuse	Replace - Same Size		II
150084568	X82004	01/08/2015	23:02	01/09/2015	0:17	7	525	75	Tree related-tree contact	Overhead Secondary	Repair	Repair	IV
150084571	B62003	01/08/2015	23:15	01/09/2015	0:40	1	85	85	Overhead equipment	Connector	Repair		I
150090162	Y59520	01/08/2015	23:18	01/09/2015	2:50	134	28408	211	Overhead equipment	Overhead Primary	Repair	Repair	IV
150090062	Y59520	01/08/2015	23:20	01/09/2015	0:29	89	6141	69	Overhead equipment	Overhead Primary	Repair	Repair	IV
150090137	A68001	01/09/2015	0:11	01/09/2015	4:20	3	747	248	Overhead equipment	Overhead Primary	Patrol/Test/Inspect	Repair	I
150090141	D62074	01/09/2015	0:27	01/09/2015	1:06	3239	126321	38	Overhead equipment	Overhead Primary	Switch/Reset		I
150090206	J47176	01/09/2015	2:40	01/09/2015	8:58	1	378	378	Underground equipment	Underground Primary	Repair	Repair	III
150092622	A68001	01/09/2015	4:33	01/09/2015	5:42	1	69	69	Overhead equipment	Other		Repair	I
150092623	A68001	01/09/2015	4:40	01/09/2015	5:35	1	55	55	Unknown	Overhead Primary	Patrol/Test/Inspect		I
150092659	M40132	01/09/2015	6:37	01/09/2015	8:00	1	83	83	Overhead equipment	Jumper	Repair		I
150092673	H14343	01/09/2015	7:08	01/09/2015	9:20	1	132	132	Underground equipment	Underground Service		Repair	V
150092707	U44529	01/09/2015	7:33	01/09/2015	16:26	1	533	532	Underground equipment	Underground Primary	Replace - New Size	Replace - New Size	II
150092775	L95110	01/09/2015	8:07	01/09/2015	9:19	1	72	72	Overhead equipment	Other			III
150092786	C66001	01/09/2015	8:08	01/09/2015	9:35	61	5307	87	Public	Overhead Primary	Repair		III
150092870	B68003	01/09/2015	8:50	01/09/2015	9:34	1	44	43	Overhead equipment	Jumper	Repair		III
150092913	K71821	01/09/2015	9:02	01/09/2015	10:46	1	104	104	Overhead equipment	Jumper		Repair	IV
150092938	J79305	01/09/2015	9:09	01/09/2015	11:00	1	111	111	Overhead equipment	Transformer Fuse	Replace - Same Size		I
150092943	H02256	01/09/2015	9:10	01/09/2015	10:15	1	65	65	Overhead equipment	Jumper		Repair	III
150092975	Y07577	01/09/2015	9:27	01/09/2015	10:05	1	38	37	Overhead equipment	Overhead Service	Repair		IV
150093123	M37191	01/09/2015	10:11	01/09/2015	10:33	15	330	21	Animal related	Fuse	Replace - Same Size		I
150093305	J84146	01/09/2015	11:22	01/09/2015	14:17	4	700	174	Overhead equipment	Overhead Transformer		Replace - Same Size	VI
150093457	Q01281	01/09/2015	11:26	01/09/2015	12:10	236	10384	43	Overhead equipment	Pole	Replace - Same Size		III
150093374	V20502	01/09/2015	11:40	01/09/2015	12:49	1	69	69	Overhead equipment				II
150093441	A80001	01/09/2015	12:04	01/09/2015	16:27	1	263	262	Underground equipment	Underground Transformer	Replace - Same Size	Replace - Same Size	I
150093459	K28180	01/09/2015	12:14	01/09/2015	14:10	1	116	116	Overhead equipment	Overhead Service	Repair		III
150093509	330128	01/09/2015	12:33	01/09/2015	13:35	1	62	61	Underground equipment	Overhead Service	Tie/Tighten		V
150093601	U97002	01/09/2015	13:07	01/09/2015	14:31	1	84	84	Overhead equipment	Overhead Service	Repair		II
5000555	R10903	01/09/2015	13:41	01/09/2015	19:15	4	1333	333	Public	Pole		Repair	VI
150093730	U52516	01/09/2015	13:50	01/09/2015	14:59	1	69	68	Overhead equipment	Other		Repair	II
150093769	B38002	01/09/2015	13:58	01/09/2015	15:01	34	2142	63	Overhead equipment	Overhead Primary	Repair		I
150093918	M18131	01/09/2015	14:51	01/09/2015	19:19	1	268	267	Underground equipment	Underground Service		Repair	III
150093988	U29001	01/09/2015	14:52	01/09/2015	16:14	372	30504	82	Public	Pole	Cut in Clear		II
150094040	U39541	01/09/2015	14:52	01/09/2015	16:14	256	20992	82	Public	Pole	Cut in Clear		II
150094144	A80001	01/09/2015	15:38	01/09/2015	16:49	1	71	71	Overhead equipment	Connector	Replace - Same Size	Replace - Same Size	I
150094305	310123	01/09/2015	16:35	01/09/2015	16:59	1	24	24	Overhead equipment				V
150094335	R04409	01/09/2015	16:50	01/09/2015	23:41	1	411	410	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	V
150094505	P49183	01/09/2015	18:41	01/09/2015	20:13	1	92	92	Overhead equipment	Overhead Service			I
150094955	A56013	01/09/2015	20:05	01/09/2015	21:20	1	75	75	Overhead equipment	Connector	Replace - Same Size	Replace - Same Size	I
150094963	X03533	01/09/2015	20:10	01/09/2015	21:55	1	105	104	Animal related	Transformer Fuse	Replace - Same Size		IV
150095418	N70331	01/09/2015	22:17	01/09/2015	22:46	1	29	29	Overhead equipment	Overhead Primary	Replace - Same Size	Replace - Same Size	I
150095429	S79510	01/09/2015	22:48	01/10/2015	0:25	1	97	97	Overhead equipment	Transformer Fuse	Repair	Replace - Same Size	VI
150101586	J07135	01/10/2015	1:43	01/10/2015	4:40	42	7434	177	Overhead equipment	Overhead Primary	Replace - Same Size		I
5000567	L59933	01/10/2015	3:52	01/10/2015	6:16	1	143	143	Underground equipment	Underground Service			VI
150101619	K80388	01/10/2015	5:46	01/10/2015	10:38	1	292	292	Overhead equipment	Jumper	Repair	Repair	IV
150101637	L12125	01/10/2015	6:16	01/10/2015	10:35	123	31857	258	Underground equipment	Underground Primary	Repair		III
150101691	B21004	01/10/2015	7:51	01/10/2015	10:15	57	8208	144	Overhead equipment	Fuse	Replace - Same Size		I
150101740	E10001	01/10/2015	7:58	01/10/2015	11:30	39	8268	211	Overhead equipment	Overhead Primary	Patrol/Test/Inspect	Patrol/Test/Inspect	III
5000571	R10943	01/10/2015	9:04	01/10/2015	9:40	1	35	35	Animal related	Fuse	Replace - Same Size		VI
150101851	N60181	01/10/2015	9:33	01/10/2015	11:15	1	102	101	Overhead equipment	Jumper	Repair		I
150101852	A85001	01/10/2015	9:35	01/10/2015	11:20	1	105	104	Overhead equipment	Jumper	Repair		I
150101861	D72001	01/10/2015	9:44	01/10/2015	10:15	1	31	31	Overhead equipment	Connector	Replace - Same Size	Replace - Same Size	I

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
150101868		01/10/2015	9:52	01/10/2015	10:37	1	45	45	Overhead equipment	Fuse	Replace - Same Size		VI
150101914	C15002	01/10/2015	10:49	01/10/2015	13:33	1	164	164	Overhead equipment	Overhead Service	Repair		III
150101959	B82001	01/10/2015	11:46	01/10/2015	20:29	1	523	523	Underground equipment	Underground Transformer	Replace - Same Size	Repair	I
150101966	A56013	01/10/2015	11:49	01/10/2015	12:15	76	1976	26	Animal related	Animal Guard			I
150101977	R33126	01/10/2015	12:11	01/10/2015	13:59	1	108	107	Overhead equipment	Transformer Fuse	Replace - Same Size	Patrol/Test/Inspect	I
150101989	D89003	01/10/2015	12:36	01/10/2015	13:15	1	39	39	Animal related	Transformer Fuse	Replace - Same Size		I
150102003	K52400	01/10/2015	12:52	01/10/2015	13:50	1	58	58	Overhead equipment				V
150102118	D69005	01/10/2015	13:10	01/10/2015	14:53	1492	153676	103	Underground equipment	Underground Primary	Switch/Reset	Repair	I
150102117	D69002	01/10/2015	13:12	01/10/2015	15:02	390	42900	109	Underground equipment	Underground Primary	Switch/Reset	Repair	I
150102215	D69005	01/10/2015	14:27	01/10/2015	16:03	30	2880	95	Underground equipment	Underground Primary	Switch/Reset	Repair	I
150102180	D69001	01/10/2015	14:39	01/10/2015	15:11	72	2304	31	Underground equipment				I
150102200	R93350	01/10/2015	15:09	01/10/2015	17:00	1	111	111	Overhead equipment	Overhead Secondary	Replace - Same Size	Repair	V
150102218	N95823	01/10/2015	15:27	01/10/2015	17:10	1	103	103	Overhead equipment	Jumper	Repair		V
150102396	D69005	01/10/2015	15:29	01/10/2015	20:52	175	56525	322	Underground equipment	Switchgear	Switch/Reset	Switch/Reset	I
150102395	D69005	01/10/2015	15:29	01/10/2015	21:35	1	366	365	Underground equipment	Switchgear	Switch/Reset		I
150102234	D69005	01/10/2015	15:31	01/10/2015	17:28	181	21177	117	Underground equipment	Underground Primary	Switch/Reset	Repair	I
150102290	D69005	01/10/2015	15:34	01/10/2015	19:56	140	36680	262	Underground equipment	Switchgear	Switch/Reset	Repair	I
150102240	N58144	01/10/2015	15:44	01/10/2015	16:42	1	58	58	Unknown	Transformer Fuse	Replace - Same Size		I
150102273	D69005	01/10/2015	16:44	01/10/2015	20:52	19	4712	247	Underground equipment	Switchgear	Switch/Reset		I
150102276	D31018	01/10/2015	16:48	01/10/2015	18:17	1	89	89	Overhead equipment	Jumper	Repair		III
150102277	S47576	01/10/2015	16:54	01/10/2015	18:40	1	106	105	Overhead equipment	Guy Wire	Repair		VI
150102312	N35851	01/10/2015	18:05	01/10/2015	21:00	30	5250	175	Overhead equipment	Overhead Primary	Repair	Repair	V
150102336	P57463	01/10/2015	18:32	01/11/2015	16:32	1	1320	1319	Underground equipment	Underground Primary			VI
150102374	N73122	01/10/2015	20:12	01/10/2015	21:29	1	77	76	Overhead equipment	Transformer Fuse	Repair		IV
150102382	X22001	01/10/2015	20:40	01/10/2015	21:52	5	360	72	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
150110016	U42512	01/11/2015	2:31	01/11/2015	3:30	1	59	59	Overhead equipment	Connector	Repair	Repair	II
150110021	M19222	01/11/2015	3:58	01/11/2015	5:47	1	109	108	Overhead equipment	Jumper	Replace - New Size		VI
150110056	S24596	01/11/2015	8:18	01/11/2015	11:10	3	516	172	Overhead equipment	Disconnect Switch	Patrol/Test/Inspect	Replace - Same Size	VI
150110057	M22812	01/11/2015	8:19	01/11/2015	10:03	1	104	103	Animal related	Transformer Fuse	Replace - Same Size		V
150110117	Z17503	01/11/2015	8:59	01/11/2015	10:15	1	76	76	Animal related	Transformer Fuse	Replace - Same Size		IV
150110135	H07106	01/11/2015	9:48	01/11/2015	10:50	1	62	62	Animal related	Transformer Fuse	Repair		IV
150110187	S42578	01/11/2015	10:57	01/11/2015	12:04	1	67	66	Animal related	Transformer Fuse	Replace - Same Size	Replace - Same Size	VI
150110198	Q24313	01/11/2015	11:18	01/11/2015	15:48	1	270	270	Underground equipment	Underground Service	Repair	Repair	VI
150110211	N93260	01/11/2015	11:51	01/11/2015	17:05	1	314	313	Overhead equipment	Fuse			III
150110224	M81402	01/11/2015	12:39	01/11/2015	16:12	1	213	213	Overhead equipment	Underground Service	Patrol/Test/Inspect	Repair	V
150110233	V23530	01/11/2015	13:02	01/11/2015	15:00	7	826	117	Animal related	Transformer Fuse	Repair	Replace - Same Size	II
150110243	R06209	01/11/2015	13:33	01/11/2015	14:35	1	62	62	Tree related-tree contact	Overhead Service	Repair		II
150110247	V40556	01/11/2015	13:40	01/11/2015	14:41	5	305	60	Animal related	Transformer Fuse			II
150110321	N58144	01/11/2015	15:54	01/11/2015	19:13	1	199	198	Overhead equipment	Overhead Transformer	Replace - Same Size	Replace - Same Size	I
150110323	R06209	01/11/2015	16:00	01/11/2015	18:55	1	175	175	Underground equipment	Underground Service	Install	Repair	II
150110367	X86543	01/11/2015	17:51	01/11/2015	20:13	1	142	142	Tree related-tree broken	Overhead Service	Raise		IV
150110379	K39153	01/11/2015	18:13	01/11/2015	20:11	1	118	117	Unknown	Fuse	Replace - Same Size		III
150110400	K52400	01/11/2015	19:21	01/11/2015	23:33	1	252	251	Underground equipment	Underground Service	Patrol/Test/Inspect	Repair	V
150110406	A85001	01/11/2015	19:40	01/13/2015	6:44	1	2104	2103	Overhead equipment	Pole	Patrol/Test/Inspect	Replace - Same Size	I
150110414	S53542	01/11/2015	20:19	01/11/2015	21:11	1	52	52	Overhead equipment	Overhead Service	Advise Customer		VI
150110415	V58507	01/11/2015	20:31	01/11/2015	22:24	1	113	113	Overhead equipment	Transformer Fuse	Replace - Same Size	Replace - Same Size	II
150110420	M42107	01/11/2015	20:55	01/12/2015	0:02	1	187	186	Overhead equipment	Overhead Primary	Raise		I
150110457	Q27185	01/11/2015	21:46	01/12/2015	2:34	3	864	287	Overhead equipment	Overhead Primary		Replace - Same Size	VI
150120039	T15570	01/12/2015	0:09	01/12/2015	2:35	1	146	146	Animal related	Disconnect Switch	Patrol/Test/Inspect	Replace - Same Size	VI
150122107	C50001	01/12/2015	1:37	01/12/2015	9:18	3	1383	460	Underground equipment	Underground Transformer	Replace - Same Size		III
150120103	C50001	01/12/2015	1:37	01/12/2015	5:48	33	8283	251	Underground equipment	Underground Transformer	Switch/Reset	Repair	III
150120112	H06135	01/12/2015	2:20	01/12/2015	3:40	40	3200	80	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
150122090	R03413	01/12/2015	3:52	01/12/2015	4:29	1	37	36	Overhead equipment	Crossarm			III
5000581	K32935	01/12/2015	5:58	01/12/2015	10:45	1	286	286	Overhead equipment	Overhead Transformer	Replace - New Size	Repair	VI
150122154	U90566	01/12/2015	6:20	01/12/2015	7:42	348	28536	81	Overhead equipment	Overhead Primary	Repair		II
150122211	B25001	01/12/2015	7:21	01/12/2015	8:18	1	57	56	Overhead equipment	Connector	Replace - Same Size		I

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
150122422		01/12/2015	7:43	01/13/2015	7:31	1	1428	1428	Underground equipment	Underground Service	Patrol/Test/Inspect	Repair	I
150122472	342001	01/12/2015	7:57	01/12/2015	8:55	1	58	58	Animal related				VI
150122474	342003	01/12/2015	7:58	01/12/2015	8:55	1	57	57	Animal related				VI
150122510	S15558	01/12/2015	8:12	01/12/2015	9:30	1	78	78	Overhead equipment	Disconnect Switch	Patrol/Test/Inspect	Replace - Same Size	VI
150122587	Q14392	01/12/2015	8:21	01/12/2015	10:35	100	13400	133	Overhead equipment	Overhead Primary	Patrol/Test/Inspect	Repair	I
150122605	V40556	01/12/2015	8:34	01/12/2015	9:40	1	66	66	Overhead equipment	Overhead Service	Repair		II
150122607	P73182	01/12/2015	8:34	01/12/2015	9:00	1	26	26	Underground equipment	Meter			VI
150122655		01/12/2015	8:49	01/12/2015	9:20	1	31	31	Overhead equipment				III
150122678	P73182	01/12/2015	8:54	01/12/2015	9:55	1	61	60	Overhead equipment	Overhead Transformer	Repair		VI
150122713	K46388	01/12/2015	9:00	01/12/2015	9:47	2	94	46	Animal related	Fuse	Replace - Same Size		V
150122785	X57566	01/12/2015	9:01	01/12/2015	9:24	268	6164	23	Animal related	Substation Breaker	Switch/Reset		IV
150122795	N93260	01/12/2015	9:08	01/12/2015	11:25	11	1507	136	Animal related	Fuse		Replace - Same Size	III
150122760	V19001	01/12/2015	9:11	01/12/2015	11:16	1	125	124	Overhead equipment	Overhead Service	Repair		II
150122792	Z18553	01/12/2015	9:19	01/12/2015	11:10	3	333	111	Overhead equipment	Disconnect Switch	Repair		IV
150122817	X73002	01/12/2015	9:23	01/12/2015	11:45	1	142	142	Overhead equipment	Overhead Service	Repair	Repair	IV
150122818	Y60593	01/12/2015	9:24	01/12/2015	11:28	1	124	123	Animal related	Transformer Fuse	Replace - Same Size		IV
150122845	S41563	01/12/2015	9:31	01/12/2015	11:48	1	137	137	Overhead equipment	Connector	Patrol/Test/Inspect	Repair	VI
150122993	Q42953	01/12/2015	10:10	01/12/2015	10:58	1	48	47	Overhead equipment	Overhead Primary	Patrol/Test/Inspect	Repair	I
150123120	M31203	01/12/2015	10:38	01/12/2015	12:20	1	102	101	Underground equipment	Underground Transformer	Replace - Same Size		I
150123123	P85141	01/12/2015	10:38	01/12/2015	13:25	1	167	166	Underground equipment	Underground Secondary	Repair	Repair	III
150123264	L24123	01/12/2015	11:01	01/12/2015	11:33	67	2144	31	Overhead equipment	Fuse			III
150123297	D53002	01/12/2015	11:09	01/12/2015	12:40	1	91	91	Overhead equipment	Connector	Repair		I
150123433	R05186	01/12/2015	11:48	01/12/2015	13:13	1	85	84	Underground equipment	Underground Transformer	Repair	Tie/Tighten	I
150123471	S21529	01/12/2015	11:55	01/12/2015	14:10	1	135	135	Overhead equipment	Overhead Service	Repair	Repair	VI
150123562	J88163	01/12/2015	12:27	01/12/2015	16:52	17	4505	264	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	VI
150123739	L24121	01/12/2015	13:20	01/12/2015	13:51	1	31	30	Animal related	Fuse	Replace - Same Size		III
150123832	P53341	01/12/2015	13:45	01/12/2015	15:30	1	105	105	Overhead equipment	Overhead Service	Repair		IV
150123844	D93001	01/12/2015	13:49	01/12/2015	17:15	1	206	206	Underground equipment	Underground Service	Patrol/Test/Inspect		IV
150123968	J88163	01/12/2015	14:25	01/12/2015	16:52	1	147	146	Underground equipment	Underground Primary	Switch/Reset		VI
150124250	P82291	01/12/2015	14:27	01/12/2015	15:09	197	8274	42	Overhead equipment	Overhead Primary		Replace - Same Size	VI
150124106	J61110	01/12/2015	14:46	01/12/2015	15:38	38	1976	52	Public	Overhead Primary			III
150124163	N60181	01/12/2015	15:02	01/12/2015	15:31	1	29	29	Overhead equipment	Overhead Primary	Repair	Replace - Same Size	I
150124282	X02547	01/12/2015	15:33	01/12/2015	16:23	1	50	49	Overhead equipment	Overhead Service			IV
150124347	K95202	01/12/2015	16:08	01/12/2015	16:30	1	22	21	Overhead equipment	Connector	Replace - Same Size		III
150124399	D35003	01/12/2015	16:31	01/13/2015	5:25	1	774	773	Public	Underground Primary	Repair	Repair	I
150124425	J82117	01/12/2015	16:50	01/12/2015	17:40	1	50	49	Overhead equipment	Connector	Repair		VI
150124443	U01523	01/12/2015	17:05	01/12/2015	18:35	1	90	90	Overhead equipment	Overhead Primary	Repair	Repair	II
150124911	R61241	01/12/2015	18:01	01/12/2015	20:44	1	163	162	Underground equipment	Meter	Patrol/Test/Inspect	Repair	IV
150124917	D37003	01/12/2015	18:08	01/12/2015	20:05	1	117	116	Overhead equipment				I
150124931	343009	01/12/2015	18:26	01/12/2015	19:45	1	79	78	Overhead equipment	Fuse	Replace - Same Size		VI
150125402	Z57516	01/12/2015	20:06	01/12/2015	22:02	1	116	116	Overhead equipment	Meter			IV
150125408	C00002	01/12/2015	20:16	01/12/2015	21:50	1	94	93	Overhead equipment	Overhead Service	Repair		I
150125412	K31124	01/12/2015	20:23	01/12/2015	21:10	1	47	46	Overhead equipment	Overhead Primary	Repair		I
150125417	C70004	01/12/2015	20:36	01/12/2015	22:14	1	98	98	Overhead equipment	Overhead Service	Repair		III
150127257	K31124	01/12/2015	22:25	01/12/2015	23:45	71	5680	79	Overhead equipment	Overhead Primary	Repair		I
150127260	R33127	01/12/2015	22:41	01/13/2015	2:17	4	864	215	Unknown	Underground Service			I
150127265	T17581	01/12/2015	22:54	01/13/2015	0:46	1	112	111	Overhead equipment	Overhead Service	Repair	Replace - Same Size	VI
150130212	P60170	01/13/2015	2:54	01/13/2015	4:32	3	294	97	Tree related-tree broken				VI
150162828	U27001	01/13/2015	4:57	01/13/2015	7:02	125	15625	124	Overhead equipment	Fuse	Replace - Same Size		II
150132724	U10569	01/13/2015	4:57	01/13/2015	7:02	66	8250	124	Overhead equipment	Fuse	Replace - Same Size		II
150132689	M78325	01/13/2015	5:31	01/13/2015	13:23	1	472	471	Underground equipment	Underground Service	Repair	Repair	V
150132748	U41596	01/13/2015	6:15	01/13/2015	7:55	1	100	100	Overhead equipment	Jumper	Replace - Same Size		II
150132756	U33586	01/13/2015	6:43	01/13/2015	8:08	1	85	84	Overhead equipment	Disconnect Switch	Repair	Repair	II
150132852	X42502	01/13/2015	7:39	01/13/2015	9:08	1	89	89	Overhead equipment	Overhead Service	Repair		IV
150132882	K82202	01/13/2015	7:42	01/13/2015	9:16	322	30268	94	Public	Fuse		Repair	III
150132867	0	01/13/2015	7:45	01/13/2015	7:52	1	7	7	Underground equipment				I

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
150132879	X75571	01/13/2015	7:47	01/13/2015	9:45	1	118	117	Overhead equipment	Overhead Service	Repair	Repair	IV
150133210	D36003	01/13/2015	9:51	01/13/2015	10:20	1	29	29	Unknown	Fuse	Repair		I
150133317	B10002	01/13/2015	10:13	01/13/2015	11:33	34	2720	79	Public	Overhead Primary	Patrol/Test/Inspect		I
150133523	L74193	01/13/2015	11:12	01/13/2015	12:15	40	2520	62	Public	Pole			IV
150133538	P42229	01/13/2015	11:15	01/13/2015	11:37	12	264	21	Animal related	Transformer Fuse			VI
150133717	V61584	01/13/2015	12:06	01/13/2015	12:56	1	50	50	Overhead equipment	Connector	Repair		II
150133760	346001	01/13/2015	12:23	01/13/2015	14:30	1	127	126	Overhead equipment	Disconnect Switch	Patrol/Test/Inspect	Replace - New Size	VI
150133881	V36002	01/13/2015	13:01	01/13/2015	13:46	1	45	45	Underground equipment	Meter	Repair		II
150134052	J08205	01/13/2015	13:33	01/13/2015	14:52	8	632	78	Overhead equipment	Overhead Primary	Repair	Repair	I
150134158		01/13/2015	14:09	01/13/2015	19:29	1	320	319	Overhead equipment				V
150134178	M53312	01/13/2015	14:15	01/13/2015	17:56	2	442	220	Overhead equipment	Lightning Arrestor	Patrol/Test/Inspect	Repair	V
150134228	J34377	01/13/2015	14:25	01/13/2015	15:20	32	1760	55	Public	Underground Primary	Switch/Reset	Repair	V
150134328	S15559	01/13/2015	14:47	01/13/2015	16:35	44	4752	107	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	VI
150134338	P82291	01/13/2015	14:50	01/13/2015	19:27	12	3324	277	Tree related-tree broken	Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
150135314	J68401	01/13/2015	16:39	01/13/2015	21:52	39	12207	313	Overhead equipment	Overhead Primary	Repair		III
150134686	J68401	01/13/2015	16:39	01/13/2015	20:43	576	140544	243	Overhead equipment	Overhead Primary	Repair		III
150134765		01/13/2015	16:42	01/13/2015	17:24	3240	136080	42	Overhead equipment	Overhead Primary			I
150134870	346002	01/13/2015	17:22	01/13/2015	19:10	1	108	107	Overhead equipment	Connector	Replace - Same Size		VI
150134878	J61115	01/13/2015	17:29	01/13/2015	23:27	1	358	357	Overhead equipment	Overhead Service			III
150134902	V59003	01/13/2015	17:51	01/13/2015	18:48	1	57	56	Overhead equipment	Overhead Service	Repair		II
150140116	N18211	01/14/2015	1:25	01/14/2015	3:39	1	134	133	Overhead equipment	Jumper	Repair		III
5000641	R10943	01/14/2015	5:19	01/14/2015	6:34	1	74	74	Animal related	Fuse	Replace - Same Size		VI
150142845	M37192	01/14/2015	8:34	01/14/2015	9:42	1	68	68	Overhead equipment	Overhead Secondary	Repair		I
150142925	C65001	01/14/2015	9:06	01/14/2015	13:51	1	285	284	Underground equipment	Underground Service	Repair		III
150142994	N93260	01/14/2015	9:26	01/14/2015	11:53	11	1617	146	Animal related	Fuse		Replace - Same Size	III
150143057	Q83148	01/14/2015	9:46	01/14/2015	11:13	1	87	87	Tree related-tree broken	Overhead Service	Replace - Same Size	Replace - Same Size	VI
150143144	B73003	01/14/2015	10:08	01/14/2015	12:17	1	129	129	Overhead equipment	Connector	Replace - New Size		I
150143273	R33127	01/14/2015	10:44	01/14/2015	12:57	3	399	132	Public	Overhead Primary	Replace - Same Size	Repair	I
150143358	R33127	01/14/2015	11:06	01/14/2015	13:05	1	119	119	Public	Fuse	Replace - Same Size	Repair	I
150143487	J18268	01/14/2015	11:30	01/14/2015	12:30	111	6660	60	Public	Recloser	Switch/Reset		VI
150143499	Y79500	01/14/2015	11:49	01/14/2015	12:50	7	427	60	Animal related	Transformer Fuse	Replace - Same Size		IV
150143763	K65221	01/14/2015	13:16	01/14/2015	13:42	1	26	26	Overhead equipment	Overhead Secondary		Repair	III
150143804	Y69553	01/14/2015	13:26	01/14/2015	14:35	1	69	69	Overhead equipment	Overhead Service	Repair	Repair	IV
5000675	L59933	01/14/2015	16:13	01/14/2015	16:31	1	17	17	Unknown				VI
5000677	L59933	01/14/2015	16:39	01/14/2015	20:56	1	256	256	Overhead equipment	Overhead Transformer	Replace - Same Size	Repair	VI
150144393	B28004	01/14/2015	16:54	01/14/2015	18:38	1	104	103	Overhead equipment				I
150144396	B44002	01/14/2015	16:56	01/14/2015	17:46	1	50	49	Overhead equipment	Overhead Service	Repair		I
150144412	D72002	01/14/2015	17:05	01/14/2015	17:55	1	50	50	Overhead equipment	Connector	Replace - Same Size		I
150144447	K75311	01/14/2015	17:21	01/14/2015	18:38	1	77	76	Overhead equipment	Transformer Fuse	Replace - New Size		IV
5000681	R10943	01/14/2015	17:26	01/14/2015	18:52	1	85	85	Animal related	Fuse	Replace - Same Size		VI
150144477	Q80353	01/14/2015	17:38	01/14/2015	22:12	1	274	274	Overhead equipment	Jumper	Repair		V
150144514	S28552	01/14/2015	18:17	01/14/2015	19:41	1	84	84	Overhead equipment	Fuse	Replace - Same Size		VI
150144527	V36001	01/14/2015	18:34	01/14/2015	20:00	7	602	86	Overhead equipment	Transformer Fuse	Repair	Replace - Same Size	II
150144881	P54828	01/14/2015	20:28	01/15/2015	6:06	1	578	577	Overhead equipment	Underground Service		Repair	V
5000683	L62928	01/14/2015	20:50	01/15/2015	4:13	1	442	442	Public	Meter	Disconnect		VI
150145166	K26136	01/14/2015	22:22	01/15/2015	0:09	1	107	107	Overhead equipment	Connector	Replace - New Size		VI
150152175	Q74148	01/15/2015	4:13	01/15/2015	6:29	1	136	136	Overhead equipment	Jumper	Repair		IV
150152271	S22592	01/15/2015	7:11	01/15/2015	8:00	1	49	49	Overhead equipment				VI
150152323	F22002	01/15/2015	7:37	01/15/2015	8:31	1	54	53	Overhead equipment	Fuse	Repair		IV
5000689	Q64918	01/15/2015	7:40	01/15/2015	8:13	1	33	33	Animal related	Transformer Fuse	Repair		VI
150152406	R49275	01/15/2015	8:07	01/15/2015	10:50	7	1141	163	Animal related	Fuse		Replace - Same Size	VI
150152482	P73182	01/15/2015	8:47	01/15/2015	12:40	1	233	233	Overhead equipment	Overhead Transformer		Replace - Same Size	VI
150152705	L93148	01/15/2015	9:37	01/15/2015	10:38	78	4697	61	Underground equipment	Underground Primary	Repair	Repair	VI
150152797	K73361	01/15/2015	9:58	01/15/2015	11:45	569	60883	107	Underground equipment	Underground Primary		Repair	IV
150152830	S93553	01/15/2015	10:06	01/15/2015	11:12	1	66	66	Overhead equipment	Connector	Repair		VI
150152861	X96524	01/15/2015	10:09	01/15/2015	11:00	15	765	50	Overhead equipment	Overhead Primary	Repair	Patrol/Test/Inspect	IV

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
150153054	R04412	01/15/2015	11:07	01/15/2015	11:50	12	516	43	Animal related	Fuse	Replace - Same Size		V
150153151	U31542	01/15/2015	11:36	01/15/2015	13:48	1	132	132	Overhead equipment	Connector	Repair		II
150153307	J71128	01/15/2015	12:31	01/15/2015	13:15	1	44	44	Overhead equipment	Overhead Secondary	Repair		I
150153674	M18131	01/15/2015	14:07	01/15/2015	14:36	1	29	29	Animal related	Transformer Fuse	Replace - Same Size		III
150153809	Q18245	01/15/2015	14:45	01/15/2015	15:34	1	49	48	Animal related	Transformer Fuse	Replace - Same Size		VI
150153817	P82291	01/15/2015	14:47	01/15/2015	15:42	1	55	55	Animal related	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
150153949	D67001	01/15/2015	15:14	01/15/2015	15:52	1	38	37	Overhead equipment	Transformer Fuse	Repair		IV
150154007	R49261	01/15/2015	15:37	01/15/2015	16:06	1	29	29	Animal related	Transformer Fuse	Replace - Same Size		VI
150154053	N44217	01/15/2015	15:52	01/15/2015	17:00	1	68	68	Overhead equipment	Connector			III
150154062	Y51505	01/15/2015	15:57	01/15/2015	16:56	1	59	59	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
150154628	S86592	01/15/2015	17:45	01/15/2015	19:28	1	103	103	Overhead equipment	Overhead Service	Patrol/Test/Inspect	Repair	VI
150154631	M36189	01/15/2015	17:50	01/15/2015	20:00	1	130	130	Overhead equipment	Fuse	Repair	Replace - Same Size	I
150154692	Q18245	01/15/2015	18:21	01/15/2015	20:26	230	28750	125	Overhead equipment	Overhead Primary	Replace - Same Size	Repair	VI
150155147	J80807	01/15/2015	19:17	01/15/2015	20:07	1	50	49	Overhead equipment	Overhead Service	Repair	Repair	V
150155206	B65003	01/15/2015	19:22	01/15/2015	20:04	1	42	42	Overhead equipment	Overhead Service	Repair		I
150155286	Q18245	01/15/2015	20:34	01/15/2015	21:18	11	484	43	Overhead equipment	Overhead Primary		Repair	VI
150155685	R23332	01/15/2015	21:44	01/16/2015	0:20	1	156	156	Underground equipment	Underground Service	Patrol/Test/Inspect	Repair	V
150155699	303004	01/15/2015	22:13	01/16/2015	4:55	15	6030	402	Public	Pole	Patrol/Test/Inspect	Replace - New Size	VI
5000719	Q64918	01/15/2015	22:37	01/15/2015	23:31	6	318	53	Overhead equipment	Fuse	Replace - Same Size		VI
150162796	N42856	01/16/2015	5:35	01/16/2015	7:12	1	97	97	Overhead equipment	Connector	Replace - Same Size		V
150162867	R23332	01/16/2015	7:15	01/16/2015	11:20	1	245	244	Underground equipment	Pedestal	Repair	Repair	V
150162899	U02597	01/16/2015	7:31	01/16/2015	9:45	1	134	133	Overhead equipment	Overhead Primary	Repair	Patrol/Test/Inspect	II
150162962	B00004	01/16/2015	7:58	01/16/2015	8:54	1	56	56	Overhead equipment	Connector	Replace - Same Size		I
150163010	R02121	01/16/2015	8:15	01/16/2015	9:40	1	85	85	Overhead equipment	Connector	Repair		VI
150163009	Q21321	01/16/2015	8:16	01/16/2015	9:38	1	82	81	Animal related	Transformer Fuse	Replace - Same Size		VI
150163039	G10002	01/16/2015	8:24	01/16/2015	10:25	1	121	121	Overhead equipment				I
150163129	M47816	01/16/2015	8:45	01/16/2015	9:30	1	45	45	Animal related	Fuse	Repair	Repair	V
150163298	M37191	01/16/2015	9:24	01/16/2015	10:00	28	1008	35	Public	Fuse	Replace - Same Size	Patrol/Test/Inspect	I
150163335	R71286	01/16/2015	9:40	01/16/2015	10:30	1	50	49	Animal related	Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
150163651	P07179	01/16/2015	10:38	01/16/2015	11:32	9	486	53	Overhead equipment	Fuse	Replace - Same Size	Patrol/Test/Inspect	I
150163704	Q23258	01/16/2015	10:53	01/16/2015	12:05	30	2160	71	Animal related	Underground Primary	Switch/Reset	Repair	VI
150163797	Q01282	01/16/2015	11:19	01/16/2015	11:59	1	40	39	Overhead equipment	Transformer Fuse	Repair	Repair	III
150163822	Z05001	01/16/2015	11:25	01/16/2015	12:30	1	65	65	Overhead equipment	Connector	Replace - Same Size		IV
150163835	M81402	01/16/2015	11:30	01/16/2015	12:30	1	60	60	Animal related	Transformer Fuse	Replace - Same Size		V
150163906	K01238	01/16/2015	11:40	01/16/2015	12:53	31	2263	73	Underground equipment				VI
150164077	U02597	01/16/2015	11:50	01/16/2015	13:05	20	1500	75	Unknown	Fuse	Replace - Same Size	Patrol/Test/Inspect	II
150163956	L99392	01/16/2015	12:10	01/16/2015	12:50	1	40	39	Animal related	Fuse	Replace - Same Size	Replace - Same Size	V
150163964	V40556	01/16/2015	12:14	01/16/2015	13:27	1	73	72	Overhead equipment	Connector	Repair		II
150163971	V36001	01/16/2015	12:16	01/16/2015	13:22	1	66	65	Overhead equipment	Transformer Fuse	Replace - Same Size		II
150164066	V36001	01/16/2015	12:41	01/16/2015	13:28	1	47	47	Overhead equipment	Transformer Fuse	Replace - Same Size		II
150164331	K73361	01/16/2015	13:08	01/16/2015	14:06	73	4234	58	Overhead equipment	Fuse	Replace - Same Size		IV
150164177	S47575	01/16/2015	13:16	01/16/2015	14:00	20	880	44	Animal related	Fuse			VI
150164214	Y23513	01/16/2015	13:30	01/16/2015	14:20	10	500	49	Animal related	Transformer Fuse	Replace - Same Size		IV
150164349	S47575	01/16/2015	14:17	01/16/2015	15:10	1	53	53	Animal related	Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
150164397	D89001	01/16/2015	14:32	01/16/2015	15:00	1	28	27	Overhead equipment	Connector	Repair		I
150164510	R53416	01/16/2015	15:13	01/16/2015	19:55	1	282	281	Overhead equipment	Overhead Transformer	Replace - Same Size		V
150164535	K94224	01/16/2015	15:26	01/16/2015	16:10	1	44	43	Tree related-tree contact	Overhead Service	Repair		III
150164560	P47123	01/16/2015	15:38	01/16/2015	20:00	1	262	262	Underground equipment	Underground Primary	Repair	Replace - Same Size	I
150164573	T09559	01/16/2015	15:43	01/16/2015	17:30	1	107	106	Overhead equipment	Disconnect Switch	Patrol/Test/Inspect	Repair	VI
150164605	Q18242	01/16/2015	15:55	01/16/2015	17:12	1	77	76	Animal related	Transformer Fuse	Replace - Same Size		VI
150164815	IP7008	01/16/2015	16:06	01/16/2015	17:24	2052	160056	78	Public				IV
150164918	IP7008	01/16/2015	16:06	01/16/2015	16:40	1750	59500	34	Public	Pole	Repair		IV
150164853	X75571	01/16/2015	16:32	01/16/2015	18:10	1	98	98	Overhead equipment	Jumper	Repair	Repair	IV
150164952	Q85162	01/16/2015	17:06	01/16/2015	19:45	1	159	158	Underground equipment	Underground Service	Patrol/Test/Inspect	Repair	VI
150165284	M19222	01/16/2015	17:48	01/16/2015	19:09	1	81	81	Animal related	Transformer Fuse	Replace - Same Size		VI
150165326	324001	01/16/2015	18:47	01/16/2015	22:00	1	193	193	Overhead equipment	Overhead Transformer		Replace - New Size	VI

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
150165327	B80004	01/16/2015	18:49	01/16/2015	19:47	1	58	58	Overhead equipment				I
150170016	J84124	01/16/2015	22:01	01/17/2015	9:40	1	699	699	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	VI
150165926	J84124	01/16/2015	22:01	01/17/2015	1:00	6	1074	178	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	VI
150170018	S49549	01/17/2015	1:31	01/17/2015	2:42	1	71	71	Overhead equipment	Fuse	Replace - Same Size		VI
150170022	P69173	01/17/2015	1:52	01/17/2015	4:05	48	6384	133	Public	Guy Wire		Repair	III
150170127	B19002	01/17/2015	8:19	01/17/2015	9:07	1	48	47	Overhead equipment	Disconnect Switch	Replace - Same Size	Replace - Same Size	I
150170128	Y23521	01/17/2015	8:23	01/17/2015	9:52	7	623	88	Public	Transformer Fuse	Repair	Replace - Same Size	IV
150170133	H14343	01/17/2015	8:31	01/17/2015	9:18	1	47	46	Animal related	Transformer Fuse	Replace - Same Size		V
150170216	V69558	01/17/2015	9:13	01/17/2015	10:37	3	252	84	Animal related	Transformer Fuse	Replace - Same Size		II
150170157	Q16867	01/17/2015	9:17	01/17/2015	11:26	1	129	129	Overhead equipment	Overhead Service	Repair		V
150170166	M26161	01/17/2015	9:18	01/17/2015	10:06	32	1536	47	Animal related	Fuse	Replace - Same Size		III
5000761	Q67948	01/17/2015	10:17	01/17/2015	11:27	85	5950	69	Animal related	Recloser	Replace - Same Size		VI
5000771	Q67938	01/17/2015	10:29	01/17/2015	11:32	1	62	62	Animal related	Recloser			VI
150170213	L12125	01/17/2015	10:35	01/17/2015	11:50	22	1650	75	Animal related	Fuse	Replace - Same Size		III
150170252	C10002	01/17/2015	11:33	01/17/2015	12:29	1	56	56	Overhead equipment	Overhead Service	Repair		III
150170268	U61001	01/17/2015	11:56	01/17/2015	14:23	1	147	147	Overhead equipment	Overhead Service	Repair		II
150170276	V13510	01/17/2015	12:12	01/17/2015	13:40	1	88	88	Tree related-tree broken	Transformer Fuse	Replace - Same Size		II
150170281	V46521	01/17/2015	12:15	01/17/2015	14:18	1	123	123	Overhead equipment	Overhead Primary	Repair		II
150170279	U62001	01/17/2015	12:15	01/17/2015	13:17	5	310	62	Overhead equipment	Transformer Fuse	Replace - Same Size		II
150170431	L24416	01/17/2015	12:29	01/17/2015	13:16	1927	90569	46	Animal related				III
150170689	L24416	01/17/2015	12:29	01/17/2015	13:06	1788	66156	36	Animal related				III
150170427	K52401	01/17/2015	12:31	01/17/2015	18:35	6	2184	364	Overhead equipment	Crossarm	Patrol/Test/Inspect	Replace - Same Size	V
150170442	L93148	01/17/2015	12:59	01/17/2015	14:06	1	67	66	Animal related	Fuse	Replace - Same Size		VI
150170447	M05360	01/17/2015	13:10	01/17/2015	14:05	1	55	55	Overhead equipment	Transformer Fuse	Replace - Same Size		V
150170452	P72318	01/17/2015	13:13	01/17/2015	14:19	1	66	66	Overhead equipment	Connector	Replace - Same Size	Repair	V
150170953	U97528	01/17/2015	17:33	01/17/2015	18:30	1	57	57	Animal related	Transformer Fuse	Replace - Same Size	Replace - Same Size	II
150170965	M09144	01/17/2015	18:05	01/17/2015	22:00	1	235	235	Overhead equipment	Overhead Secondary		Repair	VI
150170984	B93003	01/17/2015	18:47	01/17/2015	20:32	1	105	105	Overhead equipment	Fuse	Replace - Same Size		I
150171004	R48167	01/17/2015	20:24	01/17/2015	22:01	1	97	97	Overhead equipment	Overhead Service	Repair		IV
150171032	X09594	01/17/2015	21:02	01/17/2015	23:00	38	4484	118	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	IV
150171046	X60597	01/17/2015	22:21	01/18/2015	0:20	1	119	119	Underground equipment	Underground Service	Repair	Repair	IV
150180042	T15571	01/18/2015	2:16	01/18/2015	4:49	213	32589	152	Public	Pole	Repair		VI
150180168	T15571	01/18/2015	5:30	01/18/2015	11:27	74	26418	357	Public	Pole			VI
150180055	P77237	01/18/2015	6:35	01/18/2015	7:35	1	60	59	Overhead equipment	Overhead Primary	Patrol/Test/Inspect	Repair	VI
150180061	T28561	01/18/2015	7:11	01/18/2015	9:02	1	111	110	Overhead equipment	Disconnect Switch			VI
150180083	X23516	01/18/2015	8:17	01/18/2015	9:28	1	71	71	Animal related	Transformer Fuse	Replace - Same Size		IV
150180087	R49275	01/18/2015	8:23	01/18/2015	9:23	1	60	59	Animal related	Transformer Fuse	Replace - Same Size		VI
150180106	P42229	01/18/2015	9:00	01/18/2015	9:57	1	57	56	Animal related	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
150180116	Q80353	01/18/2015	9:32	01/18/2015	10:08	1	36	36	Animal related	Transformer Fuse	Replace - Same Size	Replace - Same Size	V
150180127	L99392	01/18/2015	9:48	01/18/2015	10:59	1	71	71	Animal related	Transformer Fuse	Replace - Same Size	Replace - Same Size	V
150180130	A91002	01/18/2015	9:55	01/18/2015	12:35	1	160	159	Animal related	Underground Primary	Replace - Same Size	Replace - Same Size	I
150180138	J18268	01/18/2015	10:26	01/18/2015	11:10	1	44	44	Animal related	Transformer Fuse	Replace - Same Size		VI
150180174	J80807	01/18/2015	11:27	01/18/2015	13:11	1	104	104	Overhead equipment	Overhead Primary	Replace - Same Size	Replace - Same Size	V
150180195	T15571	01/18/2015	11:28	01/18/2015	11:46	119	2142	17	Underground equipment	Underground Primary			VI
150180203	C66001	01/18/2015	11:36	01/18/2015	14:15	103	16377	159	Unknown	Fuse	Replace - Same Size		III
150180212	L24122	01/18/2015	12:06	01/18/2015	13:28	2	164	82	Overhead equipment	Overhead Transformer			III
150180337	A97001	01/18/2015	12:07	01/18/2015	16:12	7	1715	245	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
150180215	S64501	01/18/2015	12:18	01/18/2015	16:28	1	250	250	Public	Pole	Patrol/Test/Inspect	Replace - New Size	VI
150180216	J80807	01/18/2015	12:19	01/18/2015	14:53	1	154	153	Animal related	Transformer Fuse	Repair	Repair	V
150180223	Q85162	01/18/2015	12:35	01/18/2015	13:49	1	74	74	Animal related	Transformer Fuse	Repair	Repair	VI
150180340	S14511	01/18/2015	13:20	01/18/2015	17:20	3	720	239	Overhead equipment	Overhead Transformer			VI
150180341	J18267	01/18/2015	13:22	01/18/2015	14:59	1	97	97	Overhead equipment	Overhead Service	Repair		VI
150180350	P73157	01/18/2015	13:45	01/18/2015	14:34	1	49	49	Animal related	Fuse	Replace - Same Size		VI
150180367	P49180	01/18/2015	14:24	01/18/2015	15:37	2	146	72	Animal related	Fuse			I
150180366	N05172	01/18/2015	14:24	01/18/2015	15:35	1	71	71	Animal related	Transformer Fuse	Repair		I
150180381	E10003	01/18/2015	15:14	01/18/2015	16:15	1	61	60	Animal related	Other	Patrol/Test/Inspect	Patrol/Test/Inspect	III

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
150180382	J18268	01/18/2015	15:16	01/18/2015	20:45	1	329	329	Underground equipment	Underground Service	Repair	Repair	VI
150180386	J47178	01/18/2015	15:16	01/18/2015	18:45	80	16720	209	Underground equipment	Underground Primary	Switch/Reset	Repair	III
150180409	L86175	01/18/2015	16:01	01/18/2015	16:54	6	318	53	Animal related	Transformer Fuse	Replace - Same Size		IV
150180438	L12126	01/18/2015	17:25	01/18/2015	23:16	26	9126	351	Underground equipment	Underground Service	Patrol/Test/Inspect	Repair	III
150180460	H10843	01/18/2015	18:19	01/18/2015	20:07	1	108	107	Animal related	Transformer Fuse	Replace - Same Size		V
150180503	C37002	01/18/2015	19:57	01/18/2015	22:11	1	134	133	Underground equipment	Underground Service	Repair		III
150180521	R05114	01/18/2015	20:52	01/18/2015	23:05	15	1995	133	Overhead equipment	Overhead Secondary	Repair		I
150190032	N67312	01/19/2015	0:06	01/19/2015	1:40	1	94	94	Public	Overhead Transformer	Switch/Reset		I
150192046	J07135	01/19/2015	4:06	01/19/2015	9:49	1	343	343	Overhead equipment	Fuse	Patrol/Test/Inspect		I
150192060	L12125	01/19/2015	4:22	01/19/2015	7:32	5	950	190	Overhead equipment	Overhead Transformer	Replace - Same Size		III
150192049	L12125	01/19/2015	4:22	01/19/2015	5:57	63	5985	95	Overhead equipment	Fuse	Replace - Same Size		III
150192274	L12125	01/19/2015	4:22	01/19/2015	9:11	10	2890	289	Overhead equipment	Jumper	Repair		III
150192051	K30204	01/19/2015	4:45	01/19/2015	6:40	2	230	115	Unknown	Transformer Fuse	Replace - Same Size		III
150192091	J18268	01/19/2015	6:21	01/19/2015	9:20	140	25060	179	Overhead equipment	Overhead Primary	Patrol/Test/Inspect	Repair	VI
150192105	J83138	01/19/2015	6:59	01/19/2015	8:16	1	77	76	Animal related	Transformer Fuse	Replace - Same Size		VI
150192223	K01239	01/19/2015	7:54	01/19/2015	8:28	8	272	33	Animal related	Fuse			VI
150192260	K76543	01/19/2015	8:16	01/19/2015	9:44	1	88	87	Public	Overhead Service	Replace - Same Size		IV
150192298	P57101	01/19/2015	8:32	01/19/2015	11:49	4	788	196	Overhead equipment	Overhead Secondary	Repair	Repair	VI
150192326	J06167	01/19/2015	8:41	01/19/2015	10:10	1	89	88	Overhead equipment	Transformer Fuse	Replace - Same Size		I
150192346	Q01282	01/19/2015	8:48	01/19/2015	9:03	1	15	14	Jurisdictional	Recloser			III
150192611	S61529	01/19/2015	8:58	01/19/2015	12:39	24	5304	220	Underground equipment	Underground Primary	Switch/Reset	Repair	VI
150192401	S61529	01/19/2015	8:58	01/19/2015	9:25	121	3267	26	Underground equipment	Underground Primary	Switch/Reset		VI
150192506	X83533	01/19/2015	9:47	01/19/2015	10:49	1	62	62	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
150192527	X88510	01/19/2015	9:53	01/19/2015	10:55	1	62	61	Animal related	Transformer Fuse	Replace - Same Size		IV
150192647	S01511	01/19/2015	10:45	01/19/2015	11:20	1	35	34	Overhead equipment	Transformer Fuse	Repair	Replace - Same Size	VI
150192649	Z10500	01/19/2015	10:46	01/19/2015	12:20	1	94	94	Animal related	Fuse	Repair	Replace - Same Size	IV
150192650	R73840	01/19/2015	10:46	01/19/2015	12:51	1	125	124	Tree related-tree contact	Overhead Service	Repair		V
150192668	N35852	01/19/2015	10:54	01/19/2015	11:29	1	35	34	Overhead equipment	Transformer Fuse	Replace - Same Size		V
150192689	D55001	01/19/2015	10:59	01/19/2015	11:38	15	585	39	Unknown	Disconnect Switch	Replace - Same Size	Replace - Same Size	I
150192694	U10525	01/19/2015	11:02	01/19/2015	11:43	1	41	40	Animal related	Fuse	Replace - Same Size		II
150192772	V22555	01/19/2015	11:34	01/19/2015	11:44	44	440	10	Jurisdictional	Underground Primary	Switch/Reset		II
150192774	U68581	01/19/2015	11:41	01/19/2015	12:04	1	23	23	Animal related	Transformer Fuse	Replace - Same Size		II
150192792	A50001	01/19/2015	11:45	01/19/2015	12:54	115	7935	68	Public	Underground Primary	Repair		I
150192868	R53390	01/19/2015	12:25	01/19/2015	13:10	30	1350	45	Animal related	Fuse	Replace - Same Size	Replace - Same Size	V
150192905	V21500	01/19/2015	12:53	01/19/2015	13:27	3	102	33	Animal related	Transformer Fuse	Repair		II
150192917	B45003	01/19/2015	12:56	01/19/2015	14:18	1	82	81	Overhead equipment				I
150192930	P71830	01/19/2015	12:59	01/19/2015	13:55	9	504	55	Animal related	Transformer Fuse	Replace - Same Size		V
150192950	N19371	01/19/2015	13:08	01/19/2015	15:43	1	155	155	Underground equipment	Underground Secondary		Repair	V
150193123	M22812	01/19/2015	14:35	01/19/2015	15:55	1	80	79	Intentional	Meter	Replace - Same Size		V
150193140	Q85162	01/19/2015	14:47	01/19/2015	15:16	1	29	29	Animal related	Transformer Fuse	Replace - Same Size		VI
150193165	U06524	01/19/2015	15:01	01/19/2015	16:01	7	420	59	Animal related	Transformer Fuse	Repair		II
150193605	Y07576	01/19/2015	15:19	01/19/2015	23:36	6	2982	496	Underground equipment	Underground Transformer	Replace - Same Size	Replace - Same Size	IV
150193198	Y07576	01/19/2015	15:19	01/19/2015	19:00	15	3315	220	Underground equipment	Underground Transformer	Replace - Same Size	Replace - Same Size	IV
150193197	D93002	01/19/2015	15:22	01/19/2015	18:00	6	948	158	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	IV
150193323	K69117	01/19/2015	16:44	01/19/2015	17:18	1	34	33	Animal related	Transformer Fuse	Replace - Same Size		IV
150193443	R33126	01/19/2015	16:53	01/19/2015	18:53	21	2520	120	Overhead equipment	Recloser	Replace - Same Size	Patrol/Test/Inspect	I
150193381	Q36410	01/19/2015	17:11	01/19/2015	21:31	1	260	259	Underground equipment	Underground Service	Repair	Repair	I
150193514		01/19/2015	17:28	01/19/2015	18:53	1	85	85	Overhead equipment	Recloser	Replace - Same Size	Patrol/Test/Inspect	I
150193542	E10002	01/19/2015	17:58	01/19/2015	19:25	1	87	87	Animal related	Other	Patrol/Test/Inspect	Patrol/Test/Inspect	III
150194439	J61119	01/19/2015	21:17	01/19/2015	22:30	1	73	72	Public	Pole			III
150194460	K43386	01/19/2015	22:59	01/20/2015	0:31	1	92	91	Overhead equipment	Connector	Repair		V
150200126	Y66557	01/20/2015	0:53	01/20/2015	3:12	12	1668	138	Overhead equipment	Overhead Primary	Repair	Patrol/Test/Inspect	IV
150203036	R04407	01/20/2015	3:02	01/20/2015	8:00	29	8642	298	Underground equipment	Underground Primary		Repair	V
150203037	K28180	01/20/2015	3:17	01/20/2015	7:45	1	268	267	Public	Pole	Patrol/Test/Inspect	Replace - Same Size	III
150203038	J07173	01/20/2015	3:20	01/20/2015	5:00	1	100	100	Animal related	Transformer Fuse	Replace - Same Size		I
150203077	A48005	01/20/2015	6:16	01/20/2015	6:56	1	40	40	Animal related	Other	Patrol/Test/Inspect		I

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
150203194	K27150	01/20/2015	7:39	01/20/2015	9:00	14	1134	81	Animal related	Transformer Fuse	Replace - Same Size	Replace - Same Size	VI
150203323	M37192	01/20/2015	8:37	01/20/2015	9:10	2	66	33	Overhead equipment	Overhead Secondary	Repair		I
150203396	R95520	01/20/2015	8:41	01/20/2015	14:12	1	331	330	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Repair	I
150203443	K28183	01/20/2015	8:56	01/20/2015	9:52	1	56	56	Overhead equipment	Jumper	Repair		III
150203636	Y51506	01/20/2015	9:40	01/20/2015	10:28	7	336	47	Animal related	Transformer Fuse	Replace - Same Size		IV
150203749	R41131	01/20/2015	10:05	01/20/2015	11:11	1	66	65	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	VI
150203860	R05115	01/20/2015	10:22	01/20/2015	11:30	1	68	68	Overhead equipment	Transformer Fuse	Replace - Same Size	Patrol/Test/Inspect	I
150204061	C66001	01/20/2015	11:02	01/20/2015	11:47	1	45	45	Animal related	Transformer Fuse	Replace - Same Size		III
150204288	Y93003	01/20/2015	11:51	01/20/2015	12:26	1	35	34	Overhead equipment	Connector	Repair	Replace - Same Size	IV
150204303	K89142	01/20/2015	11:56	01/20/2015	12:38	1	42	42	Animal related	Fuse	Repair		III
150204374	Y51505	01/20/2015	12:17	01/20/2015	12:40	2	46	23	Animal related	Transformer Fuse	Replace - Same Size		IV
150204604	N67309	01/20/2015	13:15	01/20/2015	13:59	1	44	43	Overhead equipment	Transformer Fuse	Replace - Same Size		I
150204766	V47001	01/20/2015	13:51	01/20/2015	15:02	1	71	71	Overhead equipment	Transformer Fuse	Repair	Repair	II
150204804	M40131	01/20/2015	13:56	01/20/2015	14:30	1	34	33	Underground equipment	Underground Service			I
150204854	D87001	01/20/2015	14:06	01/20/2015	15:27	1	81	81	Overhead equipment	Disconnect Switch	Reconnect		I
150205004	M51275	01/20/2015	14:37	01/20/2015	15:54	301	23177	76	Unknown	Recloser			III
150205045	V61584	01/20/2015	14:52	01/20/2015	16:42	1	110	110	Overhead equipment	Overhead Service	Replace - New Size		II
150205263	M81404	01/20/2015	15:02	01/20/2015	15:50	12	576	47	Animal related	Fuse	Replace - Same Size		V
150205115	J87111	01/20/2015	15:09	01/20/2015	18:12	1	183	182	Public	Overhead Service		Replace - Same Size	VI
150205190	N35851	01/20/2015	15:30	01/20/2015	18:36	1	186	185	Overhead equipment	Overhead Transformer			V
150205243	H11339	01/20/2015	15:45	01/20/2015	16:44	1	59	59	Animal related	Fuse	Replace - Same Size		V
150205206	M51275	01/20/2015	16:05	01/20/2015	16:36	112	3472	30	Animal related	Other			III
150205387	K39154	01/20/2015	16:40	01/20/2015	18:10	1	90	90	Tree related-tree contact	Fuse	Replace - Same Size		III
150205404	R60551	01/20/2015	16:51	01/20/2015	21:30	1	279	279	Underground equipment				IV
5000887	K32916	01/20/2015	17:00	01/20/2015	19:17	1	136	136	Tree related-tree broken	Overhead Service			VI
150205530	IP9009	01/20/2015	17:38	01/20/2015	18:25	1	47	46	Overhead equipment	Overhead Service	Repair		VI
150205631	P17108	01/20/2015	19:35	01/20/2015	22:12	22	3454	157	Tree related-tree broken	Overhead Primary		Trim	IV
150205662	A26006	01/20/2015	20:58	01/20/2015	22:11	1	73	72	Overhead equipment	Connector	Replace - Same Size		I
150205973	M78325	01/20/2015	21:41	01/21/2015	3:30	17	5933	349	Underground equipment	Underground Primary	Switch/Reset	Switch/Reset	V
150213101	A17026	01/21/2015	5:45	01/21/2015	8:27	7	1134	161	Overhead equipment	Overhead Transformer	Replace - Same Size	Repair	I
150213130	M19222	01/21/2015	6:52	01/21/2015	8:24	1	92	91	Overhead equipment	Transformer Fuse	Repair	Repair	VI
150213324	P18104	01/21/2015	8:19	01/21/2015	9:07	1	48	47	Overhead equipment	Jumper		Repair	IV
150213530	J89126	01/21/2015	9:18	01/21/2015	10:08	1	50	50	Overhead equipment	Transformer Fuse	Repair	Repair	VI
150214031	X72535	01/21/2015	11:29	01/21/2015	13:15	6	636	105	Overhead equipment	Overhead Secondary	Repair		IV
150214039	H01194	01/21/2015	11:33	01/21/2015	13:34	1	121	121	Overhead equipment	Transformer Fuse	Replace - Same Size		III
150214239	M26161	01/21/2015	12:35	01/21/2015	13:27	23	1196	52	Animal related	Fuse	Replace - Same Size		III
150214272	F10001	01/21/2015	12:46	01/21/2015	14:02	1	76	75	Overhead equipment	Fuse	Replace - Same Size		III
150214339	K22173	01/21/2015	13:07	01/21/2015	13:40	6	198	33	Animal related	Fuse	Repair	Repair	VI
150214404	B65003	01/21/2015	13:25	01/21/2015	14:49	1	84	83	Overhead equipment	Connector	Replace - Same Size		I
150214486	P49187	01/21/2015	13:44	01/21/2015	15:10	1	86	85	Overhead equipment	Transformer Fuse	Replace - Same Size		I
150214579	L70127	01/21/2015	14:05	01/21/2015	19:51	40	13840	345	Underground equipment	Underground Secondary	Repair		IV
150214677	J89125	01/21/2015	14:44	01/21/2015	20:32	1	348	348	Underground equipment	Underground Service	Repair		VI
150215034	U45536	01/21/2015	16:38	01/21/2015	18:00	1	82	81	Animal related	Transformer Fuse	Replace - Same Size		II
150215170	Q32170	01/21/2015	17:46	01/21/2015	20:17	1	151	150	Overhead equipment	Connector	Replace - Same Size	Repair	I
5000943	K67924	01/21/2015	18:16	01/21/2015	20:00	1	103	103	Overhead equipment	Fuse		Patrol/Test/Inspect	VI
150215202	M21134	01/21/2015	18:34	01/21/2015	19:17	6	258	43	Tree related-tree broken	Transformer Fuse	Replace - Same Size		VI
150215822	S47585	01/21/2015	21:49	01/21/2015	22:41	1	52	52	Overhead equipment	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
150215823	M36185	01/21/2015	21:57	01/22/2015	0:28	1	151	150	Underground equipment	Underground Service	Repair	Replace - Same Size	I
150215835	Y96564	01/21/2015	22:29	01/22/2015	5:15	1	406	406	Underground equipment	Underground Primary	Repair	Repair	IV
150220166	K55397	01/22/2015	2:20	01/22/2015	7:10	14	4060	290	Underground equipment	Underground Primary	Patrol/Test/Inspect	Patrol/Test/Inspect	V
150222662	K73361	01/22/2015	6:38	01/22/2015	7:40	73	4526	62	Public	Fuse	Patrol/Test/Inspect	Replace - Same Size	IV
150222765	Z17503	01/22/2015	7:27	01/22/2015	8:45	1	78	78	Animal related	Transformer Fuse	Replace - Same Size		IV
150222941	338006	01/22/2015	8:30	01/22/2015	14:00	1	330	330	Overhead equipment	Pole	Patrol/Test/Inspect	Repair	VI
150223061	R49261	01/22/2015	9:04	01/22/2015	10:24	1	80	79	Animal related	Transformer Fuse	Replace - Same Size		VI
150223073	M26161	01/22/2015	9:08	01/22/2015	10:24	1	76	75	Overhead equipment	Overhead Service	Repair		III
150223175	L68114	01/22/2015	9:22	01/22/2015	10:11	7	343	49	Tree related-tree contact	Fuse			IV

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
150223220	L68114	01/22/2015	9:41	01/22/2015	10:13	1	32	31	Tree related-tree contact	Transformer Fuse			IV
150223245	C70004	01/22/2015	9:47	01/22/2015	10:16	7	203	29	Animal related	Fuse	Replace - Same Size		III
150223470	V37583	01/22/2015	10:34	01/22/2015	10:40	350	2100	5	Jurisdictional				II
150223503	D88001	01/22/2015	10:46	01/22/2015	14:25	1	219	219	Underground equipment	Underground Service	Repair		I
150223564	P69174	01/22/2015	11:01	01/22/2015	13:04	1	123	123	Overhead equipment	Transformer Fuse	Replace - Same Size		III
150223881	S11253	01/22/2015	12:05	01/22/2015	21:45	430	249400	580	Substation equipment	Substation Transformer			VI
150224578	S11253	01/22/2015	12:05	01/22/2015	14:23	771	106398	138	Substation equipment	Substation Transformer	Switch/Reset		VI
150224620	S11253	01/22/2015	12:05	01/22/2015	15:10	537	99345	185	Substation equipment	Substation Transformer	Switch/Reset		VI
150224580	M40131	01/22/2015	13:36	01/22/2015	15:45	7	903	129	Public	Overhead Primary	Repair		I
150224557	M40131	01/22/2015	13:42	01/22/2015	14:30	35	1680	47	Overhead equipment				I
150224482	M40116	01/22/2015	14:45	01/22/2015	16:09	1	84	84	Overhead equipment	Transformer Fuse	Replace - Same Size	Patrol/Test/Inspect	I
150224613	J14142	01/22/2015	15:20	01/22/2015	16:14	1	54	53	Overhead equipment	Jumper	Repair		VI
150224654	K27150	01/22/2015	15:41	01/22/2015	16:45	1	64	63	Animal related	Transformer Fuse	Replace - Same Size		VI
150224662	B28006	01/22/2015	15:47	01/22/2015	20:10	1	263	263	Overhead equipment	Overhead Transformer	Disconnect	Repair	I
150224701	Q80353	01/22/2015	16:05	01/22/2015	20:04	8	1912	238	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	V
150224775	P42229	01/22/2015	16:42	01/22/2015	20:53	6	1506	251	Public	Transformer Fuse		Replace - Same Size	VI
150225501	U09557	01/22/2015	21:57	01/23/2015	0:30	1	153	153	Overhead equipment	Overhead Transformer	Disconnect	Replace - Same Size	II
150225516	S31527	01/22/2015	23:23	01/22/2015	23:51	1	28	27	Overhead equipment	Disconnect Switch	Repair		VI
150233158	P83710	01/23/2015	8:02	01/23/2015	9:54	7	784	111	Animal related	Fuse	Repair		I
150233167	K46388	01/23/2015	8:09	01/23/2015	8:47	1	38	37	Animal related	Animal Guard	Patrol/Test/Inspect	Install	V
150233485	Q21293	01/23/2015	9:42	01/23/2015	11:45	138	16974	123	Animal related	Recloser	Switch/Reset		VI
150233651	L23145	01/23/2015	9:52	01/23/2015	10:41	32	1568	49	Animal related	Fuse	Replace - Same Size		III
5000959	R39934	01/23/2015	11:09	01/23/2015	12:01	1	51	51	Animal related	Transformer Fuse	Replace - Same Size		VI
150233957	D01001	01/23/2015	11:39	01/23/2015	11:51	130	1560	11	Jurisdictional	Other			I
150233947	U92518	01/23/2015	11:42	01/23/2015	12:25	1	43	42	Underground equipment	Underground Transformer	Replace - Same Size	Replace - Same Size	II
5000965	K67911	01/23/2015	12:05	01/23/2015	14:58	1	172	172	Animal related	Fuse	Replace - Same Size		VI
150234061	R53391	01/23/2015	12:08	01/23/2015	13:25	13	1001	76	Underground equipment	Underground Primary	Switch/Reset	Repair	V
150234218	K80388	01/23/2015	13:08	01/23/2015	16:00	1	172	171	Underground equipment	Underground Service	Repair		IV
5000969	L59929	01/23/2015	14:05	01/23/2015	15:09	1	63	63	Animal related	Fuse	Replace - Same Size		VI
5000971	Q82906	01/23/2015	14:31	01/23/2015	17:35	1	184	184	Overhead equipment	Overhead Primary	Repair	Repair	VI
150234697	P73158	01/23/2015	15:01	01/23/2015	17:55	4	696	174	Overhead equipment	Overhead Transformer		Replace - Same Size	VI
150234615	B58001	01/23/2015	15:03	01/23/2015	15:46	1	43	43	Overhead equipment	Connector	Repair		I
150234628	C70001	01/23/2015	15:10	01/23/2015	15:49	1	39	39	Animal related	Fuse	Replace - Same Size		III
150234633	C70001	01/23/2015	15:14	01/23/2015	15:50	1	36	35	Animal related	Fuse	Replace - Same Size		III
150234723	M05361	01/23/2015	15:52	01/23/2015	18:28	1	156	155	Underground equipment	Underground Service		Replace - Same Size	V
150234767	J85160	01/23/2015	16:09	01/23/2015	16:48	39	1521	38	Overhead equipment	Fuse	Replace - Same Size		VI
150234774	K36151	01/23/2015	16:15	01/23/2015	17:20	1	65	64	Overhead equipment	Jumper	Repair		III
150234813	V95586	01/23/2015	16:36	01/23/2015	21:53	3	951	317	Public	Pole	Replace - Same Size	Replace - New Size	II
5000973	Q82906	01/23/2015	16:51	01/23/2015	17:30	6	230	38	Tree related-tree broken	Fuse			VI
5000975	K67924	01/23/2015	17:30	01/23/2015	19:02	1	91	91	Overhead equipment	Fuse		Patrol/Test/Inspect	VI
150235454	Q24310	01/23/2015	19:23	01/23/2015	20:25	1	62	62	Tree related-tree contact	Fuse	Replace - Same Size		VI
150235491	N50333	01/23/2015	20:50	01/23/2015	22:03	1	73	72	Animal related	Transformer Fuse	Replace - Same Size	Replace - Same Size	II
150235581	L99392	01/23/2015	21:04	01/24/2015	1:31	13	3471	267	Overhead equipment	Overhead Primary	Patrol/Test/Inspect	Patrol/Test/Inspect	V
150240232	R78300	01/24/2015	2:52	01/24/2015	4:24	86	7912	92	Public	Pole			V
150240231	R78300	01/24/2015	2:52	01/24/2015	4:24	22	2024	92	Public	Pole			V
150240233	R78300	01/24/2015	2:53	01/24/2015	8:56	302	109626	362	Public	Pole		Repair	V
150240238	J07173	01/24/2015	6:08	01/24/2015	7:45	1	97	96	Animal related	Fuse	Repair	Replace - Same Size	I
150240273	R41131	01/24/2015	6:57	01/24/2015	11:32	6	1650	275	Underground equipment	Underground Primary	Repair	Repair	VI
150240341	R01153	01/24/2015	8:59	01/24/2015	14:15	1	316	316	Underground equipment	Underground Service			III
150240340	N35852	01/24/2015	8:59	01/24/2015	9:46	1	47	47	Jurisdictional	Meter	Patrol/Test/Inspect		V
150240358	P49183	01/24/2015	9:30	01/24/2015	10:35	1	65	64	Animal related	Overhead Transformer	Switch/Reset		I
150240370	P26284	01/24/2015	9:45	01/24/2015	11:14	1	89	88	Animal related	Fuse	Replace - Same Size	Replace - Same Size	I
150240397	K57211	01/24/2015	10:21	01/24/2015	11:40	39	3081	78	Underground equipment	Fuse	Replace - Same Size	Replace - Same Size	VI
150240513	K57211	01/24/2015	10:21	01/24/2015	12:04	14	1442	103	Animal related	Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
150240398	Q01282	01/24/2015	10:25	01/24/2015	15:30	1	305	304	Underground equipment	Underground Service			III
150240475	U73599	01/24/2015	10:53	01/24/2015	11:31	3	114	37	Animal related	Fuse	Replace - Same Size		II

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
150240544	K57211	01/24/2015	12:36	01/24/2015	14:13	14	1358	97	Animal related	Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
150240571	Q91175	01/24/2015	13:43	01/24/2015	15:19	1	96	95	Overhead equipment	Overhead Transformer	Switch/Reset		I
150240594	S43511	01/24/2015	14:40	01/24/2015	15:21	1	41	40	Animal related	Transformer Fuse	Replace - Same Size		VI
150240613	M40116	01/24/2015	15:38	01/24/2015	16:55	1	77	76	Unknown	Fuse	Repair	Replace - Same Size	I
150240633	C00001	01/24/2015	16:28	01/24/2015	17:19	1	51	50	Unknown	Fuse	Repair		I
150240638	R01153	01/24/2015	16:41	01/24/2015	18:38	1	117	116	Animal related	Transformer Fuse	Replace - Same Size		III
5000989	K67924	01/24/2015	17:03	01/24/2015	20:54	7	1615	230	Overhead equipment	Overhead Primary	Repair	Repair	VI
150240706	334001	01/24/2015	20:08	01/24/2015	22:07	1	119	119	Public	Pole	Patrol/Test/Inspect	Replace - New Size	VI
150240714	K46422	01/24/2015	20:30	01/24/2015	22:00	1	90	90	Underground equipment	Underground Service	Repair		V
150250021	A45003	01/25/2015	1:49	01/25/2015	6:15	1	266	265	Overhead equipment	Overhead Transformer	Replace - Same Size	Repair	I
150250031		01/25/2015	3:54	01/25/2015	8:00	6	1476	246	Underground equipment	Underground Primary			VI
150250099	Y23214	01/25/2015	7:47	01/25/2015	9:24	1	97	97	Overhead equipment	Lightning Arrestor	Disconnect		IV
150250156	Y23214	01/25/2015	7:47	01/25/2015	8:34	576	27072	46	Overhead equipment	Lightning Arrestor	Replace - Same Size		IV
150250104	M07235	01/25/2015	8:03	01/25/2015	13:38	1	335	335	Underground equipment	Underground Service	Patrol/Test/Inspect	Repair	III
150250148	R28870	01/25/2015	8:28	01/25/2015	9:22	1	54	53	Animal related	Transformer Fuse	Replace - Same Size		V
150250160	A49002	01/25/2015	8:45	01/25/2015	14:30	158	54510	344	Overhead equipment	Pole	Patrol/Test/Inspect	Replace - Same Size	I
150250178	T15570	01/25/2015	8:54	01/25/2015	11:30	1	156	155	Overhead equipment	Overhead Primary	Repair	Repair	VI
150250201	J07173	01/25/2015	9:01	01/25/2015	13:35	51	13974	273	Overhead equipment	Jumper	Repair		I
150250599	J07173	01/25/2015	9:01	01/25/2015	13:45	6	1704	283	Overhead equipment	Jumper	Repair		I
150250227	J07135	01/25/2015	9:16	01/25/2015	12:13	15	2655	177	Overhead equipment	Overhead Primary	Repair	Replace - Same Size	I
150250432	J07135	01/25/2015	9:16	01/25/2015	13:52	18	4968	275	Unknown	Fuse	Repair	Replace - Same Size	I
150250214	D28124	01/25/2015	9:17	01/25/2015	21:50	8	6024	752	Public	Pole	Patrol/Test/Inspect	Replace - Same Size	I
150250204	X82585	01/25/2015	9:20	01/25/2015	10:24	6	384	63	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
150250208	R53416	01/25/2015	9:25	01/25/2015	11:11	9	954	105	Overhead equipment	Lightning Arrestor	Patrol/Test/Inspect	Replace - Same Size	V
150250220	B73001	01/25/2015	9:27	01/25/2015	11:15	41	4428	107	Overhead equipment	Disconnect Switch	Replace - Same Size	Replace - Same Size	I
150250327	B77003	01/25/2015	9:32	01/25/2015	13:54	9	2358	262	Overhead equipment	Transformer Fuse	Repair	Repair	I
150250218	B77003	01/25/2015	9:32	01/25/2015	12:15	56	9128	162	Overhead equipment	Transformer Fuse	Repair		I
150250245	D28123	01/25/2015	9:42	01/25/2015	12:03	26	3666	140	Overhead equipment	Disconnect Switch	Replace - Same Size		I
150250267	B93002	01/25/2015	10:42	01/25/2015	13:21	1	159	159	Overhead equipment	Disconnect Switch	Replace - Same Size		I
150250291	S25552	01/25/2015	10:48	01/25/2015	13:00	57	7524	132	Overhead equipment	Pole	Patrol/Test/Inspect	Replace - Same Size	VI
150250305	J07135	01/25/2015	11:19	01/25/2015	13:10	24	2664	110	Unknown	Fuse	Repair	Replace - Same Size	I
150250311	L14231	01/25/2015	11:28	01/25/2015	12:19	1	51	50	Overhead equipment	Fuse	Replace - Same Size	Repair	III
150250318	J06168	01/25/2015	11:37	01/25/2015	15:28	1	231	230	Tree related-tree broken	Pole	Repair	Replace - Same Size	I
150250322	J84124	01/25/2015	11:41	01/25/2015	13:05	1	84	84	Animal related	Transformer Fuse			VI
150250384	V26292	01/25/2015	11:48	01/25/2015	17:25	801	269937	336	Overhead equipment	Pole	Repair	Replace - New Size	II
150250667		01/25/2015	11:50	01/25/2015	14:12	47	6674	142	Overhead equipment	Pole	Repair	Replace - New Size	II
150250696		01/25/2015	11:50	01/25/2015	14:16	234	34164	146	Overhead equipment	Pole	Repair	Replace - New Size	II
150250393	S61575	01/25/2015	12:16	01/25/2015	13:25	1	69	69	Animal related	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
150250420	E10002	01/25/2015	12:30	01/25/2015	14:34	419	51956	123	Overhead equipment	Overhead Primary		Repair	III
150250433	Y60593	01/25/2015	12:47	01/25/2015	13:53	1	66	66	Overhead equipment	Transformer Fuse	Replace - Same Size	Replace - Same Size	IV
150250434	Q11516	01/25/2015	12:55	01/25/2015	15:48	7	1211	172	Overhead equipment	Overhead Primary		Repair	I
150250591	D35001	01/25/2015	13:26	01/25/2015	16:35	1	189	188	Overhead equipment	Connector	Tie/Tighten	Repair	I
150250605	M36185	01/25/2015	13:59	01/25/2015	16:52	1	173	172	Overhead equipment	Overhead Service	Repair	Replace - Same Size	I
150250604	J07135	01/25/2015	13:59	01/25/2015	14:10	1	11	11	Unknown	Fuse	Repair	Replace - Same Size	I
150250600	Q70161	01/25/2015	14:26	01/25/2015	19:19	2	586	292	Overhead equipment	Overhead Primary	Repair	Repair	I
150250634	P47122	01/25/2015	14:35	01/25/2015	17:18	1	163	162	Tree related-tree broken	Overhead Service			I
150250646	U62521	01/25/2015	14:40	01/25/2015	16:42	1	122	121	Animal related	Transformer Fuse	Replace - Same Size		II
150250651	B76003	01/25/2015	14:48	01/26/2015	4:44	1	836	836	Underground equipment	Underground Service	Patrol/Test/Inspect	Repair	I
150250661	R07382	01/25/2015	15:07	01/25/2015	16:10	1	63	62	Animal related	Transformer Fuse	Replace - Same Size	Repair	I
150250672	V47001	01/25/2015	15:32	01/25/2015	17:51	7	973	139	Tree related-tree broken	Transformer Fuse			II
150250678	K74162	01/25/2015	15:38	01/25/2015	18:55	1	197	197	Overhead equipment	Jumper	Patrol/Test/Inspect	Repair	IV
150250686	B46002	01/25/2015	15:56	01/25/2015	17:16	1	80	79	Overhead equipment	Overhead Service	Repair		I
150250709	D53001	01/25/2015	16:28	01/25/2015	17:40	34	2448	71	Overhead equipment	Overhead Primary	Reconnect		I
150250710	V47001	01/25/2015	16:40	01/25/2015	17:53	1	73	72	Tree related-tree broken	Transformer Fuse			II
150250721	P83705	01/25/2015	17:03	01/26/2015	7:15	1	852	852	Underground equipment	Underground Secondary	Patrol/Test/Inspect		I
150250722	L23145	01/25/2015	17:11	01/25/2015	18:39	11	968	88	Unknown	Transformer Fuse	Replace - Same Size		III

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
150250732	B80003	01/25/2015	17:24	01/25/2015	19:13	1	109	108	Overhead equipment	Overhead Service	Reconnect		I
150250731	Y91501	01/25/2015	17:24	01/25/2015	18:25	1	61	60	Animal related	Transformer Fuse	Replace - Same Size		IV
150250759	U41517	01/25/2015	17:25	01/25/2015	18:11	52	2392	46	Overhead equipment	Pole	Replace - Same Size		II
150250743	A91002	01/25/2015	17:36	01/25/2015	18:52	7	532	76	Overhead equipment	Pole	Repair		I
150250760	N72240	01/25/2015	18:10	01/26/2015	0:24	2	748	374	Tree related-tree broken	Overhead Primary	Repair		III
150250771	A91004	01/25/2015	18:35	01/25/2015	19:09	1	34	34	Overhead equipment	Overhead Service	Repair		I
150250873	P98190	01/25/2015	18:55	01/25/2015	22:15	239	47800	200	Public	Pole	Replace - Same Size		III
150250892	P98190	01/25/2015	18:55	01/26/2015	2:04	18	7722	428	Public	Pole	Replace - Same Size		III
150250891	P98190	01/25/2015	18:55	01/25/2015	22:34	25	5475	219	Public	Pole	Replace - Same Size		III
150250793	P98190	01/25/2015	18:57	01/25/2015	21:03	299	37674	126	Public	Pole	Replace - Same Size		III
150250813	J71128	01/25/2015	19:25	01/25/2015	21:07	1	102	101	Overhead equipment	Overhead Service	Repair	Replace - Same Size	I
150250893	P98190	01/25/2015	21:00	01/26/2015	2:04	6	1824	303	Public	Pole	Replace - Same Size		III
150250890	P98190	01/25/2015	21:00	01/25/2015	22:44	89	9256	104	Public	Pole	Replace - Same Size		III
150250872	R41131	01/25/2015	21:00	01/26/2015	3:55	2	830	415	Overhead equipment	Pole			VI
150260056	D31016	01/25/2015	23:15	01/26/2015	3:11	7	1652	236	Overhead equipment	Overhead Primary		Replace - Same Size	III
150260109	S16596	01/26/2015	0:58	01/26/2015	5:40	5	1410	281	Overhead equipment	Transformer Fuse	Replace - Same Size	Replace - Same Size	VI
5001007	K32935	01/26/2015	1:21	01/26/2015	2:55	21	1974	94	Tree related-tree broken				VI
150260110	B28006	01/26/2015	1:24	01/26/2015	2:34	1	70	69	Overhead equipment				I
150262456	R59412	01/26/2015	3:29	01/26/2015	5:25	7	812	116	Overhead equipment	Transformer Fuse	Replace - New Size		IV
150262480	U12540	01/26/2015	6:27	01/26/2015	9:23	1	176	175	Overhead equipment	Disconnect Switch	Repair	Replace - Same Size	II
150262616	X34531	01/26/2015	7:47	01/26/2015	8:42	12	660	55	Overhead equipment	Jumper	Repair		IV
150262641		01/26/2015	7:57	01/26/2015	9:19	1	82	81	Overhead equipment	Transformer Fuse	Replace - Same Size		V
150262680	J07135	01/26/2015	8:11	01/26/2015	9:00	1	49	49	Tree related-tree broken	Overhead Service	Cut in Clear	Reconnect	I
150262690	K76542	01/26/2015	8:12	01/26/2015	8:55	12	516	43	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
150262793	K71822	01/26/2015	8:26	01/26/2015	9:19	31	1643	52	Animal related	Fuse	Repair		IV
150263018	H22346	01/26/2015	9:29	01/26/2015	10:44	3	225	75	Animal related	Fuse	Replace - Same Size		V
150263309	J33803	01/26/2015	10:46	01/26/2015	11:20	1	34	33	Animal related	Fuse	Repair	Repair	V
150263347	C36002	01/26/2015	10:55	01/26/2015	12:11	1	76	76	Jurisdictional	Underground Service	Repair		III
150263349	L79157	01/26/2015	10:57	01/26/2015	11:51	1	54	53	Overhead equipment	Fuse	Replace - Same Size		IV
150263423	M47816	01/26/2015	11:10	01/26/2015	11:33	69	1587	22	Animal related	Fuse	Repair	Repair	V
150263450	M45212	01/26/2015	11:20	01/26/2015	11:30	1	10	10	Animal related	Transformer Fuse	Replace - Same Size		IV
150263844	J15303	01/26/2015	13:13	01/26/2015	13:59	8	368	46	Overhead equipment	Fuse	Replace - Same Size		I
150263781	T16526	01/26/2015	13:18	01/26/2015	14:20	1	62	61	Overhead equipment	Fuse	Repair		VI
5001017	P20930	01/26/2015	13:30	01/26/2015	14:50	1	79	79	Animal related	Fuse	Replace - Same Size		VI
150264012	J74125	01/26/2015	14:32	01/26/2015	15:37	1	65	64	Overhead equipment	Overhead Service	Reconnect		VI
150264029	P73157	01/26/2015	14:39	01/26/2015	15:40	1	61	60	Animal related	Fuse	Replace - Same Size		VI
150264230	K65220	01/26/2015	15:47	01/26/2015	17:30	2	206	103	Public	Pole			III
150264373	S42579	01/26/2015	16:46	01/26/2015	17:44	1	58	58	Animal related	Transformer Fuse	Replace - Same Size		VI
150264380	X23516	01/26/2015	16:52	01/26/2015	17:50	1	58	58	Overhead equipment	Transformer Fuse	Repair	Patrol/Test/Inspect	IV
150264399	S61530	01/26/2015	16:57	01/26/2015	19:01	68	8432	123	Underground equipment	Underground Primary		Switch/Reset	VI
150264515	D70006	01/26/2015	17:47	01/26/2015	21:14	1	207	207	Underground equipment	Underground Service	Repair	Repair	I
150264548	R53391	01/26/2015	18:18	01/26/2015	19:13	1	55	55	Animal related	Fuse	Replace - Same Size		V
150264550	C50001	01/26/2015	18:21	01/26/2015	23:19	2	596	298	Overhead equipment	Transformer Fuse		Repair	III
150264593	D35002	01/26/2015	18:49	01/27/2015	4:00	5	2755	550	Public	Pole	Replace - Same Size	Repair	I
150265549	D35002	01/26/2015	18:51	01/27/2015	0:18	118	38586	326	Public	Pole			I
150265513	U29001	01/26/2015	20:56	01/26/2015	22:25	7	623	89	Unknown	Fuse	Replace - Same Size		II
150270068	D35002	01/26/2015	23:58	01/27/2015	0:18	84	1680	19	Overhead equipment				I
150272616	Y61001	01/27/2015	1:48	01/27/2015	4:05	32	4384	137	Public	Pole	Switch/Reset		IV
150272617	Y61001	01/27/2015	1:48	01/27/2015	8:50	3	1266	422	Public	Pole		Repair	IV
150270128	Y61001	01/27/2015	1:50	01/27/2015	3:21	84	7644	90	Public	Pole	Switch/Reset		IV
150272855	J46184	01/27/2015	8:25	01/27/2015	9:14	1	49	49	Public	Overhead Service			III
150273087	B28004	01/27/2015	8:58	01/27/2015	12:22	18	3672	203	Overhead equipment	Overhead Primary	Patrol/Test/Inspect	Raise	I
150272947	B28004	01/27/2015	8:58	01/27/2015	10:05	69	4623	66	Overhead equipment	Fuse	Replace - Same Size		I
150272981	J89125	01/27/2015	9:10	01/27/2015	9:24	1	14	14	Animal related	Transformer Fuse			VI
150273014	B71002	01/27/2015	9:18	01/27/2015	10:46	1	88	88	Underground equipment	Underground Service	Repair	Repair	I
150273113	D53002	01/27/2015	9:50	01/27/2015	17:08	1	438	438	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
150273375	X91510	01/27/2015	10:55	01/27/2015	11:30	1	35	34	Overhead equipment	Transformer Fuse	Repair	Replace - Same Size	IV
150273560	L93148	01/27/2015	11:43	01/27/2015	12:06	24	552	23	Underground equipment	Underground Primary			VI
150273580	M42612	01/27/2015	11:53	01/27/2015	12:27	1	34	34	Overhead equipment	Overhead Service	Repair		I
150273710	B83001	01/27/2015	12:38	01/27/2015	12:57	1	19	18	Animal related	Fuse	Replace - Same Size		III
5001057	J20931	01/27/2015	12:47	01/27/2015	13:20	144	4704	32	Other	Recloser			VI
150273876	C36001	01/27/2015	13:25	01/27/2015	14:06	1	41	40	Animal related	Fuse	Replace - Same Size		III
150273885	M07235	01/27/2015	13:27	01/27/2015	13:54	1	27	27	Unknown	Transformer Fuse	Replace - Same Size		III
150273944	H22346	01/27/2015	13:43	01/27/2015	15:05	1	82	81	Animal related	Transformer Fuse	Replace - Same Size	Replace - Same Size	V
5001067	Q82906	01/27/2015	14:08	01/27/2015	14:52	1	43	43	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	VI
5001075	R42914	01/27/2015	14:55	01/27/2015	18:11	1	195	195	Overhead equipment	Disconnect Switch		Replace - Same Size	VI
150274392	V49541	01/27/2015	16:11	01/27/2015	17:21	4	280	69	Unknown	Fuse	Replace - Same Size		II
150274466	V22555	01/27/2015	16:48	01/27/2015	19:20	1	152	152	Public	Underground Service	Repair		II
150274467	310122	01/27/2015	16:49	01/27/2015	18:23	1	94	94	Underground equipment	Underground Service	Repair	Repair	V
5001077	K08909	01/27/2015	17:59	01/27/2015	19:17	1	77	77	Overhead equipment	Transformer Fuse	Replace - Same Size		VI
150274643	M07235	01/27/2015	18:34	01/27/2015	20:20	1	106	105	Overhead equipment	Connector	Repair		III
150275081	X34531	01/27/2015	21:43	01/27/2015	22:48	21	1365	64	Overhead equipment	Transformer Fuse	Repair	Replace - Same Size	IV
150282313	R95520	01/28/2015	3:30	01/28/2015	5:56	1	146	145	Overhead equipment	Connector	Repair		I
150282317	311003	01/28/2015	4:27	01/28/2015	5:30	6	378	62	Overhead equipment	Fuse	Replace - Same Size		VI
150282328	Q47833	01/28/2015	6:11	01/28/2015	13:05	1	414	413	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - New Size	V
150282339	C10001	01/28/2015	6:17	01/28/2015	8:45	26	3848	148	Public	Overhead Primary	Repair		III
150282342	X12526	01/28/2015	6:24	01/28/2015	12:30	2	732	365	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	IV
150282350	M81405	01/28/2015	6:42	01/28/2015	10:29	1	227	226	Overhead equipment	Connector	Repair		V
150282357	B19002	01/28/2015	6:54	01/28/2015	10:31	1	217	217	Underground equipment	Underground Service	Repair	Repair	I
150282454	T09558	01/28/2015	7:49	01/28/2015	14:10	1	381	381	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	VI
150282511	330126	01/28/2015	8:12	01/28/2015	9:04	1	52	52	Jurisdictional				V
150282712	B57003	01/28/2015	9:09	01/28/2015	11:31	1	142	142	Overhead equipment	Disconnect Switch	Patrol/Test/Inspect	Repair	I
150282846	M26164	01/28/2015	9:46	01/28/2015	10:58	8	576	71	Overhead equipment	Jumper	Repair		III
150282877	P71830	01/28/2015	9:54	01/28/2015	12:15	1	141	140	Overhead equipment	Transformer Fuse	Replace - Same Size		V
150282925	K01240	01/28/2015	10:05	01/28/2015	10:55	1	50	49	Animal related	Fuse			VI
150283000	K27150	01/28/2015	10:22	01/28/2015	10:50	1	28	28	Animal related	Transformer Fuse	Replace - Same Size	Replace - Same Size	VI
150283074	D72003	01/28/2015	10:37	01/28/2015	11:09	1	32	31	Overhead equipment				I
150283160	S43511	01/28/2015	10:58	01/28/2015	11:50	1	52	52	Overhead equipment	Disconnect Switch	Replace - New Size		VI
150283483	C10001	01/28/2015	12:19	01/28/2015	13:29	1	70	69	Overhead equipment	Other	Patrol/Test/Inspect	Patrol/Test/Inspect	III
150283547	D36003	01/28/2015	12:33	01/28/2015	14:15	1	102	101	Overhead equipment	Fuse	Patrol/Test/Inspect	Repair	I
150283640	D69006	01/28/2015	12:59	01/28/2015	16:26	1	207	206	Underground equipment	Underground Service	Patrol/Test/Inspect	Repair	I
150283674		01/28/2015	13:11	01/28/2015	13:21	1	10	10	Overhead equipment	Recloser	Switch/Reset		VI
150283817	V61584	01/28/2015	13:48	01/28/2015	15:15	1	87	87	Animal related	Transformer Fuse	Replace - Same Size		II
150284055	L00134	01/28/2015	14:54	01/28/2015	16:20	1	86	85	Overhead equipment	Jumper	Repair		III
150284378	B53001	01/28/2015	16:33	01/28/2015	17:45	1	72	72	Overhead equipment	Other	Patrol/Test/Inspect	Patrol/Test/Inspect	III
150284435	D28124	01/28/2015	17:00	01/28/2015	17:59	1	59	58	Overhead equipment	Connector	Replace - New Size		I
150284633	B57003	01/28/2015	17:25	01/28/2015	22:00	4	1100	274	Overhead equipment	Other		Repair	I
150284668	Y69565	01/28/2015	18:15	01/28/2015	20:25	1	130	130	Overhead equipment	Overhead Service	Reconnect		IV
150284677	J88166	01/28/2015	18:23	01/28/2015	19:15	1	52	52	Overhead equipment	Transformer Fuse	Replace - Same Size		VI
150284685	V39003	01/28/2015	18:38	01/28/2015	19:40	1	62	62	Overhead equipment	Connector	Replace - Same Size		II
150284697	X35501	01/28/2015	18:47	01/28/2015	21:33	41	6806	166	Overhead equipment	Disconnect Switch	Repair	Replace - Same Size	IV
150284874	X35501	01/28/2015	19:00	01/28/2015	21:33	1	153	153	Overhead equipment	Jumper	Repair		IV
150284991	C70004	01/28/2015	19:51	01/28/2015	21:21	1	90	90	Overhead equipment	Fuse	Replace - Same Size		III
150284997	V61584	01/28/2015	20:03	01/28/2015	23:25	1	202	201	Overhead equipment	Overhead Service	Replace - Same Size	Repair	II
150285022	V58507	01/28/2015	20:59	01/28/2015	23:53	1	174	174	Overhead equipment	Overhead Transformer	Replace - Same Size	Replace - New Size	II
150285438	X75512	01/28/2015	21:28	01/28/2015	22:40	1	72	72	Overhead equipment	Jumper	Repair		IV
150285457		01/28/2015	22:41	01/29/2015	3:52	1	311	310	Overhead equipment	Overhead Primary	Patrol/Test/Inspect	Repair	VI
150290099	T06504	01/29/2015	0:29	01/29/2015	6:13	61	20984	344	Underground equipment	Underground Primary			VI
150293073	U79726	01/29/2015	4:44	01/29/2015	7:15	1	151	150	Overhead equipment	Insulator	Replace - Same Size		II
150292801	V69558	01/29/2015	6:51	01/29/2015	8:02	1	71	71	Overhead equipment	Jumper	Repair		II
150292807	N54214	01/29/2015	6:55	01/29/2015	8:50	1	115	114	Overhead equipment	Jumper	Repair		II
150292863	J58381	01/29/2015	7:22	01/29/2015	7:57	1	35	35	Overhead equipment	Jumper		Repair	III

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
150292866	303006	01/29/2015	7:23	01/29/2015	8:00	7	259	37	Tree related-tree broken	Tree	Trim		VI
150292936	M83326	01/29/2015	7:48	01/29/2015	11:40	1	232	232	Overhead equipment	Transformer Fuse	Replace - Same Size		V
150292944	344003	01/29/2015	7:53	01/29/2015	9:05	1	72	71	Tree related-tree broken	Overhead Service	Repair		VI
150293066	J87111	01/29/2015	8:17	01/29/2015	8:44	18	486	27	Overhead equipment	Jumper			VI
150293078	307001	01/29/2015	8:29	01/29/2015	9:15	1	46	45	Overhead equipment	Overhead Secondary	Repair		VI
150293142	J86118	01/29/2015	8:48	01/29/2015	9:49	1	61	60	Overhead equipment	Overhead Service	Repair	Repair	VI
150293150	J87111	01/29/2015	8:50	01/29/2015	8:59	1	9	8	Overhead equipment				VI
150293157	M07236	01/29/2015	8:53	01/29/2015	10:52	1	119	119	Overhead equipment	Connector	Repair		III
150293269	V20502	01/29/2015	9:23	01/29/2015	10:44	1	81	81	Overhead equipment	Overhead Primary	Repair		II
150293458	307004	01/29/2015	10:08	01/29/2015	12:29	8	1128	140	Tree related-tree broken	Overhead Primary	Patrol/Test/Inspect	Repair	VI
150293471	H92419	01/29/2015	10:12	01/29/2015	11:00	1	48	47	Overhead equipment	Substation Breaker	Repair		V
150293594	M40132	01/29/2015	10:43	01/29/2015	11:15	57	1824	31	Animal related	Fuse	Replace - Same Size		I
150293599	B28004	01/29/2015	10:46	01/29/2015	11:17	1	31	30	Overhead equipment	Fuse	Replace - Same Size		I
150293619	Y98561	01/29/2015	10:51	01/29/2015	11:36	1	45	45	Overhead equipment	Overhead Service	Repair		IV
150293789	324001	01/29/2015	11:18	01/29/2015	15:42	12	3168	264	Overhead equipment	Overhead Primary	Patrol/Test/Inspect	Repair	VI
150293783	X96523	01/29/2015	11:35	01/29/2015	13:00	1	85	84	Public	Overhead Service	Repair	Patrol/Test/Inspect	IV
150293980	A48005	01/29/2015	12:40	01/29/2015	12:59	1	19	18	Overhead equipment				I
150294164	M47802	01/29/2015	13:21	01/29/2015	14:05	1	44	43	Overhead equipment	Overhead Service			V
150294283	S15559	01/29/2015	14:00	01/29/2015	15:07	1	67	66	Overhead equipment	Overhead Primary	Patrol/Test/Inspect	Repair	VI
150294388	Y28597	01/29/2015	14:26	01/29/2015	15:28	3	186	61	Overhead equipment	Jumper	Repair		IV
5001119	T59902	01/29/2015	14:48	01/29/2015	16:16	1	87	87	Animal related	Fuse		Patrol/Test/Inspect	VI
150294592	D48003	01/29/2015	14:55	01/29/2015	16:00	12	780	64	Underground equipment	Underground Primary	Replace - Same Size		I
150294525	D48003	01/29/2015	14:57	01/29/2015	15:23	1081	28106	26	Underground equipment	Underground Primary	Replace - Same Size		I
150294643	Q23255	01/29/2015	15:52	01/29/2015	16:30	1	38	37	Animal related	Transformer Fuse	Replace - Same Size		VI
150294653	K30204	01/29/2015	15:57	01/29/2015	18:25	1	148	148	Overhead equipment	Jumper	Repair		III
150294929	Y28597	01/29/2015	16:29	01/29/2015	18:42	396	52668	133	Overhead equipment	Disconnect Switch	Patrol/Test/Inspect	Repair	IV
150294900	Y28597	01/29/2015	16:29	01/29/2015	17:48	245	19355	79	Overhead equipment	Substation Breaker	Switch/Reset		IV
150294924	D39001	01/29/2015	17:50	01/29/2015	19:20	1	90	90	Overhead equipment	Overhead Primary	Repair		I
150294937	301053	01/29/2015	17:58	01/29/2015	22:50	1	292	291	Overhead equipment	Disconnect Switch	Disconnect	Repair	VI
150294943	J80807	01/29/2015	18:01	01/29/2015	20:15	1	134	133	Overhead equipment	Disconnect Switch	Repair	Repair	V
150294983	K25164	01/29/2015	18:51	01/29/2015	21:14	1	143	143	Overhead equipment	Jumper	Repair		VI
150295007	U92593	01/29/2015	19:18	01/29/2015	21:10	10	1120	111	Overhead equipment	Disconnect Switch	Repair	Repair	II
150295003	X75512	01/29/2015	19:19	01/29/2015	21:31	1	132	132	Overhead equipment	Disconnect Switch	Replace - Same Size		IV
150295390	N14880	01/29/2015	21:59	01/29/2015	22:38	1	39	39	Overhead equipment	Transformer Fuse	Replace - Same Size		V
150295397	337002	01/29/2015	23:01	01/30/2015	0:30	1	89	89	Overhead equipment	Overhead Service	Repair		VI
150300621	M36184	01/30/2015	2:48	01/30/2015	4:00	1	72	71	Overhead equipment	Jumper	Repair		I
150302815	S41564	01/30/2015	5:47	01/30/2015	7:15	1	88	88	Overhead equipment	Transformer Fuse	Replace - Same Size		VI
150302828	S25552	01/30/2015	6:09	01/30/2015	7:55	20	2120	105	Overhead equipment	Overhead Primary	Replace - Same Size		VI
150302899	R16511	01/30/2015	7:31	01/30/2015	11:44	1	253	252	Underground equipment				I
150303006	S25552	01/30/2015	8:13	01/30/2015	10:00	15	1605	106	Underground equipment	Underground Primary	Repair	Repair	VI
150303107	Q32170	01/30/2015	8:54	01/30/2015	9:41	1	47	46	Overhead equipment	Jumper	Repair	Patrol/Test/Inspect	I
150303268	U06524	01/30/2015	9:28	01/30/2015	11:27	8	952	119	Underground equipment	Underground Primary	Repair	Repair	II
150303355	S43501	01/30/2015	10:09	01/30/2015	11:00	1	51	50	Overhead equipment	Connector	Replace - New Size	Repair	VI
150303611	R84148	01/30/2015	10:25	01/30/2015	12:23	6	708	117	Animal related	Overhead Transformer	Switch/Reset		I
150303471	B76001	01/30/2015	10:42	01/30/2015	15:15	1	273	272	Underground equipment	Underground Service	Patrol/Test/Inspect	Repair	I
150303542	K46388	01/30/2015	10:59	01/30/2015	11:52	1	53	52	Intentional				V
150303673	K28180	01/30/2015	11:48	01/30/2015	12:23	1	35	34	Animal related	Transformer Fuse	Replace - Same Size		III
150303737	D55002	01/30/2015	12:07	01/30/2015	13:08	53	3233	60	Animal related	Transformer Fuse	Replace - Same Size		I
150303744	X69555	01/30/2015	12:10	01/30/2015	12:55	1	45	45	Tree related-tree broken	Tree			IV
150303814	U01523	01/30/2015	12:39	01/30/2015	13:49	1	70	69	Overhead equipment	Transformer Fuse	Repair		II
150303848	D88001	01/30/2015	12:52	01/30/2015	13:33	30	1230	40	Animal related	Transformer Fuse	Replace - Same Size		I
150304384	U73599	01/30/2015	15:29	01/30/2015	16:10	1	41	40	Animal related	Transformer Fuse	Replace - Same Size		II
150304658	K25166	01/30/2015	18:18	01/30/2015	19:31	1	73	73	Animal related	Transformer Fuse	Replace - Same Size		VI
150304699	L93135	01/30/2015	18:59	01/30/2015	19:43	1	44	43	Animal related	Transformer Fuse	Replace - Same Size		VI
150305087	303007	01/30/2015	19:49	01/30/2015	20:24	1	35	34	Public	Overhead Transformer	Patrol/Test/Inspect		VI
150305124	J86108	01/30/2015	21:07	01/30/2015	22:13	6	396	65	Overhead equipment	Fuse	Replace - Same Size		VI

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
150305133	J86108	01/30/2015	21:23	01/30/2015	22:18	1	55	55	Overhead equipment				VI
150305158	R41132	01/30/2015	22:41	01/30/2015	23:18	45	1665	36	Overhead equipment	Overhead Transformer	Repair		VI
150310053	Y54560	01/31/2015	2:35	01/31/2015	4:17	48	4896	101	Animal related	Overhead Primary			IV
150310075	329148	01/31/2015	5:24	01/31/2015	6:58	27	2538	94	Overhead equipment	Fuse	Replace - Same Size	Repair	V
150310090	K65221	01/31/2015	6:54	01/31/2015	11:04	1	250	249	Overhead equipment	Overhead Transformer			III
5001149	K32935	01/31/2015	7:48	01/31/2015	11:43	1	234	234	Tree related-tree broken	Overhead Service			VI
150310134	D90002	01/31/2015	7:58	01/31/2015	9:00	1	62	62	Other	Other	Patrol/Test/Inspect	Patrol/Test/Inspect	III
150310158	S22593	01/31/2015	8:20	01/31/2015	9:10	10	500	50	Underground equipment	Underground Primary	Repair		VI
150310184	M30301	01/31/2015	8:59	01/31/2015	9:46	1	47	47	Animal related	Transformer Fuse	Replace - Same Size		VI
150310198	S61530	01/31/2015	9:14	01/31/2015	13:30	1	256	255	Underground equipment	Underground Service	Repair	Repair	VI
150310233	A73002	01/31/2015	10:13	01/31/2015	11:55	28	2856	102	Unknown	Fuse	Replace - Same Size		I
150310235	K25166	01/31/2015	10:16	01/31/2015	11:15	1	59	59	Animal related	Transformer Fuse	Repair	Repair	VI
150310506	L81141	01/31/2015	10:48	01/31/2015	11:47	1	59	59	Overhead equipment	Fuse			IV
150310602	X69555	01/31/2015	11:00	01/31/2015	12:32	1	92	91	Overhead equipment	Overhead Service			IV
150310675	B35002	01/31/2015	12:47	01/31/2015	13:51	1	64	63	Animal related	Transformer Fuse	Replace - Same Size	Replace - Same Size	I
150310738	B81002	01/31/2015	13:13	01/31/2015	18:01	1	288	288	Underground equipment	Underground Service	Patrol/Test/Inspect	Repair	I
150310786	B76003	01/31/2015	14:36	01/31/2015	20:00	1	324	324	Underground equipment	Underground Service			I
150310805	B27009	01/31/2015	15:05	01/31/2015	15:56	1	51	51	Underground equipment	Underground Primary	Replace - Same Size	Replace - Same Size	I
150310808	K91117	01/31/2015	15:12	01/31/2015	16:25	1	73	73	Tree related-tree broken	Overhead Service	Repair		III
150310818	R61241	01/31/2015	15:16	01/31/2015	16:05	32	1568	49	Animal related	Fuse	Replace - Same Size		IV
150310823	D28124	01/31/2015	15:47	01/31/2015	17:30	1	103	103	Overhead equipment	Connector	Replace - Same Size		I
150310842	J58381	01/31/2015	17:12	02/02/2015	6:06	22	48708	2213	Underground equipment	Underground Primary			III
150310872	A73002	01/31/2015	17:55	01/31/2015	18:45	8	400	49	Overhead equipment	Fuse	Patrol/Test/Inspect	Repair	I
150310891	G50002	01/31/2015	18:17	01/31/2015	20:25	283	36224	127	Overhead equipment	Jumper	Repair	Repair	IV
150310906	S57502	01/31/2015	19:06	01/31/2015	20:11	1	65	65	Overhead equipment	Transformer Fuse			VI
150310929	D31015	01/31/2015	20:25	01/31/2015	21:34	1	69	68	Other	Other	Patrol/Test/Inspect	Patrol/Test/Inspect	III
150310945	P83705	01/31/2015	21:00	01/31/2015	23:55	7	1225	175	Overhead equipment	Fuse	Repair	Repair	I
150310970	K01240	01/31/2015	23:02	02/01/2015	1:10	28	3584	127	Underground equipment	Fuse	Replace - Same Size		VI
150310977	C70002	01/31/2015	23:27	02/01/2015	3:08	46	10166	221	Overhead equipment	Pole			III
150310979	R58942	01/31/2015	23:33	02/01/2015	4:14	1	281	281	Tree related-tree contact	Overhead Service	Patrol/Test/Inspect	Repair	IV
150310982	M45211	01/31/2015	23:54	02/01/2015	7:06	1	432	431	Public	Pole		Replace - Same Size	IV
150320005	Y98532	02/01/2015	0:02	02/01/2015	3:00	76	13528	178	Overhead equipment	Disconnect Switch	Patrol/Test/Inspect	Replace - Same Size	IV
150320031	P26284	02/01/2015	1:04	02/01/2015	7:25	9	3429	381	Tree related-tree contact	Fuse	Replace - Same Size	Replace - Same Size	I
150320042	S13546	02/01/2015	1:44	02/01/2015	4:55	22	4202	190	Overhead equipment	Fuse	Replace - Same Size		VI
150320055	N60181	02/01/2015	1:54	02/01/2015	9:25	167	75317	450	Overhead equipment	Pole	Replace - Same Size	Replace - Same Size	I
150320091	Q34360	02/01/2015	3:07	02/01/2015	5:59	58	9976	171	Overhead equipment	Fuse	Replace - Same Size	Repair	I
150320365	B81003	02/01/2015	4:38	02/01/2015	16:30	1	712	711	Tree related-tree broken	Pole	Patrol/Test/Inspect	Replace - Same Size	I
150320374	D81001	02/01/2015	4:58	02/01/2015	6:20	1	82	82	Tree related-tree broken	Overhead Service	Repair		I
150320377	Q11516	02/01/2015	5:00	02/01/2015	7:28	56	8288	148	Overhead equipment	Fuse	Replace - Same Size		I
150320411	H07106	02/01/2015	5:08	02/01/2015	7:45	97	15229	156	Overhead equipment	Overhead Primary	Patrol/Test/Inspect	Repair	IV
150320402	N60181	02/01/2015	5:44	02/01/2015	11:48	1	364	364	Overhead equipment	Overhead Service			I
150320431	V99562	02/01/2015	6:16	02/01/2015	15:04	40	21120	528	Overhead equipment	Pole	Replace - Same Size	Repair	II
150320427	A17026	02/01/2015	6:20	02/01/2015	8:05	1	105	104	Tree related-tree contact	Overhead Service	Repair		I
150320608	Q93522	02/01/2015	6:21	02/02/2015	1:44	7	8141	1163	Tree related-tree broken	Overhead Primary	Repair		I
150320436	J15303	02/01/2015	6:26	02/01/2015	7:50	1	84	84	Tree related-tree broken	Overhead Service	Repair		I
150320494	D28124	02/01/2015	6:29	02/01/2015	12:30	9	3249	361	Overhead equipment	Overhead Primary	Cut in Clear	Repair	I
150321019	D28124	02/01/2015	6:29	02/01/2015	10:00	173	36503	210	Overhead equipment	Other		Repair	I
150320465	D55001	02/01/2015	6:40	02/01/2015	8:52	64	8448	131	Tree related-tree broken	Other	Cut in Clear		I
150320422	Q11516	02/01/2015	6:44	02/01/2015	9:00	1	136	136	Tree related-tree contact	Overhead Service	Repair		I
150320649	D01001	02/01/2015	6:48	02/01/2015	8:55	3	381	127	Overhead equipment	Overhead Primary	Repair		I
150320471	B82001	02/01/2015	6:50	02/01/2015	8:44	1	114	114	Overhead equipment				I
150320472	R01153	02/01/2015	6:53	02/01/2015	10:50	1	237	236	Overhead equipment	Overhead Primary			III
150320474	P26284	02/01/2015	6:54	02/02/2015	3:07	1	1213	1213	Overhead equipment	Overhead Primary	Repair		I
150320906	L43153	02/01/2015	6:55	02/01/2015	23:32	118	117646	997	Overhead equipment	Overhead Primary	Repair	Replace - Same Size	I
150320501	K07322	02/01/2015	6:58	02/01/2015	8:57	34	4046	119	Overhead equipment	Overhead Primary	Repair		I
150320676	K79213	02/01/2015	7:02	02/01/2015	11:31	89	23941	268	Public	Overhead Primary	Patrol/Test/Inspect	Repair	IV

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
150320598	P83710	02/01/2015	7:03	02/01/2015	9:55	33	5676	172	Overhead equipment	Tree	Remove	Remove	I
150320505	R16510	02/01/2015	7:06	02/01/2015	8:08	1	62	62	Tree related-tree contact	Overhead Service	Cut in Clear	Repair	I
150320509	U95003	02/01/2015	7:06	02/01/2015	10:12	1	186	186	Tree related-tree broken	Overhead Service	Repair	Repair	II
150320909	M42107	02/01/2015	7:09	02/01/2015	9:20	78	10218	130	Overhead equipment	Overhead Primary	Repair		I
150320811	C76002	02/01/2015	7:10	02/01/2015	12:26	10	3160	316	Overhead equipment	Overhead Primary	Patrol/Test/Inspect	Repair	I
150320524	S09520	02/01/2015	7:10	02/01/2015	8:18	1	68	68	Overhead equipment	Overhead Secondary	Repair	Repair	VI
150320552	Q34360	02/01/2015	7:14	02/01/2015	13:53	75	29925	399	Overhead equipment	Overhead Primary	Patrol/Test/Inspect	Repair	I
150320712	P26284	02/01/2015	7:14	02/01/2015	18:04	11	7150	650	Overhead equipment	Overhead Primary	Tie/Tighten	Repair	I
150322037	K31120	02/01/2015	7:15	02/01/2015	14:11	222	92352	415	Overhead equipment	Overhead Primary			I
150321023	P83710	02/01/2015	7:20	02/01/2015	11:10	4	920	230	Overhead equipment				I
150325184	R95520	02/01/2015	7:23	02/01/2015	23:04	4	3764	940	Tree related-tree broken	Transformer Fuse	Replace - Same Size		I
150320576	B77001	02/01/2015	7:29	02/01/2015	9:15	36	3816	105	Tree related-tree broken	Overhead Primary	Replace - Same Size	Replace - Same Size	I
150320575	R05186	02/01/2015	7:30	02/01/2015	10:18	6	1008	168	Overhead equipment	Overhead Secondary	Repair	Replace - Same Size	I
150320581	C30002	02/01/2015	7:30	02/01/2015	10:03	56	8568	152	Overhead equipment	Other	Patrol/Test/Inspect	Patrol/Test/Inspect	III
150320617	C30002	02/01/2015	7:31	02/01/2015	9:57	98	14308	145	Overhead equipment	Recloser	Patrol/Test/Inspect	Patrol/Test/Inspect	III
150320699	Q25802	02/01/2015	7:34	02/01/2015	20:10	14	10584	756	Overhead equipment	Overhead Primary	Repair		I
150320590	L43153	02/01/2015	7:36	02/01/2015	23:28	16	15232	952	Overhead equipment	Overhead Primary	Repair		I
150320629	J79306	02/01/2015	7:41	02/01/2015	9:09	1	88	87	Tree related-tree broken	Overhead Service	Reconnect		I
150320637	A48005	02/01/2015	7:41	02/01/2015	8:41	1155	69300	59	Tree related-tree broken	Tree			I
150320703	P26280	02/01/2015	7:47	02/01/2015	12:04	180	46260	256	Overhead equipment	Overhead Primary	Repair		I
150320668	M41112	02/01/2015	7:49	02/01/2015	10:22	1	153	152	Overhead equipment	Overhead Secondary	Repair		I
150320682	Q36410	02/01/2015	7:51	02/01/2015	9:42	115	12765	111	Overhead equipment	Fuse	Replace - Same Size	Repair	I
150320683	Q37370	02/01/2015	7:54	02/02/2015	0:45	3	3033	1010	Overhead equipment	Fuse	Replace - Same Size		I
150320685	L43154	02/01/2015	7:55	02/02/2015	4:14	1	1219	1219	Tree related-tree broken	Overhead Secondary	Repair		I
150320692	D70005	02/01/2015	7:57	02/01/2015	10:58	4	724	180	Tree related-tree broken	Tree	Trim		I
150320690	J05140	02/01/2015	7:58	02/01/2015	12:30	1	272	272	Tree related-tree broken	Overhead Service	Repair		I
150320719	B93001	02/01/2015	8:05	02/01/2015	9:33	113	9944	88	Overhead equipment	Jumper	Repair		I
150320723	N94180	02/01/2015	8:10	02/02/2015	10:00	1	1550	1549	Tree related-tree broken	Overhead Service	Repair		I
150320728	D48002	02/01/2015	8:11	02/01/2015	11:49	1	218	217	Tree related-tree broken	Overhead Service	Patrol/Test/Inspect	Repair	I
150320725	Q34366	02/01/2015	8:11	02/01/2015	22:03	1	832	831	Unknown	Fuse	Replace - Same Size	Replace - Same Size	I
150320733	D72002	02/01/2015	8:13	02/01/2015	13:31	1	318	317	Tree related-tree contact	Overhead Primary	Repair		I
150321137	R16511	02/01/2015	8:19	02/01/2015	11:00	58	9338	161	Tree related-tree contact	Overhead Primary			I
150320753	N67315	02/01/2015	8:23	02/01/2015	13:15	1	292	291	Tree related-tree broken	Overhead Service	Reconnect		I
150320759	A45001	02/01/2015	8:25	02/01/2015	15:30	2	850	425	Tree related-tree contact	Overhead Service	Repair		I
150320758	J01119	02/01/2015	8:25	02/01/2015	12:03	3	654	217	Tree related-tree broken	Overhead Service	Repair		I
150320763	R16511	02/01/2015	8:26	02/01/2015	11:14	1	168	167	Tree related-tree contact	Overhead Primary	Repair		I
150320768	Q34380	02/01/2015	8:29	02/02/2015	1:11	17	17034	1001	Tree related-tree broken	Overhead Service	Repair		I
150320769	R16511	02/01/2015	8:29	02/01/2015	11:15	1	166	165	Tree related-tree contact	Overhead Primary	Repair		I
150321276	R07382	02/01/2015	8:30	02/01/2015	15:47	17	7429	436	Tree related-tree contact	Overhead Primary	Tie/Tighten	Repair	I
150320790	R07382	02/01/2015	8:30	02/01/2015	10:45	158	21330	135	Overhead equipment	Recloser	Patrol/Test/Inspect	Repair	I
150320772	J12166	02/01/2015	8:30	02/01/2015	9:45	1	75	75	Overhead equipment	Connector	Repair		III
150320783	R50910	02/01/2015	8:31	02/02/2015	6:10	1	1299	1299	Overhead equipment	Overhead Secondary	Repair		I
150320839	Q11517	02/01/2015	8:32	02/01/2015	21:40	9	7092	788	Tree related-tree contact	Other			I
150320797	R50910	02/01/2015	8:34	02/02/2015	6:18	1	1304	1303	Tree related-tree contact	Overhead Secondary	Repair		I
150320801	D81001	02/01/2015	8:36	02/01/2015	13:30	2	588	294	Tree related-tree broken	Overhead Service	Replace - Same Size	Replace - Same Size	I
150320824	Q34366	02/01/2015	8:39	02/01/2015	15:05	23	8878	385	Tree related-tree contact	Overhead Primary	Tie/Tighten	Repair	I
150320819	K65221	02/01/2015	8:44	02/01/2015	12:30	13	2938	226	Overhead equipment	Overhead Secondary			III
150321406	B61002	02/01/2015	8:46	02/01/2015	11:40	29	5046	174	Overhead equipment	Disconnect Switch	Replace - Same Size	Patrol/Test/Inspect	I
150320846	N70331	02/01/2015	8:53	02/01/2015	11:30	1	157	156	Tree related-tree broken	Overhead Secondary	Reconnect		I
150320855	B61001	02/01/2015	8:55	02/01/2015	12:22	1	207	206	Tree related-tree broken	Tree	Remove		I
150321455	Q34360	02/01/2015	8:56	02/01/2015	14:00	9	2736	304	Tree related-tree contact	Fuse	Replace - Same Size	Repair	I
150320938	Q25801	02/01/2015	9:01	02/01/2015	19:39	158	100804	637	Overhead equipment	Overhead Primary	Repair	Replace - Same Size	I
150320896	B35002	02/01/2015	9:03	02/01/2015	10:09	7	462	66	Overhead equipment				I
150320935	B93002	02/01/2015	9:13	02/01/2015	15:52	41	16359	399	Overhead equipment	Overhead Primary	Patrol/Test/Inspect	Repair	I
150320941	D01001	02/01/2015	9:18	02/01/2015	10:30	1	72	72	Unknown	Fuse	Repair		I
150320960	P83710	02/01/2015	9:25	02/01/2015	22:30	5	3925	785	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Repair	I

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
150320976	V92555	02/01/2015	9:25	02/01/2015	11:10	87	9135	105	Overhead equipment	Fuse	Replace - Same Size	Patrol/Test/Inspect	II
150321339	R07382	02/01/2015	9:32	02/01/2015	14:50	5	1590	317	Overhead equipment	Overhead Primary	Repair	Repair	I
150321154	A91004	02/01/2015	9:32	02/01/2015	10:19	666	31302	46	Substation equipment	Substation Breaker	Switch/Reset		I
150321044	R07382	02/01/2015	9:32	02/01/2015	10:54	57	4674	82	Overhead equipment				I
150320982	B08004	02/01/2015	9:33	02/01/2015	13:12	1	219	219	Tree related-tree broken	Tree	Remove		I
150320985	J79305	02/01/2015	9:34	02/02/2015	6:45	1	1271	1271	Overhead equipment	Connector	Repair		I
150321344	P73157	02/01/2015	9:36	02/01/2015	14:01	180	47700	264	Animal related	Animal Guard			VI
150321336	P73157	02/01/2015	9:36	02/01/2015	11:13	868	84196	97	Animal related	Animal Guard			VI
150321026	J88165	02/01/2015	9:37	02/01/2015	11:33	1	116	116	Overhead equipment	Connector	Replace - Same Size		VI
150321045	M42107	02/01/2015	9:38	02/01/2015	11:48	1	130	130	Overhead equipment	Overhead Service	Repair		I
150321340	P73160	02/01/2015	9:39	02/01/2015	11:13	108	10152	94	Substation equipment	Substation Misc.			VI
5001155	R39934	02/01/2015	9:40	02/01/2015	11:02	1	81	81	Overhead equipment	Fuse		Patrol/Test/Inspect	VI
150321162	A91002	02/01/2015	9:53	02/01/2015	12:38	17	2805	164	Overhead equipment	Fuse	Replace - Same Size		I
150321155	N70331	02/01/2015	9:54	02/01/2015	10:14	1	20	20	Tree related-tree broken	Overhead Service	Reconnect		I
150321161	B61001	02/01/2015	9:55	02/01/2015	11:37	15	1530	101	Overhead equipment				I
150321229	N60181	02/01/2015	9:59	02/01/2015	10:52	18	954	52	Overhead equipment	Overhead Primary	Repair	Replace - Same Size	I
150321294	W03570	02/01/2015	9:59	02/01/2015	11:25	9	774	85	Tree related-tree broken	Overhead Primary			II
150321191	P07179	02/01/2015	10:01	02/01/2015	12:10	9	1161	129	Tree related-tree broken	Overhead Service	Repair		I
150321181	A91002	02/01/2015	10:01	02/01/2015	12:45	1	164	164	Overhead equipment				I
150321186	U02597	02/01/2015	10:01	02/01/2015	13:30	2	418	209	Overhead equipment	Overhead Secondary			II
150321218	B62003	02/01/2015	10:02	02/01/2015	14:11	3	747	248	Overhead equipment				I
150321192	P58154	02/01/2015	10:02	02/01/2015	11:40	1	98	97	Animal related	Transformer Fuse	Replace - Same Size		VI
150321197	J63173	02/01/2015	10:07	02/01/2015	15:45	1	338	338	Underground equipment	Underground Service			III
150321205	K28183	02/01/2015	10:08	02/01/2015	11:43	63	5985	94	Overhead equipment	Recloser	Switch/Reset		III
150321128	K31120	02/01/2015	10:10	02/01/2015	14:10	173	41520	240	Overhead equipment	Overhead Primary			I
150321226	J71128	02/01/2015	10:15	02/01/2015	13:32	6	1182	196	Overhead equipment	Overhead Secondary	Tie/Tighten		I
150321248	B45005	02/01/2015	10:15	02/01/2015	11:34	16	1264	78	Tree related-tree broken	Overhead Primary	Trim		I
150321225	D35003	02/01/2015	10:15	02/01/2015	11:01	1	46	45	Overhead equipment	Fuse	Repair		I
150321250	K07320	02/01/2015	10:20	02/01/2015	13:48	1	208	207	Tree related-tree contact	Overhead Service			I
150321272	P83710	02/01/2015	10:21	02/01/2015	16:36	33	12375	374	Overhead equipment	Tree	Remove	Remove	I
150321275	R16510	02/01/2015	10:28	02/01/2015	11:46	1	78	77	Overhead equipment	Fuse	Replace - Same Size		I
150321288	W03570	02/01/2015	10:33	02/01/2015	12:30	50	5850	117	Tree related-tree broken	Overhead Primary			II
150321293	C00001	02/01/2015	10:36	02/01/2015	12:04	1	88	88	Underground equipment	Underground Primary	Patrol/Test/Inspect		I
150321297	P83705	02/01/2015	10:36	02/01/2015	22:00	1	684	683	Overhead equipment	Overhead Primary	Repair	Repair	I
150321300	D35003	02/01/2015	10:37	02/01/2015	13:36	1	179	178	Overhead equipment	Overhead Service	Repair		I
150325217	P83705	02/01/2015	10:38	02/01/2015	21:00	63	39186	621	Overhead equipment	Overhead Primary	Repair	Repair	I
150325306	Q70429	02/01/2015	10:43	02/01/2015	18:25	616	284592	461	Substation equipment				I
150321385	V92540	02/01/2015	10:43	02/01/2015	12:30	32	3424	107	Overhead equipment	Fuse	Replace - Same Size	Patrol/Test/Inspect	II
150321318	P26284	02/01/2015	10:47	02/02/2015	2:21	1	934	933	Overhead equipment	Fuse	Replace - Same Size		I
150321319	J71128	02/01/2015	10:48	02/01/2015	14:26	1	218	218	Tree related-tree contact	Overhead Secondary	Repair	Patrol/Test/Inspect	I
150321322	J71128	02/01/2015	10:48	02/01/2015	14:25	1	217	217	Tree related-tree contact	Overhead Secondary	Repair		I
150321526	D28124	02/01/2015	10:50	02/01/2015	12:30	7	700	100	Overhead equipment	Overhead Primary			I
150321386	R07382	02/01/2015	10:56	02/01/2015	11:20	158	3792	23	Tree related-tree contact	Recloser			I
150321366	V35002	02/01/2015	11:05	02/01/2015	12:49	1	104	104	Tree related-tree broken	Overhead Service	Repair		II
150321537	D36001	02/01/2015	11:09	02/01/2015	12:15	6	396	65	Overhead equipment	Pole	Switch/Reset		I
150321571	D36001	02/01/2015	11:09	02/01/2015	17:53	3	1212	403	Overhead equipment	Pole	Switch/Reset	Replace - Same Size	I
150321418	D70004	02/01/2015	11:14	02/01/2015	12:11	8	456	57	Tree related-tree broken	Overhead Primary	Trim		I
150321422	R07382	02/01/2015	11:20	02/01/2015	20:50	29	16530	570	Overhead equipment	Overhead Primary	Tie/Tighten	Repair	I
150321440	B62002	02/01/2015	11:28	02/01/2015	15:02	25	5350	213	Overhead equipment	Fuse	Patrol/Test/Inspect	Replace - Same Size	I
150321457	U97528	02/01/2015	11:39	02/01/2015	13:20	1	101	100	Overhead equipment	Overhead Service	Repair		II
150321459	L43154	02/01/2015	11:42	02/02/2015	5:01	1	1039	1038	Tree related-tree broken	Overhead Service	Repair		I
150321466	B45005	02/01/2015	11:48	02/01/2015	16:05	1	257	256	Overhead equipment	Overhead Primary	Repair		I
150321471	Q36410	02/01/2015	11:49	02/01/2015	20:14	6	3030	505	Tree related-tree contact	Overhead Transformer	Switch/Reset	Repair	I
150321501	R50910	02/01/2015	11:52	02/01/2015	16:30	256	71168	278	Overhead equipment	Overhead Primary	Repair		I
150325396	K31124	02/01/2015	11:53	02/02/2015	14:00	6	9402	1567	Overhead equipment	Fuse	Replace - Same Size		I
150321496	A73002	02/01/2015	11:55	02/01/2015	13:58	21	2583	122	Unknown	Overhead Primary	Patrol/Test/Inspect		I

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
150321494	R07382	02/01/2015	11:56	02/01/2015	21:45	6	3534	589	Overhead equipment	Overhead Transformer	Switch/Reset	Switch/Reset	I
150321507	J61113	02/01/2015	11:58	02/01/2015	12:57	1	59	58	Overhead equipment				III
150321559	Q11516	02/01/2015	12:17	02/01/2015	14:20	217	26691	122	Tree related-tree contact	Fuse	Replace - Same Size		I
150321547	N70330	02/01/2015	12:19	02/01/2015	14:12	1	113	113	Tree related-tree contact	Overhead Secondary	Repair		I
150321552	R07382	02/01/2015	12:22	02/02/2015	0:15	1	713	712	Overhead equipment	Overhead Service	Repair	Repair	I
150321562	A45002	02/01/2015	12:32	02/01/2015	14:09	1	97	97	Overhead equipment				I
150321662	X09534	02/01/2015	13:04	02/01/2015	15:55	6	1026	171	Tree related-tree contact	Overhead Service	Repair		IV
150321943	A26001	02/01/2015	13:09	02/01/2015	14:00	1	51	50	Overhead equipment				I
150321952	B08004	02/01/2015	13:23	02/01/2015	14:55	6	552	92	Overhead equipment	Fuse	Replace - Same Size		I
150321953	C70004	02/01/2015	13:24	02/01/2015	14:31	1	67	66	Overhead equipment	Fuse	Replace - Same Size		III
150321962	N05170	02/01/2015	13:36	02/01/2015	22:55	1	559	558	Tree related-tree contact	Overhead Service	Repair		I
150321978	D72002	02/01/2015	13:41	02/01/2015	17:18	1	217	216	Overhead equipment	Overhead Secondary	Repair		I
150321976	Y57001	02/01/2015	13:41	02/01/2015	15:10	1	89	88	Tree related-tree broken	Overhead Service	Repair		IV
150322126	M41113	02/01/2015	13:44	02/01/2015	16:10	7	1022	145	Tree related-tree broken	Overhead Primary	Repair		I
150322738	R07381	02/01/2015	13:57	02/01/2015	15:29	71	6532	91	Tree related-tree contact	Fuse	Replace - Same Size	Repair	I
150322743	N70330	02/01/2015	14:00	02/01/2015	15:24	1	84	84	Overhead equipment	Overhead Service	Reconnect		I
150322852	A97006	02/01/2015	14:04	02/01/2015	15:45	1	101	101	Overhead equipment	Jumper	Repair		I
150322908	B00003	02/01/2015	14:05	02/01/2015	16:22	1	137	136	Tree related-tree broken	Overhead Service	Repair		I
150320984	L43153	02/01/2015	14:08	02/02/2015	1:00	7	4564	651	Overhead equipment	Overhead Secondary			I
150323089	B84006	02/01/2015	14:09	02/01/2015	15:41	1	92	91	Unknown	Fuse	Replace - Same Size		I
150323899	D70004	02/01/2015	14:32	02/01/2015	23:41	1	549	548	Tree related-tree broken	Overhead Service	Repair	Repair	I
150324261	Q93522	02/01/2015	14:40	02/02/2015	9:21	1	1121	1120	Tree related-tree broken	Fuse	Patrol/Test/Inspect	Repair	I
150324920	A91001	02/01/2015	14:55	02/01/2015	19:30	1	275	274	Overhead equipment	Other	Patrol/Test/Inspect	Repair	I
150325300	Q37370	02/01/2015	15:01	02/01/2015	20:38	273	92001	336	Overhead equipment	Overhead Primary	Raise	Raise	I
150325173	R16510	02/01/2015	15:03	02/01/2015	18:41	111	24198	217	Tree related-tree contact	Recloser	Switch/Reset		I
150325176	P83705	02/01/2015	15:12	02/01/2015	23:11	1	479	479	Overhead equipment	Overhead Primary	Repair	Repair	I
150325186	D16001	02/01/2015	15:17	02/01/2015	17:28	1	131	130	Tree related-tree broken	Overhead Service	Repair		I
150325210	J79305	02/01/2015	15:20	02/02/2015	3:23	81	58563	722	Overhead equipment	Pole	Replace - New Size	Replace - New Size	I
150325197	K31120	02/01/2015	15:21	02/02/2015	15:00	3	4257	1419	Overhead equipment	Disconnect Switch	Replace - Same Size		I
150325211	D16001	02/01/2015	15:28	02/01/2015	17:15	4	428	107	Tree related-tree broken	Tree	Trim		I
150325222	J79305	02/01/2015	15:39	02/02/2015	5:50	1	851	850	Overhead equipment	Overhead Primary	Repair	Repair	I
150325223	T08501	02/01/2015	15:39	02/01/2015	17:45	1	126	126	Overhead equipment	Overhead Service	Repair	Repair	VI
150321965	Q34360	02/01/2015	15:55	02/01/2015	23:39	1	464	464	Tree related-tree contact	Overhead Service		Reconnect	I
150325313	J63172	02/01/2015	16:36	02/01/2015	20:20	1	224	223	Underground equipment	Underground Service			III
150325318	J71128	02/01/2015	16:45	02/01/2015	18:15	1	90	90	Tree related-tree contact	Overhead Transformer	Switch/Reset		I
150325321	P83710	02/01/2015	16:50	02/01/2015	21:50	1	300	299	Overhead equipment	Tree	Remove	Remove	I
150325330	J01119	02/01/2015	17:00	02/01/2015	20:35	7	1505	214	Overhead equipment	Overhead Transformer	Replace - Same Size	Replace - Same Size	I
150325342	L43153	02/01/2015	17:04	02/02/2015	21:15	4	6764	1691	Tree related-tree broken	Fuse	Replace - Same Size		I
150325345	B45005	02/01/2015	17:22	02/01/2015	18:11	1	49	49	Tree related-tree broken	Overhead Service	Repair		I
150325348	B81003	02/01/2015	17:29	02/01/2015	19:30	1	121	120	Overhead equipment	Connector	Repair		I
150325453	R95520	02/01/2015	17:32	02/01/2015	23:48	4	1504	375	Overhead equipment	Overhead Primary	Repair		I
150325370	F10002	02/01/2015	17:42	02/01/2015	23:51	47	17343	368	Overhead equipment	Overhead Primary	Repair		III
150325361	J15303	02/01/2015	17:44	02/01/2015	18:34	1	50	49	Overhead equipment	Pole	Replace - Same Size		I
150325404	Q91175	02/01/2015	17:46	02/01/2015	20:15	3	447	149	Overhead equipment	Jumper			I
150325380	N67315	02/01/2015	17:58	02/01/2015	18:16	1	18	17	Overhead equipment	Overhead Service	Reconnect		I
150333105	K31120	02/01/2015	18:27	02/02/2015	10:31	2	1928	963	Tree related-tree broken	Overhead Service	Cut in Clear		I
150325398	X73001	02/01/2015	18:40	02/01/2015	21:42	1	182	181	Overhead equipment	Overhead Service	Repair		IV
150325400	T08501	02/01/2015	18:41	02/01/2015	22:25	1	224	224	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Repair	VI
150325431	Y79500	02/01/2015	18:45	02/01/2015	20:05	7	560	79	Overhead equipment	Overhead Primary	Raise		IV
150332887	N94180	02/01/2015	19:13	02/02/2015	15:23	6	7260	1210	Overhead equipment	Jumper	Repair		I
150325455	Q25801	02/01/2015	20:01	02/01/2015	23:40	56	12264	219	Tree related-tree contact	Fuse	Replace - Same Size		I
150325440	S31527	02/01/2015	20:31	02/01/2015	22:10	5	495	98	Overhead equipment	Fuse	Replace - Same Size		VI
150326408	V77543	02/01/2015	20:34	02/01/2015	22:54	10	1400	140	Overhead equipment	Overhead Transformer	Repair	Repair	II
150325447	D01001	02/01/2015	20:50	02/02/2015	7:23	1	633	632	Overhead equipment	Pole	Patrol/Test/Inspect		I
150325456	D72003	02/01/2015	21:25	02/02/2015	0:27	1	182	182	Overhead equipment				I
150325481	L43153	02/01/2015	21:32	02/02/2015	0:33	1	181	181	Overhead equipment				I

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
150325520	346003	02/01/2015	21:35	02/01/2015	22:08	4	132	33	Overhead equipment	Overhead Transformer	Switch/Reset		VI
150325635	D66002	02/01/2015	21:39	02/02/2015	1:25	1	226	226	Overhead equipment	Overhead Transformer	Replace - Same Size		IV
150325850	344003	02/01/2015	21:46	02/01/2015	23:17	1	91	90	Overhead equipment	Overhead Transformer	Replace - Same Size		VI
150326398	M40132	02/01/2015	22:11	02/02/2015	0:15	1	124	123	Overhead equipment	Overhead Service			I
150326430	Q93522	02/01/2015	23:03	02/03/2015	12:56	1	2273	2273	Tree related-tree broken	Tree	Patrol/Test/Inspect		I
150326438	B68002	02/01/2015	23:28	02/01/2015	23:40	1	12	11	Other	Customer Equipment			III
150332596	L71171	02/02/2015	3:40	02/02/2015	5:14	682	64108	93	Overhead equipment	Pole	Replace - Same Size	Replace - Same Size	IV
150332598	L80222	02/02/2015	3:45	02/02/2015	5:55	21	2730	130	Overhead equipment	Overhead Primary	Repair	Repair	IV
150332611	P49183	02/02/2015	4:09	02/02/2015	6:18	41	5289	128	Overhead equipment	Fuse	Repair	Replace - Same Size	I
150332606	R24832	02/02/2015	4:10	02/02/2015	6:41	1	151	150	Overhead equipment				V
150332630	L71171	02/02/2015	5:19	02/02/2015	14:47	104	59072	567	Overhead equipment				IV
150333384	L71171	02/02/2015	5:20	02/02/2015	9:57	86	23822	277	Overhead equipment				IV
150332639	F10002	02/02/2015	5:39	02/02/2015	10:20	2	562	280	Overhead equipment	Overhead Primary	Repair	Patrol/Test/Inspect	III
150333185	X16511	02/02/2015	5:53	02/02/2015	8:45	82	14104	172	Substation equipment				IV
150332667	R50910	02/02/2015	6:19	02/02/2015	13:00	8	3208	400	Overhead equipment	Overhead Primary	Repair		I
150333049	M21133	02/02/2015	6:26	02/02/2015	11:12	4	1144	285	Tree related-tree broken	Tree	Trim	Trim	VI
150332802	M21133	02/02/2015	6:26	02/02/2015	8:35	7	903	129	Overhead equipment	Overhead Primary	Repair	Repair	VI
150332672		02/02/2015	6:30	02/02/2015	7:10	1	40	39	Overhead equipment	Jumper	Replace - Same Size		IV
150332675	G50002	02/02/2015	6:36	02/02/2015	9:48	1	192	191	Underground equipment	Underground Service	Patrol/Test/Inspect	Repair	IV
150332691	L43154	02/02/2015	6:48	02/02/2015	8:50	1	122	121	Tree related-tree broken	Overhead Secondary			I
150332731	Z20542	02/02/2015	6:48	02/02/2015	11:30	34	9588	281	Overhead equipment	Overhead Primary	Patrol/Test/Inspect	Repair	IV
150332729	F03004	02/02/2015	7:05	02/02/2015	8:09	1	64	63	Overhead equipment	Connector	Repair		III
150332753	R48166	02/02/2015	7:13	02/02/2015	8:53	1	100	100	Overhead equipment	Overhead Service	Repair		IV
150332771	D01001	02/02/2015	7:21	02/02/2015	13:04	1	343	342	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Repair	I
150332870	D60001	02/02/2015	7:58	02/02/2015	10:00	26	3172	121	Underground equipment	Underground Primary		Repair	III
150332874	R07382	02/02/2015	8:02	02/02/2015	11:11	1	189	188	Tree related-tree broken	Overhead Service	Repair		I
150333042	D60001	02/02/2015	8:37	02/02/2015	10:06	1	89	88	Underground equipment	Underground Primary			III
150333144	B45005	02/02/2015	8:53	02/02/2015	10:35	1	102	101	Tree related-tree broken	Overhead Service	Repair	Repair	I
150333156	A49003	02/02/2015	8:55	02/02/2015	10:36	1	101	100	Tree related-tree broken	Overhead Service	Raise		I
150333196	K74166	02/02/2015	9:03	02/02/2015	10:09	1	66	66	Tree related-tree contact	Overhead Service	Repair		IV
150333520	D90004	02/02/2015	10:12	02/02/2015	12:59	1	167	166	Overhead equipment	Overhead Service	Replace - Same Size		III
150333606	P73157	02/02/2015	10:37	02/02/2015	13:37	1	180	180	Overhead equipment	Overhead Transformer		Replace - Same Size	VI
150333900	Q25801	02/02/2015	11:57	02/02/2015	20:24	1	507	506	Tree related-tree contact	Overhead Service	Repair		I
150334059	S22594	02/02/2015	12:52	02/02/2015	14:00	1	68	68	Overhead equipment				VI
150334287		02/02/2015	13:59	02/02/2015	18:00	1	241	240	Tree related-tree broken	Overhead Primary	Repair		I
150334479	U97002	02/02/2015	14:46	02/02/2015	15:20	1	34	34	Overhead equipment	Overhead Service	Repair	Repair	II
150334524	N94180	02/02/2015	14:55	02/04/2015	12:42	2	5494	2746	Tree related-tree broken	Overhead Primary	Repair	Repair	I
150334609	L73160	02/02/2015	15:20	02/02/2015	17:15	1	115	114	Overhead equipment	Connector	Replace - Same Size		IV
150334616	P69173	02/02/2015	15:21	02/02/2015	16:15	1	54	54	Overhead equipment	Overhead Service	Repair		III
150334623	Q83171	02/02/2015	15:24	02/02/2015	18:50	1	206	205	Underground equipment	Underground Service	Patrol/Test/Inspect	Repair	VI
150334741	C37002	02/02/2015	16:10	02/02/2015	17:07	1	57	56	Overhead equipment	Connector	Replace - Same Size		III
150334839	P77233	02/02/2015	17:15	02/02/2015	18:03	1	48	47	Overhead equipment	Transformer Fuse	Replace - Same Size		VI
150334932	K11376	02/02/2015	18:30	02/02/2015	21:33	1	183	182	Overhead equipment	Connector	Patrol/Test/Inspect	Repair	V
5001195	Q64918	02/02/2015	19:06	02/02/2015	21:04	6	704	117	Overhead equipment	Overhead Secondary	Raise		VI
150334980	X83533	02/02/2015	19:35	02/02/2015	20:58	1	83	83	Overhead equipment	Transformer Fuse	Replace - Same Size	Replace - Same Size	IV
150336348	V22555	02/02/2015	21:25	02/02/2015	22:51	1	86	85	Overhead equipment	Transformer Fuse	Replace - New Size		II
5001197	Q64918	02/02/2015	22:15	02/02/2015	23:41	6	514	85	Overhead equipment	Overhead Transformer		Replace - Same Size	VI
150340099	J88165	02/02/2015	22:52	02/03/2015	3:52	3	900	300	Underground equipment	Underground Transformer	Disconnect	Replace - Same Size	VI
150340098	J88165	02/02/2015	22:52	02/03/2015	0:50	71	8378	117	Underground equipment	Underground Transformer	Disconnect	Replace - Same Size	VI
150340097	R53416	02/03/2015	0:49	02/03/2015	5:45	5	1480	296	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Repair	V
150340525	D31016	02/03/2015	1:48	02/03/2015	3:45	46	5382	117	Overhead equipment	Overhead Primary	Repair		III
150343092	A91001	02/03/2015	2:44	02/03/2015	9:50	3	1278	425	Underground equipment	Underground Transformer	Replace - Same Size	Replace - Same Size	I
150341632	A91001	02/03/2015	2:44	02/03/2015	7:40	26	7696	296	Underground equipment	Fuse	Replace - Same Size	Replace - Same Size	I
150342964	N19371	02/03/2015	4:36	02/03/2015	10:45	8	2952	368	Overhead equipment	Overhead Primary	Repair		V
150342930	J01118	02/03/2015	5:32	02/03/2015	7:30	1	118	117	Overhead equipment	Transformer Fuse	Replace - Same Size		I
150342955	S22592	02/03/2015	6:22	02/03/2015	8:05	1	103	103	Overhead equipment				VI

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5001209	T59902	02/03/2015	8:25	02/03/2015	9:46	1	80	80	Overhead equipment	Fuse	Replace - Same Size		VI
150343205	U33586	02/03/2015	8:30	02/03/2015	9:50	1	80	79	Overhead equipment	Transformer Fuse	Repair		II
150343206	H22348	02/03/2015	8:30	02/03/2015	9:53	1	83	83	Overhead equipment	Overhead Service	Tie/Tighten	Advise Customer	V
150343401	S22594	02/03/2015	9:09	02/03/2015	9:50	1	41	40	Overhead equipment	Overhead Secondary	Repair		VI
150343606	335002	02/03/2015	9:46	02/03/2015	12:44	1	178	177	Public	Overhead Service	Repair		VI
150343723	J15302	02/03/2015	10:04	02/03/2015	10:55	42	2142	50	Overhead equipment	Overhead Primary	Cut in Clear	Repair	I
150343766	K25166	02/03/2015	10:16	02/03/2015	10:50	1	34	34	Animal related	Jumper	Repair	Repair	VI
150343874	C37001	02/03/2015	10:43	02/03/2015	12:10	1	87	87	Overhead equipment	Fuse	Replace - Same Size		III
150343894	L93132	02/03/2015	10:49	02/03/2015	13:06	1	137	136	Overhead equipment	Meter			VI
150343927	S93553	02/03/2015	10:59	02/03/2015	12:10	1	71	71	Overhead equipment	Transformer Fuse	Replace - Same Size		VI
150343938	S43512	02/03/2015	11:01	02/03/2015	11:43	1	42	42	Other	Other			VI
150343949	M47802	02/03/2015	11:03	02/03/2015	11:25	1	22	21	Overhead equipment	Overhead Service			V
150343987	U26001	02/03/2015	11:12	02/03/2015	12:05	1	53	52	Overhead equipment	Connector	Replace - Same Size		II
150344253	M31201	02/03/2015	12:30	02/03/2015	13:35	7	455	64	Tree related-tree broken	Transformer Fuse	Replace - Same Size		I
150344288	L35137	02/03/2015	12:41	02/03/2015	13:36	1	55	55	Overhead equipment	Transformer Fuse	Repair		III
150344319	P82290	02/03/2015	12:53	02/03/2015	13:18	1	25	24	Animal related	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
150344637	D41003	02/03/2015	14:07	02/03/2015	15:16	1	69	69	Overhead equipment	Disconnect Switch	Replace - Same Size	Repair	I
5001217	P20913	02/03/2015	14:25	02/03/2015	16:26	7	840	120	Animal related	Transformer Fuse	Replace - Same Size		VI
150345088	K39154	02/03/2015	14:54	02/03/2015	17:57	2	366	182	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	III
150345064	Q85162	02/03/2015	16:52	02/03/2015	17:46	1	54	53	Animal related	Transformer Fuse	Replace - Same Size		VI
150345084	J06167	02/03/2015	17:06	02/03/2015	17:57	1	51	50	Overhead equipment	Fuse	Repair	Replace - Same Size	I
150345269	J15303	02/03/2015	20:15	02/03/2015	21:05	1	50	49	Other	Other			I
150347851	R49261	02/03/2015	22:22	02/04/2015	4:50	1	388	388	Underground equipment	Underground Service	Disconnect	Repair	VI
150350146	M40132	02/04/2015	2:34	02/04/2015	5:13	13	2067	159	Overhead equipment	Recloser	Repair	Repair	I
150352327	B65003	02/04/2015	3:24	02/04/2015	4:00	1	36	35	Overhead equipment	Connector	Replace - Same Size		I
150352335	Q93522	02/04/2015	6:02	02/04/2015	9:05	1	183	182	Tree related-tree broken	Transformer Fuse	Repair		I
150352382	J80807	02/04/2015	7:12	02/04/2015	8:30	1	78	77	Overhead equipment	Overhead Service	Repair	Repair	V
150352384	Q24312	02/04/2015	7:14	02/04/2015	13:25	1	371	371	Underground equipment	Underground Service			VI
5001225	Q64918	02/04/2015	7:57	02/04/2015	9:20	5	410	82	Overhead equipment	Fuse	Repair		VI
150352494	B45004	02/04/2015	8:06	02/04/2015	10:02	1	116	116	Overhead equipment	Overhead Service	Repair	Repair	I
150352500	D31016	02/04/2015	8:10	02/04/2015	8:47	1	37	36	Overhead equipment	Other	Patrol/Test/Inspect	Patrol/Test/Inspect	III
150352527	D81001	02/04/2015	8:20	02/04/2015	9:12	1	52	52	Overhead equipment	Connector	Replace - Same Size		I
150352768	J83138	02/04/2015	9:29	02/04/2015	9:54	1	25	24	Animal related	Transformer Fuse	Replace - Same Size		VI
150352775	E10001	02/04/2015	9:30	02/04/2015	14:32	1	302	301	Underground equipment	Underground Service			III
150352808	V39002	02/04/2015	9:40	02/04/2015	10:31	1	51	50	Overhead equipment	Connector	Repair		II
150352942	N97887	02/04/2015	10:11	02/04/2015	11:24	1	73	72	Animal related	Fuse	Replace - Same Size		V
150353037	N97887	02/04/2015	10:37	02/04/2015	11:22	1	45	45	Animal related	Fuse	Replace - Same Size		V
5001235	Q82906	02/04/2015	10:40	02/04/2015	11:13	1	32	32	Animal related	Fuse	Repair		VI
150353113	R02121	02/04/2015	10:56	02/04/2015	11:20	1	24	23	Animal related	Transformer Fuse	Repair	Repair	VI
150353131	P57108	02/04/2015	11:02	02/04/2015	11:17	1	15	14	Overhead equipment	Transformer Fuse	Replace - Same Size		VI
150353372	T11508	02/04/2015	11:12	02/04/2015	12:49	57	5529	97	Overhead equipment	Overhead Primary			VI
150353191	T11508	02/04/2015	11:12	02/04/2015	12:20	42	2856	68	Overhead equipment	Overhead Primary			VI
150353221	R59415	02/04/2015	11:24	02/04/2015	12:21	1	57	56	Overhead equipment	Overhead Service	Repair		IV
150353293	N05172	02/04/2015	11:47	02/04/2015	12:55	1	68	68	Overhead equipment	Fuse	Replace - Same Size		I
5001241	R10943	02/04/2015	11:53	02/04/2015	13:23	1	89	89	Overhead equipment	Ground Wire	Repair		VI
5001243	R10943	02/04/2015	11:55	02/04/2015	12:20	43	1093	25	Overhead equipment	Ground Wire	Repair	Tie/Tighten	VI
5001245	R10943	02/04/2015	12:02	02/04/2015	12:17	1	14	14	Overhead equipment	Ground Wire	Repair		VI
150353642	U64521	02/04/2015	13:37	02/04/2015	14:29	6	312	52	Overhead equipment	Disconnect Switch	Repair	Replace - Same Size	II
150354035	B79005	02/04/2015	16:26	02/04/2015	17:35	1	69	69	Overhead equipment	Overhead Service		Replace - Same Size	I
150354055	P26283	02/04/2015	16:34	02/04/2015	18:49	1	135	135	Other	Connector	Repair		I
150354261	J85161	02/04/2015	17:32	02/04/2015	18:51	1	79	78	Overhead equipment	Overhead Service	Repair		VI
150354977	X83541	02/04/2015	20:19	02/05/2015	1:23	1	304	303	Public				IV
150354641	X83541	02/04/2015	20:19	02/04/2015	21:43	2	168	84	Public	Pole	Replace - Same Size	Replace - Same Size	IV
150354606	S03531	02/04/2015	20:40	02/05/2015	0:30	2	460	230	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	VI
150354979	X12526	02/04/2015	22:38	02/05/2015	1:55	1	197	196	Overhead equipment	Overhead Primary	Repair		IV
150360062	R60552	02/04/2015	23:51	02/05/2015	5:15	20	6480	323	Overhead equipment	Overhead Primary	Patrol/Test/Inspect	Repair	IV

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
150362092	313135	02/05/2015	3:27	02/05/2015	7:25	4	952	238	Overhead equipment	Overhead Primary	Patrol/Test/Inspect	Repair	V
150362105	M41111	02/05/2015	4:51	02/05/2015	7:46	1	175	175	Overhead equipment	Fuse	Replace - Same Size		I
150362106	M36189	02/05/2015	5:07	02/05/2015	6:35	1	88	88	Overhead equipment	Jumper	Repair		I
150362113	S47585	02/05/2015	5:48	02/05/2015	6:30	5	210	42	Overhead equipment	Transformer Fuse	Repair	Replace - New Size	VI
150362114	IP9009	02/05/2015	5:52	02/05/2015	7:12	1	80	80	Overhead equipment	Connector	Replace - Same Size		VI
150362131	R33126	02/05/2015	5:54	02/05/2015	9:25	10	2110	210	Overhead equipment	Overhead Primary		Repair	I
150362253	D69006	02/05/2015	7:20	02/05/2015	8:57	525	50925	97	Overhead equipment	Other		Repair	I
150362344	M04364	02/05/2015	7:54	02/05/2015	9:07	97	7081	72	Overhead equipment				V
150362306	M41111	02/05/2015	8:00	02/05/2015	9:45	1	105	104	Underground equipment	Transformer Fuse	Replace - Same Size	Patrol/Test/Inspect	I
150362310		02/05/2015	8:01	02/05/2015	9:18	1	77	76	Overhead equipment				V
150362320	R33126	02/05/2015	8:05	02/05/2015	9:30	1	85	85	Overhead equipment	Overhead Primary	Repair	Patrol/Test/Inspect	I
150362406	S88502	02/05/2015	8:39	02/05/2015	10:37	1	118	117	Overhead equipment	Overhead Service	Patrol/Test/Inspect	Repair	VI
150362483	D92001	02/05/2015	9:09	02/05/2015	11:10	66	7986	121	Overhead equipment	Fuse	Patrol/Test/Inspect	Replace - Same Size	I
150362561	X75512	02/05/2015	9:48	02/05/2015	11:35	1	107	107	Overhead equipment	Overhead Service	Repair	Repair	IV
150362576	HA5430	02/05/2015	9:52	02/05/2015	10:27	1	35	34	Overhead equipment				V
150362679	R48167	02/05/2015	10:24	02/05/2015	11:15	1	51	50	Jurisdictional	Other			IV
150362682	J79306	02/05/2015	10:27	02/05/2015	12:56	1	149	149	Overhead equipment	Overhead Primary	Repair		I
150362713	U09517	02/05/2015	10:35	02/05/2015	11:42	1	67	67	Unknown	Transformer Fuse		Replace - Same Size	II
5001319	Z16547	02/05/2015	10:41	02/05/2015	11:40	230	13691	59	Jurisdictional	Overhead Primary			IV
5001289	Z16547	02/05/2015	10:41	02/05/2015	11:13	296	9199	31	Jurisdictional				IV
150363220	A97003	02/05/2015	13:32	02/05/2015	17:50	1	258	258	Overhead equipment	Overhead Transformer		Repair	I
150363298	X83541	02/05/2015	13:59	02/05/2015	15:07	1	68	68	Tree related-tree contact	Overhead Service	Repair	Repair	IV
150363342		02/05/2015	14:16	02/05/2015	15:32	1	76	75	Overhead equipment	Transformer Fuse		Replace - Same Size	III
150363382	U73599	02/05/2015	14:33	02/05/2015	15:16	1	43	43	Unknown	Fuse	Replace - Same Size		II
150363650	P17107	02/05/2015	16:22	02/05/2015	19:30	53	9964	188	Overhead equipment	Overhead Primary		Repair	IV
150363641	B27006	02/05/2015	16:23	02/05/2015	17:10	1	47	47	Overhead equipment	Connector	Replace - Same Size		I
150363793	J15302	02/05/2015	17:34	02/05/2015	18:19	1	45	45	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	I
150363829	M54315	02/05/2015	17:39	02/05/2015	19:30	1	111	110	Intentional	Meter	Reconnect		V
150363837	B25002	02/05/2015	17:46	02/05/2015	21:30	1	224	224	Overhead equipment				I
150363844	K09863	02/05/2015	17:52	02/05/2015	20:41	1	169	169	Overhead equipment	Overhead Secondary			V
150363846	U16001	02/05/2015	17:54	02/05/2015	19:00	1	66	65	Overhead equipment	Fuse	Replace - Same Size	Repair	II
150363858	S14511	02/05/2015	18:04	02/05/2015	21:04	1	180	180	Overhead equipment	Overhead Service	Patrol/Test/Inspect	Repair	VI
150364118	303006	02/05/2015	19:14	02/05/2015	20:28	1	74	74	Tree related-tree broken	Overhead Service	Repair		VI
5001335	X23516	02/05/2015	20:26	02/05/2015	22:32	25	3126	125	Overhead equipment	Overhead Primary			IV
150364159	HD5253	02/05/2015	20:30	02/05/2015	20:56	1	26	26	Public	Transformer Fuse	Replace - Same Size		VI
150364364	D61001	02/05/2015	21:20	02/06/2015	3:05	3	1035	344	Underground equipment	Underground Primary	Repair		III
150364365	C60001	02/05/2015	22:05	02/05/2015	22:19	1	14	13	Other	Other			III
150372395	Q36412	02/06/2015	4:48	02/06/2015	6:48	1	120	120	Overhead equipment	Transformer Fuse	Replace - Same Size		I
150372410	U52516	02/06/2015	5:21	02/06/2015	7:46	141	20445	145	Overhead equipment	Disconnect Switch	Patrol/Test/Inspect	Repair	II
150372415	A16002	02/06/2015	5:49	02/06/2015	7:27	1	98	98	Overhead equipment	Connector	Patrol/Test/Inspect	Repair	I
150372457	332005	02/06/2015	7:01	02/06/2015	9:40	1	159	159	Overhead equipment	Overhead Service	Patrol/Test/Inspect	Replace - New Size	VI
5001339	Q64917	02/06/2015	7:16	02/06/2015	10:45	1	208	208	Underground equipment	Underground Service	Repair	Repair	VI
150373129	S61575	02/06/2015	7:50	02/06/2015	9:04	213	15762	74	Overhead equipment				VI
150373155	S63291	02/06/2015	7:50	02/06/2015	8:56	1	66	65	Overhead equipment	Overhead Primary	Repair		VI
150372982	T06202	02/06/2015	7:50	02/06/2015	8:20	1505	45150	29	Overhead equipment				VI
150373084	T06505	02/06/2015	7:50	02/06/2015	8:56	733	48378	65	Overhead equipment	Overhead Primary	Repair		VI
150372836	T06537	02/06/2015	7:50	02/06/2015	8:37	334	15698	46	Overhead equipment	Overhead Primary	Repair		VI
150373069	T06538	02/06/2015	7:50	02/06/2015	8:17	254	6858	26	Overhead equipment	Overhead Primary	Repair		VI
150373100	T06539	02/06/2015	7:50	02/06/2015	8:56	352	23232	65	Overhead equipment	Overhead Primary	Repair		VI
150373075	T06540	02/06/2015	7:50	02/06/2015	8:17	261	7047	26	Overhead equipment	Overhead Primary	Repair		VI
150372813	T09558	02/06/2015	7:53	02/06/2015	9:24	9	819	91	Overhead equipment				VI
150372924	U84566	02/06/2015	8:03	02/06/2015	8:38	1	35	34	Overhead equipment	Overhead Primary	Repair		II
150373005	B00001	02/06/2015	8:23	02/06/2015	9:55	1	92	91	Overhead equipment	Overhead Service	Repair		I
150373040	S61575	02/06/2015	8:25	02/06/2015	9:14	99	4851	49	Overhead equipment				VI
150373207	S61575	02/06/2015	9:09	02/06/2015	9:34	213	5325	24	Overhead equipment	Overhead Primary	Switch/Reset		VI
150373247	S61575	02/06/2015	9:17	02/06/2015	10:15	18	1044	58	Overhead equipment	Overhead Primary	Switch/Reset		VI

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
150373283	S61575	02/06/2015	9:18	02/06/2015	10:15	74	4218	57	Overhead equipment	Overhead Primary	Switch/Reset		VI
150373543	D28123	02/06/2015	10:29	02/06/2015	14:09	1	220	220	Overhead equipment	Overhead Service	Repair		I
150373596	K36151	02/06/2015	10:46	02/06/2015	12:10	1	84	84	Overhead equipment	Transformer Fuse	Replace - Same Size		III
150373733	N70330	02/06/2015	11:28	02/06/2015	11:58	5	150	30	Overhead equipment	Transformer Fuse	Replace - Same Size		I
150373788	B21004	02/06/2015	11:51	02/06/2015	12:34	1	43	42	Overhead equipment	Connector	Repair		I
150373856	J01118	02/06/2015	12:10	02/06/2015	13:00	1	50	49	Overhead equipment	Transformer Fuse	Replace - Same Size	Patrol/Test/Inspect	I
150373959	N50331	02/06/2015	12:20	02/06/2015	13:11	152	7752	50	Overhead equipment	Connector	Replace - Same Size		II
150374445	B21004	02/06/2015	12:21	02/06/2015	16:09	21	4788	228	Underground equipment	Underground Primary			I
150373910	B21004	02/06/2015	12:28	02/06/2015	14:16	80	8640	108	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
150373942	A42005	02/06/2015	12:33	02/06/2015	13:28	70	3850	55	Animal related	Fuse	Repair	Repair	I
150374028	D90004	02/06/2015	13:03	02/06/2015	13:15	1	12	12	Other	Other	Reconnect		III
150374036	S61583	02/06/2015	13:06	02/06/2015	14:02	1	56	56	Overhead equipment				VI
5001367	Y69553	02/06/2015	13:08	02/06/2015	16:40	1	211	211	Intentional				IV
150374356	J01118	02/06/2015	14:45	02/06/2015	20:20	1	335	334	Tree related-tree broken	Overhead Service	Repair	Replace - Same Size	I
150374427	N54214	02/06/2015	15:12	02/06/2015	17:45	1	153	153	Overhead equipment	Overhead Transformer	Replace - Same Size		II
150374476	Y20522	02/06/2015	15:31	02/06/2015	17:15	1	104	104	Overhead equipment	Overhead Service	Repair	Repair	IV
150374514	B21004	02/06/2015	15:55	02/06/2015	16:27	1	32	31	Underground equipment	Underground Primary	Repair	Repair	I
150374577	K58213	02/06/2015	16:28	02/06/2015	17:38	13	910	69	Overhead equipment	Fuse	Replace - Same Size		VI
150374605	H00163	02/06/2015	16:52	02/06/2015	19:45	12	2076	172	Overhead equipment	Overhead Transformer			III
150374626	X64503	02/06/2015	17:05	02/06/2015	20:15	1	190	190	Overhead equipment	Transformer Fuse	Repair	Repair	IV
150374632	Q32170	02/06/2015	17:12	02/06/2015	19:39	1	147	146	Overhead equipment	Overhead Service	Replace - New Size	Repair	I
150374781	N12334	02/06/2015	17:59	02/06/2015	20:12	803	106799	133	Substation equipment	Lightning Arrestor			V
150374789	R05114	02/06/2015	18:27	02/06/2015	22:20	7	1631	232	Overhead equipment	Overhead Transformer	Repair	Replace - Same Size	I
150375201	A91003	02/06/2015	20:55	02/07/2015	0:01	1	186	185	Underground equipment	Underground Service	Repair	Repair	I
150375474	B53001	02/06/2015	21:33	02/07/2015	1:41	16	3968	248	Overhead equipment	Overhead Primary	Repair		III
150375470	B44001	02/06/2015	22:33	02/07/2015	0:41	1	128	127	Animal related	Disconnect Switch	Repair		I
150380030	346003	02/07/2015	3:03	02/07/2015	6:35	122	25864	211	Public	Overhead Primary		Repair	VI
150380022	346003	02/07/2015	3:04	02/07/2015	4:21	255	19635	76	Public	Overhead Primary		Repair	VI
150380033	D37003	02/07/2015	4:41	02/07/2015	8:14	6	1278	212	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - Urgent	I
5001371	Q82907	02/07/2015	7:38	02/07/2015	8:45	1	66	66	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	VI
5001373	Q82907	02/07/2015	7:42	02/07/2015	8:45	1	62	62	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	VI
150380063	N44215	02/07/2015	7:53	02/07/2015	10:00	1	127	126	Overhead equipment	Connector			III
150380077	L81141	02/07/2015	7:59	02/07/2015	8:54	44	2420	55	Overhead equipment	Fuse			IV
150380086	374069	02/07/2015	8:18	02/07/2015	9:27	1	69	69	Overhead equipment	Fuse	Patrol/Test/Inspect		VI
150380096	J34357	02/07/2015	8:25	02/07/2015	9:48	14	1162	82	Animal related	Underground Primary	Switch/Reset	Repair	V
150380092	S47576	02/07/2015	8:30	02/07/2015	9:10	1	40	40	Animal related	Transformer Fuse			VI
150380171	Z29579	02/07/2015	9:05	02/07/2015	10:32	1	87	87	Overhead equipment	Overhead Service	Repair		IV
150380180	B53001	02/07/2015	9:20	02/07/2015	9:35	2	30	14	Overhead equipment	Connector	Repair		III
150380204	J99128	02/07/2015	9:49	02/07/2015	10:12	1	23	23	Animal related	Transformer Fuse	Replace - Same Size		VI
150380205	Q01280	02/07/2015	9:50	02/07/2015	11:54	1	124	124	Underground equipment	Underground Service			III
150380231	K28183	02/07/2015	10:37	02/07/2015	12:13	1	96	95	Animal related	Transformer Fuse	Replace - Same Size		III
150380234	U31542	02/07/2015	10:40	02/07/2015	11:28	1	48	47	Overhead equipment	Connector	Repair		II
150380255	M41182	02/07/2015	11:20	02/07/2015	16:00	1	280	280	Overhead equipment	Overhead Transformer	Repair	Replace - Same Size	I
150380263	T06505	02/07/2015	11:35	02/07/2015	12:45	1	70	69	Overhead equipment	Disconnect Switch	Repair	Repair	VI
150380271	U01514	02/07/2015	11:53	02/07/2015	13:25	1	92	92	Overhead equipment	Overhead Primary	Repair	Repair	II
150380325	D81001	02/07/2015	13:29	02/07/2015	14:30	47	2867	60	Unknown	Fuse	Replace - Same Size		I
150380343	P49180	02/07/2015	13:49	02/07/2015	15:15	1	86	85	Overhead equipment	Jumper	Repair		I
150380347	326169	02/07/2015	13:55	02/07/2015	14:54	1	59	59	Overhead equipment	Overhead Transformer	Switch/Reset		V
150380370	S55566	02/07/2015	14:46	02/07/2015	17:19	1	153	153	Tree related-tree broken	Overhead Service	Repair	Replace - Same Size	VI
150380435	Q71846	02/07/2015	15:50	02/07/2015	17:12	76	6232	82	Overhead equipment	Jumper			V
150380407	K71812	02/07/2015	15:56	02/07/2015	17:10	8	592	74	Animal related	Fuse	Patrol/Test/Inspect	Replace - Same Size	IV
150380432	K65221	02/07/2015	16:20	02/07/2015	20:32	1	252	252	Overhead equipment	Overhead Transformer			III
150380454	D31016	02/07/2015	16:37	02/07/2015	19:30	6	1038	172	Underground equipment	Underground Transformer	Replace - Same Size		III
150380520	Y50004	02/07/2015	16:46	02/07/2015	22:40	7	2478	354	Public				IV
150380468	330129	02/07/2015	17:27	02/07/2015	18:11	1	44	44	Overhead equipment	Fuse	Replace - New Size		V
150380482	S15559	02/07/2015	17:57	02/07/2015	20:42	1	165	165	Overhead equipment	Overhead Primary	Repair		VI

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
150380492	S53542	02/07/2015	18:27	02/07/2015	20:05	1	98	97	Overhead equipment	Overhead Service	Repair	Repair	VI
150380517	P69173	02/07/2015	19:30	02/07/2015	20:52	1	82	81	Overhead equipment	Fuse	Replace - Same Size		III
150390012	Q36412	02/08/2015	4:11	02/08/2015	10:26	1	375	374	Overhead equipment	Overhead Transformer	Replace - Same Size	Replace - Same Size	I
150390031	J79304	02/08/2015	7:58	02/08/2015	9:33	1	95	95	Unknown	Fuse	Replace - Same Size		I
150390048	349001	02/08/2015	8:58	02/08/2015	12:45	1	227	226	Overhead equipment	Disconnect Switch	Patrol/Test/Inspect	Replace - Same Size	VI
150390072	Y07576	02/08/2015	9:49	02/08/2015	13:05	30	5880	195	Animal related	Overhead Primary	Repair		IV
150390070	N95824	02/08/2015	9:55	02/08/2015	13:20	1	205	204	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	V
5001381	R39934	02/08/2015	10:10	02/08/2015	11:44	1	93	93	Overhead equipment	Fuse	Replace - Same Size		VI
150390076	V76002	02/08/2015	10:13	02/08/2015	12:16	1	123	123	Overhead equipment	Disconnect Switch	Replace - Same Size		II
150390075	C50001	02/08/2015	10:13	02/08/2015	13:00	1	167	166	Underground equipment	Underground Service			III
150390091	K48380	02/08/2015	10:58	02/08/2015	14:00	1	182	182	Overhead equipment	Disconnect Switch	Switch/Reset	Replace - Same Size	V
150390094	S24596	02/08/2015	11:08	02/08/2015	11:42	1	34	34	Overhead equipment	Overhead Service	Patrol/Test/Inspect	Repair	VI
150390096	K76541	02/08/2015	11:19	02/08/2015	12:40	1	81	81	Overhead equipment	Overhead Service	Patrol/Test/Inspect	Repair	IV
150390098	G30001	02/08/2015	11:27	02/08/2015	11:37	1	10	10	Other	Other			III
150390106	U37001	02/08/2015	11:32	02/08/2015	13:45	1	133	132	Public	Pole			II
150390111	S88503	02/08/2015	11:49	02/08/2015	12:49	1	60	60	Overhead equipment	Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
150390117	A32003	02/08/2015	12:06	02/08/2015	12:51	1	45	45	Overhead equipment	Connector	Repair		I
150390335	A48002	02/08/2015	13:08	02/08/2015	15:09	1	121	120	Tree related-tree broken	Overhead Service	Replace - Same Size	Replace - Same Size	I
150390468	S93553	02/08/2015	13:19	02/08/2015	19:25	7	2562	366	Underground equipment	Underground Connector			VI
150390344	S93553	02/08/2015	13:19	02/08/2015	17:00	43	9503	221	Underground equipment	Underground Connector		Repair	VI
150390460	C70001	02/08/2015	13:53	02/08/2015	21:06	1	433	432	Underground equipment	Underground Primary	Repair		III
150390363	C70001	02/08/2015	13:53	02/08/2015	17:40	6	1362	226	Underground equipment	Underground Primary	Switch/Reset		III
150390378	U86001	02/08/2015	14:41	02/08/2015	15:23	1	42	42	Overhead equipment	Overhead Service	Repair	Repair	II
150390390	T09530	02/08/2015	15:14	02/08/2015	17:25	1	131	130	Overhead equipment	Overhead Service	Repair	Repair	VI
150390396	H22349	02/08/2015	15:29	02/08/2015	16:19	8	400	49	Animal related	Transformer Fuse	Replace - Same Size	Replace - Same Size	V
150390435	M09143	02/08/2015	17:05	02/08/2015	18:06	1	61	60	Overhead equipment	Connector	Replace - Same Size		VI
150390456	307003	02/08/2015	17:48	02/08/2015	18:40	13	676	52	Public	Fuse	Repair		VI
150390463	G30001	02/08/2015	18:05	02/08/2015	18:27	5	110	22	Other	Other			III
150390513	N67309	02/08/2015	19:34	02/08/2015	21:25	64	7104	110	Tree related-tree contact	Overhead Primary	Trim		I
150390534	L17104	02/08/2015	21:00	02/09/2015	1:18	11	2838	258	Underground equipment	Underground Primary	Switch/Reset	Repair	III
150390536	X09557	02/08/2015	21:07	02/08/2015	21:55	1	48	47	Animal related	Fuse	Replace - Same Size		IV
150400077	A45003	02/09/2015	0:10	02/09/2015	4:17	549	135603	246	Substation equipment	Disconnect Switch	Repair	Repair	I
150400133	J61117	02/09/2015	1:56	02/09/2015	5:56	7	1680	239	Overhead equipment	Overhead Primary	Repair	Repair	III
150402426	U12001	02/09/2015	3:42	02/09/2015	6:28	12	1992	165	Overhead equipment	Disconnect Switch	Repair		II
150402430	A45003	02/09/2015	3:57	02/09/2015	4:30	1	33	33	Unknown	Other	Patrol/Test/Inspect		I
150402652	R84148	02/09/2015	8:03	02/09/2015	9:11	1	68	68	Overhead equipment	Jumper	Repair		I
150402760	K74162	02/09/2015	8:21	02/09/2015	11:48	1	207	207	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	IV
150402841	R33126	02/09/2015	8:45	02/09/2015	10:02	1	77	76	Animal related	Fuse	Replace - Same Size	Patrol/Test/Inspect	I
150402934	U30001	02/09/2015	9:13	02/09/2015	11:21	1	128	127	Overhead equipment	Connector	Repair		II
150402974	P09307	02/09/2015	9:19	02/09/2015	11:46	1	147	146	Overhead equipment	Overhead Primary	Replace - Same Size		V
150403066	P05826	02/09/2015	9:40	02/09/2015	15:40	1	360	360	Animal related	Underground Primary		Repair	V
150403203	X31730	02/09/2015	9:53	02/09/2015	10:05	5754	69048	11	Overhead equipment	Overhead Primary	Repair		IV
150403153	A45003	02/09/2015	9:56	02/09/2015	12:20	1	144	143	Underground equipment	Underground Service	Repair	Repair	I
150403474	C70001	02/09/2015	10:32	02/09/2015	11:28	1	56	56	Overhead equipment	Connector	Repair		III
150403539	R48167	02/09/2015	10:47	02/09/2015	12:18	1	91	90	Overhead equipment	Overhead Service	Replace - Same Size		IV
150403741	327157	02/09/2015	11:45	02/09/2015	12:20	1	35	34	Overhead equipment	Fuse	Replace - Same Size		V
150403804	K31120	02/09/2015	11:57	02/09/2015	12:42	45	2025	45	Unknown	Recloser	Patrol/Test/Inspect		I
150403887	M81405	02/09/2015	12:31	02/09/2015	14:40	1	129	129	Underground equipment	Underground Service			V
150404127	L73160	02/09/2015	13:39	02/09/2015	16:15	1	156	156	Overhead equipment	Connector	Replace - Same Size		IV
150404195	K89143	02/09/2015	13:57	02/09/2015	15:12	1	75	74	Overhead equipment	Overhead Service	Replace - Same Size		III
150404310	L24124	02/09/2015	14:34	02/09/2015	17:18	1	164	164	Overhead equipment	Overhead Service	Replace - Same Size		III
150404899	B84002	02/09/2015	19:20	02/09/2015	21:02	48	4896	101	Underground equipment				I
150405437	U10525	02/09/2015	20:27	02/09/2015	21:50	1	83	82	Overhead equipment	Transformer Fuse	Replace - Same Size	Patrol/Test/Inspect	II
150405438	P26283	02/09/2015	20:33	02/09/2015	22:30	1	117	117	Overhead equipment	Overhead Service	Repair		I
150405474	B81003	02/09/2015	21:47	02/09/2015	23:38	1	111	111	Overhead equipment				I
150405497	L93134	02/09/2015	23:47	02/10/2015	2:08	16	2256	140	Underground equipment	Underground Primary	Switch/Reset	Repair	VI

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
150412236		02/10/2015	5:46	02/10/2015	14:32	11	5786	526	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
150412333	L90359	02/10/2015	7:39	02/10/2015	9:39	1	120	120	Overhead equipment	Fuse	Replace - New Size		V
150412447	Q21293	02/10/2015	8:25	02/10/2015	10:40	1	135	135	Underground equipment	Underground Service	Disconnect	Replace - Same Size	VI
150412496	S61581	02/10/2015	8:41	02/10/2015	9:09	1	28	27	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	VI
150412504	P69175	02/10/2015	8:43	02/10/2015	10:30	1	107	107	Underground equipment	Underground Service		Repair	III
150412553	S88502	02/10/2015	8:52	02/10/2015	9:31	1	39	39	Animal related	Fuse	Replace - Same Size		VI
150412579	R66472	02/10/2015	8:58	02/10/2015	9:34	86	3096	35	Animal related	Fuse	Replace - Same Size		IV
150412620	N50334	02/10/2015	9:11	02/10/2015	12:11	1	180	180	Underground equipment	Underground Service	Patrol/Test/Inspect		II
150412795		02/10/2015	10:10	02/10/2015	13:47	1	217	217	Underground equipment	Underground Secondary	Repair	Repair	II
5001443	Z17503	02/10/2015	11:31	02/10/2015	13:45	1	133	133	Intentional				IV
150413119	L82188	02/10/2015	11:34	02/10/2015	15:00	1	206	206	Underground equipment	Underground Service		Repair	IV
150413166	R49263	02/10/2015	11:41	02/10/2015	14:34	358	61934	172	Overhead equipment	Overhead Primary	Repair	Repair	VI
150413317	J86108	02/10/2015	12:37	02/10/2015	13:02	1	25	25	Overhead equipment	Transformer Fuse	Replace - Same Size		VI
150413331	315106	02/10/2015	12:42	02/10/2015	14:30	1	108	107	Public	Overhead Service	Cut in Clear	Replace - New Size	V
150413513	N94180	02/10/2015	13:37	02/10/2015	14:39	1	62	62	Overhead equipment	Connector	Repair		I
150413693	U02597	02/10/2015	14:27	02/10/2015	15:15	1	48	47	Overhead equipment	Transformer Fuse	Replace - Same Size		II
150413758	HB6283	02/10/2015	14:47	02/10/2015	16:00	1	73	72	Animal related	Animal Guard	Install		VI
150413769	J06167	02/10/2015	14:50	02/10/2015	16:18	1	88	88	Overhead equipment	Transformer Fuse	Replace - Same Size	Patrol/Test/Inspect	I
150413773	N50332	02/10/2015	14:51	02/10/2015	16:40	1	109	108	Overhead equipment	Connector	Repair		II
150413886	Y12768	02/10/2015	14:55	02/10/2015	15:57	2033	126046	61	Substation equipment	Substation Misc.	Replace - Same Size		IV
150413948	D69006	02/10/2015	15:16	02/10/2015	16:33	1	77	76	Overhead equipment	Connector	Replace - New Size		I
150413972	Y12559	02/10/2015	15:26	02/10/2015	15:57	1	31	30	Overhead equipment	High Line Switch	Switch/Reset		IV
150413990	J15303	02/10/2015	15:32	02/10/2015	16:23	1	51	50	Overhead equipment	Overhead Primary	Replace - Same Size	Replace - Same Size	I
150414032	M09143	02/10/2015	15:52	02/10/2015	17:32	1	100	100	Animal related	Fuse	Replace - Same Size		VI
150414051	J06167	02/10/2015	16:02	02/10/2015	16:40	1	38	37	Underground equipment	Underground Service	Repair		I
150414061	R49263	02/10/2015	16:07	02/10/2015	16:42	1	35	34	Animal related	Transformer Fuse	Replace - Same Size		VI
150414416	K28183	02/10/2015	18:37	02/10/2015	19:06	1	29	29	Animal related	Other			III
150414430	Q93522	02/10/2015	18:55	02/10/2015	21:39	1	164	164	Overhead equipment	Fuse	Replace - Same Size		I
150420093	B25001	02/11/2015	0:21	02/11/2015	1:52	1	91	91	Overhead equipment				I
150421508	N70408	02/11/2015	3:36	02/11/2015	8:06	1398	377460	270	Animal related	Other	Switch/Reset		I
150421507		02/11/2015	3:38	02/11/2015	8:06	793	212524	268	Animal related	Other	Switch/Reset		I
150421529	U68581	02/11/2015	5:05	02/11/2015	6:48	1	103	103	Unknown	Fuse	Replace - Same Size		II
150421682	R61241	02/11/2015	7:47	02/11/2015	13:04	1	317	316	Underground equipment	Underground Service	Patrol/Test/Inspect	Repair	IV
150421877		02/11/2015	8:48	02/11/2015	8:57	1	9	8	Overhead equipment				I
150421898	Y11556	02/11/2015	8:52	02/11/2015	10:09	1	77	77	Overhead equipment	Overhead Service	Repair		IV
150422022		02/11/2015	9:30	02/11/2015	12:06	1	156	155	Overhead equipment	Other		Reconnect	I
150422064	J79306	02/11/2015	9:39	02/11/2015	10:19	1	40	39	Overhead equipment	Overhead Secondary	Repair		I
150422414	J15302	02/11/2015	10:39	02/11/2015	11:33	6	324	53	Overhead equipment	Fuse	Replace - Same Size		I
150422294	327155	02/11/2015	10:40	02/11/2015	13:05	1	145	145	Public	Overhead Primary	Cut in Clear	Repair	V
150422473	L79159	02/11/2015	11:09	02/11/2015	11:49	21	840	39	Jurisdictional	Fuse			IV
150422456	329148	02/11/2015	11:14	02/11/2015	12:00	1	46	46	Overhead equipment	Overhead Transformer	Repair		V
150422567	J79305	02/11/2015	11:43	02/11/2015	12:40	1	57	57	Overhead equipment	Fuse	Replace - New Size		I
150422595	P62112	02/11/2015	11:52	02/11/2015	12:06	1	14	14	Intentional				VI
150423262	HA5431	02/11/2015	15:28	02/11/2015	16:40	1	72	72	Jurisdictional				V
150423402	B35002	02/11/2015	16:49	02/11/2015	18:02	1	73	72	Overhead equipment				I
150423495	N78244	02/11/2015	17:30	02/11/2015	18:52	1	82	82	Overhead equipment	Overhead Service	Repair		I
5001507	Y96564	02/11/2015	18:02	02/11/2015	20:00	1	117	117	Intentional				IV
150423868	J63172	02/11/2015	19:48	02/11/2015	21:42	148	16872	114	Overhead equipment	Overhead Primary			III
150423877	J12166	02/11/2015	20:07	02/11/2015	21:15	9	612	68	Underground equipment	Underground Primary		Repair	III
150423879	K09864	02/11/2015	20:13	02/11/2015	21:15	1	62	61	Overhead equipment	Fuse	Replace - Same Size	Repair	V
150423892	B81003	02/11/2015	20:42	02/12/2015	3:49	2	854	426	Underground equipment	Underground Secondary	Disconnect	Repair	I
150423906	J12166	02/11/2015	21:36	02/11/2015	22:20	9	396	43	Overhead equipment	Fuse	Replace - Same Size		III
150423914	V92555	02/11/2015	22:17	02/11/2015	23:25	40	2720	68	Overhead equipment	Jumper	Repair	Patrol/Test/Inspect	II
150423919	R68900	02/11/2015	22:34	02/12/2015	1:08	1	154	153	Underground equipment	Underground Service	Patrol/Test/Inspect		I
5001511	X57566	02/12/2015	0:02	02/12/2015	0:39	12	437	36	Public	Pole			IV
5001513	X57566	02/12/2015	0:39	02/12/2015	7:06	7	2708	386	Public	Pole	Replace - New Size	Replace - New Size	IV

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
150430095	L11241	02/12/2015	1:06	02/12/2015	2:20	1	74	74	Overhead equipment	Overhead Secondary	Repair		III
150430108	V22555	02/12/2015	1:59	02/12/2015	3:20	1	81	81	Overhead equipment	Jumper	Replace - New Size		II
150430112	K76542	02/12/2015	2:03	02/12/2015	5:45	16	3552	222	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	IV
150432628	H10843	02/12/2015	4:12	02/12/2015	7:05	1	173	172	Tree related-tree broken	Overhead Service	Repair		V
150432654	V03529	02/12/2015	4:14	02/12/2015	6:30	100	13600	136	Overhead equipment	Overhead Primary			II
150432639	303005	02/12/2015	4:25	02/12/2015	6:54	2	298	148	Tree related-tree broken	Tree	Trim		VI
150432643	M18131	02/12/2015	4:29	02/12/2015	6:00	1	91	91	Tree related-tree contact	Overhead Service	Remove	Repair	III
150432655	P18104	02/12/2015	4:35	02/12/2015	6:41	1	126	126	Overhead equipment	Jumper	Repair		IV
150432667	M81403	02/12/2015	5:01	02/12/2015	6:40	3	297	99	Overhead equipment	Disconnect Switch	Patrol/Test/Inspect		V
150432741	P42229	02/12/2015	5:13	02/12/2015	7:27	48	6432	133	Overhead equipment	Jumper	Repair	Repair	VI
150432727	J89112	02/12/2015	6:14	02/12/2015	7:00	1	46	45	Overhead equipment	Overhead Secondary			VI
150432757	B93003	02/12/2015	6:46	02/12/2015	7:52	2	132	65	Overhead equipment	Jumper	Patrol/Test/Inspect	Repair	I
150432779	K15205	02/12/2015	7:05	02/12/2015	7:42	1	37	36	Overhead equipment	Jumper			VI
150432813	V34001	02/12/2015	7:19	02/12/2015	8:33	1	74	74	Tree related-tree broken	Overhead Service	Repair		II
150432881	M81405	02/12/2015	7:40	02/12/2015	12:27	109	31283	287	Public	Fuse	Replace - Same Size		V
150432875	Q74149	02/12/2015	7:46	02/12/2015	9:00	1	74	74	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
150432956	Y91500	02/12/2015	8:11	02/12/2015	9:15	1	64	63	Overhead equipment	Transformer Fuse	Repair	Replace - Same Size	IV
150433014	M40117	02/12/2015	8:30	02/12/2015	9:10	1	40	40	Overhead equipment	Overhead Secondary	Repair		I
150433028	Q01282	02/12/2015	8:32	02/12/2015	9:15	1	43	42	Overhead equipment	Jumper	Repair	Repair	III
150433032	Q91141	02/12/2015	8:34	02/12/2015	10:43	1	129	129	Overhead equipment	Overhead Service			I
150433053	P17107	02/12/2015	8:46	02/12/2015	10:27	1	101	101	Overhead equipment	Connector	Repair		IV
150433093	P60161	02/12/2015	9:02	02/12/2015	12:08	1	186	186	Overhead equipment	Overhead Transformer	Repair	Replace - Same Size	VI
150433137	R99180	02/12/2015	9:17	02/12/2015	11:24	1	127	126	Overhead equipment	Overhead Service	Patrol/Test/Inspect	Repair	IV
150433188	B73003	02/12/2015	9:29	02/12/2015	11:55	1	146	146	Overhead equipment	Overhead Service	Repair		I
150433192	R48167	02/12/2015	9:31	02/12/2015	10:35	1	64	63	Overhead equipment	Jumper			IV
150433224	R60552	02/12/2015	9:41	02/12/2015	11:20	1	99	98	Overhead equipment	Jumper	Replace - New Size		IV
150433412	U44529	02/12/2015	10:50	02/12/2015	11:30	1	40	39	Overhead equipment	Connector	Repair		II
150433519	P69173	02/12/2015	11:20	02/12/2015	11:46	19	494	26	Overhead equipment	Overhead Primary	Repair		III
5001543	R34920	02/12/2015	13:50	02/12/2015	18:28	1	277	277	Overhead equipment	Pole	Replace - New Size		VI
150433974	J12166	02/12/2015	14:28	02/12/2015	14:55	1	27	27	Underground equipment	Overhead Service	Patrol/Test/Inspect	Repair	III
150434167	K39153	02/12/2015	15:54	02/12/2015	18:40	1	166	166	Animal related	Fuse	Replace - Same Size		III
150434207	L14231	02/12/2015	16:22	02/12/2015	17:28	1	66	66	Overhead equipment	Overhead Service	Repair		III
150434245	U04571	02/12/2015	16:53	02/12/2015	17:55	1	62	62	Overhead equipment	Overhead Service	Repair		II
5001549	L59922	02/12/2015	19:08	02/12/2015	22:25	1	196	196	Overhead equipment	Overhead Primary	Raise		VI
150435942	S13550	02/12/2015	21:17	02/12/2015	22:00	1	43	42	Other	Pole			VI
150435948	C37002	02/12/2015	21:33	02/12/2015	23:13	3	300	100	Overhead equipment	Overhead Primary	Repair		III
150435963	X38792	02/12/2015	21:58	02/12/2015	23:04	35	2310	65	Overhead equipment	Substation Breaker	Switch/Reset		IV
150436020	X38792	02/12/2015	21:58	02/12/2015	22:55	1685	96045	56	Overhead equipment	Substation Breaker	Switch/Reset		IV
150440056	X42502	02/12/2015	23:01	02/13/2015	1:10	3	387	129	Overhead equipment	Jumper	Repair		IV
150440078	M19222	02/13/2015	0:43	02/13/2015	2:49	1	126	125	Underground equipment	Transformer Fuse	Replace - Same Size		VI
150440080	U37579	02/13/2015	0:48	02/13/2015	2:05	1	77	76	Overhead equipment	Disconnect Switch	Replace - Same Size	Patrol/Test/Inspect	II
150442872	J87150	02/13/2015	7:49	02/13/2015	8:22	1	33	33	Public				VI
150443018	B38002	02/13/2015	8:48	02/13/2015	9:45	1	57	56	Overhead equipment	Connector	Replace - New Size		I
150443114	M09175	02/13/2015	9:20	02/13/2015	9:58	1	38	37	Overhead equipment				VI
150443174	S22595	02/13/2015	9:38	02/13/2015	10:48	3	210	69	Animal related	Fuse	Replace - Same Size		VI
150443434	T22507	02/13/2015	10:48	02/13/2015	11:13	3	75	25	Animal related	Transformer Fuse	Replace - Same Size		VI
150443656	Q06142	02/13/2015	11:56	02/13/2015	13:47	1	111	111	Overhead equipment	Overhead Transformer	Replace - Same Size		IV
150443711	S83533	02/13/2015	12:26	02/13/2015	13:37	2	142	71	Overhead equipment	Overhead Primary			VI
150443874	Q16867	02/13/2015	13:19	02/13/2015	14:50	51	4641	91	Public	Overhead Secondary	Repair		V
150444186	D92002	02/13/2015	15:18	02/13/2015	19:17	1	239	239	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
150444192	R73841	02/13/2015	15:23	02/13/2015	17:15	1	112	111	Overhead equipment	Overhead Service	Replace - New Size		V
150444211	R01152	02/13/2015	15:29	02/13/2015	16:04	1	35	34	Unknown	Underground Service			III
150444312	K65221	02/13/2015	16:39	02/13/2015	18:26	2	214	107	Overhead equipment	Overhead Transformer			III
150444319	HB6283	02/13/2015	16:49	02/14/2015	0:30	1	461	461	Underground equipment	Underground Service		Replace - Same Size	VI
150444816	S25552	02/13/2015	20:06	02/13/2015	22:11	1	125	124	Overhead equipment	Overhead Service	Patrol/Test/Inspect	Repair	VI
150444839	Q71846	02/13/2015	20:53	02/13/2015	22:43	1	110	110	Animal related	Fuse	Replace - Same Size		V

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
150445208	L24122	02/13/2015	22:17	02/13/2015	23:02	1	45	45	Overhead equipment	Fuse	Replace - Same Size		III
150445282	B84002	02/13/2015	23:16	02/13/2015	23:55	2103	82017	39	Substation equipment	Substation Misc.	Replace - Same Size		I
150450035	H01192	02/14/2015	3:40	02/14/2015	5:17	19	1843	96	Overhead equipment	Overhead Primary	Repair		III
150450049	B68003	02/14/2015	6:36	02/14/2015	7:40	1	64	63	Tree related-tree contact	Fuse	Replace - Same Size		III
150450055	K57212	02/14/2015	6:57	02/14/2015	8:40	1	103	103	Animal related	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
150450074	K65220	02/14/2015	7:34	02/14/2015	8:59	1	85	84	Overhead equipment	Overhead Primary			III
150450110	P47120	02/14/2015	7:38	02/14/2015	10:23	8	1320	164	Overhead equipment	Jumper			I
150450076	P47120	02/14/2015	7:39	02/14/2015	10:19	4	640	159	Overhead equipment	Jumper			I
150450087	D39001	02/14/2015	7:56	02/14/2015	9:10	1	74	74	Overhead equipment	Overhead Primary	Tie/Tighten	Tie/Tighten	I
150450091	X19561	02/14/2015	8:04	02/14/2015	9:54	1	110	110	Overhead equipment	Jumper	Repair		IV
150450125	P47120	02/14/2015	8:31	02/14/2015	12:25	524	122616	233	Overhead equipment	Crossarm		Repair	I
150450126	X83541	02/14/2015	8:39	02/14/2015	10:55	1	136	135	Overhead equipment	Transformer Fuse	Repair	Repair	IV
150450149	A48005	02/14/2015	8:58	02/14/2015	13:47	32	9248	288	Overhead equipment	Fuse	Patrol/Test/Inspect	Repair	I
150450152	D32212	02/14/2015	9:02	02/14/2015	9:47	1	45	45	Overhead equipment	Overhead Primary	Replace - Same Size	Replace - Same Size	I
150450156	Z05001	02/14/2015	9:06	02/14/2015	10:50	1	104	104	Overhead equipment	Overhead Service	Repair		IV
150450170	K73361	02/14/2015	9:07	02/14/2015	11:43	73	11388	155	Overhead equipment	Overhead Primary		Repair	IV
150450163	U31003	02/14/2015	9:10	02/14/2015	10:19	1	69	68	Overhead equipment	Overhead Service	Repair	Repair	II
150450178	J79306	02/14/2015	9:20	02/14/2015	9:51	1	31	30	Overhead equipment	Overhead Secondary	Repair		I
150450177	U37003	02/14/2015	9:20	02/14/2015	10:25	8	520	65	Tree related-tree broken	Tree	Trim	Patrol/Test/Inspect	II
150450183	L68115	02/14/2015	9:24	02/14/2015	10:13	1	49	48	Tree related-tree broken	Overhead Service			IV
150450187	G10002	02/14/2015	9:26	02/14/2015	15:31	1	365	364	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
150450188	K65221	02/14/2015	9:26	02/14/2015	10:13	1	47	46	Overhead equipment	Overhead Transformer			III
150450191	B80002	02/14/2015	9:31	02/14/2015	12:30	1	179	179	Overhead equipment	Connector	Repair		I
150450420	Y52787	02/14/2015	9:34	02/14/2015	10:39	603	39195	65	Jurisdictional				IV
150450278	X85724	02/14/2015	9:38	02/14/2015	11:10	337	31004	92	Public	Overhead Primary	Repair		IV
150450232	A85002	02/14/2015	9:45	02/14/2015	14:06	1	261	261	Overhead equipment	Overhead Primary	Patrol/Test/Inspect	Repair	I
150450246	N60172	02/14/2015	9:49	02/14/2015	10:32	1	43	42	Other	Other			I
150450248	J75272	02/14/2015	9:49	02/14/2015	14:15	1	266	265	Overhead equipment	Overhead Primary		Repair	IV
150450268	Q37370	02/14/2015	9:58	02/14/2015	12:55	178	31506	177	Overhead equipment				I
150450459	L73154	02/14/2015	10:01	02/14/2015	11:35	45	4230	94	Overhead equipment	Overhead Service			IV
150450269	Y11556	02/14/2015	10:04	02/14/2015	11:15	1	71	71	Tree related-tree broken	Overhead Service	Repair	Repair	IV
150450279	P12290	02/14/2015	10:12	02/14/2015	12:22	1	130	129	Overhead equipment	Connector	Replace - Same Size	Repair	V
150450287	A85001	02/14/2015	10:14	02/14/2015	13:25	1	191	191	Overhead equipment	Connector	Repair		I
150450291	A80001	02/14/2015	10:16	02/14/2015	12:15	1	119	119	Overhead equipment	Connector	Replace - Same Size	Replace - Same Size	I
150450402	V21500	02/14/2015	10:22	02/14/2015	12:23	52	6292	121	Tree related-tree broken	Fuse	Replace - Same Size		II
150450417	J12166	02/14/2015	10:26	02/14/2015	11:25	29	1711	59	Unknown	Fuse	Replace - Same Size		III
150450405		02/14/2015	10:27	02/14/2015	12:26	1	119	119	Tree related-tree broken	Fuse	Replace - Same Size		II
150450428	J50185	02/14/2015	10:44	02/14/2015	11:07	30	690	22	Overhead equipment	Fuse			III
150450536	K27150	02/14/2015	10:46	02/14/2015	13:51	2	370	184	Tree related-tree broken	Overhead Primary	Patrol/Test/Inspect	Repair	VI
150450431	K27150	02/14/2015	10:46	02/14/2015	12:10	19	1596	84	Tree related-tree broken	Overhead Primary	Patrol/Test/Inspect	Repair	VI
150450581	Q74150	02/14/2015	10:56	02/14/2015	16:10	2	628	313	Overhead equipment				IV
150450474	Q74150	02/14/2015	10:56	02/14/2015	13:10	27	3618	133	Overhead equipment	Pole			IV
150450437	B68001	02/14/2015	10:56	02/14/2015	12:09	1	73	72	Overhead equipment	Other	Patrol/Test/Inspect	Patrol/Test/Inspect	III
150450440	J12166	02/14/2015	10:58	02/14/2015	11:20	1	22	21	Unknown	Fuse	Replace - Same Size		III
150450477	P47123	02/14/2015	11:03	02/14/2015	14:37	72	15408	213	Overhead equipment	Crossarm	Repair	Replace - Same Size	I
150450449	X82004	02/14/2015	11:04	02/14/2015	11:48	1	44	44	Overhead equipment	Overhead Secondary	Repair	Repair	IV
150450455	K28183	02/14/2015	11:09	02/14/2015	13:49	1	160	159	Overhead equipment	Overhead Service	Repair		III
150450484	P85141	02/14/2015	11:29	02/14/2015	12:06	13	481	36	Overhead equipment	Overhead Transformer			III
150450498	L11241	02/14/2015	11:40	02/14/2015	13:24	1	104	104	Tree related-tree contact	Overhead Service	Replace - New Size		III
150450503	K76547	02/14/2015	11:45	02/14/2015	13:30	77	8085	104	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
150450625	D32211	02/14/2015	11:47	02/14/2015	16:01	10	2540	254	Overhead equipment	Overhead Primary	Replace - Same Size	Repair	I
150450516	D66002	02/14/2015	11:59	02/14/2015	13:11	1	72	72	Overhead equipment	Jumper			IV
150450531	342002	02/14/2015	12:01	02/14/2015	14:00	1	119	119	Tree related-tree broken	Overhead Primary	Cut in Clear		VI
150450589	342002	02/14/2015	12:01	02/14/2015	13:17	11	836	75	Tree related-tree contact	Tree			VI
150450526	M78323	02/14/2015	12:04	02/14/2015	13:15	43	3053	71	Overhead equipment	Fuse	Replace - Same Size	Repair	V
150450537	R33126	02/14/2015	12:14	02/14/2015	13:49	1	95	94	Overhead equipment	Jumper	Repair	Patrol/Test/Inspect	I

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
150450551	P47120	02/14/2015	12:28	02/14/2015	13:09	1	41	41	Overhead equipment	Overhead Service			I
150450553	Y55003	02/14/2015	12:29	02/14/2015	13:00	1	31	30	Overhead equipment	Overhead Service	Repair	Repair	IV
150450563	J87150	02/14/2015	12:48	02/14/2015	14:10	21	1722	82	Overhead equipment	Pole		Replace - Same Size	VI
150450665	J87150	02/14/2015	12:49	02/14/2015	14:10	12	972	81	Overhead equipment	Pole	Replace - Same Size		VI
150450657	J87150	02/14/2015	12:49	02/14/2015	20:48	14	6706	479	Overhead equipment	Pole	Replace - Same Size		VI
150450566	N70332	02/14/2015	12:53	02/14/2015	14:12	1	79	78	Overhead equipment	Jumper	Repair		I
150450567	F22001	02/14/2015	12:54	02/14/2015	16:55	1	241	240	Overhead equipment	Jumper	Patrol/Test/Inspect	Repair	IV
5001583	X60597	02/14/2015	12:59	02/14/2015	15:00	1	120	120	Overhead equipment	Jumper	Repair		IV
150450578	342004	02/14/2015	13:07	02/14/2015	14:59	1	112	111	Overhead equipment	Overhead Secondary	Repair		VI
150450592	J15303	02/14/2015	13:18	02/14/2015	14:55	1	97	97	Animal related	Fuse	Replace - Same Size		I
150450593	335002	02/14/2015	13:20	02/14/2015	14:40	1	80	79	Overhead equipment	Overhead Secondary	Repair		VI
150450684	Q85162	02/14/2015	13:26	02/14/2015	15:38	2	264	132	Tree related-tree broken	Overhead Primary			VI
150450621	Q85162	02/14/2015	13:26	02/14/2015	15:06	23	2300	100	Tree related-tree broken	Overhead Primary	Patrol/Test/Inspect	Repair	VI
150450611	P69175	02/14/2015	13:28	02/14/2015	14:48	1	80	79	Unknown	Transformer Fuse	Replace - Same Size		III
150450628	R78301	02/14/2015	13:38	02/14/2015	14:25	1	47	46	Overhead equipment	Overhead Service	Replace - Same Size	Repair	V
150450631	Q85162	02/14/2015	13:38	02/14/2015	14:30	3	156	51	Tree related-tree broken	Fuse	Repair	Repair	VI
150450641	A48005	02/14/2015	13:50	02/14/2015	16:00	1	130	129	Overhead equipment	Overhead Service	Repair		I
150450649	K48380	02/14/2015	14:03	02/14/2015	14:30	1	27	26	Overhead equipment				V
150450658	K80388	02/14/2015	14:20	02/14/2015	15:50	1	90	90	Overhead equipment	Overhead Primary	Repair		IV
150450701	T28561	02/14/2015	15:20	02/14/2015	17:55	1	155	155	Overhead equipment	Fuse			VI
5001589	X02548	02/14/2015	15:35	02/14/2015	16:25	306	15039	49	Overhead equipment	Recloser	Switch/Reset		IV
150450742	B84002	02/14/2015	16:09	02/14/2015	17:02	1	53	52	Overhead equipment	Overhead Service	Reconnect		I
150450675	X09594	02/14/2015	16:14	02/14/2015	17:30	1	76	75	Overhead equipment	Disconnect Switch	Replace - Same Size		IV
150450748	V42572	02/14/2015	16:20	02/14/2015	17:20	1	60	59	Overhead equipment	Overhead Service	Replace - Same Size		II
150450755	B77001	02/14/2015	16:25	02/14/2015	17:10	1	45	45	Overhead equipment	Connector	Replace - Same Size	Replace - Same Size	I
150450784	A50002	02/14/2015	17:00	02/14/2015	19:22	1	142	141	Underground equipment	Underground Primary	Patrol/Test/Inspect	Reconnect	I
150450792	C66001	02/14/2015	17:24	02/14/2015	20:20	1	176	175	Overhead equipment	Overhead Service	Repair		III
150450799	P83710	02/14/2015	17:50	02/14/2015	19:36	1	106	105	Overhead equipment	Fuse	Replace - Same Size		I
150450805	P49187	02/14/2015	17:56	02/14/2015	19:13	6	462	76	Overhead equipment	Fuse	Replace - Same Size		I
150450815	P47125	02/14/2015	18:20	02/14/2015	19:46	1	86	85	Overhead equipment	Overhead Service	Tie/Tighten		I
150450820	J15303	02/14/2015	18:30	02/14/2015	19:35	1	65	64	Overhead equipment	Jumper	Repair		I
150450857	J83139	02/14/2015	20:15	02/14/2015	22:32	113	15481	136	Overhead equipment	Jumper		Replace - Same Size	VI
150450858	R61241	02/14/2015	20:23	02/14/2015	21:48	1	85	84	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
150450868	U97528	02/14/2015	21:09	02/14/2015	23:25	1	136	136	Overhead equipment	Overhead Primary	Repair		II
150450869	U97528	02/14/2015	21:10	02/14/2015	23:25	5	675	135	Overhead equipment	Overhead Primary	Repair		II
150450888	U97528	02/14/2015	21:16	02/14/2015	23:24	1	128	127	Overhead equipment	Overhead Primary	Repair		II
150450894	U52516	02/14/2015	21:24	02/14/2015	23:16	4	448	111	Overhead equipment	Fuse	Replace - Same Size		II
150450902	R60551	02/14/2015	23:01	02/15/2015	3:50	1	289	288	Overhead equipment	Overhead Transformer		Replace - Same Size	IV
150450903	A49003	02/14/2015	23:10	02/15/2015	4:07	1	297	296	Underground equipment	Underground Service	Patrol/Test/Inspect	Reconnect	I
5001599	X24536	02/15/2015	0:35	02/15/2015	2:16	59	5902	100	Overhead equipment	Disconnect Switch	Repair		IV
150460017	H11340	02/15/2015	2:42	02/15/2015	7:26	1	284	283	Overhead equipment	Overhead Transformer	Repair	Replace - Same Size	V
150460043	Q74149	02/15/2015	7:02	02/15/2015	8:46	13	1352	103	Overhead equipment	Jumper			IV
150460056	K62102	02/15/2015	8:40	02/15/2015	10:38	1	118	118	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	II
150460066	Y91500	02/15/2015	9:11	02/15/2015	12:52	4	884	220	Overhead equipment	Overhead Transformer	Repair	Replace - Same Size	IV
150460096	N60181	02/15/2015	10:20	02/15/2015	11:22	1	62	62	Overhead equipment	Fuse	Repair	Replace - Same Size	I
150460109	307002	02/15/2015	10:59	02/15/2015	12:40	1	101	101	Overhead equipment	Connector	Replace - Same Size		VI
5001611	Y37010	02/15/2015	11:06	02/15/2015	13:25	1	138	138	Overhead equipment	Overhead Transformer		Replace - Same Size	IV
5001613	Y37010	02/15/2015	11:10	02/15/2015	13:25	1	134	134	Overhead equipment	Overhead Transformer		Replace - Same Size	IV
5001615	X57545	02/15/2015	11:59	02/15/2015	13:09	1	69	69	Overhead equipment	Jumper	Repair		IV
150460289	K43386	02/15/2015	13:14	02/15/2015	14:45	1	91	91	Overhead equipment	Connector	Replace - Same Size	Replace - Same Size	V
150460296	M41112	02/15/2015	13:19	02/15/2015	15:04	36	3780	105	Overhead equipment	Overhead Secondary	Repair	Replace - Same Size	I
150460324	H11339	02/15/2015	15:02	02/15/2015	15:53	1	51	51	Overhead equipment	Transformer Fuse	Replace - Same Size	Replace - Same Size	V
5001617	X49570	02/15/2015	15:50	02/15/2015	19:06	24	4702	195	Overhead equipment	Disconnect Switch		Repair	IV
150460350	U80511	02/15/2015	16:16	02/15/2015	18:45	1	149	149	Other	Overhead Transformer	Replace - New Size		II
150460362	S32550	02/15/2015	16:51	02/15/2015	22:18	1	327	327	Underground equipment	Underground Service	Patrol/Test/Inspect	Repair	VI
150460363	R73841	02/15/2015	16:54	02/15/2015	18:45	1	111	110	Overhead equipment	Connector	Replace - Same Size		V

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
150460366	U84001	02/15/2015	16:57	02/15/2015	17:54	5	285	56	Overhead equipment	Transformer Fuse	Replace - Same Size		II
150460397	C37001	02/15/2015	18:26	02/15/2015	20:28	1	122	121	Overhead equipment	Disconnect Switch	Switch/Reset		III
150460400	U16522	02/15/2015	18:29	02/15/2015	19:55	19	1634	85	Overhead equipment	Fuse	Replace - Same Size	Repair	II
150460416	P19395	02/15/2015	18:43	02/15/2015	20:29	1	106	105	Overhead equipment	Transformer Fuse	Replace - Same Size	Replace - Same Size	V
150460447	S61580	02/15/2015	20:28	02/15/2015	21:20	70	3640	52	Overhead equipment	Transformer Fuse	Replace - New Size		VI
150460450	S88553	02/15/2015	21:06	02/15/2015	23:30	1	144	143	Overhead equipment	Disconnect Switch	Replace - Same Size		VI
150460454	D72002	02/15/2015	21:08	02/16/2015	1:34	1	266	265	Underground equipment	Underground Service	Patrol/Test/Inspect	Patrol/Test/Inspect	I
150460463	R53391	02/15/2015	22:37	02/16/2015	3:38	1	301	300	Underground equipment	Underground Service	Patrol/Test/Inspect	Repair	V
150460466	374057	02/15/2015	22:47	02/16/2015	12:30	1	823	823	Overhead equipment	Customer Equipment			VI
150460469	R60552	02/15/2015	22:58	02/16/2015	1:00	15	1830	121	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	IV
150470037	V30004	02/16/2015	1:17	02/16/2015	4:27	1	190	190	Unknown	Fuse	Replace - Same Size		II
5001629	R34920	02/16/2015	3:29	02/16/2015	9:08	1	338	338	Overhead equipment	Transformer Fuse	Replace - Same Size	Repair	VI
150471650	D37004	02/16/2015	4:14	02/16/2015	6:35	29	4089	140	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
150471661	V21548	02/16/2015	5:22	02/16/2015	8:53	1	211	210	Underground equipment	Underground Service	Repair		II
150471697	S32550	02/16/2015	7:30	02/16/2015	12:40	1	310	310	Unknown	Underground Service	Repair	Replace - Same Size	VI
150471716	B73001	02/16/2015	7:51	02/16/2015	9:30	1	99	99	Overhead equipment	Connector	Replace - New Size		I
150471825	N18211	02/16/2015	8:40	02/16/2015	11:02	5	710	142	Overhead equipment	Jumper	Repair		III
150471817	V22555	02/16/2015	9:24	02/16/2015	10:29	1	65	64	Overhead equipment	Transformer Fuse	Replace - Same Size		II
5001631	R08910	02/16/2015	9:28	02/16/2015	13:06	1	217	217	Overhead equipment	Overhead Transformer	Replace - Same Size	Replace - Same Size	VI
150472035	K31124	02/16/2015	11:45	02/16/2015	12:44	1	59	58	Overhead equipment	Jumper	Repair		I
150472033	V77543	02/16/2015	11:45	02/16/2015	13:23	2	196	97	Overhead equipment	Disconnect Switch		Replace - New Size	II
150472065	N50334	02/16/2015	12:05	02/16/2015	16:17	1	252	252	Underground equipment	Underground Service	Patrol/Test/Inspect	Replace - Same Size	II
5001643	Q64919	02/16/2015	13:08	02/16/2015	17:47	1	278	278	Tree related-tree broken	Overhead Primary	Repair		VI
150472265	308005	02/16/2015	13:44	02/16/2015	14:30	1	46	45	Overhead equipment	Overhead Transformer	Switch/Reset		VI
150472275	M51275	02/16/2015	13:47	02/16/2015	15:22	1	95	94	Overhead equipment	Connector			III
150472411	C70001	02/16/2015	15:17	02/16/2015	17:15	1	118	117	Overhead equipment	Fuse	Replace - Same Size		III
5001647	R34920	02/16/2015	19:27	02/16/2015	20:33	1	65	65	Overhead equipment	Fuse	Replace - Same Size		VI
150472726	L74197	02/16/2015	19:41	02/16/2015	21:14	59	5487	92	Public	Pole		Straighten	IV
150472735	X88510	02/16/2015	20:06	02/16/2015	21:25	42	3318	78	Overhead equipment	Fuse	Replace - Same Size		IV
150473249	B38002	02/16/2015	23:00	02/17/2015	6:04	12	5088	423	Overhead equipment	Overhead Primary	Repair	Repair	I
150480063	R02121	02/17/2015	0:20	02/17/2015	2:36	1	136	135	Overhead equipment	Connector	Repair		VI
5001651	X87578	02/17/2015	2:17	02/17/2015	3:33	1	75	75	Overhead equipment	Transformer Fuse	Repair		IV
150483338	S64502	02/17/2015	3:34	02/17/2015	6:25	8	1368	171	Overhead equipment	Overhead Primary	Replace - Same Size	Patrol/Test/Inspect	VI
150483357	P71830	02/17/2015	6:30	02/17/2015	7:54	67	5628	84	Overhead equipment	Jumper	Repair		V
150483447	328120	02/17/2015	7:23	02/17/2015	8:52	18	1602	88	Overhead equipment	Fuse	Patrol/Test/Inspect		V
150483742	R16510	02/17/2015	9:12	02/17/2015	10:17	14	910	65	Overhead equipment	Jumper	Repair		I
150483645	R16510	02/17/2015	9:13	02/17/2015	10:17	1	64	63	Overhead equipment	Jumper	Repair		I
150483663	R16510	02/17/2015	9:19	02/17/2015	10:17	1	58	58	Overhead equipment	Jumper	Repair		I
150483691	P17109	02/17/2015	9:27	02/17/2015	10:45	50	3900	77	Public	Underground Primary			IV
150483735	D28124	02/17/2015	9:47	02/17/2015	10:47	1	60	60	Overhead equipment	Overhead Service	Patrol/Test/Inspect		I
150483788	U01523	02/17/2015	10:01	02/17/2015	10:45	1	44	43	Overhead equipment	Jumper	Repair	Repair	II
150483926	U68001	02/17/2015	10:45	02/17/2015	12:18	2	186	92	Unknown	Transformer Fuse	Replace - Same Size		II
150484030	Z04520	02/17/2015	11:27	02/17/2015	13:55	1	148	148	Underground equipment	Underground Service	Disconnect		IV
150484081	L12125	02/17/2015	11:43	02/17/2015	12:28	1	45	45	Overhead equipment	Connector	Replace - Same Size		III
150484283	M47802	02/17/2015	12:38	02/17/2015	14:05	141	12267	87	Public	Pole	Repair	Repair	V
150484398	Z29579	02/17/2015	13:10	02/17/2015	14:39	10	890	89	Animal related	Disconnect Switch		Install	IV
150484393	J89112	02/17/2015	13:11	02/17/2015	14:24	13	949	72	Overhead equipment	Overhead Primary	Repair		VI
150484413	D31016	02/17/2015	13:17	02/17/2015	18:15	1	298	297	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	III
150484426	Q23256	02/17/2015	13:20	02/17/2015	14:54	4	376	94	Overhead equipment	Disconnect Switch	Patrol/Test/Inspect	Replace - Same Size	VI
150484498	L14232	02/17/2015	13:47	02/17/2015	14:27	1	40	39	Overhead equipment	Jumper	Replace - Same Size		III
150484583	K89143	02/17/2015	14:17	02/17/2015	14:44	1	27	27	Animal related	Transformer Fuse	Replace - Same Size		III
150484639	N70331	02/17/2015	14:32	02/17/2015	15:40	1	68	68	Overhead equipment	Other	Replace - Same Size	Replace - Same Size	I
150484687	K95208	02/17/2015	14:51	02/17/2015	15:15	38	912	23	Unknown	Transformer Fuse	Replace - Same Size		III
150484795	U31002	02/17/2015	15:45	02/17/2015	16:00	1	15	14	Overhead equipment	Overhead Secondary	Repair		II
5001685	X96524	02/17/2015	16:24	02/17/2015	17:03	1	38	38	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
150484938	T46001	02/17/2015	17:50	02/17/2015	22:50	1	300	300	Underground equipment	Underground Service		Repair	VI

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
150484956	R84148	02/17/2015	18:00	02/18/2015	1:30	1	450	450	Underground equipment	Underground Primary	Switch/Reset	Repair	I
5154867	R39934	02/17/2015	18:16	02/18/2015	11:09	26	26361	1013	Overhead equipment				VI
150485476	S43501	02/17/2015	22:13	02/17/2015	23:56	1	103	103	Overhead equipment	Transformer Fuse	Replace - Same Size		VI
150485544	Q87319	02/17/2015	23:38	02/18/2015	0:30	3424	178048	52	Overhead equipment	Pole			V
150492110	P17109	02/17/2015	23:43	02/18/2015	9:12	8	4552	569	Underground equipment	Underground Primary	Disconnect	Repair	IV
150490034	P17109	02/17/2015	23:43	02/18/2015	5:00	8	2536	317	Underground equipment	Underground Primary		Repair	IV
5001711	R39934	02/18/2015	2:19	02/18/2015	11:02	22	11506	522	Overhead equipment	Overhead Primary			VI
150492103	S34528	02/18/2015	3:10	02/18/2015	5:38	1	148	148	Overhead equipment	Overhead Secondary	Repair	Repair	VI
5001697	K67911	02/18/2015	3:16	02/18/2015	7:20	1	243	243	Overhead equipment	Overhead Transformer	Replace - Same Size	Repair	VI
150492109	T17582	02/18/2015	4:17	02/18/2015	5:27	1	70	69	Overhead equipment	Disconnect Switch	Patrol/Test/Inspect	Replace - Same Size	VI
150492195	H01194	02/18/2015	7:21	02/18/2015	9:01	174	17400	100	Overhead equipment	Jumper	Repair		III
150492368	M15375	02/18/2015	7:57	02/18/2015	8:51	42	2268	53	Animal related	Fuse	Replace - Same Size		V
150492273	R05186	02/18/2015	8:08	02/18/2015	12:00	2	464	232	Overhead equipment	Overhead Service	Repair	Tie/Tighten	I
150492336	S92559	02/18/2015	8:36	02/18/2015	10:10	1	94	94	Overhead equipment	Transformer Fuse	Replace - Same Size		VI
150492481	L24124	02/18/2015	9:24	02/18/2015	10:19	1	55	54	Overhead equipment	Overhead Primary	Repair		III
150492517	N35851	02/18/2015	9:34	02/18/2015	10:03	1	29	29	Overhead equipment	Meter	Replace - Same Size		V
150492598	332004	02/18/2015	10:06	02/18/2015	13:35	1	209	209	Overhead equipment	Jumper	Patrol/Test/Inspect	Repair	VI
150492842	332003	02/18/2015	11:34	02/18/2015	12:35	26	1586	60	Overhead equipment	Jumper	Patrol/Test/Inspect	Repair	VI
150492957	Q74150	02/18/2015	11:39	02/18/2015	12:40	4	244	60	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
150492848	S79510	02/18/2015	11:42	02/18/2015	13:15	1	93	92	Overhead equipment	Overhead Service			VI
150492885	R05186	02/18/2015	11:45	02/18/2015	15:45	19	4560	239	Underground equipment	Underground Primary	Switch/Reset	Repair	I
150492861	J46183	02/18/2015	11:46	02/18/2015	12:40	13	702	54	Overhead equipment	Fuse			III
150492945	325004	02/18/2015	12:25	02/18/2015	16:40	27	6885	255	Overhead equipment	Overhead Primary	Patrol/Test/Inspect	Repair	VI
150493024	U61568	02/18/2015	13:02	02/18/2015	14:15	13	949	72	Overhead equipment	Overhead Primary	Repair		II
150493059		02/18/2015	13:17	02/18/2015	14:19	1	62	62	Overhead equipment	Overhead Primary	Repair	Repair	I
150493093		02/18/2015	13:29	02/18/2015	14:23	78	4212	54	Unknown				VI
150493156	L43153	02/18/2015	13:33	02/18/2015	14:56	24	1992	82	Overhead equipment	Jumper	Repair		I
150493169	K79633	02/18/2015	13:34	02/18/2015	15:06	70	6440	91	Overhead equipment	Jumper	Repair		IV
150493296	R05186	02/18/2015	14:25	02/18/2015	15:35	1	70	69	Unknown	Other			I
150493351	337002	02/18/2015	14:38	02/18/2015	16:08	1	90	90	Tree related-tree contact	Overhead Service	Repair		VI
150493439	B48001	02/18/2015	15:06	02/18/2015	19:20	1	254	254	Overhead equipment	Overhead Primary	Patrol/Test/Inspect	Reconnect	I
150493527	U52516	02/18/2015	15:48	02/18/2015	19:35	1	227	226	Underground equipment	Underground Service	Repair	Repair	II
150493610	U01514	02/18/2015	15:49	02/18/2015	17:08	25	1975	78	Overhead equipment	Overhead Primary	Repair	Repair	II
150493679	X12001	02/18/2015	17:39	02/18/2015	19:10	1	91	90	Overhead equipment	Overhead Secondary	Patrol/Test/Inspect	Repair	IV
150493683	T04512	02/18/2015	17:41	02/18/2015	19:54	1	133	133	Overhead equipment	Transformer Fuse			VI
150493713	P18103	02/18/2015	18:25	02/18/2015	18:55	1	30	30	Overhead equipment	Fuse	Replace - Same Size		IV
150493728	J80807	02/18/2015	18:35	02/18/2015	20:48	484	64372	133	Overhead equipment	Overhead Primary	Repair	Repair	V
5001727	X99538	02/18/2015	18:37	02/18/2015	19:22	1	44	44	Overhead equipment	Overhead Service	Repair	Replace - Same Size	IV
150493731	J06167	02/18/2015	18:39	02/18/2015	19:22	1	43	42	Unknown	Fuse	Repair	Replace - Same Size	I
150493742	D96002	02/18/2015	18:53	02/18/2015	20:06	1	73	72	Overhead equipment	Overhead Service			I
150494337	F03003	02/18/2015	19:55	02/19/2015	0:35	7	1960	280	Underground equipment	Underground Primary	Repair		III
150494134	F03003	02/18/2015	19:55	02/18/2015	21:45	2	220	110	Underground equipment	Underground Primary	Switch/Reset		III
150494138	K28183	02/18/2015	20:13	02/18/2015	20:50	1	37	36	Overhead equipment	Jumper	Repair		III
150494150	S41565	02/18/2015	20:38	02/18/2015	21:20	1	42	42	Other	Customer Equipment			VI
150494155	H11340	02/18/2015	20:51	02/18/2015	21:46	1	55	55	Overhead equipment	Connector	Replace - Same Size		V
150494311	F10002	02/18/2015	21:02	02/18/2015	21:58	1	56	56	Overhead equipment	Jumper	Repair		III
5001729	K67912	02/18/2015	21:04	02/18/2015	22:55	1	110	110	Overhead equipment	Connector	Tie/Tighten		VI
150494321	J18268	02/18/2015	21:22	02/18/2015	22:57	1	95	95	Overhead equipment	Jumper	Repair		VI
5001751	R10903	02/18/2015	23:27	02/19/2015	7:08	25	11520	460	Public	Pole	Replace - Same Size		VI
5001747	R10903	02/18/2015	23:29	02/19/2015	0:49	25	1990	79	Public	Pole		Replace - Same Size	VI
150500156	S84709	02/19/2015	0:50	02/19/2015	2:05	3283	246225	75	Substation equipment	Substation Transformer			VI
150500169	S84710	02/19/2015	0:50	02/19/2015	2:22	1097	100924	92	Substation equipment	Substation Transformer	Switch/Reset		VI
150500207	K01236	02/19/2015	1:52	02/19/2015	7:11	1	319	319	Underground equipment	Underground Secondary	Disconnect	Repair	VI
150500246	P19395	02/19/2015	2:17	02/19/2015	6:26	1	249	249	Underground equipment	Overhead Service	Repair	Repair	V
150502919	V18553	02/19/2015	3:34	02/19/2015	4:35	7	427	60	Overhead equipment	Fuse	Replace - Same Size		II
5001753	K67924	02/19/2015	4:05	02/19/2015	6:36	18	2701	150	Overhead equipment	Overhead Primary	Repair		VI

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
150502926	HD0574	02/19/2015	4:16	02/19/2015	8:45	1	269	269	Overhead equipment	Overhead Transformer	Replace - Same Size	Patrol/Test/Inspect	VI
150502929	S20555	02/19/2015	4:27	02/19/2015	5:46	1	79	78	Overhead equipment	Transformer Fuse	Replace - Same Size	Replace - Same Size	VI
150503046	S86582	02/19/2015	4:44	02/19/2015	7:00	21	2856	135	Overhead equipment	Overhead Primary	Patrol/Test/Inspect	Repair	VI
150503013	S86582	02/19/2015	5:08	02/19/2015	7:30	15	2130	142	Overhead equipment	Fuse	Replace - Same Size		VI
150503030	HD0574	02/19/2015	5:58	02/19/2015	6:29	34	1054	30	Other	Fuse	Replace - Same Size	Patrol/Test/Inspect	VI
150503032	P49180	02/19/2015	6:05	02/19/2015	9:04	1	179	179	Overhead equipment	Overhead Transformer	Replace - Same Size	Replace - New Size	I
150503061	P83710	02/19/2015	6:34	02/19/2015	9:15	12	1932	161	Overhead equipment	Overhead Primary	Repair		I
150503055	M09144	02/19/2015	6:38	02/19/2015	8:26	4	432	108	Overhead equipment	Overhead Transformer	Replace - Same Size	Repair	VI
150503080	T03582	02/19/2015	6:52	02/19/2015	8:30	25	2450	97	Overhead equipment	Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
150503087	S49550	02/19/2015	6:58	02/19/2015	8:02	50	3200	63	Other	Fuse	Replace - Same Size	Patrol/Test/Inspect	VI
150503078	S49550	02/19/2015	6:59	02/19/2015	7:50	50	2550	50	Other	Fuse	Replace - Same Size	Patrol/Test/Inspect	VI
150503135	V10551	02/19/2015	7:30	02/19/2015	8:30	1	60	59	Animal related	Fuse			II
150503144	HD0574	02/19/2015	7:34	02/19/2015	8:45	1	71	71	Overhead equipment				VI
150503208	S49550	02/19/2015	8:03	02/19/2015	10:35	50	7600	151	Other	Fuse	Replace - Same Size	Patrol/Test/Inspect	VI
150503236	S49550	02/19/2015	8:10	02/19/2015	9:22	50	3600	71	Other	Fuse	Replace - Same Size	Patrol/Test/Inspect	VI
150503395	D88002	02/19/2015	9:17	02/19/2015	10:50	57	5301	92	Overhead equipment	Overhead Primary	Repair		I
150503444	N67312	02/19/2015	9:52	02/19/2015	10:30	1	38	37	Overhead equipment	Overhead Service	Reconnect		I
150503605	T06505	02/19/2015	10:44	02/19/2015	11:50	1	66	65	Overhead equipment	Overhead Service	Patrol/Test/Inspect		VI
150503777	M07235	02/19/2015	11:50	02/19/2015	13:15	1	85	85	Overhead equipment	Overhead Service	Replace - Same Size		III
150503816	V61563	02/19/2015	11:50	02/19/2015	12:44	54	2916	53	Overhead equipment	Transformer Fuse	Replace - Same Size		II
150503829	H10843	02/19/2015	12:06	02/19/2015	13:33	1	87	87	Overhead equipment	Overhead Service	Repair		V
150503955	N03298	02/19/2015	13:10	02/19/2015	15:21	1	131	130	Overhead equipment	Connector	Replace - Same Size		V
150503959	Q34367	02/19/2015	13:12	02/19/2015	14:36	22	1848	83	Animal related	Overhead Primary	Patrol/Test/Inspect	Repair	I
150503979	J12166	02/19/2015	13:16	02/19/2015	13:30	1	14	14	Underground equipment				III
5001761	L59929	02/19/2015	13:39	02/19/2015	15:39	4	479	119	Animal related	Fuse	Replace - Same Size	Replace - Same Size	VI
150504731	J80807	02/19/2015	18:22	02/19/2015	19:34	1	72	72	Overhead equipment	Overhead Service	Replace - Same Size	Replace - Same Size	V
150504751	D67002	02/19/2015	19:01	02/19/2015	21:47	1	166	165	Overhead equipment	Jumper			IV
150505153	J34357	02/19/2015	22:55	02/20/2015	2:15	1	200	200	Underground equipment	Underground Service	Patrol/Test/Inspect	Repair	V
5001773	X02548	02/19/2015	23:47	02/20/2015	1:57	241	31293	129	Overhead equipment				IV
5001789	X96524	02/19/2015	23:56	02/20/2015	1:35	21	2079	98	Overhead equipment	Overhead Primary			IV
5001835	X02548	02/20/2015	0:50	02/20/2015	1:32	1	41	41	Overhead equipment				IV
150510085	P57102	02/20/2015	0:52	02/20/2015	6:09	1	317	316	Overhead equipment	Overhead Primary	Repair	Repair	VI
5001851	X02548	02/20/2015	1:19	02/20/2015	1:32	1	12	12	Overhead equipment				IV
5001845	X02548	02/20/2015	1:19	02/20/2015	1:32	1	12	12	Overhead equipment				IV
5001857	X02548	02/20/2015	1:21	02/20/2015	1:32	1	10	10	Overhead equipment				IV
5001849	X02548	02/20/2015	1:21	02/20/2015	1:32	1	10	10	Overhead equipment				IV
5001837	X02548	02/20/2015	1:21	02/20/2015	3:57	1	155	155	Overhead equipment	Overhead Primary			IV
5001853	X02548	02/20/2015	1:22	02/20/2015	1:32	1	9	9	Overhead equipment				IV
5001843	X02548	02/20/2015	1:22	02/20/2015	1:32	2	18	9	Overhead equipment				IV
5001855	X02548	02/20/2015	1:22	02/20/2015	1:32	1	9	9	Overhead equipment				IV
5001859	X02548	02/20/2015	1:23	02/20/2015	1:32	1	8	8	Overhead equipment				IV
5001875	X02547	02/20/2015	1:23	02/20/2015	1:32	19	162	8	Overhead equipment	Overhead Primary			IV
5001847	X02548	02/20/2015	1:24	02/20/2015	1:32	1	7	7	Overhead equipment				IV
5001839	X02548	02/20/2015	1:24	02/20/2015	1:32	1	7	7	Overhead equipment				IV
5001861	X02548	02/20/2015	1:24	02/20/2015	1:32	1	7	7	Overhead equipment				IV
5001863	X02547	02/20/2015	1:25	02/20/2015	3:58	39	5948	152	Overhead equipment				IV
5001865	X02547	02/20/2015	1:25	02/20/2015	1:32	1	6	6	Overhead equipment				IV
5001867	X02548	02/20/2015	1:26	02/20/2015	1:32	1	5	5	Overhead equipment				IV
5001869	X02548	02/20/2015	1:26	02/20/2015	1:32	1	5	5	Overhead equipment				IV
5001871	X02547	02/20/2015	1:27	02/20/2015	3:57	6	899	149	Overhead equipment	Overhead Primary			IV
5001873	X02547	02/20/2015	1:27	02/20/2015	1:32	1	4	4	Overhead equipment				IV
5001879	X02548	02/20/2015	1:28	02/20/2015	1:32	1	3	3	Overhead equipment				IV
150512881	P57102	02/20/2015	4:03	02/20/2015	5:59	604	70064	116	Overhead equipment	Overhead Primary			VI
150512884	K39153	02/20/2015	5:07	02/20/2015	6:39	8	736	92	Overhead equipment	Overhead Primary			III
150512887	P61111	02/20/2015	5:38	02/20/2015	5:56	1	18	17	Overhead equipment	Overhead Primary	Repair	Repair	VI
150512894	S22592	02/20/2015	5:39	02/20/2015	7:10	19	1729	90	Overhead equipment	Fuse	Patrol/Test/Inspect	Replace - Same Size	VI

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
150512890	J89126	02/20/2015	5:42	02/20/2015	5:55	1	13	13	Overhead equipment	Overhead Primary	Repair	Repair	VI
150512895	R94269	02/20/2015	5:54	02/20/2015	6:13	1	19	18	Overhead equipment				VI
150512955	W03570	02/20/2015	7:14	02/20/2015	10:30	1	196	195	Underground equipment	Underground Primary	Repair		II
150512992	Q93522	02/20/2015	7:42	02/20/2015	9:00	1	78	78	Overhead equipment	Connector	Replace - Same Size	Repair	I
150513243	Q32170	02/20/2015	9:37	02/20/2015	12:07	1	150	150	Animal related	Fuse	Replace - Same Size	Patrol/Test/Inspect	I
150513334	J34356	02/20/2015	10:02	02/20/2015	10:38	1	36	36	Overhead equipment	Transformer Fuse	Replace - Same Size		V
150513666	R95520	02/20/2015	10:06	02/20/2015	12:13	347	44069	127	Overhead equipment	Overhead Primary	Switch/Reset		I
150513594	R95520	02/20/2015	10:06	02/20/2015	11:40	198	18612	94	Overhead equipment	Overhead Primary	Switch/Reset		I
150513469	R95520	02/20/2015	10:06	02/20/2015	11:01	221	12155	55	Overhead equipment	Overhead Primary	Switch/Reset		I
150513495	Q16867	02/20/2015	10:36	02/20/2015	11:02	1	26	26	Overhead equipment	Transformer Fuse	Replace - Same Size		V
150513600	L24123	02/20/2015	10:59	02/20/2015	12:43	1	104	104	Overhead equipment	Overhead Service	Tie/Tighten		III
150513767	S43511	02/20/2015	12:00	02/20/2015	12:30	1	30	30	Overhead equipment	Connector	Replace - New Size		VI
150513923	T06505	02/20/2015	12:48	02/20/2015	13:46	1	58	58	Overhead equipment	Disconnect Switch	Replace - New Size		VI
150513943	R20502	02/20/2015	12:52	02/20/2015	13:29	1	37	36	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
150514025	P49180	02/20/2015	13:16	02/20/2015	14:13	1	57	57	Animal related	Fuse			I
150514074	J06167	02/20/2015	13:32	02/20/2015	15:30	34	4012	118	Overhead equipment	Overhead Primary	Tie/Tighten	Repair	I
150514022	P26283	02/20/2015	13:46	02/20/2015	17:35	3	687	229	Public	Pole	Patrol/Test/Inspect	Replace - Same Size	I
150514205	Y45003	02/20/2015	14:12	02/20/2015	14:50	1	38	37	Overhead equipment	Jumper	Repair	Replace - Same Size	IV
150514223	B84004	02/20/2015	14:19	02/20/2015	15:15	1	56	55	Overhead equipment				I
150514288	J07135	02/20/2015	14:19	02/20/2015	15:03	18	792	43	Overhead equipment	Overhead Primary	Tie/Tighten	Repair	I
150514312	X32032	02/20/2015	15:02	02/20/2015	16:05	1	63	63	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
150514425	HA5430	02/20/2015	15:40	02/20/2015	18:55	1	195	194	Underground equipment	Underground Service	Repair	Repair	V
150514648	B73003	02/20/2015	17:47	02/20/2015	19:15	1	88	88	Overhead equipment	Connector	Replace - Same Size		I
150515069	R49261	02/20/2015	20:22	02/21/2015	0:30	17	4216	248	Underground equipment	Underground Transformer		Replace - Same Size	VI
5001913	R10903	02/20/2015	22:58	02/21/2015	2:25	50	10312	206	Overhead equipment				VI
5001937	R34920	02/21/2015	0:29	02/21/2015	5:47	3	952	317	Tree related-tree broken	Tree	Trim	Trim	VI
5001939	R34920	02/21/2015	0:35	02/21/2015	3:00	1	144	144	Tree related-tree broken				VI
150520020	S47589	02/21/2015	0:39	02/21/2015	2:33	18	2052	113	Tree related-tree broken	Fuse	Replace - Same Size	Patrol/Test/Inspect	VI
150520057		02/21/2015	1:31	02/21/2015	4:30	1	179	178	Tree related-tree broken	Overhead Service	Repair		VI
150520221	T22508	02/21/2015	1:57	02/21/2015	7:50	56	19768	352	Tree related-tree broken	Overhead Primary	Patrol/Test/Inspect	Repair	VI
150520083	S47589	02/21/2015	1:59	02/21/2015	4:26	25	3675	146	Tree related-tree broken	Overhead Primary	Repair	Patrol/Test/Inspect	VI
5001931	R34920	02/21/2015	2:02	02/21/2015	4:10	17	2175	127	Overhead equipment	Recloser	Replace - Same Size		VI
150520174	S36571	02/21/2015	2:03	02/21/2015	4:30	332	48804	146	Overhead equipment	Pole			VI
150520093	S75505	02/21/2015	2:06	02/21/2015	4:55	197	33293	168	Tree related-tree contact				VI
150520103	S04545	02/21/2015	2:16	02/21/2015	6:04	13	2964	227	Tree related-tree broken	Overhead Primary	Switch/Reset	Repair	VI
150520155	T14576	02/21/2015	2:32	02/21/2015	6:36	6	1464	243	Tree related-tree broken	Overhead Secondary	Patrol/Test/Inspect	Repair	VI
150520109	S03529	02/21/2015	2:35	02/21/2015	4:17	1	102	101	Overhead equipment				VI
150520119	S50544	02/21/2015	2:45	02/21/2015	4:43	1	118	117	Tree related-tree broken	Overhead Service	Replace - New Size		VI
150521048	Y45504	02/21/2015	3:10	02/21/2015	22:53	1	1183	1183	Overhead equipment	Jumper	Repair	Replace - Same Size	IV
150520160	Y45504	02/21/2015	3:10	02/21/2015	5:47	45	7065	156	Public	Overhead Primary		Replace - Same Size	IV
150520231	S27599	02/21/2015	3:19	02/21/2015	8:04	35	9975	284	Tree related-tree broken	Disconnect Switch			VI
5001935	L59929	02/21/2015	3:27	02/21/2015	8:31	5	1520	304	Overhead equipment	Overhead Primary	Raise	Repair	VI
150520153	S22594	02/21/2015	3:30	02/21/2015	6:11	1	161	161	Tree related-tree broken	Overhead Service	Repair		VI
150520173	S04513	02/21/2015	4:20	02/21/2015	4:50	1	30	30	Overhead equipment	Fuse	Repair		VI
150520203	T01534	02/21/2015	4:58	02/21/2015	7:30	1	152	152	Tree related-tree broken	Overhead Service	Patrol/Test/Inspect	Repair	VI
150520379	T11509	02/21/2015	5:13	02/21/2015	9:25	105	26460	251	Overhead equipment	Overhead Primary			VI
5001941	X02547	02/21/2015	5:19	02/21/2015	7:41	7	990	141	Overhead equipment	Overhead Primary	Repair		IV
150520225	S28552	02/21/2015	5:56	02/21/2015	8:00	1	124	124	Other	Overhead Service	Replace - Same Size	Patrol/Test/Inspect	VI
5001945	Q64919	02/21/2015	6:38	02/21/2015	7:53	1	74	74	Overhead equipment				VI
150520254	S47584	02/21/2015	7:03	02/21/2015	8:35	1	92	92	Tree related-tree broken	Overhead Service	Repair		VI
150520279	S15558	02/21/2015	7:34	02/21/2015	9:40	1	126	126	Tree related-tree broken				VI
150520289	Q75146	02/21/2015	7:46	02/21/2015	11:40	1	234	233	Tree related-tree broken	Overhead Secondary	Repair		VI
150520292	S49550	02/21/2015	7:49	02/21/2015	9:14	1	85	85	Tree related-tree broken	Overhead Service	Repair	Patrol/Test/Inspect	VI
150520358	G10001	02/21/2015	8:09	02/21/2015	9:20	1	71	71	Overhead equipment	Connector	Replace - Same Size		I
150520367	S50541	02/21/2015	8:17	02/21/2015	9:45	1	88	88	Tree related-tree broken	Overhead Service	Repair		VI
150520376	S07536	02/21/2015	8:30	02/21/2015	10:14	1	104	104	Tree related-tree broken	Overhead Secondary	Patrol/Test/Inspect	Repair	VI

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
150520591	V10551	02/21/2015	8:39	02/21/2015	12:00	619	124419	200	Overhead equipment	Lightning Arrestor	Replace - Same Size	Replace - Same Size	II
150520498	L12127	02/21/2015	8:52	02/21/2015	10:21	8	712	89	Public	Overhead Primary	Tie/Tighten		III
150520637	K11373	02/21/2015	9:06	02/21/2015	15:15	268	98892	368	Overhead equipment	Overhead Primary	Repair	Replace - New Size	V
150520494	K11373	02/21/2015	9:06	02/21/2015	10:30	41	3444	84	Overhead equipment	Overhead Primary	Cut in Clear	Repair	V
150520513	T22508	02/21/2015	9:17	02/21/2015	11:00	1	103	103	Tree related-tree broken	Overhead Secondary	Patrol/Test/Inspect	Repair	VI
150520534	S30518	02/21/2015	9:26	02/21/2015	10:35	1	69	68	Tree related-tree contact	Overhead Service	Repair		VI
150520546	B71002	02/21/2015	9:34	02/21/2015	11:04	1	90	90	Overhead equipment	Overhead Service	Repair		I
150520550	U68003	02/21/2015	9:37	02/21/2015	12:13	1	156	156	Overhead equipment	Transformer Fuse	Repair	Repair	II
150520552	A17025	02/21/2015	9:39	02/21/2015	12:40	1	181	181	Overhead equipment	Overhead Service	Repair		I
150520555	T22508	02/21/2015	9:44	02/21/2015	11:50	1	126	126	Tree related-tree broken				VI
150520581	K28183	02/21/2015	9:50	02/21/2015	11:06	63	4788	76	Unknown	Recloser	Switch/Reset		III
150520650	S36571	02/21/2015	10:21	02/21/2015	11:51	1	90	90	Tree related-tree contact	Overhead Service	Repair		VI
150520655	M36185	02/21/2015	10:28	02/21/2015	12:15	1	107	106	Overhead equipment	Overhead Service	Repair	Replace - Same Size	I
150520657	S03529	02/21/2015	10:29	02/21/2015	11:10	1	41	41	Tree related-tree broken	Overhead Service	Patrol/Test/Inspect	Cut in Clear	VI
150520673	S31561	02/21/2015	10:47	02/21/2015	13:30	1	163	162	Tree related-tree broken	Overhead Service	Repair		VI
150520680	HD0574	02/21/2015	10:57	02/21/2015	12:12	1	75	74	Tree related-tree broken	Tree	Trim		VI
150520705	S27599	02/21/2015	11:18	02/21/2015	13:00	1	102	101	Overhead equipment				VI
5001953	X23516	02/21/2015	11:24	02/21/2015	13:37	1	132	132	Overhead equipment	Disconnect Switch	Replace - New Size		IV
150520720	S03529	02/21/2015	11:44	02/21/2015	12:47	1	63	62	Tree related-tree broken	Overhead Service	Patrol/Test/Inspect	Repair	VI
5001955	K08909	02/21/2015	12:18	02/21/2015	18:07	1	349	349	Tree related-tree broken	Overhead Transformer	Patrol/Test/Inspect	Repair	VI
150520757	A45002	02/21/2015	12:20	02/21/2015	13:18	1	58	58	Overhead equipment	Overhead Service	Repair		I
150520766	S31527	02/21/2015	12:34	02/21/2015	14:30	1	116	116	Tree related-tree broken	Overhead Service	Repair		VI
150520813	S24596	02/21/2015	13:42	02/21/2015	14:50	1	68	68	Tree related-tree broken	Overhead Service	Repair	Repair	VI
150520836	T23527	02/21/2015	14:01	02/21/2015	16:27	1	146	146	Tree related-tree broken	Overhead Service	Replace - Same Size	Patrol/Test/Inspect	VI
150520848	S27599	02/21/2015	14:23	02/21/2015	16:00	1	97	96	Tree related-tree contact	Overhead Service			VI
150520865	V67001	02/21/2015	14:33	02/21/2015	17:11	11	1738	158	Overhead equipment	Disconnect Switch	Replace - Same Size	Replace - Same Size	II
150520881	M41113	02/21/2015	15:12	02/21/2015	16:33	1	81	81	Overhead equipment	Overhead Service	Repair	Replace - Same Size	I
150520882	T23527	02/21/2015	15:19	02/21/2015	16:30	2	142	71	Tree related-tree broken	Overhead Service	Repair		VI
150520890	M36185	02/21/2015	15:38	02/21/2015	15:50	1	12	11	Other	Overhead Service			I
150520892	T23527	02/21/2015	15:39	02/21/2015	16:55	1	76	75	Tree related-tree broken	Overhead Service	Repair	Patrol/Test/Inspect	VI
150520920	Y11556	02/21/2015	16:21	02/21/2015	20:10	1	229	229	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	IV
5001965	X66582	02/21/2015	16:41	02/21/2015	19:10	1	148	148	Overhead equipment	Overhead Service	Replace - Same Size		IV
150520928	S28551	02/21/2015	16:43	02/21/2015	18:07	1	84	84	Tree related-tree broken	Overhead Service	Repair		VI
150520975	N44217	02/21/2015	17:39	02/21/2015	19:25	30	3180	105	Overhead equipment	Overhead Primary			III
150520982	L79157	02/21/2015	18:10	02/21/2015	20:30	2	280	139	Overhead equipment	Overhead Transformer	Replace - Same Size		IV
150521008	K11373	02/21/2015	19:16	02/21/2015	21:26	1	130	130	Overhead equipment	Connector	Repair		V
150521071	S61530	02/21/2015	22:53	02/22/2015	1:45	3	516	171	Overhead equipment	Overhead Transformer			VI
150530060	J88163	02/22/2015	7:31	02/22/2015	9:46	29	3915	135	Overhead equipment	Overhead Primary	Repair		VI
150530071	V92555	02/22/2015	8:40	02/22/2015	10:00	2	160	79	Animal related	Transformer Fuse			II
150530304	P52305	02/22/2015	13:11	02/22/2015	14:45	1	94	94	Overhead equipment	Jumper	Repair		IV
150530307	S55534	02/22/2015	13:15	02/22/2015	15:18	1	123	122	Overhead equipment	Overhead Service			VI
150530315	K09864	02/22/2015	13:35	02/22/2015	15:30	41	4715	115	Animal related				V
150530403	N94180	02/22/2015	16:30	02/22/2015	17:34	25	1600	63	Overhead equipment	Jumper	Repair		I
150530401	K58213	02/22/2015	16:43	02/22/2015	19:28	10	1650	165	Animal related	Fuse	Replace - Same Size		VI
150530397	311003	02/22/2015	16:54	02/22/2015	18:18	1	84	83	Overhead equipment	Overhead Service	Patrol/Test/Inspect	Replace - New Size	VI
150530421	C37001	02/22/2015	17:45	02/22/2015	20:42	1	177	177	Overhead equipment	Connector	Repair		III
150530426	H01192	02/22/2015	18:08	02/22/2015	19:30	1	82	81	Overhead equipment	Jumper	Repair		III
5001973	R29905	02/22/2015	18:25	02/22/2015	19:46	12	971	80	Overhead equipment	Fuse	Replace - Same Size		VI
150530442	C70001	02/22/2015	18:45	02/22/2015	23:32	1	287	287	Underground equipment	Underground Secondary		Repair	III
150530455	P60170	02/22/2015	19:27	02/22/2015	21:30	1	123	123	Overhead equipment	Connector	Patrol/Test/Inspect	Tie/Tighten	VI
150530464	N05172	02/22/2015	19:43	02/22/2015	23:07	10	2040	203	Overhead equipment	Overhead Primary	Patrol/Test/Inspect	Repair	I
150530483	S49550	02/22/2015	20:52	02/22/2015	23:03	1	131	131	Tree related-tree broken	Overhead Service	Repair		VI
150531252	U84566	02/22/2015	22:46	02/22/2015	23:58	1	72	72	Overhead equipment	Jumper	Repair		II
150540068	S83533	02/23/2015	0:32	02/23/2015	2:47	1	135	135	Unknown				VI
150540075	S83533	02/23/2015	0:34	02/23/2015	2:33	13	1547	119	Unknown	Fuse			VI
150540077	S83533	02/23/2015	0:39	02/23/2015	2:48	1	129	129	Unknown				VI

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
150540079	S83533	02/23/2015	0:56	02/23/2015	2:49	1	113	112	Unknown				VI
150540109	S16596	02/23/2015	1:25	02/23/2015	5:00	3	645	214	Overhead equipment	Overhead Primary			VI
150540108	S16596	02/23/2015	1:25	02/23/2015	3:00	31	2945	94	Overhead equipment	Overhead Primary			VI
150540107	S83533	02/23/2015	1:57	02/23/2015	2:50	1	53	52	Unknown				VI
150540112	E05001	02/23/2015	2:32	02/23/2015	7:22	44	12760	289	Underground equipment	Underground Primary	Switch/Reset	Repair	IV
150542678	R50910	02/23/2015	5:40	02/23/2015	6:40	1	60	60	Overhead equipment	Jumper	Repair		I
150542702	D66002	02/23/2015	7:00	02/23/2015	8:13	1	73	73	Overhead equipment	Disconnect Switch			IV
150542714	K73362	02/23/2015	7:07	02/23/2015	12:29	1	322	322	Underground equipment	Underground Service	Repair	Repair	IV
150542822	P73158	02/23/2015	7:56	02/23/2015	8:42	1	46	46	Animal related	Fuse	Replace - Same Size		VI
150542938	J98130	02/23/2015	8:52	02/23/2015	9:45	1	53	53	Overhead equipment	Jumper			VI
150542967	B57002	02/23/2015	9:04	02/23/2015	14:00	1	296	296	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
150542973	R49261	02/23/2015	9:06	02/23/2015	9:49	1	43	43	Overhead equipment	Transformer Fuse			VI
150543046	S16596	02/23/2015	9:29	02/23/2015	10:20	1	51	50	Unknown	Customer Equipment	Replace - Same Size		VI
150543080	N58144	02/23/2015	9:40	02/23/2015	10:43	1	63	62	Overhead equipment	Jumper	Repair		I
150543173	B45005	02/23/2015	10:10	02/23/2015	11:14	35	2240	63	Animal related	Fuse	Replace - Same Size		I
150543187	R05115	02/23/2015	10:17	02/23/2015	11:26	1	69	69	Overhead equipment	Connector	Replace - Same Size	Patrol/Test/Inspect	I
150543203	T16526	02/23/2015	10:25	02/23/2015	10:45	3	60	19	Overhead equipment	Transformer Fuse			VI
150543233	T12528	02/23/2015	10:35	02/23/2015	10:47	1	12	12	Public				VI
150543270	N44215	02/23/2015	10:49	02/23/2015	13:25	1	156	156	Overhead equipment	Jumper	Repair		III
150543335	V18541	02/23/2015	11:04	02/23/2015	13:40	52	8112	156	Underground equipment	Fuse		Repair	II
150543607	HD0574	02/23/2015	12:57	02/23/2015	13:28	1	31	31	Overhead equipment				VI
150543635	M40117	02/23/2015	13:01	02/23/2015	15:30	1	149	149	Overhead equipment	Transformer Fuse	Replace - Same Size	Patrol/Test/Inspect	I
150543644	Q80353	02/23/2015	13:05	02/23/2015	13:38	1	33	33	Animal related	Transformer Fuse	Replace - Same Size	Replace - Same Size	V
150543676	V78513	02/23/2015	13:12	02/23/2015	13:58	1	46	45	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	II
150543687	L17102	02/23/2015	13:14	02/23/2015	15:31	69	9453	136	Overhead equipment	Overhead Primary	Repair		III
150543718	C36002	02/23/2015	13:31	02/23/2015	14:20	1	49	48	Overhead equipment	Fuse	Replace - Same Size		III
150543728		02/23/2015	13:33	02/23/2015	16:15	1	162	162	Underground equipment	Underground Service	Disconnect	Replace - Same Size	I
150543821	J12166	02/23/2015	14:08	02/23/2015	15:28	1	80	79	Overhead equipment	Overhead Primary	Repair		III
150544071	U12001	02/23/2015	15:50	02/23/2015	16:43	2	106	53	Overhead equipment	Transformer Fuse	Replace - Same Size		II
150544153	S61575	02/23/2015	16:35	02/23/2015	20:52	1	257	256	Overhead equipment	Overhead Transformer		Replace - Same Size	VI
150544368	D37001	02/23/2015	17:47	02/23/2015	19:05	1	78	78	Overhead equipment	Overhead Secondary	Reconnect		I
150544433	V21548	02/23/2015	18:41	02/23/2015	23:15	80	21920	274	Overhead equipment	Overhead Primary	Repair		II
150544422	P49180	02/23/2015	18:46	02/23/2015	20:10	1	84	84	Overhead equipment	Overhead Primary	Repair		I
150544448	N35851	02/23/2015	19:02	02/23/2015	20:03	1	61	60	Overhead equipment	Jumper	Repair		V
150544696	Q15844	02/23/2015	19:14	02/23/2015	20:06	1	52	52	Overhead equipment	Transformer Fuse	Replace - Same Size		V
150544944	T23528	02/23/2015	20:53	02/23/2015	21:45	7	364	52	Overhead equipment	Disconnect Switch		Repair	VI
150553157	Q95247	02/24/2015	2:55	02/24/2015	7:17	8	2096	261	Overhead equipment	Overhead Primary	Repair	Repair	VI
150553183	H07106	02/24/2015	2:58	02/24/2015	6:30	5	1060	211	Overhead equipment	Overhead Primary	Patrol/Test/Inspect	Repair	IV
150553158	R05115	02/24/2015	3:54	02/24/2015	6:00	1	126	126	Overhead equipment	Jumper	Repair		I
150553189	P69174	02/24/2015	6:24	02/24/2015	7:02	1	38	37	Overhead equipment	Overhead Primary			III
150553253	N54214	02/24/2015	7:13	02/24/2015	9:34	106	14946	140	Overhead equipment	Overhead Primary	Repair		II
150553312	S52515	02/24/2015	7:50	02/24/2015	9:50	1	120	119	Overhead equipment	Disconnect Switch	Replace - Same Size		VI
150553344	U80511	02/24/2015	8:04	02/24/2015	9:07	1	63	63	Overhead equipment	Overhead Service	Repair		II
150553479	L79157	02/24/2015	8:49	02/24/2015	9:45	2	112	56	Overhead equipment	Overhead Primary	Repair		IV
150553547	J89126	02/24/2015	9:14	02/24/2015	9:35	6	126	20	Animal related	Transformer Fuse			VI
150554120	N54214	02/24/2015	9:39	02/24/2015	11:38	25	2975	119	Underground equipment	Underground Primary	Switch/Reset		II
150553678	N54214	02/24/2015	9:40	02/24/2015	12:30	19	3230	169	Overhead equipment	Fuse	Replace - Same Size		II
150554006	S22593	02/24/2015	11:07	02/24/2015	11:45	1	38	38	Other				VI
150554036	N97887	02/24/2015	11:16	02/24/2015	11:44	1	28	27	Animal related	Transformer Fuse	Replace - Same Size		V
150554195	350103	02/24/2015	12:16	02/24/2015	13:30	10	740	74	Overhead equipment	Disconnect Switch	Patrol/Test/Inspect	Replace - Same Size	V
150554208	J01118	02/24/2015	12:20	02/24/2015	14:43	1	143	142	Animal related	Transformer Fuse	Replace - Same Size	Patrol/Test/Inspect	I
150554244	N54214	02/24/2015	12:34	02/24/2015	13:00	19	494	26	Overhead equipment	Fuse	Replace - New Size		II
150554271	HB6251	02/24/2015	12:41	02/24/2015	13:05	1	24	24	Animal related	Fuse	Replace - Same Size		VI
150554292	K79212	02/24/2015	12:49	02/24/2015	14:25	1	96	95	Overhead equipment	Jumper	Repair		IV
150554321	N70330	02/24/2015	12:55	02/24/2015	13:33	1	38	37	Overhead equipment	Jumper	Reconnect		I
150554743	L73155	02/24/2015	15:10	02/24/2015	15:46	1	36	36	Overhead equipment	Connector	Replace - Same Size		IV

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
150554918	V59561	02/24/2015	16:28	02/24/2015	17:35	5	335	66	Animal related	Fuse	Replace - Same Size		II
150554941	V59561	02/24/2015	16:52	02/24/2015	17:41	1	49	49	Animal related	Fuse	Replace - Same Size		II
5002029	Y06544	02/24/2015	16:54	02/24/2015	21:20	1	265	265	Intentional	Meter	Replace - Same Size	Replace - Same Size	IV
150554994	D96002	02/24/2015	17:27	02/24/2015	21:02	1	215	214	Underground equipment	Underground Service		Repair	I
150555013	P47120	02/24/2015	17:53	02/24/2015	21:35	1	222	222	Overhead equipment	Overhead Primary	Repair	Replace - Same Size	I
150555049	T05539	02/24/2015	18:46	02/24/2015	21:10	1	144	143	Other	Fuse	Replace - Same Size	Replace - Same Size	VI
150555608	C36002	02/24/2015	21:12	02/25/2015	0:32	1	200	200	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Repair	III
150555642	R20501	02/24/2015	22:10	02/24/2015	23:23	74	5402	73	Overhead equipment	Jumper	Repair		IV
150560130	C00001	02/24/2015	23:29	02/25/2015	4:33	1	304	303	Underground equipment	Pedestal	Replace - Same Size		I
150555670	C00001	02/24/2015	23:29	02/25/2015	2:25	9	1584	175	Underground equipment	Pedestal	Replace - Same Size	Repair	I
150555672	M45211	02/24/2015	23:39	02/25/2015	2:41	1	182	181	Underground equipment	Underground Service			IV
150560092	Y89002	02/25/2015	2:07	02/25/2015	5:15	1	188	188	Overhead equipment	Overhead Transformer	Repair	Replace - Same Size	IV
150562568	M12151	02/25/2015	5:08	02/25/2015	6:51	1	103	103	Overhead equipment	Overhead Service	Replace - Same Size		VI
150562610	R58961	02/25/2015	6:14	02/25/2015	9:29	2	390	194	Overhead equipment	Lightning Arrestor	Replace - Same Size		IV
150562650	P39298	02/25/2015	7:18	02/25/2015	9:15	1	117	116	Overhead equipment	Transformer Fuse	Replace - Same Size		VI
150562671		02/25/2015	7:28	02/25/2015	8:05	1	37	36	Overhead equipment	Fuse	Replace - Same Size		IV
5002035	X57525	02/25/2015	7:35	02/25/2015	8:21	1	45	45	Overhead equipment	Overhead Service	Replace - New Size	Replace - New Size	IV
150562691	C30002	02/25/2015	7:37	02/25/2015	10:45	1	188	187	Overhead equipment	Connector	Replace - Same Size		III
150562721	J63172	02/25/2015	7:49	02/25/2015	10:35	1	166	165	Underground equipment	Underground Service	Repair	Repair	III
150562726	C37001	02/25/2015	7:50	02/25/2015	8:42	1	52	52	Overhead equipment	Overhead Service	Tie/Tighten		III
150562811	S14511	02/25/2015	8:25	02/25/2015	10:04	1	99	98	Unknown	Customer Equipment	Replace - Same Size		VI
150562888	B00005	02/25/2015	8:52	02/25/2015	13:43	1	291	291	Underground equipment	Underground Transformer	Repair	Repair	I
150562956	V45526	02/25/2015	9:12	02/25/2015	9:59	1	47	47	Overhead equipment	Transformer Fuse	Repair	Repair	II
150563048	J01119	02/25/2015	9:36	02/25/2015	13:46	1	250	249	Tree related-tree contact	Overhead Service	Replace - New Size	Patrol/Test/Inspect	I
150563169	M09144	02/25/2015	10:02	02/25/2015	11:45	1	103	103	Overhead equipment	Fuse	Replace - Same Size		VI
150563176	P17108	02/25/2015	10:03	02/25/2015	12:30	29	4263	147	Overhead equipment	Fuse	Repair		IV
150563336	P62138	02/25/2015	10:45	02/25/2015	12:05	13	1040	79	Overhead equipment	Fuse	Replace - Same Size		VI
150563482	U90566	02/25/2015	11:21	02/25/2015	11:45	1	24	24	Overhead equipment	Transformer Fuse	Repair	Repair	II
150563513	U10569	02/25/2015	11:32	02/25/2015	13:45	1	133	132	Overhead equipment	Overhead Service			II
150563567	X29548	02/25/2015	11:47	02/25/2015	12:14	20	540	27	Animal related	Fuse	Replace - Same Size		IV
150563693	N95823	02/25/2015	12:34	02/25/2015	13:56	1	82	82	Public	Overhead Service	Repair		V
5002069	K08909	02/25/2015	14:09	02/25/2015	16:26	1	136	136	Overhead equipment	Overhead Service	Replace - New Size		VI
150564187	J08207	02/25/2015	15:35	02/25/2015	17:05	1	90	90	Overhead equipment	Connector	Replace - Same Size	Replace - Same Size	I
150564238	F10002	02/25/2015	15:59	02/25/2015	18:16	1	137	136	Overhead equipment	Disconnect Switch	Replace - Same Size		III
150564407	D66004	02/25/2015	17:34	02/25/2015	23:12	1	338	338	Underground equipment	Underground Service		Repair	IV
150564427	P47120	02/25/2015	17:42	02/26/2015	1:30	14	6552	467	Overhead equipment	Pole			I
150564438	L16213	02/25/2015	17:58	02/25/2015	18:51	9	477	52	Overhead equipment	Overhead Transformer	Repair		III
150564930	P73158	02/25/2015	22:54	02/26/2015	6:39	11	5115	464	Underground equipment	Underground Primary	Repair	Repair	VI
150570049	K95203	02/25/2015	23:33	02/26/2015	4:41	13	4004	308	Tree related-tree broken	Overhead Primary	Repair		III
150564933	K95203	02/25/2015	23:33	02/26/2015	0:39	18	1188	66	Tree related-tree broken	Overhead Primary	Repair		III
150570085	A48005	02/26/2015	0:19	02/26/2015	1:30	24	1704	71	Overhead equipment	Jumper	Replace - Same Size		I
150570102	M45212	02/26/2015	1:46	02/26/2015	4:00	69	9246	133	Overhead equipment				IV
150570146	342003	02/26/2015	3:01	02/26/2015	4:15	4	296	74	Overhead equipment	Fuse	Replace - Same Size		VI
150572272	B00008	02/26/2015	4:23	02/26/2015	8:55	19	5168	272	Underground equipment	Underground Primary	Repair	Repair	I
150572404	B00008	02/26/2015	4:23	02/26/2015	14:08	8	4680	585	Underground equipment	Underground Primary	Repair	Repair	I
150572216	S22595	02/26/2015	7:18	02/26/2015	8:16	4	232	58	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	VI
150572289	J12166	02/26/2015	8:00	02/26/2015	8:48	1	48	47	Animal related	Fuse	Replace - Same Size		III
150572310	M22812	02/26/2015	8:10	02/26/2015	10:15	9	1125	124	Public	Pole	Repair		V
150572393	H22348	02/26/2015	8:52	02/26/2015	10:02	1	70	70	Overhead equipment	Connector	Replace - Same Size		V
150572464	P47123	02/26/2015	9:07	02/26/2015	11:08	15	1815	120	Unknown	Fuse			I
150572622	B68004	02/26/2015	10:24	02/26/2015	11:00	2	72	36	Public	Fuse	Replace - Same Size		III
150572787	A81004	02/26/2015	11:11	02/26/2015	11:49	1	38	37	Overhead equipment	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	I
150572832	V23522	02/26/2015	11:32	02/26/2015	15:14	14	3108	222	Underground equipment	Underground Primary	Repair		II
150572919	S42578	02/26/2015	12:06	02/26/2015	12:45	1	39	39	Animal related	Transformer Fuse	Replace - Same Size		VI
150572990	Q27186	02/26/2015	12:30	02/26/2015	13:26	10	560	55	Animal related	Fuse	Replace - Same Size		VI
150573201	311001	02/26/2015	13:59	02/26/2015	16:32	1	153	152	Overhead equipment	Overhead Service	Patrol/Test/Inspect	Replace - New Size	VI

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
150573698	S50544	02/26/2015	17:58	02/26/2015	19:25	4	348	87	Overhead equipment	Transformer Fuse	Replace - New Size		VI
150573744	P69173	02/26/2015	18:37	02/26/2015	22:00	153	31059	203	Overhead equipment	Overhead Primary	Repair		III
150574031	M04365	02/26/2015	20:56	02/26/2015	22:00	4	256	63	Overhead equipment	Fuse	Repair		V
150574055	B73002	02/26/2015	22:23	02/27/2015	0:04	1	101	101	Overhead equipment	Jumper	Repair		I
150574057	X77543	02/26/2015	22:30	02/27/2015	0:01	1	91	91	Overhead equipment	Jumper	Repair		IV
150574074	P25150	02/26/2015	22:39	02/26/2015	23:55	5	380	76	Overhead equipment	Jumper			III
150574085	M05360	02/26/2015	22:49	02/26/2015	23:45	82	4592	56	Public	Pole			V
150574084	D39001	02/26/2015	23:38	02/27/2015	1:59	1	141	140	Overhead equipment	Fuse			I
150580050	H11339	02/27/2015	0:01	02/27/2015	3:38	18	3906	216	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	V
150580065	U57560	02/27/2015	0:14	02/27/2015	2:58	11	1804	164	Underground equipment	Underground Primary		Repair	II
150580077	S31527	02/27/2015	0:38	02/27/2015	2:00	1	82	82	Overhead equipment	Fuse	Replace - Same Size		VI
150583123	U02597	02/27/2015	3:45	02/27/2015	8:00	29	7395	255	Overhead equipment	Overhead Primary	Repair		II
150583131	V14579	02/27/2015	5:24	02/27/2015	7:35	5	655	130	Overhead equipment	Overhead Primary	Repair		II
150583180	P47120	02/27/2015	6:26	02/27/2015	7:53	1	87	87	Unknown	Transformer Fuse	Replace - Same Size		I
150583247	R73841	02/27/2015	7:34	02/27/2015	9:59	1	145	145	Overhead equipment	Overhead Secondary	Repair		V
150583267	Y20522	02/27/2015	7:42	02/27/2015	8:54	1	72	72	Overhead equipment	Jumper	Repair		IV
150583274	R60551	02/27/2015	7:47	02/27/2015	8:46	1	59	58	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
150583606	S84709	02/27/2015	8:43	02/27/2015	8:58	3282	49230	15	Public				VI
150583854	K78352	02/27/2015	9:59	02/27/2015	10:25	375	9750	26	Overhead equipment	Recloser	Switch/Reset	Switch/Reset	IV
5002101	Z10500	02/27/2015	10:07	02/27/2015	11:00	1	52	52	Overhead equipment	Overhead Primary			IV
150583825	U84001	02/27/2015	10:11	02/27/2015	11:00	1	49	49	Overhead equipment	Transformer Fuse	Replace - Same Size		II
150583884	D70001	02/27/2015	10:29	02/27/2015	12:15	48	5088	105	Underground equipment	Switchgear	Repair	Repair	I
150583916	N44215	02/27/2015	10:50	02/27/2015	14:45	1	235	235	Underground equipment	Underground Primary			III
5002107	L59929	02/27/2015	12:31	02/27/2015	13:09	4	149	37	Animal related	Fuse	Replace - Same Size		VI
150584195	D70001	02/27/2015	12:47	02/27/2015	15:23	1	156	156	Underground equipment	Underground Transformer	Repair	Repair	I
150584201	T46001	02/27/2015	12:51	02/27/2015	20:05	1	434	434	Underground equipment	Underground Secondary	Disconnect	Repair	VI
150584207	R58951	02/27/2015	12:52	02/27/2015	13:42	1	50	49	Animal related	Transformer Fuse	Replace - Same Size		IV
150584299	K27150	02/27/2015	13:35	02/27/2015	14:25	1	50	50	Unknown	Transformer Fuse	Replace - Same Size	Replace - Same Size	VI
150584386	R99180	02/27/2015	14:11	02/27/2015	15:57	1	106	105	Overhead equipment	Connector		Repair	IV
150584411	M07236	02/27/2015	14:18	02/27/2015	15:45	1	87	87	Unknown	Transformer Fuse	Replace - Same Size		III
150584688	T06503	02/27/2015	15:29	02/27/2015	16:19	1	50	49	Overhead equipment	Overhead Service	Patrol/Test/Inspect	Repair	VI
150584741	Q32170	02/27/2015	16:00	02/27/2015	17:30	1	90	90	Overhead equipment	Overhead Service	Repair		I
150584780	S43512	02/27/2015	16:40	02/27/2015	17:23	1	43	43	Other	Other			VI
150584969	J12166	02/27/2015	17:45	02/27/2015	19:25	1	100	100	Underground equipment	Underground Service		Repair	III
150584994	X36550	02/27/2015	18:34	02/27/2015	20:05	1	91	91	Overhead equipment	Fuse	Replace - Same Size		IV
150585301	S41564	02/27/2015	19:26	02/27/2015	20:00	3	102	34	Overhead equipment	Transformer Fuse	Replace - Same Size		VI
150590044	J13108	02/28/2015	5:34	02/28/2015	11:00	1	326	326	Unknown	Overhead Primary	Replace - Same Size		I
150590118	R20502	02/28/2015	8:29	02/28/2015	11:47	1	198	197	Overhead equipment	Overhead Transformer		Repair	IV
150590120	B45005	02/28/2015	8:35	02/28/2015	9:41	1	66	65	Overhead equipment	Connector	Replace - Same Size	Replace - Same Size	I
150590148	B84004	02/28/2015	9:25	02/28/2015	10:40	1	75	75	Animal related	Transformer Fuse	Replace - Same Size		I
150590162	J63174	02/28/2015	10:01	02/28/2015	14:43	1	282	281	Underground equipment	Underground Service			III
150590171	T04513	02/28/2015	10:17	02/28/2015	11:00	1	43	43	Animal related	Fuse	Replace - Same Size		VI
150590178	P26283	02/28/2015	10:30	02/28/2015	12:35	1	125	124	Other	Jumper	Repair		I
150590205	L23145	02/28/2015	10:36	02/28/2015	11:30	4	216	53	Unknown	Fuse	Replace - Same Size		III
150590191	R71285	02/28/2015	10:43	02/28/2015	12:02	1	79	78	Animal related	Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
150590199	P26283	02/28/2015	10:50	02/28/2015	12:35	1	105	104	Other	Jumper	Repair		I
150590212	U13551	02/28/2015	11:17	02/28/2015	12:45	1	88	88	Overhead equipment	Transformer Fuse	Replace - Same Size		II
150590280	M54292	02/28/2015	13:18	02/28/2015	14:30	1	72	71	Overhead equipment	Connector	Replace - Same Size	Repair	V
150590301	R59421	02/28/2015	14:12	02/28/2015	15:22	1	70	69	Overhead equipment	Overhead Service			IV
150590305	J63172	02/28/2015	14:21	02/28/2015	15:03	1	42	42	Animal related	Transformer Fuse			III
150590321	B45003	02/28/2015	14:57	02/28/2015	16:10	1	73	72	Overhead equipment	Connector	Replace - Same Size	Replace - Same Size	I
150590333	W03570	02/28/2015	15:23	02/28/2015	16:45	1	82	81	Animal related	Transformer Fuse			II
5002113	Q64919	02/28/2015	15:54	02/28/2015	17:43	1	108	108	Animal related	Fuse	Replace - Same Size		VI
150590354	329146	02/28/2015	15:58	02/28/2015	19:25	13	2691	207	Overhead equipment	Disconnect Switch	Patrol/Test/Inspect	Repair	V
150590417	338005	02/28/2015	16:40	02/28/2015	18:00	102	8160	79	Overhead equipment	Overhead Primary	Patrol/Test/Inspect	Repair	VI
150590431	X39530	02/28/2015	16:53	02/28/2015	18:00	6	402	66	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	IV

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
150590495	L42158	02/28/2015	18:37	02/28/2015	21:35	6	1068	178	Public	Pole		Replace - Same Size	III
150590533	V41533	02/28/2015	23:22	03/01/2015	1:14	4	448	111	Overhead equipment	Transformer Fuse	Repair	Repair	II
150590535	M31201	02/28/2015	23:36	03/01/2015	11:00	1	684	684	Underground equipment	Underground Secondary	Reconnect		I
5002119	Y61003	03/01/2015	0:10	03/01/2015	1:32	12	981	81	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
150600004	L00133	03/01/2015	0:27	03/01/2015	1:06	1	39	38	Public	Pole	Replace - Same Size		III
150600006	S88553	03/01/2015	0:42	03/01/2015	2:40	4	472	117	Overhead equipment	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
150600274	L35139	03/01/2015	4:54	03/01/2015	5:51	1	57	56	Overhead equipment	Overhead Transformer	Repair		III
150600281	K69117	03/01/2015	5:07	03/01/2015	7:41	8	1232	154	Underground equipment	Underground Primary	Switch/Reset	Repair	IV
150600293	R50910	03/01/2015	7:25	03/01/2015	10:10	7	1155	164	Overhead equipment	Overhead Primary	Repair		I
150600294	K69117	03/01/2015	7:30	03/01/2015	7:43	1	13	13	Underground equipment	Underground Primary			IV
150600395	U29001	03/01/2015	8:11	03/01/2015	11:30	3	597	198	Public	Underground Transformer			II
150600304	U29001	03/01/2015	8:11	03/01/2015	13:49	3	1014	338	Public	Underground Transformer		Repair	II
150600305	S21529	03/01/2015	8:15	03/01/2015	10:18	1	123	123	Animal related	Transformer Fuse	Replace - New Size		VI
150600307	D81001	03/01/2015	8:22	03/01/2015	11:45	6	1218	203	Overhead equipment	Disconnect Switch	Replace - Same Size	Repair	I
150600311	K28183	03/01/2015	8:24	03/01/2015	10:28	24	2976	124	Overhead equipment	Lightning Arrestor	Replace - New Size		III
150600322	Y28597	03/01/2015	8:55	03/01/2015	12:50	4	940	234	Overhead equipment	Overhead Transformer	Replace - Same Size	Replace - Same Size	IV
150600375	K71821	03/01/2015	9:01	03/01/2015	12:41	1070	235400	219	Overhead equipment	Overhead Primary			IV
150600479		03/01/2015	9:08	03/01/2015	12:11	2	366	182	Unknown	Substation Transformer			III
150600383	C00002	03/01/2015	9:19	03/01/2015	11:05	1	106	105	Overhead equipment	Connector	Replace - Same Size	Replace - Same Size	I
150600404	J79306	03/01/2015	10:08	03/01/2015	11:52	1	104	103	Underground equipment	Underground Service	Repair		I
150600411	P73182	03/01/2015	10:24	03/01/2015	12:25	1	121	120	Public	Overhead Secondary	Replace - Same Size	Replace - Same Size	VI
150600426	Z29579	03/01/2015	10:51	03/01/2015	13:30	23	3657	159	Overhead equipment	Disconnect Switch	Replace - Same Size	Install	IV
150600446	U16500	03/01/2015	11:04	03/01/2015	13:23	77	10703	139	Underground equipment	Underground Primary			II
150600496	U78001	03/01/2015	12:47	03/01/2015	17:55	1	308	308	Public	Pole	Replace - New Size	Replace - New Size	II
150600497	P57108	03/01/2015	12:48	03/01/2015	14:40	22	2464	111	Overhead equipment	Fuse	Replace - Same Size		VI
5002127	K67924	03/01/2015	13:02	03/01/2015	13:24	1	21	21	Animal related	Fuse	Repair		VI
5002129	Y61004	03/01/2015	13:16	03/01/2015	17:05	7	1600	228	Overhead equipment	Overhead Transformer	Replace - Same Size	Replace - Same Size	IV
150600621	D60001	03/01/2015	13:46	03/01/2015	14:48	1	62	62	Animal related	Fuse	Repair	Replace - Same Size	III
150600631	V14579	03/01/2015	14:31	03/01/2015	16:02	1	91	91	Public	Other			II
150600641	L82187	03/01/2015	14:48	03/01/2015	17:30	1	162	161	Tree related-tree broken	Overhead Secondary		Repair	IV
150600669	S47537	03/01/2015	16:16	03/01/2015	20:06	9	2070	230	Underground equipment				VI
150600672	D41003	03/01/2015	16:22	03/01/2015	17:20	1	58	58	Underground equipment	Underground Primary	Repair		I
150600673	R48165	03/01/2015	16:32	03/01/2015	19:40	2	376	188	Overhead equipment	Transformer Fuse		Replace - Same Size	IV
150600708	A45002	03/01/2015	18:39	03/02/2015	4:38	9	5391	599	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
150600736	S47537	03/01/2015	20:10	03/02/2015	0:26	6	1536	255	Underground equipment	Underground Transformer		Replace - Same Size	VI
150600764	J79306	03/01/2015	21:42	03/02/2015	1:44	1	242	242	Underground equipment	Underground Service	Patrol/Test/Inspect	Replace - Same Size	I
150600798	J84146	03/01/2015	23:55	03/02/2015	4:15	1	260	259	Underground equipment	Underground Service	Patrol/Test/Inspect	Repair	VI
150610080	D48002	03/02/2015	0:43	03/02/2015	4:52	1	249	248	Underground equipment	Underground Service	Repair	Repair	I
150613087	D48002	03/02/2015	6:53	03/02/2015	13:07	1	374	373	Underground equipment	Underground Service	Patrol/Test/Inspect	Reconnect	I
150613622	Y32002	03/02/2015	7:16	03/02/2015	10:08	511	87892	172	Jurisdictional	Pole	Repair	Replace - Same Size	IV
150613455	M45212	03/02/2015	8:44	03/02/2015	9:41	1	57	56	Overhead equipment	Overhead Service	Advise Customer		IV
150614242	D16004	03/02/2015	8:51	03/02/2015	11:31	279	44640	159	Underground equipment	Underground Primary	Switch/Reset		I
150614239	D16004	03/02/2015	8:51	03/02/2015	11:25	661	101794	153	Underground equipment	Underground Primary	Switch/Reset		I
150613538	D16004	03/02/2015	8:53	03/02/2015	11:27	253	38962	153	Underground equipment	Underground Primary	Switch/Reset	Switch/Reset	I
150613654	R04412	03/02/2015	9:21	03/02/2015	10:33	57	4104	72	Overhead equipment	Fuse	Replace - New Size		V
150613652	J75271	03/02/2015	9:22	03/02/2015	10:59	1	97	97	Overhead equipment	Overhead Service			IV
150613757	P42229	03/02/2015	9:38	03/02/2015	11:21	17	1751	103	Underground equipment	Underground Primary			VI
150613767	Q80353	03/02/2015	9:42	03/02/2015	12:30	29	4872	168	Overhead equipment	Jumper	Patrol/Test/Inspect	Replace - Same Size	V
150613867	HB6281	03/02/2015	10:11	03/02/2015	12:32	1	141	140	Overhead equipment	Lightning Arrestor	Replace - Same Size		VI
150613906	B71002	03/02/2015	10:23	03/02/2015	14:40	1	257	256	Overhead equipment	Jumper		Repair	I
150613997	Q93522	03/02/2015	10:51	03/02/2015	17:55	2	848	424	Underground equipment	Underground Primary	Patrol/Test/Inspect		I
150614258	Q34360	03/02/2015	11:34	03/02/2015	12:43	9	621	69	Animal related	Fuse	Patrol/Test/Inspect	Repair	I
150614396	U73759	03/02/2015	11:53	03/02/2015	14:49	965	169840	175	Substation equipment	Substation Misc.	Replace - Same Size		II
150614393	R05115	03/02/2015	12:10	03/02/2015	13:05	1	55	55	Other	Overhead Service			I
150614719	H14343	03/02/2015	13:08	03/02/2015	15:17	2	258	129	Overhead equipment	Fuse	Replace - Same Size		V
150614699	H10843	03/02/2015	13:46	03/02/2015	13:55	24	216	8	Overhead equipment	Overhead Primary			V

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
150614758	S86580	03/02/2015	14:12	03/02/2015	15:11	1	59	59	Overhead equipment	Overhead Service	Patrol/Test/Inspect	Repair	VI
150614814	Y28597	03/02/2015	14:23	03/02/2015	15:50	1	87	86	Animal related	Disconnect Switch			IV
150614960	P26284	03/02/2015	15:02	03/02/2015	17:00	1	118	118	Unknown	Fuse	Patrol/Test/Inspect	Repair	I
150615258	Y59519	03/02/2015	15:06	03/02/2015	17:30	1	144	143	Overhead equipment				IV
150615172	Y59519	03/02/2015	15:06	03/02/2015	16:12	350	21978	66	Public	Pole	Repair	Repair	IV
5002183	Y35513	03/02/2015	15:08	03/02/2015	15:30	1	21	21	Overhead equipment	Overhead Service			IV
150616136	A45003	03/02/2015	16:09	03/03/2015	0:05	2	952	475	Underground equipment	Underground Primary	Repair	Repair	I
150615216	A45003	03/02/2015	16:09	03/02/2015	19:30	40	8040	200	Public	Underground Primary			I
150615340	M26161	03/02/2015	17:20	03/02/2015	18:10	1	50	50	Overhead equipment	Jumper	Repair		III
150615491	M22812	03/02/2015	17:44	03/02/2015	19:25	1	101	101	Overhead equipment	Transformer Fuse	Replace - Same Size		V
5002189	R08910	03/02/2015	19:22	03/02/2015	21:45	6	858	143	Overhead equipment	Jumper	Repair	Repair	VI
150616153	A45003	03/02/2015	20:11	03/02/2015	21:40	22	1958	89	Underground equipment	Underground Primary			I
150620088	X65540	03/03/2015	0:17	03/03/2015	8:49	10	5120	511	Underground equipment	Underground Primary	Repair		IV
150620058	X65540	03/03/2015	0:26	03/03/2015	2:00	21	1974	94	Underground equipment	Underground Primary			IV
150620081	D92002	03/03/2015	1:11	03/03/2015	7:19	1	368	367	Underground equipment	Underground Transformer	Replace - Same Size	Repair	I
150620087	L24123	03/03/2015	1:51	03/03/2015	3:10	3	237	79	Overhead equipment	Overhead Transformer		Replace - Same Size	III
150622514	D70006	03/03/2015	3:15	03/03/2015	5:38	73	10439	143	Unknown	Fuse	Replace - Same Size	Replace - Same Size	I
150622518	J07135	03/03/2015	3:33	03/03/2015	7:48	2	510	254	Unknown	Fuse	Replace - Same Size		I
150622516	J07135	03/03/2015	3:34	03/03/2015	8:41	1	307	307	Unknown	Fuse	Replace - Same Size		I
150622603	R84148	03/03/2015	4:30	03/03/2015	6:20	781	85910	110	Unknown	Recloser	Patrol/Test/Inspect	Switch/Reset	I
150622593	J07135	03/03/2015	4:46	03/03/2015	8:19	4	852	213	Unknown	Fuse			I
150622594	N70625	03/03/2015	4:57	03/03/2015	8:06	1	189	188	Unknown	Substation Breaker	Switch/Reset	Patrol/Test/Inspect	I
150622609	R33127	03/03/2015	5:53	03/03/2015	11:40	1	347	346	Overhead equipment	Fuse	Replace - Same Size	Patrol/Test/Inspect	I
150622629	Q25801	03/03/2015	6:46	03/03/2015	7:54	40	2720	68	Tree related-tree broken	Fuse	Replace - Same Size		I
150623050	D35002	03/03/2015	6:50	03/03/2015	11:29	1	279	279	Overhead equipment	Pole	Replace - Same Size	Repair	I
150622651	D35002	03/03/2015	6:50	03/03/2015	8:30	25	2500	100	Overhead equipment	Pole		Replace - Same Size	I
150622741	K82202	03/03/2015	6:51	03/03/2015	8:39	224	24192	108	Overhead equipment	Overhead Primary	Patrol/Test/Inspect		III
150622759	Z05725	03/03/2015	7:16	03/03/2015	10:22	599	111414	185	Overhead equipment	Crossarm			IV
150622774	Z05725	03/03/2015	7:16	03/03/2015	7:33	1676	28492	17	Overhead equipment	Crossarm			IV
150623327	Z05725	03/03/2015	7:16	03/03/2015	9:30	741	99294	134	Overhead equipment	Overhead Primary			IV
150622733	U28510	03/03/2015	7:23	03/03/2015	11:18	1	235	235	Overhead equipment	Disconnect Switch			II
150622761	K95207	03/03/2015	7:24	03/03/2015	7:40	1	16	15	Public	Other			III
150622793	K71812	03/03/2015	7:41	03/03/2015	8:41	1	60	59	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
150622906	A12037	03/03/2015	8:01	03/03/2015	9:13	2585	186120	72	Overhead equipment	Other	Patrol/Test/Inspect	Repair	I
150623076	U53737	03/03/2015	8:19	03/03/2015	8:27	2106	16848	7	Substation equipment	Substation Misc.	Switch/Reset		II
150622930		03/03/2015	8:19	03/03/2015	9:20	1	61	60	Overhead equipment				IV
150623010	B81002	03/03/2015	8:20	03/03/2015	9:31	10	710	71	Overhead equipment				I
150622989	B81001	03/03/2015	8:24	03/03/2015	9:53	60	5340	89	Overhead equipment				I
150623035	B25001	03/03/2015	8:29	03/03/2015	12:20	32	7392	230	Overhead equipment	Jumper		Repair	I
150623254	X09557	03/03/2015	8:37	03/03/2015	10:23	9	954	105	Overhead equipment	Fuse	Patrol/Test/Inspect	Replace - Same Size	IV
150623192	K31124	03/03/2015	8:47	03/03/2015	10:00	12	876	72	Overhead equipment	Connector	Replace - Same Size		I
150623122	H02256	03/03/2015	8:53	03/03/2015	10:27	1	94	94	Overhead equipment				III
150623159	H02256	03/03/2015	9:06	03/03/2015	10:28	1	82	82	Overhead equipment				III
150623239	N44216	03/03/2015	9:18	03/03/2015	10:45	322	28014	87	Overhead equipment				III
150623217	S21529	03/03/2015	9:23	03/03/2015	10:45	1	82	81	Overhead equipment	Connector	Patrol/Test/Inspect	Repair	VI
150623406	B19002	03/03/2015	9:24	03/03/2015	11:06	265	27030	101	Overhead equipment	Jumper	Repair	Repair	I
150623431	X75512	03/03/2015	9:36	03/03/2015	16:26	122	50020	409	Overhead equipment	Crossarm	Replace - Same Size	Replace - Same Size	IV
150623386	Q70429	03/03/2015	9:44	03/03/2015	11:13	616	54824	89	Substation equipment	Substation Breaker	Replace - Same Size		I
150623316	H02256	03/03/2015	9:45	03/03/2015	10:27	1	42	42	Overhead equipment				III
150623905	Y84526	03/03/2015	9:56	03/03/2015	12:09	76	10108	132	Overhead equipment	Overhead Primary			IV
150623476	337001	03/03/2015	10:00	03/03/2015	13:00	74	13320	180	Overhead equipment	Overhead Primary	Patrol/Test/Inspect	Repair	VI
150623575	J07135	03/03/2015	10:02	03/03/2015	11:47	107	11235	104	Overhead equipment	Jumper	Repair		I
150623973	B68068	03/03/2015	10:24	03/03/2015	17:32	1686	721608	428	Overhead equipment	Pole	Replace - Same Size		III
150623738	S49549	03/03/2015	10:26	03/03/2015	11:20	44	2376	53	Overhead equipment				VI
150623626	B44001	03/03/2015	10:40	03/03/2015	11:26	1	46	46	Overhead equipment	Overhead Service	Raise		I
150623696	J01118	03/03/2015	10:46	03/03/2015	12:20	36	3384	94	Unknown	Recloser	Patrol/Test/Inspect	Switch/Reset	I

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
150623694	X72535	03/03/2015	10:52	03/03/2015	21:15	1	623	622	Overhead equipment	Pole	Replace - Same Size	Replace - Same Size	IV
150623901	C30001	03/03/2015	11:10	03/03/2015	17:30	28	10640	379	Overhead equipment	Pole	Replace - Same Size		III
150623933	N15850	03/03/2015	11:17	03/03/2015	14:31	3	582	194	Overhead equipment	Pole	Replace - New Size	Replace - New Size	V
150623925	N15850	03/03/2015	11:17	03/03/2015	12:20	71	4473	63	Overhead equipment	Pole			V
150623784	K19117	03/03/2015	11:19	03/03/2015	11:30	1	11	10	Other	Overhead Transformer			VI
150623858	M45212	03/03/2015	11:41	03/03/2015	13:15	3	282	94	Overhead equipment	Fuse	Replace - Same Size		IV
150623867	K69112	03/03/2015	11:43	03/03/2015	13:48	1	125	124	Overhead equipment	Jumper	Repair		IV
150623877	D28124	03/03/2015	11:47	03/03/2015	17:27	1	340	339	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
150623930	D89001	03/03/2015	12:02	03/03/2015	13:54	62	6944	112	Overhead equipment	Overhead Primary	Tie/Tighten		I
150623952	J07173	03/03/2015	12:14	03/03/2015	13:41	1	87	87	Overhead equipment	Fuse	Replace - Same Size		I
150623970	S22593	03/03/2015	12:23	03/03/2015	13:32	1	69	68	Overhead equipment	Connector			VI
150624037	338005	03/03/2015	12:50	03/03/2015	14:29	1	99	99	Overhead equipment	Other	Patrol/Test/Inspect		VI
150624054		03/03/2015	12:59	03/03/2015	13:46	1	47	46	Unknown	Fuse	Replace - Same Size		I
150624128	M40117	03/03/2015	13:18	03/03/2015	15:08	1	110	110	Animal related	Underground Transformer	Replace - Same Size		I
150624136	M45212	03/03/2015	13:24	03/03/2015	15:25	1	121	120	Overhead equipment	Overhead Transformer			IV
150624209	B19002	03/03/2015	13:46	03/03/2015	14:54	1	68	68	Overhead equipment	Overhead Primary	Repair		I
150624319	K89141	03/03/2015	14:32	03/03/2015	15:15	1	43	42	Overhead equipment	Fuse	Replace - Same Size		III
150624331	Y28597	03/03/2015	14:39	03/03/2015	15:20	1	41	40	Tree related-tree broken	Fuse	Replace - Same Size		IV
150624332	P57104	03/03/2015	14:39	03/03/2015	15:27	1	48	47	Other				VI
150624339	U92593	03/03/2015	14:41	03/03/2015	16:05	1	84	84	Overhead equipment	Fuse			II
150624341	338005	03/03/2015	14:44	03/03/2015	16:25	1	101	101	Public	Overhead Transformer	Switch/Reset		VI
150624380	M41111	03/03/2015	14:57	03/03/2015	16:00	5	315	62	Unknown	Fuse	Replace - Same Size	Patrol/Test/Inspect	I
150624368	HA5430	03/03/2015	15:01	03/03/2015	19:25	1	264	264	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - New Size	V
150624390	X30505	03/03/2015	15:06	03/03/2015	16:25	1	79	79	Overhead equipment	Disconnect Switch	Replace - New Size		IV
150624412	K07320	03/03/2015	15:16	03/03/2015	15:57	1	41	40	Other	Other	Replace - Same Size	Replace - Same Size	I
150624565	M78322	03/03/2015	16:32	03/03/2015	17:52	1	80	79	Unknown	Overhead Service	Patrol/Test/Inspect	Raise	V
150625410	Y73504	03/03/2015	19:21	03/03/2015	20:50	1	89	88	Tree related-tree contact	Overhead Service	Repair		IV
150625463	T04513	03/03/2015	21:17	03/03/2015	23:24	1	127	126	Overhead equipment	Transformer Fuse	Repair	Replace - Same Size	VI
150625507	P18104	03/03/2015	22:34	03/04/2015	4:47	1	373	373	Underground equipment	Underground Service		Repair	IV
150625599	J84123	03/03/2015	23:11	03/04/2015	5:08	515	183855	357	Overhead equipment	Jumper		Repair	VI
150625539	J84124	03/03/2015	23:14	03/04/2015	4:48	1	334	333	Overhead equipment	Customer Equipment			VI
150625552	J84124	03/03/2015	23:20	03/04/2015	5:01	1	341	341	Other				VI
150630131	Q18245	03/03/2015	23:22	03/04/2015	3:28	716	176136	245	Overhead equipment	Overhead Primary	Repair	Repair	VI
150630045	HA5431	03/04/2015	0:16	03/04/2015	2:01	1	105	104	Tree related-tree contact	Transformer Fuse	Replace - Same Size		V
150630076	R49261	03/04/2015	0:22	03/04/2015	5:05	831	235173	283	Overhead equipment	Overhead Primary	Patrol/Test/Inspect	Repair	VI
150632232	R49261	03/04/2015	0:22	03/04/2015	4:15	518	120694	233	Overhead equipment	Overhead Primary			VI
150632218	V24583	03/04/2015	3:12	03/04/2015	4:25	5	365	73	Animal related	Transformer Fuse	Replace - Same Size		II
150632230	M09143	03/04/2015	3:55	03/04/2015	6:25	1	150	149	Public	Overhead Secondary	Replace - Same Size	Repair	VI
150632248	S27599	03/04/2015	4:17	03/04/2015	7:00	11	1793	162	Tree related-tree broken	Overhead Primary			VI
150632272	D92002	03/04/2015	6:18	03/04/2015	7:53	1	95	95	Underground equipment	Underground Transformer	Patrol/Test/Inspect	Replace - Same Size	I
150632283		03/04/2015	6:40	03/04/2015	7:52	1	72	71	Overhead equipment	Overhead Primary		Repair	VI
150632357	Q91175	03/04/2015	7:22	03/04/2015	10:50	1	208	208	Overhead equipment	Transformer Fuse	Replace - Same Size	Patrol/Test/Inspect	I
150632508	R71286	03/04/2015	8:37	03/04/2015	11:16	1	159	159	Overhead equipment	Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
150632552	R04415	03/04/2015	8:54	03/04/2015	17:30	1	516	515	Underground equipment	Underground Secondary	Disconnect		V
150632604	329146	03/04/2015	9:09	03/04/2015	9:43	1	34	34	Overhead equipment	Overhead Transformer	Repair		V
150632603	X12526	03/04/2015	9:10	03/04/2015	10:40	4	360	90	Overhead equipment	Fuse	Patrol/Test/Inspect	Replace - Same Size	IV
150632884	T04512	03/04/2015	9:20	03/04/2015	13:02	101	22422	222	Overhead equipment	Connector			VI
150632690	J99141	03/04/2015	9:44	03/04/2015	14:13	1	269	269	Underground equipment	Underground Service		Replace - Same Size	VI
150632987	V74513	03/04/2015	10:02	03/04/2015	13:45	5	1115	222	Animal related	Underground Primary	Repair		II
5002223	X96524	03/04/2015	10:16	03/04/2015	14:18	5	1210	242	Overhead equipment	Transformer Fuse	Disconnect	Repair	IV
150632873	C52002	03/04/2015	11:01	03/04/2015	12:26	1	85	85	Overhead equipment	Connector	Repair		III
150632991	351001	03/04/2015	11:41	03/04/2015	14:00	1	139	139	Tree related-tree contact	Overhead Service	Repair		VI
150633032	HB6251	03/04/2015	12:03	03/04/2015	13:35	1	92	91	Underground equipment	Underground Service		Replace - Same Size	VI
150633121	J79306	03/04/2015	12:34	03/04/2015	13:10	1	36	36	Other	Fuse	Replace - Same Size		I
150633166	H10843	03/04/2015	12:52	03/04/2015	13:35	1	43	42	Overhead equipment	Transformer Fuse	Replace - Same Size		V
150633399	U04550	03/04/2015	14:06	03/04/2015	14:20	1	14	13	Overhead equipment				II

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
150633568	J80807	03/04/2015	15:01	03/04/2015	15:59	1	58	58	Overhead equipment				V
150633744	J61113	03/04/2015	16:03	03/04/2015	17:10	1	67	67	Overhead equipment	Overhead Transformer		Replace - Same Size	III
150633918	N97887	03/04/2015	17:52	03/04/2015	20:10	1	138	138	Overhead equipment	Overhead Service	Repair		V
150633927	M41111	03/04/2015	18:04	03/04/2015	19:11	1	67	66	Overhead equipment	Overhead Secondary	Repair		I
150633932	S61529	03/04/2015	18:09	03/04/2015	19:10	1	61	60	Other	Underground Service	Advise Customer		VI
150633937	R71286	03/04/2015	18:15	03/04/2015	19:43	1	88	88	Overhead equipment	Connector	Repair		VI
150634410	J05139	03/04/2015	20:16	03/04/2015	21:03	2	94	46	Unknown	Fuse	Patrol/Test/Inspect	Replace - Same Size	I
150634412	J14140	03/04/2015	20:31	03/04/2015	23:54	1	203	203	Overhead equipment	Jumper		Replace - Same Size	VI
150643593	B58001	03/05/2015	7:39	03/05/2015	8:55	1	76	76	Overhead equipment	Connector	Repair		I
150643628	X88507	03/05/2015	8:00	03/05/2015	8:47	1	47	46	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
150643711	S14511	03/05/2015	8:44	03/05/2015	10:35	1	111	110	Overhead equipment	Overhead Service	Replace - Same Size		VI
150643791	K62102	03/05/2015	9:17	03/05/2015	10:11	1	54	53	Overhead equipment	Jumper	Repair		II
150643803	V95586	03/05/2015	9:21	03/05/2015	9:25	1	4	4	Animal related	Transformer Fuse	Replace - Same Size		II
150643830	D66004	03/05/2015	9:28	03/05/2015	10:35	1	67	66	Overhead equipment	Overhead Primary	Repair		IV
150644107	S13549	03/05/2015	10:55	03/05/2015	11:40	14	630	45	Overhead equipment				VI
5002259	X66582	03/05/2015	11:42	03/05/2015	13:47	23	2855	124	Overhead equipment	Bracket	Tie/Tighten		IV
150644438	Q04411	03/05/2015	13:15	03/05/2015	14:59	1	104	103	Public	Other			III
150644564	313135	03/05/2015	13:52	03/05/2015	15:39	1	107	107	Overhead equipment	Overhead Service	Repair		V
5002265	P20913	03/05/2015	15:14	03/05/2015	16:48	3	279	93	Overhead equipment	Connector	Replace - New Size	Replace - New Size	VI
150644783	R94269	03/05/2015	15:18	03/05/2015	20:44	1	326	326	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	VI
150644840	J83138	03/05/2015	15:48	03/05/2015	19:08	1	200	200	Overhead equipment	Lightning Arrestor		Replace - Same Size	VI
150644926	U15004	03/05/2015	16:59	03/05/2015	21:32	4	1092	272	Overhead equipment	Overhead Transformer	Replace - Same Size	Replace - New Size	II
150645024	M26164	03/05/2015	17:56	03/05/2015	20:28	15	2280	152	Overhead equipment	Overhead Primary	Repair		III
150645063	X13001	03/05/2015	18:53	03/05/2015	20:35	1	102	101	Overhead equipment	Overhead Secondary	Raise		IV
150645073	N44215	03/05/2015	19:09	03/05/2015	21:18	1	129	128	Overhead equipment	Connector			III
150645274	M51275	03/05/2015	19:14	03/05/2015	20:16	1	62	62	Overhead equipment	Fuse			III
150645441	N44215	03/05/2015	20:36	03/05/2015	22:11	1	95	95	Overhead equipment	Connector			III
150645446	S20555	03/05/2015	20:50	03/05/2015	21:44	5	270	53	Overhead equipment	Transformer Fuse	Replace - Same Size		VI
150645601	X68506	03/05/2015	23:08	03/06/2015	0:20	1	72	72	Overhead equipment	Transformer Fuse	Replace - Same Size	Replace - Same Size	IV
150650153	X88507	03/05/2015	23:30	03/06/2015	1:54	2	288	144	Overhead equipment	Overhead Primary	Repair		IV
150645606	X88507	03/05/2015	23:30	03/06/2015	0:54	27	2268	84	Overhead equipment	Overhead Primary	Repair		IV
150652326	N44215	03/06/2015	5:53	03/06/2015	7:25	1	92	92	Overhead equipment	Fuse			III
150652344	Q27185	03/06/2015	6:00	03/06/2015	7:33	9	837	92	Animal related	Fuse	Replace - Same Size		VI
150652454	S20555	03/06/2015	7:49	03/06/2015	8:52	7	441	62	Overhead equipment	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
150652535	311001	03/06/2015	8:23	03/06/2015	10:22	1	119	118	Overhead equipment	Fuse	Repair		VI
150652579	G50001	03/06/2015	8:42	03/06/2015	10:15	1	93	92	Overhead equipment	Overhead Service	Repair	Repair	IV
150652618	Z21564	03/06/2015	8:56	03/06/2015	11:05	1	129	129	Overhead equipment	Overhead Primary	Raise		IV
150652789	P77235	03/06/2015	9:52	03/06/2015	10:45	4	212	52	Animal related				VI
5002313	R39934	03/06/2015	10:12	03/06/2015	10:27	363	5401	14	Overhead equipment				VI
150652904	J61114	03/06/2015	10:23	03/06/2015	10:49	1	26	26	Overhead equipment	Connector			III
5002333	R39934	03/06/2015	10:43	03/06/2015	11:32	1	48	48	Overhead equipment	Overhead Primary			VI
150653040	350103	03/06/2015	11:10	03/06/2015	11:39	1	29	29	Overhead equipment	Overhead Transformer	Repair		V
150653092	N50331	03/06/2015	11:21	03/06/2015	12:35	31	2294	74	Overhead equipment	Jumper	Repair		II
150653216	Q04411	03/06/2015	12:12	03/06/2015	13:02	1	50	50	Overhead equipment	Overhead Primary			III
150653251	B61001	03/06/2015	12:26	03/06/2015	23:01	1	635	634	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
150653260	H22346	03/06/2015	12:29	03/06/2015	13:26	1	57	56	Animal related	Transformer Fuse	Replace - Same Size		V
5002341	Q54908	03/06/2015	12:37	03/06/2015	13:29	1	51	51	Overhead equipment	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
150653303	K28183	03/06/2015	12:43	03/06/2015	13:19	52	1872	35	Overhead equipment	Jumper	Repair		III
150653310	338007	03/06/2015	12:47	03/06/2015	14:14	1	87	87	Overhead equipment	Fuse	Repair		VI
150653435	D55002	03/06/2015	13:33	03/06/2015	14:20	1	47	46	Overhead equipment	Connector	Replace - Same Size		I
5002347	R34921	03/06/2015	13:46	03/06/2015	15:53	26	3301	126	Overhead equipment	Recloser	Patrol/Test/Inspect	Repair	VI
150653538	P60161	03/06/2015	14:09	03/06/2015	14:53	1	44	43	Other				VI
150653663	R58951	03/06/2015	14:58	03/06/2015	15:45	1	47	46	Overhead equipment	Jumper	Repair		IV
150653683	338007	03/06/2015	15:00	03/06/2015	16:30	1	90	90	Public	Overhead Primary	Patrol/Test/Inspect	Repair	VI
150653771	V45574	03/06/2015	15:04	03/06/2015	15:51	136	6392	46	Jurisdictional	Overhead Primary	Switch/Reset	Repair	II
150653995	V46552	03/06/2015	15:04	03/06/2015	17:02	297	35046	117	Jurisdictional	Overhead Primary	Repair		II

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
150653889	V36001	03/06/2015	15:05	03/06/2015	17:15	1	130	130	Overhead equipment				II
5002351	R34921	03/06/2015	15:49	03/06/2015	15:53	1	3	3	Overhead equipment	Recloser	Replace - Same Size	Replace - Same Size	VI
150653831	R78300	03/06/2015	15:54	03/06/2015	20:05	4	1004	251	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - New Size	V
150653871	B71001	03/06/2015	16:24	03/06/2015	18:36	1	132	132	Overhead equipment	Overhead Service	Repair		I
150654018	R48166	03/06/2015	17:09	03/06/2015	20:40	1	211	210	Overhead equipment	Overhead Transformer	Replace - Same Size		IV
150653844	B44002	03/06/2015	17:10	03/06/2015	18:23	1	73	72	Overhead equipment	Connector	Replace - Same Size		I
150654241	J83140	03/06/2015	18:12	03/06/2015	19:20	15	1020	68	Overhead equipment	Fuse	Replace - Same Size		VI
150654248	V10551	03/06/2015	18:25	03/06/2015	23:30	1	305	304	Other	Overhead Transformer	Replace - Same Size	Replace - Same Size	II
150654573	A50002	03/06/2015	18:34	03/06/2015	19:41	6	402	67	Overhead equipment	Overhead Primary	Cut in Clear	Repair	I
150654568	A50002	03/06/2015	18:34	03/07/2015	1:05	34	13294	391	Overhead equipment	Overhead Primary	Cut in Clear	Repair	I
150654266	Y68581	03/06/2015	18:37	03/06/2015	21:53	1	196	196	Overhead equipment	Disconnect Switch	Replace - Same Size		IV
150654571	V29003	03/06/2015	19:56	03/06/2015	20:58	1	62	62	Overhead equipment	Connector	Repair		II
150654589	T04513	03/06/2015	20:43	03/06/2015	23:19	1	156	156	Overhead equipment	Overhead Secondary			VI
150660018	R84148	03/07/2015	0:53	03/07/2015	2:00	1	67	66	Unknown	Transformer Fuse	Replace - Same Size		I
150660027	M05360	03/07/2015	1:05	03/07/2015	2:08	57	3591	62	Public	Recloser	Switch/Reset		V
150660021	M05360	03/07/2015	1:05	03/07/2015	8:18	99	42867	432	Public	Pole	Replace - Same Size	Replace - Same Size	V
150660069	H07106	03/07/2015	4:22	03/07/2015	7:32	1	190	190	Overhead equipment	Fuse			IV
150660129	C00001	03/07/2015	6:57	03/07/2015	9:15	12	1656	137	Animal related	Fuse	Replace - Same Size		I
5002355	Q82906	03/07/2015	7:11	03/07/2015	8:12	1	60	60	Animal related	Transformer Fuse	Repair		VI
150660127	S47575	03/07/2015	7:25	03/07/2015	11:00	1	215	214	Overhead equipment	Overhead Service	Repair		VI
150660156	K52400	03/07/2015	7:50	03/07/2015	9:10	52	4160	79	Animal related	Fuse	Replace - Same Size		V
150660184	P73157	03/07/2015	8:38	03/07/2015	9:41	18	1134	62	Animal related	Fuse	Replace - Same Size		VI
150660281	303005	03/07/2015	9:15	03/07/2015	15:34	1	379	378	Public	Pole	Patrol/Test/Inspect	Replace - New Size	VI
150660325	Q14390	03/07/2015	9:54	03/07/2015	10:30	21	756	36	Unknown	Fuse	Replace - Same Size	Replace - Same Size	I
150660338	Z21564	03/07/2015	10:18	03/07/2015	11:40	4	328	81	Animal related	Transformer Fuse	Repair	Replace - Same Size	IV
150660420	U02597	03/07/2015	11:15	03/07/2015	13:20	54	6750	124	Overhead equipment	Fuse	Replace - Same Size		II
150660384	J34377	03/07/2015	11:21	03/07/2015	12:16	1	55	55	Overhead equipment	Fuse	Replace - Same Size		V
150660395	L81142	03/07/2015	11:40	03/07/2015	12:30	2	100	50	Overhead equipment	Transformer Fuse			IV
150660438	Q24313	03/07/2015	12:56	03/07/2015	13:55	1	59	58	Overhead equipment	Transformer Fuse	Replace - Same Size		VI
150660471	L12126	03/07/2015	13:32	03/07/2015	19:03	26	8606	330	Underground equipment	Underground Secondary	Repair		III
150660498	P83710	03/07/2015	14:35	03/07/2015	17:39	1	184	184	Other	Transformer Fuse	Repair		I
150660508	N05172	03/07/2015	15:02	03/07/2015	18:48	2	452	226	Overhead equipment	Overhead Transformer	Replace - Same Size		I
150660515	P77235	03/07/2015	15:09	03/07/2015	16:38	36	3204	89	Overhead equipment	Overhead Primary	Replace - Same Size		VI
150660625	J47175	03/07/2015	16:01	03/07/2015	18:51	28	4760	169	Overhead equipment	Overhead Primary			III
150660578	A85001	03/07/2015	16:35	03/07/2015	17:42	43	2881	67	Overhead equipment	Overhead Primary	Reconnect		I
150660589	R60552	03/07/2015	17:18	03/07/2015	18:00	4	168	42	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
150660605	P26283	03/07/2015	17:39	03/08/2015	1:11	1	452	451	Underground equipment	Underground Service	Patrol/Test/Inspect	Repair	I
150660626	S14511	03/07/2015	18:34	03/07/2015	20:45	1	131	131	Overhead equipment	Overhead Service	Patrol/Test/Inspect	Repair	VI
150660646	V99562	03/07/2015	18:49	03/08/2015	1:15	1	386	386	Overhead equipment	Pole	Replace - Same Size	Replace - Same Size	II
150670007	Z30584	03/08/2015	0:48	03/08/2015	10:30	1	582	582	Underground equipment	Underground Service	Repair		IV
150670033	J05138	03/08/2015	7:27	03/08/2015	9:15	1	108	107	Overhead equipment	Fuse	Replace - New Size		I
150670053	P73157	03/08/2015	8:30	03/08/2015	9:47	11	847	76	Animal related	Fuse	Replace - Same Size		VI
5002373	J20931	03/08/2015	8:50	03/08/2015	10:50	166	19463	119	Overhead equipment	Overhead Primary	Repair	Repair	VI
150670064	U11531	03/08/2015	9:31	03/08/2015	12:30	1	179	179	Overhead equipment	Overhead Transformer	Replace - Same Size		II
150670110	K01239	03/08/2015	10:53	03/08/2015	12:06	151	11023	72	Animal related	Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
150670113	H06135	03/08/2015	11:06	03/08/2015	12:56	1	110	110	Animal related	Transformer Fuse	Replace - Same Size		IV
150670115	350104	03/08/2015	11:09	03/08/2015	11:55	1	46	46	Animal related	Fuse	Replace - Same Size		V
150670119	D16001	03/08/2015	11:17	03/08/2015	12:17	5	300	60	Unknown	Disconnect Switch	Replace - Same Size	Replace - Same Size	I
150670121	350104	03/08/2015	11:26	03/08/2015	11:55	1	29	29	Animal related	Fuse	Replace - Same Size		V
150670116	V37537	03/08/2015	11:38	03/08/2015	13:39	2	242	120	Unknown	Fuse	Replace - Same Size	Replace - Same Size	II
150670131	P05826	03/08/2015	11:53	03/08/2015	13:45	1	112	111	Overhead equipment	Overhead Primary	Repair	Repair	V
150670270	A26005	03/08/2015	14:18	03/08/2015	15:24	1	66	66	Animal related	Overhead Transformer	Replace - Same Size		I
5002383	K32915	03/08/2015	14:25	03/08/2015	18:37	4	1005	251	Animal related	Overhead Primary	Repair	Repair	VI
150670289	V25504	03/08/2015	14:44	03/08/2015	16:10	1	86	85	Overhead equipment	Overhead Service	Repair		II
150670293	J06167	03/08/2015	14:49	03/08/2015	16:14	1	85	85	Other	Transformer Fuse	Replace - Same Size		I
150670294	P69173	03/08/2015	14:50	03/08/2015	15:41	1	51	50	Animal related	Fuse	Replace - Same Size		III

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
150670298	D16001	03/08/2015	14:54	03/08/2015	17:53	1	179	178	Underground equipment	Underground Primary	Replace - Same Size	Replace - Same Size	I
150670335	R71285	03/08/2015	17:03	03/08/2015	18:23	1	80	79	Animal related	Transformer Fuse	Replace - Same Size		VI
5002389	X02546	03/08/2015	17:43	03/08/2015	19:51	39	4979	127	Tree related-tree broken	Fuse	Replace - Same Size		IV
150670364	K01239	03/08/2015	18:24	03/08/2015	19:45	6	486	80	Animal related	Transformer Fuse	Replace - Same Size		VI
150670368	L43153	03/08/2015	18:38	03/08/2015	19:37	1	59	59	Animal related	Transformer Fuse	Replace - Same Size		I
5002397	J20931	03/08/2015	18:49	03/08/2015	21:06	1	136	136	Overhead equipment	Fuse	Repair		VI
150670415	S88503	03/08/2015	20:25	03/08/2015	23:19	2	348	174	Animal related	Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
150670426	V37537	03/08/2015	22:17	03/08/2015	23:58	1	101	101	Animal related	Transformer Fuse	Repair		II
150682213	D88001	03/09/2015	3:33	03/09/2015	6:00	62	9114	146	Overhead equipment	Lightning Arrestor	Replace - Same Size		I
150682245	J47175	03/09/2015	6:30	03/09/2015	7:15	1	45	45	Animal related	Transformer Fuse	Repair	Repair	III
150682343		03/09/2015	7:35	03/09/2015	8:41	1	66	66	Animal related	Overhead Transformer	Switch/Reset		I
150682386	B73001	03/09/2015	7:56	03/09/2015	9:42	1	106	105	Public	Overhead Service	Raise		I
150682474	J06167	03/09/2015	8:25	03/09/2015	9:45	1	80	79	Unknown	Fuse			I
150682601	U42512	03/09/2015	8:59	03/09/2015	11:00	1	121	121	Overhead equipment	Disconnect Switch	Replace - Same Size	Replace - Same Size	II
150682741	U60559	03/09/2015	9:29	03/09/2015	10:25	1	56	56	Animal related	Transformer Fuse			II
150683017	K31120	03/09/2015	10:26	03/09/2015	11:15	1	49	49	Overhead equipment	Jumper	Repair	Repair	I
150683041	N35852	03/09/2015	10:31	03/09/2015	12:55	1	144	143	Animal related	Fuse	Replace - Same Size		V
150683273	R04407	03/09/2015	11:22	03/09/2015	11:58	1	36	36	Overhead equipment	Fuse	Replace - Same Size		V
150683323	M41112	03/09/2015	11:36	03/09/2015	12:20	1	44	44	Animal related	Fuse			I
150683451	T41540	03/09/2015	12:06	03/09/2015	13:00	1	54	53	Animal related	Fuse	Replace - Same Size		IV
150683471	M18131	03/09/2015	12:11	03/09/2015	14:36	1	145	144	Animal related	Transformer Fuse	Repair		III
150683609	P49187	03/09/2015	12:46	03/09/2015	13:29	1	43	42	Animal related	Transformer Fuse	Replace - Same Size	Replace - Same Size	I
150683637	D36001	03/09/2015	12:55	03/09/2015	13:20	1	25	24	Animal related	Fuse	Repair	Replace - Same Size	I
150683805	M37192	03/09/2015	13:04	03/09/2015	13:30	165	4290	26	Public	Fuse			I
150683794	M09143	03/09/2015	13:07	03/09/2015	13:29	263	5786	21	Other	Overhead Primary			VI
150683881	R95520	03/09/2015	13:33	03/09/2015	15:20	1	107	107	Weather	Transformer Fuse	Replace - Same Size		I
5002417	T59902	03/09/2015	13:39	03/09/2015	14:32	1	52	52	Overhead equipment	Disconnect Switch	Replace - Same Size		VI
150684325	V21500	03/09/2015	15:11	03/09/2015	15:32	6	126	20	Overhead equipment				II
5002423	X02546	03/09/2015	15:45	03/09/2015	16:14	1	28	28	Animal related	Transformer Fuse	Replace - Same Size		IV
5002425	R34920	03/09/2015	16:44	03/09/2015	19:52	1	187	187	Tree related-tree contact	Fuse	Replace - Same Size		VI
150684621	D16003	03/09/2015	16:52	03/09/2015	18:20	72	6336	88	Underground equipment	Underground Primary	Repair		I
150684894	D16003	03/09/2015	16:52	03/09/2015	23:34	14	5628	402	Underground equipment	Other	Repair	Repair	I
150684696	B35002	03/09/2015	17:26	03/10/2015	0:30	1	424	423	Underground equipment	Underground Service	Patrol/Test/Inspect	Repair	I
150684837	M05368	03/09/2015	17:32	03/09/2015	18:55	10	830	82	Tree related-tree contact	Transformer Fuse	Replace - Same Size		V
150684864	G50002	03/09/2015	17:46	03/09/2015	19:31	1	105	105	Overhead equipment	Jumper	Repair		IV
5002441	N59-UNIT-1	03/10/2015	2:33	03/10/2015	2:53	1	19	19	Unknown				VI
150690267	K65221	03/10/2015	2:51	03/10/2015	4:13	1	82	81	Overhead equipment	Jumper	Repair	Repair	III
150692755		03/10/2015	4:25	03/10/2015	6:50	321	46545	144	Underground equipment	Underground Connector	Repair		I
150692774		03/10/2015	4:25	03/10/2015	7:04	891	141669	158	Underground equipment	Underground Connector	Repair		I
150692805		03/10/2015	4:25	03/10/2015	7:28	535	97905	182	Underground equipment	Underground Connector	Repair		I
150692825		03/10/2015	4:25	03/10/2015	7:37	344	66048	191	Underground equipment	Underground Connector	Repair		I
150692556	Q18242	03/10/2015	4:31	03/10/2015	5:47	70	5320	75	Animal related	Recloser			VI
150692590	C70004	03/10/2015	4:51	03/10/2015	8:26	1	215	215	Underground equipment	Underground Service	Repair	Repair	III
5002447	Q82906	03/10/2015	5:27	03/10/2015	7:19	1	111	111	Overhead equipment				VI
150692711	HB6251	03/10/2015	6:18	03/10/2015	6:55	1	37	37	Overhead equipment	Transformer Fuse			VI
150692740	Q06131	03/10/2015	6:59	03/10/2015	8:20	1	81	80	Overhead equipment	Fuse		Replace - Same Size	IV
150692891	J80807	03/10/2015	8:03	03/10/2015	9:39	41	3936	95	Tree related-tree broken	Overhead Primary	Repair	Repair	V
150692995	B76003	03/10/2015	8:47	03/10/2015	11:55	1	188	188	Underground equipment	Underground Service	Repair		I
150693216	L95110	03/10/2015	9:55	03/10/2015	10:41	1	46	46	Animal related	Fuse	Replace - Same Size		III
150693285	Y51505	03/10/2015	10:13	03/10/2015	10:58	8	360	45	Overhead equipment	Fuse	Replace - Same Size		IV
150693327	J14140	03/10/2015	10:24	03/10/2015	11:23	1	59	59	Animal related	Fuse	Replace - Same Size		VI
150693331	S95570	03/10/2015	10:26	03/10/2015	19:04	5	2590	518	Tree related-tree broken	Crossarm	Replace - New Size		VI
150693426	X64503	03/10/2015	10:50	03/10/2015	12:14	1	84	84	Underground equipment	Underground Service	Repair	Advise Customer	IV
150693527	S86580	03/10/2015	11:13	03/10/2015	11:50	1	37	36	Animal related	Transformer Fuse	Replace - Same Size		VI
150693620	H10843	03/10/2015	11:38	03/10/2015	12:34	3	168	55	Animal related	Transformer Fuse	Replace - Same Size		V
5002463	K32932	03/10/2015	12:26	03/10/2015	14:37	1	130	130	Overhead equipment	Fuse			VI

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
150694018	Q91175	03/10/2015	13:32	03/10/2015	15:35	1	123	123	Other	Overhead Service	Reconnect	Reconnect	I
150694031	M21133	03/10/2015	13:35	03/10/2015	16:52	1	197	197	Overhead equipment	Overhead Transformer	Replace - Same Size	Replace - Same Size	VI
150694114	N60181	03/10/2015	13:55	03/10/2015	14:31	1	36	36	Overhead equipment	Lightning Arrestor	Patrol/Test/Inspect	Replace - Same Size	I
150694207	J01119	03/10/2015	14:22	03/10/2015	14:58	1	36	36	Public	Transformer Fuse	Replace - Same Size	Patrol/Test/Inspect	I
150694456	U06524	03/10/2015	15:28	03/10/2015	16:10	359	15078	42	Unknown	Substation Breaker	Switch/Reset		II
150694588	L17104	03/10/2015	16:20	03/10/2015	17:16	1	56	56	Overhead equipment	Transformer Fuse	Repair		III
5002473	L62927	03/10/2015	17:02	03/10/2015	18:16	1	73	73	Overhead equipment	Fuse	Replace - Same Size		VI
150694687	S13546	03/10/2015	17:16	03/10/2015	20:27	1	191	190	Tree related-tree contact	Overhead Service	Replace - Same Size		VI
150694751	HA5432	03/10/2015	17:43	03/10/2015	21:54	1	251	251	Overhead equipment	Fuse		Replace - Same Size	V
150694798	R16510	03/10/2015	18:05	03/10/2015	19:05	1	60	60	Animal related	Transformer Fuse	Replace - Same Size		I
150694851	R16510	03/10/2015	18:23	03/10/2015	23:10	1	287	287	Underground equipment	Underground Secondary	Repair		I
150694921	P69175	03/10/2015	19:10	03/10/2015	20:45	1	95	95	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect		III
150694960	M47816	03/10/2015	19:56	03/10/2015	21:00	1	64	63	Overhead equipment	Fuse	Repair	Repair	V
150694977	P69175	03/10/2015	20:14	03/10/2015	22:45	7	1057	150	Overhead equipment	Overhead Transformer	Replace - New Size		III
150694999	N70330	03/10/2015	20:48	03/10/2015	23:35	1	167	166	Overhead equipment	Overhead Transformer			I
150700144	U86500	03/11/2015	0:37	03/11/2015	2:40	1	123	123	Tree related-tree broken				II
150700730	Z04001	03/11/2015	2:07	03/11/2015	5:20	248	47864	193	Overhead equipment	Recloser	Replace - Same Size		IV
150701686	D66002	03/11/2015	2:21	03/11/2015	6:51	7	1890	270	Overhead equipment	Overhead Primary	Repair		IV
150701680	S47586	03/11/2015	2:52	03/11/2015	3:49	20	1140	57	Overhead equipment	Fuse		Replace - Same Size	VI
150701811	P42230	03/11/2015	7:26	03/11/2015	8:43	1	77	76	Animal related	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
150701874	D90002	03/11/2015	7:54	03/11/2015	8:58	1	64	63	Overhead equipment				III
150702016	U04550	03/11/2015	8:47	03/11/2015	11:05	1	138	137	Overhead equipment				II
150702022	A73002	03/11/2015	8:49	03/11/2015	15:32	1	403	403	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Repair	I
150702105	J83137	03/11/2015	9:13	03/11/2015	9:56	1	43	43	Animal related	Transformer Fuse	Replace - Same Size		VI
150702223	K76543	03/11/2015	9:42	03/11/2015	10:40	1	58	58	Animal related	Fuse	Replace - Same Size		IV
150702261	K76543	03/11/2015	9:54	03/11/2015	11:00	10	660	66	Animal related	Fuse	Replace - Same Size		IV
150702332	N35851	03/11/2015	10:14	03/11/2015	11:37	1	83	82	Overhead equipment	Overhead Service	Repair		V
150702401	J07173	03/11/2015	10:26	03/11/2015	12:07	1	101	101	Unknown	Overhead Transformer	Switch/Reset		I
150702485	V24583	03/11/2015	10:36	03/11/2015	10:53	736	12512	17	Jurisdictional	Substation Breaker	Switch/Reset		II
150702498	D61001	03/11/2015	10:44	03/11/2015	11:54	1	70	69	Overhead equipment	Other	Patrol/Test/Inspect	Patrol/Test/Inspect	III
150702617	M05368	03/11/2015	11:04	03/11/2015	14:38	1	214	214	Underground equipment	Underground Service	Patrol/Test/Inspect	Repair	V
150702643	N44217	03/11/2015	11:11	03/11/2015	11:52	1	41	40	Animal related	Transformer Fuse		Replace - Same Size	III
150702722	B38001	03/11/2015	11:19	03/11/2015	12:30	15	1065	71	Unknown	Fuse	Replace - Same Size		I
150702775	A85001	03/11/2015	11:36	03/11/2015	12:56	43	3440	80	Unknown	Fuse	Replace - Same Size		I
150703048	D53002	03/11/2015	12:30	03/11/2015	17:00	24	6480	270	Underground equipment	Underground Primary	Switch/Reset	Repair	I
150703318	L71170	03/11/2015	12:35	03/11/2015	14:10	1	95	95	Overhead equipment	Overhead Primary	Raise	Replace - Same Size	IV
150703105	L71170	03/11/2015	12:35	03/11/2015	13:45	43	3010	69	Overhead equipment	Overhead Primary	Raise		IV
150703465	N18211	03/11/2015	14:36	03/11/2015	16:38	1	122	122	Overhead equipment	Transformer Fuse	Replace - Same Size		III
150703667	Q32170	03/11/2015	15:19	03/11/2015	17:10	1	111	111	Underground equipment	Underground Service	Patrol/Test/Inspect	Patrol/Test/Inspect	I
150703705	V18553	03/11/2015	15:30	03/11/2015	16:32	4	248	61	Animal related	Transformer Fuse	Replace - Same Size		II
150703741	P77237	03/11/2015	15:47	03/11/2015	16:47	1	60	60	Overhead equipment	Transformer Fuse	Replace - Same Size		VI
150703745	D88001	03/11/2015	15:48	03/11/2015	21:24	1	336	336	Public	Underground Transformer	Patrol/Test/Inspect	Replace - Same Size	I
150703753	M05360	03/11/2015	15:50	03/11/2015	21:25	1	335	335	Overhead equipment	Overhead Transformer	Replace - Same Size	Patrol/Test/Inspect	V
150703755	D81001	03/11/2015	15:51	03/11/2015	18:39	1	168	168	Tree related-tree contact	Connector	Repair		I
150703793	P18104	03/11/2015	16:00	03/11/2015	18:50	2	340	169	Underground equipment				IV
150704469	P77235	03/11/2015	16:57	03/11/2015	20:40	22	4906	222	Public	Overhead Primary	Repair		VI
150704055	P60161	03/11/2015	18:19	03/11/2015	19:20	1	61	60	Other	Meter	Reconnect		VI
150704060	P57102	03/11/2015	18:22	03/11/2015	20:55	1	153	153	Overhead equipment	Disconnect Switch		Replace - Same Size	VI
150704062	M36185	03/11/2015	18:23	03/11/2015	19:01	1	38	37	Overhead equipment	Other	Replace - Same Size		I
150704076	Q21321	03/11/2015	18:39	03/11/2015	18:45	80	480	5	Overhead equipment	Recloser		Patrol/Test/Inspect	VI
150704475	P83710	03/11/2015	20:56	03/12/2015	5:15	1	499	499	Underground equipment	Underground Secondary	Repair		I
150704500	K43386	03/11/2015	22:12	03/12/2015	0:44	1	152	151	Public	Pole	Cut in Clear	Replace - Same Size	V
150704513	P60161	03/11/2015	23:17	03/12/2015	0:42	1	85	85	Other				VI
150712689	A56015	03/12/2015	7:06	03/12/2015	10:37	107	22577	211	Overhead equipment	Overhead Transformer	Replace - Same Size	Repair	I
150712357	R33127	03/12/2015	8:09	03/12/2015	10:51	1	162	161	Overhead equipment	Overhead Transformer	Repair	Patrol/Test/Inspect	I
150712375	B00002	03/12/2015	8:16	03/12/2015	9:08	6	312	52	Unknown	Transformer Fuse	Replace - Same Size	Repair	I

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
150712444	N93260	03/12/2015	8:26	03/12/2015	9:31	54	3510	64	Overhead equipment	Recloser		Repair	III
5002525	X96543	03/12/2015	9:19	03/12/2015	10:47	1	87	87	Overhead equipment	Overhead Primary	Repair	Patrol/Test/Inspect	IV
150712572	A45001	03/12/2015	9:20	03/12/2015	9:49	1	29	29	Animal related	Transformer Fuse	Replace - Same Size		I
150712663	P98191	03/12/2015	9:44	03/12/2015	10:36	1	52	52	Overhead equipment	Connector	Repair	Repair	III
5002531	X02547	03/12/2015	10:08	03/12/2015	10:51	1	42	42	Animal related	Fuse	Repair		IV
150713118	S13546	03/12/2015	11:39	03/12/2015	11:56	1	17	16	Other				VI
150713317	S79771	03/12/2015	12:21	03/12/2015	14:00	659	65241	99	Tree related-tree broken				VI
150713505	S79771	03/12/2015	12:21	03/12/2015	12:52	886	27466	31	Tree related-tree broken	Tree			VI
150713287	V23530	03/12/2015	12:22	03/12/2015	13:56	1	94	94	Overhead equipment	Overhead Service	Repair		II
150713313	T04512	03/12/2015	12:25	03/12/2015	14:21	1	116	116	Transmission outage				VI
5002539	K67924	03/12/2015	12:26	03/12/2015	13:19	1	52	52	Overhead equipment	Fuse	Replace - Same Size		VI
5002541	Y61003	03/12/2015	12:52	03/12/2015	15:45	1	172	172	Tree related-tree broken	Overhead Secondary			IV
150713543	Y28597	03/12/2015	13:17	03/12/2015	15:30	1	133	133	Animal related	Transformer Fuse	Replace - Same Size		IV
150713569	U84534	03/12/2015	13:24	03/12/2015	14:07	1	43	42	Animal related	Fuse	Replace - Same Size		II
150713603	V14579	03/12/2015	13:35	03/12/2015	14:57	1	82	82	Animal related	Fuse	Replace - Same Size		II
5002545	R34920	03/12/2015	13:42	03/12/2015	17:42	1	239	239	Overhead equipment	Overhead Transformer	Replace - Same Size	Repair	VI
5002549	Y61003	03/12/2015	14:00	03/12/2015	14:07	9	57	6	Tree related-tree broken	Tree		Trim	IV
150713905	S34527	03/12/2015	14:05	03/12/2015	14:59	211	11394	53	Unknown				VI
150713760	S34527	03/12/2015	14:14	03/12/2015	16:55	1	161	161	Transmission outage				VI
150713881	J07173	03/12/2015	14:44	03/12/2015	16:21	1	97	97	Unknown	Transformer Fuse	Replace - Same Size		I
150713996	S34527	03/12/2015	15:14	03/12/2015	15:49	10	350	34	Overhead equipment	Fuse			VI
150714070	B08004	03/12/2015	15:17	03/12/2015	16:26	847	58443	68	Underground equipment				I
150714027	P69175	03/12/2015	15:21	03/12/2015	16:27	1	66	66	Overhead equipment	Overhead Service	Replace - Same Size		III
150714086	U16522	03/12/2015	15:36	03/12/2015	16:40	1	64	63	Overhead equipment	Fuse	Replace - Same Size	Repair	II
150714240	D92002	03/12/2015	16:44	03/12/2015	18:10	1	86	85	Overhead equipment	Fuse		Replace - Same Size	I
150714325	J61113	03/12/2015	17:26	03/12/2015	18:32	1	66	65	Overhead equipment	Connector			III
150714435	K76546	03/12/2015	18:31	03/12/2015	19:10	26	1014	39	Animal related	Fuse	Replace - Same Size		IV
150714735	U86500	03/12/2015	19:05	03/13/2015	0:03	1	298	297	Underground equipment	Underground Secondary	Repair		II
5002561	J84124	03/12/2015	19:15	03/13/2015	0:19	4	1214	303	Public	Underground Service	Disconnect	Repair	VI
150714975	K89143	03/12/2015	23:00	03/13/2015	2:30	1	210	209	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - New Size	III
150714981	J15302	03/12/2015	23:51	03/13/2015	1:00	1	69	68	Animal related	Transformer Fuse	Replace - Same Size	Replace - Same Size	I
150720099	R50910	03/13/2015	1:35	03/13/2015	4:00	1	145	145	Overhead equipment	Connector	Replace - Same Size		I
150722666	M25144	03/13/2015	4:32	03/13/2015	6:39	1	127	127	Animal related	Overhead Primary			IV
150722730	Y54591	03/13/2015	5:51	03/13/2015	7:14	3	249	82	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
150722679	Y54591	03/13/2015	5:51	03/13/2015	6:52	22	1342	60	Overhead equipment	Lightning Arrestor	Replace - Same Size		IV
150722709	S25551	03/13/2015	6:00	03/13/2015	9:00	142	25560	180	Tree related-tree broken	Overhead Primary	Repair	Repair	VI
150722824	341001	03/13/2015	7:42	03/13/2015	8:35	1	53	53	Tree related-tree broken	Tree	Patrol/Test/Inspect		VI
150722904	J50186	03/13/2015	8:19	03/13/2015	12:15	1	236	235	Underground equipment	Underground Transformer			III
150722958	T23528	03/13/2015	8:44	03/13/2015	9:43	1	59	59	Animal related	Transformer Fuse	Replace - New Size		VI
150723013	R33126	03/13/2015	9:08	03/13/2015	9:47	1	39	38	Unknown	Fuse	Replace - Same Size	Patrol/Test/Inspect	I
150752930	V45574	03/13/2015	10:25	03/13/2015	10:51	169	4394	25	Underground equipment	Underground Primary			II
150723284	V46552	03/13/2015	10:25	03/13/2015	10:51	297	7722	25	Underground equipment	Underground Primary			II
150723253		03/13/2015	10:27	03/13/2015	11:03	1	36	36	Underground equipment	Underground Primary	Switch/Reset		II
150723366	R20501	03/13/2015	10:54	03/13/2015	12:29	22	2090	94	Overhead equipment	Jumper	Repair		IV
150723390	U80564	03/13/2015	11:03	03/13/2015	11:55	2	104	52	Animal related	Transformer Fuse	Replace - Same Size		II
150723428	U68581	03/13/2015	11:18	03/13/2015	12:31	1	73	72	Animal related	Transformer Fuse	Replace - Same Size		II
150723453	T02534	03/13/2015	11:24	03/13/2015	13:30	43	5418	126	Overhead equipment	Other	Repair	Repair	VI
150723818	T13581	03/13/2015	12:11	03/13/2015	18:18	20	7340	366	Overhead equipment	Pole			VI
150723815	T13581	03/13/2015	12:11	03/13/2015	13:47	104	9984	95	Overhead equipment	Pole			VI
5002577	Q54908	03/13/2015	13:01	03/13/2015	13:46	1	44	44	Animal related	Transformer Fuse	Replace - Same Size		VI
150723710	Q15844	03/13/2015	13:04	03/13/2015	13:48	1	44	43	Animal related	Transformer Fuse	Replace - Same Size		V
5002581	P20930	03/13/2015	13:40	03/13/2015	14:39	1	58	58	Animal related	Fuse	Replace - Same Size		VI
5002583	J85161	03/13/2015	13:43	03/13/2015	16:14	4	601	150	Overhead equipment	Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
5002585	J85161	03/13/2015	14:00	03/13/2015	16:14	6	800	133	Overhead equipment	Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
150723879	H22349	03/13/2015	14:12	03/13/2015	15:31	1	79	78	Overhead equipment	Fuse	Replace - Same Size		V
5002587	Y69553	03/13/2015	14:37	03/13/2015	16:46	1	128	128	Tree related-tree broken	Overhead Service			IV

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
150724396	B84005	03/13/2015	15:19	03/13/2015	18:55	17	3672	216	Underground equipment	Underground Primary	Repair		I
150724067	B84005	03/13/2015	15:19	03/13/2015	18:30	28	5348	191	Underground equipment	Underground Primary	Switch/Reset		I
150724178	B84005	03/13/2015	15:30	03/13/2015	17:19	13	1417	108	Underground equipment	Underground Primary	Switch/Reset		I
150724107	B84005	03/13/2015	15:36	03/13/2015	17:19	1	103	103	Underground equipment	Underground Primary	Switch/Reset		I
150724117	P60170	03/13/2015	15:39	03/13/2015	16:26	1	47	46	Animal related	Transformer Fuse	Replace - Same Size		VI
150724208	B25002	03/13/2015	16:21	03/13/2015	17:12	1	51	50	Overhead equipment	Disconnect Switch	Repair		I
150724234	M40132	03/13/2015	16:35	03/13/2015	18:15	1	100	100	Underground equipment	Underground Service	Patrol/Test/Inspect	Repair	I
150724244	T08502	03/13/2015	16:43	03/13/2015	18:30	1	107	107	Overhead equipment	Transformer Fuse	Repair	Repair	VI
5002593	HB6251	03/13/2015	17:09	03/13/2015	17:32	1	22	22	Animal related	Fuse	Replace - Same Size		VI
5002595	J89126	03/13/2015	17:17	03/13/2015	17:28	1	10	10	Animal related	Fuse	Replace - Same Size		VI
150724299	A17026	03/13/2015	17:26	03/13/2015	18:38	1	72	71	Other	Meter			I
150724344	M04365	03/13/2015	17:33	03/13/2015	18:41	1	68	68	Tree related-tree broken	Overhead Service	Repair		V
5002605	R34920	03/13/2015	18:02	03/13/2015	23:05	77	23329	302	Overhead equipment	Overhead Primary	Patrol/Test/Inspect	Repair	VI
150724386	Z21564	03/13/2015	18:18	03/13/2015	19:45	1	87	87	Overhead equipment	Transformer Fuse	Repair	Replace - Same Size	IV
150724421	B84005	03/13/2015	18:47	03/13/2015	20:25	3	294	98	Underground equipment	Underground Primary	Repair		I
150724427	347003	03/13/2015	18:54	03/13/2015	22:11	2	394	197	Overhead equipment	Other			VI
5002617	K15205	03/13/2015	18:58	03/13/2015	21:00	6	731	121	Overhead equipment				VI
5002619	K01240	03/13/2015	19:55	03/13/2015	23:53	1	237	237	Underground equipment	Underground Service	Patrol/Test/Inspect	Repair	VI
150724786	A97002	03/13/2015	19:56	03/13/2015	23:40	1	224	223	Public	Underground Transformer	Replace - Same Size	Replace - Same Size	I
150724796	X30505	03/13/2015	20:19	03/13/2015	22:28	50	6450	129	Overhead equipment	Disconnect Switch	Replace - Same Size	Replace - Same Size	IV
5002623	J84146	03/13/2015	21:24	03/13/2015	22:23	1	58	58	Overhead equipment	Fuse	Replace - Same Size		VI
150724780	N35851	03/13/2015	21:25	03/14/2015	0:03	1	158	158	Animal related	Overhead Transformer	Disconnect		V
150725054	Q75145	03/13/2015	22:20	03/13/2015	23:19	1	59	59	Overhead equipment	Overhead Service	Replace - Same Size		VI
5002627	L59923	03/14/2015	0:35	03/14/2015	1:53	1	77	77	Tree related-tree broken	Overhead Service	Cut in Clear		VI
150730052	P44324	03/14/2015	3:29	03/14/2015	4:28	1	59	59	Unknown	Fuse	Replace - Same Size		I
150730066	S47575	03/14/2015	4:48	03/14/2015	7:45	1	177	177	Overhead equipment	Disconnect Switch	Replace - New Size	Patrol/Test/Inspect	VI
150730067	T04512	03/14/2015	5:03	03/14/2015	7:10	1	127	126	Tree related-tree contact	Tree	Remove		VI
5002631	N86227	03/14/2015	5:43	03/14/2015	10:47	8	2424	303	Tree related-tree broken	Overhead Primary	Patrol/Test/Inspect	Repair	VI
150730097	S27599	03/14/2015	7:20	03/14/2015	9:50	1	150	149	Unknown	Disconnect Switch	Replace - Same Size		VI
150730115	S27599	03/14/2015	8:09	03/14/2015	9:15	11	726	65	Overhead equipment	Disconnect Switch	Replace - Same Size		VI
150730116	X30505	03/14/2015	8:18	03/14/2015	9:15	1	57	56	Animal related	Transformer Fuse	Replace - Same Size		IV
150730158	S27599	03/14/2015	9:41	03/14/2015	15:45	11	4004	364	Weather				VI
150730192	D88001	03/14/2015	10:13	03/14/2015	15:11	1	298	298	Underground equipment	Underground Service	Patrol/Test/Inspect	Repair	I
150730215	303001	03/14/2015	10:42	03/14/2015	11:55	1	73	73	Overhead equipment	Connector	Replace - Same Size		VI
150730241	R60551	03/14/2015	11:30	03/14/2015	12:31	1	61	60	Animal related	Fuse	Replace - Same Size		IV
150730304	J80807	03/14/2015	11:46	03/14/2015	14:22	1	156	156	Underground equipment	Underground Connector	Repair	Repair	V
150730312	N67316	03/14/2015	11:59	03/14/2015	13:00	1	61	60	Overhead equipment	Overhead Secondary			I
150730313	X88510	03/14/2015	12:00	03/14/2015	13:25	1	85	85	Overhead equipment	Overhead Service	Repair		IV
150730327	Y93544	03/14/2015	12:19	03/14/2015	14:10	1	111	111	Tree related-tree broken	Overhead Service	Repair	Replace - Same Size	IV
150730338	N05170	03/14/2015	12:28	03/14/2015	13:10	1	42	42	Animal related	Fuse	Replace - Same Size		I
150730466	B77001	03/14/2015	12:32	03/14/2015	18:25	5	1765	352	Underground equipment	Underground Primary	Repair	Repair	I
150730542	B77001	03/14/2015	12:32	03/14/2015	20:47	3	1485	495	Underground equipment	Underground Transformer	Repair	Repair	I
150730344	B77001	03/14/2015	12:32	03/14/2015	16:10	48	10464	217	Underground equipment	Underground Primary	Replace - Same Size	Replace - Same Size	I
150730363	R07382	03/14/2015	13:07	03/14/2015	18:18	1	311	310	Underground equipment	Underground Service	Repair	Repair	I
150730373	R05115	03/14/2015	13:24	03/14/2015	14:55	1	91	91	Overhead equipment	Overhead Service	Reconnect	Patrol/Test/Inspect	I
150730421	J01119	03/14/2015	14:49	03/14/2015	15:25	1	36	36	Underground equipment	Underground Service	Repair		I
150730448	N93260	03/14/2015	15:16	03/14/2015	16:55	102	10098	98	Overhead equipment	Pole	Replace - Same Size		III
150730462	D96001	03/14/2015	16:00	03/14/2015	21:57	1	357	357	Overhead equipment	Overhead Service	Repair		I
150730470	J79304	03/14/2015	16:21	03/14/2015	17:45	1	84	84	Overhead equipment	Overhead Service			I
150730496	L23146	03/14/2015	17:38	03/14/2015	18:11	1	33	33	Animal related	Transformer Fuse	Replace - Same Size		III
150730525	302004	03/14/2015	18:16	03/14/2015	22:51	398	109450	274	Overhead equipment	Overhead Primary	Repair	Repair	VI
150730530	338003	03/14/2015	18:31	03/14/2015	23:00	1	269	269	Overhead equipment	Other			VI
150730531		03/14/2015	18:32	03/14/2015	23:00	1	268	268	Overhead equipment	Other			VI
150730535	302003	03/14/2015	18:32	03/14/2015	23:10	1	278	278	Overhead equipment				VI
150730582	Q80353	03/14/2015	20:44	03/14/2015	22:11	1	87	87	Overhead equipment	Overhead Service	Repair		V
150730598	S62522	03/14/2015	21:36	03/15/2015	0:48	1	192	191	Underground equipment	Underground Secondary			VI

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
150740115	P73157	03/15/2015	2:44	03/15/2015	3:47	1048	66024	62	Substation equipment	Overhead Primary		Replace - Same Size	VI
150740119	P73160	03/15/2015	2:44	03/15/2015	3:47	108	6804	62	Substation equipment				VI
150740122	P73182	03/15/2015	2:44	03/15/2015	3:47	567	35721	62	Substation equipment				VI
150740117	P73158	03/15/2015	2:45	03/15/2015	3:47	735	45570	61	Substation equipment				VI
150740096	J13108	03/15/2015	2:54	03/15/2015	5:45	1	171	171	Unknown	Fuse	Replace - Same Size	Patrol/Test/Inspect	I
150740123	J13108	03/15/2015	3:06	03/15/2015	5:45	1	159	159	Unknown	Fuse	Replace - Same Size	Patrol/Test/Inspect	I
150740138	S04512	03/15/2015	3:31	03/15/2015	9:40	15	5535	369	Overhead equipment	Overhead Primary	Replace - Same Size	Replace - Same Size	VI
150740129	S04512	03/15/2015	3:31	03/15/2015	6:20	37	6253	169	Overhead equipment	Overhead Primary	Replace - Same Size	Replace - Same Size	VI
150740132	S04512	03/15/2015	4:07	03/15/2015	6:57	1	170	169	Overhead equipment	Overhead Primary	Patrol/Test/Inspect	Repair	VI
150740137	M45212	03/15/2015	6:42	03/15/2015	8:30	1	108	107	Overhead equipment	Fuse	Replace - Same Size		IV
150740251	J15302	03/15/2015	8:11	03/15/2015	11:06	241	42175	175	Overhead equipment	Overhead Transformer	Repair	Patrol/Test/Inspect	I
150740193	D88001	03/15/2015	8:45	03/15/2015	13:27	1	282	281	Underground equipment	Underground Service	Patrol/Test/Inspect	Repair	I
150740243	303001	03/15/2015	9:55	03/15/2015	10:44	1	49	49	Overhead equipment	Connector	Replace - Same Size		VI
150740246	L73160	03/15/2015	9:58	03/15/2015	10:54	1	56	56	Overhead equipment	Overhead Secondary	Repair		IV
5002685	J83138	03/15/2015	10:20	03/15/2015	14:47	1	266	266	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	VI
150740256	R33126	03/15/2015	10:21	03/15/2015	11:22	1	61	60	Animal related	Transformer Fuse	Replace - Same Size	Patrol/Test/Inspect	I
150740263	X92508	03/15/2015	10:33	03/15/2015	11:50	1	77	76	Animal related	Transformer Fuse	Repair	Replace - Same Size	IV
150740266	D69003	03/15/2015	10:35	03/15/2015	14:39	1	244	244	Underground equipment	Underground Service	Replace - Same Size	Replace - Same Size	I
150740276	P17107	03/15/2015	10:57	03/15/2015	12:02	1	65	64	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
150740296	332002	03/15/2015	11:38	03/15/2015	12:40	1	62	62	Public	Overhead Service	Repair		VI
150740297	M47802	03/15/2015	11:40	03/15/2015	13:25	1	105	105	Overhead equipment	Overhead Secondary	Repair	Repair	V
150740474	S93507	03/15/2015	13:15	03/15/2015	16:09	1	174	174	Animal related	Transformer Fuse	Repair	Replace - Same Size	VI
150740482	F03003	03/15/2015	13:34	03/16/2015	7:50	1	1096	1095	Underground equipment	Underground Secondary			III
5002689	N86225	03/15/2015	14:08	03/15/2015	16:00	5	561	112	Overhead equipment	Overhead Secondary	Patrol/Test/Inspect	Repair	VI
150740542	D55002	03/15/2015	14:24	03/15/2015	16:06	1	102	101	Underground equipment	Underground Primary	Replace - Same Size	Replace - Same Size	I
150740572	S52515	03/15/2015	15:55	03/15/2015	16:45	1	50	49	Overhead equipment	Transformer Fuse	Replace - Same Size		VI
150740578	V20502	03/15/2015	16:09	03/15/2015	17:34	1	85	84	Animal related	Transformer Fuse			II
150740621	S43512	03/15/2015	17:25	03/15/2015	18:46	61	4941	81	Overhead equipment	Transformer Fuse	Repair	Replace - Same Size	VI
150740624	312112	03/15/2015	18:09	03/15/2015	21:15	1	186	185	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	V
150740644	M61302	03/15/2015	18:47	03/16/2015	0:30	268	91924	343	Substation equipment	Disconnect Switch	Patrol/Test/Inspect	Replace - Same Size	V
150740651	S86582	03/15/2015	19:05	03/16/2015	6:25	3	2040	679	Public	Pole	Replace - Same Size	Replace - Same Size	VI
150740656	S86582	03/15/2015	19:05	03/15/2015	22:11	16	2976	185	Public	Pole	Replace - Same Size	Replace - Same Size	VI
150740660	N91255	03/15/2015	19:23	03/15/2015	20:10	6	282	47	Overhead equipment	Transformer Fuse	Replace - Same Size		III
150740663	C37001	03/15/2015	19:29	03/15/2015	20:31	2	124	62	Overhead equipment	Disconnect Switch	Repair	Replace - Same Size	III
150740681	N15850	03/15/2015	20:19	03/15/2015	20:57	1	38	37	Overhead equipment	Transformer Fuse	Replace - Same Size		V
5002691	X22001	03/15/2015	20:27	03/15/2015	21:43	5	379	75	Overhead equipment	Transformer Fuse	Repair	Patrol/Test/Inspect	IV
150740716	B73001	03/15/2015	20:38	03/16/2015	1:25	1	287	287	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
150752372	V23530	03/16/2015	5:35	03/16/2015	6:52	2	154	76	Animal related	Transformer Fuse	Repair	Replace - Same Size	II
150752376	R04409	03/16/2015	6:01	03/16/2015	7:50	1	109	108	Animal related	Fuse	Replace - Same Size		V
150752423	K31124	03/16/2015	6:56	03/16/2015	9:30	1	154	153	Underground equipment	Underground Secondary	Repair	Repair	I
150752520	S25552	03/16/2015	7:39	03/16/2015	13:20	1	341	341	Underground equipment	Underground Secondary	Patrol/Test/Inspect	Repair	VI
150752586		03/16/2015	8:08	03/16/2015	10:24	1	136	136	Overhead equipment	Fuse	Replace - Same Size		V
5002717	K67924	03/16/2015	8:16	03/16/2015	9:32	1	75	75	Overhead equipment	Fuse	Replace - Same Size		VI
5002719	K01240	03/16/2015	8:18	03/16/2015	9:32	1	73	73	Underground equipment	Overhead Service	Repair	Repair	VI
5002721	Z57516	03/16/2015	8:39	03/16/2015	10:13	3	279	93	Tree related-tree broken	Transformer Fuse			IV
5002725	K58213	03/16/2015	8:58	03/16/2015	13:59	1	301	301	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	VI
150752802	P26283	03/16/2015	9:02	03/16/2015	11:24	1	142	142	Animal related	Transformer Fuse	Repair		I
150752806	L90358	03/16/2015	9:03	03/16/2015	9:41	1	38	37	Overhead equipment	Fuse	Replace - Same Size		V
5002729	K32916	03/16/2015	9:06	03/16/2015	10:18	1	71	71	Animal related	Fuse	Replace - Same Size		VI
150752837	N48101	03/16/2015	9:10	03/16/2015	9:40	1	30	30	Animal related	Transformer Fuse	Replace - Same Size		II
150752905	S03530	03/16/2015	9:22	03/16/2015	10:15	1	53	53	Overhead equipment	Overhead Service	Repair	Repair	VI
5002757	Y06544	03/16/2015	9:25	03/16/2015	12:20	3	523	174	Public	Overhead Service	Repair	Repair	IV
150752941	C10002	03/16/2015	9:32	03/16/2015	10:03	1	31	30	Overhead equipment	Fuse	Replace - Same Size		III
5002745	HC9327	03/16/2015	10:06	03/16/2015	10:50	1	43	43	Animal related	Transformer Fuse			VI
150753357	M61302	03/16/2015	10:28	03/16/2015	10:35	81	567	6	Overhead equipment				V
150753488	M61302	03/16/2015	10:51	03/16/2015	18:54	1	483	483	Underground equipment	Underground Transformer	Replace - Same Size	Replace - Same Size	V

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
150753599	U60559	03/16/2015	10:53	03/16/2015	11:23	479	14370	30	Public	Substation Breaker	Switch/Reset		II
5002779	L59933	03/16/2015	11:36	03/16/2015	18:06	1	389	389	Underground equipment	Underground Service		Repair	VI
5002783	J82116	03/16/2015	12:20	03/16/2015	13:19	1	58	58	Overhead equipment	Connector	Repair		VI
150753919	U13551	03/16/2015	12:21	03/16/2015	17:07	1	286	285	Underground equipment	Underground Primary	Patrol/Test/Inspect	Patrol/Test/Inspect	II
150754145	B93001	03/16/2015	13:03	03/16/2015	14:04	1	61	60	Unknown	Fuse	Replace - Same Size		I
150754173	B21002	03/16/2015	13:11	03/16/2015	17:33	1	262	261	Underground equipment	Underground Primary	Patrol/Test/Inspect	Reconnect	I
150754732	B73002	03/16/2015	13:11	03/16/2015	17:32	6	1566	261	Underground equipment	Underground Connector	Replace - Same Size	Repair	I
150754187	B73002	03/16/2015	13:11	03/16/2015	15:20	8	1032	129	Underground equipment	Underground Connector	Replace - Same Size		I
150754341	S61575	03/16/2015	13:43	03/16/2015	17:52	1	249	248	Underground equipment	Underground Primary	Repair		VI
150754575	Z30584	03/16/2015	14:37	03/16/2015	15:00	1	23	23	Overhead equipment	Transformer Fuse	Repair		IV
150754579	S16501	03/16/2015	14:37	03/16/2015	15:17	1	40	40	Unknown	Overhead Service	Replace - Same Size		VI
150754587	M18131	03/16/2015	14:39	03/16/2015	18:40	1	241	240	Tree related-tree contact	Pole	Repair	Replace - Same Size	III
150754596	B68002	03/16/2015	14:42	03/16/2015	15:01	1	19	18	Overhead equipment	Fuse	Replace - Same Size		III
150754688	J01118	03/16/2015	15:08	03/16/2015	16:12	1	64	63	Unknown	Transformer Fuse	Replace - Same Size		I
150754709	N50332	03/16/2015	15:14	03/16/2015	18:50	4	864	215	Overhead equipment	Overhead Transformer	Replace - Same Size	Replace - Same Size	II
150754753	S43511	03/16/2015	15:22	03/16/2015	16:56	78	7332	94	Overhead equipment	Overhead Primary	Replace - Same Size		VI
150754768	P47120	03/16/2015	15:28	03/16/2015	17:00	1	92	92	Unknown	Transformer Fuse	Replace - Same Size		I
150754866	D32212	03/16/2015	15:43	03/16/2015	18:56	114	22002	193	Unknown	Jumper	Repair	Repair	I
150754836	S68512	03/16/2015	15:49	03/16/2015	18:10	1	141	140	Overhead equipment				VI
150754913	N67315	03/16/2015	16:14	03/16/2015	17:39	3	255	85	Overhead equipment	Transformer Fuse	Replace - Same Size	Replace - Same Size	I
150755063	M07236	03/16/2015	17:19	03/16/2015	19:00	18	1818	100	Overhead equipment	Jumper	Repair		III
150755271	S25551	03/16/2015	17:56	03/16/2015	18:38	1	42	42	Overhead equipment	Meter			VI
5002813	Y66556	03/16/2015	18:25	03/16/2015	21:00	4	618	154	Overhead equipment	Overhead Transformer	Repair		IV
150755318	M18131	03/16/2015	18:42	03/16/2015	19:45	1	63	62	Underground equipment	Underground Service		Repair	III
150755723	P19395	03/16/2015	20:04	03/17/2015	2:20	1	376	375	Overhead equipment	Overhead Transformer	Disconnect	Replace - New Size	V
150755742		03/16/2015	20:38	03/17/2015	3:00	2	764	381	Public	Jumper	Patrol/Test/Inspect	Repair	V
150755748	L79159	03/16/2015	20:47	03/16/2015	22:03	3	228	75	Animal related	Transformer Fuse	Replace - Same Size		IV
150755812	C10002	03/16/2015	21:48	03/17/2015	0:05	1	137	136	Underground equipment	Underground Primary	Repair		III
150762501	P60170	03/17/2015	7:08	03/17/2015	7:56	1	48	47	Tree related-tree broken	Overhead Secondary	Repair	Repair	VI
150762534	B73002	03/17/2015	7:24	03/17/2015	8:32	1	68	68	Overhead equipment	Connector	Replace - Same Size		I
150762601	C70002	03/17/2015	7:55	03/17/2015	9:24	1	89	89	Animal related	Fuse	Replace - Same Size		III
150762623	Q06144	03/17/2015	8:05	03/17/2015	9:03	1	58	58	Overhead equipment	Fuse			IV
150762631	B73001	03/17/2015	8:07	03/17/2015	9:23	1	76	76	Other				I
5002823	Y96564	03/17/2015	8:18	03/17/2015	10:00	1	101	101	Tree related-tree contact	Overhead Service	Replace - New Size		IV
150762712	S28552	03/17/2015	8:34	03/17/2015	10:30	1	116	116	Overhead equipment	Jumper	Replace - New Size		VI
5002825	K01240	03/17/2015	8:35	03/17/2015	9:35	9	538	59	Overhead equipment	Fuse	Repair	Repair	VI
150763129	R20501	03/17/2015	8:42	03/17/2015	10:10	185	16280	87	Overhead equipment	Jumper	Repair		IV
5002837	X16-XTR1	03/17/2015	8:46	03/17/2015	9:02	85	1417	16	Transmission outage				IV
150762772	X64501	03/17/2015	8:48	03/17/2015	14:24	1	336	335	Overhead equipment	Overhead Transformer	Replace - Same Size		IV
5002827	X16511	03/17/2015	8:56	03/17/2015	9:08	1	11	11	Transmission outage	Substation Misc.			IV
150762942	Y04504	03/17/2015	8:58	03/17/2015	9:54	11	616	55	Tree related-tree broken	Fuse	Replace - Same Size		IV
5002829	X16511	03/17/2015	9:01	03/17/2015	9:13	1	11	11	Transmission outage	Substation Misc.			IV
5002831	R49265	03/17/2015	9:01	03/17/2015	9:48	1	46	46	Overhead equipment	Disconnect Switch	Repair		VI
5002833	X16511	03/17/2015	9:03	03/17/2015	9:10	1	6	6	Transmission outage	Substation Misc.			IV
150762856	X37001	03/17/2015	9:04	03/17/2015	10:38	1	94	94	Overhead equipment	Jumper	Repair		IV
150762903	B65003	03/17/2015	9:14	03/17/2015	10:15	1	61	60	Tree related-tree contact	Overhead Service		Replace - Same Size	I
150762907		03/17/2015	9:15	03/17/2015	10:28	1	73	73	Underground equipment	Underground Transformer	Patrol/Test/Inspect		V
150763016	P62138	03/17/2015	9:35	03/17/2015	9:57	1	22	21	Other				VI
150763034	N67309	03/17/2015	9:40	03/17/2015	11:10	1	90	90	Overhead equipment	Transformer Fuse	Replace - Same Size		I
150763064	K74162	03/17/2015	9:47	03/17/2015	11:30	1	103	103	Overhead equipment	Jumper		Repair	IV
150763079	B19002	03/17/2015	9:48	03/17/2015	13:50	1	242	242	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Repair	I
150763094	X88507	03/17/2015	9:50	03/17/2015	14:31	1	281	281	Tree related-tree broken	Overhead Service	Repair		IV
150763184	L08225	03/17/2015	10:03	03/17/2015	10:30	607	16389	27	Substation equipment	Substation Misc.	Switch/Reset		III
150763352	Y39515	03/17/2015	10:04	03/17/2015	13:25	31	6231	201	Tree related-tree broken	Overhead Primary	Repair		IV
150763190	U12540	03/17/2015	10:07	03/17/2015	11:22	1	75	75	Animal related	Transformer Fuse	Repair	Replace - Same Size	II
150763197	Y45503	03/17/2015	10:08	03/17/2015	11:41	1	93	92	Overhead equipment	Disconnect Switch	Repair	Replace - Same Size	IV

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5002843	N22296	03/17/2015	10:09	03/17/2015	11:08	1	58	58	Animal related	Fuse			VI
150763225	L35283	03/17/2015	10:16	03/17/2015	10:30	1	14	14	Substation equipment	Substation Misc.	Switch/Reset		III
150763248	R33126	03/17/2015	10:21	03/17/2015	12:18	1	117	116	Overhead equipment	Transformer Fuse	Replace - Same Size	Patrol/Test/Inspect	I
150763252	L08225	03/17/2015	10:21	03/17/2015	10:30	1	9	8	Substation equipment	Substation Misc.	Switch/Reset		III
150763339	L70128	03/17/2015	10:41	03/17/2015	13:35	1	174	173	Overhead equipment	Overhead Transformer		Repair	IV
150763351	M26161	03/17/2015	10:43	03/17/2015	11:36	1	53	52	Unknown	Transformer Fuse	Replace - Same Size		III
150763520	L12127	03/17/2015	11:16	03/17/2015	12:07	83	4233	50	Animal related	Fuse	Replace - Same Size		III
150763748	Y04504	03/17/2015	12:08	03/17/2015	13:51	11	1133	102	Tree related-tree broken	Overhead Primary	Repair		IV
150763956	K19115	03/17/2015	12:50	03/17/2015	13:25	17	595	35	Overhead equipment	Fuse	Repair	Repair	VI
150764152	K19115	03/17/2015	13:31	03/17/2015	14:45	5	370	74	Overhead equipment	Overhead Transformer			VI
5002855	Y06544	03/17/2015	13:31	03/17/2015	15:06	1	94	94	Overhead equipment	Jumper	Repair	Repair	IV
150764246	X30505	03/17/2015	13:53	03/17/2015	14:51	1	58	58	Tree related-tree contact	Overhead Service			IV
150764379	C15002	03/17/2015	14:23	03/17/2015	15:12	1	49	48	Animal related	Fuse	Replace - Same Size		III
150764399	V03562	03/17/2015	14:30	03/17/2015	15:55	2	170	85	Overhead equipment	Transformer Fuse	Replace - Same Size		II
150764434	B81003	03/17/2015	14:43	03/17/2015	15:41	1	58	58	Other	Fuse	Replace - Same Size	Replace - Same Size	I
150764505	Q91175	03/17/2015	15:04	03/17/2015	16:41	1	97	97	Overhead equipment	Overhead Service	Tie/Tighten		I
150764516	Y55789	03/17/2015	15:14	03/17/2015	16:48	1599	150306	93	Substation equipment	Substation Misc.	Switch/Reset		IV
5002867	Q64919	03/17/2015	15:58	03/17/2015	20:13	1	254	254	Underground equipment	Underground Service	Replace - Same Size	Repair	VI
150764811	Y97512	03/17/2015	16:55	03/17/2015	18:38	1	103	103	Overhead equipment	Overhead Service	Repair		IV
150764818	D96001	03/17/2015	16:57	03/17/2015	17:54	1	57	56	Animal related	Fuse	Replace - Same Size		I
150764982	D36001	03/17/2015	17:50	03/17/2015	18:40	1	50	50	Overhead equipment	Overhead Service	Repair		I
150764992	B76003	03/17/2015	17:56	03/17/2015	19:12	1	76	76	Animal related	Fuse	Replace - Same Size		I
150765409	P73157	03/17/2015	19:19	03/17/2015	20:47	1	88	88	Overhead equipment	Overhead Secondary		Replace - Same Size	VI
150765482	R95520	03/17/2015	19:23	03/18/2015	1:00	50	16850	336	Public	Overhead Primary	Repair		I
5002897	Y63527	03/17/2015	19:35	03/17/2015	21:14	530	52814	99	Overhead equipment				IV
150765479	325010	03/17/2015	20:21	03/17/2015	22:15	1	114	114	Underground equipment	Underground Service	Repair	Replace - New Size	VI
150765635	T06538	03/17/2015	21:50	03/17/2015	23:05	1	75	75	Overhead equipment	Overhead Service	Repair	Repair	VI
5002933	X62031	03/18/2015	6:01	03/18/2015	6:48	1	46	46	Intentional	Meter			IV
150772513	K74164	03/18/2015	7:28	03/18/2015	8:35	1	67	66	Overhead equipment	Connector	Replace - New Size		IV
150772594	L00133	03/18/2015	7:59	03/18/2015	9:16	1	77	76	Underground equipment	Underground Service		Repair	III
5002935	N22296	03/18/2015	8:10	03/18/2015	12:05	1	234	234	Overhead equipment	Overhead Transformer		Repair	VI
150772709	R84148	03/18/2015	8:48	03/18/2015	9:25	1	37	36	Overhead equipment	Connector	Tie/Tighten		I
150772815	M12151	03/18/2015	9:08	03/18/2015	12:02	1	174	173	Overhead equipment	Disconnect Switch	Replace - Same Size	Repair	VI
150772894	N70331	03/18/2015	9:27	03/18/2015	9:53	1	26	26	Unknown	Transformer Fuse	Replace - Same Size		I
150772940	E10002	03/18/2015	9:35	03/18/2015	10:40	1	65	65	Overhead equipment	Other	Repair	Patrol/Test/Inspect	III
150773048	Q93522	03/18/2015	9:38	03/18/2015	11:17	33	3267	98	Overhead equipment	Fuse	Patrol/Test/Inspect	Repair	I
150773099	S20555	03/18/2015	10:09	03/18/2015	11:47	6	588	97	Overhead equipment	Connector	Patrol/Test/Inspect	Repair	VI
150773127	S19551	03/18/2015	10:14	03/18/2015	17:47	1	453	452	Underground equipment	Underground Secondary		Replace - Same Size	VI
150773130	D92002	03/18/2015	10:15	03/18/2015	11:33	9	702	77	Animal related	Fuse	Replace - Same Size		I
150773169	B58002	03/18/2015	10:24	03/18/2015	12:13	1	109	108	Animal related	Fuse	Replace - Same Size		I
150773441	Q14390	03/18/2015	10:58	03/18/2015	13:01	21	2583	123	Unknown	Fuse	Replace - Same Size	Replace - Same Size	I
150773317	R66470	03/18/2015	11:00	03/18/2015	11:19	6	114	18	Animal related	Transformer Fuse	Replace - Same Size		IV
150773560	R04409	03/18/2015	12:04	03/18/2015	13:00	1	56	55	Animal related	Fuse	Replace - Same Size		V
150773658	K91117	03/18/2015	12:36	03/18/2015	13:52	1	76	75	Tree related-tree broken	Overhead Service	Repair		III
150773776	D16001	03/18/2015	13:01	03/18/2015	13:50	49	2401	49	Animal related	Fuse	Replace - Same Size		I
150773807	B84006	03/18/2015	13:15	03/18/2015	14:13	1	58	58	Animal related	Fuse	Replace - Same Size		I
150774517	V26225	03/18/2015	13:49	03/18/2015	15:25	2940	282240	95	Overhead equipment	Overhead Primary	Replace - New Size		II
150774545	V26276	03/18/2015	13:49	03/18/2015	15:25	1316	126336	95	Overhead equipment	Overhead Primary	Switch/Reset		II
150774004	P62138	03/18/2015	13:59	03/18/2015	14:57	47	2726	58	Overhead equipment	Fuse	Replace - Same Size		VI
150774006	P62138	03/18/2015	14:01	03/18/2015	14:52	1	51	50	Overhead equipment	Transformer Fuse	Replace - Same Size		VI
5002957	J18268	03/18/2015	14:19	03/18/2015	15:06	3	140	46	Animal related	Transformer Fuse	Replace - Same Size		VI
150774094	V44504	03/18/2015	14:23	03/18/2015	15:32	1	69	68	Animal related	Transformer Fuse			II
150774535	V26290	03/18/2015	14:39	03/18/2015	15:25	2501	115046	45	Overhead equipment	Overhead Primary	Switch/Reset		II
150774520	V28233	03/18/2015	14:39	03/18/2015	16:33	806	91884	113	Overhead equipment	Overhead Primary	Switch/Reset		II
150774313		03/18/2015	14:45	03/18/2015	16:52	3	381	126	Overhead equipment				II
5002963	L59929	03/18/2015	14:50	03/18/2015	19:07	1	256	256	Underground equipment	Underground Service		Repair	VI

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5002965	J82106	03/18/2015	14:53	03/18/2015	16:49	1	115	115	Tree related-tree contact	Overhead Service	Replace - New Size		VI
150774598	B93003	03/18/2015	14:59	03/18/2015	16:03	1	64	63	Animal related	Transformer Fuse	Replace - Same Size		I
150774735	V37509	03/18/2015	15:31	03/18/2015	16:13	1	42	42	Overhead equipment				II
150774758	V39002	03/18/2015	15:34	03/18/2015	16:27	1	53	53	Overhead equipment				II
150774760	V37509	03/18/2015	15:35	03/18/2015	16:15	1	40	40	Overhead equipment				II
5002969	X60597	03/18/2015	15:51	03/18/2015	17:15	3	249	83	Overhead equipment	Disconnect Switch	Replace - Same Size		IV
150774915	Y20002	03/18/2015	16:18	03/18/2015	17:57	1	99	98	Overhead equipment	Jumper	Repair		IV
150775016	H01192	03/18/2015	16:49	03/18/2015	17:37	14	672	47	Public	Overhead Primary	Repair		III
150775045	H01192	03/18/2015	17:02	03/18/2015	18:26	1	84	84	Public	Overhead Primary	Repair		III
150775072	M48814	03/18/2015	17:23	03/18/2015	18:50	1	87	86	Overhead equipment	Overhead Secondary			V
150775081	M09144	03/18/2015	17:28	03/18/2015	18:09	1	41	40	Tree related-tree broken	Fuse	Replace - Same Size	Repair	VI
150775067	A29002	03/18/2015	17:55	03/18/2015	21:00	2	370	184	Overhead equipment	Crossarm	Repair		I
150775143	L24124	03/18/2015	18:00	03/18/2015	21:10	44	8360	190	Underground equipment	Underground Primary		Repair	III
150775202	Y54560	03/18/2015	18:55	03/18/2015	19:40	1	45	45	Overhead equipment	Fuse	Replace - Same Size		IV
150775248	K76542	03/18/2015	19:49	03/18/2015	20:48	11	649	59	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
150781154	U10525	03/19/2015	3:21	03/19/2015	5:30	2	258	129	Overhead equipment	Transformer Fuse	Replace - Same Size		II
150782524	Y07576	03/19/2015	7:29	03/19/2015	10:38	1	189	189	Underground equipment	Underground Service	Repair	Replace - Same Size	IV
150782588	B82001	03/19/2015	8:03	03/19/2015	10:00	1	117	116	Overhead equipment	Connector	Replace - Same Size	Replace - Same Size	I
5002997	R49261	03/19/2015	8:09	03/19/2015	11:43	56	11981	213	Overhead equipment	Overhead Primary	Patrol/Test/Inspect	Repair	VI
150782672	D70003	03/19/2015	8:31	03/19/2015	11:27	9	1584	175	Underground equipment	Underground Primary	Patrol/Test/Inspect		I
150782722	S61530	03/19/2015	8:44	03/19/2015	10:40	19	2204	116	Underground equipment	Underground Transformer		Replace - Same Size	VI
150782810	S86582	03/19/2015	9:13	03/19/2015	11:00	1	107	107	Overhead equipment	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
150782831	B80003	03/19/2015	9:17	03/19/2015	14:45	1	328	328	Underground equipment	Underground Service	Patrol/Test/Inspect	Repair	I
150782862	U41517	03/19/2015	9:30	03/19/2015	10:11	1	41	40	Jurisdictional	Meter	Reconnect		II
150782899	U33586	03/19/2015	9:41	03/19/2015	10:07	1	26	26	Overhead equipment	Transformer Fuse	Repair	Repair	II
150783010	310122	03/19/2015	10:07	03/19/2015	10:57	34	1700	50	Animal related	Fuse	Replace - Same Size		V
5003017	R49261	03/19/2015	10:34	03/19/2015	12:07	1	93	93	Overhead equipment				VI
150783268	K71821	03/19/2015	11:16	03/19/2015	11:55	10	390	39	Animal related	Transformer Fuse	Replace - Same Size		IV
5003031	X60596	03/19/2015	12:34	03/19/2015	16:52	1	258	258	Underground equipment	Underground Primary	Repair	Replace - Same Size	IV
5003033	J89126	03/19/2015	12:36	03/19/2015	13:24	1	47	47	Overhead equipment	Transformer Fuse			VI
150783565	D89001	03/19/2015	12:37	03/19/2015	13:25	1120	53760	48	Animal related	Animal Guard			I
150783724	U68581	03/19/2015	13:24	03/19/2015	14:05	1	41	40	Animal related	Transformer Fuse	Replace - Same Size		II
150783732	S60581	03/19/2015	13:25	03/19/2015	14:10	1	45	45	Other				VI
150783794	B44002	03/19/2015	13:41	03/19/2015	15:04	1	83	82	Overhead equipment	Connector	Replace - Same Size		I
150784014	A42005	03/19/2015	14:06	03/19/2015	19:22	60	18960	315	Overhead equipment	Other		Repair	I
150783934	L00134	03/19/2015	14:12	03/19/2015	14:35	48	1104	23	Animal related	Fuse	Replace - Same Size		III
150783953	A49002	03/19/2015	14:16	03/19/2015	17:00	15	2460	164	Overhead equipment	Connector	Repair		I
150784010	K27153	03/19/2015	14:30	03/19/2015	15:19	7	343	49	Animal related	Transformer Fuse	Replace - Same Size		VI
150784028	M78325	03/19/2015	14:34	03/19/2015	15:31	1	57	56	Animal related	Transformer Fuse	Repair		V
150784071	V80506	03/19/2015	14:44	03/19/2015	17:00	1	136	136	Overhead equipment	Connector	Repair	Repair	II
150784115	T14575	03/19/2015	14:55	03/19/2015	15:57	1	62	61	Overhead equipment	Connector	Patrol/Test/Inspect	Repair	VI
150784114	P62138	03/19/2015	14:55	03/19/2015	15:50	1	55	54	Animal related	Transformer Fuse	Replace - Same Size		VI
150784279	U11531	03/19/2015	15:45	03/19/2015	18:49	1	184	184	Underground equipment	Underground Service	Repair	Repair	II
150784297	S13549	03/19/2015	15:55	03/20/2015	5:32	1	817	817	Underground equipment	Underground Secondary	Patrol/Test/Inspect	Repair	VI
5003043	R50910	03/19/2015	17:54	03/19/2015	18:57	1	62	62	Overhead equipment	Overhead Primary	Repair		I
150784602	D70006	03/19/2015	18:43	03/20/2015	1:55	1	432	431	Underground equipment	Underground Service	Repair	Repair	I
150785014	U11531	03/19/2015	19:40	03/20/2015	0:19	782	218178	278	Overhead equipment	Substation Misc.	Replace - Same Size	Replace - Same Size	II
5003045	J99141	03/19/2015	20:07	03/19/2015	21:15	1	67	67	Animal related	Fuse	Repair		VI
150785057	Y55594	03/19/2015	21:14	03/20/2015	0:01	1	167	166	Public	Pole	Replace - Same Size	Repair	IV
150785058	HA5432	03/19/2015	21:15	03/20/2015	4:05	1	410	410	Overhead equipment	Overhead Secondary	Replace - New Size	Replace - New Size	V
150785078	L68111	03/19/2015	22:58	03/20/2015	1:16	1	138	137	Overhead equipment	Overhead Service	Replace - New Size		IV
150792506	F03004	03/20/2015	3:00	03/20/2015	8:59	13	4667	358	Underground equipment	Underground Primary			III
150792505	F03004	03/20/2015	3:00	03/20/2015	4:30	6	540	90	Underground equipment	Underground Primary	Switch/Reset		III
150792477	D92002	03/20/2015	3:17	03/20/2015	6:15	1	178	177	Overhead equipment	Crossarm	Patrol/Test/Inspect	Replace - Urgent	I
150792486	E10002	03/20/2015	4:05	03/20/2015	6:58	1	173	172	Overhead equipment	Lightning Arrestor	Replace - Same Size		III
150792542	310124	03/20/2015	6:44	03/20/2015	8:38	45	5130	114	Animal related	Fuse	Replace - Same Size		V

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
150792621	M41182	03/20/2015	7:38	03/20/2015	14:00	1	382	381	Underground equipment	Underground Service	Replace - Urgent	Patrol/Test/Inspect	I
150793081	D36002	03/20/2015	8:25	03/20/2015	11:55	29	6090	210	Underground equipment	Underground Transformer	Replace - Same Size	Repair	I
150792925	J12166	03/20/2015	9:21	03/20/2015	9:52	1	31	31	Animal related	Overhead Transformer	Repair		III
150792993	P05825	03/20/2015	9:45	03/20/2015	10:40	5	275	55	Animal related	Transformer Fuse	Replace - Same Size		V
150793164	S42579	03/20/2015	10:31	03/20/2015	11:10	1	39	39	Overhead equipment	Transformer Fuse	Replace - Same Size		VI
150793240	Y04504	03/20/2015	10:50	03/20/2015	11:51	1	61	60	Animal related	Transformer Fuse	Replace - Same Size		IV
150793283	J67132	03/20/2015	11:03	03/20/2015	12:40	1	97	97	Overhead equipment	Other			III
150793464	HA5432	03/20/2015	12:06	03/20/2015	12:52	1	46	46	Animal related	Fuse	Replace - Same Size		V
150793532	S42579	03/20/2015	12:32	03/20/2015	13:37	1	65	65	Overhead equipment	Overhead Service	Repair	Replace - Same Size	VI
5003067	P26283	03/20/2015	12:36	03/20/2015	14:16	1	99	99	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	I
150793594	D32212	03/20/2015	12:56	03/20/2015	14:33	1	97	96	Overhead equipment	Connector	Replace - Same Size	Replace - Same Size	I
150793649	Y20522	03/20/2015	13:08	03/20/2015	17:33	1	265	264	Underground equipment	Underground Service	Repair	Repair	IV
150793740	H14343	03/20/2015	13:31	03/20/2015	15:19	1	108	107	Tree related-tree broken	Overhead Service	Repair		V
150793924	R41132	03/20/2015	14:20	03/20/2015	14:55	1	35	35	Animal related	Transformer Fuse	Replace - Same Size		VI
150793955	M25143	03/20/2015	14:28	03/20/2015	16:38	3	390	130	Animal related	Fuse	Replace - Same Size		IV
150793991	S15559	03/20/2015	14:34	03/20/2015	15:55	1	81	81	Other				VI
150794251	K71812	03/20/2015	16:14	03/20/2015	20:42	67	17956	268	Underground equipment	Underground Primary			IV
150794304	K28183	03/20/2015	17:02	03/20/2015	17:25	1	23	23	Animal related	Transformer Fuse	Replace - Same Size		III
150794411	S41563	03/20/2015	18:41	03/20/2015	21:07	1	146	146	Overhead equipment	Overhead Secondary	Repair	Replace - Same Size	VI
5003089	P26280	03/20/2015	19:37	03/20/2015	21:30	1	112	112	Overhead equipment	Fuse	Replace - Same Size		I
150794826	X67508	03/20/2015	21:40	03/21/2015	3:27	1	347	346	Overhead equipment	Crossarm	Patrol/Test/Inspect	Replace - Same Size	IV
150794813	X67508	03/20/2015	21:40	03/20/2015	23:05	1	85	84	Overhead equipment	Substation Breaker	Switch/Reset		IV
5003095	K01240	03/21/2015	5:25	03/21/2015	7:40	29	3888	134	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	VI
5003097	Q24311	03/21/2015	5:35	03/21/2015	7:44	1	128	128	Underground equipment	Underground Primary	Patrol/Test/Inspect	Replace - Same Size	VI
150800123	H11340	03/21/2015	7:59	03/21/2015	9:05	18	1188	65	Animal related	Fuse	Replace - Same Size		V
5003105	K01239	03/21/2015	8:06	03/21/2015	9:10	21	1339	63	Overhead equipment	Fuse	Replace - Same Size		VI
150800133	H11340	03/21/2015	8:11	03/21/2015	9:34	1	83	82	Animal related	Transformer Fuse	Replace - Same Size		V
5003107	K58210	03/21/2015	8:12	03/21/2015	9:35	57	4691	82	Animal related	Fuse	Replace - Same Size		VI
150800148	P52305	03/21/2015	8:28	03/21/2015	19:03	1	635	634	Underground equipment	Underground Service	Repair	Repair	IV
150800163	J63173	03/21/2015	8:44	03/21/2015	12:46	1	242	242	Underground equipment	Underground Service			III
150800247	B10001	03/21/2015	9:58	03/21/2015	10:50	1	52	52	Animal related	Transformer Fuse	Replace - Same Size		I
150800320	S93507	03/21/2015	11:04	03/21/2015	17:09	1	365	365	Overhead equipment	Connector	Replace - Same Size		VI
150800330	Y51505	03/21/2015	11:18	03/21/2015	12:11	1	53	53	Animal related	Transformer Fuse	Replace - Same Size		IV
150800345	N60181	03/21/2015	11:42	03/21/2015	13:13	1	91	90	Overhead equipment	Fuse	Replace - Same Size	Patrol/Test/Inspect	I
150800348	308002	03/21/2015	11:47	03/21/2015	12:34	1	47	46	Overhead equipment	Fuse	Repair		VI
150800357	U32594	03/21/2015	12:03	03/21/2015	12:34	1	31	30	Overhead equipment	Transformer Fuse	Repair	Repair	II
5003117	Q82907	03/21/2015	12:41	03/21/2015	13:35	1	53	53	Animal related	Transformer Fuse	Repair		VI
5003119	Q82907	03/21/2015	12:42	03/21/2015	13:36	1	53	53	Animal related	Transformer Fuse	Repair		VI
150800436	T02543	03/21/2015	13:36	03/21/2015	15:00	1	84	84	Overhead equipment	Connector	Patrol/Test/Inspect	Repair	VI
5003123	P26283	03/21/2015	13:44	03/21/2015	15:33	1	108	108	Overhead equipment	Connector	Replace - Same Size		I
150800473	U12540	03/21/2015	14:31	03/21/2015	16:19	1	108	107	Overhead equipment	Transformer Fuse	Repair	Replace - Same Size	II
150800506	Y39515	03/21/2015	16:23	03/21/2015	18:00	1	97	97	Tree related-tree contact	Overhead Service	Repair	Repair	IV
150800512	341001	03/21/2015	16:30	03/21/2015	17:41	1	71	71	Overhead equipment	Overhead Transformer	Switch/Reset		VI
5003125	Q69926	03/21/2015	17:55	03/21/2015	21:29	1	213	213	Overhead equipment	Overhead Transformer	Repair	Repair	VI
150800547	Y97512	03/21/2015	18:50	03/21/2015	22:30	1	220	220	Underground equipment	Underground Service	Patrol/Test/Inspect	Disconnect	IV
150800560	J76804	03/21/2015	19:11	03/21/2015	19:50	58	2262	39	Animal related	Overhead Primary	Repair	Repair	V
150800604	L17105	03/21/2015	23:39	03/22/2015	0:16	1	37	36	Public	Meter	Reconnect		III
150810057	M25143	03/22/2015	8:29	03/22/2015	10:22	19	2147	112	Overhead equipment				IV
150810049	S28552	03/22/2015	8:39	03/22/2015	10:05	1	86	85	Animal related	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
150810081	D16004	03/22/2015	10:22	03/22/2015	15:27	1	305	305	Underground equipment	Underground Service	Replace - Same Size	Replace - Same Size	I
5003135	X86543	03/22/2015	10:22	03/22/2015	13:13	1	170	170	Overhead equipment	Transformer Fuse			IV
150810099	T29562	03/22/2015	11:00	03/22/2015	12:45	1	105	104	Overhead equipment	Fuse	Replace - Same Size		VI
5003137	K67912	03/22/2015	11:32	03/22/2015	12:30	1	57	57	Animal related	Transformer Fuse	Repair		VI
5003139	R34920	03/22/2015	12:26	03/22/2015	14:00	1	93	93	Overhead equipment				VI
150810130	D90003	03/22/2015	12:30	03/22/2015	13:36	1	66	65	Other	Other	Patrol/Test/Inspect	Patrol/Test/Inspect	III
150810210	K43386	03/22/2015	15:34	03/22/2015	18:33	1	179	179	Public	Overhead Secondary	Patrol/Test/Inspect	Replace - Urgent	V

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
150810604	P57102	03/22/2015	16:03	03/22/2015	18:55	1	172	172	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	VI
150810621	A49001	03/22/2015	16:26	03/22/2015	17:05	385	15015	39	Overhead equipment	Overhead Primary	Repair		I
150810629	A49001	03/22/2015	16:26	03/22/2015	16:44	42	756	18	Overhead equipment	Overhead Primary	Repair		I
150810614	P47169	03/22/2015	16:30	03/22/2015	17:40	1	70	69	Overhead equipment	Connector	Replace - Same Size	Patrol/Test/Inspect	I
150810637	U06524	03/22/2015	17:36	03/22/2015	18:52	3	228	76	Animal related	Transformer Fuse	Replace - Same Size		II
150810640	R58951	03/22/2015	17:41	03/22/2015	18:54	1	73	72	Animal related	Fuse	Replace - Same Size		IV
150810651	S04545	03/22/2015	18:30	03/23/2015	5:47	1	677	676	Underground equipment	Underground Transformer	Patrol/Test/Inspect	Replace - Same Size	VI
5003141	N05170	03/22/2015	18:33	03/22/2015	19:44	1	70	70	Animal related	Fuse	Replace - Same Size		I
5003145	Q18242	03/22/2015	23:59	03/23/2015	5:56	6	2141	356	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	VI
150822565	N60181	03/23/2015	4:37	03/23/2015	5:32	1	55	55	Unknown	Fuse	Patrol/Test/Inspect	Replace - Same Size	I
150822606	P19395	03/23/2015	6:05	03/23/2015	9:20	296	57720	195	Overhead equipment	Jumper	Patrol/Test/Inspect	Repair	V
150822613	M09144	03/23/2015	6:24	03/23/2015	15:13	2	1058	528	Overhead equipment	Pole	Replace - Same Size	Repair	VI
150822631	N60181	03/23/2015	7:00	03/23/2015	8:48	1	108	108	Overhead equipment	Fuse	Patrol/Test/Inspect	Replace - Same Size	I
150822728	D69004	03/23/2015	7:42	03/23/2015	10:24	1	162	162	Underground equipment	Underground Service	Repair	Repair	I
150822741	U13551	03/23/2015	7:48	03/23/2015	9:15	1	87	87	Overhead equipment	Transformer Fuse	Replace - Same Size		II
150822894	S88553	03/23/2015	8:45	03/23/2015	10:30	7	735	104	Overhead equipment	Overhead Primary	Patrol/Test/Inspect	Repair	VI
150822957	M09175	03/23/2015	8:58	03/23/2015	10:18	3	240	79	Animal related	Fuse	Replace - Same Size		VI
150823027	B45005	03/23/2015	9:11	03/23/2015	10:22	28	1988	70	Unknown	Fuse	Replace - Same Size		I
5003161	Q95249	03/23/2015	9:39	03/23/2015	14:33	17	3842	294	Underground equipment	Underground Primary			VI
150823599	B25001	03/23/2015	9:53	03/23/2015	15:29	1	336	335	Overhead equipment	Pole	Patrol/Test/Inspect	Repair	I
150823509	B25001	03/23/2015	9:53	03/23/2015	11:15	4	328	81	Overhead equipment	Pole	Repair		I
5003167	K01236	03/23/2015	9:57	03/23/2015	11:27	1	89	89	Underground equipment	Underground Primary	Repair		VI
5003169	K01236	03/23/2015	10:13	03/23/2015	11:37	19	1577	83	Underground equipment	Underground Primary	Repair		VI
5003171	N05172	03/23/2015	10:22	03/23/2015	11:41	1	78	78	Overhead equipment	Disconnect Switch	Replace - Same Size		I
150823655	V74002	03/23/2015	11:27	03/23/2015	11:54	5	135	27	Overhead equipment	Transformer Fuse	Replace - Same Size	Repair	II
150823888	B82001	03/23/2015	11:41	03/23/2015	15:44	3	729	242	Overhead equipment	Overhead Primary	Patrol/Test/Inspect	Repair	I
150823835	D28124	03/23/2015	12:12	03/23/2015	13:43	3	273	91	Overhead equipment	Overhead Primary	Patrol/Test/Inspect		I
5003187	X69555	03/23/2015	12:21	03/23/2015	13:00	1	38	38	Overhead equipment	Transformer Fuse			IV
5003189	X60598	03/23/2015	12:39	03/23/2015	15:15	1	155	155	Underground equipment	Underground Service	Repair		IV
150824006	J07173	03/23/2015	13:06	03/23/2015	14:20	1	74	74	Unknown	Fuse		Replace - Same Size	I
150824104	D69009	03/23/2015	13:18	03/23/2015	13:56	4	152	37	Animal related	Fuse	Replace - Same Size		I
150824326	Q74148	03/23/2015	14:13	03/23/2015	16:07	2	228	113	Overhead equipment	Overhead Primary			IV
150825526	K82202	03/23/2015	19:34	03/23/2015	21:38	1	124	123	Tree related-tree contact	Overhead Service			III
150825541	B21003	03/23/2015	19:39	03/23/2015	20:31	149	7748	52	Overhead equipment	Overhead Primary		Repair	I
150825627	L79159	03/23/2015	21:36	03/23/2015	22:23	3	141	46	Animal related	Transformer Fuse	Replace - Same Size		IV
150830130	J50186	03/24/2015	1:06	03/24/2015	8:04	44	18392	418	Underground equipment	Underground Primary	Switch/Reset	Repair	III
150832654	B93003	03/24/2015	6:01	03/24/2015	7:55	15	1710	113	Overhead equipment	Jumper	Repair		I
150832687	X30505	03/24/2015	6:59	03/24/2015	8:25	1	86	85	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
150832689	M41182	03/24/2015	7:02	03/24/2015	8:50	1	108	107	Overhead equipment	Connector	Replace - Same Size		I
150832758	R60551	03/24/2015	7:34	03/24/2015	11:15	1	221	220	Underground equipment	Underground Service	Patrol/Test/Inspect	Repair	IV
150832978	U32594	03/24/2015	9:02	03/24/2015	9:25	1	23	23	Animal related	Transformer Fuse	Replace - Same Size		II
150833146	X92508	03/24/2015	9:52	03/24/2015	10:25	1	33	33	Overhead equipment	Overhead Transformer	Repair	Replace - Same Size	IV
150833259	V34002	03/24/2015	10:17	03/24/2015	11:29	1	72	72	Overhead equipment	Overhead Service	Replace - Same Size	Replace - Same Size	II
150833355	J76804	03/24/2015	10:42	03/24/2015	11:56	1	74	74	Tree related-tree contact				V
150833371	V42572	03/24/2015	10:48	03/24/2015	12:30	1	102	102	Overhead equipment	Overhead Service	Repair		II
150833497	A56013	03/24/2015	11:21	03/24/2015	12:02	1	41	40	Overhead equipment				I
5003221	P26283	03/24/2015	12:46	03/24/2015	14:30	1	103	103	Weather	Transformer Fuse	Repair		I
150833779		03/24/2015	12:50	03/24/2015	16:45	1	235	235	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Repair	IV
150833778	Q75145	03/24/2015	12:50	03/24/2015	13:50	1	60	60	Animal related	Fuse	Replace - Same Size		VI
150833864	U99593	03/24/2015	13:13	03/24/2015	14:46	2	186	92	Unknown	Transformer Fuse	Repair		II
150833905	Z05001	03/24/2015	13:24	03/24/2015	14:40	1	76	75	Overhead equipment	Fuse	Replace - Same Size		IV
5003227	R39934	03/24/2015	15:25	03/24/2015	21:32	11	2078	367	Weather	Pole	Replace - New Size	Repair	VI
150834379	332004	03/24/2015	15:30	03/25/2015	1:59	17	10693	628	Tree related-tree broken	Tree	Patrol/Test/Inspect	Remove	VI
150834388	K22173	03/24/2015	15:40	03/24/2015	16:25	4	180	45	Overhead equipment	Transformer Fuse	Replace - Same Size		VI
150834448		03/24/2015	16:07	03/24/2015	18:35	1	148	148	Underground equipment	Underground Service	Repair	Repair	V
5003229	R29905	03/24/2015	16:54	03/24/2015	18:07	6	437	72	Weather	Fuse	Replace - Same Size		VI

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5003237	Q54908	03/24/2015	16:58	03/24/2015	18:58	2	238	119	Weather	Transformer Fuse	Replace - Same Size		VI
150834640	T06504	03/24/2015	17:43	03/25/2015	0:05	3	1146	381	Overhead equipment	Other	Repair	Repair	VI
5003233	L62928	03/24/2015	17:54	03/24/2015	19:49	1	114	114	Overhead equipment	Connector	Replace - New Size		VI
5003235	R39934	03/24/2015	18:08	03/24/2015	19:48	1	99	99	Overhead equipment				VI
150834705	Q47833	03/24/2015	18:38	03/24/2015	18:45	18	126	7	Weather	Overhead Transformer	Repair		V
150835036	P98192	03/24/2015	19:09	03/25/2015	4:06	1	537	536	Overhead equipment	Overhead Transformer			III
150835072	Q47833	03/24/2015	19:53	03/25/2015	1:40	1	347	346	Weather	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	V
150835075	R01153	03/24/2015	19:57	03/25/2015	2:05	1	368	367	Tree related-tree contact	Pole			III
150835101	M49424	03/24/2015	20:42	03/24/2015	23:32	1	170	169	Weather	Transformer Fuse	Replace - Same Size		V
150835172	R04409	03/24/2015	20:46	03/24/2015	22:20	3	282	94	Weather	Fuse	Replace - Same Size		V
150835192	R04409	03/24/2015	20:46	03/25/2015	1:09	4	1052	263	Weather	Overhead Transformer	Replace - Same Size	Replace - Same Size	V
150835174	R04409	03/24/2015	20:46	03/24/2015	22:29	4	412	103	Weather	Overhead Transformer			V
150835116	U84587	03/24/2015	21:08	03/25/2015	0:45	1	217	216	Overhead equipment	Disconnect Switch	Replace - Same Size		II
150835119	K27150	03/24/2015	21:10	03/24/2015	22:52	1	102	101	Weather	Fuse	Replace - Same Size		VI
150835121	N97887	03/24/2015	21:11	03/24/2015	22:42	1	91	90	Weather	Overhead Primary	Replace - Same Size		V
150835123	Q47833	03/24/2015	21:13	03/25/2015	1:39	1	266	265	Weather	Overhead Transformer	Replace - Same Size	Repair	V
5003241	Q64919	03/24/2015	21:15	03/25/2015	2:31	1	315	315	Weather	Overhead Transformer	Replace - Same Size	Repair	VI
150835133	H32370	03/24/2015	21:18	03/24/2015	23:09	11	1221	111	Weather	Overhead Secondary	Raise		V
5003243	Y36541	03/24/2015	21:18	03/24/2015	23:42	3	430	143	Weather	Overhead Transformer	Replace - Same Size		IV
150835153	M41111	03/24/2015	21:43	03/25/2015	4:17	150	59100	393	Public	Pole	Replace - Same Size		I
5003251	Q24310	03/24/2015	21:54	03/24/2015	23:45	3	332	110	Weather	Lightning Arrestor	Replace - Same Size		VI
150835183	J06167	03/24/2015	22:32	03/25/2015	1:48	21	4116	195	Overhead equipment	Fuse	Patrol/Test/Inspect	Replace - Same Size	I
150840110	D92001	03/24/2015	22:40	03/25/2015	3:31	2	582	290	Underground equipment	Other		Repair	I
150840102	D92001	03/24/2015	22:40	03/25/2015	0:33	64	7232	113	Underground equipment	Underground Transformer		Replace - Same Size	I
150835197	V14579	03/24/2015	23:11	03/25/2015	1:45	1	154	153	Overhead equipment	Other			II
150840001	F03004	03/25/2015	0:01	03/25/2015	1:40	1	99	98	Overhead equipment				III
150842714	C70001	03/25/2015	0:05	03/25/2015	13:45	3	2460	820	Overhead equipment	Pole	Repair	Replace - Same Size	III
150840105	E05002	03/25/2015	0:09	03/25/2015	1:17	71	4828	68	Weather	Fuse	Repair		IV
150840111	C70001	03/25/2015	0:20	03/25/2015	2:32	1	132	132	Weather	Fuse	Replace - Same Size		III
150840112	C36001	03/25/2015	0:22	03/25/2015	3:11	1	169	169	Overhead equipment	Pole		Replace - Same Size	III
150840116	H06135	03/25/2015	0:25	03/25/2015	2:03	10	980	98	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
150842648	H01190	03/25/2015	0:33	03/25/2015	9:34	1	541	540	Tree related-tree contact	Pole		Replace - Same Size	III
150840127	H01190	03/25/2015	0:37	03/25/2015	3:48	15	2865	191	Overhead equipment	Fuse	Replace - Same Size		III
150840147	M18131	03/25/2015	0:46	03/25/2015	7:45	47	19693	418	Overhead equipment	Overhead Primary			III
150840153	M18131	03/25/2015	1:13	03/25/2015	6:14	3	903	301	Tree related-tree contact	Overhead Primary	Repair		III
150840159	D66004	03/25/2015	1:13	03/25/2015	3:00	70	7490	107	Weather	Fuse			IV
150842660	L42158	03/25/2015	1:14	03/25/2015	5:02	1	228	227	Tree related-tree broken	Overhead Service	Repair		III
150840207	U06524	03/25/2015	2:12	03/25/2015	3:45	1	93	92	Tree related-tree contact	Transformer Fuse	Replace - Same Size		II
150842658	C70001	03/25/2015	4:30	03/25/2015	6:03	1	93	92	Weather	Fuse	Replace - Same Size		III
150842664	P69174	03/25/2015	4:50	03/25/2015	6:29	2	198	98	Tree related-tree contact	Tree		Remove	III
150842666	A85001	03/25/2015	4:51	03/25/2015	7:45	1	174	174	Unknown	Fuse	Patrol/Test/Inspect	Replace - Same Size	I
150842667	E05002	03/25/2015	5:00	03/25/2015	7:34	1	154	153	Overhead equipment	Fuse		Repair	IV
150842670	K73362	03/25/2015	5:03	03/25/2015	7:00	1	117	116	Overhead equipment	Transformer Fuse		Replace - Same Size	IV
150842671	K27150	03/25/2015	5:04	03/25/2015	5:54	1	50	50	Overhead equipment	Transformer Fuse	Repair	Repair	VI
150842681	B21001	03/25/2015	5:33	03/25/2015	9:46	9	2277	253	Underground equipment	Underground Primary	Patrol/Test/Inspect	Replace - Urgent	I
150842698	V50542	03/25/2015	6:39	03/25/2015	8:46	2	254	126	Weather	Fuse	Replace - Same Size	Repair	II
150842751	P47123	03/25/2015	6:48	03/25/2015	9:15	17	2499	146	Unknown	Fuse	Replace - Same Size	Replace - Same Size	I
150842739	F10002	03/25/2015	6:58	03/25/2015	7:45	1	47	46	Overhead equipment	Transformer Fuse	Replace - Same Size		III
150842743	C70001	03/25/2015	7:00	03/25/2015	8:39	1	99	99	Weather	Fuse	Repair	Replace - Same Size	III
150842763	S28551	03/25/2015	7:07	03/25/2015	8:25	1	78	78	Public				VI
150842868	U52516	03/25/2015	7:47	03/25/2015	9:16	1	89	88	Animal related	Transformer Fuse			II
150843545	M31203	03/25/2015	8:00	03/25/2015	12:45	7	1995	284	Overhead equipment	Pole	Replace - Urgent		I
150843040	E10003	03/25/2015	8:52	03/25/2015	9:28	1	36	36	Other	Transformer Fuse	Replace - Same Size		III
5003273	R16511	03/25/2015	9:01	03/25/2015	11:58	2	355	177	Underground equipment	Underground Primary	Repair	Replace - Same Size	I
150843398	S27599	03/25/2015	9:30	03/25/2015	10:04	331	11254	33	Animal related	Substation Misc.			VI
150843254	V59561	03/25/2015	9:41	03/25/2015	10:30	1	49	49	Overhead equipment	Transformer Fuse	Replace - Same Size	Replace - Same Size	II

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5003279	Q36410	03/25/2015	9:46	03/25/2015	11:33	1	106	106	Overhead equipment	Connector	Repair	Repair	I
150843408	X72536	03/25/2015	10:11	03/25/2015	11:16	1	65	65	Animal related	Transformer Fuse			IV
150843425	R48167	03/25/2015	10:15	03/25/2015	10:45	1	30	29	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
150843619	S92559	03/25/2015	11:08	03/25/2015	11:50	1	42	42	Animal related	Transformer Fuse	Replace - Same Size		VI
150843708	R59412	03/25/2015	11:30	03/25/2015	12:50	1	80	79	Overhead equipment	Connector	Replace - Same Size		IV
150843813	U73583	03/25/2015	12:00	03/25/2015	13:17	9	693	76	Animal related	Transformer Fuse	Replace - Same Size		II
150843833	S52515	03/25/2015	12:06	03/25/2015	13:25	1	79	79	Animal related	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
150843899	Y89535	03/25/2015	12:22	03/25/2015	12:49	1	27	27	Overhead equipment	Overhead Transformer	Repair	Replace - Same Size	IV
150843902	X83533	03/25/2015	12:23	03/25/2015	12:59	29	1044	36	Animal related	Overhead Primary	Patrol/Test/Inspect		IV
150844044	S22595	03/25/2015	12:51	03/25/2015	13:19	1	28	27	Overhead equipment				VI
150844107	T46001	03/25/2015	13:12	03/25/2015	13:44	1	32	31	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect		VI
150844211	P54828	03/25/2015	13:37	03/25/2015	14:39	1	62	62	Animal related	Transformer Fuse	Replace - Same Size		V
150844259	K27150	03/25/2015	13:46	03/25/2015	14:03	1	17	17	Unknown	Transformer Fuse	Replace - Same Size	Replace - Same Size	VI
5003349	X24536	03/25/2015	13:51	03/25/2015	14:27	1	35	35	Animal related	Transformer Fuse	Replace - Same Size		IV
150844485	K48381	03/25/2015	14:40	03/25/2015	15:21	1	41	40	Overhead equipment	Connector	Repair		V
150844533	B10001	03/25/2015	14:56	03/25/2015	15:30	1	34	34	Unknown	Transformer Fuse	Replace - Same Size		I
150844637	Y57001	03/25/2015	15:21	03/25/2015	18:06	1	165	165	Underground equipment	Underground Service	Patrol/Test/Inspect	Advise Customer	IV
150844706	J56342	03/25/2015	15:40	03/25/2015	20:45	1	305	304	Underground equipment	Underground Service			III
150844713	U30003	03/25/2015	15:45	03/25/2015	16:19	1	34	33	Public	Overhead Service	Repair		II
150845073	J56342	03/25/2015	17:58	03/25/2015	18:38	1	40	39	Unknown	Other			III
5003369	L50214	03/25/2015	18:26	03/25/2015	19:55	17	1504	88	Tree related-tree contact	Tree	Trim		VI
150845496	R73841	03/25/2015	20:06	03/25/2015	22:30	1	144	143	Weather	Overhead Transformer	Replace - Same Size		V
150845505	C50001	03/25/2015	20:13	03/26/2015	6:29	1	616	615	Underground equipment	Underground Primary			III
150852239	C50001	03/25/2015	20:13	03/26/2015	3:05	10	4120	411	Underground equipment	Underground Primary	Switch/Reset		III
150845513	S55566	03/25/2015	20:25	03/25/2015	23:20	4	700	174	Weather	Overhead Secondary	Repair		VI
150845515	R53416	03/25/2015	20:26	03/25/2015	21:26	1	60	59	Overhead equipment	Connector	Repair		V
150845522	M18131	03/25/2015	20:33	03/25/2015	21:31	1	58	58	Overhead equipment	Overhead Service	Repair		III
5003373	Q64919	03/25/2015	21:41	03/25/2015	22:37	1	55	55	Weather	Fuse	Replace - Same Size		VI
5003375	Q64919	03/25/2015	21:46	03/25/2015	22:52	1	65	65	Weather	Fuse	Replace - Same Size		VI
150846233	M09143	03/25/2015	22:24	03/25/2015	23:29	1	65	65	Weather	Fuse	Replace - Same Size		VI
150846238	M21133	03/25/2015	22:37	03/26/2015	1:05	1	148	148	Weather	Transformer Fuse	Replace - Same Size		VI
5003377	R07381	03/25/2015	23:13	03/26/2015	1:18	1	124	124	Overhead equipment	Connector	Replace - Same Size	Repair	I
150846252	301053	03/25/2015	23:34	03/26/2015	0:46	1	72	72	Overhead equipment	Fuse	Replace - Same Size		VI
150850095	K09864	03/26/2015	0:11	03/26/2015	2:11	1	120	119	Overhead equipment	Transformer Fuse	Remove	Replace - Same Size	V
150852253	S83533	03/26/2015	5:16	03/26/2015	7:02	1	106	105	Overhead equipment	Transformer Fuse	Repair	Replace - Same Size	VI
150852259	T06504	03/26/2015	5:45	03/26/2015	7:54	1	129	129	Overhead equipment	Overhead Service	Repair	Repair	VI
150852314	U13551	03/26/2015	6:54	03/26/2015	8:00	1	66	66	Overhead equipment	Transformer Fuse	Replace - Same Size		II
150852318	Y45503	03/26/2015	7:03	03/26/2015	7:40	1	37	37	Overhead equipment	Transformer Fuse	Repair	Replace - Same Size	IV
150852350	L74191	03/26/2015	7:18	03/26/2015	9:30	1	132	132	Animal related	Transformer Fuse	Replace - Same Size		IV
150852395	P72320	03/26/2015	7:46	03/26/2015	9:35	1	109	108	Overhead equipment	Overhead Service	Patrol/Test/Inspect	Replace - New Size	V
150852418	L46810	03/26/2015	7:52	03/26/2015	9:00	1	68	68	Overhead equipment	Connector	Replace - Same Size		V
150852542	S61530	03/26/2015	8:29	03/26/2015	8:55	1	26	26	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	VI
150852612	P58156	03/26/2015	8:54	03/26/2015	10:12	1	78	78	Animal related	Fuse	Repair	Repair	VI
150852618	J07173	03/26/2015	8:56	03/26/2015	10:25	1	89	89	Unknown	Fuse	Replace - Same Size		I
5003385	Q82906	03/26/2015	8:59	03/26/2015	14:21	1	321	321	Underground equipment	Fuse	Replace - Same Size	Replace - Same Size	VI
150853102	Y13043	03/26/2015	9:43	03/26/2015	13:30	16	3632	226	Overhead equipment	Overhead Transformer	Disconnect	Replace - Same Size	IV
150852925	D60001	03/26/2015	10:15	03/26/2015	11:47	1	92	91	Other	Other			III
150853176	S42578	03/26/2015	11:29	03/26/2015	12:58	1	89	88	Overhead equipment	Overhead Secondary	Replace - Same Size	Replace - Same Size	VI
150853196		03/26/2015	11:40	03/26/2015	13:43	1	123	123	Weather	Fuse	Replace - Same Size		V
150853240	N50331	03/26/2015	11:55	03/26/2015	12:28	1	33	32	Animal related	Fuse	Replace - Same Size		II
150853284	A36002	03/26/2015	12:10	03/26/2015	13:10	1	60	59	Animal related	Transformer Fuse	Replace - Same Size		I
5003409	P82290	03/26/2015	13:50	03/26/2015	15:28	1	97	97	Overhead equipment	Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
150853171	328119	03/26/2015	14:00	03/26/2015	15:38	2	196	97	Underground equipment	Overhead Secondary	Repair	Repair	V
150853916	N67315	03/26/2015	15:29	03/26/2015	16:25	1	56	56	Other	Other			I
150854074	B10001	03/26/2015	16:45	03/26/2015	17:40	1	55	55	Overhead equipment	Overhead Service	Replace - New Size		I
150854184	P54828	03/26/2015	17:35	03/26/2015	18:56	1	81	81	Animal related	Fuse	Replace - Same Size		V

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
150854338	S84535	03/26/2015	18:46	03/26/2015	19:59	1	73	72	Other	Other			VI
5003417	X69555	03/26/2015	20:07	03/26/2015	21:00	1	52	52	Overhead equipment	Overhead Service	Repair	Replace - Same Size	IV
150854894	S62520	03/26/2015	21:21	03/26/2015	22:03	1	42	42	Overhead equipment				VI
150854901	D90002	03/26/2015	21:43	03/26/2015	23:15	1	92	91	Overhead equipment	Fuse	Replace - Same Size		III
150854911	R65451	03/26/2015	22:25	03/27/2015	0:57	65	9880	151	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	IV
150860174	T28562	03/27/2015	2:25	03/27/2015	6:56	6	1626	271	Overhead equipment				VI
150862637	T13581	03/27/2015	3:27	03/27/2015	10:16	1	409	408	Tree related-tree broken	Overhead Primary	Repair	Replace - Same Size	VI
150862742	M09143	03/27/2015	7:22	03/27/2015	16:25	1	543	543	Overhead equipment	Overhead Transformer		Repair	VI
150862846	M22812	03/27/2015	7:25	03/27/2015	8:29	5	320	63	Overhead equipment	Fuse	Replace - Same Size		V
150862901	T05539	03/27/2015	8:29	03/27/2015	16:31	1	482	481	Underground equipment	Underground Secondary	Replace - Same Size		VI
150862913	P47123	03/27/2015	8:33	03/27/2015	9:15	1	42	42	Overhead equipment	Overhead Transformer		Repair	I
5003447	R10943	03/27/2015	8:53	03/27/2015	10:22	1	88	88	Underground equipment	Underground Service		Repair	VI
150862991	Y54587	03/27/2015	8:55	03/27/2015	9:50	1	55	54	Overhead equipment	Overhead Secondary	Repair		IV
150863497	M22812	03/27/2015	10:17	03/27/2015	11:26	161	11109	69	Overhead equipment	Recloser	Switch/Reset		V
150863399	M25144	03/27/2015	10:49	03/27/2015	11:34	1	45	45	Overhead equipment	Transformer Fuse	Replace - Same Size	Replace - Urgent	IV
150863482	R99180	03/27/2015	11:17	03/27/2015	13:27	1	130	130	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
150863530	M40132	03/27/2015	11:34	03/27/2015	12:45	1	71	71	Animal related	Fuse	Replace - Same Size		I
150863587	328119	03/27/2015	11:56	03/27/2015	13:37	1	101	101	Underground equipment	Underground Service	Repair		V
150863591	V59561	03/27/2015	11:58	03/27/2015	13:10	1	72	71	Animal related	Transformer Fuse	Replace - Same Size		II
150863672	D90003	03/27/2015	12:32	03/27/2015	12:54	1	22	21	Overhead equipment	Fuse	Replace - Same Size		III
150863692	D90003	03/27/2015	12:44	03/27/2015	12:56	1	12	12	Overhead equipment	Transformer Fuse	Replace - Same Size		III
150863696		03/27/2015	12:45	03/27/2015	14:07	1	82	81	Underground equipment				V
150863796	D01001	03/27/2015	13:17	03/27/2015	14:21	1	64	63	Overhead equipment	Disconnect Switch	Replace - Same Size	Replace - Same Size	I
150863859	R99180	03/27/2015	13:31	03/27/2015	14:02	1	31	30	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
5003485	Q34360	03/27/2015	14:04	03/27/2015	18:22	13	3349	257	Public	Overhead Secondary	Replace - Same Size		I
150864135	S57502	03/27/2015	14:45	03/27/2015	18:30	1	225	225	Overhead equipment	Overhead Service			VI
5003489	R49275	03/27/2015	14:53	03/27/2015	16:10	1	76	76	Jurisdictional	Meter	Reconnect		VI
150864175	302003	03/27/2015	14:57	03/27/2015	18:00	1	183	182	Overhead equipment	Overhead Transformer	Advise Customer	Replace - Same Size	VI
150864236	S27599	03/27/2015	14:57	03/27/2015	15:15	227	4086	17	Animal related	Other			VI
150864187	K52401	03/27/2015	14:59	03/27/2015	17:08	1	129	129	Overhead equipment	Connector	Repair	Repair	V
150864251	M12151	03/27/2015	15:23	03/27/2015	17:00	1	97	97	Overhead equipment	Connector	Replace - Same Size		VI
150864329	L73155	03/27/2015	15:52	03/27/2015	16:35	125	5375	42	Public	Pole	Replace - Same Size	Replace - Same Size	IV
150864413	L73155	03/27/2015	15:54	03/27/2015	18:14	250	35000	140	Public				IV
150864312	K28183	03/27/2015	15:56	03/27/2015	17:17	1	81	80	Overhead equipment	Transformer Fuse	Replace - Same Size		III
150864332	B80003	03/27/2015	16:01	03/27/2015	16:38	1	37	37	Animal related				I
150864447	D96002	03/27/2015	17:16	03/27/2015	19:03	1	107	106	Overhead equipment	Connector	Replace - Same Size		I
150864484	Y79500	03/27/2015	17:39	03/27/2015	22:01	1	262	261	Underground equipment	Overhead Service	Repair	Replace - Same Size	IV
150864520	L70127	03/27/2015	18:57	03/27/2015	22:10	1	193	193	Underground equipment	Underground Secondary		Repair	IV
150864775	R24832	03/27/2015	19:24	03/27/2015	20:37	37	2701	72	Animal related	Fuse	Replace - Same Size	Repair	V
150864846	R58931	03/27/2015	20:27	03/27/2015	21:54	17	1479	87	Underground equipment	Underground Primary			IV
150864841	R58931	03/27/2015	20:27	03/27/2015	21:45	30	2340	78	Underground equipment	Underground Primary			IV
150864832	S30518	03/27/2015	20:30	03/27/2015	22:21	1	111	111	Overhead equipment	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
150864859	V01002	03/27/2015	22:56	03/28/2015	8:00	3	1632	544	Public	Pole		Replace - Same Size	II
150864873	S43511	03/27/2015	23:38	03/28/2015	0:31	1	53	52	Unknown				VI
150870036	R01152	03/28/2015	1:16	03/28/2015	2:12	1	56	56	Unknown	Other			III
150870074	M26164	03/28/2015	6:18	03/28/2015	8:30	1	132	132	Underground equipment	Underground Service			III
150870144	T28562	03/28/2015	7:55	03/28/2015	10:20	5	725	145	Overhead equipment	Pole	Repair	Repair	VI
150870146	K89141	03/28/2015	8:12	03/28/2015	10:22	1	130	129	Overhead equipment	Overhead Secondary	Repair		III
150870165	N50333	03/28/2015	8:35	03/28/2015	11:25	1	170	169	Underground equipment	Underground Service	Repair		II
150870174	R48166	03/28/2015	8:42	03/28/2015	11:46	1	184	183	Overhead equipment	Disconnect Switch			IV
150870212		03/28/2015	9:49	03/28/2015	11:55	1	126	126	Animal related	Transformer Fuse	Replace - Same Size		VI
5003519	R07382	03/28/2015	9:54	03/28/2015	11:01	1	66	66	Animal related	Fuse	Replace - Same Size	Replace - Same Size	I
150870230	L46811	03/28/2015	10:10	03/28/2015	11:40	1	90	90	Overhead equipment	Overhead Transformer			V
150870233	J71129	03/28/2015	10:13	03/28/2015	12:03	1	110	110	Unknown	Fuse	Replace - Same Size		I
150870245	R59417	03/28/2015	10:36	03/28/2015	14:35	1	239	239	Underground equipment	Underground Secondary	Repair		IV
150870271	J05138	03/28/2015	11:10	03/28/2015	16:35	1	325	324	Overhead equipment	Overhead Transformer	Repair	Replace - Same Size	I

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5003529	X49569	03/28/2015	11:41	03/28/2015	12:56	1	74	74	Animal related	Customer Equipment	Advise Customer		IV
5003531	Y34596	03/28/2015	11:43	03/28/2015	14:07	1	143	143	Overhead equipment	Jumper	Repair		IV
150870325	M26161	03/28/2015	12:06	03/28/2015	13:11	1	65	65	Animal related	Transformer Fuse	Replace - Same Size		III
150870377	S49550	03/28/2015	13:25	03/28/2015	14:08	1	43	42	Animal related	Transformer Fuse			VI
150870442	V38002	03/28/2015	14:57	03/28/2015	16:44	405	43335	107	Public				II
150870498	V38002	03/28/2015	16:56	03/28/2015	17:18	1	22	21	Tree related-tree contact				II
150870522	K27150	03/28/2015	18:09	03/28/2015	18:55	1	46	46	Animal related	Transformer Fuse	Repair	Repair	VI
150870547	R60551	03/28/2015	19:22	03/28/2015	21:00	49	4802	98	Overhead equipment	Jumper	Replace - Same Size		IV
150870558	R60551	03/28/2015	19:40	03/28/2015	21:05	1	85	84	Overhead equipment	Jumper	Replace - Same Size		IV
5003545	Y69565	03/28/2015	19:45	03/28/2015	22:29	35	5740	164	Overhead equipment	Overhead Primary	Repair		IV
150880010	K07322	03/29/2015	2:10	03/29/2015	3:38	1	88	87	Unknown	Fuse	Replace - Same Size		I
150880016	K39154	03/29/2015	3:37	03/29/2015	8:30	1	293	293	Public	Pole	Replace - Same Size	Replace - Urgent	III
150880024	U68001	03/29/2015	6:10	03/29/2015	9:37	1	207	206	Overhead equipment	Overhead Service	Repair		II
150880150	Y55505	03/29/2015	8:21	03/29/2015	10:30	1	129	129	Animal related	Transformer Fuse	Replace - Same Size		IV
150880337	V74513	03/29/2015	9:34	03/29/2015	17:25	2	942	471	Underground equipment	Underground Primary	Repair	Repair	II
150880179	V74513	03/29/2015	9:34	03/29/2015	13:05	4	844	211	Underground equipment	Underground Primary	Switch/Reset		II
150880189	D39002	03/29/2015	9:46	03/29/2015	11:30	1	104	103	Unknown	Fuse	Replace - Same Size		I
150880211	D92003	03/29/2015	10:11	03/29/2015	11:50	32	3168	98	Overhead equipment	Transformer Fuse	Replace - Same Size		I
150880228	U60559	03/29/2015	10:36	03/29/2015	12:45	1	129	129	Tree related-tree broken	Customer Equipment	Cut in Clear		II
150880241	S25552	03/29/2015	10:53	03/29/2015	16:00	5	1535	306	Overhead equipment	Disconnect Switch	Patrol/Test/Inspect	Replace - Same Size	VI
150880253	A80001	03/29/2015	11:06	03/29/2015	17:35	1	389	389	Overhead equipment	Pole	Replace - Same Size	Repair	I
150880804	B82002	03/29/2015	12:20	03/30/2015	0:57	1	757	756	Overhead equipment	Crossarm	Replace - Same Size	Repair	I
150880459	B82002	03/29/2015	12:20	03/29/2015	17:18	17	5066	297	Overhead equipment	Crossarm		Replace - Same Size	I
150880301	D32212	03/29/2015	12:33	03/29/2015	16:06	1	213	212	Overhead equipment	Fuse	Repair	Replace - New Size	I
150880307	B25001	03/29/2015	12:37	03/29/2015	14:58	26	3666	141	Overhead equipment	Pole	Patrol/Test/Inspect		I
150880352	M21133	03/29/2015	13:36	03/29/2015	14:44	33	2244	68	Overhead equipment	Jumper	Repair	Repair	VI
150880349	Q15844	03/29/2015	13:40	03/29/2015	16:41	1	181	181	Tree related-tree broken	Overhead Service	Repair		V
150880356	S86580	03/29/2015	13:50	03/29/2015	15:30	1	100	100	Overhead equipment	Overhead Secondary	Patrol/Test/Inspect	Repair	VI
5003553	X02546	03/29/2015	13:58	03/29/2015	15:40	2	203	101	Tree related-tree broken	Fuse	Repair	Replace - Same Size	IV
150880375	P69175	03/29/2015	14:37	03/29/2015	16:50	1	133	133	Underground equipment	Underground Service		Repair	III
5003583	R50-UNIT-1	03/29/2015	15:08	03/29/2015	17:05	550	64350	116	Public	Substation Breaker	Replace - Same Size	Replace - Same Size	I
150880596	Q06132	03/29/2015	15:30	03/29/2015	21:05	26	8710	334	Underground equipment	Underground Primary	Repair		IV
150880565	Q06132	03/29/2015	15:30	03/29/2015	19:30	65	15600	239	Underground equipment	Underground Primary	Repair		IV
150880412	X42502	03/29/2015	15:31	03/29/2015	16:37	1	66	66	Overhead equipment	Jumper	Repair		IV
150880469	S60581	03/29/2015	16:15	03/29/2015	19:02	1	167	166	Overhead equipment	Jumper	Patrol/Test/Inspect	Replace - Same Size	VI
5003651	N05170	03/29/2015	17:19	03/29/2015	19:43	1	143	143	Animal related	Fuse	Replace - Same Size		I
5003653	Q36410	03/29/2015	17:23	03/29/2015	19:36	1	132	132	Overhead equipment	Overhead Secondary	Tie/Tighten	Repair	I
150880581	339162	03/29/2015	18:06	03/29/2015	21:24	136	26928	198	Public	Overhead Primary			V
150880524	R61242	03/29/2015	18:07	03/29/2015	23:50	1	343	342	Underground equipment	Underground Service			IV
150880532	339162	03/29/2015	18:07	03/29/2015	19:33	82	7052	85	Public	Overhead Primary			V
150880554	R73841	03/29/2015	18:25	03/29/2015	20:32	1	127	127	Weather	Transformer Fuse	Replace - Same Size		V
150880551	Q06132	03/29/2015	18:29	03/29/2015	18:55	40	1040	26	Underground equipment	Fuse			IV
150880560	D89002	03/29/2015	18:33	03/29/2015	22:30	1	237	236	Underground equipment	Underground Service	Patrol/Test/Inspect	Repair	I
5003657	T59925	03/29/2015	19:10	03/29/2015	20:30	4	316	79	Animal related	Transformer Fuse	Replace - Same Size		VI
150880974	307004	03/29/2015	20:37	03/29/2015	21:56	1	79	79	Overhead equipment	Overhead Service	Repair		VI
150892377	U93563	03/30/2015	6:24	03/30/2015	7:28	1	64	63	Overhead equipment	Transformer Fuse	Repair		II
150892381	K76543	03/30/2015	6:35	03/30/2015	7:52	1	77	76	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
150892394	339160	03/30/2015	6:53	03/30/2015	7:38	1	45	45	Overhead equipment	Overhead Service	Repair		V
150892398	Q15845	03/30/2015	6:57	03/30/2015	7:38	1	41	41	Animal related	Fuse	Replace - Same Size		V
150892441	S61529	03/30/2015	7:28	03/30/2015	7:55	1	27	26	Substation equipment	Substation Misc.	Repair	Switch/Reset	VI
150892506	S15560	03/30/2015	7:55	03/30/2015	9:10	1	75	75	Animal related	Fuse	Replace - Same Size		VI
150892724	X82585	03/30/2015	8:52	03/30/2015	9:24	1	32	32	Animal related	Transformer Fuse	Replace - Same Size		IV
150892731	D69006	03/30/2015	8:53	03/30/2015	10:22	1	89	88	Overhead equipment	Fuse	Patrol/Test/Inspect	Repair	I
150892831	K71810	03/30/2015	9:13	03/30/2015	9:30	61	1037	17	Animal related	Fuse	Replace - Same Size		IV
150892857	B80002	03/30/2015	9:20	03/30/2015	10:41	1	81	81	Overhead equipment	Connector	Patrol/Test/Inspect	Repair	I
5003725	Q36410	03/30/2015	9:23	03/30/2015	11:01	304	29716	97	Overhead equipment	Recloser	Replace - Same Size	Repair	I

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
150892865	A91003	03/30/2015	9:24	03/30/2015	10:27	5	315	62	Animal related	Fuse	Replace - Same Size		I
150892907	328120	03/30/2015	9:30	03/30/2015	10:11	1	41	40	Overhead equipment	Transformer Fuse	Replace - Same Size	Repair	V
5003693	Q36410	03/30/2015	9:30	03/30/2015	11:03	1	92	92	Overhead equipment	Recloser	Replace - Same Size	Replace - Same Size	I
150892931	S25552	03/30/2015	9:34	03/30/2015	10:16	1	42	42	Animal related	Transformer Fuse	Repair	Repair	VI
150892953	D92002	03/30/2015	9:36	03/30/2015	11:07	1	91	90	Overhead equipment				I
5003731	Q36410	03/30/2015	9:40	03/30/2015	11:03	1	82	82	Overhead equipment				I
5003705	X69555	03/30/2015	9:57	03/30/2015	10:55	1	57	57	Overhead equipment	Overhead Transformer	Repair	Replace - Same Size	IV
5003709	K58213	03/30/2015	10:06	03/30/2015	11:05	1	58	58	Animal related	Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
5003711	K58213	03/30/2015	10:11	03/30/2015	11:05	1	53	53	Animal related	Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
150893181	D36001	03/30/2015	10:13	03/30/2015	11:20	22	1474	66	Unknown	Fuse	Repair	Replace - Same Size	I
150893235	Q32170	03/30/2015	10:26	03/30/2015	11:52	1	86	85	Unknown	Transformer Fuse	Replace - Same Size	Patrol/Test/Inspect	I
5003741	Q34360	03/30/2015	11:04	03/30/2015	17:43	4	1593	398	Underground equipment	Underground Service	Repair	Repair	I
150893477	S09520	03/30/2015	11:16	03/30/2015	11:48	1	32	31	Overhead equipment	Fuse			VI
150893505	D36002	03/30/2015	11:21	03/30/2015	11:48	1	27	27	Unknown	Meter	Patrol/Test/Inspect		I
5003745	J84123	03/30/2015	11:32	03/30/2015	13:35	2	245	122	Overhead equipment	Overhead Service			VI
5003747	Q11516	03/30/2015	11:37	03/30/2015	12:44	4	265	66	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	I
150893639	Y79500	03/30/2015	11:56	03/30/2015	15:00	1	184	184	Overhead equipment	Overhead Transformer	Repair	Replace - Same Size	IV
150893761	M78323	03/30/2015	12:17	03/30/2015	16:00	1	223	222	Overhead equipment	Overhead Transformer		Replace - Same Size	V
150893829	D92001	03/30/2015	12:32	03/30/2015	19:57	4	1780	445	Underground equipment	Underground Service	Patrol/Test/Inspect	Repair	I
5003751	R10903	03/30/2015	12:38	03/30/2015	14:05	1	86	86	Animal related	Fuse	Repair		VI
5003763	R10903	03/30/2015	12:38	03/30/2015	14:07	31	2737	88	Animal related	Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
150893961	H11339	03/30/2015	13:00	03/30/2015	17:26	53	14098	266	Tree related-tree broken	Overhead Secondary		Repair	V
150894181	V49541	03/30/2015	13:39	03/30/2015	16:33	1	174	174	Underground equipment	Fuse		Patrol/Test/Inspect	II
150894290	P52305	03/30/2015	14:02	03/30/2015	15:13	28	1988	71	Overhead equipment	Overhead Primary	Switch/Reset		IV
150894512	B93001	03/30/2015	14:33	03/30/2015	16:15	1	102	102	Overhead equipment	Connector	Replace - Same Size		I
150894535	A48005	03/30/2015	14:37	03/30/2015	15:52	1	75	75	Overhead equipment	Connector	Replace - Same Size		I
150894537	H22346	03/30/2015	14:37	03/30/2015	15:44	1	67	66	Animal related	Transformer Fuse	Replace - Same Size		V
150894545	S20555	03/30/2015	14:39	03/30/2015	15:20	1	41	40	Overhead equipment	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
150894766	A81003	03/30/2015	15:15	03/30/2015	17:02	21	2247	107	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
150894792	S55534	03/30/2015	15:30	03/30/2015	17:07	1	97	96	Underground equipment	Underground Secondary			VI
150894845	E10003	03/30/2015	15:45	03/30/2015	18:44	1	179	178	Other	Other			III
5003775	J86118	03/30/2015	15:52	03/30/2015	20:00	1	247	247	Overhead equipment	Overhead Transformer		Replace - New Size	VI
5003785	J86118	03/30/2015	15:52	03/30/2015	20:00	2	496	248	Overhead equipment	Overhead Transformer	Repair	Replace - Same Size	VI
150894905	L74193	03/30/2015	16:07	03/30/2015	17:01	1	54	53	Overhead equipment	Connector	Replace - Same Size		IV
150895116	P25150	03/30/2015	17:25	03/30/2015	18:30	1	65	65	Underground equipment	Meter	Repair		III
150895287	J34356	03/30/2015	17:37	03/30/2015	21:30	1	233	233	Underground equipment	Underground Service	Patrol/Test/Inspect	Repair	V
150895402	P52305	03/30/2015	18:10	03/30/2015	20:13	55	6765	123	Public				IV
150895370	L79157	03/30/2015	18:34	03/30/2015	21:30	1	176	176	Overhead equipment	Lightning Arrestor	Replace - Same Size		IV
150895385	C52001	03/30/2015	18:42	03/30/2015	20:16	34	3196	94	Overhead equipment	Fuse	Replace - Same Size		III
150895398	342004	03/30/2015	18:55	03/30/2015	20:24	1	89	88	Tree related-tree contact	Tree	Trim		VI
150896309	J67132	03/30/2015	22:01	03/30/2015	23:22	1	81	81	Unknown	Connector			III
5003787	Y63539	03/30/2015	22:06	03/31/2015	1:30	1	203	203	Tree related-tree broken	Overhead Service	Repair		IV
150896320	C00002	03/30/2015	22:32	03/31/2015	3:17	1	285	285	Overhead equipment	Connector	Replace - Same Size		I
150896321	M78322	03/30/2015	23:20	03/31/2015	0:56	1	96	96	Overhead equipment	Jumper	Repair		V
150902864	P53341	03/31/2015	3:55	03/31/2015	6:41	1	166	165	Substation equipment	Other			IV
150902863	Q09605	03/31/2015	3:55	03/31/2015	5:13	907	70746	78	Substation equipment	Fuse	Patrol/Test/Inspect		IV
150902865	S36570	03/31/2015	5:28	03/31/2015	6:51	1	83	82	Animal related	Fuse	Repair		VI
150902997	K71810	03/31/2015	7:22	03/31/2015	7:53	61	1891	31	Animal related	Fuse	Replace - Same Size		IV
150903158	C30002	03/31/2015	7:34	03/31/2015	9:28	10	1140	113	Underground equipment	Underground Primary	Patrol/Test/Inspect	Patrol/Test/Inspect	III
150903023	P98190	03/31/2015	7:42	03/31/2015	8:24	8	336	42	Animal related	Transformer Fuse	Repair	Repair	III
150903061	S07536	03/31/2015	7:59	03/31/2015	10:00	1	121	120	Overhead equipment	Overhead Service	Repair	Repair	VI
150903174	C10001	03/31/2015	8:33	03/31/2015	9:20	1	47	47	Animal related	Transformer Fuse	Replace - Same Size		III
150903176	L08226	03/31/2015	8:33	03/31/2015	9:11	1	38	38	Overhead equipment	Overhead Primary	Repair		III
150903336	R09226	03/31/2015	9:12	03/31/2015	9:33	1	21	21	Animal related	Fuse			III
150903372	N70330	03/31/2015	9:21	03/31/2015	9:45	1	24	24	Animal related	Transformer Fuse	Replace - Same Size		I
150903524	D93001	03/31/2015	9:58	03/31/2015	11:20	1	82	81	Overhead equipment	Fuse	Patrol/Test/Inspect	Replace - Same Size	IV

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5003813	R34920	03/31/2015	10:00	03/31/2015	11:09	1	68	68	Jurisdictional				VI
150903547	A16002	03/31/2015	10:02	03/31/2015	11:14	1	72	71	Overhead equipment	Connector	Patrol/Test/Inspect	Repair	I
150903669	Q27185	03/31/2015	10:27	03/31/2015	12:16	1	109	108	Intentional	Meter	Replace - Same Size		VI
5003819	M20221	03/31/2015	10:42	03/31/2015	11:40	1	57	57	Animal related	Fuse	Replace - Same Size		VI
150903983	B82002	03/31/2015	11:26	03/31/2015	12:40	1	74	74	Unknown	Fuse	Repair	Replace - Same Size	I
150904211	J76804	03/31/2015	12:16	03/31/2015	13:38	1	82	82	Animal related	Overhead Service			V
150904571	J67132	03/31/2015	13:45	03/31/2015	15:24	1	99	99	Overhead equipment	Overhead Service			III
150904921	J76804	03/31/2015	15:03	03/31/2015	17:30	1	147	146	Overhead equipment	Overhead Service	Repair	Repair	V
150904999	J05624	03/31/2015	15:04	04/01/2015	0:36	1679	960388	571	Public	Pole	Replace - New Size	Repair	I
150905008	M37191	03/31/2015	15:12	03/31/2015	16:05	8	424	53	Overhead equipment	Disconnect Switch	Replace - Same Size		I
150905079	U04589	03/31/2015	15:31	03/31/2015	17:55	4	576	144	Overhead equipment	Transformer Fuse	Replace - Same Size		II
5003833	Z41528	03/31/2015	15:54	03/31/2015	16:33	1	38	38	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
5003835	R34920	03/31/2015	16:00	03/31/2015	16:47	1	46	46	Overhead equipment	Connector	Replace - Same Size		VI
150905274	Y26520	03/31/2015	16:23	03/31/2015	17:37	1	74	74	Underground equipment	Underground Service	Patrol/Test/Inspect	Replace - Same Size	IV
150905628	D90004	03/31/2015	18:24	03/31/2015	20:33	1	129	128	Underground equipment	Underground Primary		Repair	III
150905997	H11339	03/31/2015	19:31	03/31/2015	20:40	1	69	68	Overhead equipment	Connector	Replace - Same Size		V
150906089	J56342	03/31/2015	21:45	03/31/2015	23:52	498	63246	126	Unknown	Recloser			III
150906110	V36002	03/31/2015	22:17	04/01/2015	3:15	38	11324	297	Underground equipment	Underground Primary	Repair	Repair	II
5003847	L50215	03/31/2015	23:20	04/01/2015	2:01	5	805	161	Overhead equipment	Transformer Fuse	Replace - Same Size		VI
150912756	U33586	04/01/2015	6:25	04/01/2015	7:47	1	82	82	Overhead equipment	Connector	Repair		II
150912970	A91003	04/01/2015	8:07	04/01/2015	10:09	1	122	122	Animal related	Transformer Fuse	Replace - Same Size		I
5003859	P77235	04/01/2015	8:24	04/01/2015	9:37	1	72	72	Animal related	Fuse	Replace - Same Size		VI
150913046	F10003	04/01/2015	8:25	04/01/2015	8:49	1	24	23	Overhead equipment	Connector	Replace - Same Size		III
150913482	L42158	04/01/2015	9:32	04/01/2015	11:54	54	7668	142	Overhead equipment				III
150913375	L42158	04/01/2015	9:32	04/01/2015	11:10	114	11172	98	Overhead equipment	Overhead Primary		Repair	III
5003867	Q11517	04/01/2015	9:38	04/01/2015	10:45	33	2191	66	Animal related	Fuse	Repair		I
150913399	A91002	04/01/2015	9:42	04/01/2015	13:03	1	201	200	Animal related	Underground Primary	Replace - Same Size	Replace - Same Size	I
150913415	S07536	04/01/2015	9:44	04/01/2015	10:20	1	36	36	Overhead equipment	Connector	Patrol/Test/Inspect	Repair	VI
5003871	Q21294	04/01/2015	9:57	04/01/2015	11:00	1	63	63	Animal related	Transformer Fuse	Replace - Same Size		VI
150913582	Z08509	04/01/2015	10:09	04/01/2015	10:53	1	44	43	Overhead equipment	Overhead Transformer			IV
150913617	U54503	04/01/2015	10:13	04/01/2015	11:30	1	77	76	Public	Overhead Service	Repair		II
5003887	K31124	04/01/2015	10:36	04/01/2015	12:20	38	3943	103	Public	Overhead Primary	Repair		I
150913670	U26001	04/01/2015	11:04	04/01/2015	11:45	1	41	41	Public				II
150914069	B57002	04/01/2015	11:10	04/01/2015	12:05	19	1045	54	Animal related	Fuse	Patrol/Test/Inspect	Replace - Same Size	I
150913925	N58144	04/01/2015	11:16	04/01/2015	12:30	1	74	74	Unknown	Transformer Fuse	Replace - Same Size		I
5003889	K31124	04/01/2015	11:32	04/01/2015	12:20	1	47	47	Public	Overhead Primary	Replace - Same Size	Replace - Same Size	I
150914057	Q63835	04/01/2015	11:41	04/01/2015	19:15	1	454	454	Underground equipment	Underground Service	Patrol/Test/Inspect	Repair	V
150914138	B81003	04/01/2015	11:55	04/01/2015	13:17	25	2050	81	Animal related	Fuse	Replace - Same Size		I
150914157	U90566	04/01/2015	12:02	04/01/2015	14:03	1	121	121	Overhead equipment	Transformer Fuse	Replace - Same Size		II
150914424	D36002	04/01/2015	12:59	04/01/2015	14:45	1	106	105	Underground equipment	Underground Primary	Repair	Replace - Same Size	I
150914425	U33509	04/01/2015	12:59	04/01/2015	13:44	1	45	45	Overhead equipment	Transformer Fuse	Replace - Same Size		II
150914601	U04589	04/01/2015	13:39	04/01/2015	14:35	1	56	56	Other				II
150914632	D93001	04/01/2015	13:43	04/01/2015	17:45	1	242	242	Overhead equipment	Overhead Transformer	Replace - Same Size	Repair	IV
150914664	Q63835	04/01/2015	13:51	04/01/2015	15:00	1	69	69	Public	Overhead Service	Repair		V
150914670	U84587	04/01/2015	13:52	04/01/2015	15:25	1	93	92	Overhead equipment	Overhead Primary	Repair		II
150914897	U86500	04/01/2015	14:12	04/01/2015	18:52	7	1960	280	Overhead equipment	Pole	Repair	Repair	II
150914965	Y60593	04/01/2015	14:54	04/01/2015	18:15	1	201	200	Overhead equipment	Overhead Transformer	Replace - Same Size	Repair	IV
150915586	B84002	04/01/2015	15:09	04/01/2015	20:40	10	3310	330	Underground equipment	Underground Transformer	Patrol/Test/Inspect	Reconnect	I
150915040	J06167	04/01/2015	15:09	04/01/2015	18:30	1	201	201	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - New Size	I
150915056	B84002	04/01/2015	15:09	04/01/2015	18:00	15	2565	171	Underground equipment	Underground Transformer	Patrol/Test/Inspect	Reconnect	I
150915055	V03562	04/01/2015	15:12	04/01/2015	17:10	1	118	118	Tree related-tree broken	Overhead Service	Repair		II
150915166	B84003	04/01/2015	15:43	04/02/2015	0:49	1	546	545	Underground equipment	Underground Service	Patrol/Test/Inspect	Repair	I
150915201	J63171	04/01/2015	15:43	04/01/2015	16:43	63	3780	59	Public	Other			III
150915375	B65004	04/01/2015	16:36	04/01/2015	20:39	91	22113	243	Underground equipment	Underground Primary	Patrol/Test/Inspect	Patrol/Test/Inspect	I
150915585	S88551	04/01/2015	17:34	04/01/2015	18:15	64	2624	40	Public	Pole			VI
150915552	M37191	04/01/2015	17:56	04/01/2015	19:30	63	5922	94	Overhead equipment	Jumper	Repair		I

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
150915554	B27009	04/01/2015	17:59	04/01/2015	18:42	1	43	43	Tree related-tree broken	Overhead Service	Repair		I
150915621	R33126	04/01/2015	18:39	04/01/2015	19:50	1	71	71	Overhead equipment	Overhead Service	Repair	Repair	I
5003925	Q34380	04/01/2015	18:43	04/01/2015	22:29	1	225	225	Tree related-tree contact	Overhead Secondary	Replace - New Size	Repair	I
5003929	N74242	04/01/2015	19:42	04/01/2015	20:17	1	34	34	Overhead equipment	Other	Patrol/Test/Inspect		I
150916083	Y39521	04/01/2015	20:01	04/02/2015	0:45	1	284	284	Underground equipment	Underground Primary		Repair	IV
150916111	303002	04/01/2015	20:49	04/01/2015	21:40	1	51	51	Tree related-tree broken	Overhead Service	Repair		VI
150916123	N35852	04/01/2015	21:31	04/01/2015	23:42	1	131	131	Animal related	Transformer Fuse	Replace - Same Size	Replace - Same Size	V
150920110	L73154	04/02/2015	0:52	04/02/2015	1:44	1	52	52	Overhead equipment	Pole		Replace - Same Size	IV
5003937	Q54908	04/02/2015	1:52	04/02/2015	4:11	1	138	138	Tree related-tree broken	Overhead Service	Replace - Same Size		VI
150920177	U11531	04/02/2015	2:04	04/02/2015	5:42	13	2834	218	Weather	Fuse	Repair	Repair	II
150920181	U11531	04/02/2015	2:28	04/02/2015	5:38	1	190	190	Overhead equipment	Transformer Fuse	Repair	Repair	II
150920182	D72002	04/02/2015	2:29	04/02/2015	3:50	1	81	80	Tree related-tree broken	Fuse	Replace - Same Size		I
150920183	N50333	04/02/2015	2:33	04/02/2015	3:56	1	83	83	Overhead equipment	Disconnect Switch	Replace - Same Size		II
150920187	D53002	04/02/2015	2:36	04/02/2015	4:43	80	10160	127	Weather	Fuse	Patrol/Test/Inspect	Replace - Same Size	I
150922630	H07106	04/02/2015	3:54	04/02/2015	5:20	1	86	85	Animal related	Transformer Fuse	Replace - Same Size		IV
150922631	N60181	04/02/2015	3:58	04/02/2015	9:28	1	330	329	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	I
150922645	B19002	04/02/2015	4:07	04/02/2015	9:42	313	104855	335	Overhead equipment	Fuse	Patrol/Test/Inspect	Repair	I
5003945	P26281	04/02/2015	4:22	04/02/2015	7:35	36	6936	192	Overhead equipment	Overhead Primary	Repair		I
150922648	D37003	04/02/2015	4:24	04/02/2015	5:42	1	78	78	Weather	Fuse	Patrol/Test/Inspect	Replace - Same Size	I
150923075	D39002	04/02/2015	4:59	04/02/2015	9:40	6	1686	281	Unknown	Fuse	Replace - Same Size		I
150922673	B61001	04/02/2015	5:26	04/02/2015	7:40	1	134	133	Tree related-tree broken	Fuse	Replace - Same Size		I
5003947	Q11517	04/02/2015	5:52	04/02/2015	8:28	1	155	155	Weather	Transformer Fuse	Replace - Same Size		I
150922745	B53001	04/02/2015	6:09	04/02/2015	10:00	6	1386	230	Weather	Other	Replace - Same Size	Patrol/Test/Inspect	III
5003951	K32915	04/02/2015	6:24	04/02/2015	8:00	1	95	95	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	VI
5003953	P83710	04/02/2015	6:46	04/02/2015	8:25	16	1575	98	Weather	Fuse	Replace - Same Size		I
150922773	B61001	04/02/2015	7:03	04/02/2015	7:54	1	51	51	Tree related-tree broken	Fuse	Replace - Same Size		I
150922771	J79304	04/02/2015	7:03	04/02/2015	7:53	1	50	50	Unknown	Fuse	Replace - Same Size		I
150922784	D96002	04/02/2015	7:08	04/02/2015	9:17	1	129	129	Weather	Transformer Fuse	Replace - Same Size		I
150922799	K71822	04/02/2015	7:13	04/02/2015	8:03	44	2200	50	Underground equipment	Underground Primary	Repair		IV
150922810	D89002	04/02/2015	7:16	04/02/2015	8:15	66	3894	59	Animal related	Fuse	Replace - Same Size		I
150922807	D70002	04/02/2015	7:17	04/02/2015	8:38	1	81	81	Overhead equipment				I
150923191	A56013	04/02/2015	7:22	04/02/2015	10:05	82	13366	163	Overhead equipment	Insulator	Replace - Same Size	Repair	I
150922904	A56013	04/02/2015	7:27	04/02/2015	9:12	1223	128415	104	Overhead equipment	Overhead Primary	Replace - Same Size	Repair	I
5003957	P83710	04/02/2015	7:27	04/02/2015	8:29	1	61	61	Weather	Fuse	Replace - Same Size		I
150922839	B61001	04/02/2015	7:29	04/02/2015	7:53	1	24	24	Tree related-tree broken	Fuse	Replace - Same Size		I
150922917	S66594	04/02/2015	7:31	04/02/2015	8:10	33	1287	39	Animal related	Fuse	Replace - Same Size		VI
150922870	D28124	04/02/2015	7:34	04/02/2015	12:05	1	271	270	Overhead equipment	Pole	Patrol/Test/Inspect	Replace - Same Size	I
150922933	D28124	04/02/2015	7:55	04/02/2015	8:59	1	64	63	Weather	Fuse	Replace - Same Size		I
5003963	R16511	04/02/2015	8:06	04/02/2015	9:31	98	8327	84	Weather	Pole	Replace - Same Size	Replace - Same Size	I
5003967	K15207	04/02/2015	8:08	04/02/2015	9:10	1	61	61	Overhead equipment	Transformer Fuse			VI
5004011	R16511	04/02/2015	8:13	04/02/2015	12:17	2	489	244	Overhead equipment	Pole	Repair		I
5003981	M19222	04/02/2015	8:33	04/02/2015	10:10	1	96	96	Animal related	Transformer Fuse			VI
5003991	R34920	04/02/2015	8:54	04/02/2015	10:59	1	124	124	Animal related	Transformer Fuse	Replace - Same Size		VI
150923135	B00004	04/02/2015	8:59	04/02/2015	10:06	49	3283	66	Unknown	Fuse	Replace - Same Size		I
150923163	S15560	04/02/2015	9:09	04/02/2015	10:00	1	51	50	Animal related	Fuse	Replace - Same Size		VI
150923239	B58002	04/02/2015	9:29	04/02/2015	12:31	1	182	181	Overhead equipment	Disconnect Switch	Patrol/Test/Inspect	Replace - Same Size	I
150923279	B19002	04/02/2015	9:36	04/02/2015	9:42	3	18	5	Overhead equipment				I
150923309		04/02/2015	9:40	04/02/2015	18:06	1	506	505	Underground equipment	Underground Transformer	Replace - Same Size	Repair	III
150923333	K82202	04/02/2015	9:44	04/02/2015	10:27	1	43	43	Other	Overhead Service			III
5004023	K67912	04/02/2015	9:54	04/02/2015	10:45	1	50	50	Animal related	Fuse	Replace - Same Size	Replace - Same Size	VI
150923392	K89144	04/02/2015	9:56	04/02/2015	11:15	1	79	78	Animal related	Fuse	Replace - Same Size	Repair	III
150923459	A56013	04/02/2015	10:06	04/02/2015	10:33	89	2403	27	Overhead equipment	Fuse	Patrol/Test/Inspect		I
5004025	Y69553	04/02/2015	10:10	04/02/2015	14:01	5	1157	231	Weather	Overhead Transformer	Replace - Same Size		IV
150923575	B57002	04/02/2015	10:35	04/02/2015	12:00	46	3910	85	Unknown	Fuse	Patrol/Test/Inspect	Replace - Same Size	I
5004045	R16511	04/02/2015	10:44	04/02/2015	12:00	1	75	75	Animal related	Fuse	Replace - Same Size		I
150923748	308004	04/02/2015	11:26	04/02/2015	13:15	7	763	108	Overhead equipment	Overhead Secondary	Raise	Repair	VI

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
150924624	J79305	04/02/2015	11:42	04/02/2015	18:00	2	756	377	Overhead equipment	Pole	Replace - Urgent		I
150923826	J79305	04/02/2015	11:42	04/02/2015	15:35	46	10718	232	Overhead equipment	Pole	Switch/Reset	Replace - New Size	I
150923817	M73331	04/02/2015	11:46	04/02/2015	13:00	1	74	74	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	V
150923853	R05186	04/02/2015	12:00	04/02/2015	13:39	1	99	98	Other	Underground Service			I
5004055	Z10501	04/02/2015	12:02	04/02/2015	13:40	1	97	97	Tree related-tree broken	Fuse	Replace - Same Size		IV
150923878	M83327	04/02/2015	12:07	04/02/2015	13:34	1	87	87	Underground equipment	Underground Primary	Repair		V
5004057	L62927	04/02/2015	12:15	04/02/2015	15:25	1	189	189	Tree related-tree broken	Pole	Patrol/Test/Inspect		VI
150924201	R84148	04/02/2015	12:31	04/02/2015	18:06	46	15410	335	Overhead equipment	Pole	Replace - Same Size		I
150923972	Q63835	04/02/2015	12:37	04/02/2015	13:25	1	48	48	Tree related-tree broken	Overhead Service	Repair		V
150924018	Y48002	04/02/2015	12:50	04/02/2015	14:05	1	75	75	Tree related-tree contact	Overhead Service	Repair	Replace - Same Size	IV
5004069	Q54908	04/02/2015	12:59	04/02/2015	14:04	36	2337	64	Animal related	Fuse	Replace - Same Size		VI
150924247	L86176	04/02/2015	13:56	04/02/2015	15:40	1	104	104	Weather	Lightning Arrestor	Repair		IV
5004077	P26283	04/02/2015	14:12	04/02/2015	16:06	1	113	113	Weather	Transformer Fuse	Replace - Same Size		I
150924329	N93260	04/02/2015	14:21	04/02/2015	15:20	1	59	59	Overhead equipment	Other			III
5004083	Q82906	04/02/2015	14:55	04/02/2015	15:33	1	37	37	Overhead equipment	Underground Primary	Repair	Repair	VI
5004085	Q70161	04/02/2015	15:10	04/02/2015	16:04	1	54	53	Unknown	Transformer Fuse	Replace - Same Size		I
150924622	X89754	04/02/2015	15:27	04/02/2015	21:00	1	333	332	Tree related-tree broken	Tree		Remove	IV
150924792	X89754	04/02/2015	15:27	04/02/2015	16:14	681	32007	46	Tree related-tree broken				IV
150924796	X89754	04/02/2015	15:27	04/02/2015	16:39	1	72	71	Tree related-tree broken				IV
5004087	L62927	04/02/2015	15:31	04/02/2015	15:42	1	10	10	Tree related-tree broken	Pole	Patrol/Test/Inspect		VI
5004089	R29904	04/02/2015	15:37	04/02/2015	17:03	24	2046	85	Weather	Fuse	Replace - Same Size		VI
150924651	D67001	04/02/2015	15:51	04/02/2015	16:28	1	37	37	Weather	Transformer Fuse	Repair		IV
150924725	Q63835	04/02/2015	16:04	04/02/2015	19:06	81	14742	181	Tree related-tree broken	Tree	Trim		V
150924697	S61580	04/02/2015	16:04	04/02/2015	17:10	47	3102	66	Weather	Fuse	Replace - New Size		VI
150924773	M51275	04/02/2015	16:32	04/02/2015	17:31	2	118	59	Animal related	Fuse			III
150924876	S61580	04/02/2015	17:28	04/02/2015	20:55	5	1035	207	Overhead equipment	Overhead Transformer		Replace - Same Size	VI
150924890	S61580	04/02/2015	17:33	04/02/2015	18:05	7	224	31	Weather	Fuse	Replace - New Size		VI
5004099	R95520	04/02/2015	17:35	04/02/2015	18:25	1	49	49	Animal related	Transformer Fuse	Replace - Same Size		I
150924885	N13861	04/02/2015	17:38	04/02/2015	18:10	1	32	31	Tree related-tree contact	Tree	Remove		V
150924920	K27150	04/02/2015	17:42	04/02/2015	19:15	1	93	92	Animal related	Fuse	Replace - Same Size		VI
5004101	Y36559	04/02/2015	17:45	04/02/2015	18:34	3	144	48	Weather	Transformer Fuse			IV
150924936	U80001	04/02/2015	17:53	04/02/2015	18:49	1	56	56	Overhead equipment	Overhead Service			II
150924959	P73182	04/02/2015	18:19	04/02/2015	22:39	1	260	259	Weather	Overhead Transformer		Replace - Same Size	VI
5004103	R08910	04/02/2015	18:56	04/02/2015	21:56	1	179	179	Weather	Overhead Primary	Repair	Repair	VI
150924985	B73002	04/02/2015	18:59	04/02/2015	21:01	1	122	121	Overhead equipment	Connector	Replace - Same Size		I
150925302	K27150	04/02/2015	20:02	04/02/2015	21:50	3	324	107	Tree related-tree broken	Transformer Fuse	Replace - Same Size		VI
150925285	T01534	04/02/2015	20:22	04/02/2015	21:28	1	66	65	Overhead equipment	Overhead Service	Patrol/Test/Inspect	Repair	VI
150925288	A81001	04/02/2015	20:30	04/03/2015	2:26	1	356	356	Underground equipment	Underground Service	Disconnect	Repair	I
5004111	X96543	04/02/2015	20:41	04/02/2015	21:45	23	1452	63	Overhead equipment	Fuse	Replace - Same Size		IV
150925338	D39001	04/02/2015	20:59	04/02/2015	22:11	1	72	72	Animal related	Fuse	Replace - Same Size		I
150925379	R60552	04/02/2015	21:17	04/02/2015	22:46	3	267	88	Overhead equipment	Fuse	Replace - Same Size		IV
150925374	S53542	04/02/2015	22:14	04/03/2015	0:30	6	816	136	Tree related-tree broken	Overhead Primary	Repair		VI
150930065	S02502	04/02/2015	22:52	04/03/2015	1:30	316	49928	158	Weather				VI
150925422	R53391	04/02/2015	23:00	04/03/2015	6:14	1	434	434	Weather	Fuse	Replace - Same Size	Replace - Same Size	V
150930685	L99392	04/02/2015	23:02	04/03/2015	17:00	19	20482	1078	Weather	Overhead Primary	Patrol/Test/Inspect	Repair	V
5004113	K15207	04/02/2015	23:06	04/03/2015	0:35	1	88	88	Weather	Fuse	Replace - Same Size		VI
150925469	329146	04/02/2015	23:11	04/03/2015	0:36	5	425	85	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	V
5004135	J85161	04/02/2015	23:15	04/03/2015	5:32	3	1130	376	Weather	Overhead Transformer	Replace - Same Size	Replace - Same Size	VI
150925502	Q15844	04/02/2015	23:26	04/03/2015	4:25	1	299	299	Overhead equipment	Overhead Transformer		Replace - Same Size	V
5004119	HC9327	04/02/2015	23:36	04/03/2015	2:03	1	146	146	Weather	Fuse	Replace - Same Size		VI
5004139	J85161	04/02/2015	23:38	04/03/2015	0:35	1	56	56	Overhead equipment	Overhead Transformer	Repair	Replace - Same Size	VI
5004137	J85161	04/02/2015	23:41	04/03/2015	0:35	3	162	54	Overhead equipment	Transformer Fuse	Replace - Same Size	Replace - Same Size	VI
5004123	P77237	04/02/2015	23:44	04/03/2015	2:08	1	144	144	Weather	Fuse	Replace - Same Size		VI
150925528	M49424	04/02/2015	23:48	04/03/2015	4:12	1	264	264	Weather	Fuse	Replace - Same Size	Replace - Same Size	V
5004127	J30203	04/02/2015	23:50	04/03/2015	11:37	332	76245	706	Weather	Tree	Trim	Trim	VI
150930022	S86580	04/02/2015	23:58	04/03/2015	2:05	178	22606	126	Weather	Fuse	Repair		VI

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
150930029	Q85162	04/03/2015	0:12	04/03/2015	3:45	2	426	213	Overhead equipment	Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
150930038	R73841	04/03/2015	0:14	04/03/2015	2:04	1	110	109	Weather	Transformer Fuse	Replace - Same Size	Replace - Same Size	V
150930053	P73158	04/03/2015	0:38	04/03/2015	4:30	1	232	232	Overhead equipment	Transformer Fuse	Replace - Same Size	Replace - Same Size	VI
150930096	Q85162	04/03/2015	0:39	04/03/2015	3:01	42	5964	142	Weather	Fuse	Replace - Same Size		VI
150930057	T23528	04/03/2015	0:44	04/03/2015	1:15	1	31	31	Overhead equipment				VI
150930078	P58156	04/03/2015	1:10	04/03/2015	2:27	13	1001	76	Weather	Fuse	Repair	Repair	VI
150930075	S24597	04/03/2015	1:12	04/03/2015	8:33	1	441	440	Weather	Fuse	Patrol/Test/Inspect	Repair	VI
150930266	M09143	04/03/2015	1:13	04/03/2015	7:21	20	7360	368	Overhead equipment	Jumper	Replace - Same Size	Repair	VI
150930136	S47585	04/03/2015	1:14	04/03/2015	1:55	14	574	40	Overhead equipment	Fuse		Replace - Same Size	VI
150930126	S86580	04/03/2015	1:15	04/03/2015	2:36	48	3888	80	Weather	Fuse	Repair		VI
150930086	K19115	04/03/2015	1:16	04/03/2015	4:30	1	194	194	Tree related-tree broken	Overhead Service	Repair		VI
5004141	HC9327	04/03/2015	1:18	04/03/2015	2:30	1	71	71	Weather				VI
150930108	S86580	04/03/2015	1:22	04/03/2015	2:38	1	76	76	Weather	Fuse	Repair		VI
150930120	S49550	04/03/2015	1:22	04/03/2015	2:15	15	795	53	Overhead equipment	Fuse		Replace - Same Size	VI
150930187	S61580	04/03/2015	1:24	04/03/2015	2:30	46	3036	65	Weather	Fuse	Replace - Same Size	Replace - Same Size	VI
150930208	S61582	04/03/2015	1:26	04/03/2015	3:00	39	3666	94	Weather	Fuse	Replace - Same Size		VI
5004143	P77237	04/03/2015	2:08	04/03/2015	7:19	2	620	310	Overhead equipment	Overhead Transformer			VI
150930190	T09559	04/03/2015	2:16	04/03/2015	5:37	16	3216	200	Overhead equipment	Other	Repair	Repair	VI
150930205	S86580	04/03/2015	3:00	04/03/2015	7:17	3	771	256	Weather	Overhead Transformer	Repair	Repair	VI
150930228	Y93544	04/03/2015	3:06	04/03/2015	4:12	1	66	66	Overhead equipment	Disconnect Switch	Repair	Replace - Same Size	IV
150930230	S61582	04/03/2015	3:18	04/03/2015	4:00	1	42	42	Weather	Fuse	Replace - Same Size		VI
150930249	K27150	04/03/2015	3:47	04/03/2015	5:14	27	2349	87	Weather	Fuse	Replace - Same Size		VI
150930253	325007	04/03/2015	4:19	04/03/2015	8:18	10	2390	239	Overhead equipment	Overhead Secondary	Advise Customer	Repair	VI
5004149	J30203	04/03/2015	4:51	04/03/2015	5:55	10	632	63	Tree related-tree contact	Overhead Primary	Replace - Same Size	Replace - Same Size	VI
150930291	K27123	04/03/2015	6:08	04/03/2015	7:15	1	67	66	Tree related-tree broken	Overhead Service	Patrol/Test/Inspect	Repair	VI
150930335	T23527	04/03/2015	6:50	04/03/2015	8:58	11	1408	128	Weather	Transformer Fuse			VI
150930548	61079	04/03/2015	6:52	04/03/2015	10:22	1341	281610	209	Overhead equipment	Crossarm	Patrol/Test/Inspect	Replace - New Size	VI
150930343	343006	04/03/2015	6:53	04/03/2015	9:36	5	815	162	Weather	Overhead Primary	Patrol/Test/Inspect		VI
150930473	Q28141	04/03/2015	7:05	04/03/2015	12:07	1	302	301	Overhead equipment	Jumper	Repair	Repair	VI
150930537	S21529	04/03/2015	7:20	04/03/2015	12:49	1	329	329	Weather	Underground Transformer	Repair	Replace - Same Size	VI
150930564	307003	04/03/2015	7:24	04/03/2015	9:00	6	576	95	Overhead equipment	Fuse	Repair		VI
150930556	S52515	04/03/2015	7:32	04/03/2015	10:45	15	2895	193	Overhead equipment	Other	Repair	Repair	VI
150930910	K11376	04/03/2015	8:09	04/03/2015	13:06	11	3267	296	Overhead equipment	Jumper	Repair	Repair	V
150930639	P58156	04/03/2015	8:34	04/03/2015	10:18	1	104	104	Overhead equipment	Fuse	Repair	Repair	VI
150930669	J50185	04/03/2015	8:49	04/03/2015	9:56	66	4422	67	Animal related	Fuse	Repair	Repair	III
150930670	R06211	04/03/2015	8:50	04/03/2015	9:48	1	58	58	Animal related	Fuse	Replace - Same Size		II
150930674	J50185	04/03/2015	8:51	04/03/2015	9:56	1	65	65	Animal related	Fuse	Repair	Repair	III
150930676	J50185	04/03/2015	8:53	04/03/2015	9:56	1	63	63	Animal related	Fuse	Repair	Repair	III
150930681	J50185	04/03/2015	8:53	04/03/2015	9:56	22	1386	63	Animal related	Fuse	Repair	Repair	III
150930697	J50185	04/03/2015	8:57	04/03/2015	9:56	63	3717	59	Animal related	Fuse	Repair	Repair	III
150930700	S36570	04/03/2015	9:04	04/03/2015	9:43	1	39	39	Weather	Fuse	Repair		VI
5004155	J99141	04/03/2015	9:18	04/03/2015	14:00	4	1127	281	Tree related-tree contact	Overhead Primary		Repair	VI
5004157	Q95247	04/03/2015	9:22	04/03/2015	10:57	1	94	94	Overhead equipment	Fuse	Repair	Repair	VI
150930770	L46811	04/03/2015	9:46	04/03/2015	11:10	1	84	84	Animal related	Transformer Fuse	Replace - Same Size		V
150930923	M61302	04/03/2015	9:50	04/03/2015	14:03	4	1012	253	Overhead equipment	Overhead Transformer	Replace - Same Size	Replace - Same Size	V
150930784	325008	04/03/2015	9:53	04/03/2015	11:30	1	97	96	Overhead equipment	Overhead Service	Repair		VI
5004167	P77237	04/03/2015	10:21	04/03/2015	11:40	1	78	78	Weather	Fuse			VI
5004169	J30201	04/03/2015	10:36	04/03/2015	17:30	1	413	413	Underground equipment	Underground Service	Patrol/Test/Inspect	Repair	VI
150930934	X75512	04/03/2015	10:37	04/03/2015	11:30	1	53	52	Animal related	Transformer Fuse	Replace - Same Size		IV
5004173	P26281	04/03/2015	10:49	04/03/2015	11:49	1	59	59	Animal related	Transformer Fuse	Replace - Same Size		I
5004175	Q95247	04/03/2015	10:50	04/03/2015	11:59	1	68	68	Overhead equipment	Transformer Fuse	Repair	Repair	VI
5004179	X60597	04/03/2015	11:28	04/03/2015	12:03	60	2091	34	Overhead equipment	Jumper	Repair		IV
150930998	329146	04/03/2015	11:36	04/03/2015	14:25	3	507	169	Tree related-tree broken	Overhead Primary	Cut in Clear	Repair	V
150931015	N35819	04/03/2015	11:38	04/03/2015	14:20	1	162	161	Tree related-tree broken	Overhead Service	Repair		V
150931034	S78551	04/03/2015	11:51	04/03/2015	13:44	1	113	113	Overhead equipment				VI
150931198	S93507	04/03/2015	12:18	04/03/2015	16:25	18	4446	247	Overhead equipment	Disconnect Switch			VI