Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
150931144	S93507	04/03/2015	12:18	04/03/2015	13:18	297	17820	60	Overhead equipment	Disconnect Switch			VI
150931102	B84002	04/03/2015	12:23	04/03/2015	15:00	86	13502	156	Overhead equipment	Jumper	Repair		I
150931117	L35138	04/03/2015	12:32	04/03/2015	13:30	31	1798	58	Animal related	Fuse	Replace - Same Size		III
150931145	K46388	04/03/2015	12:50	04/03/2015	13:54	1	64	64	Weather				V
150931157	K46388	04/03/2015	13:03	04/03/2015	17:44	1	281	281	Weather	Underground Primary	Patrol/Test/Inspect	Patrol/Test/Inspect	V
5004189	Z10501	04/03/2015	13:03	04/03/2015	14:15	1	71	71	Overhead equipment	Overhead Primary			IV
5004203	X66580	04/03/2015	13:22	04/03/2015	14:32	67	4676	69	Tree related-tree broken	Tree	Remove		IV
150931208	B80002	04/03/2015	13:26	04/03/2015	16:40	86	16684	194	Animal related	Underground Primary	Switch/Reset		I
150931196	N73122	04/03/2015	13:34	04/03/2015	15:26	1	112	111	Overhead equipment	Overhead Primary	Repair		IV
5004201	X66580	04/03/2015	13:40	04/03/2015	18:07	3	799	266	Tree related-tree broken	Fuse	Replace - Same Size	Replace - Same Size	IV
150931247	M18131	04/03/2015	14:04	04/03/2015	14:27	9	207	23	Animal related	Fuse	Replace - Same Size		III
150931239	P69173	04/03/2015	14:07	04/03/2015	15:15	1	68	68	Animal related	Transformer Fuse	Replace - Same Size		III
150931267	K89142	04/03/2015	14:29	04/03/2015	15:45	1	76	75	Animal related	Transformer Fuse	Replace - Same Size		III
150931274	N35851	04/03/2015	14:33	04/03/2015	15:32	1	59	59	Overhead equipment	Transformer Fuse	Replace - Same Size		V
150931283	S93504	04/03/2015	14:40	04/03/2015	15:53	5	365	73	Overhead equipment	Disconnect Switch			VI
150931294	S92559	04/03/2015	14:47	04/03/2015	15:25	225	8550	37	Overhead equipment	Disconnect Switch			VI
150931311	L99392	04/03/2015	15:00	04/03/2015	19:00	1	240	239	Weather	Overhead Primary	Patrol/Test/Inspect	Repair	V
150931356	S92559	04/03/2015	15:46	04/03/2015	16:32	8	368	45	Overhead equipment				VI
150931378	U93507	04/03/2015	16:09	04/03/2015	17:15	1	66	65	Overhead equipment	Overhead Service	Repair		II
150931521	D33142	04/03/2015	16:25	04/03/2015	20:15	23	5290	229	Overhead equipment	Disconnect Switch	Patrol/Test/Inspect	Repair	I
150931398	M04365	04/03/2015	16:28	04/03/2015	20:21	19	4427	232	Tree related-tree broken	Overhead Primary	Patrol/Test/Inspect	Repair	V
150931400	S93504	04/03/2015	16:32	04/03/2015	16:40	1	8	8	Overhead equipment				VI
150931403	N67315	04/03/2015	16:35	04/03/2015	17:31	1	56	56	Other	Other			I
150931407	P98191	04/03/2015	16:37	04/03/2015	17:37	54	3240	59	Overhead equipment	Connector			III
150931418	R01153	04/03/2015	16:53	04/03/2015	19:22	1	149	148	Overhead equipment	Overhead Transformer			III
150931428	K73361	04/03/2015	17:11	04/03/2015	17:30	1	19	18	Overhead equipment				IV
150931484	L79180	04/03/2015	18:08	04/03/2015	23:43	1	335	334	Underground equipment	Underground Transformer		Replace - New Size	IV
150931549	A27011	04/03/2015	18:16	04/03/2015	23:49	1	333	332	Underground equipment	Underground Primary	Switch/Reset	Repair	I
150931471	A27011	04/03/2015	18:16	04/03/2015	21:35	73	14527	198	Underground equipment	Underground Primary	Switch/Reset	Repair	I
150931475	L79180	04/03/2015	18:19	04/03/2015	20:32	1	133	133	Overhead equipment				IV
5004219	N94182	04/03/2015	19:36	04/03/2015	20:51	1	74	74	Unknown	Transformer Fuse	Repair		I
150931538	J39391	04/03/2015	20:56	04/04/2015	6:30	1	574	574	Underground equipment	Underground Service			III
150931544	U60518	04/03/2015	21:16	04/03/2015	23:27	1	131	130	Overhead equipment	Disconnect Switch	Repair		II
150931554	P09307	04/03/2015	22:02	04/03/2015	23:42	1	100	100	Overhead equipment	Overhead Secondary	Repair		V
5004221	J20931	04/03/2015	22:18	04/04/2015	3:43	1	324	324	Overhead equipment	Overhead Transformer		Replace - New Size	VI
5004223	N22295	04/03/2015	22:24	04/03/2015	23:59	1	94	94	Weather	Fuse	Replace - Same Size		VI
150940010	M81403	04/04/2015	0:03	04/04/2015	0:42	5	195	39	Overhead equipment	Transformer Fuse	Repair		V
5004227	R10903	04/04/2015	2:29	04/04/2015	8:04	1	334	334	Overhead equipment	Overhead Secondary		Repair	VI
150940028	P09305	04/04/2015	2:39	04/04/2015	4:21	1	102	101	Animal related	Fuse	Replace - Same Size		V
150940040	R48166	04/04/2015	5:28	04/04/2015	8:35	1	187	187	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	IV
5004231	R10903	04/04/2015	6:11	04/04/2015	7:50	1	98	98	Overhead equipment				VI
150940064	J79304	04/04/2015	7:16	04/04/2015	9:00	8	832	104	Animal related	Fuse	Replace - Same Size		I
5004233	N22295	04/04/2015	7:22	04/04/2015	8:40	1	77	77	Overhead equipment	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
150940087	B77001	04/04/2015	8:09	04/04/2015	8:51	1	42	42	Other				I
150940091	M36185	04/04/2015	8:14	04/04/2015	9:11	8	456	57	Animal related	Fuse	Replace - Same Size		I
5004237	X87576	04/04/2015	8:26	04/04/2015	11:20	1	173	173	Animal related	Disconnect Switch			IV
5004239	X78536	04/04/2015	9:08	04/04/2015	10:25	1	76	76	Tree related-tree broken	Transformer Fuse			IV
150940171	L24124	04/04/2015	9:12	04/04/2015	10:00	4	192	47	Animal related	Fuse	Replace - Same Size		III
150940147	R33127	04/04/2015	9:14	04/04/2015	15:09	1	355	354	Overhead equipment	Overhead Transformer	Replace - Same Size	Patrol/Test/Inspect	I
5004241	Y63527	04/04/2015	9:27	04/04/2015	10:43	1	75	75	Animal related	Transformer Fuse	Replace - Same Size		IV
150940165	R06211	04/04/2015	9:38	04/04/2015	10:10	1	32	31	Animal related	Fuse	Replace - Same Size		II
5004245	X02549	04/04/2015	10:38	04/04/2015	10:45	1	6	6	Animal related	Transformer Fuse			IV
150940210	342004	04/04/2015	10:56	04/04/2015	11:30	1	34	33	Overhead equipment	Overhead Service	Repair		VI
150940216	P60170	04/04/2015	11:00	04/04/2015	11:35	78	2730	34	Overhead equipment	Overhead Primary		Repair	VI
150940257	D87001	04/04/2015	11:08	04/04/2015	20:32	8	4512	564	Underground equipment	Underground Primary		Repair	I
150940218	L35283	04/04/2015	11:08	04/04/2015	11:53	1	45	45	Overhead equipment	Connector	Repair		III

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
150940249	K78351	04/04/2015	11:50	04/04/2015	13:18	1	88	88	Overhead equipment	Overhead Service			IV
150940271	L99392	04/04/2015	12:19	04/04/2015	13:36	5	385	76	Overhead equipment	Fuse	Replace - Same Size		V
150940276	D72001	04/04/2015	12:28	04/04/2015	13:01	36	1188	33	Animal related	Fuse	Replace - Same Size		I
150940298	D31017	04/04/2015	12:59	04/04/2015	14:49	1	110	109	Other	Other	Patrol/Test/Inspect	Patrol/Test/Inspect	III
150940304	J61121	04/04/2015	13:08	04/04/2015	13:39	1	31	30	Overhead equipment	Overhead Service			III
150940346	P49183	04/04/2015	14:54	04/04/2015	15:55	15	915	60	Animal related	Fuse	Replace - Same Size	Replace - Same Size	I
5004249	Q24310	04/04/2015	15:01	04/04/2015	20:20	2	637	318	Tree related-tree broken	Overhead Primary		Replace - Same Size	VI
150940361	R41131	04/04/2015	15:28	04/04/2015	16:39	1	71	71	Overhead equipment	Overhead Transformer	Replace - Same Size		VI
150940384	V23530	04/04/2015	16:19	04/04/2015	17:46	6	522	87	Animal related	Transformer Fuse	Repair	Replace - Same Size	II
150940392	A36002	04/04/2015	16:20	04/04/2015	20:10	19	4370	230	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	I
150940398	A91003	04/04/2015	16:42	04/04/2015	18:11	1	89	89	Animal related	Fuse	Replace - Same Size	Repair	I
150940402	B73003	04/04/2015	16:47	04/04/2015	17:55	1	68	68	Overhead equipment	Fuse	Repair		I
5004251	X78536	04/04/2015	16:54	04/04/2015	23:48	1	413	413	Overhead equipment	Overhead Transformer	Repair		IV
150940412	B62003	04/04/2015	16:58	04/04/2015	18:37	16	1584	98	Animal related	Underground Primary	Replace - Same Size		I
5004255	X02549	04/04/2015	17:06	04/04/2015	19:30	713	102208	143	Tree related-tree broken	Overhead Primary			IV
150940418	B73003	04/04/2015	17:07	04/04/2015	18:00	1	53	53	Overhead equipment	Fuse	Repair		I
5004271	K57211	04/04/2015	17:10	04/04/2015	20:48	1	217	217	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	VI
150940450	K36151	04/04/2015	17:22	04/04/2015	19:50	6	888	148	Underground equipment	Underground Primary	Switch/Reset	Repair	III
150950022	J05138	04/05/2015	2:25	04/05/2015	10:50	1	505	505	Public	Transformer Fuse	Replace - Same Size		I
150950024	N35851	04/05/2015	2:59	04/05/2015	4:27	1	88	88	Overhead equipment	Overhead Secondary	Repair		V
150950033	D41003	04/05/2015	4:41	04/05/2015	8:13	26	5512	211	Public	Fuse	Replace - Same Size	Repair	I
5004317	HB6283	04/05/2015	4:48	04/05/2015	9:15	1	266	266	Underground equipment	Underground Service	Patrol/Test/Inspect	Repair	VI
150950039	N35851	04/05/2015	6:19	04/05/2015	7:10	1	51	50	Animal related	Transformer Fuse	Replace - Same Size		V
150950058	A17026	04/05/2015	8:31	04/05/2015	10:20	1	109	108	Animal related	Fuse	Replace - Same Size		I
150950060	A50002	04/05/2015	8:51	04/05/2015	9:35	1	44	43	Animal related	Transformer Fuse	Replace - Same Size		I
5004321	R16511	04/05/2015	9:38	04/05/2015	10:45	84	5596	66	Unknown	Fuse	Replace - Same Size		I
150950068	L24123	04/05/2015	9:45	04/05/2015	10:30	1	45	45	Animal related	Transformer Fuse	Replace - Same Size		III
5004323	R16511	04/05/2015	9:51	04/05/2015	10:56	5	323	64	Unknown	Fuse	Replace - Same Size		I
5004329	R16511	04/05/2015	10:35	04/05/2015	10:52	1	16	16	Unknown	Fuse	Replace - Same Size		I
150950088	Q01282	04/05/2015	10:53	04/05/2015	14:15	1	202	201	Underground equipment	Underground Primary	Repair		III
150950098	U32594	04/05/2015	11:34	04/05/2015	14:10	1	156	156	Public	Overhead Service	Repair		II
5004333	Y86593	04/05/2015	12:42	04/05/2015	14:15	1	92	92	Animal related	Transformer Fuse	Replace - Same Size		IV
150950111	U30003	04/05/2015	12:55	04/05/2015	15:03	1	128	127	Public	Overhead Service	Repair		II
150950364	S27598	04/05/2015	13:15	04/05/2015	15:41	1	146	145	Overhead equipment	Fuse			VI
150950379	J79304	04/05/2015	14:15	04/05/2015	15:51	1	96	95	Unknown	Fuse	Replace - Same Size		I
5004337	P20930	04/05/2015	15:15	04/05/2015	17:15	1	119	119	Overhead equipment	Connector	Replace - New Size		VI
150950427	B68001	04/05/2015	16:48	04/05/2015	17:42	1	54	54	Overhead equipment	Overhead Service	Repair		III
150950434	Q91175	04/05/2015	17:14	04/05/2015	21:00	1	226	226	Overhead equipment	Overhead Service		Repair	I
150950449	K71810	04/05/2015	17:31	04/05/2015	18:59	1	88	88	Public	Underground Transformer	Switch/Reset		IV
150950469	D39001	04/05/2015	17:49	04/05/2015	20:46	3	531	177	Unknown	Fuse	Repair		I
5004339	Q95247	04/05/2015	18:23	04/05/2015	19:35	1	71	71	Overhead equipment	Fuse	Replace - Same Size		VI
150950524	L00133	04/05/2015	19:25	04/05/2015	20:35	1	70	69	Underground equipment	Underground Service	Switch/Reset	Repair	III
150950485	A56015	04/05/2015	19:33	04/05/2015	21:05	6	552	91	Public	Pole	Patrol/Test/Inspect	Repair	I
150950547	M37191	04/05/2015	20:19	04/05/2015	23:05	1	166	165	Tree related-tree contact	Overhead Service	Repair		I
150950555	V23001	04/05/2015	20:45	04/05/2015	21:32	9	423	46	Unknown	Transformer Fuse	Repair	Replace - Same Size	II
150950576	P18104	04/05/2015	22:52	04/06/2015	3:05	1	253	252	Underground equipment	Underground Primary		Repair	IV
150965603	L08226	04/06/2015	5:49	04/06/2015	6:54	1	65	65	Overhead equipment	Overhead Primary			III
150965702	B27007	04/06/2015	7:24	04/06/2015	7:55	1	31	30	Animal related	Fuse	Replace - Same Size		I
150965891	335003	04/06/2015	8:23	04/06/2015	9:34	1	71	70	Overhead equipment	Jumper	Repair		VI
5004345	N05172	04/06/2015	9:13	04/06/2015	9:54	2	80	40	Animal related	Fuse	Replace - Same Size		I
150966196		04/06/2015	9:24	04/06/2015	10:16	1	52	51	Animal related	Fuse	Replace - Same Size		I
150966240	R04414	04/06/2015	9:28	04/06/2015	10:11	39	1677	43	Animal related	Fuse	Replace - Same Size		V
150966271	B28006	04/06/2015	9:35	04/06/2015	14:49	1	314	313	Underground equipment	Jumper	Repair		I
5004349	K32915	04/06/2015	10:10	04/06/2015	11:10	1	59	59	Tree related-tree broken	Fuse	Replace - Same Size		VI
150966526	B68002	04/06/2015	10:24	04/06/2015	10:50	1	26	26	Animal related	Fuse	Replace - Same Size		III
150966812	U61572	04/06/2015	11:12	04/06/2015	11:53	1	41	40	Public	Transformer Fuse	Repair		II

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
150966952	M42107	04/06/2015	11:28	04/06/2015	12:57	1	89	88	Other	Overhead Service			I
150966972	U95003	04/06/2015	11:33	04/06/2015	11:46	1	13	13	Overhead equipment	Overhead Service	Repair	Repair	II
150967027	T09559	04/06/2015	11:45	04/06/2015	13:20	1	95	94	Overhead equipment	Connector	Patrol/Test/Inspect	Repair	VI
150967047	N93260	04/06/2015	11:48	04/06/2015	15:30	1	222	222	Public	Pole		Repair	III
150967105	A80002	04/06/2015	12:00	04/06/2015	13:02	10	620	62	Unknown	Fuse	Repair		I
150967111	C37002	04/06/2015	12:02	04/06/2015	12:29	1	27	27	Animal related	Fuse	Replace - Same Size		III
150967120	D31016	04/06/2015	12:02	04/06/2015	12:37	1	35	34	Overhead equipment	Connector	Repair		III
5004367	Q95249	04/06/2015	13:51	04/06/2015	17:45	1	233	233	Underground equipment	Underground Secondary	Patrol/Test/Inspect	Repair	VI
150967708	R33126	04/06/2015	14:02	04/06/2015	15:18	1	76	75	Weather	Transformer Fuse	Replace - Same Size	Patrol/Test/Inspect	I
5004371	L93133	04/06/2015	14:06	04/06/2015	15:38	3	273	91	Animal related	Transformer Fuse	Replace - Same Size		VI
150967752	F22001	04/06/2015	14:07	04/06/2015	14:40	1	33	33	Tree related-tree broken	Overhead Service	Repair		IV
150967787	V59561	04/06/2015	14:14	04/06/2015	17:57	1	223	223	Public	Pole	Replace - Same Size	Replace - Same Size	II
150968114	Q80353	04/06/2015	15:18	04/06/2015	16:00	1	42	42	Animal related	Fuse	Replace - Same Size		V
150968286	U57560	04/06/2015	16:09	04/06/2015	17:31	1	82	81	Overhead equipment	Disconnect Switch	Repair		II
150968374	H01192	04/06/2015	16:37	04/06/2015	17:13	8	288	36	Animal related	Transformer Fuse	Replace - Same Size		III
150968457	K09863	04/06/2015	16:38	04/06/2015	23:57	1127	494753	438	Substation equipment	Substation Misc.		Replace - New Size	V
150968467	K09864	04/06/2015	16:38	04/06/2015	23:57	1290	566310	438	Substation equipment	Substation Misc.		Replace - New Size	V
5004379	R16510	04/06/2015	16:54	04/06/2015	18:40	1	105	105	Animal related	Fuse	Repair		I
150968545	J61114	04/06/2015	17:12	04/06/2015	18:25	1	73	72	Unknown				III
150968562	T41556	04/06/2015	17:20	04/06/2015	19:45	1	145	145	Animal related	Transformer Fuse	Replace - Same Size	Replace - Same Size	IV
150968600	A45002	04/06/2015	17:29	04/06/2015	18:17	8	384	47	Unknown	Fuse	Patrol/Test/Inspect		I
150968675	L12126	04/06/2015	18:09	04/06/2015	18:28	66	1254	18	Animal related	Fuse	Replace - Same Size		III
150968776	B44002	04/06/2015	19:30	04/06/2015	19:51	1	21	20	Overhead equipment	Overhead Service	Repair		I
5004395	R34921	04/06/2015	20:00	04/06/2015	21:15	1	74	74	Animal related	Fuse	Replace - Same Size		VI
5004397	Q21294	04/06/2015	20:06	04/06/2015	20:09	8	20	2	Unknown				VI
150968992	U32258	04/06/2015	20:11	04/07/2015	4:08	466	222282	477	Public	Pole	Replace - Same Size	Replace - New Size	II
150969004	S01560	04/06/2015	21:01	04/06/2015	21:50	1	49	48	Overhead equipment	Transformer Fuse	Repair	Replace - Same Size	VI
150969481	J15303	04/06/2015	21:45	04/06/2015	22:48	1	63	62	Unknown	Transformer Fuse	Replace - Same Size	Replace - Same Size	I
5004401	Q82906	04/06/2015	22:16	04/07/2015	2:21	3	733	244	Weather	Fuse	Replace - Same Size		VI
5004403	R08910	04/06/2015	22:18	04/07/2015	3:54	1	335	335	Weather	Fuse	Replace - Same Size		VI
5004413	R10943	04/06/2015	22:56	04/07/2015	5:14	207	78252	378	Weather				VI
5004407	K67924	04/06/2015	22:57	04/07/2015	2:00	7	1279	182	Weather	Fuse	Replace - Same Size		VI
5004411	K67924	04/06/2015	23:20	04/07/2015	2:44	1	203	203	Weather	Transformer Fuse	Replace - Same Size		VI
5004415	R39934	04/06/2015	23:34	04/07/2015	1:42	1	127	127	Weather	Fuse	Replace - Same Size		VI
5004419	Q64919	04/06/2015	23:43	04/07/2015	2:32	1	168	168	Weather	Fuse	Replace - Same Size		VI
5004421	R39934	04/06/2015	23:46	04/07/2015	0:45	2	116	58	Weather	Fuse	Replace - Same Size		VI
5004425	Q64919	04/06/2015	23:55	04/07/2015	3:05	1	189	189	Weather	Fuse	Replace - Same Size		VI
5004427	M19222	04/07/2015	0:24	04/07/2015	1:51	1	86	86	Weather	Transformer Fuse	Replace - Same Size		VI
150972574	S50544	04/07/2015	0:47	04/07/2015	4:12	1	205	205	Other	Fuse	Replace - Same Size	Patrol/Test/Inspect	VI
150972592	S93504	04/07/2015	0:52	04/07/2015	2:10	1	78	78	Overhead equipment	Overhead Service	Repair	Advise Customer	VI
150972598	J14140	04/07/2015	0:55	04/07/2015	2:09	1	74	74	Weather	Fuse	Replace - Same Size		VI
5004429	Q64939	04/07/2015	1:11	04/07/2015	3:55	1	163	163	Weather	Fuse	Replace - Same Size		VI
150972721	A12034	04/07/2015	1:55	04/07/2015	6:34	770	214830	278	Overhead equipment	Other	Repair	Repair	I
150974089	D32212	04/07/2015	3:10	04/07/2015	5:39	483	71967	149	Overhead equipment				I
150974104	B35002	04/07/2015	3:12	04/07/2015	5:39	686	100842	147	Overhead equipment				I
150974009	D32211	04/07/2015	3:12	04/07/2015	5:39	398	58506	147	Overhead equipment	Crossarm	Patrol/Test/Inspect	Repair	I
150974088	A81001	04/07/2015	3:17	04/07/2015	4:40	62	5146	82	Overhead equipment	Disconnect Switch	Patrol/Test/Inspect	Replace - Same Size	I
150974140	T06505	04/07/2015	5:17	04/07/2015	7:10	144	16272	113	Weather	Fuse	Patrol/Test/Inspect	Repair	VI
150974165	K27153	04/07/2015	6:18	04/07/2015	6:40	1	22	22	Weather	Fuse	Repair	Repair	VI
150974221	B38001	04/07/2015	6:44	04/07/2015	10:39	30	7050	235	Overhead equipment	Fuse		Repair	I
5004439	P20930	04/07/2015	7:06	04/07/2015	7:45	1	38	38	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	VI
5004443	R10943	04/07/2015	7:11	04/07/2015	7:35	1	23	23	Weather	Overhead Primary	Raise		VI
5004441	R10943	04/07/2015	7:12	04/07/2015	7:33	1	21	20	Weather	Overhead Primary	Raise		VI
150974247	Y68582	04/07/2015	7:18	04/07/2015	8:25	1	67	66	Animal related	Transformer Fuse	Replace - Same Size	Replace - Same Size	IV
5004445	K67924	04/07/2015	7:19	04/07/2015	8:55	1	95	95	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	VI
150974255	B38001	04/07/2015	7:20	04/07/2015	15:09	1	469	468	Underground equipment	Underground Primary		Repair	I

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5004447	P20930	04/07/2015	7:22	04/07/2015	8:18	1	55	55	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	VI
5004449	Q64919	04/07/2015	7:36	04/07/2015	10:55	2	396	198	Weather	Fuse	Replace - Same Size		VI
150974419	M36189	04/07/2015	8:29	04/07/2015	9:35	1	66	65	Other				I
150974480	R59422	04/07/2015	8:42	04/07/2015	9:47	1	65	64	Animal related	Fuse	Replace - Same Size		IV
5004453	Q21294	04/07/2015	8:46	04/07/2015	13:31	1	284	284	Underground equipment	Underground Service	Patrol/Test/Inspect	Repair	VI
150974526	D16002	04/07/2015	8:54	04/07/2015	12:00	1	186	185	Overhead equipment	Fuse	Patrol/Test/Inspect	Repair	I
150974547	R60551	04/07/2015	8:59	04/07/2015	10:43	2	208	104	Animal related	Transformer Fuse	Replace - Same Size		IV
150974552	309142	04/07/2015	9:00	04/07/2015	9:45	1	45	45	Jurisdictional	Meter	Reconnect		V
150974676	D32211	04/07/2015	9:02	04/07/2015	9:34	285	9120	31	Overhead equipment	Overhead Primary	Repair		I
150974604	L74191	04/07/2015	9:07	04/07/2015	9:52	1	45	45	Overhead equipment	Fuse			IV
5004461	M19222	04/07/2015	9:08	04/07/2015	10:19	1	70	70	Weather	Fuse			VI
5004463	L63936	04/07/2015	9:18	04/07/2015	11:26	6	762	127	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	VI
150974788	S01501	04/07/2015	9:35	04/07/2015	10:06	1	31	30	Overhead equipment	Transformer Fuse	Repair	Replace - Same Size	VI
150974972	Q28141	04/07/2015	10:02	04/07/2015	12:29	1	147	146	Overhead equipment	Connector	Replace - Same Size		VI
150975001	K52400	04/07/2015	10:06	04/07/2015	10:44	1	38	38	Weather	Fuse	Replace - Same Size		V
150975015	D32211	04/07/2015	10:07	04/07/2015	11:29	1	82	82	Unknown	Fuse	Repair		I
150975093	M21133	04/07/2015	10:24	04/07/2015	13:16	1	172	171	Tree related-tree broken	Overhead Primary	Repair	Repair	VI
150975187	D32211	04/07/2015	10:40	04/07/2015	12:05	1	85	84	Unknown	Fuse	Repair		I
5004473	R94271	04/07/2015	11:06	04/07/2015	12:20	24	1760	73	Overhead equipment	Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
150975413	N44216	04/07/2015	11:19	04/07/2015	15:33	1	254	254	Overhead equipment	Overhead Transformer		Replace - Same Size	III
150975448	T09559	04/07/2015	11:24	04/07/2015	12:55	1	91	91	Other				VI
5004483	P42230	04/07/2015	11:44	04/07/2015	13:08	2	167	83	Weather	Transformer Fuse			VI
5004487	J83138	04/07/2015	11:56	04/07/2015	13:10	2	147	73	Overhead equipment	Fuse	Replace - Same Size		VI
150975718	S50544	04/07/2015	12:16	04/07/2015	12:29	1	13	13	Other	Customer Equipment	Advise Customer		VI
150975740	R33127	04/07/2015	12:20	04/07/2015	16:02	1	222	222	Overhead equipment	Overhead Service	Replace - New Size	Patrol/Test/Inspect	I
5004495	X60598	04/07/2015	12:49	04/07/2015	14:29	1	99	99	Overhead equipment	Disconnect Switch	Replace - Same Size		IV
150976331	R23313	04/07/2015	13:15	04/07/2015	15:26	1108	145148	130	Overhead equipment				V
150976111	U97001	04/07/2015	13:22	04/07/2015	14:42	1	80	80	Overhead equipment	Overhead Service	Repair		II
5004499	Q64939	04/07/2015	13:29	04/07/2015	13:59	2	58	29	Weather	Fuse	Replace - Same Size		VI
5004501	K32915	04/07/2015	13:35	04/07/2015	16:29	1	173	173	Overhead equipment	Overhead Transformer	Replace - Same Size		VI
5004503	K32915	04/07/2015	13:38	04/07/2015	17:25	1	226	226	Overhead equipment	Overhead Transformer	Replace - Same Size		VI
150976293	X91510	04/07/2015	13:42	04/07/2015	14:24	1	42	42	Overhead equipment	Connector	Repair	Replace - Same Size	IV
5004505	K08909	04/07/2015	13:49	04/07/2015	15:12	22	1826	82	Overhead equipment	Fuse	Replace - Same Size		VI
5004511	R29904	04/07/2015	14:02	04/07/2015	21:09	1	426	426	Weather	Overhead Transformer	Replace - Same Size	Repair	VI
150976494	S03530	04/07/2015	14:17	04/07/2015	20:09	1	352	352	Unknown				VI
5004519	K32935	04/07/2015	14:42	04/07/2015	18:38	5	1178	235	Tree related-tree contact	Fuse			VI
150977027	S31532	04/07/2015	15:05	04/07/2015	16:50	208	21840	105	Overhead equipment	Regulator	Repair	Repair	VI
5004525	X02548	04/07/2015	15:28	04/07/2015	16:08	1	39	39	Weather	Transformer Fuse	Replace - Same Size		IV
5004527	Q64919	04/07/2015	15:40	04/07/2015	16:54	2	147	73	Weather	Fuse	Replace - Same Size		VI
5004529	K32915	04/07/2015	15:44	04/07/2015	16:23	1	38	38	Overhead equipment				VI
150977133	S43502	04/07/2015	16:05	04/07/2015	17:26	41	3321	81	Weather	Fuse	Repair	Replace - Same Size	VI
150977152	S19543	04/07/2015	16:05	04/07/2015	17:03	21	1218	58	Weather	Fuse	Repair		VI
150977142	S43502	04/07/2015	16:13	04/07/2015	17:29	1	76	76	Weather	Other			VI
5004531	Q64939	04/07/2015	16:34	04/07/2015	17:10	1	35	35	Weather	Fuse	Replace - Same Size		VI
5004535	X02548	04/07/2015	16:56	04/07/2015	18:09	1	72	72	Weather	Transformer Fuse	Replace - Same Size		IV
5004537	R34920	04/07/2015	17:07	04/07/2015	17:29	1	21	21	Weather	Fuse	Replace - Same Size		VI
150977348	M45211	04/07/2015	17:13	04/07/2015	18:46	1	93	92	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
150977547		04/07/2015	18:34	04/07/2015	20:15	1	101	101	Overhead equipment	Overhead Service	Repair	Repair	II
150980129	M21133	04/08/2015	0:47	04/08/2015	2:22	3	285	95	Unknown	Fuse	Replace - Same Size		VI
150980130	Q91175	04/08/2015	1:29	04/08/2015	4:05	1	156	156	Weather	Fuse	Replace - Same Size	Replace - Same Size	I
150980137	Q91175	04/08/2015	1:51	04/08/2015	7:55	1	364	364	Weather	Fuse	Replace - Same Size	Replace - Same Size	I
150983660	R05115	04/08/2015	3:18	04/08/2015	6:00	895	144990	162	Unknown				I
150983629	P47169	04/08/2015	3:18	04/08/2015	5:28	20	2600	130	Weather	Fuse	Replace - Same Size	Replace - Same Size	I
150983925	M40117	04/08/2015	3:25	04/08/2015	7:32	59	14573	246	Overhead equipment	Crossarm	Replace		I
150983670	B19002	04/08/2015	3:46	04/08/2015	10:08	1	382	381	Weather	Overhead Transformer	Replace - Same Size	Repair	I
150983678	D81001	04/08/2015	3:52	04/08/2015	5:51	121	14399	119	Unknown	Overhead Transformer			I

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
150983692	A97001	04/08/2015	4:05	04/08/2015	5:58	18	2034	113	Unknown	Fuse	Patrol/Test/Inspect	Replace - Same Size	I
150983686	B19002	04/08/2015	4:16	04/08/2015	6:34	17	2346	137	Weather	Fuse	Replace - Same Size		I
150983738	J05139	04/08/2015	4:40	04/08/2015	7:41	2	362	181	Weather	Fuse	Patrol/Test/Inspect	Replace - Same Size	I
150983945	Q01280	04/08/2015	5:09	04/08/2015	7:45	11	1716	155	Weather	Fuse	Repair	Repair	III
150983711	C30002	04/08/2015	5:27	04/08/2015	6:58	1	91	91	Weather	Overhead Primary	Replace - Same Size	Patrol/Test/Inspect	III
150983714	R99180	04/08/2015	5:39	04/08/2015	8:32	1	173	172	Weather	Fuse		Replace - Same Size	IV
150983720	S19543	04/08/2015	5:49	04/08/2015	7:15	21	1806	86	Weather	Fuse	Replace - Same Size		VI
150983735	X68506	04/08/2015	6:05	04/08/2015	10:05	5	1200	240	Weather	Overhead Transformer		Replace - New Size	IV
150983989	P46607	04/08/2015	6:07	04/08/2015	7:47	2255	225500	100	Weather	Substation Misc.	Switch/Reset		IV
150983843	R60552	04/08/2015	6:14	04/08/2015	9:55	104	22984	220	Overhead equipment	Fuse	Patrol/Test/Inspect	Replace - Same Size	IV
150983697	B80002	04/08/2015	6:19	04/08/2015	7:00	1	41	40	Unknown	Fuse	Patrol/Test/Inspect	Replace - Same Size	I
150983846	A85001	04/08/2015	6:29	04/08/2015	10:58	1	269	268	Weather	Fuse	Patrol/Test/Inspect	Replace - Same Size	I
150983855	F22001	04/08/2015	6:31	04/08/2015	7:55	112	9408	84	Weather	Fuse	Repair		IV
150983856	Q91141	04/08/2015	6:33	04/08/2015	8:19	1	106	105	Animal related	Transformer Fuse	Replace - Same Size		I
150983857	R66472	04/08/2015	6:35	04/08/2015	8:06	1	91	91	Substation equipment				IV
150983874	C00001	04/08/2015	6:46	04/08/2015	9:10	1	144	143	Unknown	Fuse	Repair		I
150983872	S21529	04/08/2015	6:46	04/08/2015	8:17	1	91	90	Weather	Disconnect Switch	Repair	Replace - Same Size	VI
150983901	351001	04/08/2015	6:55	04/08/2015	15:28	1	513	512	Public	Pole	Patrol/Test/Inspect	Repair	VI
150983910	L79157	04/08/2015	6:59	04/08/2015	8:30	1	91	90	Weather	Transformer Fuse	Replace - Same Size		IV
150983941	M36184	04/08/2015	7:13	04/08/2015	8:35	1	82	82	Other				I
150983955	P17108	04/08/2015	7:17	04/08/2015	9:30	1	133	133	Weather	Fuse	Patrol/Test/Inspect	Replace - Same Size	IV
150983957	B61001	04/08/2015	7:18	04/08/2015	8:15	1	57	56	Weather	Transformer Fuse	Replace - Same Size		I
150983969	B25002	04/08/2015	7:24	04/08/2015	10:20	1	176	175	Weather	Transformer Fuse	Replace - Same Size		I
150983971	P73182	04/08/2015	7:25	04/08/2015	8:04	1	39	38	Overhead equipment	Overhead Transformer		Replace - Same Size	VI
150983991	S36571	04/08/2015	7:29	04/08/2015	9:20	10	1110	111	Weather	Fuse	Replace - Same Size		VI
150984063	S15559	04/08/2015	7:55	04/08/2015	9:10	7	525	75	Animal related	Transformer Fuse	Replace - Same Size		VI
150984099	K52400	04/08/2015	8:00	04/08/2015	8:55	90	4950	55	Animal related	Fuse	Replace - Same Size		V
150984110	X42502	04/08/2015	8:07	04/08/2015	10:12	1	125	125	Tree related-tree contact	Overhead Service	Repair		IV
150984114	Q85162	04/08/2015	8:08	04/08/2015	8:55	1	47	47	Animal related	Transformer Fuse	Repair	Repair	VI
150984147	X88510	04/08/2015	8:17	04/08/2015	9:01	1	44	44	Weather	Fuse	Replace - Same Size		IV
5004553	K32915	04/08/2015	8:19	04/08/2015	10:50	1	150	150	Overhead equipment	Overhead Transformer	Replace - Same Size	Repair	VI
150984166	S15559	04/08/2015	8:23	04/08/2015	9:08	1	45	45	Weather	Fuse	Repair		VI
150984176	P47169	04/08/2015	8:27	04/08/2015	9:59	1	92	92	Weather	Fuse	Replace - Same Size		I
150984213	K28183	04/08/2015	8:36	04/08/2015	11:02	1	146	146	Weather	Transformer Fuse	Replace - Same Size		III
150984320	D32211	04/08/2015	8:59	04/08/2015	9:45	1	46	46	Unknown	Fuse	Repair		I
150984336	A91003	04/08/2015	9:01	04/08/2015	12:19	1	198	197	Underground equipment	Underground Service	Patrol/Test/Inspect	Patrol/Test/Inspect	I
150984425	S15559	04/08/2015	9:20	04/08/2015	10:54	1	94	94	Weather	Overhead Transformer	Repair		VI
150984764	B61001	04/08/2015	9:24	04/08/2015	12:38	11	2134	193	Weather	Fuse	Replace - Same Size		I
150984560	M40132	04/08/2015	9:46	04/08/2015	11:49	1	123	122	Other	Overhead Transformer			I
150984610	C00001	04/08/2015	9:50	04/08/2015	11:48	16	1888	118	Jurisdictional	Underground Primary	Patrol/Test/Inspect		I
150984627	K89141	04/08/2015	10:00	04/08/2015	10:53	1	53	53	Animal related	Fuse	Replace - Same Size		III
150984649	D87001	04/08/2015	10:03	04/08/2015	11:03	1	60	60	Animal related	Fuse	Replace - Same Size		I
5004561	J99151	04/08/2015	10:12	04/08/2015	14:33	1	260	260	Public	Pole		Replace - Same Size	VI
150984759	P17108	04/08/2015	10:21	04/08/2015	11:58	1	97	97	Weather	Transformer Fuse		Replace - Same Size	IV
150984807	S14509	04/08/2015	10:32	04/08/2015	10:45	1	13	13	Other				VI
150984816	N67309	04/08/2015	10:33	04/08/2015	11:31	1	58	58	Unknown	Fuse	Replace - Same Size		I
150985010	B21001	04/08/2015	11:07	04/08/2015	14:58	1	231	231	Overhead equipment	Overhead Transformer	Replace - New Size		I
150985017	F22001	04/08/2015	11:09	04/08/2015	12:10	1	61	60	Weather	Transformer Fuse	Repair		IV
150985025	X19561	04/08/2015	11:11	04/08/2015	13:55	1	164	164	Animal related	Animal Guard		Install	IV
150985113	B65003	04/08/2015	11:23	04/08/2015	18:28	1	425	424	Unknown	Fuse	Replace - Same Size	Replace - Same Size	I
5004571	J97113	04/08/2015	11:47	04/08/2015	12:55	1	67	67	Overhead equipment	Transformer Fuse			VI
150985263	B10001	04/08/2015	11:50	04/08/2015	13:09	1	79	79	Other	Connector			I
150985310	B44002	04/08/2015	12:00	04/08/2015	12:48	1	48	47	Overhead equipment	Connector	Replace - Same Size		I
150985332	328119	04/08/2015	12:03	04/08/2015	12:55	1	52	52	Tree related-tree broken	Overhead Service	Repair		V
150985598	R48165	04/08/2015	12:05	04/08/2015	13:00	451	24805	55	Overhead equipment	Recloser			IV
5154879	J89105	04/08/2015	12:09	04/08/2015	17:25	26	8204	315	Overhead equipment				VI

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
150985538	Q32170	04/08/2015	12:41	04/08/2015	14:25	11	1144	104	Weather	Pole	Cut in Clear	Repair	I
150986193	Q32170	04/08/2015	12:41	04/08/2015	18:33	3	1056	352	Weather	Pole	Replace - Urgent		I
5004583	Q18245	04/08/2015	12:50	04/08/2015	13:54	1	64	64	Overhead equipment	Overhead Transformer			VI
5004587	Q18245	04/08/2015	12:52	04/08/2015	13:50	70	4048	57	Overhead equipment	Recloser			VI
150985630	P62138	04/08/2015	13:04	04/08/2015	14:08	1	64	63	Overhead equipment	Transformer Fuse	Replace - Same Size		VI
150985782	J56342	04/08/2015	13:33	04/08/2015	15:00	1	87	87	Animal related	Fuse			III
150985822	S53543	04/08/2015	13:40	04/08/2015	14:10	1	30	30	Overhead equipment	Fuse	Replace - Same Size	Patrol/Test/Inspect	VI
150985874	Q83172	04/08/2015	13:51	04/08/2015	16:36	5	825	165	Weather	Transformer Fuse	Replace - Same Size		VI
150985959	Q71846	04/08/2015	14:04	04/08/2015	16:15	1	131	131	Tree related-tree contact	Overhead Service	Repair		V
150985999	R58961	04/08/2015	14:12	04/08/2015	15:20	1	68	68	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
150986070	K27150	04/08/2015	14:17	04/08/2015	15:11	26	1404	54	Overhead equipment	Fuse	Replace - Same Size		VI
5004615	Y61003	04/08/2015	14:21	04/08/2015	15:15	1	53	53	Weather	Jumper		Repair	IV
5004619	Y61003	04/08/2015	14:23	04/08/2015	15:16	1	52	52	Weather	Jumper	Repair		IV
150986124	D69001	04/08/2015	14:29	04/08/2015	15:43	1	74	74	Underground equipment	Underground Primary		Repair	I
150986165	D31016	04/08/2015	14:39	04/08/2015	15:18	1	39	38	Overhead equipment	Fuse	Replace - Same Size		III
150986201	B61001	04/08/2015	14:45	04/08/2015	17:44	1	179	178	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Repair	I
150986273	B21004	04/08/2015	15:00	04/08/2015	19:37	1	277	277	Underground equipment	Underground Service	Repair	Repair	I
5004623	Y41002	04/08/2015	15:02	04/08/2015	16:55	6	677	112	Overhead equipment	Overhead Transformer	Replace - Same Size	Replace - Same Size	IV
150986387	U60559	04/08/2015	15:24	04/08/2015	15:55	1	31	30	Unknown				II
150986443	U10525	04/08/2015	15:35	04/08/2015	19:20	1	225	225	Underground equipment	Underground Primary	Replace - Same Size		II
5004629	Z19538	04/08/2015	15:36	04/08/2015	17:17	2	201	100	Overhead equipment	Substation Breaker	Switch/Reset		IV
150986756	H01194	04/08/2015	16:21	04/08/2015	17:01	1	40	39	Overhead equipment	Transformer Fuse	Replace - Same Size		III
150986779	E10003	04/08/2015	16:24	04/08/2015	17:10	1	46	46	Overhead equipment	Transformer Fuse	Replace - Same Size		III
150986929	L82187	04/08/2015	16:55	04/08/2015	17:56	1	61	60	Animal related	Transformer Fuse	Replace - Same Size		IV
5004635	J84145	04/08/2015	16:59	04/08/2015	17:50	37	1861	50	Overhead equipment	Overhead Primary			VI
5004647	J84145	04/08/2015	17:04	04/08/2015	19:43	8	1270	158	Overhead equipment	Overhead Primary			VI
150987310	T41556	04/08/2015	17:32	04/08/2015	20:14	12	1944	161	Overhead equipment	Pole	Replace - Same Size	Replace - Same Size	IV
150987350	F10001	04/08/2015	18:43	04/08/2015	19:56	1	73	72	Animal related	Other	Replace - Same Size	Patrol/Test/Inspect	III
150987379	V61563	04/08/2015	18:58	04/09/2015	0:10	1	312	312	Overhead equipment	Overhead Transformer	Replace - Same Size		II
150987666	T01534	04/08/2015	19:35	04/08/2015	21:25	1	110	110	Tree related-tree broken	Overhead Service	Repair	Repair	VI
150987690	328119	04/08/2015	19:48	04/08/2015	20:35	1	47	47	Overhead equipment	Overhead Service	Repair	Replace - Same Size	V
150987831	M81403	04/08/2015	20:41	04/08/2015	21:50	12	828	68	Weather	Fuse	Repair		V
150988077	U80564	04/08/2015	20:48	04/08/2015	21:35	2	94	46	Overhead equipment	Pole	Replace - New Size		II
150987880	U80564	04/08/2015	20:48	04/08/2015	21:35	12	564	46	Overhead equipment	Pole	Replace - New Size		II
150987848	U84534	04/08/2015	20:49	04/08/2015	22:32	5	515	103	Weather	Fuse	Replace - Same Size		II
150987869	R04409	04/08/2015	21:04	04/08/2015	21:46	1	42	42	Weather	Transformer Fuse	Replace - Same Size		V
150987876	J34356	04/08/2015	21:05	04/09/2015	2:25	1	320	320	Weather	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	V
150987903	H32370	04/08/2015	21:15	04/09/2015	0:50	1	215	214	Weather	Transformer Fuse	Patrol/Test/Inspect		V
150988053	P05825	04/08/2015	21:21	04/09/2015	0:13	17	2924	172	Weather	Overhead Primary		Repair	V
150988046	P19395	04/08/2015	21:28	04/08/2015	22:30	1	62	62	Overhead equipment	Fuse	Replace - Same Size		V
150988056	N95823	04/08/2015	21:32	04/08/2015	22:20	1	48	47	Weather	Transformer Fuse	Replace - Same Size		V
5004659	L50214	04/08/2015	21:35	04/08/2015	23:55	27	3771	139	Weather	Fuse	Replace - Same Size		VI
150988330	H11340	04/08/2015	21:49	04/09/2015	4:15	4	1544	386	Weather	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	V
150988206	H11340	04/08/2015	21:51	04/08/2015	22:45	35	1890	53	Weather				V
5004657	Q24313	04/08/2015	21:57	04/08/2015	22:45	2	95	47	Weather	Fuse	Replace - Same Size		VI
150988246	V41568	04/08/2015	22:04	04/08/2015	22:41	1	37	37	Overhead equipment	Connector	Repair		II
150988239	F03003	04/08/2015	22:04	04/08/2015	23:21	5	385	76	Weather	Fuse	Replace - Same Size		III
150988249	M81403	04/08/2015	22:05	04/08/2015	22:49	1	44	43	Weather	Transformer Fuse	Repair		V
150988268	U61568	04/08/2015	22:11	04/09/2015	6:01	1	470	470	Overhead equipment	Pole	Replace - New Size		II
5004663	K15205	04/08/2015	22:13	04/09/2015	1:24	13	2474	190	Weather	Fuse	Replace - Same Size	Replace - Same Size	VI
150990001	U33509	04/08/2015	22:21	04/09/2015	0:58	3	471	156	Overhead equipment	Disconnect Switch	Repair		II
150987861	U80564	04/08/2015	22:22	04/09/2015	2:30	1	248	248	Overhead equipment	Pole	Replace - New Size		II
150988309	N42856	04/08/2015	22:30	04/09/2015	3:01	121	32791	271	Overhead equipment	Overhead Primary	Patrol/Test/Inspect	Repair	V
150990132	L15441	04/08/2015	22:55	04/09/2015	1:11	1	136	136	Unknown	Substation Breaker	Switch/Reset		III
150988331	J80806	04/08/2015	22:57	04/08/2015	23:59	1	62	61	Animal related	Overhead Transformer	Repair	Repair	V
150988341	K39153	04/08/2015	23:11	04/09/2015	0:45	80	7520	94	Unknown	Recloser	Switch/Reset		III

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
150988359	FS5901	04/08/2015	23:31	04/09/2015	1:40	1	129	129	Unknown	Other			III
150988364	R65451	04/08/2015	23:38	04/09/2015	6:50	7	3024	431	Tree related-tree contact	Overhead Secondary	Patrol/Test/Inspect	Trim	IV
150988370	B82001	04/08/2015	23:47	04/09/2015	1:20	1	93	92	Overhead equipment	Overhead Secondary	Repair		I
150990126	K69116	04/09/2015	1:29	04/09/2015	2:28	1	59	59	Overhead equipment	Jumper	Repair		IV
150990212	N70330	04/09/2015	2:47	04/09/2015	5:05	78	10764	137	Weather	Overhead Primary	Remove		I
150990210	C52002	04/09/2015	2:52	04/09/2015	4:15	34	2822	83	Unknown	Fuse	Repair	Replace - Same Size	III
150993009	F10003	04/09/2015	3:21	04/09/2015	5:20	35	4165	119	Overhead equipment	Fuse	Replace - Same Size		III
150992980	D32212	04/09/2015	3:29	04/09/2015	4:35	1	66	65	Weather	Transformer Fuse	Replace - Same Size		I
150992988	B25001	04/09/2015	3:43	04/09/2015	10:10	1	387	386	Weather	Overhead Transformer	Replace - Same Size	Repair	I
150993000	P69173	04/09/2015	3:55	04/09/2015	5:21	43	3698	85	Weather	Fuse	Replace - Same Size		III
150993005	N50333	04/09/2015	4:09	04/09/2015	6:00	1	111	110	Weather	Transformer Fuse	Replace - Same Size		II
5004671	M19222	04/09/2015	4:14	04/09/2015	11:00	1	405	405	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	VI
150993014	J75271	04/09/2015	4:18	04/09/2015	5:51	8	744	92	Weather	Fuse	Replace - Same Size		IV
150993016	D01001	04/09/2015	4:21	04/09/2015	5:50	1	89	88	Weather	Transformer Fuse	Replace - Same Size		I
150993022	B93002	04/09/2015	4:32	04/09/2015	6:29	1	117	117	Weather	Fuse	Replace - Same Size		I
5004673	M20221	04/09/2015	4:38	04/09/2015	6:07	155	13857	89	Substation equipment				VI
5004675	M20221	04/09/2015	4:40	04/09/2015	6:09	11	980	89	Substation equipment				VI
150993036	R58951	04/09/2015	4:45	04/09/2015	8:30	69	15525	225	Weather	Fuse	Patrol/Test/Inspect	Repair	IV
150994053	R20501	04/09/2015	4:48	04/09/2015	10:30	17	5814	342	Weather	Fuse			IV
150993093	R20501	04/09/2015	4:48	04/09/2015	9:05	2	514	256	Weather	Transformer Fuse	Repair		IV
150993224	R20502	04/09/2015	4:52	04/09/2015	7:26	42	6468	153	Weather	Pole		Repair	IV
150993459	R20502	04/09/2015	4:52	04/09/2015	10:05	20	6260	313	Overhead equipment	Fuse	Patrol/Test/Inspect	Replace - Same Size	IV
150993125	M21133	04/09/2015	4:52	04/09/2015	7:40	22	3696	168	Weather	Overhead Primary	Repair	Repair	VI
150993049	R66470	04/09/2015	4:53	04/09/2015	7:20	48	7056	146	Overhead equipment	Transformer Fuse	Replace - Same Size	Replace - Same Size	IV
5004677	M20221	04/09/2015	4:53	04/09/2015	6:09	7	531	75	Substation equipment				VI
5004679	M20221	04/09/2015	4:53	04/09/2015	6:09	1	75	75	Substation equipment	Regulator			VI
150993050	D72002	04/09/2015	4:54	04/09/2015	8:45	1	231	230	Tree related-tree broken	Overhead Primary	Patrol/Test/Inspect	Repair	I
150993056	Z04520	04/09/2015	4:55	04/09/2015	6:32	1	97	97	Animal related	Fuse	Replace - Same Size		IV
150993055	R20502	04/09/2015	4:56	04/09/2015	7:28	1	152	152	Weather	Transformer Fuse	Repair		IV
150993089	R20501	04/09/2015	5:00	04/09/2015	8:34	48	10272	213	Overhead equipment				IV
150993378	V18553	04/09/2015	5:01	04/09/2015	6:37	1	96	95	Weather	Fuse	Replace - Same Size		II
150993066	M21133	04/09/2015	5:02	04/09/2015	7:05	1	123	123	Overhead equipment	Overhead Primary	Repair	Repair	VI
150993073	J14140	04/09/2015	5:04	04/09/2015	8:48	1	224	224	Weather	Overhead Transformer		Replace - Same Size	VI
5004681	N94182	04/09/2015	5:05	04/09/2015	6:48	1	102	102	Animal related	Fuse	Replace - Same Size		I
150993172	C66001	04/09/2015	5:09	04/09/2015	6:36	26	2262	87	Unknown	Fuse	Repair	Replace - Same Size	III
150993087	M18131	04/09/2015	5:11	04/09/2015	6:56	1	105	105	Weather	Fuse	Replace - Same Size		III
150993086	P73182	04/09/2015	5:11	04/09/2015	7:12	1	121	121	Weather	Fuse	Replace - Same Size		VI
5004683	Q64919	04/09/2015	5:26	04/09/2015	7:00	1	93	93	Weather	Transformer Fuse	Replace - Same Size		VI
150993110	J80807	04/09/2015	5:27	04/09/2015	7:10	1	103	103	Overhead equipment	Overhead Primary	Repair	Repair	V
150993119	U86500	04/09/2015	5:35	04/09/2015	6:49	1	74	74	Overhead equipment	Transformer Fuse	Repair	Repair	II
150993123	R41131	04/09/2015	5:41	04/09/2015	8:38	2	354	177	Weather	Transformer Fuse	Repair	Repair	VI
150993242	R41132	04/09/2015	5:46	04/09/2015	7:48	32	3904	121	Weather	Fuse	Replace - Same Size		VI
150993201	K27150	04/09/2015	5:49	04/09/2015	6:57	6	408	68	Weather	Fuse	Repair	Repair	VI
150993170	S07536	04/09/2015	6:05	04/09/2015	8:21	1	136	136	Overhead equipment	Overhead Primary	Repair	Repair	VI
150993191	K28180	04/09/2015	6:14	04/09/2015	10:20	1	246	245	Weather	Overhead Transformer		Repair	III
150993193	L70128	04/09/2015	6:16	04/09/2015	7:18	1	62	62	Weather	Transformer Fuse	Replace - Same Size		IV
150993206	344003	04/09/2015	6:23	04/09/2015	7:38	1	75	75	Overhead equipment	Fuse	Replace - Same Size		VI
5004687	Q18243	04/09/2015	6:26	04/09/2015	7:57	11	996	90	Weather	Fuse	Replace - Same Size		VI
5004689	J83138	04/09/2015	6:29	04/09/2015	10:42	6	1514	252	Overhead equipment	Overhead Transformer		Replace - Same Size	VI
150993217	P49180	04/09/2015	6:30	04/09/2015	8:00	1	90	90	Unknown	Fuse	Replace - Same Size	Replace - Same Size	I
150993239	306003	04/09/2015	6:32	04/09/2015	8:36	27	3348	123	Weather	Fuse			VI
150993226	R60552	04/09/2015	6:34	04/09/2015	8:13	1	99	99	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
150993299	N42856	04/09/2015	6:34	04/09/2015	11:35	11	3311	301	Weather	Underground Primary	Patrol/Test/Inspect	Repair	V
5004695	HC9327	04/09/2015	6:36	04/09/2015	11:39	2	605	302	Weather	Underground Transformer	Patrol/Test/Inspect	Replace - Same Size	VI
150993356	306003	04/09/2015	6:50	04/09/2015	9:19	11	1639	149	Weather	Fuse	Repair		VI
150993267	P54828	04/09/2015	6:50	04/09/2015	8:00	1	70	70	Weather	Fuse	Replace - Same Size		V

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5004701	Q21294	04/09/2015	6:50	04/09/2015	12:08	1	317	317	Underground equipment	Underground Transformer	Switch/Reset	Replace - Same Size	VI
150993272	L99392	04/09/2015	6:51	04/09/2015	10:43	1	232	232	Weather	Fuse	Replace - Same Size	Replace - Same Size	V
150993266	K09864	04/09/2015	6:51	04/09/2015	7:24	1	33	33	Weather	Transformer Fuse	Replace - Same Size	Repair	V
5004703	R08910	04/09/2015	6:53	04/09/2015	7:50	1	56	56	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	VI
150993280	C37002	04/09/2015	6:55	04/09/2015	7:53	1	58	58	Weather	Fuse	Replace - Same Size		III
5004707	K31120	04/09/2015	6:56	04/09/2015	7:40	1	43	43	Unknown	Fuse	Replace - Same Size		I
150993290	T23528	04/09/2015	6:57	04/09/2015	13:10	1	373	373	Underground equipment	Underground Service	Repair	Repair	VI
150993289	Q83168	04/09/2015	6:57	04/09/2015	7:50	1	53	53	Weather				VI
150993292	312114	04/09/2015	6:59	04/09/2015	7:58	1	59	58	Weather	Fuse	Replace - Same Size		V
150993296	M18131	04/09/2015	6:59	04/09/2015	11:48	1	289	288	Unknown	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	III
150993309	306003	04/09/2015	7:04	04/09/2015	9:45	1	161	161	Overhead equipment	Meter			VI
150993324	U68581	04/09/2015	7:07	04/09/2015	7:50	3	129	43	Animal related	Transformer Fuse	Replace - Same Size		II
150993329	374052	04/09/2015	7:08	04/09/2015	8:20	1	72	71	Weather	Fuse	Replace - Same Size		VI
150993402	310123	04/09/2015	7:14	04/09/2015	8:46	8	736	91	Other	Disconnect Switch		Install	V
150993351	A97003	04/09/2015	7:15	04/09/2015	12:01	1	286	285	Underground equipment	Underground Primary	Patrol/Test/Inspect	Replace - Urgent	I
150993358	F10003	04/09/2015	7:15	04/09/2015	9:34	1	139	138	Weather	Other	Patrol/Test/Inspect	Patrol/Test/Inspect	III
150993370	N35851	04/09/2015	7:18	04/09/2015	10:09	1	171	171	Weather	Overhead Transformer	Replace - Same Size		V
150993377	P19395	04/09/2015	7:19	04/09/2015	8:01	1	42	42	Weather	Fuse	Replace - Same Size		V
150993395	N54213	04/09/2015	7:24	04/09/2015	8:50	1	86	85	Overhead equipment	Overhead Transformer	Replace - Same Size		II
150993444	R60552	04/09/2015	7:27	04/09/2015	9:31	2	248	123	Overhead equipment	Fuse	Replace - Same Size		IV
5004715	X87578	04/09/2015	7:30	04/09/2015	9:30	1	119	119	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	IV
150993429	R93350	04/09/2015	7:33	04/09/2015	8:18	1	45	45	Weather	Fuse	Replace - Same Size		V
150993434	L23146	04/09/2015	7:35	04/09/2015	9:06	1	91	91	Overhead equipment	Fuse	Replace - Same Size		III
150993455	350104	04/09/2015	7:41	04/09/2015	10:15	1	154	153	Underground equipment	Underground Secondary		Repair	V
150993458	V74513	04/09/2015	7:41	04/09/2015	7:50	6	54	8	Tree related-tree broken	Transformer Fuse	Replace - Same Size		II
150993456	P69174	04/09/2015	7:41	04/09/2015	9:30	1	109	108	Weather	Overhead Transformer		Repair	III
150993482	K11373	04/09/2015	7:41	04/09/2015	9:00	6	474	78	Overhead equipment	Fuse	Replace - Same Size		V
150993498	Q06131	04/09/2015	7:48	04/09/2015	9:15	10	870	87	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
150993491	N95824	04/09/2015	7:48	04/09/2015	9:05	1	77	76	Weather	Transformer Fuse	Replace - Same Size		V
150993515	R58961	04/09/2015	7:48	04/09/2015	9:57	137	17673	129	Overhead equipment	Jumper	Repair		IV
150993508	D53002	04/09/2015	7:50	04/09/2015	12:34	1	284	283	Underground equipment	Underground Service	Patrol/Test/Inspect	Repair	I
150993550	306003	04/09/2015	7:59	04/09/2015	10:40	1	161	161	Weather	Fuse	Repair		VI
150993557	Y28598	04/09/2015	8:02	04/09/2015	9:30	1	88	88	Weather	Fuse	Replace - Same Size		IV
150993609	J33803	04/09/2015	8:18	04/09/2015	8:55	1	37	37	Overhead equipment				V
150993649	X09594	04/09/2015	8:26	04/09/2015	9:11	2	90	45	Weather	Fuse	Replace - Same Size		IV
150993739	H14342	04/09/2015	8:28	04/09/2015	10:13	61	6405	104	Weather	Fuse	Replace - Same Size		V
150993706	J34357	04/09/2015	8:37	04/09/2015	9:14	28	1036	37	Weather	Fuse	Replace - Same Size		V
150993716	Z43549	04/09/2015	8:40	04/09/2015	9:22	1	42	42	Overhead equipment	Fuse	Replace - Same Size		IV
150993731	M04365	04/09/2015	8:42	04/09/2015	9:31	1	49	48	Weather	Transformer Fuse	Replace - Same Size		V
150993726	H22349	04/09/2015	8:42	04/09/2015	13:30	8	2304	287	Overhead equipment	Overhead Transformer	Replace - Same Size		V
150993759	V22555	04/09/2015	8:47	04/09/2015	9:40	1	53	53	Weather	Transformer Fuse	Replace - Same Size		II
150993779	310123	04/09/2015	8:53	04/09/2015	9:39	1	46	46	Weather	Fuse	Replace - Same Size		V
150993531	R20501	04/09/2015	8:59	04/09/2015	15:22	5	1915	383	Overhead equipment	Pole		Repair	IV
150993670	R04409	04/09/2015	9:01	04/09/2015	12:29	48	9984	207	Overhead equipment	Pole			V
150993912	R04409	04/09/2015	9:01	04/09/2015	11:17	1327	180472	135	Overhead equipment	Pole			V
150993969	R20501	04/09/2015	9:05	04/09/2015	12:15	21	3990	190	Weather	Crossarm	Patrol/Test/Inspect	Replace - Same Size	IV
150993859	F03003	04/09/2015	9:06	04/09/2015	11:57	1	171	171	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	III
150993882	N42856	04/09/2015	9:08	04/09/2015	10:56	1	108	107	Weather	Transformer Fuse	Replace - Same Size		V
150993896	L68114	04/09/2015	9:10	04/09/2015	10:57	1	107	107	Tree related-tree broken	Overhead Service	Repair		IV
150993903	J34377	04/09/2015	9:11	04/09/2015	10:27	1	76	75	Weather	Transformer Fuse	Replace - Same Size		V
5004725	R08910	04/09/2015	9:12	04/09/2015	11:27	1	134	134	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	VI
150993918	Y45504	04/09/2015	9:13	04/09/2015	9:48	1	35	34	Overhead equipment	Transformer Fuse	Repair	Replace - Same Size	IV
150995007	J07173	04/09/2015	9:26	04/09/2015	12:25	1	179	178	Overhead equipment	Overhead Transformer	Replace - Same Size	Replace - Same Size	I
150994016	315106	04/09/2015	9:35	04/09/2015	11:49	1	134	133	Overhead equipment	Overhead Transformer	Replace - Same Size		V
5004731	Q24312	04/09/2015	9:36	04/09/2015	14:04	1	267	267	Tree related-tree broken	Overhead Primary	Switch/Reset	Repair	VI
150994072	K89143	04/09/2015	9:42	04/09/2015	10:27	1	45	45	Weather	Transformer Fuse	Replace - Same Size		III

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
150994098	349001	04/09/2015	9:49	04/09/2015	10:55	1	66	65	Overhead equipment	Fuse	Replace - Same Size		VI
5004739	Q21423	04/09/2015	10:01	04/09/2015	11:14	2	145	72	Overhead equipment	Transformer Fuse	Repair	Repair	VI
150994179	P05825	04/09/2015	10:05	04/09/2015	11:20	1	75	74	Weather	Fuse	Replace - Same Size		V
5004741	K67924	04/09/2015	10:17	04/09/2015	12:56	1	158	158	Weather	Pole	Repair	Repair	VI
5004749	Q11517	04/09/2015	10:22	04/09/2015	11:10	1	47	47	Weather	Fuse	Replace - Same Size		I
150994300	P19395	04/09/2015	10:29	04/09/2015	11:23	1	54	54	Weather	Fuse	Replace - Same Size		V
150994323	D48003	04/09/2015	10:33	04/09/2015	14:28	1	235	235	Underground equipment	Underground Secondary	Repair		I
5004753	R95520	04/09/2015	10:42	04/09/2015	11:50	1	67	67	Weather	Transformer Fuse	Repair		I
150994428	V25513	04/09/2015	10:50	04/09/2015	11:30	1	40	39	Weather				II
150994576	R61242	04/09/2015	11:18	04/09/2015	12:45	1	87	87	Overhead equipment	Transformer Fuse	Repair		IV
150994667	Q74150	04/09/2015	11:36	04/09/2015	12:36	1	60	60	Weather	Transformer Fuse	Replace - Same Size		IV
150994677	M12151	04/09/2015	11:37	04/09/2015	12:14	4	148	37	Overhead equipment				VI
150994749	L99392	04/09/2015	11:48	04/09/2015	12:58	1	70	69	Weather	Transformer Fuse	Replace - Same Size		V
150994745	K76546	04/09/2015	11:49	04/09/2015	14:15	1	146	146	Tree related-tree broken	Overhead Secondary	Repair		IV
150994811	P52305	04/09/2015	12:00	04/09/2015	12:55	1	55	55	Weather	Transformer Fuse	Replace - Same Size		IV
150994831	R59415	04/09/2015	12:05	04/09/2015	13:15	1	70	70	Overhead equipment				IV
150994835	Y93544	04/09/2015	12:06	04/09/2015	12:41	1	35	34	Overhead equipment	Transformer Fuse	Repair	Replace - Same Size	IV
150995006	C70002	04/09/2015	12:07	04/09/2015	13:03	43	2408	55	Overhead equipment	Fuse	Replace - Same Size		III
150994869	N50331	04/09/2015	12:11	04/09/2015	13:00	1	49	48	Weather	Overhead Service	Repair		II
150994886	C70002	04/09/2015	12:13	04/09/2015	13:04	1	51	50	Overhead equipment	Fuse	Replace - Same Size		III
150994899	D53001	04/09/2015	12:16	04/09/2015	13:06	1	50	49	Animal related	Fuse	Replace - Same Size		I
150994900	C70002	04/09/2015	12:16	04/09/2015	13:02	1	46	46	Overhead equipment	Fuse	Replace - Same Size		III
5004767	Q82907	04/09/2015	12:17	04/09/2015	13:07	1	49	49	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	VI
150994921	S34527	04/09/2015	12:19	04/09/2015	13:25	1	66	66	Other	Other			VI
150994978	E10001	04/09/2015	12:31	04/09/2015	13:22	1	51	50	Animal related	Transformer Fuse	Replace - Same Size		III
150995051	306003	04/09/2015	12:43	04/09/2015	13:39	1	56	55	Weather	Fuse	Repair		VI
150995050	L79158	04/09/2015	12:43	04/09/2015	13:32	1	49	48	Animal related	Transformer Fuse	Replace - Same Size		IV
150995072	R20501	04/09/2015	12:49	04/09/2015	13:30	1	41	40	Weather	Transformer Fuse	Repair		IV
150995872	B25002	04/09/2015	12:51	04/09/2015	16:45	2	468	233	Overhead equipment	Overhead Primary		Repair	I
150995134	B25002	04/09/2015	12:51	04/09/2015	14:44	51	5763	113	Overhead equipment	Recloser	Switch/Reset		I
150995212	M04364	04/09/2015	13:06	04/09/2015	13:33	199	5373	27	Overhead equipment	Recloser	Patrol/Test/Inspect		V
150995568	S06264	04/09/2015	13:13	04/09/2015	14:34	3887	314847	81	Overhead equipment	Pole	Replace - Same Size	Replace - Same Size	VI
150995197		04/09/2015	13:15	04/09/2015	18:14	1	299	299	Underground equipment	Underground Primary	Repair	Repair	VI
150995220	S14510	04/09/2015	13:20	04/09/2015	14:08	1	48	47	Tree related-tree broken	Transformer Fuse	Repair	Replace - Same Size	VI
150995235	S22595	04/09/2015	13:21	04/09/2015	13:45	30	720	23	Tree related-tree broken	Overhead Primary	Remove	Remove	VI
150995342	R20501	04/09/2015	13:39	04/09/2015	14:27	1	48	47	Weather	Transformer Fuse	Repair		IV
150995401	T09559	04/09/2015	13:47	04/09/2015	15:08	3	243	81	Overhead equipment	Overhead Transformer	Repair	Repair	VI
150995588	J58380	04/09/2015	13:57	04/09/2015	14:19	1	22	21	Overhead equipment	Jumper		Repair	III
150995595	C70004	04/09/2015	13:59	04/09/2015	14:21	1	22	21	Animal related	Fuse	Replace - Same Size		III
5004781	P77233	04/09/2015	14:03	04/09/2015	14:58	1	54	54	Weather	Transformer Fuse	Replace - Same Size		VI
150995683	S60581	04/09/2015	14:16	04/09/2015	16:15	1	119	119	Overhead equipment	Overhead Transformer	Repair		VI
150995692	K39156	04/09/2015	14:16	04/09/2015	18:42	1	266	265	Overhead equipment	Jumper	Repair		III
150995697	E10002	04/09/2015	14:18	04/09/2015	17:20	1	182	181	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	III
150995706	R60552	04/09/2015	14:20	04/09/2015	15:10	1	50	50	Overhead equipment	Fuse	Replace - Same Size		IV
150995709	S88502	04/09/2015	14:21	04/09/2015	15:03	1	42	42	Overhead equipment	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
5004789	K32935	04/09/2015	14:27	04/09/2015	19:17	6	1739	289	Tree related-tree contact	Overhead Transformer	Replace - Same Size	Repair	VI
150995765	303005	04/09/2015	14:30	04/09/2015	15:49	1	79	79	Tree related-tree broken	Overhead Service	Repair		VI
150995771	S15560	04/09/2015	14:32	04/09/2015	15:35	1	63	62	Overhead equipment	Overhead Secondary	Replace - Same Size	Repair	VI
5004791	R29904	04/09/2015	14:55	04/09/2015	15:54	1	58	58	Animal related	Transformer Fuse			VI
5004793	T59925	04/09/2015	15:03	04/09/2015	18:17	1	194	194	Overhead equipment	Pole		Replace - New Size	VI
150996365	J63174	04/09/2015	15:10	04/09/2015	18:04	13	2262	174	Underground equipment	Underground Transformer			III
150996089	J63174	04/09/2015	15:10	04/09/2015	16:22	111	7992	71	Underground equipment	Underground Transformer			III
5004797	T59925	04/09/2015	15:15	04/09/2015	15:40	37	908	24	Overhead equipment	Pole	Cut in Clear		VI
150996022	M37191	04/09/2015	15:20	04/09/2015	16:35	1	75	74	Overhead equipment	Overhead Service	Repair		I
150996120	K62102	04/09/2015	15:43	04/09/2015	17:01	1	78	77	Weather	Fuse	Replace - Same Size		II
150996146	C00002	04/09/2015	15:47	04/09/2015	16:34	5	235	47	Weather	Transformer Fuse	Replace - Same Size	Replace - Same Size	I

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
150996154	F03003	04/09/2015	15:50	04/09/2015	18:08	1	138	138	Other	Meter			III
150996163	Q27185	04/09/2015	15:52	04/10/2015	0:12	1	500	499	Weather	Overhead Transformer		Replace - Same Size	VI
150996167	T15570	04/09/2015	15:53	04/09/2015	17:15	1	82	81	Overhead equipment	Overhead Service	Patrol/Test/Inspect	Repair	VI
150996198	S04545	04/09/2015	16:00	04/09/2015	17:45	1	105	105	Underground equipment				VI
150996199	K09863	04/09/2015	16:01	04/09/2015	16:47	1	46	46	Overhead equipment	Jumper	Replace - Same Size	Repair	V
150996277	B46002	04/09/2015	16:09	04/09/2015	17:05	1	56	55	Weather	Overhead Service	Repair		I
150996313	C70002	04/09/2015	16:12	04/09/2015	19:00	1	168	167	Animal related	Fuse	Replace - Same Size		III
5004803	Y61003	04/09/2015	16:13	04/09/2015	16:38	6	149	24	Overhead equipment	Overhead Secondary			IV
150996355	P54827	04/09/2015	16:26	04/09/2015	17:40	1	74	74	Overhead equipment	Connector	Tie/Tighten		V
150996407	U90566	04/09/2015	16:40	04/09/2015	17:29	1	49	49	Overhead equipment				II
150996436	M40132	04/09/2015	16:47	04/09/2015	18:45	1	118	117	Overhead equipment	Overhead Service	Repair	Replace - Same Size	I
150996442	K36151	04/09/2015	16:50	04/09/2015	17:50	1	60	59	Tree related-tree contact	Overhead Service	Repair		III
150996481	L82187	04/09/2015	16:59	04/09/2015	18:49	1	110	110	Overhead equipment	Fuse	Replace - Same Size		IV
5004807	X96543	04/09/2015	17:02	04/09/2015	18:15	1	72	72	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
5004809	K31120	04/09/2015	17:11	04/09/2015	17:55	1	43	43	Weather	Transformer Fuse	Repair		I
150996526	J01118	04/09/2015	17:14	04/09/2015	18:50	1	96	95	Tree related-tree broken	Overhead Service	Cut in Clear	Cut in Clear	I
5004813	K08909	04/09/2015	17:39	04/09/2015	18:33	1	53	53	Overhead equipment	Connector	Patrol/Test/Inspect	Repair	VI
150996658	M18216	04/09/2015	17:46	04/09/2015	18:40	1	54	54	Overhead equipment	Connector	Replace - Same Size		III
150996704	U64518	04/09/2015	18:00	04/09/2015	19:20	1	80	79	Overhead equipment	Overhead Service	Repair		II
5004815	K08909	04/09/2015	18:01	04/09/2015	18:33	1	31	31	Overhead equipment	Connector	Patrol/Test/Inspect	Repair	VI
5004819	R95520	04/09/2015	18:17	04/09/2015	19:30	1	72	72	Weather	Transformer Fuse	Repair		I
150996838	N58144	04/09/2015	18:36	04/09/2015	19:18	7	294	42	Tree related-tree broken	Fuse			I
5004825	T59925	04/09/2015	18:36	04/09/2015	19:55	1	78	78	Overhead equipment	Fuse	Replace - Same Size	Patrol/Test/Inspect	VI
150996823	U83746	04/09/2015	18:37	04/09/2015	19:07	1	30	30	Overhead equipment	Pole	Replace - Same Size		II
150996820	H02256	04/09/2015	18:42	04/09/2015	20:05	10	830	82	Overhead equipment	Overhead Primary			III
150996837	P73158	04/09/2015	18:45	04/09/2015	19:57	1	72	72	Weather	Fuse		Replace - Same Size	VI
150997199	V18582	04/09/2015	18:45	04/09/2015	20:25	236	23600	100	Weather	Fuse	Replace - Same Size		II
150996876	U84587	04/09/2015	18:47	04/10/2015	8:42	121	101035	835	Overhead equipment	Pole	Switch/Reset	Repair	II
150996850	B84002	04/09/2015	18:48	04/09/2015	19:49	1	61	60	Overhead equipment	Connector	Replace - New Size		I
150996847	U33586	04/09/2015	18:48	04/09/2015	19:57	1	69	69	Overhead equipment	Transformer Fuse	Replace - Same Size		II
150996872	J13108	04/09/2015	18:53	04/09/2015	20:15	1	82	81	Overhead equipment	Connector	Replace - Same Size		I
150997282	Q87319	04/09/2015	19:06	04/10/2015	0:35	467	153643	329	Weather	Pole			V
150997644	Q87319	04/09/2015	19:06	04/09/2015	21:00	1510	172140	114	Overhead equipment	Pole			V
150998108	J80807	04/09/2015	19:07	04/10/2015	2:55	1416	662688	468	Weather	Pole	Replace - Same Size		V
150997284	A85001	04/09/2015	19:17	04/09/2015	23:04	1	227	226	Tree related-tree contact	Overhead Secondary			I
150997292	U07001	04/09/2015	19:21	04/09/2015	20:55	7	658	94	Weather	Transformer Fuse	Repair	Repair	II
151000199	M47816	04/09/2015	19:32	04/10/2015	2:48	2	872	436	Overhead equipment	Overhead Primary	Repair		V
150997343	V22555	04/09/2015	19:36	04/10/2015	3:30	1	474	474	Weather	Pole	Replace - New Size		II
150997423	M26164	04/09/2015	19:36	04/09/2015	20:05	132	3828	29	Overhead equipment	Jumper	Repair		III
151000135	M47816	04/09/2015	19:37	04/10/2015	2:50	76	32908	432	Tree related-tree broken	Overhead Primary	Replace - Same Size		V
150997375	315106	04/09/2015	19:42	04/09/2015	21:40	1	118	118	Tree related-tree broken	Overhead Service		Repair	V
150997422	329146	04/09/2015	19:42	04/10/2015	1:00	21	6678	317	Overhead equipment	Overhead Secondary	Patrol/Test/Inspect	Repair	V
150997380	329149	04/09/2015	19:44	04/09/2015	19:51	1	7	6	Overhead equipment	Overhead Service	Repair		V
151000159	J80807	04/09/2015	19:47	04/10/2015	7:20	3	2079	692	Overhead equipment	Jumper			V
151000157	J80807	04/09/2015	19:47	04/10/2015	2:55	24	10272	428	Overhead equipment	Fuse			V
150997678	N35852	04/09/2015	19:48	04/10/2015	0:02	501	127254	254	Weather	Recloser	Switch/Reset		V
150997447	A17024	04/09/2015	19:58	04/09/2015	20:34	1	36	36	Other	Other			I
150997445	U32579	04/09/2015	19:58	04/09/2015	21:18	7	560	79	Tree related-tree broken	Overhead Secondary	Remove		II
150997448	Q15844	04/09/2015	20:00	04/10/2015	0:08	1	248	248	Tree related-tree broken	Overhead Service	Replace - Same Size		V
150997459	V23522	04/09/2015	20:02	04/10/2015	2:25	1	383	383	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	II
5004827	R16511	04/09/2015	20:03	04/09/2015	21:20	1	76	76	Tree related-tree contact				I
150997537	N67309	04/09/2015	20:06	04/09/2015	22:38	63	9576	152	Overhead equipment	Overhead Primary	Replace - Same Size	Replace - Same Size	I
150997471	J33803	04/09/2015	20:06	04/09/2015	21:00	1	54	53	Weather	Tree	Remove	Remove	V
150997475	A48002	04/09/2015	20:07	04/09/2015	21:22	1	75	75	Overhead equipment	Overhead Secondary	Repair		I
150997482	V77543	04/09/2015	20:08	04/09/2015	23:02	1	174	174	Weather	Overhead Transformer	Disconnect	Replace - Same Size	II
150997500	B82001	04/09/2015	20:15	04/10/2015	2:55	1	400	400	Overhead equipment	Overhead Transformer	Replace - Same Size		I

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
150997503	Q15844	04/09/2015	20:16	04/09/2015	23:23	1	187	187	Public	Overhead Service			V
150997513	N67309	04/09/2015	20:18	04/10/2015	0:44	1	266	265	Tree related-tree broken	Pole	Replace - Urgent		I
150997618	D28124	04/09/2015	20:19	04/10/2015	5:27	71	38908	547	Overhead equipment	Pole	Replace - Same Size		I
150997516	U33586	04/09/2015	20:19	04/10/2015	1:20	1	301	300	Overhead equipment	Fuse	Replace - Same Size		II
150997548	M22812	04/09/2015	20:27	04/10/2015	0:06	17	3723	219	Tree related-tree broken	Overhead Primary	Repair	Repair	V
150997540	Q15844	04/09/2015	20:28	04/09/2015	23:05	1	157	156	Overhead equipment	Transformer Fuse	Replace - Same Size		V
5004829	P77237	04/09/2015	20:35	04/09/2015	21:49	1	73	73	Weather	Fuse	Replace - Same Size		VI
150997567	N67315	04/09/2015	20:37	04/09/2015	21:42	3	195	65	Unknown	Transformer Fuse	Replace - Same Size		I
150997579	B38002	04/09/2015	20:41	04/09/2015	22:33	2	224	111	Overhead equipment	Fuse	Replace - Same Size		I
5004855	N22296	04/09/2015	20:41	04/09/2015	21:45	149	9488	63	Tree related-tree broken	Overhead Primary			VI
5004841	N22296	04/09/2015	20:51	04/09/2015	21:45	1	53	53	Tree related-tree broken				VI
5004847	K31120	04/09/2015	20:52	04/09/2015	21:59	60	4000	66	Tree related-tree broken	Fuse	Replace - Same Size		I
150997615	K89143	04/09/2015	20:53	04/09/2015	21:50	65	3705	56	Tree related-tree broken	Tree	Remove		III
150997598	R28871	04/09/2015	20:55	04/10/2015	6:42	1	587	586	Tree related-tree broken	Overhead Primary	Replace - Same Size	Replace - Same Size	V
150997602	U32594	04/09/2015	20:57	04/10/2015	3:40	3	1209	403	Overhead equipment	Jumper	Repair		II
5004853	M19222	04/09/2015	20:58	04/10/2015	0:42	1	223	223	Tree related-tree broken	Tree			VI
5005049	M19222	04/09/2015	21:02	04/10/2015	6:25	3	1686	562	Tree related-tree broken	Pole		Repair	VI
150997638	V40549	04/09/2015	21:08	04/10/2015	8:16	9	6012	667	Tree related-tree broken	Pole	Replace - Same Size	Replace - Same Size	II
150997662	P73158	04/09/2015	21:12	04/09/2015	22:10	12	696	58	Weather	Fuse		Replace - Same Size	VI
150997671	M37192	04/09/2015	21:15	04/09/2015	23:22	6	762	127	Overhead equipment	Overhead Secondary	Repair		I
150997676	U06551	04/09/2015	21:15	04/09/2015	23:20	11	1375	124	Overhead equipment	Fuse	Replace - Same Size		II
150997675	A45002	04/09/2015	21:17	04/09/2015	22:02	1	45	45	Overhead equipment	Overhead Service	Repair		I
150997688	349002	04/09/2015	21:22	04/09/2015	22:08	1	46	46	Overhead equipment	Overhead Transformer	Switch/Reset		VI
150997690	P05825	04/09/2015	21:22	04/10/2015	2:45	1	323	323	Weather	Fuse	Repair	Repair	V
150997694	Z43549	04/09/2015	21:24	04/09/2015	22:25	14	854	60	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
150997697	N35852	04/09/2015	21:24	04/10/2015	0:14	91	15470	169	Weather	Overhead Primary	Repair		V
5004865	K32915	04/09/2015	21:26	04/10/2015	1:18	1	232	232	Tree related-tree broken	Tree		Remove	VI
5004867	M20221	04/09/2015	21:26	04/09/2015	22:53	1	86	86	Tree related-tree broken	Tree			VI
150997704	J79305	04/09/2015	21:28	04/09/2015	23:35	1	127	127	Overhead equipment	Overhead Primary	Replace - Same Size	Replace - Same Size	I
150997705	P73158	04/09/2015	21:28	04/09/2015	22:11	1	43	43	Weather	Fuse	Replace - Same Size		VI
150997710	V03529	04/09/2015	21:30	04/09/2015	23:29	1	119	119	Weather	Overhead Service	Repair		II
150997739	P49183	04/09/2015	21:33	04/09/2015	22:19	1	46	45	Overhead equipment	Jumper	Repair		I
150997746	A17022	04/09/2015	21:39	04/09/2015	22:45	1	66	65	Overhead equipment	Overhead Service	Repair		I
150997748	A81001	04/09/2015	21:41	04/09/2015	22:27	1	46	46	Overhead equipment				I
5004925	HE3303	04/09/2015	21:43	04/09/2015	23:55	99	13010	131	Other	Overhead Primary			VI
150997754	R84148	04/09/2015	21:44	04/09/2015	23:14	4	360	90	Overhead equipment	Jumper	Repair	Reconnect	I
150997788	N35852	04/09/2015	21:49	04/10/2015	0:17	1	148	148	Weather	Overhead Primary	Repair		V
150997790	J76804	04/09/2015	21:50	04/10/2015	1:30	1	220	220	Overhead equipment	Overhead Transformer	Repair	Repair	V
150997794	N67315	04/09/2015	21:52	04/10/2015	1:07	3	585	194	Overhead equipment	Overhead Secondary	Cut in Clear		I
150997816	A85001	04/09/2015	21:59	04/10/2015	3:12	1	313	312	Overhead equipment	Overhead Transformer	Disconnect	Replace - Same Size	I
5004907	R95520	04/09/2015	21:59	04/10/2015	0:28	73	10884	149	Overhead equipment	Overhead Primary	Patrol/Test/Inspect	Repair	I
5004889	K67912	04/09/2015	22:01	04/10/2015	0:20	1	138	138	Weather	Fuse	Replace - Same Size	Patrol/Test/Inspect	VI
150997822	N35852	04/09/2015	22:03	04/10/2015	0:19	1	136	136	Weather	Overhead Primary	Repair		V
150997875	S60581	04/09/2015	22:04	04/10/2015	6:13	7	3423	489	Tree related-tree broken	Overhead Primary	Patrol/Test/Inspect	Repair	VI
150997942	Y04504	04/09/2015	22:04	04/09/2015	23:43	278	27522	98	Overhead equipment	Substation Breaker	Switch/Reset		IV
150997938	Y04508	04/09/2015	22:04	04/09/2015	23:42	61	5978	98	Overhead equipment	Substation Breaker	Switch/Reset		IV
150997856	Y52787	04/09/2015	22:04	04/09/2015	23:01	606	34542	56	Overhead equipment	Substation Breaker	Switch/Reset		IV
5004895	M20221	04/09/2015	22:04	04/10/2015	2:45	1	280	280	Tree related-tree broken	Tree			VI
5005071	L93132	04/09/2015	22:08	04/10/2015	2:26	51	13196	258	Underground equipment	Underground Primary	Switch/Reset	Replace - New Size	VI
150997888	V34002	04/09/2015	22:16	04/10/2015	3:17	1	301	301	Tree related-tree broken	Overhead Service	Repair		II
150998077	Z06537	04/09/2015	22:18	04/09/2015	23:47	33	2937	88	Tree related-tree contact	Fuse	Replace - Same Size		IV
150997899	A17026	04/09/2015	22:19	04/09/2015	23:14	1	55	55	Tree related-tree broken	Overhead Service			I
150997901	P57102	04/09/2015	22:19	04/10/2015	0:20	1	121	121	Tree related-tree broken	Overhead Service	Replace - Same Size		VI
5005027	X86543	04/09/2015	22:22	04/10/2015	12:40	548	107064	858	Overhead equipment	Pole	Replace - New Size	Replace - New Size	IV
150997937	U11531	04/09/2015	22:28	04/10/2015	6:15	1	467	466	Tree related-tree broken	Fuse	Replace - Same Size		II
5004921	N22296	04/09/2015	22:30	04/10/2015	2:25	1	234	234	Overhead equipment	Overhead Primary	Repair		VI

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
150997958	J76804	04/09/2015	22:37	04/10/2015	1:48	1	191	190	Overhead equipment	Overhead Transformer	Repair	Repair	V
150997966	D69003	04/09/2015	22:40	04/10/2015	0:22	1	102	101	Unknown	Fuse	Replace - Same Size		I
150997971	A80001	04/09/2015	22:41	04/10/2015	1:44	1	183	182	Overhead equipment	Jumper	Repair		I
5004923	R95520	04/09/2015	22:45	04/10/2015	5:06	1	380	380	Overhead equipment	Disconnect Switch	Patrol/Test/Inspect	Repair	I
150997980	S47576	04/09/2015	22:51	04/10/2015	1:00	1	129	129	Tree related-tree broken	Overhead Service	Repair	Reconnect	VI
150997983	M22812	04/09/2015	22:51	04/10/2015	2:26	1	215	215	Weather	Fuse	Replace - Same Size		V
150997984	M09144	04/09/2015	22:52	04/10/2015	0:47	1	115	114	Weather	Fuse	Replace - Same Size		VI
150997985	S55535	04/09/2015	22:53	04/10/2015	1:05	1	132	132	Tree related-tree broken	Overhead Secondary			VI
150997991	L17101	04/09/2015	22:57	04/09/2015	23:57	1	60	59	Overhead equipment	Jumper	Repair		III
5004933	Y66557	04/09/2015	23:06	04/10/2015	15:40	678	133000	994	Tree related-tree broken	Pole	Replace - New Size	Replace - New Size	IV
150998012	M09144	04/09/2015	23:14	04/10/2015	0:13	8	472	59	Tree related-tree broken	Overhead Primary	Replace - Same Size		VI
150998024	B73003	04/09/2015	23:18	04/10/2015	1:04	1	106	105	Tree related-tree broken	Overhead Service	Repair		I
151000001	U44529	04/09/2015	23:18	04/10/2015	1:16	305	35990	117	Overhead equipment	Guy Wire			II
5004975	Y63541	04/09/2015	23:24	04/10/2015	3:35	12	3006	250	Weather	Transformer Fuse		Replace - Same Size	IV
150998053	R84148	04/09/2015	23:27	04/10/2015	0:21	1	54	53	Unknown	Transformer Fuse	Replace - Same Size		I
151000173	S92559	04/09/2015	23:27	04/10/2015	1:25	56	6608	118	Weather	Recloser	Switch/Reset		VI
150998054	M09144	04/09/2015	23:28	04/10/2015	2:10	1	162	162	Weather	Fuse	Replace - Same Size		VI
150998058	S78551	04/09/2015	23:29	04/10/2015	1:24	1	115	114	Tree related-tree broken	Overhead Service	Repair	Replace - Same Size	VI
150998139	Q75145	04/09/2015	23:33	04/10/2015	6:35	16	6752	422	Tree related-tree broken	Overhead Primary	Replace - Same Size		VI
150998091	D66004	04/09/2015	23:37	04/10/2015	5:25	1	348	348	Tree related-tree broken	Overhead Service	Repair		IV
150998102	308003	04/09/2015	23:44	04/10/2015	1:05	1	81	81	Overhead equipment	Overhead Service	Repair		VI
5004991	P83710	04/09/2015	23:45	04/10/2015	4:56	607	188758	310	Public	Overhead Primary	Patrol/Test/Inspect	Repair	I
151003544	M09143	04/09/2015	23:54	04/10/2015	5:35	13	4433	341	Tree related-tree broken	Overhead Primary	Repair		VI
5005023	X49569	04/10/2015	0:00	04/10/2015	4:00	1	239	239	Tree related-tree broken	Overhead Service			IV
151000002	Q32171	04/10/2015	0:01	04/10/2015	5:55	1	354	354	Overhead equipment	Overhead Transformer	Replace - New Size	Repair	I
5005025	Q34360	04/10/2015	0:02	04/10/2015	2:06	1	123	123	Overhead equipment	Fuse	Replace - Same Size		I
151000109	S92559	04/10/2015	0:04	04/10/2015	2:58	1	174	174	Tree related-tree broken	Overhead Service	Replace - New Size		VI
151000113	V18553	04/10/2015	0:06	04/10/2015	1:42	1	96	95	Tree related-tree broken	Overhead Service		Repair	II
151000114	M09143	04/10/2015	0:07	04/10/2015	6:27	1	380	380	Weather	Fuse	Replace - Same Size		VI
151000136	N35852	04/10/2015	0:22	04/10/2015	2:05	1	103	103	Weather	Overhead Transformer	Replace - Same Size		V
151000137	339162	04/10/2015	0:25	04/10/2015	1:40	1	75	75	Tree related-tree broken	Overhead Service	Repair		V
151000216	U33509	04/10/2015	0:39	04/10/2015	2:25	51	5406	105	Overhead equipment	Jumper	Repair		II
151000158	D72002	04/10/2015	0:58	04/10/2015	2:20	1	82	81	Tree related-tree broken	Fuse	Replace - Same Size		I
5005047	Y31589	04/10/2015	1:01	04/10/2015	1:58	1	56	56	Weather	Transformer Fuse			IV
151000169	X88510	04/10/2015	1:13	04/10/2015	3:00	1	107	107	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
5005053	Y63539	04/10/2015	1:21	04/10/2015	3:29	1	127	127	Overhead equipment	Overhead Secondary	Repair		IV
151000190	P60170	04/10/2015	1:31	04/10/2015	4:06	1	155	154	Tree related-tree broken	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	VI
151000196	309143	04/10/2015	1:44	04/10/2015	2:35	1	51	50	Tree related-tree broken	Overhead Service	Repair		V
151000210	327155	04/10/2015	1:46	04/10/2015	5:45	15	3585	239	Tree related-tree broken	Overhead Primary			V
151000212	R53391	04/10/2015	1:47	04/10/2015	3:08	1	81	81	Underground equipment	Underground Service	Patrol/Test/Inspect	Repair	V
5005073	M20221	04/10/2015	2:15	04/10/2015	2:37	2	43	21	Tree related-tree broken	Overhead Transformer			VI
151003540	J80806	04/10/2015	3:18	04/10/2015	6:30	10	1920	192	Overhead equipment	Overhead Primary	Repair	Repair	V
151003538	K28183	04/10/2015	3:20	04/10/2015	5:21	1	121	120	Tree related-tree contact	Fuse	Replace - Same Size		III
151003547	N35852	04/10/2015	3:38	04/10/2015	4:30	1	52	52	Weather	Transformer Fuse	Replace - Same Size	Replace - Same Size	V
5005087	J99141	04/10/2015	4:23	04/10/2015	8:48	3	793	264	Underground equipment	Underground Transformer		Repair	VI
5005089	Q93522	04/10/2015	4:51	04/10/2015	7:12	1	140	140	Weather	Recloser	Patrol/Test/Inspect	Replace - Urgent	I
5005091	Y63527	04/10/2015	5:19	04/10/2015	7:07	1	107	107	Tree related-tree broken	Overhead Service	Repair		IV
151003622	L79158	04/10/2015	5:20	04/10/2015	8:50	1	210	210	Underground equipment	Underground Service	Repair		IV
151003742	M37191	04/10/2015	5:36	04/10/2015	13:10	7	3178	454	Overhead equipment	Pole	Replace - Same Size	Replace - Same Size	I
151003655	U16522	04/10/2015	5:45	04/10/2015	8:30	3	495	164	Tree related-tree broken	Fuse			II
151003661	Y04508	04/10/2015	5:55	04/10/2015	9:35	1	220	219	Overhead equipment	Transformer Fuse	Replace - New Size		IV
151003662	R48166	04/10/2015	5:56	04/10/2015	7:01	2	130	65	Overhead equipment	Fuse			IV
151003671		04/10/2015	6:05	04/10/2015	8:16	1	131	131	Tree related-tree broken	Tree	Patrol/Test/Inspect	Remove	II
151003675	K28180	04/10/2015	6:09	04/10/2015	8:40	1	151	150	Tree related-tree contact	Fuse	Replace - Same Size		III
151003678	S49549	04/10/2015	6:17	04/10/2015	9:10	1	173	172	Tree related-tree broken	Overhead Service	Repair	Patrol/Test/Inspect	VI
151003680	K89143	04/10/2015	6:20	04/10/2015	9:12	4	688	171	Tree related-tree broken	Overhead Primary	Repair		III

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
151003696	Q04411	04/10/2015	6:36	04/10/2015	9:26	1	170	169	Overhead equipment	Jumper	Repair	Repair	III
151003700	K89143	04/10/2015	6:39	04/10/2015	10:36	9	2133	236	Tree related-tree broken	Overhead Secondary	Raise		III
151003740	S25551	04/10/2015	7:02	04/10/2015	9:06	1	124	123	Tree related-tree broken	Overhead Secondary	Patrol/Test/Inspect	Repair	VI
151003776	P52305	04/10/2015	7:13	04/10/2015	8:42	1	89	89	Animal related	Transformer Fuse	Replace - Same Size		IV
151003774	M47816	04/10/2015	7:13	04/10/2015	8:34	1	81	81	Tree related-tree broken	Overhead Service	Repair	Repair	V
151003792	T15570	04/10/2015	7:18	04/10/2015	8:40	1	82	81	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	VI
151003800	Q15844	04/10/2015	7:20	04/10/2015	8:04	1	44	43	Tree related-tree broken				V
151003815	M09175	04/10/2015	7:26	04/10/2015	9:07	1	101	101	Weather	Fuse	Replace - Same Size		VI
151003853	Q01282	04/10/2015	7:39	04/10/2015	10:07	1	148	148	Overhead equipment	Connector	Repair	Repair	III
5005137	Q37372	04/10/2015	7:50	04/10/2015	10:26	32	4996	156	Public	Underground Primary	Repair	Replace - Same Size	I
151003902	K89142	04/10/2015	7:53	04/10/2015	9:00	1	67	66	Tree related-tree contact	Overhead Service	Repair		III
5005103	Q37372	04/10/2015	8:01	04/10/2015	11:00	1	178	178	Public	Underground Primary	Repair	Replace - Same Size	I
5005105	R16511	04/10/2015	8:02	04/10/2015	13:06	1	303	303	Overhead equipment				I
151003947	J34356	04/10/2015	8:04	04/10/2015	10:11	1	127	127	Weather	Transformer Fuse	Replace - Same Size		V
151003951	J80807	04/10/2015	8:05	04/10/2015	9:10	1	65	65	Overhead equipment	Transformer Fuse	Replace - Same Size		V
5005107	R08910	04/10/2015	8:07	04/10/2015	8:48	1	40	40	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	VI
5005109	J99127	04/10/2015	8:09	04/10/2015	10:51	1	161	161	Overhead equipment	Overhead Service		Repair	VI
151003975	S49549	04/10/2015	8:10	04/10/2015	10:45	1	155	154	Tree related-tree contact	Transformer Fuse	Replace - Same Size		VI
5005111	J18268	04/10/2015	8:11	04/10/2015	9:40	1	88	88	Overhead equipment	Overhead Service	Repair	Repair	VI
151004027	X09534	04/10/2015	8:21	04/10/2015	10:35	1	134	133	Tree related-tree broken	Tree	Remove		IV
151004046	P47169	04/10/2015	8:27	04/10/2015	10:45	1	138	137	Other	Overhead Service	Remove		I
151004099	P05825	04/10/2015	8:41	04/10/2015	9:43	1	62	62	Weather	Transformer Fuse	Replace - Same Size	Repair	V
151004112	M22812	04/10/2015	8:44	04/10/2015	10:23	1	99	98	Weather	Meter	Patrol/Test/Inspect		V
151004150	S47576	04/10/2015	8:53	04/10/2015	14:35	1	342	342	Tree related-tree broken	Overhead Service	Cut in Clear		VI
151004161	L80221	04/10/2015	8:56	04/10/2015	11:35	1	159	159	Overhead equipment	Overhead Transformer			IV
151004250	N03296	04/10/2015	9:01	04/10/2015	9:55	18	972	53	Overhead equipment	Pole	Patrol/Test/Inspect	Replace - New Size	V
151004196	D36001	04/10/2015	9:03	04/10/2015	10:04	1	61	60	Overhead equipment	Overhead Service	Replace - Same Size	Replace - Same Size	I
151004223	Q15844	04/10/2015	9:08	04/10/2015	10:55	1	107	106	Overhead equipment	Connector	Replace - Same Size	Repair	V
151004301	M09144	04/10/2015	9:23	04/10/2015	10:31	1	68	68	Tree related-tree contact	Overhead Service	Repair	Replace - Same Size	VI
151004328	K71812	04/10/2015	9:25	04/10/2015	11:15	17	1870	110	Animal related	Fuse	Patrol/Test/Inspect	Replace - Same Size	IV
151004350	C37002	04/10/2015	9:32	04/10/2015	10:08	1	36	36	Underground equipment	Underground Transformer	Repair	Replace - Same Size	III
151004435	U31542	04/10/2015	9:50	04/10/2015	10:31	1	41	41	Overhead equipment	Connector	Repair		II
5005133	Q54908	04/10/2015	10:08	04/10/2015	11:01	1	52	52	Animal related	Transformer Fuse		Replace - Same Size	VI
151004033	N03296	04/10/2015	10:15	04/10/2015	14:45	16	4320	270	Tree related-tree broken	Pole	Patrol/Test/Inspect	Replace - New Size	V
151004795	U10547	04/10/2015	11:05	04/10/2015	12:30	4	340	85	Animal related	Transformer Fuse	Replace - Same Size	Patrol/Test/Inspect	II
151004872	Y51505	04/10/2015	11:17	04/10/2015	15:16	1	239	239	Underground equipment	Underground Service	Patrol/Test/Inspect	Repair	IV
5005157	X86546	04/10/2015	11:26	04/10/2015	12:54	90	7948	88	Overhead equipment	Fuse	Replace - Same Size		IV
5005155	HB5890	04/10/2015	11:30	04/10/2015	13:20	1	109	109	Animal related	Fuse	Repair		I
5005163	HB5890	04/10/2015	12:09	04/10/2015	13:20	1	70	70	Animal related	Fuse	Repair		I
5005167	M19222	04/10/2015	12:26	04/10/2015	15:47	1	200	200	Weather	Fuse	Replace - Same Size		VI
151006191	C60001	04/10/2015	13:42	04/10/2015	17:17	189	40635	214	Overhead equipment	Fuse	Replace - Same Size		III
5005177	R50910	04/10/2015	14:00	04/10/2015	16:50	1	169	169	Overhead equipment	Jumper	Repair		I
151005630	A97006	04/10/2015	14:07	04/10/2015	15:32	1	85	85	Overhead equipment	Jumper	Repair		I
151005667	P73158	04/10/2015	14:14	04/10/2015	17:00	1	166	166	Overhead equipment	Overhead Transformer	Repair	Repair	VI
151005681	K79211	04/10/2015	14:17	04/10/2015	15:22	1	65	65	Tree related-tree broken	Overhead Service	Cut in Clear		IV
151005760	J34356	04/10/2015	14:40	04/10/2015	16:42	1	122	121	Weather	Transformer Fuse	Replace - Same Size		V
151005788	B93003	04/10/2015	14:42	04/10/2015	18:55	9	2277	252	Tree related-tree broken	Overhead Primary	Patrol/Test/Inspect	Repair	I
151005777	V03562	04/10/2015	14:44	04/10/2015	19:10	1	266	265	Other	Overhead Transformer	Replace - New Size	Replace - Same Size	II
151005797	U80564	04/10/2015	14:49	04/10/2015	18:36	1	227	227	Overhead equipment	Overhead Transformer	Replace - Same Size	Repair	II
5005185	Y66557	04/10/2015	14:55	04/10/2015	15:40	59	2626	44	Overhead equipment	Overhead Primary	Replace - Same Size	Replace - Same Size	IV
151005854	J15303	04/10/2015	15:04	04/10/2015	20:20	1	316	315	Overhead equipment	Overhead Primary	Replace - Same Size	Replace - Same Size	I
151005880	B84004	04/10/2015	15:12	04/10/2015	17:03	1	111	111	Overhead equipment	Transformer Fuse			I
5005293	Q70161	04/10/2015	15:21	04/10/2015	17:57	4	623	155	Overhead equipment	Overhead Primary	Replace - Same Size	Replace - Same Size	I
5005277	Q70161	04/10/2015	15:22	04/10/2015	17:57	227	35293	155	Overhead equipment	Overhead Primary	Replace - Same Size	Replace - Same Size	I
5005295	Q70161	04/10/2015	15:23	04/10/2015	17:57	7	1075	153	Overhead equipment	Overhead Primary	Replace - Same Size	Replace - Same Size	I
5005245	Q70161	04/10/2015	15:24	04/10/2015	16:49	107	9044	84	Overhead equipment	Overhead Primary	Replace - Same Size	Replace - Same Size	I

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
151005910	B10002	04/10/2015	15:26	04/10/2015	20:21	2	590	294	Tree related-tree contact	Overhead Service	Cut in Clear	Repair	I
5005281	Q70161	04/10/2015	15:33	04/10/2015	17:57	3	430	143	Overhead equipment	Overhead Primary	Replace - Same Size	Replace - Same Size	I
5005283	Q70161	04/10/2015	15:35	04/10/2015	17:57	4	567	141	Overhead equipment	Overhead Primary	Replace - Same Size	Replace - Same Size	I
5005289	Q70161	04/10/2015	15:37	04/10/2015	17:57	1	139	139	Overhead equipment	Overhead Primary	Replace - Same Size	Replace - Same Size	I
5005247	Q70161	04/10/2015	15:37	04/10/2015	17:57	1	139	139	Overhead equipment	Overhead Primary	Replace - Same Size	Replace - Same Size	I
5005261	Q70161	04/10/2015	15:40	04/10/2015	17:57	1	136	136	Overhead equipment	Overhead Primary	Replace - Same Size	Replace - Same Size	I
151005998	U11531	04/10/2015	15:41	04/10/2015	16:27	1	46	46	Tree related-tree contact	Fuse	Replace - Same Size		II
5005243	R49261	04/10/2015	15:43	04/10/2015	17:54	1	130	130	Underground equipment	Underground Service		Repair	VI
151006011	D36002	04/10/2015	15:46	04/10/2015	18:44	1	178	177	Overhead equipment	Overhead Service	Repair		I
5005301	Q70161	04/10/2015	15:46	04/10/2015	17:57	12	1570	130	Overhead equipment				I
151006073	A36001	04/10/2015	15:49	04/10/2015	16:50	260	15860	60	Tree related-tree broken	Fuse	Replace - Same Size		I
151006039	D39001	04/10/2015	15:49	04/10/2015	20:00	1	251	251	Overhead equipment	Overhead Primary	Repair		I
151006036	M09175	04/10/2015	15:49	04/10/2015	18:09	1	140	139	Overhead equipment	Overhead Service	Replace - Same Size		VI
151006319	M25144	04/10/2015	15:52	04/10/2015	17:20	8	704	87	Overhead equipment	Disconnect Switch	Replace - Same Size		IV
151006079	R33126	04/10/2015	15:57	04/10/2015	18:20	1	143	143	Overhead equipment	Overhead Service	Cut in Clear	Repair	I
151006087	J79304	04/10/2015	15:57	04/10/2015	17:43	1	106	105	Tree related-tree contact	Overhead Service	Repair		I
151006100	J07173	04/10/2015	16:00	04/10/2015	17:08	1	68	68	Tree related-tree contact	Overhead Service	Repair		I
151006351	K39153	04/10/2015	16:05	04/10/2015	16:25	22	440	20	Overhead equipment	Transformer Fuse	Replace - Same Size		III
5005269	Q23256	04/10/2015	16:14	04/10/2015	17:32	54	4199	77	Overhead equipment	Fuse	Replace - Same Size		VI
151006179	A36001	04/10/2015	16:15	04/10/2015	17:09	1	54	53	Tree related-tree broken	Other			I
151006202	Q04411	04/10/2015	16:21	04/10/2015	21:28	1	307	306	Overhead equipment	Overhead Transformer			III
151006225	A36001	04/10/2015	16:29	04/10/2015	17:11	1	42	42	Tree related-tree broken	Other			I
5005291	Q70161	04/10/2015	16:37	04/10/2015	17:57	1	79	79	Overhead equipment				I
5005279	Q25801	04/10/2015	16:40	04/10/2015	23:23	2	806	403	Tree related-tree contact	Fuse	Repair		I
5005303	Q70161	04/10/2015	16:44	04/10/2015	17:57	4	288	72	Overhead equipment	Overhead Primary	Replace - Same Size	Replace - Same Size	I
5005297	Q25801	04/10/2015	16:57	04/10/2015	18:42	3	312	104	Tree related-tree contact	Fuse	Replace - Same Size		I
5005299	Q37370	04/10/2015	17:00	04/10/2015	20:15	1	194	194	Overhead equipment	Jumper	Repair	Repair	I
151006337	J79304	04/10/2015	17:08	04/10/2015	22:16	1	308	307	Other	Recloser	Switch/Reset		I
151006387	N54214	04/10/2015	17:26	04/10/2015	18:40	1	74	74	Unknown	Transformer Fuse	Replace - Same Size		II
5005305	N05172	04/10/2015	17:32	04/10/2015	19:45	1	132	132	Unknown	Fuse	Repair		I
151006435	A56017	04/10/2015	17:40	04/10/2015	19:11	1	91	91	Overhead equipment	Jumper	Repair		I
151006453	V21500	04/10/2015	17:51	04/10/2015	19:20	1	89	88	Other				II
151006455	P98191	04/10/2015	17:53	04/10/2015	20:50	1	177	177	Underground equipment	Underground Primary			III
151006457	M31202	04/10/2015	17:55	04/10/2015	19:23	1	88	87	Overhead equipment	Connector	Replace - Same Size	Replace - Same Size	I
151006471	A36001	04/10/2015	18:02	04/10/2015	19:04	1	62	62	Overhead equipment	Connector	Replace - Same Size		I
151006519	A80001	04/10/2015	18:22	04/10/2015	20:50	1	148	148	Overhead equipment	Overhead Primary	Repair		I
151006538	L35139	04/10/2015	18:43	04/10/2015	19:32	1	49	48	Tree related-tree contact	Overhead Service	Repair		III
151006543	J15303	04/10/2015	18:48	04/10/2015	20:29	1	101	101	Overhead equipment	Overhead Primary	Repair	Replace - Same Size	I
151006547	B68003	04/10/2015	18:51	04/10/2015	19:55	1	64	63	Tree related-tree broken	Fuse	Replace - Same Size		III
151006800	Q71846	04/10/2015	19:22	04/10/2015	21:09	1	107	107	Tree related-tree broken	Overhead Service	Repair	Repair	V
5005315	N05172	04/10/2015	19:31	04/10/2015	20:10	1	38	38	Unknown	Fuse	Repair		I
151006818	K89143	04/10/2015	19:40	04/10/2015	20:13	1	33	33	Overhead equipment	Connector	Replace - Same Size		III
151006858	J06167	04/10/2015	20:40	04/10/2015	21:24	2	88	44	Overhead equipment	Pole	Replace - Same Size		I
151006877	L35139	04/10/2015	21:06	04/10/2015	22:30	1	84	84	Tree related-tree broken	Overhead Service	Repair		III
5005321	N74230	04/10/2015	22:38	04/11/2015	0:05	1	86	86	Overhead equipment	Overhead Service	Replace - New Size		I
151010029	M45212	04/11/2015	1:15	04/11/2015	4:16	1	181	180	Overhead equipment	Overhead Service	Repair		IV
5005329	K32935	04/11/2015	1:15	04/11/2015	6:41	226	33362	326	Public				VI
5005341	K32935	04/11/2015	3:31	04/11/2015	6:41	22	4174	189	Public	Pole	Replace - Same Size		VI
151010067	U35554	04/11/2015	3:41	04/11/2015	9:20	1	339	339	Public	Pole	Replace - New Size	Repair	II
5005347	Y35004	04/11/2015	3:43	04/11/2015	4:10	1	26	26	Overhead equipment	Overhead Service			IV
151010078	U35554	04/11/2015	4:59	04/11/2015	6:41	1	102	101	Overhead equipment	Pole		Repair	II
5005359	X02546	04/11/2015	7:26	04/11/2015	9:21	1	114	114	Animal related	Transformer Fuse	Replace - Same Size		IV
5005361	K57211	04/11/2015	7:50	04/11/2015	9:35	4	418	104	Animal related	Fuse			VI
151010191	R60552	04/11/2015	8:25	04/11/2015	10:00	1	95	94	Overhead equipment	Fuse	Repair		IV
151010339	Q83171	04/11/2015	9:38	04/11/2015	19:40	8	4816	602	Underground equipment	Underground Primary	Repair	Repair	VI
151010355	L71171	04/11/2015	9:58	04/11/2015	10:23	1	25	24	Animal related	Transformer Fuse			IV

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
151010371	S66595	04/11/2015	10:14	04/11/2015	13:40	1	206	206	Overhead equipment				VI
5005367	J20931	04/11/2015	10:56	04/11/2015	12:36	1	99	99	Animal related	Fuse	Replace - Same Size		VI
151010424	J06168	04/11/2015	11:02	04/11/2015	14:30	1	208	207	Overhead equipment	Overhead Service	Repair		I
5005371	Q21293	04/11/2015	11:05	04/11/2015	14:11	21	3898	185	Public	Pole	Patrol/Test/Inspect	Replace - Same Size	VI
151010438	Q91175	04/11/2015	11:17	04/11/2015	13:45	1	148	148	Overhead equipment	Overhead Service	Repair		I
5005375	R95520	04/11/2015	11:27	04/11/2015	12:30	1	62	62	Animal related	Transformer Fuse	Replace - Same Size		I
151010457	M22812	04/11/2015	11:32	04/11/2015	12:29	1	57	56	Animal related	Transformer Fuse	Replace - Same Size	Replace - Same Size	V
5005379	N74230	04/11/2015	11:42	04/11/2015	13:40	1	117	117	Overhead equipment	Connector	Replace - Same Size		I
5005381	Q21293	04/11/2015	11:46	04/11/2015	17:56	1	369	369	Overhead equipment	Pole	Replace - Same Size	Replace - Same Size	VI
151010521	K39154	04/11/2015	12:33	04/11/2015	13:49	49	3724	75	Animal related	Fuse	Replace - Same Size		III
5005385	L63936	04/11/2015	12:53	04/11/2015	14:48	1	114	114	Animal related	Fuse	Replace - Same Size		VI
151010551	325008	04/11/2015	13:05	04/11/2015	17:56	1	291	290	Public	Overhead Secondary	Patrol/Test/Inspect		VI
151010557	H10843	04/11/2015	13:11	04/11/2015	16:10	1	179	178	Weather	Transformer Fuse	Replace - Same Size		V
151010558	V10551	04/11/2015	13:12	04/11/2015	15:07	1	115	114	Overhead equipment	Transformer Fuse	Replace - Same Size		II
151010564	342001	04/11/2015	13:20	04/11/2015	13:56	1	36	36	Public	Meter	Patrol/Test/Inspect		VI
5005393	K31124	04/11/2015	14:18	04/11/2015	15:38	77	6107	79	Overhead equipment	Recloser	Replace - Same Size	Replace - Same Size	I
151010621	P49183	04/11/2015	14:28	04/11/2015	15:35	1	67	66	Unknown	Fuse	Replace - Same Size		I
151010623	B35002	04/11/2015	14:29	04/11/2015	16:14	1	105	104	Overhead equipment				I
5005407	P26284	04/11/2015	14:33	04/11/2015	16:00	477	41532	87	Public	Pole	Replace - Same Size	Replace - Same Size	I
151010627	V17574	04/11/2015	14:35	04/11/2015	16:00	1	85	84	Unknown	Transformer Fuse	Repair		II
151010653		04/11/2015	15:20	04/11/2015	16:51	1	91	90	Overhead equipment	Overhead Service	Repair		I
151010676	J14140	04/11/2015	15:24	04/11/2015	16:25	4	244	60	Overhead equipment	Fuse	Replace - Same Size		VI
151010664	X91510	04/11/2015	15:36	04/11/2015	16:30	8	432	53	Animal related	Transformer Fuse	Replace - Same Size		IV
151010672	K76546	04/11/2015	15:46	04/11/2015	18:20	1	154	153	Overhead equipment	Overhead Service	Repair		IV
151010691	S61531	04/11/2015	16:04	04/11/2015	17:55	53	5883	111	Overhead equipment	Fuse	Replace - Same Size		VI
151010712	M51275	04/11/2015	16:26	04/11/2015	17:37	51	3621	71	Overhead equipment				III
151010714	D35003	04/11/2015	16:36	04/11/2015	22:37	1	361	361	Underground equipment	Underground Service	Patrol/Test/Inspect	Repair	I
151010716	346004	04/11/2015	16:43	04/11/2015	17:40	1	57	56	Tree related-tree broken	Tree	Trim		VI
151010827	V03758	04/11/2015	16:43	04/11/2015	17:40	1616	92112	56	Transmission outage	Other			II
151010840	J71128	04/11/2015	17:16	04/11/2015	19:31	8	1080	135	Other	Overhead Service	Repair		I
151010852	T08501	04/11/2015	17:34	04/11/2015	18:35	3	183	60	Overhead equipment	Transformer Fuse	Repair	Repair	VI
151010880	D72003	04/11/2015	18:30	04/11/2015	20:40	1	130	129	Unknown	Fuse	Repair		I
5005429	X02549	04/11/2015	19:28	04/11/2015	21:21	5	563	112	Animal related	Fuse	Replace - Same Size		IV
151010909	V25504	04/11/2015	19:36	04/11/2015	20:25	1	49	49	Unknown				II
5005431	X02549	04/11/2015	20:08	04/11/2015	21:22	1	73	73	Animal related	Fuse	Replace - Same Size		IV
5005433	J91501	04/11/2015	20:17	04/11/2015	23:56	1	218	218	Overhead equipment	Fuse	Replace - Same Size		VI
5005437	K67911	04/11/2015	21:55	04/12/2015	1:20	1	204	204	Underground equipment	Underground Service	Repair	Repair	VI
151010956	V20512	04/11/2015	22:47	04/12/2015	0:15	1	88	87	Animal related	Transformer Fuse	Replace - Same Size		II
5005439	N78243	04/12/2015	0:51	04/12/2015	1:45	1	53	53	Overhead equipment	Overhead Service	Repair		I
151020021	M40132	04/12/2015	1:48	04/12/2015	3:24	1	96	96	Overhead equipment	Overhead Service	Tie/Tighten		I
151020037	Q32170	04/12/2015	6:06	04/12/2015	10:30	1	264	264	Overhead equipment	Overhead Transformer	Replace - Same Size	Replace - Same Size	I
151020159	D41003	04/12/2015	7:00	04/12/2015	11:55	2	590	295	Underground equipment	Underground Primary	Repair	Repair	I
151020044	M09144	04/12/2015	7:05	04/12/2015	12:04	2	598	299	Tree related-tree broken	Overhead Secondary		Repair	VI
5005443	J84123	04/12/2015	7:27	04/12/2015	8:35	4	268	67	Animal related	Transformer Fuse			VI
151020101	H00163	04/12/2015	8:26	04/12/2015	9:48	1	82	81	Overhead equipment	Fuse			III
151020102	V80506	04/12/2015	8:29	04/12/2015	10:40	11	1441	130	Animal related	Transformer Fuse	Replace - Same Size		II
5005445	J84123	04/12/2015	8:51	04/12/2015	9:44	1	52	52	Overhead equipment	Overhead Service		Replace - Same Size	VI
151020117	P69174	04/12/2015	8:54	04/12/2015	9:30	1	36	36	Unknown	Transformer Fuse	Replace - Same Size		III
151020211	P53341	04/12/2015	10:22	04/12/2015	11:53	1	91	91	Overhead equipment	Connector	Repair		IV
151020253	T41540	04/12/2015	10:31	04/12/2015	11:35	10	640	63	Animal related	Transformer Fuse	Replace - Same Size	Replace - Same Size	IV
151020234	V33002	04/12/2015	10:38	04/12/2015	11:18	1	40	39	Overhead equipment	Transformer Fuse	Replace - Same Size		II
151020243	J08207	04/12/2015	10:47	04/12/2015	11:20	1	33	32	Overhead equipment	Overhead Service	Repair		I
151020244	D90004	04/12/2015	10:49	04/12/2015	11:27	1	38	37	Animal related	Other	Replace - Same Size	Patrol/Test/Inspect	III
151020287	N67309	04/12/2015	11:51	04/12/2015	13:13	1	82	81	Tree related-tree broken	Overhead Secondary	Repair		I
151020336	D55003	04/12/2015	12:15	04/12/2015	12:43	85	2380	28	Overhead equipment	Disconnect Switch	Replace - Same Size	Replace - Same Size	I
151020366	T22508	04/12/2015	13:02	04/12/2015	13:25	1	23	23	Other				VI

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
151020375	D55003	04/12/2015	13:07	04/12/2015	14:10	85	5355	63	Unknown	Transformer Fuse	Replace - Same Size	Replace - Same Size	I
151020369	C15002	04/12/2015	13:09	04/12/2015	14:46	1	97	96	Unknown	Transformer Fuse	Replace - Same Size		III
151020595	M73330	04/12/2015	15:06	04/12/2015	15:50	23	1012	43	Public	Fuse	Replace - Same Size	Replace - Same Size	V
151020605	U01514	04/12/2015	15:28	04/12/2015	16:35	1	67	66	Overhead equipment	Transformer Fuse	Replace - Same Size	Replace - Same Size	II
5005449	Q93522	04/12/2015	15:48	04/12/2015	20:36	1	287	287	Overhead equipment	Overhead Transformer	Replace - Same Size		I
151020628	340100	04/12/2015	15:57	04/12/2015	16:38	1	41	41	Overhead equipment	Overhead Service	Cut in Clear	Replace - Same Size	V
151020633	R09225	04/12/2015	16:08	04/12/2015	17:55	1	107	107	Animal related	Fuse			III
151020650	V40556	04/12/2015	16:36	04/12/2015	17:03	7	189	27	Overhead equipment	Transformer Fuse	Replace - Same Size		II
151020686	315106	04/12/2015	17:16	04/12/2015	20:08	1	172	171	Overhead equipment	Overhead Service	Patrol/Test/Inspect	Replace - Same Size	V
151020717	B21004	04/12/2015	18:28	04/12/2015	21:17	67	11323	169	Underground equipment	Underground Primary	Switch/Reset	Switch/Reset	I
151020719	H10843	04/12/2015	18:33	04/12/2015	19:26	1	53	52	Animal related	Transformer Fuse	Replace - Same Size		V
5005455	J83138	04/12/2015	18:39	04/12/2015	21:49	1	189	189	Public	Overhead Service			VI
151020740	R61241	04/12/2015	19:08	04/13/2015	0:50	1	342	341	Underground equipment	Underground Secondary		Repair	IV
151020742	D28123	04/12/2015	19:09	04/13/2015	2:50	1	461	460	Underground equipment	Underground Transformer	Patrol/Test/Inspect	Reconnect	I
151020771	R60551	04/12/2015	20:22	04/12/2015	23:00	1	158	158	Underground equipment	Underground Secondary	Repair		IV
5005457	HD5254	04/12/2015	20:39	04/13/2015	5:20	1	520	520	Underground equipment	Underground Service		Repair	VI
5005461	K58210	04/12/2015	21:18	04/13/2015	2:42	8	2584	323	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	VI
151020804	J80807	04/12/2015	21:35	04/12/2015	22:18	1	43	43	Animal related	Overhead Transformer	Repair	Repair	V
151020813	J01118	04/12/2015	22:25	04/13/2015	2:43	1	258	257	Overhead equipment	Overhead Transformer		Replace - Same Size	I
151030121	A26006	04/13/2015	2:35	04/13/2015	7:00	1	265	264	Public	Pole	Replace - Same Size	Replace - Same Size	I
151033509	B73002	04/13/2015	4:54	04/13/2015	9:15	1	261	260	Unknown	Fuse	Replace - Same Size		I
151033524	C00002	04/13/2015	4:58	04/13/2015	7:44	32	5312	166	Overhead equipment	Disconnect Switch	Replace - Same Size		I
151033864	D35003	04/13/2015	4:59	04/13/2015	10:24	1	325	325	Overhead equipment	Fuse	Replace - Same Size		I
151033533	D35003	04/13/2015	4:59	04/13/2015	10:20	90	28890	320	Overhead equipment	Fuse		Replace - Same Size	I
151033521	D35003	04/13/2015	5:05	04/13/2015	10:26	1	321	320	Unknown	Fuse	Replace - Same Size		I
151033531	D39002	04/13/2015	5:14	04/13/2015	14:12	1	538	538	Underground equipment	Other	Repair	Repair	I
151033529	V65549	04/13/2015	5:14	04/13/2015	6:54	1	100	100	Unknown	Transformer Fuse	Replace - Same Size		II
151033555	Q04411	04/13/2015	6:11	04/13/2015	6:46	41	1435	34	Weather	Fuse	Repair	Repair	III
151033556	S47589	04/13/2015	6:15	04/13/2015	7:30	2	150	75	Animal related	Fuse	Replace - Same Size	Patrol/Test/Inspect	VI
151033754	U97528	04/13/2015	6:16	04/13/2015	9:35	2	398	198	Overhead equipment	Overhead Primary	Repair	Repair	II
151033594	Y54591	04/13/2015	6:34	04/13/2015	8:21	1	107	107	Animal related	Transformer Fuse	Replace - Same Size		IV
151033613	D87001	04/13/2015	6:42	04/13/2015	8:40	19	2242	117	Overhead equipment	Overhead Primary	Switch/Reset		I
151033611	V18582	04/13/2015	6:46	04/13/2015	8:57	1	131	130	Underground equipment	Underground Service			II
151033620	J01118	04/13/2015	6:57	04/13/2015	8:58	1	121	121	Unknown	Transformer Fuse	Replace - Same Size	Patrol/Test/Inspect	I
151033625	Q04411	04/13/2015	7:01	04/13/2015	9:29	10	1480	148	Underground equipment	Underground Transformer	Repair	Repair	III
151033630	N35852	04/13/2015	7:02	04/13/2015	9:05	10	1230	122	Underground equipment	Underground Primary	Patrol/Test/Inspect	Patrol/Test/Inspect	V
5005469	J87111	04/13/2015	7:18	04/13/2015	8:35	1	76	76	Weather	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
151033732	B93002	04/13/2015	7:36	04/13/2015	11:17	1	221	220	Overhead equipment	Disconnect Switch	Patrol/Test/Inspect	Replace - Same Size	I
151033741	H11340	04/13/2015	7:36	04/13/2015	8:37	44	2684	60	Overhead equipment				V
151033836	D87001	04/13/2015	8:06	04/13/2015	12:03	3	711	236	Overhead equipment	Overhead Primary	Switch/Reset	Raise	I
5005485	HB5890	04/13/2015	8:11	04/13/2015	12:40	1	268	268	Overhead equipment	Overhead Transformer	Replace - Same Size	Replace - Same Size	I
151033885	Q32170	04/13/2015	8:14	04/13/2015	9:35	1	81	81	Tree related-tree broken	Fuse	Patrol/Test/Inspect		I
151033888	N50332	04/13/2015	8:15	04/13/2015	10:07	11	1232	111	Underground equipment	Fuse	Replace - Same Size		II
5005491	P77237	04/13/2015	8:15	04/13/2015	17:14	1	538	538	Weather	Underground Transformer	Patrol/Test/Inspect	Replace - Same Size	VI
151033972	V49541	04/13/2015	8:37	04/13/2015	10:10	1	93	92	Unknown				II
151034017	H06135	04/13/2015	8:43	04/13/2015	8:55	859	10308	12	Jurisdictional				IV
151034114	J80807	04/13/2015	8:57	04/13/2015	9:18	1	21	20	Animal related	Overhead Primary	Repair	Repair	V
5005499	R49263	04/13/2015	9:13	04/13/2015	12:34	1	200	200	Overhead equipment	Overhead Service	Repair	Repair	VI
151034348	D35003	04/13/2015	9:40	04/13/2015	10:31	1	51	50	Unknown	Fuse	Replace - Same Size		I
151035227	B08003	04/13/2015	9:54	04/13/2015	13:14	136	27200	200	Overhead equipment	Crossarm	Patrol/Test/Inspect	Replace - Same Size	I
151034425	B19001	04/13/2015	9:55	04/13/2015	10:46	1	51	50	Animal related	Fuse	Replace - Same Size		I
151034583	Q32170	04/13/2015	9:58	04/13/2015	11:25	3	261	87	Animal related	Fuse	Replace - Same Size	Patrol/Test/Inspect	I
5005507	J30203	04/13/2015	10:07	04/13/2015	13:12	1	184	184	Overhead equipment	Fuse			VI
151034503	A97003	04/13/2015	10:10	04/13/2015	12:07	1	117	117	Overhead equipment	Overhead Service	Patrol/Test/Inspect		I
151034556	V22555	04/13/2015	10:19	04/13/2015	10:41	1	22	22	Overhead equipment	Transformer Fuse	Replace - Same Size		II
151034621	R53391	04/13/2015	10:30	04/13/2015	11:50	60	4800	79	Public	Fuse	Replace - Same Size	Replace - Same Size	V

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
151034622	Q74148	04/13/2015	10:32	04/13/2015	12:00	1	88	88	Animal related	Transformer Fuse	Replace - Same Size		IV
151036025	N50332	04/13/2015	10:34	04/13/2015	15:45	5	1555	310	Underground equipment	Underground Transformer	Replace - Same Size	Replace - Same Size	II
151035562	N50332	04/13/2015	10:34	04/13/2015	14:40	6	1476	245	Underground equipment	Underground Transformer	Replace - Same Size		II
151035068	K11376	04/13/2015	10:34	04/13/2015	12:08	357	33558	94	Overhead equipment	Fuse		Replace - Same Size	V
151034696	IP9055	04/13/2015	10:38	04/13/2015	11:58	18	1440	79	Overhead equipment	Other			VI
151034685	IP9055	04/13/2015	10:39	04/13/2015	12:00	1	81	81	Overhead equipment	Other			VI
151034698	IP9055	04/13/2015	10:40	04/13/2015	12:01	8	648	81	Overhead equipment				VI
151034785	G10002	04/13/2015	10:43	04/13/2015	11:59	38	2888	75	Animal related	Fuse	Replace - Same Size		I
151034719	K43385	04/13/2015	10:43	04/13/2015	13:24	1	161	161	Overhead equipment	Fuse	Replace - Same Size	Patrol/Test/Inspect	V
151034722	IP9055	04/13/2015	10:44	04/13/2015	12:02	1	78	77	Overhead equipment				VI
5005511	N94180	04/13/2015	10:44	04/13/2015	11:49	1	64	64	Animal related	Transformer Fuse	Replace - Same Size		I
151034808	K71812	04/13/2015	10:57	04/13/2015	11:35	1	38	37	Animal related	Transformer Fuse	Replace - Same Size		IV
151034815	342001	04/13/2015	10:59	04/13/2015	11:21	1	22	21	Overhead equipment	Overhead Service	Repair		VI
151034887		04/13/2015	11:16	04/13/2015	12:17	1	61	60	Overhead equipment				V
151034921	Q16868	04/13/2015	11:21	04/13/2015	13:00	1	99	98	Animal related	Transformer Fuse	Replace - Same Size		V
151034977	S84535	04/13/2015	11:31	04/13/2015	11:39	1	8	8	Other				VI
151035020	A85001	04/13/2015	11:39	04/13/2015	12:40	1	61	60	Weather	Fuse	Replace - Same Size		I
151035048	Q32170	04/13/2015	11:45	04/13/2015	12:15	1	30	29	Other	Overhead Service			I
151035071	K79211	04/13/2015	11:50	04/13/2015	12:26	1	36	36	Overhead equipment				IV
151035083	R41131	04/13/2015	11:52	04/13/2015	13:40	1	108	108	Overhead equipment	Transformer Fuse	Repair	Repair	VI
151035186	K80381	04/13/2015	12:10	04/13/2015	13:10	1	60	59	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
151035190	M22812	04/13/2015	12:11	04/13/2015	13:28	1	77	76	Animal related	Underground Primary	Replace - Same Size		V
151035261	K27150	04/13/2015	12:24	04/13/2015	13:00	1	36	35	Overhead equipment	Fuse	Repair	Repair	VI
151035306	U03001	04/13/2015	12:36	04/13/2015	13:35	2	118	58	Overhead equipment				II
5005525	J20931	04/13/2015	12:44	04/13/2015	13:14	1	29	29	Other				VI
151035585	U84587	04/13/2015	13:12	04/13/2015	22:00	5	2640	527	Underground equipment	Underground Primary	Repair		II
5005533	M30301	04/13/2015	13:19	04/13/2015	14:00	1	40	40	Weather	Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
5005537	X57566	04/13/2015	13:30	04/13/2015	14:30	1	59	59	Overhead equipment	Fuse	Replace - Same Size		IV
151035749	D87001	04/13/2015	13:51	04/13/2015	14:45	1	54	54	Animal related	Fuse	Replace - Same Size		I
151035906	Y28598	04/13/2015	14:22	04/13/2015	17:05	1	163	162	Overhead equipment	Overhead Transformer	Replace - Same Size	Repair	IV
5005543	L43154	04/13/2015	14:30	04/13/2015	16:40	1	129	129	Unknown				I
5005547	L43154	04/13/2015	15:07	04/13/2015	16:40	1	92	92	Unknown				I
151036293	M42107	04/13/2015	15:42	04/13/2015	19:35	1	233	232	Overhead equipment	Overhead Transformer	Replace - Same Size	Replace - Urgent	I
5005551	P26283	04/13/2015	16:27	04/13/2015	20:50	1	262	262	Underground equipment	Underground Secondary	Repair		I
151036469	J15302	04/13/2015	16:39	04/13/2015	17:31	1	52	52	Overhead equipment	Overhead Primary	Replace - Same Size	Replace - Same Size	I
151036600	L95210	04/13/2015	17:22	04/13/2015	17:45	1	23	23	Overhead equipment	Connector	Repair		III
151036911	J39392	04/13/2015	18:55	04/13/2015	20:17	1	82	81	Animal related	Fuse			III
151037391	Q75145	04/13/2015	18:56	04/13/2015	19:57	30	1830	60	Overhead equipment	Jumper	Replace - Same Size		VI
151037394	S27599	04/13/2015	19:12	04/14/2015	1:25	7	2611	373	Underground equipment	Underground Primary			VI
151037364	M48814	04/13/2015	19:14	04/13/2015	19:45	1	31	30	Intentional	Meter			V
151037410	B82001	04/13/2015	19:39	04/13/2015	21:15	1	96	95	Overhead equipment	Overhead Service	Repair		I
5005557	P77233	04/13/2015	20:35	04/13/2015	21:49	1	73	73	Overhead equipment	Transformer Fuse	Replace - Same Size		VI
151037453	N60181	04/13/2015	20:37	04/13/2015	22:10	1	93	92	Overhead equipment	Connector	Replace - Same Size	Patrol/Test/Inspect	I
151037479	U80003	04/13/2015	21:50	04/13/2015	23:35	1	105	105	Overhead equipment	Overhead Service	Repair		II
5005563	Q54908	04/13/2015	22:06	04/14/2015	0:01	4	456	114	Animal related	Fuse	Replace - Same Size	Patrol/Test/Inspect	VI
151037492	R84148	04/13/2015	22:14	04/13/2015	23:30	1	76	75	Overhead equipment	Disconnect Switch	Replace - Same Size		I
5005565	Q14390	04/13/2015	22:41	04/14/2015	1:03	32	4535	141	Unknown	Fuse	Repair		I
5005569	Q14390	04/14/2015	0:23	04/14/2015	1:03	1	39	39	Unknown	Fuse	Repair		I
151040235	C36002	04/14/2015	2:45	04/14/2015	4:07	1	82	81	Animal related	Fuse	Replace - Same Size		III
151043876	D39002	04/14/2015	5:36	04/14/2015	6:35	1	59	59	Animal related	Fuse	Replace - Same Size		I
151043893	S47538	04/14/2015	6:20	04/14/2015	8:31	6	786	130	Overhead equipment	Fuse	Replace - Same Size		VI
151043955	Q91141	04/14/2015	7:15	04/14/2015	7:43	1	28	27	Animal related	Fuse	Replace - Same Size		I
5005573	Q93522	04/14/2015	7:16	04/14/2015	9:29	1	132	132	Overhead equipment	Overhead Secondary	Patrol/Test/Inspect	Repair	I
151043990	J58380	04/14/2015	7:28	04/14/2015	8:16	1	48	47	Overhead equipment	Transformer Fuse		Replace - Same Size	III
5005579	J88166	04/14/2015	8:42	04/14/2015	9:27	1	44	44	Overhead equipment	Transformer Fuse	Repair	Repair	VI
151044574	R33126	04/14/2015	9:23	04/14/2015	11:11	7	756	107	Unknown	Fuse	Replace - Same Size	Patrol/Test/Inspect	I

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
151044464	Y89540	04/14/2015	9:31	04/14/2015	10:00	1	29	29	Overhead equipment	Connector	Repair	Replace - Same Size	IV
151044482	Q75146	04/14/2015	9:32	04/14/2015	10:03	1	31	30	Overhead equipment	Fuse	Replace - Same Size		VI
151044505	A49001	04/14/2015	9:38	04/14/2015	10:38	1	60	60	Animal related	Fuse	Replace - Same Size		I
151044617	C52002	04/14/2015	9:56	04/14/2015	10:39	1	43	42	Overhead equipment	Connector	Repair		III
151044637	C00002	04/14/2015	9:58	04/14/2015	10:28	1	30	30	Animal related	Fuse	Repair	Replace - Same Size	I
151044707	L79157	04/14/2015	10:07	04/14/2015	11:35	1	88	88	Animal related	Transformer Fuse	Replace - Same Size	Replace - Same Size	IV
151044828	U39541	04/14/2015	10:22	04/14/2015	10:48	170	4420	26	Underground equipment				II
151044957	U29001	04/14/2015	10:23	04/14/2015	10:48	372	9300	24	Underground equipment				II
5005599	Y37592	04/14/2015	10:31	04/14/2015	11:30	1	58	58	Tree related-tree broken	Transformer Fuse			IV
151044996	K30204	04/14/2015	10:49	04/14/2015	12:23	1	94	94	Unknown	Transformer Fuse	Replace - Same Size		III
151045016	Y73504	04/14/2015	10:55	04/14/2015	11:30	1	35	34	Animal related	Transformer Fuse	Repair	Repair	IV
151045074	341002	04/14/2015	11:05	04/14/2015	12:50	1	105	104	Overhead equipment	Overhead Service	Repair		VI
151045440	S47538	04/14/2015	11:49	04/14/2015	13:05	10	760	76	Unknown				VI
151045668	S47538	04/14/2015	12:10	04/14/2015	12:44	12	408	33	Overhead equipment	Fuse	Replace - New Size		VI
151045507	S47538	04/14/2015	12:20	04/14/2015	12:44	1	24	23	Overhead equipment	Fuse	Replace - New Size		VI
151045672	S47538	04/14/2015	12:21	04/14/2015	12:44	1	23	23	Overhead equipment	Fuse	Replace - New Size		VI
151045611	A45001	04/14/2015	12:37	04/14/2015	16:03	2	412	206	Underground equipment	Fuse	Replace - Same Size	Replace - Same Size	I
151045618	R48167	04/14/2015	12:40	04/14/2015	14:17	1	97	96	Overhead equipment	Overhead Service			IV
151045651	B38002	04/14/2015	12:45	04/14/2015	13:55	1	70	69	Animal related	Fuse	Replace - Same Size		I
151045784	L73160	04/14/2015	13:07	04/14/2015	15:00	1	113	113	Tree related-tree broken	Overhead Service			IV
151046104	U60518	04/14/2015	13:19	04/14/2015	14:05	610	28060	46	Tree related-tree broken	Tree	Remove		II
151046014	S88553	04/14/2015	13:41	04/14/2015	15:10	1	89	88	Overhead equipment	Overhead Service	Repair		VI
151046559	P57103	04/14/2015	15:23	04/14/2015	16:32	1	69	68	Unknown	Transformer Fuse	Replace - Same Size		VI
151046719	U10547	04/14/2015	16:04	04/14/2015	17:37	1	93	92	Overhead equipment	Transformer Fuse	Replace - Same Size	Replace - Same Size	II
151046800	R09226	04/14/2015	16:27	04/14/2015	18:05	1	98	97	Overhead equipment	Connector			III
5005627	R08910	04/14/2015	17:04	04/15/2015	0:22	1	437	437	Weather	Overhead Transformer		Replace - Same Size	VI
151047121	U73599	04/14/2015	18:07	04/14/2015	18:39	1	32	31	Animal related	Transformer Fuse	Replace - Same Size		II
151047128	U32579	04/14/2015	18:09	04/14/2015	19:08	1	59	59	Overhead equipment	Transformer Fuse	Repair	Repair	II
151047162	B10001	04/14/2015	18:28	04/14/2015	23:06	1	278	278	Underground equipment	Underground Service	Disconnect	Repair	I
151047465	N44217	04/14/2015	19:31	04/14/2015	21:09	1	98	97	Overhead equipment	Connector			III
151047509	Y07003	04/14/2015	20:52	04/14/2015	22:05	1	73	73	Overhead equipment	Overhead Service	Repair		IV
151047548	S25552	04/14/2015	23:13	04/15/2015	1:58	19	3135	164	Public	Guy Wire	Repair	Repair	VI
151050169	A45003	04/15/2015	2:16	04/15/2015	3:20	1	64	63	Animal related	Transformer Fuse	Replace - Same Size		I
151053478	N93260	04/15/2015	3:27	04/15/2015	5:09	1	102	101	Animal related	Fuse	Repair	Repair	III
151053502	S31532	04/15/2015	4:56	04/15/2015	5:15	208	3952	18	Overhead equipment				VI
151053510	Y07576	04/15/2015	5:43	04/15/2015	7:10	1	87	87	Animal related	Transformer Fuse	Replace - Same Size		IV
151053528	B19002	04/15/2015	6:21	04/15/2015	7:30	1	69	69	Overhead equipment	Jumper	Replace - Same Size		I
5005631	Q11-X1	04/15/2015	7:09	04/15/2015	8:00	1	50	50	Overhead equipment	Connector	Replace - Same Size		I
151053605	S43511	04/15/2015	7:19	04/15/2015	8:05	1	46	46	Animal related	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
5005633	X60597	04/15/2015	7:41	04/15/2015	10:30	1	168	168	Underground equipment	Underground Service	Repair		IV
151053667	R73841	04/15/2015	7:49	04/15/2015	9:47	1	118	117	Overhead equipment	Overhead Service	Repair		V
151053698	S49550	04/15/2015	7:58	04/15/2015	9:28	1	90	90	Overhead equipment	Overhead Service	Repair		VI
151053821	R73841	04/15/2015	8:32	04/15/2015	16:09	1	457	457	Underground equipment	Underground Secondary			V
151053935	S60581	04/15/2015	8:54	04/15/2015	10:15	1	81	81	Unknown	Customer Equipment	Replace - Same Size		VI
151053965	H00163	04/15/2015	9:00	04/15/2015	10:00	1	60	59	Intentional				III
151054117	H00162	04/15/2015	9:27	04/15/2015	9:57	1	30	29	Overhead equipment	Connector	Repair	Repair	III
151054133	Z21564	04/15/2015	9:31	04/15/2015	10:15	1	44	44	Animal related	Fuse	Replace - Same Size		IV
151054174	303006	04/15/2015	9:37	04/15/2015	10:05	1	28	28	Overhead equipment	Other	Patrol/Test/Inspect		VI
151054306	D41002	04/15/2015	9:55	04/15/2015	13:17	1	202	201	Underground equipment	Underground Primary	Repair	Repair	I
151054315	U31003	04/15/2015	9:57	04/15/2015	10:30	1	33	33	Overhead equipment	Transformer Fuse	Replace - Same Size		II
151054394	E10001	04/15/2015	10:14	04/15/2015	14:30	1	256	255	Public	Underground Primary	Patrol/Test/Inspect	Repair	III
151054414	D28123	04/15/2015	10:17	04/15/2015	11:20	1	63	62	Unknown	Fuse	Replace - Same Size		I
5005653	Q93522	04/15/2015	10:18	04/15/2015	11:04	1	45	45	Public	Overhead Service		Disconnect	I
5005655	P77237	04/15/2015	10:19	04/15/2015	11:30	1	70	70	Animal related	Fuse	Repair		VI
151054457	342004	04/15/2015	10:25	04/15/2015	11:15	1	50	49	Other	Meter	Replace - Same Size		VI
151054832	D93001	04/15/2015	10:34	04/15/2015	12:06	9	828	91	Overhead equipment	Pole	Cut in Clear	Replace - Same Size	IV

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
151054942	D93001	04/15/2015	10:34	04/15/2015	14:33	4	956	238	Overhead equipment	Pole	Cut in Clear	Replace - Same Size	IV
151054642	D93001	04/15/2015	10:34	04/15/2015	11:36	2	124	61	Overhead equipment	Pole	Replace - Same Size	Replace - Same Size	IV
151054571	V65549	04/15/2015	10:45	04/15/2015	18:15	1	450	450	Overhead equipment	Overhead Transformer		Replace - Same Size	II
151054592	B82002	04/15/2015	10:49	04/15/2015	13:30	1	161	161	Unknown	Fuse	Repair	Replace - Same Size	I
151054959	D36001	04/15/2015	10:52	04/15/2015	15:25	4	1092	272	Public	Underground Primary	Replace - Same Size	Repair	I
151054678	D36001	04/15/2015	10:52	04/15/2015	12:00	61	4148	68	Public	Underground Primary	Patrol/Test/Inspect		I
151054708	R65451	04/15/2015	11:09	04/15/2015	14:21	1	192	191	Underground equipment	Underground Service	Repair		IV
5005665	N05172	04/15/2015	11:31	04/15/2015	13:03	22	2012	91	Animal related	Fuse	Replace - Same Size		I
151054872	B73002	04/15/2015	11:41	04/15/2015	14:20	1	159	158	Animal related	Fuse	Replace - Same Size		I
151054934	B19001	04/15/2015	11:52	04/15/2015	13:15	1	83	83	Overhead equipment	Jumper	Repair		I
151055009	S88503	04/15/2015	12:06	04/15/2015	13:52	1	106	105	Overhead equipment	Fuse	Replace - Same Size		VI
5005671	R34920	04/15/2015	12:26	04/15/2015	15:15	3	506	168	Overhead equipment	Overhead Primary	Repair		VI
151055175	L46810	04/15/2015	12:40	04/15/2015	13:11	1	31	30	Animal related	Transformer Fuse	Replace - Same Size		V
151055280	Q85162	04/15/2015	13:02	04/15/2015	13:54	1	52	52	Unknown				VI
151055702	B80004	04/15/2015	14:17	04/15/2015	15:47	286	25740	90	Overhead equipment	Overhead Primary	Repair		I
151055755	L00133	04/15/2015	14:30	04/15/2015	15:42	1	72	72	Overhead equipment	Connector	Repair		III
151055878	M09143	04/15/2015	14:53	04/15/2015	15:44	1	51	50	Overhead equipment	Fuse	Replace - Same Size		VI
5005707	J18268	04/15/2015	15:25	04/15/2015	20:36	2	620	310	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	VI
151056062	Y91501	04/15/2015	15:32	04/15/2015	16:18	1	46	46	Overhead equipment	Transformer Fuse	Repair	Replace - Same Size	IV
151056201	Q01280	04/15/2015	16:01	04/15/2015	17:09	11	748	68	Underground equipment	Underground Primary			III
151056417	D53002	04/15/2015	17:02	04/15/2015	18:19	1	77	76	Unknown	Fuse	Replace - Same Size		I
151056422	B68003	04/15/2015	17:05	04/15/2015	17:25	1	20	20	Animal related	Fuse	Replace - Same Size		III
151056445	S84535	04/15/2015	17:13	04/15/2015	22:11	1	298	297	Underground equipment	Underground Service	Patrol/Test/Inspect	Repair	VI
151056500	K36151	04/15/2015	17:33	04/15/2015	20:55	237	47874	202	Unknown	Recloser	Switch/Reset		III
5005713	R25906	04/15/2015	17:48	04/15/2015	19:25	2	192	96	Tree related-tree contact	Overhead Primary	Replace - Same Size		I
151056750	B57001	04/15/2015	18:28	04/15/2015	19:26	1	58	58	Overhead equipment	Overhead Service	Cut in Clear	Repair	I
151056796	N48101	04/15/2015	18:54	04/15/2015	21:22	6	888	148	Animal related	Transformer Fuse	Replace - Same Size		II
151057113	D96001	04/15/2015	20:03	04/15/2015	22:26	1	143	142	Overhead equipment	Jumper	Repair		I
151057178	J07135	04/15/2015	21:10	04/15/2015	23:10	109	13080	120	Overhead equipment	Overhead Primary	Repair		I
151057184	J07135	04/15/2015	21:25	04/15/2015	23:19	1	114	114	Overhead equipment	Crossarm	Patrol/Test/Inspect	Replace - Same Size	I
151057190	S01501	04/15/2015	21:31	04/15/2015	22:24	1	53	53	Overhead equipment	Fuse	Repair	Replace - Same Size	VI
151057208	R28871	04/15/2015	22:54	04/16/2015	0:30	5	480	95	Overhead equipment	Transformer Fuse	Replace - Same Size	Replace - Same Size	V
151063750	M18131	04/16/2015	6:17	04/16/2015	8:00	1	103	103	Underground equipment	Underground Service		Repair	III
151063868	Y04504	04/16/2015	6:43	04/16/2015	9:14	5	755	150	Underground equipment	Underground Transformer	Disconnect	Replace - Same Size	IV
151063870	M42107	04/16/2015	7:23	04/16/2015	10:00	14	2198	156	Animal related	Fuse	Replace - Same Size	Patrol/Test/Inspect	I
151063857	C36002	04/16/2015	7:28	04/16/2015	8:37	1	69	68	Animal related	Fuse	Replace - Same Size		III
151063865	S19556	04/16/2015	7:32	04/16/2015	11:38	1	246	246	Overhead equipment	Overhead Secondary	Repair		VI
151063885	B77004	04/16/2015	7:38	04/16/2015	9:18	3	300	99	Animal related				I
151063971	Q32171	04/16/2015	8:06	04/16/2015	10:35	1	149	148	Tree related-tree contact	Overhead Secondary	Cut in Clear	Repair	I
151064042	V23522	04/16/2015	8:26	04/16/2015	9:36	1	70	69	Overhead equipment	Transformer Fuse	Replace - Same Size		II
151064067	C15002	04/16/2015	8:32	04/16/2015	11:02	1	150	149	Underground equipment	Underground Service	Switch/Reset	Repair	III
5005727	K58213	04/16/2015	8:44	04/16/2015	10:18	1	93	93	Animal related	Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
151064158	B76001	04/16/2015	8:47	04/16/2015	12:10	43	8729	203	Underground equipment	Underground Primary	Switch/Reset	Repair	I
151064182	M36185	04/16/2015	8:54	04/16/2015	13:15	9	2349	261	Underground equipment	Underground Primary	Repair	Replace - Same Size	I
5005731	K58213	04/16/2015	8:54	04/16/2015	10:18	9	754	83	Animal related	Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
151064167	L12125	04/16/2015	8:56	04/16/2015	10:27	6	546	91	Animal related	Transformer Fuse	Replace - Same Size		III
151064447	J61119	04/16/2015	10:02	04/16/2015	11:23	1	81	81	Overhead equipment	Connector	Repair	Repair	III
151064849	X77543	04/16/2015	10:04	04/16/2015	11:10	55	3630	66	Overhead equipment	Fuse	Replace - Same Size		IV
151064861	X77543	04/16/2015	10:04	04/16/2015	16:30	1	386	386	Underground equipment	Underground Primary	Disconnect	Repair	IV
151064529	B62002	04/16/2015	10:16	04/16/2015	15:52	1	336	336	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
151064517	C36002	04/16/2015	10:16	04/16/2015	11:28	1	72	72	Animal related	Fuse	Replace - Same Size		III
151064598	L12125	04/16/2015	10:24	04/16/2015	10:51	22	594	26	Animal related	Underground Primary	Replace - Same Size		III
151064897	P07179	04/16/2015	11:26	04/16/2015	13:12	1	106	105	Overhead equipment	Overhead Transformer	Repair	Replace - Same Size	I
151064960	Z08509	04/16/2015	11:40	04/16/2015	12:42	1	62	62	Overhead equipment	Transformer Fuse	Repair	Replace - Same Size	IV
151065102	X19561	04/16/2015	12:10	04/16/2015	14:05	1	115	114	Animal related	Transformer Fuse	Replace - Same Size		IV
151065340	K25166	04/16/2015	13:04	04/16/2015	13:45	1	41	40	Tree related-tree broken	Overhead Service	Replace - Same Size	Replace - Same Size	VI

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
151065371	U54503	04/16/2015	13:10	04/16/2015	14:20	1	70	69	Tree related-tree broken	Fuse	Replace - Same Size		II
151065484	T22508	04/16/2015	13:27	04/16/2015	14:09	1	42	42	Overhead equipment	Fuse	Repair		VI
151065846	U79726	04/16/2015	13:39	04/16/2015	14:49	1	70	69	Overhead equipment	Ground Wire			II
151065886	K39156	04/16/2015	14:30	04/16/2015	16:14	1	104	104	Overhead equipment	Connector	Replace - Same Size		III
151066266	D31018	04/16/2015	15:55	04/16/2015	16:58	1	63	62	Overhead equipment	Jumper	Repair		III
151066280	B25001	04/16/2015	15:58	04/16/2015	16:43	1	45	45	Unknown	Transformer Fuse	Replace - Same Size		I
151066428	J15302	04/16/2015	16:45	04/16/2015	17:37	1	52	52	Other	Other			I
5005777	P20930	04/16/2015	17:32	04/16/2015	21:02	1	209	209	Public	Overhead Transformer		Replace - Same Size	VI
151066570	B81002	04/16/2015	17:40	04/17/2015	2:41	1	541	541	Underground equipment	Underground Service	Disconnect	Repair	I
151066574	J08205	04/16/2015	17:42	04/16/2015	19:47	1	125	124	Other	Other			I
151066661	V78513	04/16/2015	18:00	04/16/2015	22:20	1	260	259	Public	Underground Primary	Replace - Same Size	Repair	II
151066767	A97006	04/16/2015	19:00	04/16/2015	23:02	1	242	242	Underground equipment	Underground Primary	Repair	Repair	I
151066983	R05114	04/16/2015	19:06	04/16/2015	20:07	1	61	60	Public	Overhead Service	Cut in Clear		I
5005783	Z17503	04/16/2015	19:23	04/16/2015	21:12	1	108	108	Overhead equipment				IV
151067128	J34357	04/16/2015	20:28	04/17/2015	2:20	1	352	351	Underground equipment	Underground Secondary	Patrol/Test/Inspect	Repair	V
151067130	M09144	04/16/2015	20:39	04/16/2015	23:55	1	196	195	Overhead equipment	Overhead Transformer	Replace - Same Size	Repair	VI
151067168	K76542	04/16/2015	22:52	04/17/2015	3:26	1	274	274	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	IV
151067174	K71822	04/16/2015	23:14	04/17/2015	5:34	1	380	380	Underground equipment	Underground Service	Patrol/Test/Inspect	Repair	IV
151070177	M48814	04/17/2015	1:27	04/17/2015	5:30	1	243	242	Overhead equipment	Overhead Transformer	Repair	Repair	V
151070208	V01002	04/17/2015	2:53	04/17/2015	3:43	1	50	50	Animal related	Transformer Fuse	Replace - Same Size		II
151073787	A50001	04/17/2015	7:18	04/17/2015	9:30	5	660	132	Unknown	Fuse	Repair		I
151073956	R04412	04/17/2015	8:12	04/17/2015	9:14	1	62	62	Jurisdictional				V
151073970	B62004	04/17/2015	8:15	04/17/2015	10:34	1	139	139	Overhead equipment	Jumper	Repair		I
151074197	B44001	04/17/2015	8:58	04/17/2015	9:59	32	1952	60	Overhead equipment				I
151074220	C00002	04/17/2015	9:07	04/17/2015	11:55	20	3360	168	Public	Overhead Primary	Replace - Same Size	Repair	I
151074395	B27009	04/17/2015	9:38	04/17/2015	10:24	1	46	46	Overhead equipment	Connector	Replace - Same Size		I
151074577	306003	04/17/2015	10:15	04/17/2015	10:50	1	35	34	Unknown	Overhead Service	Repair		VI
151074598	D88001	04/17/2015	10:19	04/17/2015	11:37	1	78	78	Overhead equipment	Jumper	Repair		I
151074614	S49549	04/17/2015	10:22	04/17/2015	11:00	2	76	38	Overhead equipment	Overhead Primary		Repair	VI
151074696	T29562	04/17/2015	10:37	04/17/2015	11:01	1	24	23	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	VI
151074796	D87001	04/17/2015	10:49	04/17/2015	15:08	19	4921	259	Underground equipment	Underground Primary	Repair	Repair	I
151074821	U31598	04/17/2015	10:55	04/17/2015	11:55	1	60	60	Animal related	Fuse	Replace - Same Size		II
151074888	D66002	04/17/2015	11:06	04/17/2015	14:36	1	210	209	Overhead equipment	Overhead Service	Repair		IV
151075075	U31598	04/17/2015	11:06	04/17/2015	11:55	24	1176	49	Animal related	Fuse	Replace - Same Size		II
5005813	R39-UNIT-1	04/17/2015	11:38	04/17/2015	12:38	926	55902	60	Overhead equipment	Substation Breaker	Switch/Reset		VI
5005819	R34-UNIT-1	04/17/2015	11:38	04/17/2015	12:39	878	52899	60	Overhead equipment	Substation Breaker	Switch/Reset		VI
151075024	J14662	04/17/2015	11:40	04/17/2015	13:47	237	30099	127	Substation equipment	Lightning Arrestor	Repair		VI
151075295	J14662	04/17/2015	11:40	04/17/2015	12:27	1	47	47	Substation equipment	Lightning Arrestor	Repair		VI
151075076	K69116	04/17/2015	11:45	04/17/2015	12:15	50	1500	29	Animal related	Fuse	Replace - Same Size		IV
151075097	U31598	04/17/2015	11:57	04/17/2015	12:58	3	183	60	Overhead equipment	Lightning Arrestor	Repair		II
151075157	B84004	04/17/2015	12:17	04/17/2015	15:20	1	183	182	Overhead equipment	Fuse	Repair	Replace - Same Size	I
151075365		04/17/2015	13:11	04/17/2015	13:25	1	14	14	Overhead equipment				VI
5005837	R94271	04/17/2015	13:45	04/17/2015	14:45	1	59	59	Tree related-tree broken	Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
5005841	R69924	04/17/2015	14:12	04/17/2015	18:00	1	227	227	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	I
151075631	N70330	04/17/2015	14:19	04/17/2015	15:20	1	61	60	Overhead equipment	Overhead Secondary	Reconnect		I
151075677	P58154	04/17/2015	14:31	04/17/2015	16:23	1	112	111	Other	Transformer Fuse	Replace - Same Size		VI
151075775	P52305	04/17/2015	14:33	04/17/2015	15:53	36	2880	80	Public	Pole			IV
151075708	F03003	04/17/2015	14:40	04/17/2015	15:57	1	77	76	Underground equipment	Underground Primary	Straighten		III
151075934	R48165	04/17/2015	14:48	04/17/2015	16:13	98	8330	84	Overhead equipment	Fuse	Replace - Same Size		IV
151076263	P17107	04/17/2015	14:52	04/17/2015	17:54	18	3276	182	Underground equipment	Underground Transformer	Replace - Same Size		IV
151075869	J75603	04/17/2015	15:01	04/17/2015	19:25	260	68640	264	Substation equipment				IV
151075896	J75603	04/17/2015	15:01	04/17/2015	16:50	854	93086	108	Substation equipment	Substation Misc.			IV
151075982	J75603	04/17/2015	15:01	04/17/2015	19:25	491	129624	264	Substation equipment				IV
151076070	S09520	04/17/2015	16:04	04/17/2015	17:50	1	106	105	Overhead equipment	Transformer Fuse	Replace - Same Size	Replace - Same Size	VI
151076306	Y60593	04/17/2015	16:21	04/17/2015	20:30	3	747	248	Underground equipment	Underground Primary		Advise Customer	IV
151076148	V14579	04/17/2015	16:39	04/17/2015	18:15	1	96	95	Public	Pole		Repair	II

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
151076338	R99180	04/17/2015	17:11	04/17/2015	18:24	342	24966	73	Overhead equipment	Overhead Primary			IV
151076397	P58155	04/17/2015	18:38	04/17/2015	19:01	1	23	23	Animal related	Transformer Fuse	Replace - Same Size		VI
151076408	L79180	04/17/2015	18:50	04/18/2015	0:36	1	346	346	Underground equipment	Underground Service		Repair	IV
151076714	D70006	04/17/2015	19:10	04/17/2015	22:16	71	13206	185	Animal related	Other	Repair	Repair	I
151076703	S19553	04/17/2015	19:20	04/17/2015	20:57	15	1455	97	Other	Other	Patrol/Test/Inspect	Advise Customer	VI
5005869	P83710	04/17/2015	22:08	04/18/2015	0:09	1	120	120	Unknown	Fuse	Replace - Same Size		I
5005871	P83710	04/17/2015	22:08	04/18/2015	0:09	1	120	120	Unknown	Fuse	Replace - Same Size		I
151080006	M05362	04/18/2015	0:11	04/18/2015	1:45	1	94	93	Weather	Fuse	Replace - Same Size		V
151080020	N54108	04/18/2015	1:53	04/18/2015	5:55	1	242	242	Overhead equipment	Overhead Transformer	Replace - Same Size	Replace - Same Size	II
151080050	M78323	04/18/2015	6:25	04/18/2015	11:25	6	1800	300	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Repair	V
151080056	D31017	04/18/2015	6:43	04/18/2015	7:18	1	35	34	Animal related	Fuse	Replace - Same Size		III
151080078	B73002	04/18/2015	7:22	04/18/2015	8:30	8	544	68	Animal related	Fuse	Replace - Same Size		I
5005879	R07382	04/18/2015	7:36	04/18/2015	9:00	143	11893	83	Animal related	Fuse	Replace - Same Size	Replace - Same Size	I
5005877	R07382	04/18/2015	7:39	04/18/2015	9:45	16	2009	125	Animal related	Fuse	Replace - Same Size	Replace - Same Size	I
5005881	R07382	04/18/2015	7:45	04/18/2015	9:06	12	961	80	Animal related	Fuse	Replace - Same Size	Replace - Same Size	I
151080135	N70330	04/18/2015	8:39	04/18/2015	10:43	1	124	123	Unknown	Fuse	Replace - Same Size		I
5005885	K58213	04/18/2015	8:39	04/18/2015	11:00	9	1267	140	Animal related	Fuse	Replace - Same Size		VI
151080143	339161	04/18/2015	8:50	04/18/2015	9:30	1	40	40	Overhead equipment	Overhead Service	Repair		V
5005889	X66580	04/18/2015	9:35	04/18/2015	10:40	5	324	64	Animal related	Transformer Fuse	Replace - Same Size		IV
151080198	M21134	04/18/2015	9:54	04/18/2015	10:50	1	56	56	Overhead equipment	Transformer Fuse	Repair	Repair	VI
5005893	N05173	04/18/2015	10:28	04/18/2015	12:10	1	101	101	Animal related	Transformer Fuse	Replace - Same Size		I
151080247	T28561	04/18/2015	10:44	04/18/2015	13:55	1	191	190	Tree related-tree broken	Overhead Service	Repair		VI
151080256	T28561	04/18/2015	10:45	04/18/2015	13:00	22	2970	135	Overhead equipment	Fuse	Replace - Same Size		VI
151080273	J39391	04/18/2015	11:04	04/18/2015	11:34	1	30	30	Animal related	Fuse			III
151080279	T08502	04/18/2015	11:08	04/18/2015	13:24	1	136	136	Overhead equipment	Other	Repair	Repair	VI
151080298	J07135	04/18/2015	11:23	04/18/2015	13:30	1	127	126	Animal related	Transformer Fuse	Replace - Same Size	Patrol/Test/Inspect	I
151080318	L68111	04/18/2015	11:41	04/18/2015	14:15	1	154	153	Tree related-tree broken	Overhead Service			IV
151080337	T09559	04/18/2015	12:11	04/18/2015	13:22	1	71	70	Overhead equipment	Overhead Primary	Repair	Repair	VI
151080380	V40556	04/18/2015	12:14	04/18/2015	14:04	24	2640	109	Tree related-tree broken	Overhead Primary	Repair	Repair	II
151080407	K71812	04/18/2015	14:04	04/18/2015	14:38	1	34	34	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
5005897	X52537	04/18/2015	14:05	04/18/2015	16:20	5	670	134	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
151080409	X34531	04/18/2015	14:08	04/18/2015	14:30	11	242	21	Animal related	Transformer Fuse	Replace - Same Size		IV
5005899	K32935	04/18/2015	14:46	04/18/2015	16:20	1	93	93	Overhead equipment	Fuse			VI
151080453	C66001	04/18/2015	15:18	04/18/2015	16:33	1	75	75	Animal related	Fuse	Replace - Same Size		III
5005905	X52537	04/18/2015	15:49	04/18/2015	17:07	1	77	77	Overhead equipment	Overhead Service	Repair	Repair	IV
151080493	V40549	04/18/2015	15:53	04/18/2015	17:22	9	801	88	Tree related-tree broken	Tree	Trim		II
151080479	J39391	04/18/2015	15:55	04/18/2015	17:05	1	70	69	Animal related	Fuse	Replace - Same Size		III
151080537	P54828	04/18/2015	16:17	04/18/2015	18:53	1	156	156	Tree related-tree broken	Overhead Secondary	Repair		V
151080539	L12128	04/18/2015	16:21	04/18/2015	17:32	3	213	71	Tree related-tree contact	Transformer Fuse	Replace - Same Size		III
151080595	D31017	04/18/2015	16:49	04/18/2015	18:09	10	800	79	Overhead equipment	Fuse	Replace - Same Size		III
151080556	X12002	04/18/2015	16:53	04/18/2015	17:48	1	55	55	Overhead equipment	Overhead Service	Patrol/Test/Inspect	Reconnect	IV
151080563	U31598	04/18/2015	17:00	04/18/2015	18:44	1	104	103	Public	Overhead Service	Repair	Repair	II
151080583	N50331	04/18/2015	17:39	04/18/2015	19:52	1	133	132	Overhead equipment	Transformer Fuse	Replace - Same Size		II
151080586	S28551	04/18/2015	17:45	04/18/2015	18:32	1	47	46	Animal related	Transformer Fuse	Replace - Same Size		VI
151080589	J71129	04/18/2015	17:52	04/18/2015	19:40	1	108	108	Overhead equipment	Connector	Replace - Same Size	Patrol/Test/Inspect	I
151080610	A56014	04/18/2015	18:24	04/18/2015	19:45	285	23085	80	Unknown	Fuse	Replace - Same Size		I
151080634	N54213	04/18/2015	18:42	04/18/2015	19:22	1	40	39	Animal related	Fuse	Replace - Same Size		II
151080638	L42158	04/18/2015	18:47	04/18/2015	20:39	1	112	112	Overhead equipment	Overhead Transformer	Repair		III
151080669	M09144	04/18/2015	18:58	04/18/2015	20:50	75	8400	111	Public	Fuse	Replace - Same Size		VI
5005913	Q36-UNIT-1	04/18/2015	21:16	04/19/2015	3:30	6	2239	373	Underground equipment	Underground Primary	Repair	Repair	I
151080732	L46811	04/18/2015	22:02	04/18/2015	22:44	1	42	42	Overhead equipment	Connector	Replace - Same Size		V
151080748	S61529	04/18/2015	23:12	04/19/2015	1:17	11	1375	124	Tree related-tree broken	Overhead Primary	Repair		VI
151090015	P69173	04/19/2015	0:28	04/19/2015	6:59	23	8993	391	Public	Pole	Replace - Same Size	Repair	III
151090024	P47124	04/19/2015	0:32	04/19/2015	10:20	22	12936	587	Public	Pole	Replace - Same Size	Replace - Same Size	I
5005915	X66582	04/19/2015	1:13	04/19/2015	2:30	1	76	76	Animal related	Transformer Fuse	Replace - Same Size	Repair	IV
151090026	M22812	04/19/2015	3:21	04/19/2015	4:47	1	86	86	Overhead equipment	Transformer Fuse	Replace - Same Size		V

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
151090029	B81003	04/19/2015	5:21	04/19/2015	6:21	1	60	59	Animal related	Fuse	Replace - Same Size		I
151090036	U62510	04/19/2015	6:13	04/19/2015	7:20	1	67	66	Unknown	Transformer Fuse	Replace - Same Size		II
5005919	X49568	04/19/2015	7:49	04/19/2015	8:50	1	60	60	Animal related	Fuse			IV
151090055	K43386	04/19/2015	7:56	04/19/2015	9:00	1	64	63	Animal related	Transformer Fuse	Replace - Same Size	Replace - Same Size	V
5005923	R39934	04/19/2015	8:07	04/19/2015	10:04	1	116	116	Overhead equipment	Fuse	Replace - Same Size		VI
151090078	D88001	04/19/2015	8:41	04/19/2015	9:35	1	54	53	Animal related	Fuse			I
151090092	L17104	04/19/2015	9:22	04/19/2015	10:56	1	94	94	Animal related	Transformer Fuse	Replace - Same Size		III
151090160	H22347	04/19/2015	9:25	04/19/2015	10:46	1434	116154	81	Substation equipment	Overhead Transformer			V
5005929	X02548	04/19/2015	9:42	04/19/2015	11:20	1	97	97	Overhead equipment	Meter			IV
151090177	P47124	04/19/2015	9:49	04/19/2015	10:23	66	2244	33	Public	Pole	Replace - New Size	Patrol/Test/Inspect	I
151090178	C70001	04/19/2015	10:02	04/19/2015	11:15	1	73	72	Animal related	Fuse	Replace - Same Size		III
151090199	U54516	04/19/2015	10:44	04/19/2015	12:30	1	106	105	Overhead equipment	Overhead Primary	Repair		II
5005931	X87578	04/19/2015	10:49	04/19/2015	13:50	1	180	180	Overhead equipment	Disconnect Switch	Replace - Same Size	Repair	IV
151090216	J56342	04/19/2015	11:05	04/19/2015	12:19	1	74	74	Animal related	Transformer Fuse	Replace - Same Size		III
151090222	A45001	04/19/2015	11:25	04/19/2015	14:45	1	200	200	Overhead equipment	Overhead Service	Replace - Same Size	Repair	I
151090225	J14140	04/19/2015	11:26	04/19/2015	13:18	1	112	111	Animal related	Transformer Fuse	Replace - Same Size		VI
5005935	J84124	04/19/2015	11:32	04/19/2015	16:42	135	41785	309	Overhead equipment	Jumper		Replace - Same Size	VI
151090231	P17109	04/19/2015	11:44	04/19/2015	12:19	3	105	34	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
151090238	U16003	04/19/2015	11:49	04/19/2015	14:33	1	164	164	Tree related-tree contact	Overhead Service	Replace - New Size		II
5005937	K57212	04/19/2015	12:20	04/19/2015	13:24	1	63	63	Animal related	Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
151090246	B61001	04/19/2015	12:28	04/19/2015	13:26	1	58	58	Unknown	Transformer Fuse	Replace - Same Size	Replace - Same Size	I
151090260	J80807	04/19/2015	12:54	04/19/2015	13:33	1	39	39	Overhead equipment	Overhead Service	Repair	Repair	V
151090261	S27599	04/19/2015	12:58	04/19/2015	15:09	1	131	130	Overhead equipment	Transformer Fuse	Repair	Replace - Same Size	VI
151090322	D41003	04/19/2015	15:18	04/19/2015	16:31	1	73	73	Overhead equipment	Overhead Transformer	Repair	Repair	I
151090384	V65549	04/19/2015	15:42	04/19/2015	18:15	689	105417	152	Unknown				II
5005941	J86118	04/19/2015	15:48	04/19/2015	17:39	1	110	110	Tree related-tree broken	Overhead Service		Repair	VI
5005943	J84124	04/19/2015	16:01	04/19/2015	16:38	1	36	36	Overhead equipment				VI
151090399	D39001	04/19/2015	16:21	04/19/2015	17:10	1	49	49	Weather	Transformer Fuse	Replace - Same Size	Replace - Same Size	I
151090413	N90245	04/19/2015	16:40	04/19/2015	17:19	1	39	39	Overhead equipment	Overhead Service	Repair		III
151090415	S52515	04/19/2015	16:41	04/19/2015	17:25	1	44	43	Animal related	Transformer Fuse	Repair	Repair	VI
151090485	V20512	04/19/2015	16:49	04/19/2015	18:45	421	48836	116	Tree related-tree broken	Tree	Remove		II
5005947	J87111	04/19/2015	16:56	04/19/2015	18:28	1	91	91	Tree related-tree contact	Overhead Service			VI
151090455	X36550	04/19/2015	17:19	04/19/2015	18:20	1	61	60	Overhead equipment	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	IV
151090460	D87001	04/19/2015	17:23	04/19/2015	23:14	31	10881	350	Overhead equipment	Other	Patrol/Test/Inspect	Repair	I
151090526	B65001	04/19/2015	19:05	04/19/2015	19:53	25	1200	47	Overhead equipment	Fuse	Repair	Repair	I
151090528	P07179	04/19/2015	19:07	04/19/2015	19:56	1	49	49	Unknown				I
151090536	L14232	04/19/2015	19:23	04/19/2015	22:50	1	207	207	Tree related-tree contact	Overhead Service	Repair		III
151090542	J01118	04/19/2015	19:35	04/19/2015	20:35	1	60	60	Overhead equipment	Connector	Replace - Same Size	Patrol/Test/Inspect	I
151090543	K94223	04/19/2015	19:37	04/19/2015	21:10	12	1116	92	Overhead equipment	Transformer Fuse	Replace - Same Size		III
151090544	Q16868	04/19/2015	19:37	04/20/2015	2:30	1	413	412	Underground equipment	Overhead Secondary	Patrol/Test/Inspect	Repair	V
151090666	D39001	04/19/2015	20:12	04/19/2015	22:52	18	2880	159	Overhead equipment	Insulator	Repair	Repair	I
151090558	C66002	04/19/2015	20:18	04/20/2015	1:30	82	25584	312	Overhead equipment	Overhead Primary			III
151090570	Y45504	04/19/2015	20:36	04/19/2015	22:45	1	129	129	Tree related-tree contact	Overhead Service	Repair	Replace - Same Size	IV
5005971	Q25802	04/19/2015	21:03	04/19/2015	22:26	139	11638	83	Tree related-tree contact	Recloser	Switch/Reset		I
151090651	Q75146	04/19/2015	21:08	04/19/2015	23:06	1179	139122	117	Unknown	Insulator	Repair		VI
151090647	U04538	04/19/2015	21:22	04/20/2015	2:43	1	321	320	Weather	Disconnect Switch	Replace - Same Size		II
151090660	K48380	04/19/2015	21:38	04/19/2015	23:20	2	204	101	Weather	Disconnect Switch	Replace - New Size		V
5005981	K08909	04/19/2015	21:43	04/19/2015	23:21	1	97	97	Animal related	Fuse	Replace - Same Size		VI
5005987	P83705	04/19/2015	22:41	04/20/2015	0:44	14	1715	122	Overhead equipment	Pole	Replace - Same Size	Replace - Same Size	I
5005989	P83705	04/19/2015	22:50	04/20/2015	4:56	5	1829	365	Overhead equipment	Pole	Repair	Replace - Same Size	I
151100207	L79180	04/19/2015	23:07	04/20/2015	6:30	8	3544	443	Tree related-tree broken	Overhead Primary	Replace - New Size		IV
151090692	L79180	04/19/2015	23:07	04/20/2015	1:50	30	4890	163	Tree related-tree broken	Overhead Primary	Replace - New Size		IV
151090714	U99593	04/19/2015	23:13	04/20/2015	1:28	36	4860	135	Overhead equipment	Fuse	Repair		II
151090704	D69007	04/19/2015	23:16	04/20/2015	3:30	22	5588	254	Underground equipment	Underground Primary	Repair	Repair	I
151090723	S21529	04/19/2015	23:58	04/20/2015	1:58	1	120	119	Weather	Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
151100141	B68042	04/20/2015	0:29	04/20/2015	4:19	2066	475180	229	Overhead equipment	Pole	Repair		III

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
151100149	D31016	04/20/2015	0:29	04/20/2015	4:43	979	248666	254	Overhead equipment	Pole	Repair		III
151100189	B73003	04/20/2015	0:53	04/20/2015	6:09	83	26228	315	Overhead equipment	Pole	Replace - Same Size		I
151100181	B73003	04/20/2015	0:57	04/20/2015	1:33	1	36	36	Overhead equipment	Pole		Replace - Same Size	I
151100210	K30204	04/20/2015	1:52	04/20/2015	4:55	10	1830	182	Overhead equipment	Other	Replace - Same Size		III
151100213	U32594	04/20/2015	2:07	04/20/2015	3:49	1	102	102	Animal related	Fuse	Repair	Repair	II
151104135	B73003	04/20/2015	3:07	04/20/2015	3:53	45	2070	46	Unknown				I
5005997	Z10501	04/20/2015	5:14	04/20/2015	6:15	1	60	60	Weather	Fuse	Repair		IV
151104149	D69008	04/20/2015	5:27	04/20/2015	10:18	37	10767	291	Overhead equipment	Overhead Primary		Repair	I
151104164	U04538	04/20/2015	6:01	04/20/2015	9:31	1	210	209	Overhead equipment	Disconnect Switch	Replace - Same Size		II
5006001	Q21423	04/20/2015	6:06	04/20/2015	12:40	4	1574	393	Overhead equipment	Overhead Primary	Repair	Repair	VI
5006005	K32935	04/20/2015	6:39	04/20/2015	7:39	1	59	59	Tree related-tree broken	Tree			VI
151104315	F03003	04/20/2015	7:41	04/20/2015	8:30	8	392	48	Overhead equipment	Fuse	Replace - Same Size		III
5006019	N05172	04/20/2015	8:10	04/20/2015	12:47	5	1383	276	Public	Pole	Repair	Replace - Same Size	I
151104550	U35511	04/20/2015	8:46	04/20/2015	9:38	1	52	52	Weather	Transformer Fuse	Replace - Same Size		II
151104558	U32594	04/20/2015	8:47	04/20/2015	9:40	1	53	53	Overhead equipment	Transformer Fuse	Replace - Same Size		II
151104597	A17022	04/20/2015	8:56	04/20/2015	14:02	1	306	306	Overhead equipment	Overhead Transformer	Repair	Repair	I
151104648	U02597	04/20/2015	9:06	04/20/2015	14:30	1	324	323	Overhead equipment	Overhead Transformer	Replace - Same Size		II
151104687	V74513	04/20/2015	9:15	04/20/2015	11:39	1	144	144	Underground equipment	Underground Primary		Replace - Same Size	II
5006013	N05172	04/20/2015	9:16	04/20/2015	9:41	5	122	24	Public	Pole		Repair	I
151104760	S01501	04/20/2015	9:28	04/20/2015	9:40	1	12	12	Other				VI
151104770	C40002	04/20/2015	9:30	04/20/2015	11:22	1	112	111	Tree related-tree contact	Overhead Service	Repair	Repair	I
151104795	Y07576	04/20/2015	9:35	04/20/2015	11:00	1	85	85	Overhead equipment	Transformer Fuse	Repair		IV
151104834	343006	04/20/2015	9:43	04/20/2015	10:50	1	67	66	Tree related-tree broken	Overhead Service	Cut in Clear		VI
151105060	K27150	04/20/2015	9:54	04/20/2015	12:00	74	9324	126	Unknown				VI
151104982	310122	04/20/2015	9:59	04/20/2015	16:39	80	32000	399	Tree related-tree broken	Overhead Primary	Cut in Clear	Repair	V
151104995	M47802	04/20/2015	10:03	04/20/2015	10:50	1	47	47	Tree related-tree contact	Overhead Transformer			V
5006029	X02546	04/20/2015	10:08	04/20/2015	10:55	1	46	46	Overhead equipment	Overhead Transformer	Repair		IV
151105273	D39001	04/20/2015	10:54	04/20/2015	11:50	1	56	55	Unknown	Fuse	Repair	Replace - Same Size	I
151105401	M37192	04/20/2015	11:10	04/20/2015	12:14	19	1216	63	Animal related	Fuse	Patrol/Test/Inspect	Replace - Same Size	I
151105511	P60170	04/20/2015	11:26	04/20/2015	12:33	78	5226	66	Tree related-tree broken	Overhead Primary			VI
151105507	B68003	04/20/2015	11:38	04/20/2015	13:28	1	110	110	Overhead equipment	Other	Patrol/Test/Inspect	Patrol/Test/Inspect	III
151105648	R41131	04/20/2015	12:07	04/20/2015	13:10	1	63	62	Unknown				VI
151105660	M45212	04/20/2015	12:11	04/20/2015	15:15	1	184	183	Underground equipment	Underground Service	Repair		IV
5006045	P20930	04/20/2015	12:19	04/20/2015	13:22	1	62	62	Animal related	Transformer Fuse	Repair		VI
151105806	V01001	04/20/2015	12:38	04/20/2015	13:57	1	79	79	Overhead equipment	Overhead Service			II
5006049	N05172	04/20/2015	12:38	04/20/2015	12:47	5	42	8	Public	Pole	Repair	Repair	I
5006051	X49570	04/20/2015	13:08	04/20/2015	14:30	1	81	81	Tree related-tree broken	Fuse	Repair		IV
151106553	J07135	04/20/2015	13:23	04/20/2015	15:25	8	976	121	Overhead equipment	Fuse	Replace - Same Size	Patrol/Test/Inspect	I
5006081	J85161	04/20/2015	13:53	04/20/2015	14:38	1	44	44	Jurisdictional	Meter	Reconnect		VI
5006083	Y35001	04/20/2015	13:58	04/20/2015	14:43	1	44	44	Tree related-tree contact	Overhead Service			IV
151106257	U37579	04/20/2015	14:01	04/20/2015	16:20	1	139	139	Underground equipment	Underground Service	Patrol/Test/Inspect	Patrol/Test/Inspect	II
151106317	Q83171	04/20/2015	14:11	04/20/2015	16:25	1	134	134	Jurisdictional	Overhead Service	Cut in Clear	Repair	VI
151106421	P17107	04/20/2015	14:32	04/20/2015	15:30	2	116	58	Jurisdictional	Underground Primary	Repair	Repair	IV
151106748	L68115	04/20/2015	14:43	04/20/2015	15:58	5	375	75	Overhead equipment	Overhead Primary	Replace - Same Size		IV
151106523	V92540	04/20/2015	14:46	04/20/2015	15:18	1	32	31	Other	Other			II
5006089	P26280	04/20/2015	14:49	04/20/2015	16:35	1	105	105	Unknown	Fuse	Repair		I
151106709	K79223	04/20/2015	15:26	04/20/2015	16:15	1	49	49	Overhead equipment	Jumper	Repair		IV
151106753	L73155	04/20/2015	15:36	04/20/2015	17:26	1	110	110	Tree related-tree contact	Overhead Service	Repair		IV
151106784	Y32001	04/20/2015	15:43	04/20/2015	19:50	1	247	246	Underground equipment	Underground Service	Repair	Replace - Same Size	IV
151106797	P09305	04/20/2015	15:48	04/21/2015	3:08	1	680	680	Overhead equipment	Pole	Patrol/Test/Inspect	Replace - New Size	V
151106825	Q27185	04/20/2015	15:55	04/20/2015	17:57	1	122	121	Tree related-tree broken				VI
5006101	L59929	04/20/2015	16:39	04/20/2015	18:55	1	135	135	Underground equipment	Underground Service	Patrol/Test/Inspect	Repair	VI
151107110	J07135	04/20/2015	16:46	04/20/2015	17:50	30	1920	63	Public				I
151107116	U33509	04/20/2015	17:05	04/20/2015	18:07	1	62	62	Overhead equipment	Overhead Service	Repair	Repair	II
5006109	P26283	04/20/2015	17:09	04/20/2015	18:40	1	90	90	Overhead equipment	Connector	Repair		I
151107370	G10002	04/20/2015	17:57	04/20/2015	18:56	1	59	59	Overhead equipment				I

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
151107397	M42107	04/20/2015	18:08	04/20/2015	18:35	7	189	26	Public	Transformer Fuse	Replace - Same Size		I
151107413	D16004	04/20/2015	18:15	04/20/2015	20:00	1	105	105	Overhead equipment	Fuse	Replace - Same Size		I
151107415	S43511	04/20/2015	18:16	04/20/2015	19:34	1	78	78	Other	Customer Equipment		Advise Customer	VI
151107923	B57002	04/20/2015	19:21	04/20/2015	19:57	1	36	36	Overhead equipment	Connector	Replace - Same Size		I
151107967	R60552	04/20/2015	20:12	04/20/2015	21:11	1	59	59	Overhead equipment	Overhead Service	Repair		IV
151107980	S09520	04/20/2015	20:24	04/20/2015	21:28	1	64	63	Overhead equipment	Fuse		Replace - Same Size	VI
151107992	R04407	04/20/2015	20:59	04/20/2015	23:19	1	140	140	Tree related-tree contact	Overhead Service	Repair		V
151113959	Q75146	04/21/2015	4:32	04/21/2015	5:45	130	9490	73	Overhead equipment	Overhead Primary	Replace - Same Size	Repair	VI
151113963	A36001	04/21/2015	5:11	04/21/2015	7:12	9	1089	121	Animal related	Fuse	Replace - Same Size		I
151114084	J79305	04/21/2015	7:39	04/21/2015	8:45	1	66	66	Animal related	Transformer Fuse	Replace - Same Size		I
5006121	X69554	04/21/2015	7:53	04/21/2015	9:36	4	408	102	Animal related	Fuse	Replace - Same Size		IV
151114145	T13581	04/21/2015	7:58	04/21/2015	11:31	1	213	213	Overhead equipment	Overhead Transformer	Replace - Same Size	Replace - Same Size	VI
151114159	K76541	04/21/2015	8:02	04/21/2015	8:44	1	42	42	Animal related	Transformer Fuse	Replace - Same Size		IV
151114161	L70127	04/21/2015	8:03	04/21/2015	10:55	1	172	171	Overhead equipment	Overhead Service	Repair	Repair	IV
151114971	342003	04/21/2015	8:11	04/21/2015	11:35	10	2040	204	Overhead equipment	Tree	Patrol/Test/Inspect		VI
5006123	J30203	04/21/2015	8:19	04/21/2015	10:05	1	105	105	Weather	Transformer Fuse	Replace - Same Size		VI
151114973	B73001	04/21/2015	9:46	04/21/2015	11:20	1	94	93	Overhead equipment	Connector	Replace - Same Size		I
151114981	M47802	04/21/2015	9:47	04/21/2015	10:15	1	28	28	Animal related	Fuse	Repair	Repair	V
151115049	V23522	04/21/2015	9:58	04/21/2015	10:52	1	54	53	Animal related	Transformer Fuse	Replace - Same Size		II
151115144	S88503	04/21/2015	10:16	04/21/2015	10:47	1	31	31	Animal related	Fuse	Replace - Same Size		VI
151115189		04/21/2015	10:26	04/21/2015	11:39	1	73	73	Overhead equipment				V
5006137	L93135	04/21/2015	11:12	04/21/2015	11:59	1	46	46	Overhead equipment	Transformer Fuse			VI
151115599	J15303	04/21/2015	11:36	04/21/2015	12:30	5	270	54	Overhead equipment				I
151115807	J01118	04/21/2015	12:22	04/21/2015	13:55	1	93	92	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Switch/Reset	I
151115813	R28870	04/21/2015	12:24	04/21/2015	12:54	1	30	29	Animal related	Transformer Fuse	Replace - Same Size		V
5006139	R10941	04/21/2015	12:44	04/21/2015	13:18	1	33	33	Overhead equipment	Fuse	Replace - Same Size		VI
5006143	J99128	04/21/2015	12:52	04/21/2015	16:26	1	213	213	Underground equipment	Underground Service		Replace - Same Size	VI
151115966	U04571	04/21/2015	12:53	04/21/2015	14:05	3	216	71	Overhead equipment	Transformer Fuse	Repair		II
151115989	X72536	04/21/2015	12:57	04/21/2015	14:00	1	63	63	Overhead equipment	Jumper	Repair		IV
151116041	303006	04/21/2015	13:08	04/21/2015	14:30	1	82	81	Overhead equipment	Overhead Service	Repair		VI
151116153	B84004	04/21/2015	13:26	04/21/2015	13:52	39	1014	26	Overhead equipment	Overhead Primary	Reconnect		I
151116265	K71812	04/21/2015	13:45	04/21/2015	17:20	1	215	214	Tree related-tree broken	Overhead Service	Patrol/Test/Inspect	Repair	IV
151116431	R61241	04/21/2015	14:02	04/21/2015	14:50	23	1104	47	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
151116564	M31203	04/21/2015	14:03	04/21/2015	15:20	68	5236	76	Overhead equipment	Pole	Repair	Repair	I
5006155	K15205	04/21/2015	14:08	04/21/2015	14:47	1	38	38	Jurisdictional	Meter	Reconnect		VI
5006171	Q14392	04/21/2015	14:38	04/21/2015	15:34	78	4383	56	Public	Underground Primary	Repair	Replace - Same Size	I
5006173	Q14392	04/21/2015	14:44	04/21/2015	15:34	1	49	49	Public	Underground Primary	Repair	Replace - Same Size	I
151116752	Y54591	04/21/2015	14:45	04/21/2015	15:26	3	123	40	Animal related	Transformer Fuse	Replace - Same Size		IV
151116774	L35137	04/21/2015	14:50	04/21/2015	15:55	122	7930	65	Animal related	Fuse	Replace - Same Size		III
151116819	K82202	04/21/2015	15:00	04/21/2015	16:16	1	76	75	Overhead equipment	Overhead Primary			III
151116955	Z33507	04/21/2015	15:23	04/21/2015	16:24	1	61	60	Overhead equipment	Disconnect Switch	Repair	Replace - Same Size	IV
5006175	J89126	04/21/2015	15:25	04/21/2015	15:47	1	21	21	Jurisdictional	Meter	Reconnect		VI
151116976	N44215	04/21/2015	15:26	04/21/2015	17:55	76	11324	149	Overhead equipment	Jumper		Repair	III
151117004	N44217	04/21/2015	15:36	04/21/2015	16:58	1	82	81	Overhead equipment	Overhead Service			III
5006177	R50910	04/21/2015	15:57	04/21/2015	18:16	1	138	138	Overhead equipment	Jumper	Repair		I
151117123	J01118	04/21/2015	15:58	04/21/2015	17:00	1	62	62	Overhead equipment	Overhead Primary	Repair		I
5006179	X23516	04/21/2015	15:58	04/21/2015	17:10	1	71	71	Overhead equipment	Overhead Primary	Repair	Patrol/Test/Inspect	IV
5006181	K31120	04/21/2015	16:04	04/21/2015	17:51	4	427	106	Overhead equipment	Jumper	Repair		I
151117175	307002	04/21/2015	16:05	04/21/2015	16:58	1	53	52	Overhead equipment	Overhead Secondary	Repair		VI
151117187	R48166	04/21/2015	16:09	04/21/2015	18:45	1	156	155	Tree related-tree broken	Overhead Service	Repair		IV
151117403	S47575	04/21/2015	16:28	04/21/2015	18:01	7	651	92	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	VI
151117309	Q06142	04/21/2015	16:40	04/21/2015	21:30	1	290	290	Underground equipment	Underground Service	Patrol/Test/Inspect	Repair	IV
151117353	Y04504	04/21/2015	16:51	04/21/2015	17:51	1	60	60	Animal related	Transformer Fuse	Replace - Same Size		IV
151117380	J15303	04/21/2015	17:00	04/21/2015	17:39	1	39	39	Unknown	Fuse	Replace - Same Size	Replace - Same Size	I
151117522	T05539	04/21/2015	17:22	04/21/2015	18:29	13	871	66	Overhead equipment	Fuse			VI
151118048	J63174	04/21/2015	17:27	04/21/2015	21:45	13	3354	258	Underground equipment	Underground Primary	Repair		III

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
151117648	C52002	04/21/2015	17:56	04/21/2015	18:59	1	63	63	Animal related	Fuse	Replace - Same Size		III
151117719	L68111	04/21/2015	18:09	04/21/2015	19:25	2	152	76	Public	Other			IV
151117722	K46388	04/21/2015	18:23	04/21/2015	21:58	1	215	214	Underground equipment	Underground Secondary	Patrol/Test/Inspect	Repair	V
151117781	K43386	04/21/2015	18:56	04/21/2015	23:32	1	276	275	Overhead equipment	Overhead Service	Repair		V
151118007	V18582	04/21/2015	19:18	04/21/2015	19:55	1	37	36	Animal related	Transformer Fuse	Replace - Same Size		II
151118013	R48165	04/21/2015	19:22	04/21/2015	20:10	1	48	48	Overhead equipment	Overhead Primary			IV
151118087	V59003	04/21/2015	19:23	04/21/2015	21:40	2	274	137	Other				II
151118063	A56013	04/21/2015	20:16	04/21/2015	21:15	1	59	58	Overhead equipment	Connector	Replace - Same Size		I
151118123	K39156	04/21/2015	21:21	04/21/2015	23:22	1	121	121	Overhead equipment	Connector	Replace - Same Size		III
5006193	M19222	04/21/2015	21:44	04/22/2015	2:15	1	270	270	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	VI
151118153	K94224	04/21/2015	22:34	04/22/2015	0:33	1	119	119	Tree related-tree contact	Overhead Service	Repair		III
151118164	P98192	04/21/2015	23:40	04/22/2015	1:15	1	95	95	Tree related-tree contact	Overhead Service			III
151120189	A85001	04/21/2015	23:59	04/22/2015	1:53	104	11856	114	Overhead equipment	Fuse	Repair	Repair	I
151120135	A85002	04/22/2015	0:02	04/22/2015	5:57	15	5325	355	Overhead equipment	Pole	Patrol/Test/Inspect	Replace - Urgent	I
151124223	R60552	04/22/2015	4:36	04/22/2015	7:11	15	2325	155	Underground equipment	Underground Primary	Replace - New Size	Replace - New Size	IV
151124234	U35511	04/22/2015	5:33	04/22/2015	9:43	3	750	250	Underground equipment	Underground Primary	Repair		II
151124241	R02121	04/22/2015	6:03	04/22/2015	6:40	1	37	37	Overhead equipment	Transformer Fuse	Repair	Repair	VI
151124240	K91117	04/22/2015	6:07	04/22/2015	6:41	1	34	33	Tree related-tree contact	Overhead Service	Repair		III
5006345	R49275	04/22/2015	7:10	04/23/2015	8:28	33	50070	1517	Animal related				VI
151124348	A91003	04/22/2015	7:18	04/22/2015	7:49	1	31	30	Animal related	Transformer Fuse	Replace - Same Size		I
5006205	N05172	04/22/2015	7:38	04/22/2015	9:00	1	81	81	Overhead equipment	Jumper	Repair		I
151124495	J75271	04/22/2015	8:05	04/22/2015	9:25	1	80	79	Overhead equipment	Overhead Service	Patrol/Test/Inspect	Replace - Same Size	IV
151124533	K80382	04/22/2015	8:17	04/22/2015	9:21	1	64	63	Animal related	Transformer Fuse	Replace - Same Size		IV
5006207	L62928	04/22/2015	8:19	04/22/2015	9:48	2	177	88	Overhead equipment	Disconnect Switch		Replace - Same Size	VI
5006209	Y63527	04/22/2015	8:30	04/22/2015	9:33	1	62	62	Overhead equipment	Disconnect Switch	Replace - Same Size		IV
151124630	D28124	04/22/2015	8:45	04/22/2015	10:37	1	112	111	Public	Overhead Service	Patrol/Test/Inspect	Repair	I
5006217	HB5890	04/22/2015	8:58	04/22/2015	10:38	1	99	99	Animal related	Transformer Fuse	Replace - Same Size		I
151124905	N18211	04/22/2015	9:44	04/22/2015	11:26	1	102	102	Overhead equipment	Connector	Repair		III
151124949	V23530	04/22/2015	9:48	04/22/2015	10:20	28	896	31	Animal related	Fuse	Replace - Same Size		II
151124939	M26161	04/22/2015	9:50	04/22/2015	11:06	1	76	76	Overhead equipment	Transformer Fuse	Replace - Same Size		III
151124973	L23148	04/22/2015	9:57	04/22/2015	12:21	1	144	143	Overhead equipment	Overhead Secondary	Replace - Same Size		III
5006221	J89112	04/22/2015	9:57	04/22/2015	10:50	1	52	52	Overhead equipment	Overhead Service			VI
151125491	J08207	04/22/2015	10:00	04/22/2015	13:01	3	543	181	Overhead equipment	Overhead Transformer			I
151125050	S47575	04/22/2015	10:14	04/22/2015	10:34	1	20	20	Other				VI
5006241	X78536	04/22/2015	10:45	04/22/2015	12:24	1	98	98	Animal related	Transformer Fuse	Replace - Same Size		IV
151125230	M40131	04/22/2015	10:47	04/22/2015	13:00	1	133	132	Overhead equipment	Transformer Fuse	Replace - Same Size	Patrol/Test/Inspect	I
151125466	Y98003	04/22/2015	11:15	04/22/2015	12:20	155	10075	65	Overhead equipment	Jumper	Repair		IV
5006237	R34920	04/22/2015	11:32	04/22/2015	12:39	1	66	66	Public				VI
151125528	H02256	04/22/2015	11:42	04/22/2015	12:18	1	36	35	Overhead equipment	Jumper			III
151125618	S61575	04/22/2015	12:04	04/22/2015	14:50	1	166	165	Overhead equipment	Disconnect Switch	Replace - Same Size	Patrol/Test/Inspect	VI
5006243	HB5890	04/22/2015	12:17	04/22/2015	15:19	1	181	181	Unknown	Fuse	Repair		I
5006247	M20221	04/22/2015	12:59	04/22/2015	14:13	1	73	73	Overhead equipment	Fuse	Replace - Same Size		VI
151125931	K46389	04/22/2015	13:07	04/22/2015	13:40	1	33	33	Overhead equipment	Connector	Repair		V
151126105	E10002	04/22/2015	13:42	04/22/2015	14:34	2	104	52	Overhead equipment	Jumper	Replace - Same Size		III
151126207	H02256	04/22/2015	13:59	04/22/2015	16:29	1	150	149	Overhead equipment	Overhead Primary			III
151126230	D81001	04/22/2015	14:03	04/22/2015	14:51	1	48	47	Animal related	Fuse	Replace - Same Size		I
151126268	J75272	04/22/2015	14:08	04/22/2015	16:00	149	16688	111	Public	Underground Primary	Switch/Reset	Repair	IV
151126292	M54317	04/22/2015	14:15	04/22/2015	15:01	1	46	46	Intentional				V
151126391	C50001	04/22/2015	14:39	04/22/2015	18:55	82	20992	255	Overhead equipment	Crossarm	Repair		III
5006261	Q36-UNIT-1	04/22/2015	14:55	04/22/2015	16:30	1	94	94	Overhead equipment	Connector	Repair	Repair	I
151126588	J67132	04/22/2015	15:16	04/22/2015	16:02	1	46	46	Overhead equipment	Overhead Primary			III
151126650	A49003	04/22/2015	15:20	04/22/2015	16:42	22	1804	81	Underground equipment	Underground Primary	Patrol/Test/Inspect	Replace - Same Size	I
151126710	S16502	04/22/2015	15:40	04/22/2015	15:53	1	13	13	Unknown	Customer Equipment	Replace - Same Size		VI
5006265	R34920	04/22/2015	15:41	04/22/2015	19:30	1	228	228	Overhead equipment	Other		Repair	VI
151126767	Q27185	04/22/2015	15:55	04/22/2015	20:16	1	261	261	Tree related-tree broken	Pole		Straighten	VI
151126784	S88502	04/22/2015	16:00	04/22/2015	17:40	1	100	100	Overhead equipment	Transformer Fuse	Repair	Replace - Same Size	VI

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
151126972	S86597	04/22/2015	16:29	04/22/2015	19:35	356	66216	185	Public	Overhead Primary			VI
151126916	S86594	04/22/2015	16:32	04/22/2015	19:35	29	5307	182	Public	Overhead Primary			VI
151126994	B62004	04/22/2015	16:50	04/22/2015	18:25	1	95	94	Tree related-tree broken	Overhead Service	Repair		I
151127010	B73001	04/22/2015	16:53	04/22/2015	18:24	1	91	91	Overhead equipment	Jumper	Repair		I
151127087	M42107	04/22/2015	17:18	04/22/2015	18:50	1	92	91	Overhead equipment				I
151127214	Y91501	04/22/2015	17:26	04/22/2015	18:24	9	522	58	Overhead equipment				IV
151127121	Y91501	04/22/2015	17:35	04/22/2015	18:20	1	45	45	Overhead equipment	Recloser	Switch/Reset	Switch/Reset	IV
151127213	Y91501	04/22/2015	17:44	04/22/2015	18:20	14	504	36	Overhead equipment				IV
151127171	M49410	04/22/2015	17:53	04/22/2015	19:54	1	121	121	Underground equipment	Overhead Service	Cut in Clear	Repair	V
151127278	A36001	04/22/2015	18:50	04/22/2015	20:28	1	98	98	Overhead equipment	Connector	Replace - Same Size		I
151127637	K39154	04/22/2015	20:09	04/22/2015	20:43	1	34	33	Overhead equipment	Meter			III
151127642	L73154	04/22/2015	20:15	04/22/2015	21:00	1	45	45	Overhead equipment	Meter	Repair		IV
5006293	J18268	04/22/2015	20:16	04/23/2015	0:30	1	253	253	Public	Underground Service	Patrol/Test/Inspect	Repair	VI
151127648	P49183	04/22/2015	20:18	04/22/2015	22:35	1	137	136	Overhead equipment	Overhead Primary	Repair		I
5006305	R34920	04/23/2015	2:49	04/23/2015	5:00	32	4186	130	Overhead equipment	Fuse	Replace - Same Size	Patrol/Test/Inspect	VI
5006309	R34920	04/23/2015	2:53	04/23/2015	7:40	12	3449	287	Overhead equipment	Overhead Primary		Repair	VI
151134275	Z08509	04/23/2015	6:24	04/23/2015	7:03	1	39	38	Overhead equipment	Transformer Fuse	Repair	Replace - Same Size	IV
151134486	S86582	04/23/2015	6:52	04/23/2015	15:13	3	1503	500	Underground equipment	Underground Primary			VI
5006347	R49275	04/23/2015	7:10	04/23/2015	8:28	37	2879	77	Animal related				VI
5006333	R49275	04/23/2015	7:10	04/23/2015	8:28	47	3661	77	Animal related				VI
151134336	M05368	04/23/2015	7:15	04/23/2015	8:10	1	55	55	Animal related	Fuse	Replace - Same Size		V
151134503	J71128	04/23/2015	8:13	04/23/2015	10:25	1	132	132	Overhead equipment	Transformer Fuse	Replace - Same Size		I
5006343	J20931	04/23/2015	8:18	04/23/2015	9:24	11	715	65	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	VI
151134581	R66472	04/23/2015	8:34	04/23/2015	10:43	1	129	129	Tree related-tree broken	Overhead Service	Repair		IV
151134582	J80807	04/23/2015	8:34	04/23/2015	8:44	1	10	10	Jurisdictional				V
151134625	S27599	04/23/2015	8:43	04/23/2015	9:41	1	58	58	Animal related	Transformer Fuse	Repair	Replace - Same Size	VI
151134788	U33586	04/23/2015	9:23	04/23/2015	10:15	1	52	52	Animal related	Transformer Fuse	Replace - Same Size		II
151134828	B53001	04/23/2015	9:35	04/23/2015	10:21	1	46	46	Overhead equipment	Transformer Fuse	Replace - Same Size		III
151134851	F10002	04/23/2015	9:41	04/23/2015	11:32	1	111	111	Public	Overhead Service	Replace - Same Size		III
151134889	S47576	04/23/2015	9:51	04/23/2015	11:33	1	102	101	Animal related	Disconnect Switch	Replace - New Size	Patrol/Test/Inspect	VI
151134985	K43386	04/23/2015	10:04	04/23/2015	10:46	45	1890	42	Animal related	Fuse	Replace - Same Size		V
151135097	S47537	04/23/2015	10:27	04/23/2015	12:13	1	106	105	Animal related	Transformer Fuse	Replace - New Size	Patrol/Test/Inspect	VI
151135336	S47575	04/23/2015	11:15	04/23/2015	12:20	1	65	65	Animal related	Fuse	Replace - Same Size	Patrol/Test/Inspect	VI
151135459	S47575	04/23/2015	11:41	04/23/2015	12:50	1	69	68	Animal related	Transformer Fuse	Replace - Same Size		VI
151135881	L35282	04/23/2015	13:18	04/23/2015	14:32	1	74	74	Tree related-tree contact	Overhead Service	Repair		III
5006419	Q34360	04/23/2015	13:32	04/23/2015	14:21	1	48	48	Animal related	Fuse	Replace - Same Size	Replace - Same Size	I
151136286	P47120	04/23/2015	14:34	04/23/2015	19:12	1	278	278	Tree related-tree contact	Overhead Service	Repair		I
151136432	Z05548	04/23/2015	15:05	04/23/2015	16:10	1	65	65	Overhead equipment	Jumper	Repair		IV
151136507	S86582	04/23/2015	15:25	04/23/2015	19:50	3	795	265	Underground equipment	Underground Primary	Repair	Replace - Same Size	VI
151136748	K82202	04/23/2015	16:21	04/23/2015	21:30	1	309	309	Underground equipment	Underground Service			III
5006487	J86118	04/23/2015	16:51	04/23/2015	18:05	7	511	73	Tree related-tree broken	Overhead Secondary	Repair		VI
5006481	J86118	04/23/2015	16:55	04/23/2015	18:06	1	70	70	Tree related-tree broken	Overhead Secondary	Repair		VI
5006485	Q21293	04/23/2015	17:17	04/23/2015	18:39	1	81	81	Unknown	Meter	Reconnect		VI
151137090	A91004	04/23/2015	18:23	04/23/2015	19:34	1	71	71	Overhead equipment	Connector	Replace - Same Size		I
151137396	S60581	04/23/2015	20:06	04/24/2015	8:10	1	724	724	Underground equipment	Underground Secondary	Repair	Repair	VI
151137411	R23333	04/23/2015	20:42	04/24/2015	2:04	1	322	321	Underground equipment	Underground Secondary	Disconnect	Repair	V
151137432	S60581	04/23/2015	21:16	04/24/2015	8:05	1	649	648	Overhead equipment	Overhead Secondary	Repair	Replace - Same Size	VI
151137438	306003	04/23/2015	21:41	04/23/2015	23:35	1	114	114	Other	Fuse	Replace - Same Size		VI
151137447	K39153	04/23/2015	22:16	04/23/2015	23:20	1	64	63	Overhead equipment	Overhead Service	Repair		III
151137461	J46180	04/23/2015	23:23	04/24/2015	0:46	12	996	82	Overhead equipment	Overhead Primary			III
151140156		04/23/2015	23:45	04/24/2015	2:45	1877	337860	180	Overhead equipment	Substation Breaker	Repair		I
151140124	L96623	04/23/2015	23:46	04/24/2015	4:49	1	303	303	Overhead equipment	High Line Switch		Repair	I
151140253	L96623	04/23/2015	23:46	04/24/2015	3:48	2349	568458	242	Overhead equipment	Overhead Primary	Replace - Same Size		I
5006493	P26281	04/24/2015	5:46	04/24/2015	7:46	1	119	119	Overhead equipment	Disconnect Switch	Repair		I
151146082	D88002	04/24/2015	6:44	04/24/2015	7:42	1	58	58	Animal related	Fuse	Patrol/Test/Inspect	Replace - Same Size	I
151146087	M04364	04/24/2015	6:49	04/24/2015	7:35	1	46	45	Intentional				V

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
151146127	K43386	04/24/2015	7:08	04/24/2015	8:05	8	456	56	Overhead equipment	Fuse	Replace - Same Size		V
151146139	C52001	04/24/2015	7:13	04/24/2015	7:49	1	36	36	Animal related	Transformer Fuse	Repair	Replace - Same Size	III
151146183	R60551	04/24/2015	7:27	04/24/2015	13:35	1	368	367	Underground equipment	Underground Service	Patrol/Test/Inspect	Repair	IV
151146431	D36001	04/24/2015	7:37	04/24/2015	11:23	4	904	226	Underground equipment	Underground Transformer	Replace - Same Size	Repair	I
151146265	V37537	04/24/2015	7:55	04/24/2015	9:55	1	120	120	Overhead equipment	Overhead Service	Repair	Repair	II
151146303	R53391	04/24/2015	8:08	04/24/2015	8:55	1	47	47	Animal related	Transformer Fuse	Replace - Same Size		V
151146407	K78352	04/24/2015	8:35	04/24/2015	9:42	3	201	66	Animal related	Fuse			IV
151146424	K76546	04/24/2015	8:40	04/24/2015	10:30	1	110	110	Overhead equipment	Overhead Transformer			IV
5006499	P83710	04/24/2015	8:44	04/24/2015	10:54	14	1809	129	Animal related	Fuse	Repair		I
5006501	J97103	04/24/2015	8:44	04/24/2015	9:49	1	64	64	Overhead equipment	Meter			VI
151146518		04/24/2015	9:02	04/24/2015	10:20	1	78	78	Tree related-tree broken	Overhead Service			I
151146527	R60552	04/24/2015	9:03	04/24/2015	9:44	1	41	40	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
151146624	B00002	04/24/2015	9:24	04/24/2015	10:50	1	86	85	Animal related	Transformer Fuse	Replace - Same Size		I
151146684	U64518	04/24/2015	9:39	04/24/2015	11:07	1	88	87	Tree related-tree broken	Overhead Secondary	Repair		II
151146706	D96001	04/24/2015	9:44	04/24/2015	14:51	1	307	307	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
151146714	Q01282	04/24/2015	9:46	04/24/2015	10:28	1	42	42	Animal related	Transformer Fuse			III
151146725	U64518	04/24/2015	9:47	04/24/2015	10:40	1	53	53	Tree related-tree broken	Overhead Secondary	Repair		II
151146916	J58380	04/24/2015	10:29	04/24/2015	10:55	1	26	26	Overhead equipment	Transformer Fuse		Replace - Same Size	III
151146957	M54315	04/24/2015	10:37	04/24/2015	11:40	1	63	62	Overhead equipment	Overhead Service			V
151147201	D96002	04/24/2015	11:22	04/24/2015	13:13	35	3885	110	Unknown	Recloser	Switch/Reset		I
151147289	K71811	04/24/2015	11:57	04/24/2015	12:36	1	39	39	Animal related	Transformer Fuse	Repair	Repair	IV
151147392	A48002	04/24/2015	12:28	04/24/2015	13:35	1	67	66	Overhead equipment	Overhead Transformer	Switch/Reset		I
151147513	S09520	04/24/2015	12:59	04/24/2015	13:26	1	27	26	Overhead equipment	Fuse		Replace - Same Size	VI
151148317	K09864	04/24/2015	13:18	04/24/2015	18:14	50	14800	296	Overhead equipment	Pole	Replace - New Size	Repair	V
151147848	D48001	04/24/2015	14:14	04/24/2015	14:45	6	186	31	Overhead equipment	Transformer Fuse	Replace - Same Size		I
5006529	R39934	04/24/2015	15:17	04/24/2015	16:05	1	47	47	Animal related	Fuse	Replace - Same Size		VI
151148308	V18732	04/24/2015	15:19	04/24/2015	16:45	716	61576	85	Substation equipment	Capacitor	Switch/Reset	Repair	II
151148125	N91255	04/24/2015	15:26	04/24/2015	21:15	1	349	348	Underground equipment	Underground Service			III
5006531	Q18242	04/24/2015	15:45	04/24/2015	17:36	19	2105	110	Underground equipment	Underground Secondary	Disconnect	Repair	VI
151148331	S60581	04/24/2015	16:11	04/24/2015	19:20	1	189	188	Overhead equipment	Overhead Service	Repair	Repair	VI
151148362	M37192	04/24/2015	16:28	04/24/2015	20:55	1	267	267	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	I
151148379	A48002	04/24/2015	16:38	04/24/2015	18:08	1	90	90	Other	Meter			I
151148406	S86597	04/24/2015	16:50	04/24/2015	18:05	7	525	74	Overhead equipment	Fuse	Replace - Same Size		VI
151148684	U84566	04/24/2015	18:54	04/24/2015	20:47	1	113	113	Tree related-tree broken	Overhead Service			II
151148931	T02534	04/24/2015	19:13	04/24/2015	20:40	1	87	87	Other				VI
151148936	A91003	04/24/2015	19:33	04/24/2015	20:20	1	47	46	Overhead equipment	Fuse	Replace - Same Size		I
151148948	N35851	04/24/2015	20:07	04/24/2015	22:27	1	140	140	Overhead equipment	Transformer Fuse	Replace - Same Size		V
151148966	H11339	04/24/2015	21:16	04/24/2015	22:02	8	368	46	Animal related	Transformer Fuse	Replace - Same Size		V
151148994	M18131	04/24/2015	22:59	04/25/2015	1:00	1	121	120	Public	Overhead Transformer	Replace - Same Size		III
151150018	L24124	04/25/2015	1:04	04/25/2015	2:14	58	4060	69	Underground equipment	Underground Primary	Repair	Repair	III
151150020	M37192	04/25/2015	1:15	04/25/2015	2:11	1	56	55	Overhead equipment	Overhead Service	Repair		I
151150032	S64502	04/25/2015	2:42	04/25/2015	5:14	1	152	151	Underground equipment	Switchgear			VI
151150057	D39002	04/25/2015	3:51	04/25/2015	5:54	1	123	123	Overhead equipment	Disconnect Switch			I
151150058	V49535	04/25/2015	4:00	04/25/2015	9:48	1	348	348	Underground equipment	Underground Primary		Repair	II
151150083	V36001	04/25/2015	4:30	04/25/2015	6:54	35	5040	143	Tree related-tree broken	Overhead Primary	Repair		II
151150121	V26292	04/25/2015	4:35	04/25/2015	6:41	235	29610	126	Overhead equipment	Overhead Primary	Replace - Same Size		II
151150066	V26292	04/25/2015	4:43	04/25/2015	7:10	43	6321	146	Overhead equipment	Overhead Primary			II
151150085	B73001	04/25/2015	5:31	04/25/2015	11:29	79	28282	358	Overhead equipment	Pole	Replace - Same Size	Repair	I
5006539	R16511	04/25/2015	5:45	04/25/2015	8:14	11	1639	148	Overhead equipment	Pole	Repair	Replace - Same Size	I
151150094	X88502	04/25/2015	5:50	04/25/2015	6:55	1	65	65	Animal related	Transformer Fuse	Replace - Same Size		IV
151150105	S21529	04/25/2015	6:21	04/25/2015	7:39	1	78	78	Overhead equipment	Transformer Fuse	Replace - Same Size		VI
5006541	L93149	04/25/2015	6:40	04/25/2015	7:50	1	69	69	Overhead equipment	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
151150120	L12126	04/25/2015	6:42	04/25/2015	7:42	1	60	59	Animal related	Fuse	Repair		III
5006543	R16511	04/25/2015	7:09	04/25/2015	16:48	1	579	579	Overhead equipment	Pole	Repair		I
151150157	Y24523	04/25/2015	7:10	04/25/2015	8:55	32	3360	105	Overhead equipment	Disconnect Switch	Repair		IV
151150134	R33126	04/25/2015	7:13	04/25/2015	8:14	1	61	60	Overhead equipment	Overhead Primary	Patrol/Test/Inspect	Patrol/Test/Inspect	I

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5006545	R71285	04/25/2015	7:22	04/25/2015	9:00	5	485	97	Overhead equipment	Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
151150141	K09863	04/25/2015	7:25	04/25/2015	9:03	2	196	97	Animal related	Transformer Fuse	Remove	Replace - Same Size	V
151150153	Z01751	04/25/2015	7:46	04/25/2015	10:55	1	189	188	Animal related				IV
151150167	J61115	04/25/2015	8:05	04/25/2015	8:56	12	612	50	Tree related-tree broken	Overhead Service			III
151150177	R84148	04/25/2015	8:23	04/25/2015	10:15	1	112	111	Animal related	Transformer Fuse	Replace - Same Size		I
151150178	D48001	04/25/2015	8:24	04/25/2015	9:05	1	41	40	Animal related	Transformer Fuse	Replace - Same Size		I
151150184	K73362	04/25/2015	8:38	04/25/2015	9:58	1	80	79	Overhead equipment	Overhead Service	Repair		IV
151150188	D36001	04/25/2015	8:45	04/25/2015	10:54	1	129	129	Overhead equipment	Fuse	Replace - Same Size		I
151150259	N50334	04/25/2015	8:45	04/25/2015	9:50	257	16705	64	Weather	Recloser	Switch/Reset		II
151150248	B71001	04/25/2015	8:51	04/25/2015	11:59	347	65236	187	Overhead equipment	Overhead Primary	Replace - Same Size	Repair	I
151150220	B71001	04/25/2015	8:54	04/25/2015	9:34	473	18920	39	Overhead equipment	Overhead Primary	Replace - Same Size	Replace - Same Size	I
151150373	C66001	04/25/2015	8:54	04/25/2015	10:57	79	9717	123	Weather				III
151150237	P60170	04/25/2015	9:04	04/25/2015	10:44	1	100	100	Tree related-tree broken	Overhead Service	Reconnect		VI
151150245	C66001	04/25/2015	9:06	04/25/2015	11:38	5	760	152	Weather				III
151150253	D16002	04/25/2015	9:18	04/25/2015	11:59	1	161	161	Overhead equipment	Overhead Primary	Replace - Same Size		I
151150274	L79180	04/25/2015	9:29	04/25/2015	11:19	31	3410	110	Underground equipment	Underground Primary	Switch/Reset	Repair	IV
151150278	A80001	04/25/2015	9:39	04/25/2015	10:40	1	61	60	Overhead equipment	Overhead Primary	Replace - Same Size	Replace - Same Size	I
151150294	D88001	04/25/2015	9:56	04/25/2015	11:10	1	74	74	Overhead equipment	Overhead Service	Repair		I
151150297	C15002	04/25/2015	10:04	04/25/2015	11:56	1	112	111	Overhead equipment				III
151150302	C15002	04/25/2015	10:08	04/25/2015	11:53	1	105	104	Overhead equipment	Fuse	Replace - Same Size		III
151150394	K39153	04/25/2015	10:36	04/25/2015	12:34	157	18526	117	Weather	Fuse	Repair		III
151150337	K39156	04/25/2015	10:37	04/25/2015	11:20	88	3784	42	Overhead equipment	Jumper	Repair		III
151150328	L17102	04/25/2015	10:37	04/25/2015	12:46	1	129	129	Weather	Fuse	Replace - Same Size		III
151150342	D89003	04/25/2015	10:49	04/25/2015	12:35	1	106	105	Overhead equipment	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	I
151150602	A27011	04/25/2015	11:26	04/25/2015	18:35	36	15444	428	Underground equipment	Underground Transformer	Replace - Same Size	Repair	I
151150401	A27011	04/25/2015	11:26	04/25/2015	16:23	88	26136	296	Unknown	Fuse		Repair	I
5006557	Q82906	04/25/2015	11:27	04/25/2015	12:44	1	76	76	Animal related	Fuse	Replace - Same Size		VI
151150377	P47120	04/25/2015	11:41	04/25/2015	15:08	1	207	207	Overhead equipment	Fuse	Replace - Same Size	Patrol/Test/Inspect	I
151150381	U68581	04/25/2015	11:43	04/25/2015	12:55	1	72	72	Weather	Fuse	Replace - Same Size		II
151150399	M36184	04/25/2015	11:59	04/25/2015	16:27	1	268	268	Overhead equipment	Connector		Replace - Same Size	I
151150450	M41111	04/25/2015	12:59	04/25/2015	14:00	1	61	60	Overhead equipment	Overhead Service	Replace - Same Size		I
5006563	J84146	04/25/2015	12:59	04/25/2015	14:50	1	110	110	Underground equipment	Underground Service	Patrol/Test/Inspect	Repair	VI
151150481	D01001	04/25/2015	13:04	04/25/2015	15:53	33	5577	169	Overhead equipment	Other		Repair	I
151150463	U60518	04/25/2015	13:07	04/25/2015	14:15	1	68	68	Animal related	Transformer Fuse	Replace - Same Size		II
151150465	A80001	04/25/2015	13:09	04/25/2015	14:27	1	78	77	Animal related	Transformer Fuse	Replace - Same Size	Replace - Same Size	I
151150556	Y20522	04/25/2015	13:34	04/25/2015	15:30	4	464	116	Overhead equipment	Fuse	Replace - Same Size		IV
151150539	Y20522	04/25/2015	13:45	04/25/2015	19:00	11	3465	315	Overhead equipment	Pole		Repair	IV
151150505	Y20522	04/25/2015	13:45	04/25/2015	14:46	96	5856	60	Overhead equipment	Pole	Replace - Same Size		IV
151150516	K25166	04/25/2015	14:21	04/25/2015	16:27	1	126	126	Jurisdictional	Overhead Service	Cut in Clear	Repair	VI
151150521	S92559	04/25/2015	14:26	04/25/2015	15:27	1	61	60	Overhead equipment	Transformer Fuse	Replace - Same Size		VI
151150525	B21003	04/25/2015	14:28	04/25/2015	15:12	16	704	43	Animal related	Transformer Fuse	Replace - Same Size		I
151150524	D31016	04/25/2015	14:28	04/25/2015	15:21	1	53	52	Unknown	Fuse	Replace - Same Size		III
151150526	U33509	04/25/2015	14:30	04/25/2015	15:10	8	320	40	Overhead equipment	Disconnect Switch	Repair	Repair	II
151150535	U33509	04/25/2015	14:42	04/25/2015	15:11	1	29	29	Overhead equipment	Disconnect Switch	Repair	Repair	II
151150553	308005	04/25/2015	15:15	04/25/2015	16:00	15	675	45	Underground equipment	Underground Transformer	Switch/Reset		VI
151150564	308005	04/25/2015	15:27	04/25/2015	16:00	1	33	32	Underground equipment				VI
151150570	K39153	04/25/2015	15:43	04/25/2015	21:15	1	332	331	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect		III
151150578	K89141	04/25/2015	16:05	04/25/2015	16:30	2	50	24	Overhead equipment	Transformer Fuse	Repair		III
151150584	M09175	04/25/2015	16:26	04/25/2015	19:49	1	203	203	Tree related-tree contact	Overhead Service	Replace - Same Size		VI
5006571	J18267	04/25/2015	16:29	04/25/2015	18:05	1	95	95	Animal related	Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
151150606	M09175	04/25/2015	16:31	04/25/2015	17:59	96	8448	87	Overhead equipment	Overhead Primary			VI
151150591	F10001	04/25/2015	16:32	04/25/2015	17:56	1	84	84	Overhead equipment	Disconnect Switch	Replace - Same Size		III
151150609	M09175	04/25/2015	16:37	04/25/2015	19:50	132	25476	193	Overhead equipment	Overhead Primary			VI
5006573	Q82906	04/25/2015	16:48	04/25/2015	18:00	31	2210	71	Tree related-tree contact	Fuse			VI
5006745	P20-X1	04/25/2015	16:52	04/25/2015	18:51	1284	151640	118	Jurisdictional				VI
5006617	R42-UNIT-1	04/25/2015	16:52	04/25/2015	19:28	520	80730	155	Overhead equipment				VI

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5006759	Q82906	04/25/2015	16:54	04/25/2015	23:47	10	4138	413	Tree related-tree contact	Overhead Primary	Repair	Repair	VI
151150612	A48002	04/25/2015	16:56	04/25/2015	17:33	1	37	36	Overhead equipment	Disconnect Switch	Replace - Same Size	Replace - Same Size	I
151150613		04/25/2015	16:58	04/25/2015	19:30	1	152	152	Overhead equipment				VI
5006753	R44-UNIT-1	04/25/2015	17:07	04/25/2015	19:28	3	423	141	Overhead equipment				VI
5006757	R45-UNIT-1	04/25/2015	17:08	04/25/2015	19:28	1	140	140	Overhead equipment				VI
151150696	Q28141	04/25/2015	17:12	04/25/2015	20:44	1	212	211	Tree related-tree broken	Overhead Service			VI
151150701	A48002	04/25/2015	17:17	04/25/2015	17:47	1	30	30	Overhead equipment	Disconnect Switch	Replace - Same Size		I
151150712	Q75146	04/25/2015	17:32	04/25/2015	21:28	1	236	235	Tree related-tree broken	Overhead Service	Replace - Same Size		VI
151150721	308005	04/25/2015	17:51	04/25/2015	18:50	1	59	58	Underground equipment				VI
151150777	J34377	04/25/2015	19:13	04/25/2015	21:19	28	3528	126	Animal related	Fuse	Replace - Same Size		V
5006767	P20913	04/25/2015	19:22	04/25/2015	19:29	1	6	6	Overhead equipment				VI
5006785	R42-UNIT-1	04/25/2015	19:28	04/25/2015	20:44	520	39530	76	Overhead equipment				VI
151150784	N44215	04/25/2015	19:29	04/25/2015	21:39	1	130	130	Overhead equipment	Fuse			III
151150806	Y20522	04/25/2015	20:04	04/25/2015	21:12	5	340	68	Overhead equipment	Jumper			IV
151150817	D28124	04/25/2015	21:03	04/25/2015	21:57	1	54	53	Animal related	Transformer Fuse	Replace - Same Size		I
151150838	L23146	04/25/2015	22:20	04/25/2015	22:35	1	15	14	Animal related	Transformer Fuse	Repair		III
5006797	P26280	04/26/2015	8:14	04/26/2015	9:39	1	84	84	Animal related	Transformer Fuse	Repair		I
151160101	S62522	04/26/2015	8:15	04/26/2015	8:52	1	37	36	Overhead equipment	Fuse		Replace - Same Size	VI
151160153	Y55505	04/26/2015	9:09	04/26/2015	10:59	8	880	110	Animal related	Fuse	Replace - Same Size		IV
151160121	Y73504	04/26/2015	9:19	04/26/2015	10:21	1	62	62	Animal related	Transformer Fuse	Replace - Same Size	Replace - Same Size	IV
151160123	B25001	04/26/2015	9:22	04/26/2015	10:23	1	61	60	Animal related	Transformer Fuse	Replace - Same Size	Replace - Same Size	I
151160147	P47169	04/26/2015	10:17	04/26/2015	11:11	1	54	53	Overhead equipment	Jumper	Repair		I
5006799	Y37592	04/26/2015	11:04	04/26/2015	11:45	1	40	40	Animal related	Transformer Fuse	Replace - Same Size		IV
151160177	K65220	04/26/2015	11:20	04/26/2015	12:44	1	84	84	Overhead equipment	Fuse			III
151160184	S62522	04/26/2015	11:32	04/26/2015	12:17	1	45	45	Animal related	Transformer Fuse	Replace - Same Size		VI
151160330	B68004	04/26/2015	12:00	04/26/2015	13:27	50	4350	87	Overhead equipment	Jumper	Repair		III
151160203	V59003	04/26/2015	12:23	04/26/2015	15:20	1	177	177	Underground equipment	Underground Transformer	Replace - New Size		II
151160209	X09594	04/26/2015	12:35	04/26/2015	14:02	1	87	87	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
151160327	Y57001	04/26/2015	13:32	04/26/2015	14:45	1	73	73	Tree related-tree broken	Overhead Service	Repair		IV
151160333	S14511	04/26/2015	13:53	04/26/2015	14:54	1	61	60	Other				VI
151160357	J80807	04/26/2015	15:16	04/26/2015	15:53	14	518	37	Animal related	Fuse	Replace - Same Size	Replace - Same Size	V
5006805	K32915	04/26/2015	16:03	04/26/2015	17:00	1	56	56	Overhead equipment	Overhead Service	Repair		VI
151160377	J58380	04/26/2015	16:47	04/26/2015	17:56	1	69	68	Overhead equipment	Fuse			III
5006807	HC9325	04/26/2015	16:53	04/26/2015	18:18	1	84	84	Overhead equipment	Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
151160397	K80382	04/26/2015	17:34	04/26/2015	22:10	1	276	275	Underground equipment	Underground Service			IV
151160446	M09144	04/26/2015	18:25	04/26/2015	19:30	9	585	65	Animal related	Transformer Fuse			VI
151160420	339160	04/26/2015	18:48	04/27/2015	2:19	9	4059	451	Public	Pole	Patrol/Test/Inspect	Replace - Same Size	V
151160435	K27150	04/26/2015	19:08	04/26/2015	21:30	61	8662	142	Underground equipment	Underground Primary	Switch/Reset	Repair	VI
151160451	C66001	04/26/2015	19:42	04/26/2015	21:53	1	131	131	Overhead equipment	Disconnect Switch		Repair	III
151160458	R05114	04/26/2015	20:30	04/26/2015	22:20	1	110	110	Overhead equipment	Overhead Service	Patrol/Test/Inspect		I
151160461	S15558	04/26/2015	20:52	04/26/2015	21:35	1	43	43	Animal related	Transformer Fuse	Replace - Same Size		VI
151160474	L24122	04/26/2015	21:54	04/26/2015	22:58	9	576	63	Overhead equipment	Fuse	Repair		III
151160476	U06551	04/26/2015	22:10	04/27/2015	6:02	1	472	471	Underground equipment	Underground Secondary	Repair	Repair	II
151160479	M48814	04/26/2015	22:44	04/27/2015	0:01	1	77	76	Overhead equipment	Overhead Service			V
151170130	A73002	04/26/2015	23:00	04/27/2015	0:45	5	525	104	Underground equipment	Underground Primary	Switch/Reset		I
151160485	A73002	04/26/2015	23:01	04/27/2015	5:58	10	4170	417	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
151160496		04/26/2015	23:44	04/26/2015	23:49	1	5	4	Substation equipment				V
151170114	T06539	04/27/2015	0:40	04/27/2015	4:19	1	219	218	Tree related-tree broken	Overhead Primary	Repair	Repair	VI
151173968	U19534	04/27/2015	3:08	04/27/2015	4:49	1	101	100	Animal related	Transformer Fuse	Replace - Same Size		II
151173978	S93507	04/27/2015	4:46	04/27/2015	5:11	2	50	24	Public				VI
151174013	N93260	04/27/2015	6:20	04/27/2015	7:26	64	4224	65	Animal related	Fuse	Repair	Repair	III
151174022	U13551	04/27/2015	6:47	04/27/2015	8:25	1	98	98	Animal related	Transformer Fuse	Replace - Same Size		II
151174024	T12528	04/27/2015	6:48	04/27/2015	8:34	1	106	105	Animal related	Transformer Fuse	Repair	Repair	VI
151174170	M09175	04/27/2015	7:34	04/27/2015	8:53	34	2686	78	Animal related				VI
151174135	J68402	04/27/2015	7:36	04/27/2015	8:28	16	832	52	Animal related	Fuse	Repair	Repair	III
151174162	D36002	04/27/2015	7:43	04/27/2015	9:25	106	10812	101	Animal related	Fuse	Replace - Same Size		I

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
151174174	N58144	04/27/2015	7:50	04/27/2015	10:30	1	160	159	Animal related	Fuse	Replace - Same Size		I
151174213	R84148	04/27/2015	7:59	04/27/2015	8:41	1	42	42	Animal related	Transformer Fuse	Replace - Same Size		I
151174446	HD0573	04/27/2015	8:55	04/27/2015	10:40	1	105	104	Public	Underground Service	Repair	Repair	VI
5006833	Z57516	04/27/2015	9:26	04/27/2015	10:32	1	65	65	Animal related	Fuse	Replace - Same Size		IV
151174669	L17101	04/27/2015	9:37	04/27/2015	10:26	1	49	49	Overhead equipment	Transformer Fuse	Replace - Same Size		III
151174703	L71171	04/27/2015	9:43	04/27/2015	12:00	1	137	136	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
151174766	M26164	04/27/2015	9:46	04/27/2015	10:26	1212	48480	39	Public	Overhead Primary	Repair		III
151174783	M31203	04/27/2015	9:56	04/27/2015	10:25	1	29	29	Unknown	Transformer Fuse	Replace - Same Size		I
151174879	M26161	04/27/2015	10:14	04/27/2015	10:30	1	16	15	Public	Overhead Primary	Repair		III
151174919	B65003	04/27/2015	10:23	04/27/2015	11:24	1	61	60	Jurisdictional	Meter			I
151175079	N60181	04/27/2015	10:51	04/27/2015	14:56	1	245	245	Overhead equipment	Overhead Secondary	Patrol/Test/Inspect	Replace - Same Size	I
151175575	N93260	04/27/2015	11:46	04/27/2015	12:46	8	480	60	Overhead equipment	Fuse		Replace - Same Size	III
151175428	N93260	04/27/2015	11:47	04/27/2015	12:47	8	480	59	Overhead equipment				III
151175459	X92508	04/27/2015	11:58	04/27/2015	12:25	1	27	26	Overhead equipment	Transformer Fuse	Repair	Replace - Same Size	IV
151175505	U80001	04/27/2015	12:06	04/27/2015	12:50	1	44	43	Public	Meter	Replace - Same Size		II
5006857	K01241	04/27/2015	12:13	04/27/2015	13:35	1	81	81	Overhead equipment	Disconnect Switch	Patrol/Test/Inspect	Replace - Same Size	VI
151175567	M37191	04/27/2015	12:19	04/27/2015	14:50	1	151	150	Other	Overhead Service			I
151175623	R73841	04/27/2015	12:31	04/27/2015	14:55	1	144	144	Overhead equipment	Transformer Fuse	Replace - Same Size		V
151176076	K95205	04/27/2015	13:47	04/27/2015	14:51	1	64	63	Overhead equipment	Overhead Transformer		Replace - Same Size	III
151176364	D53001	04/27/2015	14:36	04/27/2015	15:18	7	294	42	Animal related	Fuse	Replace - Same Size		I
151176425	Z05549	04/27/2015	14:47	04/27/2015	15:10	1	23	23	Overhead equipment	Overhead Service	Repair		IV
151176481	S25551	04/27/2015	15:01	04/27/2015	15:55	1	54	53	Animal related	Transformer Fuse	Repair	Repair	VI
151176757	U80511	04/27/2015	15:51	04/27/2015	16:23	1	32	31	Public	Overhead Service	Remove		II
151176865	D31016	04/27/2015	16:12	04/27/2015	17:14	1	62	61	Overhead equipment	Connector	Replace - Same Size		III
151176918	B08004	04/27/2015	16:22	04/27/2015	17:45	1	83	83	Tree related-tree contact	Overhead Service	Repair		I
151177524	L46810	04/27/2015	17:10	04/27/2015	20:27	7	1379	196	Public	Overhead Primary		Repair	V
151177103	L46810	04/27/2015	17:10	04/27/2015	18:15	28	1820	64	Public	Overhead Primary			V
151177264	P53341	04/27/2015	17:32	04/27/2015	18:35	1	63	62	Overhead equipment	Jumper	Patrol/Test/Inspect	Repair	IV
151177466	A85001	04/27/2015	18:24	04/27/2015	19:11	22	1034	46	Unknown	Fuse		Repair	I
151177491	K76541	04/27/2015	18:27	04/27/2015	19:41	711	52614	74	Overhead equipment				IV
151177482	K76546	04/27/2015	18:28	04/27/2015	19:33	1741	113165	65	Overhead equipment				IV
151177442	N91255	04/27/2015	18:31	04/27/2015	19:50	1	79	79	Overhead equipment	Other			III
151178078	374057	04/27/2015	18:45	04/27/2015	20:15	1	90	90	Jurisdictional	Substation Breaker			VI
151178084	374058	04/27/2015	18:45	04/27/2015	20:15	3	270	90	Jurisdictional	Substation Breaker			VI
151178085	374059	04/27/2015	18:45	04/27/2015	20:15	1	90	90	Jurisdictional	Substation Breaker			VI
151178087	374060	04/27/2015	18:45	04/27/2015	20:15	3	270	90	Jurisdictional	Substation Breaker			VI
151178088	374064	04/27/2015	18:45	04/27/2015	20:15	2	180	90	Jurisdictional	Substation Breaker			VI
151177534	K76541	04/27/2015	18:52	04/27/2015	19:46	1	54	53	Overhead equipment				IV
151177549	374060	04/27/2015	18:59	04/27/2015	20:22	1	83	82	Substation equipment	Other	Patrol/Test/Inspect		VI
151177590	374057	04/27/2015	19:13	04/27/2015	20:22	1	69	69	Jurisdictional				VI
151178013	U30001	04/27/2015	19:29	04/27/2015	20:15	5	230	46	Overhead equipment	Transformer Fuse	Replace - Same Size		II
151178027	K76541	04/27/2015	19:44	04/27/2015	19:49	1	5	4	Overhead equipment				IV
151178031	F10002	04/27/2015	19:49	04/27/2015	21:10	1	81	81	Overhead equipment	Overhead Service			III
151178032	K76541	04/27/2015	19:50	04/27/2015	19:54	1	4	4	Overhead equipment				IV
151178068	M49411	04/27/2015	20:37	04/28/2015	4:54	1	497	497	Underground equipment	Underground Secondary	Patrol/Test/Inspect	Repair	V
151178882	L95110	04/27/2015	22:19	04/27/2015	23:20	1	61	60	Tree related-tree contact	Overhead Service	Repair		III
5006911	N05172	04/27/2015	23:25	04/28/2015	4:20	1	294	294	Overhead equipment	Overhead Transformer	Replace - New Size	Replace - New Size	I
151180107	Y55004	04/28/2015	0:07	04/28/2015	3:20	1	193	193	Overhead equipment	Overhead Transformer		Replace - Same Size	IV
5006913	K57211	04/28/2015	3:02	04/28/2015	8:38	1	335	335	Overhead equipment	Overhead Transformer		Repair	VI
151184340	R05115	04/28/2015	3:59	04/28/2015	4:59	1	60	59	Animal related	Fuse	Patrol/Test/Inspect	Replace - Same Size	I
151184344	U44529	04/28/2015	4:59	04/28/2015	6:15	1	76	75	Animal related	Fuse	Replace - Same Size		II
151184411	S25552	04/28/2015	6:59	04/28/2015	8:15	1	76	75	Animal related	Fuse	Patrol/Test/Inspect	Repair	VI
151184491	303005	04/28/2015	7:34	04/28/2015	8:45	1	71	71	Overhead equipment	Overhead Service	Patrol/Test/Inspect		VI
151184593	V42572	04/28/2015	8:00	04/28/2015	8:50	36	1800	49	Animal related	Fuse	Replace - Same Size		II
151184628	K80388	04/28/2015	8:04	04/28/2015	9:16	24	1728	72	Animal related	Fuse	Replace - Same Size		IV
151184595	Q83148	04/28/2015	8:05	04/28/2015	8:45	1	40	40	Intentional				VI

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
151184705	B71001	04/28/2015	8:33	04/28/2015	9:00	1	27	27	Jurisdictional	Customer Equipment	Reconnect		I
151184747	D36003	04/28/2015	8:44	04/28/2015	10:06	1	82	81	Unknown	Fuse	Repair		I
151184765	N93260	04/28/2015	8:49	04/28/2015	10:03	1	74	74	Overhead equipment	Transformer Fuse		Replace - Same Size	III
151184773	Y55555	04/28/2015	8:53	04/28/2015	10:03	6	420	69	Animal related	Transformer Fuse	Replace - Same Size		IV
151184803	U66515	04/28/2015	8:56	04/28/2015	10:50	1	114	114	Animal related	Transformer Fuse	Replace - Same Size		II
151184972	D16004	04/28/2015	9:00	04/28/2015	9:52	18	936	52	Animal related	Fuse	Replace - Same Size		I
151185001	Z05549	04/28/2015	9:37	04/28/2015	11:05	4	352	88	Overhead equipment	Fuse	Repair		IV
151185098	Y04508	04/28/2015	9:53	04/28/2015	10:57	1	64	63	Overhead equipment	Transformer Fuse	Replace - New Size		IV
5006929	J89125	04/28/2015	9:56	04/28/2015	10:55	6	349	58	Overhead equipment	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
151185290	K89143	04/28/2015	10:19	04/28/2015	10:53	115	3910	34	Animal related	Fuse	Replace - Same Size		III
151185452	R48165	04/28/2015	10:47	04/28/2015	11:42	1	55	55	Overhead equipment	Overhead Service			IV
151185562	A81001	04/28/2015	11:06	04/28/2015	12:15	1	69	68	Overhead equipment	Overhead Service	Patrol/Test/Inspect	Repair	I
151185597	D66001	04/28/2015	11:13	04/28/2015	12:59	1	106	105	Animal related	Transformer Fuse	Replace - Same Size		IV
151185694	S83533	04/28/2015	11:28	04/28/2015	11:45	1	17	17	Other	Other			VI
5006941	Z57516	04/28/2015	11:34	04/28/2015	12:30	3	166	55	Animal related	Fuse	Replace - Same Size		IV
151185789	P98190	04/28/2015	11:44	04/28/2015	12:50	1	66	65	Animal related	Transformer Fuse	Repair	Repair	III
151185908	C36001	04/28/2015	12:04	04/28/2015	12:42	1	38	37	Other	Other			III
151186187	S49549	04/28/2015	12:55	04/28/2015	13:11	1	16	15	Other	Overhead Service			VI
151186309	Q04411	04/28/2015	13:13	04/28/2015	14:54	1	101	101	Unknown				III
151186456	M07235	04/28/2015	13:35	04/28/2015	14:33	1	58	58	Tree related-tree broken	Fuse			III
151186635	N97886	04/28/2015	14:06	04/28/2015	17:05	1	179	178	Overhead equipment	Connector	Replace - New Size		V
151186935	L17102	04/28/2015	14:59	04/28/2015	16:10	1	71	71	Underground equipment	Underground Secondary	Patrol/Test/Inspect	Repair	III
151187177	S15560	04/28/2015	15:29	04/28/2015	16:20	574	29274	50	Overhead equipment	Overhead Primary	Repair		VI
151187156	X64503	04/28/2015	15:36	04/28/2015	17:30	1	114	113	Public	Overhead Service	Repair		IV
5006961	R08910	04/28/2015	15:37	04/28/2015	19:30	1	232	232	Overhead equipment	Transformer Fuse	Replace - Same Size		VI
151187290	H00162	04/28/2015	16:01	04/28/2015	20:45	1	284	284	Underground equipment	Underground Service			III
5006967	J86108	04/28/2015	16:09	04/28/2015	19:17	1	187	187	Overhead equipment	Disconnect Switch	Patrol/Test/Inspect	Repair	VI
151187346	X72535	04/28/2015	16:14	04/28/2015	18:22	5	640	127	Animal related	Transformer Fuse	Replace - Same Size		IV
151187373	S60581	04/28/2015	16:18	04/28/2015	17:16	1	58	58	Overhead equipment	Overhead Service			VI
151187387	U93563	04/28/2015	16:18	04/28/2015	18:37	76	10564	138	Underground equipment	Underground Primary	Repair	Repair	II
151187473	J80806	04/28/2015	16:33	04/29/2015	0:52	15	7485	499	Public	Pole	Replace - Same Size	Replace - Same Size	V
5006975	R94269	04/28/2015	16:49	04/28/2015	18:31	1	101	101	Animal related	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
151187557	K46388	04/28/2015	17:01	04/28/2015	17:38	1	37	37	Animal related	Transformer Fuse	Replace - Same Size		V
151187670	Q32170	04/28/2015	17:33	04/28/2015	19:30	1	117	117	Animal related	Transformer Fuse	Replace - Same Size		I
5006979	K15207	04/28/2015	18:13	04/28/2015	19:15	1	61	61	Overhead equipment	Transformer Fuse	Replace - Same Size		VI
151187812	D61001	04/28/2015	18:17	04/28/2015	19:40	1	83	82	Overhead equipment	Fuse	Replace - Same Size		III
5006993	N05170	04/28/2015	18:48	04/28/2015	22:00	70	13428	191	Underground equipment	Underground Primary	Repair	Repair	I
151187894	R84148	04/28/2015	19:00	04/28/2015	22:33	1	213	213	Overhead equipment	Overhead Transformer	Replace - Same Size	Repair	I
5006995	J84124	04/28/2015	19:16	04/28/2015	21:00	3	312	104	Overhead equipment	Lightning Arrestor		Replace - Same Size	VI
151188275	L35138	04/28/2015	20:42	04/28/2015	21:33	1	51	50	Unknown	Transformer Fuse	Replace - Same Size		III
151188321	K71812	04/28/2015	22:30	04/28/2015	23:39	1	69	69	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	IV
151190157	H00163	04/29/2015	1:36	04/29/2015	6:30	53	15582	294	Underground equipment	Underground Primary			III
151193970	J13108	04/29/2015	4:13	04/29/2015	5:45	1	92	92	Unknown	Fuse	Patrol/Test/Inspect	Replace - Same Size	I
151193998	J13108	04/29/2015	4:13	04/29/2015	11:19	1	426	426	Underground equipment	Underground Primary			I
151194036	P25152	04/29/2015	6:41	04/29/2015	12:28	1	347	346	Underground equipment	Underground Service	Repair		III
151194079	N15850	04/29/2015	7:08	04/29/2015	8:15	1	67	66	Overhead equipment	Overhead Primary	Patrol/Test/Inspect	Repair	V
151194100	M81402	04/29/2015	7:14	04/29/2015	10:57	1	223	223	Animal related	Lightning Arrestor		Repair	V
5007031	Y86593	04/29/2015	7:31	04/29/2015	8:15	1	43	43	Animal related	Transformer Fuse			IV
151194239	L79180	04/29/2015	7:34	04/29/2015	8:29	42	2310	55	Animal related	Fuse	Replace - Same Size		IV
151194162	S22595	04/29/2015	7:39	04/29/2015	8:15	4	144	36	Overhead equipment	Fuse		Replace - Same Size	VI
151194321	P80145	04/29/2015	8:21	04/29/2015	8:37	1	16	15	Animal related	Transformer Fuse	Replace - Same Size	Replace - Same Size	I
5007049	R10941	04/29/2015	8:24	04/29/2015	9:36	14	997	71	Animal related	Fuse	Replace - Same Size		VI
151194550	M36185	04/29/2015	8:46	04/29/2015	12:10	1683	343332	204	Animal related	Overhead Primary	Repair	Tie/Tighten	I
151194440	N95823	04/29/2015	8:46	04/29/2015	9:22	1	36	36	Animal related	Transformer Fuse	Replace - Same Size		V
151194523	302001	04/29/2015	8:51	04/29/2015	11:05	1	134	133	Overhead equipment	Fuse	Repair		VI
151194556	M42107	04/29/2015	8:54	04/29/2015	11:50	1	176	175	Overhead equipment				I

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
151194597	R73841	04/29/2015	9:02	04/29/2015	10:24	1	82	82	Animal related	Transformer Fuse	Replace - Same Size		V
151194630	M37192	04/29/2015	9:08	04/29/2015	12:45	1	217	216	Animal related	Overhead Primary	Repair	Tie/Tighten	I
5007065	K58213	04/29/2015	9:09	04/29/2015	10:04	1	54	54	Overhead equipment	Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
5007067	K58213	04/29/2015	9:09	04/29/2015	10:04	4	217	54	Overhead equipment	Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
151194671	R73841	04/29/2015	9:19	04/29/2015	10:24	4	260	65	Animal related	Transformer Fuse	Replace - Same Size		V
151194700	J34357	04/29/2015	9:24	04/29/2015	10:07	1	43	42	Animal related	Transformer Fuse	Replace - Same Size		V
151194831	R60551	04/29/2015	9:55	04/29/2015	11:13	1	78	78	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
151194903	V61563	04/29/2015	10:08	04/29/2015	12:23	1	135	135	Overhead equipment	Overhead Service	Repair		II
5007117	Q64939	04/29/2015	11:05	04/29/2015	14:00	1	174	174	Overhead equipment	Transformer Fuse	Replace - Same Size	Repair	VI
5007119	J83140	04/29/2015	11:08	04/29/2015	18:26	1	437	437	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	VI
151195616	S43501	04/29/2015	12:12	04/29/2015	13:15	1	63	63	Other	Other			VI
151195833	D48001	04/29/2015	12:59	04/29/2015	13:41	20	840	42	Overhead equipment	Transformer Fuse	Replace - New Size		I
151196152	A91002	04/29/2015	13:25	04/29/2015	18:39	32	10048	313	Overhead equipment	Pole	Patrol/Test/Inspect	Repair	I
151196153	Y93544	04/29/2015	13:58	04/29/2015	14:40	1	42	42	Overhead equipment	Connector	Repair	Replace - Same Size	IV
151196338	310123	04/29/2015	14:30	04/29/2015	15:02	1	32	31	Animal related	Fuse	Replace - New Size		V
151196485	D69001	04/29/2015	14:58	04/29/2015	15:55	1	57	56	Other	Customer Equipment	Reconnect		I
151196952	B68002	04/29/2015	15:09	04/29/2015	17:45	4	624	156	Overhead equipment	Pole	Repair		III
151196661	N35851	04/29/2015	15:27	04/29/2015	15:59	183	5856	31	Overhead equipment	Overhead Primary		Repair	V
5007135	Y86595	04/29/2015	15:36	04/29/2015	16:55	1	78	78	Overhead equipment	Fuse	Replace - Same Size		IV
151197284	P53341	04/29/2015	18:03	04/29/2015	18:52	9	441	49	Overhead equipment	Fuse	Patrol/Test/Inspect	Replace - Same Size	IV
151197285	N50333	04/29/2015	18:19	04/29/2015	23:13	1	294	294	Animal related	Underground Service	Repair	Repair	II
5007153	X60596	04/29/2015	18:31	04/29/2015	22:05	1	214	214	Underground equipment	Underground Service	Repair	Repair	IV
151197359	A80001	04/29/2015	18:35	04/29/2015	20:13	1	98	98	Animal related	Fuse	Replace - Same Size		I
5007155	Q70161	04/29/2015	19:18	04/30/2015	1:21	14	5081	362	Public	Pole	Repair	Repair	I
151197709	D36001	04/29/2015	19:23	04/29/2015	22:20	1	177	177	Unknown	Fuse	Replace - Same Size		I
151197751	S47576	04/29/2015	20:10	04/29/2015	20:38	1	28	27	Animal related	Fuse	Replace - Same Size	Patrol/Test/Inspect	VI
151197823	N42856	04/29/2015	22:59	04/30/2015	0:29	88	7920	90	Overhead equipment	Lightning Arrestor	Repair		V
5007163	K32932	04/30/2015	0:36	04/30/2015	4:30	8	1865	233	Tree related-tree broken	Overhead Primary	Repair	Repair	VI
151204226	Y55505	04/30/2015	3:39	04/30/2015	4:30	1	51	50	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
151204230	B82001	04/30/2015	4:01	04/30/2015	5:55	1	114	114	Unknown	Fuse	Replace - Same Size		I
151204311	K76546	04/30/2015	6:12	04/30/2015	7:24	88	6336	72	Overhead equipment	Overhead Transformer	Replace - Same Size		IV
151204384	J63172	04/30/2015	7:18	04/30/2015	8:04	146	6716	45	Animal related	Fuse	Repair	Repair	III
5007177	P20930	04/30/2015	7:49	04/30/2015	8:47	1	57	57	Overhead equipment	Fuse	Replace - Same Size		VI
5007179	Y37592	04/30/2015	7:50	04/30/2015	8:57	5	330	66	Animal related	Transformer Fuse	Replace - Same Size		IV
5007181	R04413	04/30/2015	8:00	04/30/2015	9:40	1	99	99	Public	Underground Service			V
5007183	Y37592	04/30/2015	8:01	04/30/2015	8:57	1	55	55	Animal related	Transformer Fuse	Replace - Same Size		IV
5007189	P20930	04/30/2015	8:06	04/30/2015	13:21	1	314	314	Underground equipment	Underground Service	Patrol/Test/Inspect	Repair	VI
151204633	B68002	04/30/2015	8:30	04/30/2015	9:07	1	37	37	Other				III
151204649	K09864	04/30/2015	8:34	04/30/2015	9:11	10	370	37	Animal related	Transformer Fuse	Replace - Same Size	Repair	V
151204708	Q04411	04/30/2015	8:43	04/30/2015	9:15	66	2112	31	Animal related	Fuse	Repair	Repair	III
151205169	D01002	04/30/2015	9:59	04/30/2015	10:27	13	364	27	Overhead equipment	Overhead Primary	Repair		I
5007213	M05368	04/30/2015	10:32	04/30/2015	14:35	1	242	242	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	V
5007215	Y59520	04/30/2015	10:38	04/30/2015	13:52	1	193	193	Public	Underground Service	Repair		IV
5007221	X19561	04/30/2015	11:14	04/30/2015	15:04	13	2995	230	Underground equipment	Underground Primary	Repair	Repair	IV
151205580	L36214	04/30/2015	11:26	04/30/2015	13:31	1	125	124	Tree related-tree broken	Overhead Primary	Switch/Reset		III
5007229	P47169	04/30/2015	11:45	04/30/2015	12:23	1	37	37	Other				I
151205780		04/30/2015	12:02	04/30/2015	12:11	1	9	9	Overhead equipment				II
151205799		04/30/2015	12:05	04/30/2015	15:50	1	225	225	Overhead equipment	Overhead Transformer	Replace - Same Size	Repair	II
151206169	K39154	04/30/2015	13:08	04/30/2015	13:37	19	551	29	Animal related	Fuse	Repair		III
5007245	Q91175	04/30/2015	13:20	04/30/2015	15:40	1	139	139	Animal related	Transformer Fuse	Replace - Same Size	Replace - Same Size	I
5007251	L43153	04/30/2015	13:36	04/30/2015	14:25	9	437	48	Overhead equipment	Overhead Primary	Repair	Repair	I
5007263	M49410	04/30/2015	14:32	04/30/2015	17:03	1	150	150	Underground equipment				V
5007267	T59902	04/30/2015	14:48	04/30/2015	16:55	1	126	126	Public	Overhead Transformer	Replace - Same Size	Replace - Same Size	VI
151206785	R01153	04/30/2015	15:28	04/30/2015	18:41	1	193	193	Underground equipment	Underground Service			III
151206811	V65549	04/30/2015	15:37	04/30/2015	16:44	1	67	67	Unknown	Transformer Fuse	Replace - Same Size		II
5007281	Q37370	04/30/2015	15:56	04/30/2015	17:47	1	110	110	Overhead equipment	Jumper	Repair	Repair	I

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
151206909	J63172	04/30/2015	15:57	04/30/2015	16:42	1	45	45	Unknown				III
5007339	H39-UNIT-1	04/30/2015	16:01	04/30/2015	17:38	1	97	97	Overhead equipment	Lightning Arrestor		Replace - Same Size	V
5007303	Q10-UNIT-1	04/30/2015	16:01	04/30/2015	17:38	202	19648	97	Overhead equipment	Lightning Arrestor		Replace - Same Size	V
5007323	M67-UNIT-1	04/30/2015	16:01	04/30/2015	17:38	1	96	96	Overhead equipment	Lightning Arrestor		Replace - Same Size	V
5007293	M63822	04/30/2015	16:08	04/30/2015	17:38	1	89	89	Overhead equipment	Lightning Arrestor		Replace - Same Size	V
5007333	M79-UNIT-1	04/30/2015	16:29	04/30/2015	17:38	1	68	68	Overhead equipment	Lightning Arrestor		Replace - Same Size	V
5007335	N86227	04/30/2015	16:32	04/30/2015	17:43	1	70	70	Overhead equipment	Overhead Service	Patrol/Test/Inspect	Repair	VI
5007337	M81402	04/30/2015	16:36	04/30/2015	17:38	1	61	61	Overhead equipment	Lightning Arrestor		Replace - Same Size	V
151207091	T09559	04/30/2015	16:39	04/30/2015	18:00	1	81	81	Tree related-tree broken	Overhead Service	Patrol/Test/Inspect	Repair	VI
5007341	Q18245	04/30/2015	16:45	04/30/2015	19:00	1	134	134	Tree related-tree broken	Overhead Service	Repair		VI
5007343	M54315	04/30/2015	16:57	04/30/2015	17:38	1	40	40	Overhead equipment	Lightning Arrestor		Replace - Same Size	V
5007345	Y60593	04/30/2015	17:01	04/30/2015	21:04	99	24025	242	Public	Pole	Replace - New Size	Replace - New Size	IV
5007353	M78325	04/30/2015	17:15	04/30/2015	17:38	1	22	22	Overhead equipment	Lightning Arrestor		Replace - Same Size	V
5007357	N03296	04/30/2015	17:18	04/30/2015	17:38	1	19	19	Overhead equipment	Lightning Arrestor		Replace - Same Size	V
5007355	M40132	04/30/2015	17:18	04/30/2015	18:34	1	75	75	Overhead equipment	Transformer Fuse	Patrol/Test/Inspect		I
151207321	K27150	04/30/2015	17:44	04/30/2015	18:53	1	69	69	Animal related	Transformer Fuse	Replace - Same Size		VI
5007367	Q10702	04/30/2015	18:45	04/30/2015	19:54	1	68	68	Overhead equipment	Overhead Primary		Repair	V
5007375	HB5891	04/30/2015	19:16	04/30/2015	20:14	1	57	57	Other	Other			I
151207726	S27599	04/30/2015	19:53	04/30/2015	21:00	1	67	66	Overhead equipment	Transformer Fuse			VI
151210123	340102	05/01/2015	0:21	05/01/2015	1:28	1	67	67	Overhead equipment	Meter	Install		V
151210174	303005	05/01/2015	1:29	05/01/2015	5:05	21	4536	216	Public	Overhead Secondary	Patrol/Test/Inspect	Repair	VI
151210208	V21500	05/01/2015	1:58	05/01/2015	9:35	16	7312	457	Underground equipment				II
151210217	S47589	05/01/2015	3:00	05/01/2015	3:45	1	45	45	Overhead equipment	Fuse		Replace - Same Size	VI
151214341	L12125	05/01/2015	4:28	05/01/2015	5:56	1	88	87	Animal related	Transformer Fuse	Replace - Same Size		III
151214383	343004	05/01/2015	6:21	05/01/2015	10:00	1	219	219	Tree related-tree contact	Overhead Service	Patrol/Test/Inspect	Repair	VI
151214462	D72002	05/01/2015	7:08	05/01/2015	7:37	1	29	29	Animal related	Transformer Fuse	Replace - Same Size		I
5007397	Q32171	05/01/2015	7:14	05/01/2015	9:19	1	124	124	Overhead equipment	Transformer Fuse	Replace - Same Size		I
151214620	T06504	05/01/2015	7:56	05/01/2015	9:17	1	81	81	Animal related	Fuse	Patrol/Test/Inspect	Repair	VI
151214671	V28597	05/01/2015	8:07	05/01/2015	9:18	4	284	71	Animal related	Transformer Fuse	Replace - Same Size		II
5007403	A97001	05/01/2015	8:17	05/01/2015	9:47	17	1529	89	Animal related	Transformer Fuse	Replace - Same Size		I
151214771	K76543	05/01/2015	8:32	05/01/2015	9:58	1	86	85	Animal related	Transformer Fuse	Replace - Same Size		IV
151214808	S47575	05/01/2015	8:38	05/01/2015	9:13	1	35	34	Animal related	Fuse	Replace - Same Size		VI
5007413	L93132	05/01/2015	9:14	05/01/2015	10:08	6	322	53	Animal related	Fuse	Replace - Same Size		VI
151215374	HD0573	05/01/2015	9:19	05/01/2015	16:10	1	411	410	Public	Underground Primary			VI
151215335	HD0573	05/01/2015	9:19	05/01/2015	10:42	5	415	82	Underground equipment	Underground Primary	Switch/Reset		VI
5007415	L93132	05/01/2015	9:21	05/01/2015	10:10	1	48	48	Animal related	Fuse	Replace - Same Size		VI
151215112	325010	05/01/2015	9:27	05/01/2015	11:13	1	106	105	Public	Overhead Transformer	Patrol/Test/Inspect		VI
151215120	325010	05/01/2015	9:28	05/01/2015	11:37	1	129	129	Public	Overhead Service	Patrol/Test/Inspect	Repair	VI
5007417	Q18243	05/01/2015	9:32	05/01/2015	13:18	11	2476	225	Other				VI
151215217	J67131	05/01/2015	9:45	05/01/2015	10:13	1	28	27	Other	Other			III
5007419	K46388	05/01/2015	9:54	05/01/2015	10:46	1	51	51	Overhead equipment	Connector	Repair		V
151215431	R28871	05/01/2015	10:13	05/01/2015	11:15	8	496	62	Public	Overhead Primary		Repair	V
151215432	T08501	05/01/2015	10:16	05/01/2015	11:04	1	48	47	Overhead equipment	Transformer Fuse	Repair	Repair	VI
151215498	L24121	05/01/2015	10:25	05/01/2015	11:50	1	85	84	Animal related	Fuse	Replace - Same Size		III
151215593	325010	05/01/2015	10:43	05/01/2015	11:30	1	47	46	Public	Overhead Service	Patrol/Test/Inspect	Repair	VI
151215607	343004	05/01/2015	10:45	05/01/2015	12:50	1	125	124	Tree related-tree contact	Overhead Service		Repair	VI
5007433	X88502	05/01/2015	11:03	05/01/2015	11:40	20	751	37	Animal related	Transformer Fuse	Replace - Same Size		IV
5007437	K57211	05/01/2015	11:30	05/01/2015	13:30	1	119	119	Animal related	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
151215860	J61115	05/01/2015	11:34	05/01/2015	12:14	1	40	40	Other	Other			III
151215873	S86581	05/01/2015	11:39	05/01/2015	12:30	1	51	50	Other				VI
151215890	L24122	05/01/2015	11:42	05/01/2015	12:30	4	192	47	Animal related	Fuse	Replace - Same Size		III
151215947	D55002	05/01/2015	12:00	05/01/2015	12:32	1	32	31	Overhead equipment	Connector	Replace - Same Size		I
5007447	Y55594	05/01/2015	12:43	05/01/2015	14:05	1	81	81	Animal related	Transformer Fuse	Replace - Same Size		IV
151216354	S13546	05/01/2015	13:21	05/01/2015	13:58	1	37	36	Unknown	Customer Equipment	Replace - Same Size		VI
151216392	N15850	05/01/2015	13:28	05/01/2015	14:20	1	52	51	Overhead equipment	Meter	Replace - Same Size		V
151216479	J47176	05/01/2015	13:41	05/01/2015	16:16	104	16120	154	Public	Underground Primary			III

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5007465	Q32171	05/01/2015	13:46	05/01/2015	18:30	1	283	283	Animal related	Transformer Fuse	Replace - Same Size		I
5007467	X24536	05/01/2015	13:49	05/01/2015	14:25	1	35	35	Animal related	Fuse		Replace - Same Size	IV
151216680	K39156	05/01/2015	14:30	05/01/2015	16:45	1	135	135	Tree related-tree contact	Tree	Remove		III
151216691	U78001	05/01/2015	14:33	05/01/2015	17:30	1	177	177	Overhead equipment	Overhead Service	Repair		II
5007475	D48003	05/01/2015	14:51	05/01/2015	17:46	6	1046	174	Unknown	Other		Repair	I
5007477	D28124	05/01/2015	15:01	05/01/2015	16:04	1	62	62	Overhead equipment	Overhead Primary	Repair		I
151216967	L71171	05/01/2015	15:07	05/01/2015	19:00	6	1398	232	Public	Pole	Replace - New Size		IV
5007481	K31124	05/01/2015	15:18	05/01/2015	16:30	1	71	71	Unknown	Fuse	Repair	Repair	I
5007487	X64503	05/01/2015	15:41	05/01/2015	17:00	1	78	78	Public	Customer Equipment	Cut in Clear	Advise Customer	IV
5007489	N70331	05/01/2015	15:50	05/01/2015	17:36	19	2014	106	Overhead equipment	Overhead Transformer			I
151217039	R99180	05/01/2015	16:12	05/01/2015	20:45	4	1092	272	Overhead equipment	Fuse		Replace - Same Size	IV
151217056	K65221	05/01/2015	16:17	05/01/2015	16:30	1	13	13	Other				III
151217139	J47176	05/01/2015	16:30	05/01/2015	17:16	1	46	46	Underground equipment				III
5007503	P77233	05/01/2015	17:07	05/01/2015	19:29	1	141	141	Overhead equipment	Lightning Arrestor	Replace - Same Size		VI
151217264	325010	05/01/2015	17:15	05/01/2015	19:30	1	135	135	Public	Overhead Service		Replace - New Size	VI
151217307	M22812	05/01/2015	17:38	05/01/2015	19:00	17	1394	81	Public	Fuse	Replace - Same Size		V
151217347	M18131	05/01/2015	18:06	05/01/2015	19:20	1	74	74	Animal related	Transformer Fuse	Replace - Same Size		III
151217479	N18211	05/01/2015	18:14	05/01/2015	20:06	27	3024	111	Overhead equipment	Overhead Secondary		Repair	III
5007511	Y07576	05/01/2015	18:20	05/01/2015	19:20	1	59	59	Overhead equipment	Overhead Service	Repair		IV
5007513	J34357	05/01/2015	19:03	05/01/2015	19:33	6	175	29	Animal related	Transformer Fuse	Replace - Same Size		V
151217454	D66004	05/01/2015	19:07	05/01/2015	21:08	8	968	121	Animal related	Fuse	Replace - Same Size		IV
5007515	J99141	05/01/2015	19:09	05/01/2015	19:36	1	26	26	Unknown	Overhead Service	Patrol/Test/Inspect		VI
5007517	X24536	05/01/2015	19:16	05/01/2015	22:45	1	208	208	Underground equipment	Underground Service			IV
151217457	K69116	05/01/2015	19:18	05/02/2015	0:53	1	335	335	Underground equipment	Underground Service	Patrol/Test/Inspect	Repair	IV
151217721	D32212	05/01/2015	21:53	05/01/2015	23:30	24	2328	96	Animal related	Fuse	Replace - Same Size		I
5007551	L59-UNIT-1	05/01/2015	22:11	05/02/2015	1:43	888	188193	212	Substation equipment	Substation Transformer			VI
5007683	Y23-XTR3	05/01/2015	22:35	05/01/2015	23:52	1618	125314	77	Substation equipment	Substation Misc.			IV
5007585	X20001	05/01/2015	22:36	05/01/2015	23:45	583	39836	68	Substation equipment	Substation Misc.			IV
5007703	Y22139	05/01/2015	22:52	05/02/2015	0:15	1	83	83	Substation equipment				IV
5007733	X88502	05/02/2015	5:15	05/02/2015	6:15	1	59	59	Animal related	Transformer Fuse	Replace - Same Size		IV
5007743	Y98532	05/02/2015	7:14	05/02/2015	9:13	22	2625	119	Animal related				IV
5007747	Y98532	05/02/2015	7:14	05/02/2015	9:13	91	10849	119	Animal related				IV
151220080	A17025	05/02/2015	7:25	05/02/2015	8:02	1	37	36	Animal related	Transformer Fuse	Replace - Same Size		I
5007755	P82291	05/02/2015	7:52	05/02/2015	9:27	1	94	94	Overhead equipment	Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
5007759	J99121	05/02/2015	7:55	05/02/2015	9:02	83	5531	66	Overhead equipment	Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
151220125	M09144	05/02/2015	8:00	05/02/2015	8:40	1	40	39	Animal related	Fuse	Replace - Same Size		VI
151220134	B45005	05/02/2015	8:08	05/02/2015	9:33	1	85	85	Overhead equipment				I
151220172	P98192	05/02/2015	8:44	05/02/2015	13:30	1	286	285	Underground equipment	Underground Service			III
5007783	Q18245	05/02/2015	9:03	05/02/2015	9:05	1	2	2	Unknown				VI
5007791	Y98532	05/02/2015	9:21	05/02/2015	10:50	34	3005	88	Animal related				IV
151220234	K69117	05/02/2015	9:36	05/02/2015	10:36	1	60	59	Overhead equipment				IV
151220267	D16003	05/02/2015	10:07	05/02/2015	10:37	4	120	30	Animal related	Transformer Fuse	Replace - Same Size	Replace - Same Size	I
5007809	Y98532	05/02/2015	10:46	05/02/2015	10:48	1	2	2	Unknown				IV
5007811	Y98532	05/02/2015	10:49	05/02/2015	11:20	1	31	31	Animal related				IV
151220329	B82001	05/02/2015	11:08	05/02/2015	11:59	57	2907	50	Unknown	Recloser			I
5007817	P83705	05/02/2015	11:09	05/02/2015	12:34	1	84	84	Overhead equipment	Fuse	Repair	Repair	I
5007821	P83705	05/02/2015	11:14	05/02/2015	13:30	1	135	135	Public	Overhead Primary	Repair	Repair	I
151220366	J47176	05/02/2015	11:25	05/02/2015	14:31	15	2790	185	Public	Underground Primary	Repair		III
151220345	J47176	05/02/2015	11:25	05/02/2015	11:56	1	31	30	Underground equipment	Underground Primary	Switch/Reset		III
151220343	H06135	05/02/2015	11:26	05/02/2015	12:30	1	64	63	Animal related	Fuse			IV
151220376	348116	05/02/2015	12:07	05/02/2015	13:04	1	57	56	Overhead equipment	Overhead Service	Repair		V
5007831	R94269	05/02/2015	12:22	05/02/2015	17:27	1	304	304	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	VI
151220392	R48166	05/02/2015	12:31	05/02/2015	13:00	1	29	29	Animal related	Fuse			IV
5007835	Q80352	05/02/2015	12:56	05/02/2015	14:48	1	111	111	Public	Overhead Service	Repair		V
151220415	F10001	05/02/2015	13:01	05/02/2015	14:54	1	113	113	Animal related	Transformer Fuse	Replace - Same Size		III
151220432	R20502	05/02/2015	13:10	05/02/2015	14:35	11	935	85	Public	Guy Wire		Replace - Same Size	IV

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5007837	R49261	05/02/2015	13:20	05/02/2015	17:30	1	249	249	Underground equipment	Underground Service	Patrol/Test/Inspect	Repair	VI
151220433	V35002	05/02/2015	13:22	05/02/2015	15:05	1	103	103	Tree related-tree contact	Overhead Service	Repair		II
151220496	T11508	05/02/2015	13:58	05/02/2015	15:58	164	19680	120	Public	Overhead Primary			VI
151220522	L81141	05/02/2015	14:57	05/02/2015	16:19	13	1066	81	Animal related	Fuse	Replace - Same Size		IV
151220526	H07106	05/02/2015	15:11	05/02/2015	16:54	1	103	103	Overhead equipment	Fuse	Repair		IV
151220544	R06212	05/02/2015	15:46	05/02/2015	18:29	1	163	162	Underground equipment	Underground Service	Patrol/Test/Inspect	Repair	II
151220616	S15566	05/02/2015	15:47	05/02/2015	20:50	5	1515	303	Overhead equipment	Overhead Transformer		Replace - Same Size	VI
151220577	B82001	05/02/2015	15:59	05/02/2015	19:34	4	860	214	Public	Pole	Replace - New Size	Repair	I
151220604	S21529	05/02/2015	16:29	05/02/2015	20:38	7	1743	249	Underground equipment	Underground Primary		Repair	VI
151220592	L81141	05/02/2015	16:55	05/02/2015	19:34	13	2067	159	Underground equipment	Underground Primary	Repair		IV
5007841	R33126	05/02/2015	17:50	05/02/2015	19:30	1	99	99	Animal related	Transformer Fuse	Replace - Same Size		I
5007845	X09557	05/02/2015	18:03	05/03/2015	1:31	23	10294	447	Other	Overhead Primary	Repair		IV
151220621	P98192	05/02/2015	18:24	05/02/2015	19:32	1	68	67	Overhead equipment	Overhead Secondary		Repair	III
151220620	K91115	05/02/2015	18:24	05/02/2015	19:26	1	62	61	Public	Transformer Fuse	Replace - Same Size	Repair	III
5007847	N58144	05/02/2015	19:04	05/02/2015	20:45	1	100	100	Animal related	Fuse	Replace - Same Size		I
151220833	V99562	05/02/2015	19:10	05/02/2015	22:07	15	2655	177	Overhead equipment	Fuse	Replace - Same Size		II
5007853	D28124	05/02/2015	19:20	05/02/2015	21:59	17	2689	158	Overhead equipment	Overhead Primary	Patrol/Test/Inspect	Repair	I
151220845	V83505	05/02/2015	19:46	05/02/2015	21:52	214	26964	126	Public	Pole	Switch/Reset		II
151220664	V83505	05/02/2015	19:46	05/03/2015	1:36	2	700	349	Public	Pole	Replace - Same Size	Repair	II
151220653		05/02/2015	19:48	05/02/2015	21:52	1	124	124	Public	Pole	Switch/Reset		II
5007869	K31124	05/02/2015	20:06	05/02/2015	23:30	101	20558	203	Overhead equipment	Regulator	Repair	Repair	I
5007901	Y45-XTR1	05/02/2015	20:48	05/02/2015	21:40	1697	88108	51	Substation equipment	Substation Misc.			IV
5008045	Y45-XTR2	05/02/2015	20:48	05/02/2015	21:40	1374	71338	51	Substation equipment	Substation Misc.			IV
5007939	Y48-XTR1	05/02/2015	20:48	05/02/2015	21:38	610	29999	49	Substation equipment	Substation Misc.			IV
5008117	Y47-XBK3	05/02/2015	20:59	05/02/2015	21:32	2	64	32	Substation equipment	Substation Misc.			IV
5008171	Y46-XTR1	05/02/2015	21:08	05/02/2015	22:38	1	89	89	Substation equipment	Substation Misc.			IV
151220832	344002	05/02/2015	21:54	05/03/2015	6:55	1	541	541	Tree related-tree broken	Overhead Secondary	Patrol/Test/Inspect	Repair	VI
151220862	V36002	05/02/2015	22:22	05/03/2015	0:02	3	300	100	Underground equipment	Underground Primary	Switch/Reset		II
5008177	J99141	05/02/2015	23:05	05/02/2015	23:54	1	48	48	Animal related	Fuse	Replace - Same Size		VI
151230014	K22173	05/03/2015	0:47	05/03/2015	1:33	1	46	46	Public	Pole	Repair		VI
151230037	M26164	05/03/2015	1:59	05/03/2015	8:00	10	3610	361	Public	Pole		Repair	III
151230024	M26164	05/03/2015	1:59	05/03/2015	5:18	12	2388	198	Public	Pole	Switch/Reset	Repair	III
5008211	Y28597	05/03/2015	6:01	05/03/2015	7:43	58	5902	101	Overhead equipment				IV
5008203	Y28597	05/03/2015	6:03	05/03/2015	8:34	25	3773	150	Public	Pole	Patrol/Test/Inspect	Replace - New Size	IV
5008209	Y28597	05/03/2015	6:06	05/03/2015	7:44	26	2531	97	Overhead equipment				IV
5008207	K57212	05/03/2015	6:17	05/03/2015	7:42	1	84	84	Animal related	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
151230069	C52002	05/03/2015	6:44	05/03/2015	9:12	162	23976	148	Overhead equipment	Other			III
5008215	X87578	05/03/2015	7:01	05/03/2015	9:16	1	134	134	Animal related	Transformer Fuse	Replace - Same Size		IV
151230077	N35851	05/03/2015	7:03	05/03/2015	8:15	56	4032	72	Animal related	Recloser	Switch/Reset		V
151230116	N35851	05/03/2015	7:03	05/03/2015	8:05	16	992	62	Animal related				V
5008219	Q80353	05/03/2015	7:08	05/03/2015	7:52	1	43	43	Animal related	Transformer Fuse	Replace - Same Size	Replace - Same Size	V
5008221	A81004	05/03/2015	7:08	05/03/2015	17:13	1	604	604	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
5008223	Q93522	05/03/2015	7:22	05/03/2015	9:18	19	2198	115	Animal related	Fuse	Repair		I
5008225	X82585	05/03/2015	7:40	05/03/2015	9:06	1	85	85	Animal related	Animal Guard		Install	IV
5008227	Z10501	05/03/2015	7:41	05/03/2015	8:58	1	76	76	Animal related	Fuse	Repair	Replace - Same Size	IV
5008229	X02546	05/03/2015	7:47	05/03/2015	9:28	3	301	100	Overhead equipment	Fuse	Repair	Replace - Same Size	IV
5008231	Y28597	05/03/2015	7:51	05/03/2015	8:53	6	369	61	Overhead equipment				IV
5008233	Y28597	05/03/2015	7:51	05/03/2015	8:53	7	434	62	Overhead equipment				IV
151230113	V92540	05/03/2015	7:52	05/03/2015	9:11	1	79	79	Animal related	Transformer Fuse	Replace - Same Size		II
151230126	S47589	05/03/2015	8:14	05/03/2015	9:00	1	46	46	Overhead equipment	Fuse		Replace - Same Size	VI
151230128	M22812	05/03/2015	8:15	05/03/2015	10:40	1	145	145	Overhead equipment	Fuse	Replace - Same Size		V
151230136	D81001	05/03/2015	8:16	05/03/2015	8:59	13	559	42	Unknown	Disconnect Switch	Replace - Same Size	Replace - Same Size	I
151230130	S14511	05/03/2015	8:16	05/03/2015	9:22	1	66	65	Animal related	Transformer Fuse	Replace - Same Size		VI
5008237	Z50-XTR1	05/03/2015	8:25	05/03/2015	10:30	1	124	124	Overhead equipment	Jumper	Repair	Repair	IV
151230138	S02501	05/03/2015	8:28	05/03/2015	11:20	1	172	171	Animal related	Transformer Fuse	Replace - Same Size		VI
151230137	J12166	05/03/2015	8:28	05/03/2015	8:50	7	154	21	Unknown	Transformer Fuse	Replace - Same Size		III

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
151230142	P98190	05/03/2015	8:28	05/03/2015	9:37	79	5451	68	Overhead equipment				III
5008239	HD5254	05/03/2015	8:30	05/03/2015	9:27	7	396	56	Animal related	Fuse	Replace - Same Size		VI
5008241	Y28597	05/03/2015	8:33	05/03/2015	15:31	2	835	417	Public	Jumper	Reconnect		IV
151230153		05/03/2015	8:42	05/03/2015	9:47	1	65	64	Animal related	Transformer Fuse	Replace - Same Size		V
151230159	P58155	05/03/2015	8:47	05/03/2015	9:58	17	1207	71	Overhead equipment				VI
5008243	K32932	05/03/2015	9:00	05/03/2015	9:55	1	54	54	Animal related	Fuse	Replace - Same Size		VI
5008245	B93001	05/03/2015	9:06	05/03/2015	10:30	47	3916	83	Animal related	Other			I
5008251	R71285	05/03/2015	9:34	05/03/2015	10:20	10	460	46	Overhead equipment				VI
5008261	D37001	05/03/2015	9:56	05/03/2015	10:40	60	2613	43	Animal related	Fuse	Replace - Same Size		I
5008263	K07320	05/03/2015	10:05	05/03/2015	11:10	6	389	64	Animal related	Fuse	Replace - Same Size		I
5008265	K11376	05/03/2015	10:11	05/03/2015	11:11	1	59	59	Animal related	Transformer Fuse	Replace - Same Size	Replace - Same Size	V
151230194	301053	05/03/2015	10:12	05/03/2015	12:30	1	138	137	Animal related	Fuse	Replace - Same Size		VI
5008267	A81002	05/03/2015	10:29	05/03/2015	17:13	16	6457	403	Underground equipment	Underground Primary	Patrol/Test/Inspect	Replace - Same Size	I
5008269	Z04520	05/03/2015	10:36	05/03/2015	14:06	2	420	210	Underground equipment	Underground Transformer	Replace - Same Size	Repair	IV
5008271	Y35515	05/03/2015	11:01	05/03/2015	12:53	12	1337	111	Overhead equipment	Overhead Transformer	Repair	Replace - Same Size	IV
151230251	P69175	05/03/2015	11:44	05/03/2015	12:35	1	51	50	Animal related	Transformer Fuse	Replace - Same Size		III
151230261	V25513	05/03/2015	11:49	05/03/2015	14:00	203	26593	131	Tree related-tree contact	Overhead Primary	Trim		II
151230486	V25513	05/03/2015	11:57	05/03/2015	21:15	3	1674	557	Tree related-tree broken	Overhead Primary			II
151230304	342001	05/03/2015	12:34	05/03/2015	15:50	2	392	195	Tree related-tree broken	Overhead Primary	Patrol/Test/Inspect	Repair	VI
5008283	R34920	05/03/2015	13:21	05/03/2015	15:56	6	931	155	Public				VI
5008285	R34920	05/03/2015	13:31	05/03/2015	18:24	19	5551	292	Public	Fuse	Replace - Same Size		VI
151230556	S02501	05/03/2015	13:52	05/03/2015	16:30	199	31442	158	Overhead equipment	Connector			VI
5008287	Z04520	05/03/2015	13:56	05/03/2015	18:06	1	250	250	Underground equipment	Underground Primary	Repair		IV
5008291	M81403	05/03/2015	14:37	05/03/2015	19:48	3	932	310	Tree related-tree broken	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	V
151230559	334004	05/03/2015	14:41	05/03/2015	16:30	7	763	108	Overhead equipment	Fuse	Replace - Same Size		VI
151230548	J61117	05/03/2015	15:06	05/03/2015	15:44	1	38	37	Overhead equipment				III
5008295	Q32171	05/03/2015	15:22	05/03/2015	17:30	1	127	127	Animal related	Transformer Fuse	Replace - Same Size		I
151230563	K30204	05/03/2015	15:37	05/03/2015	17:16	6	594	99	Unknown	Fuse	Replace - Same Size		III
151230598	T22508	05/03/2015	17:35	05/03/2015	20:00	1	145	145	Tree related-tree broken	Overhead Secondary	Replace - New Size		VI
5008303	N05173	05/03/2015	17:45	05/03/2015	19:40	7	803	114	Weather	Fuse	Repair	Repair	I
5008317	D37003	05/03/2015	18:54	05/03/2015	20:54	98	11786	120	Overhead equipment	Overhead Primary	Repair		I
5008321	N05172	05/03/2015	19:06	05/03/2015	19:26	1	19	19	Weather	Meter	Disconnect	Disconnect	I
151230653	M09143	05/03/2015	19:12	05/03/2015	19:38	6	156	26	Animal related	Fuse	Replace - Same Size		VI
5008325	B84006	05/03/2015	19:15	05/03/2015	23:30	29	7382	254	Underground equipment	Underground Primary	Patrol/Test/Inspect	Reconnect	I
5008329	Q91175	05/03/2015	19:25	05/03/2015	21:18	1	112	112	Overhead equipment	Jumper	Repair		I
5008335	D87001	05/03/2015	20:17	05/04/2015	4:19	1	481	481	Underground equipment	Underground Primary	Patrol/Test/Inspect	Reconnect	I
5008337	Z51551	05/03/2015	20:22	05/03/2015	22:18	1	115	115	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
5008341	D37003	05/03/2015	20:48	05/04/2015	0:26	56	12177	217	Overhead equipment	Lightning Arrestor	Replace - Same Size		I
5008345	J83138	05/03/2015	22:11	05/03/2015	23:19	1	67	67	Overhead equipment	Overhead Service	Repair		VI
5008349	Q70161	05/03/2015	23:47	05/04/2015	4:30	1	282	282	Weather	Overhead Transformer	Repair	Repair	I
5008405	J01118	05/04/2015	4:16	05/04/2015	7:56	38	8334	219	Overhead equipment				I
151243926	D70004	05/04/2015	4:31	05/04/2015	12:44	35	17255	492	Underground equipment	Underground Primary	Repair	Repair	I
151243361	V69546	05/04/2015	5:14	05/04/2015	7:35	1	141	140	Unknown	Transformer Fuse	Replace - Same Size		II
5008367	A36001	05/04/2015	5:42	05/04/2015	6:52	1	69	69	Weather	Fuse	Replace - Same Size		I
151243365	S61575	05/04/2015	5:43	05/04/2015	6:36	1	53	53	Overhead equipment	Fuse		Replace - Same Size	VI
151243366	K65221	05/04/2015	5:49	05/04/2015	7:39	1	110	110	Weather	Transformer Fuse	Repair	Repair	III
151243375	U04589	05/04/2015	5:59	05/04/2015	7:05	1	66	66	Animal related	Transformer Fuse	Replace - Same Size	Repair	II
5008371	D89003	05/04/2015	6:15	05/04/2015	7:47	120	11052	92	Overhead equipment	Fuse	Replace - Same Size		I
5008447	D89003	05/04/2015	6:16	05/04/2015	12:01	10	3444	344	Overhead equipment	Disconnect Switch	Switch/Reset	Replace - Same Size	I
151243397	S02501	05/04/2015	6:23	05/04/2015	9:12	1	169	168	Overhead equipment				VI
5008387	Z05548	05/04/2015	6:34	05/04/2015	7:52	398	31004	77	Animal related	Lightning Arrestor	Disconnect		IV
151243422	V21548	05/04/2015	6:43	05/04/2015	7:55	1	72	71	Animal related	Transformer Fuse	Replace - Same Size		II
151243558	R60552	05/04/2015	6:54	05/04/2015	9:50	3	528	175	Overhead equipment	Overhead Primary	Repair		IV
5008421	X64501	05/04/2015	6:56	05/04/2015	8:40	8	828	103	Weather	Fuse	Replace - Same Size		IV
151243488	L95110	05/04/2015	7:05	05/04/2015	8:00	3	165	55	Animal related	Fuse	Replace - Same Size	Repair	III
151243606	D55025	05/04/2015	7:18	05/04/2015	9:58	2334	373440	159	Overhead equipment	Other	Replace - Same Size	Repair	I

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5008433	Y89540	05/04/2015	7:19	05/04/2015	8:38	1	78	78	Underground equipment	Underground Transformer	Repair	Replace - Same Size	IV
151243599	D36001	05/04/2015	7:25	05/04/2015	8:35	1	70	69	Overhead equipment	Overhead Service	Repair		I
5008439	R33126	05/04/2015	7:26	05/04/2015	9:11	1	104	104	Weather	Fuse	Repair	Replace - Same Size	I
5008443	J87120	05/04/2015	7:32	05/04/2015	8:08	1	35	35	Animal related	Transformer Fuse	Replace - Same Size		VI
5008463	B93003	05/04/2015	7:34	05/04/2015	10:36	211	38345	181	Overhead equipment	Overhead Primary	Patrol/Test/Inspect	Repair	I
151243643	C50001	05/04/2015	7:39	05/04/2015	9:45	1	126	126	Overhead equipment	Disconnect Switch	Replace - Same Size		III
5008449	J07135	05/04/2015	7:43	05/04/2015	9:30	1	106	106	Overhead equipment	Jumper	Replace - New Size	Patrol/Test/Inspect	I
5008461	X19561	05/04/2015	8:00	05/04/2015	14:14	1	373	373	Weather	Overhead Transformer	Replace - Same Size	Replace - Same Size	IV
151243744	Q75146	05/04/2015	8:05	05/04/2015	8:50	1	45	45	Animal related	Fuse	Replace - Same Size	Repair	VI
151243765	339164	05/04/2015	8:10	05/04/2015	8:49	1	39	38	Jurisdictional	Overhead Service	Reconnect		V
151243809	S02501	05/04/2015	8:19	05/04/2015	13:53	1	334	333	Overhead equipment	Fuse	Patrol/Test/Inspect	Patrol/Test/Inspect	VI
151243846	D96001	05/04/2015	8:25	05/04/2015	9:02	1	37	36	Other	Customer Equipment	Patrol/Test/Inspect		I
5008473	B93003	05/04/2015	8:30	05/04/2015	9:34	1	63	63	Unknown	Fuse	Replace - Same Size		I
151243902	K39154	05/04/2015	8:35	05/04/2015	12:00	1	205	204	Public	Underground Transformer	Replace - Same Size	Repair	III
151243931	V95586	05/04/2015	8:39	05/04/2015	9:42	1	63	62	Overhead equipment	Overhead Secondary	Repair	Replace - Same Size	II
151243964	E05002	05/04/2015	8:45	05/04/2015	9:12	5	135	26	Animal related	Transformer Fuse	Replace - Same Size		IV
151243989	V28597	05/04/2015	8:50	05/04/2015	9:19	1	29	29	Jurisdictional				II
5008479	M36185	05/04/2015	8:56	05/04/2015	10:30	10	934	93	Animal related	Transformer Fuse	Replace - Same Size	Patrol/Test/Inspect	I
151244048	CW1017	05/04/2015	9:00	05/04/2015	10:40	1	100	100	Animal related	Fuse	Replace - Same Size		III
151244049	C36001	05/04/2015	9:01	05/04/2015	9:52	1	51	50	Unknown	Fuse	Replace - Same Size		III
151244098	R59421	05/04/2015	9:11	05/04/2015	11:25	1	134	133	Tree related-tree contact	Overhead Service	Repair		IV
151244146	J75271	05/04/2015	9:19	05/04/2015	13:08	1	229	229	Underground equipment	Underground Service	Repair		IV
151244179	V40556	05/04/2015	9:25	05/04/2015	10:00	1	35	34	Animal related	Transformer Fuse	Replace - Same Size		II
151244182	D66002	05/04/2015	9:26	05/04/2015	10:00	1	34	33	Overhead equipment	Overhead Primary	Repair		IV
151244254	L08226	05/04/2015	9:38	05/04/2015	11:17	1	99	98	Unknown	Fuse	Replace - Same Size		III
5008489	R84148	05/04/2015	9:39	05/04/2015	11:20	1	100	100	Animal related	Transformer Fuse	Replace - Same Size		I
151244282	D72002	05/04/2015	9:42	05/04/2015	14:48	1	306	306	Underground equipment	Other	Repair	Repair	I
151244323	C65001	05/04/2015	9:50	05/04/2015	10:34	1	44	44	Animal related	Fuse	Replace - Same Size		III
151244475	N44217	05/04/2015	10:11	05/04/2015	15:03	1	292	291	Overhead equipment	Transformer Fuse		Replace - Same Size	III
151244506	M45211	05/04/2015	10:15	05/04/2015	10:40	1	25	24	Animal related	Transformer Fuse	Replace - Same Size		IV
5008519	X88510	05/04/2015	10:34	05/04/2015	11:31	1	56	56	Animal related	Transformer Fuse	Replace - Same Size		IV
5008511	P77235	05/04/2015	11:03	05/04/2015	11:49	1	45	45	Animal related	Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
151244829	K91115	05/04/2015	11:13	05/04/2015	12:15	1	62	61	Tree related-tree contact	Overhead Service	Repair		III
151244949	P62138	05/04/2015	11:30	05/04/2015	13:16	24	2544	105	Overhead equipment	Fuse		Patrol/Test/Inspect	VI
5008529	P23-UNIT-1	05/04/2015	11:41	05/04/2015	12:20	1	38	38	Animal related	Fuse	Replace - Same Size		VI
151245239	P69175	05/04/2015	12:19	05/04/2015	12:43	1	24	24	Animal related	Fuse	Replace - Same Size	Repair	III
151245252	V58507	05/04/2015	12:21	05/04/2015	14:25	1	124	124	Weather	Transformer Fuse	Replace - Same Size	Replace - Same Size	II
5008539	Q25801	05/04/2015	12:39	05/04/2015	13:33	1	53	53	Tree related-tree contact	Overhead Service	Disconnect		I
151245383	B44001	05/04/2015	12:52	05/04/2015	13:27	7	245	34	Weather	Disconnect Switch	Replace - Same Size	Replace - Same Size	I
5008559	D89003	05/04/2015	13:10	05/04/2015	14:06	89	4973	55	Animal related	Fuse	Replace - Same Size		I
5008571	J83140	05/04/2015	13:12	05/04/2015	14:19	39	2592	66	Other	Pole	Replace - Same Size	Replace - Same Size	VI
5008561	K11376	05/04/2015	13:12	05/04/2015	14:18	1	65	65	Overhead equipment				V
151245552	M47816	05/04/2015	13:24	05/04/2015	15:25	1	121	120	Overhead equipment	Overhead Transformer	Repair	Repair	V
5008569	Q21321	05/04/2015	13:31	05/04/2015	16:32	3	540	180	Underground equipment	Underground Primary	Switch/Reset	Repair	VI
151245717	310124	05/04/2015	13:35	05/04/2015	14:20	38	1710	45	Tree related-tree broken	Tree	Trim		V
5008583	J83140	05/04/2015	13:36	05/04/2015	18:46	18	5568	309	Other	Pole	Repair	Replace - Same Size	VI
5008577	K08909	05/04/2015	14:00	05/04/2015	18:54	1	294	293	Animal related	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
151245773	Q71846	05/04/2015	14:00	05/04/2015	17:44	1	224	223	Other	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	V
151245838	S22595	05/04/2015	14:09	05/04/2015	14:58	1	49	49	Overhead equipment				VI
151245962	L68115	05/04/2015	14:31	05/04/2015	15:57	1	86	85	Tree related-tree contact	Customer Equipment			IV
151246092	R09226	05/04/2015	14:59	05/04/2015	16:30	1	91	91	Unknown	Fuse			III
151246143	S60581	05/04/2015	15:07	05/04/2015	16:29	1	82	81	Overhead equipment	Disconnect Switch	Repair		VI
5008585	M42107	05/04/2015	15:19	05/04/2015	17:39	8	1119	139	Overhead equipment	Overhead Transformer		Replace - Same Size	I
5008587	M36185	05/04/2015	15:24	05/04/2015	16:25	1	60	60	Tree related-tree broken	Overhead Service	Repair		I
5008601	X19561	05/04/2015	16:07	05/04/2015	18:02	106	12168	114	Overhead equipment	Fuse	Replace - Same Size		IV
151246555	P73157	05/04/2015	16:32	05/04/2015	19:37	130	24050	185	Overhead equipment	Jumper		Replace - Same Size	VI

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5008625	A85001	05/04/2015	16:53	05/04/2015	18:50	5	584	116	Tree related-tree contact	Overhead Secondary		Repair	I
151246586	B73002	05/04/2015	16:57	05/04/2015	19:04	1	127	126	Overhead equipment	Disconnect Switch	Replace - Same Size		I
151246697	P62138	05/04/2015	16:58	05/04/2015	17:57	2	118	59	Animal related	Fuse	Replace - Same Size		VI
151246642	C36001	05/04/2015	17:19	05/04/2015	18:46	1	87	87	Animal related	Transformer Fuse	Replace - Same Size		III
151247405	U29001	05/04/2015	17:24	05/04/2015	21:41	97	24929	256	Unknown	Substation Breaker	Switch/Reset		II
151247406	U29001	05/04/2015	17:24	05/04/2015	22:13	76	21964	288	Unknown	Substation Breaker	Switch/Reset	Patrol/Test/Inspect	II
151246729	U29001	05/04/2015	17:24	05/04/2015	21:27	199	48357	243	Unknown	Substation Breaker	Switch/Reset		II
5008633	X19561	05/04/2015	18:28	05/04/2015	18:48	4	79	19	Overhead equipment	Fuse	Replace - Same Size		IV
151246934	L79159	05/04/2015	18:32	05/04/2015	21:08	88	13728	156	Tree related-tree broken	Overhead Primary	Repair		IV
5008635	X19561	05/04/2015	19:08	05/04/2015	23:18	4	999	249	Underground equipment	Underground Transformer	Replace - Same Size	Replace - Same Size	IV
151247248	P05825	05/04/2015	19:11	05/04/2015	20:08	1	57	56	Animal related	Transformer Fuse	Replace - Same Size		V
5008637	K01239	05/04/2015	19:16	05/04/2015	19:49	21	673	32	Overhead equipment	Fuse	Replace - Same Size		VI
151247305	N95823	05/04/2015	19:23	05/04/2015	20:40	2	154	76	Tree related-tree contact	Tree	Trim		V
151247323	T05539	05/04/2015	19:37	05/05/2015	3:21	1	464	463	Overhead equipment	Overhead Transformer	Repair	Replace - Same Size	VI
5008647	P83710	05/04/2015	20:11	05/05/2015	3:15	1	423	423	Underground equipment	Underground Service	Repair	Repair	I
5008649	G10002	05/04/2015	21:08	05/05/2015	0:01	15	2582	172	Overhead equipment	Fuse		Repair	I
151247417	B68002	05/04/2015	21:44	05/05/2015	3:14	2	660	330	Weather	Overhead Primary			III
151247420	B68003	05/04/2015	21:55	05/05/2015	1:30	12	2580	214	Overhead equipment	Fuse	Replace - Same Size		III
151247421	U97520	05/04/2015	21:56	05/04/2015	22:45	1	49	48	Overhead equipment	Disconnect Switch	Replace - Same Size	Replace - Same Size	II
151247429	D31017	05/04/2015	22:01	05/05/2015	1:10	29	5481	188	Weather	Overhead Primary			III
151247434	D31017	05/04/2015	22:05	05/05/2015	2:01	30	7080	235	Weather	Fuse	Replace - Same Size		III
151247440	D90002	05/04/2015	22:16	05/05/2015	5:40	15	6660	444	Overhead equipment	Overhead Primary			III
5008655	H14343	05/04/2015	23:05	05/05/2015	0:25	1	79	79	Animal related	Fuse	Replace - Same Size		V
5008657	Q70161	05/04/2015	23:41	05/05/2015	5:02	1	320	320	Animal related	Fuse	Replace - Same Size		I
5008659	J08205	05/04/2015	23:44	05/05/2015	1:31	1	106	106	Unknown	Fuse	Replace - Same Size	Replace - Same Size	I
5008661	J08205	05/04/2015	23:49	05/05/2015	1:27	1	97	97	Unknown	Fuse	Replace - Same Size	Replace - Same Size	I
5008663	J08205	05/04/2015	23:55	05/05/2015	1:09	7	521	74	Unknown	Fuse	Replace - Same Size		I
5008665	Q91175	05/05/2015	0:01	05/05/2015	5:30	1	328	328	Overhead equipment	Overhead Transformer	Replace - Same Size	Replace - Same Size	I
5008667	J08205	05/05/2015	0:08	05/05/2015	2:47	1	158	158	Weather	Transformer Fuse	Replace - Same Size		I
5008669	J08205	05/05/2015	0:18	05/05/2015	3:16	1	177	177	Weather	Fuse	Replace - Same Size		I
5008671	J06167	05/05/2015	0:24	05/05/2015	3:10	1	165	165	Weather	Pole	Repair		I
5008673	J06167	05/05/2015	0:29	05/05/2015	3:10	1	160	160	Weather	Pole	Patrol/Test/Inspect	Replace - Same Size	I
5008721	N70330	05/05/2015	1:07	05/05/2015	5:05	1540	366520	238	Weather	Jumper	Reconnect		I
5008691	P49180	05/05/2015	1:10	05/05/2015	10:52	3	1745	581	Overhead equipment	Pole	Patrol/Test/Inspect	Patrol/Test/Inspect	I
151250439	V99562	05/05/2015	3:03	05/05/2015	5:00	1	117	117	Weather	Transformer Fuse	Replace - Same Size		II
151253263	L17102	05/05/2015	4:53	05/05/2015	10:00	1	307	306	Tree related-tree contact	Overhead Service			III
5008733	X77001	05/05/2015	5:12	05/05/2015	6:20	4	271	67	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
151253278	B68002	05/05/2015	5:37	05/05/2015	7:40	1	123	123	Overhead equipment	Overhead Transformer			III
5008743	R50910	05/05/2015	6:15	05/05/2015	7:30	1	75	75	Weather	Transformer Fuse	Replace - Same Size		I
5008745	N70332	05/05/2015	6:21	05/05/2015	7:11	1	49	49	Weather	Fuse	Replace - Same Size		I
5008747	Y07576	05/05/2015	6:32	05/05/2015	8:00	4	351	87	Animal related	Transformer Fuse	Repair	Replace - Same Size	IV
151253312	U95003	05/05/2015	6:37	05/05/2015	8:17	1	100	100	Overhead equipment	Fuse			II
5008749	P47125	05/05/2015	6:47	05/05/2015	8:42	1	115	115	Unknown	Fuse	Repair	Replace - Same Size	I
151253371	B65003	05/05/2015	6:48	05/05/2015	7:34	1237	56902	46	Animal related	Overhead Primary			I
5008751	Q93522	05/05/2015	7:02	05/05/2015	9:18	1	135	135	Weather	Fuse	Repair		I
5008753	Q93522	05/05/2015	7:05	05/05/2015	9:18	1	132	132	Weather	Fuse	Repair		I
5008755	J20931	05/05/2015	7:07	05/05/2015	7:52	1	45	45	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	VI
5008757	J07135	05/05/2015	7:07	05/05/2015	8:33	1	85	85	Unknown	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	I
5008759	M37192	05/05/2015	7:07	05/05/2015	8:39	1	91	91	Overhead equipment	Overhead Service	Repair	Tie/Tighten	I
5008763	X75571	05/05/2015	7:13	05/05/2015	9:17	1	123	123	Weather	Fuse	Replace - Same Size		IV
151253610	S15558	05/05/2015	7:15	05/05/2015	8:30	13	975	74	Overhead equipment	Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
5008765	J20931	05/05/2015	7:19	05/05/2015	7:52	1	32	32	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	VI
151253444	S47576	05/05/2015	7:30	05/05/2015	8:20	1	50	49	Animal related	Transformer Fuse	Replace - Same Size	Replace - Same Size	VI
151253454	L08226	05/05/2015	7:35	05/05/2015	10:00	1	145	145	Overhead equipment	Overhead Transformer		Repair	III
5008771	X77543	05/05/2015	7:37	05/05/2015	8:08	4	123	30	Weather	Transformer Fuse	Replace - Same Size		IV
5008779	G10002	05/05/2015	8:05	05/05/2015	9:08	4	250	62	Overhead equipment	Disconnect Switch	Replace - Same Size		I

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
151253573	B65001	05/05/2015	8:13	05/05/2015	8:57	1	44	43	Animal related	Other	Replace - Same Size		I
5008785	P26283	05/05/2015	8:14	05/05/2015	10:15	6	725	120	Weather	Fuse	Patrol/Test/Inspect	Repair	I
151253283	D70004	05/05/2015	8:33	05/05/2015	14:12	1	339	339	Overhead equipment	Pole	Replace - Same Size	Repair	I
5008797	N60172	05/05/2015	8:45	05/05/2015	14:42	54	19272	356	Underground equipment	Underground Primary	Replace - Urgent	Switch/Reset	I
151253725	U37579	05/05/2015	8:48	05/05/2015	9:58	1	70	69	Underground equipment	Underground Service	Replace - Same Size	Replace - Same Size	II
151253760	L95110	05/05/2015	8:54	05/05/2015	10:13	28	2212	78	Underground equipment	Underground Primary		Repair	III
151253757	K65220	05/05/2015	8:55	05/05/2015	9:30	44	1540	34	Public				III
5008803	J08206	05/05/2015	8:55	05/05/2015	10:58	1	122	122	Weather	Transformer Fuse	Replace - Same Size		I
151253869	B82002	05/05/2015	9:18	05/05/2015	10:50	1	92	92	Overhead equipment	Lightning Arrestor	Repair		I
151253973	A73002	05/05/2015	9:44	05/05/2015	12:28	1	164	164	Other	Connector	Repair		I
151254131	K30205	05/05/2015	10:13	05/05/2015	11:02	1	49	49	Overhead equipment	Fuse	Replace - Same Size		III
5008815	Y98518	05/05/2015	10:16	05/05/2015	11:00	1	43	43	Animal related	Other	Repair	Repair	IV
151254192	J61112	05/05/2015	10:25	05/05/2015	10:58	1	33	32	Other	Overhead Service			III
151254232	C36002	05/05/2015	10:32	05/05/2015	11:37	1	65	65	Animal related	Transformer Fuse	Repair	Replace - Same Size	III
151254510	B38002	05/05/2015	10:51	05/05/2015	13:24	35	5355	153	Animal related	Recloser	Replace - Same Size	Repair	I
5008831	X77002	05/05/2015	10:54	05/05/2015	17:41	1	407	407	Overhead equipment	Underground Transformer	Disconnect		IV
5008837	M41111	05/05/2015	11:37	05/05/2015	14:25	1	167	167	Unknown	Transformer Fuse	Replace - Same Size	Patrol/Test/Inspect	I
5008841	M41111	05/05/2015	11:49	05/05/2015	15:25	1	215	215	Overhead equipment	Overhead Transformer	Replace - Same Size	Replace - Urgent	I
5008843	Z17522	05/05/2015	12:09	05/05/2015	15:13	1	183	183	Underground equipment	Underground Transformer	Replace - Same Size	Replace - Same Size	IV
151254811	U73599	05/05/2015	12:42	05/05/2015	13:20	2	76	37	Unknown	Transformer Fuse	Replace - Same Size		II
5008847	Y54587	05/05/2015	12:52	05/05/2015	13:50	1	57	57	Overhead equipment	Overhead Secondary	Repair		IV
151255058	Q71846	05/05/2015	13:28	05/05/2015	16:44	1	196	195	Public	Overhead Service	Replace - Same Size		V
151255074	S27599	05/05/2015	13:31	05/05/2015	14:06	1	35	34	Tree related-tree contact	Overhead Service			VI
5008865	N05172	05/05/2015	13:58	05/05/2015	15:30	1	91	91	Overhead equipment	Pole	Repair	Repair	I
151255251	K65220	05/05/2015	14:08	05/05/2015	14:51	1	43	43	Overhead equipment				III
151255298	308003	05/05/2015	14:22	05/05/2015	15:02	1	40	39	Overhead equipment	Other	Patrol/Test/Inspect		VI
5008873	A97006	05/05/2015	14:30	05/05/2015	16:35	1	124	124	Animal related	Fuse	Replace - Same Size		I
5008875	N05172	05/05/2015	14:32	05/05/2015	19:15	1	282	282	Overhead equipment	Pole	Repair	Repair	I
5008883	N86225	05/05/2015	14:47	05/05/2015	15:55	1	67	67	Animal related	Overhead Service	Repair		VI
5008887	N60172	05/05/2015	15:00	05/05/2015	15:08	1	7	7	Underground equipment	Underground Service		Repair	I
151256044	B19001	05/05/2015	15:37	05/05/2015	19:53	5	1280	256	Overhead equipment	Overhead Transformer		Repair	I
5008897	X82576	05/05/2015	16:09	05/05/2015	18:06	6	700	116	Overhead equipment	Disconnect Switch		Install	IV
151255815	P71830	05/05/2015	16:18	05/05/2015	19:55	2	434	216	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	V
151255828	R01153	05/05/2015	16:24	05/05/2015	16:47	1	23	23	Animal related	Fuse			III
5008901	Z21564	05/05/2015	16:32	05/05/2015	17:33	1	60	60	Animal related	Transformer Fuse	Repair	Replace - Same Size	IV
151255868	V41568	05/05/2015	16:34	05/05/2015	19:56	5	1010	201	Tree related-tree contact	Overhead Primary			II
151255957	T09558	05/05/2015	17:01	05/05/2015	18:10	1	69	69	Other				VI
5008911	R93351	05/05/2015	17:01	05/05/2015	21:53	1	291	291	Overhead equipment	Pole	Cut in Clear	Remove	V
151256184	U66515	05/05/2015	17:09	05/05/2015	20:00	45	7695	171	Public	Fuse	Patrol/Test/Inspect	Patrol/Test/Inspect	II
5008913	B93002	05/05/2015	17:13	05/05/2015	22:32	1	318	318	Overhead equipment	Disconnect Switch	Patrol/Test/Inspect	Replace - Same Size	I
151256072	T17581	05/05/2015	17:44	05/05/2015	19:38	1	114	114	Overhead equipment	Jumper	Repair	Replace - Same Size	VI
151256124	U99515	05/05/2015	17:59	05/05/2015	19:35	1	96	95	Animal related	Transformer Fuse	Repair		II
151256181	U66515	05/05/2015	18:40	05/05/2015	20:00	1	80	79	Public				II
151256301	T28561	05/05/2015	19:08	05/06/2015	1:08	33	11880	360	Overhead equipment	Overhead Primary			VI
5008925	A81002	05/05/2015	20:25	05/06/2015	7:50	16	10964	685	Underground equipment	Underground Primary	Repair	Repair	I
151256499	T17581	05/05/2015	20:31	05/05/2015	21:45	1	74	74	Overhead equipment	Connector	Repair	Replace - Same Size	VI
151256522	N44216	05/05/2015	21:32	05/06/2015	1:12	1	220	220	Underground equipment	Underground Service			III
5008931	R94269	05/05/2015	21:57	05/06/2015	0:06	1	128	128	Overhead equipment	Transformer Fuse	Replace - Same Size		VI
5008935	Q70161	05/05/2015	22:27	05/06/2015	1:05	1	157	157	Overhead equipment	Transformer Fuse	Replace - Same Size		I
5008937	J07135	05/05/2015	22:28	05/05/2015	23:20	24	1239	51	Public	Fuse	Replace - Same Size		I
151256549	M18131	05/05/2015	22:33	05/06/2015	3:20	1	287	287	Underground equipment	Underground Primary	Repair		III
151256561	H01194	05/05/2015	22:52	05/06/2015	1:00	1	128	127	Overhead equipment	Connector	Replace - Same Size		III
151260125	C37001	05/06/2015	0:15	05/06/2015	2:21	1	126	126	Overhead equipment	Disconnect Switch	Replace - Same Size		III
151260230	S56730	05/06/2015	2:02	05/06/2015	2:10	792	6336	8	Transmission outage				VI
151260231	S56736	05/06/2015	2:02	05/06/2015	2:10	1752	14016	8	Transmission outage				VI
5008951	A81002	05/06/2015	2:09	05/06/2015	5:35	2	411	205	Underground equipment				I

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
151260225	B71001	05/06/2015	2:14	05/06/2015	3:19	1	65	65	Overhead equipment	Connector	Replace - Same Size		I
151260229	U62521	05/06/2015	2:17	05/06/2015	3:49	4	368	92	Unknown	Transformer Fuse	Repair		II
5008971	Y66556	05/06/2015	3:52	05/06/2015	4:56	295	18723	63	Underground equipment	Underground Primary	Repair		IV
151263088	N44217	05/06/2015	5:27	05/06/2015	6:40	1	73	73	Overhead equipment	Transformer Fuse	Repair	Repair	III
5008977	A81004	05/06/2015	5:56	05/06/2015	7:55	1	118	118	Underground equipment				I
5008979	J83140	05/06/2015	6:22	05/06/2015	7:29	1	66	66	Overhead equipment	Overhead Service			VI
5008981	Q34360	05/06/2015	6:43	05/06/2015	7:59	1	75	75	Overhead equipment	Connector	Replace - Same Size		I
151263133	P69173	05/06/2015	6:48	05/06/2015	7:42	27	1458	53	Animal related	Fuse	Repair		III
151263154	V20502	05/06/2015	7:03	05/06/2015	7:48	1	45	45	Animal related	Transformer Fuse			II
151263182	L00133	05/06/2015	7:18	05/06/2015	8:21	1	63	62	Animal related	Fuse	Replace - Same Size		III
5008983	Y37593	05/06/2015	7:24	05/06/2015	7:55	3	92	30	Animal related	Transformer Fuse			IV
151263206	L79159	05/06/2015	7:28	05/06/2015	8:48	1	80	79	Animal related	Transformer Fuse	Replace - Same Size		IV
151263257	A91002	05/06/2015	7:48	05/06/2015	12:38	1	290	290	Underground equipment	Underground Transformer	Patrol/Test/Inspect	Replace - Same Size	I
5008985	T41556	05/06/2015	7:54	05/06/2015	10:50	1	175	175	Overhead equipment	Fuse	Replace - Same Size		IV
151263301	K39153	05/06/2015	8:05	05/06/2015	9:04	1	59	59	Animal related	Transformer Fuse	Repair		III
5008987	R10943	05/06/2015	8:30	05/06/2015	9:53	1	82	82	Overhead equipment	Connector	Repair		VI
151263475	V42572	05/06/2015	8:52	05/06/2015	10:10	1	78	78	Animal related	Transformer Fuse	Replace - Same Size		II
151263490	S08548	05/06/2015	8:53	05/06/2015	10:16	1	83	82	Overhead equipment	Transformer Fuse			VI
151263595	U37579	05/06/2015	9:15	05/06/2015	13:59	1	284	284	Underground equipment	Underground Service	Repair		II
151263771	T15570	05/06/2015	9:48	05/06/2015	10:42	1	54	53	Overhead equipment	Overhead Service	Repair	Repair	VI
5009007	J13108	05/06/2015	9:50	05/06/2015	11:30	1	99	99	Overhead equipment	Disconnect Switch	Replace - Same Size	Reconnect	I
5009017	X09557	05/06/2015	10:14	05/06/2015	11:48	1	93	93	Other	Overhead Service	Patrol/Test/Inspect	Repair	IV
151263924	B00004	05/06/2015	10:17	05/06/2015	10:41	6	144	24	Animal related	Other	Replace - Same Size		I
151264185	R73841	05/06/2015	11:05	05/06/2015	11:24	135	2565	18	Jurisdictional	Overhead Primary			V
5009031	M78325	05/06/2015	11:21	05/06/2015	12:45	56	4664	83	Animal related	Fuse	Replace - Same Size		V
151264335	D66001	05/06/2015	11:39	05/06/2015	12:30	1	51	50	Animal related	Transformer Fuse	Replace - Same Size		IV
151264374	C66002	05/06/2015	11:48	05/06/2015	13:39	1	111	110	Overhead equipment	Customer Equipment			III
5009041	A85001	05/06/2015	11:50	05/06/2015	19:01	3	1290	430	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
5009045	M78325	05/06/2015	11:58	05/06/2015	13:01	1	62	62	Overhead equipment				V
151264514	N50331	05/06/2015	12:09	05/06/2015	13:19	623	43610	69	Public	Recloser	Patrol/Test/Inspect		II
151264521	V82551	05/06/2015	12:21	05/06/2015	13:50	1	89	89	Overhead equipment	Fuse			II
5009049	L62927	05/06/2015	12:24	05/06/2015	13:18	1	53	53	Public	Overhead Service	Cut in Clear		VI
151264584	K28180	05/06/2015	12:36	05/06/2015	13:27	1	51	50	Other	Meter	Reconnect		III
5009051	R50910	05/06/2015	12:39	05/06/2015	14:34	1	114	114	Animal related	Fuse	Replace - Same Size		I
5009053	Q91175	05/06/2015	12:41	05/06/2015	13:16	1	35	34	Weather	Transformer Fuse	Replace - Same Size	Replace - Same Size	I
151264850	K95202	05/06/2015	13:24	05/06/2015	13:55	1	31	30	Other	Other			III
151265316	T06504	05/06/2015	13:46	05/06/2015	15:00	196	14504	74	Overhead equipment				VI
5009065	R50910	05/06/2015	13:58	05/06/2015	14:48	12	594	49	Animal related	Fuse	Replace - Same Size		I
5009101	Q95247	05/06/2015	14:27	05/06/2015	19:08	1	280	280	Overhead equipment	Ground Wire			VI
151265302	L79157	05/06/2015	14:56	05/06/2015	20:00	1	304	304	Underground equipment	Underground Service	Repair		IV
151265431	D41003	05/06/2015	15:31	05/06/2015	17:10	1	99	99	Unknown	Fuse	Replace - Same Size		I
151265480	U52516	05/06/2015	15:39	05/06/2015	20:01	4	1048	261	Overhead equipment	Pole	Replace - Same Size	Repair	II
151265457	U52516	05/06/2015	15:39	05/06/2015	17:00	18	1458	81	Overhead equipment	Pole	Repair	Repair	II
5009097	J34377	05/06/2015	16:37	05/06/2015	18:25	1	107	107	Intentional				V
5009099	Y32002	05/06/2015	16:43	05/06/2015	17:56	1	72	72	Tree related-tree broken	Overhead Service	Repair	Replace - Same Size	IV
151265692	V20512	05/06/2015	16:46	05/06/2015	19:19	1	153	152	Tree related-tree contact	Overhead Service			II
151265742	K82202	05/06/2015	17:03	05/06/2015	17:53	1	50	49	Overhead equipment	Fuse			III
151265773	V61563	05/06/2015	17:16	05/06/2015	20:02	1	166	165	Weather	Fuse	Replace - Same Size		II
151265891	S01501	05/06/2015	17:42	05/06/2015	17:53	591	6501	10	Unknown				VI
5009103	N05172	05/06/2015	17:45	05/06/2015	19:24	1	98	98	Other	Customer Equipment			I
151265912	337003	05/06/2015	17:58	05/06/2015	18:44	6	276	45	Tree related-tree broken	Fuse	Replace - Same Size		VI
151265999	S01501	05/06/2015	18:09	05/11/2015	8:46	1	6637	6636	Underground equipment	Underground Primary			VI
151266079	D36002	05/06/2015	18:34	05/06/2015	22:50	37	9472	256	Tree related-tree broken	Overhead Primary	Repair	Repair	I
151266089	T06504	05/06/2015	18:34	05/06/2015	23:59	60	19500	325	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	VI
151266126	D72003	05/06/2015	19:06	05/07/2015	2:38	1	452	452	Underground equipment	Underground Primary	Patrol/Test/Inspect	Patrol/Test/Inspect	I
5009115	R07382	05/06/2015	19:07	05/07/2015	1:50	1	402	402	Underground equipment	Underground Service	Repair	Repair	I

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
151266383	S09520	05/06/2015	19:14	05/06/2015	20:45	10	910	91	Overhead equipment	Jumper	Repair	Repair	VI
5009119	M05360	05/06/2015	20:20	05/07/2015	6:40	1	619	619	Overhead equipment	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	V
5009123	Q82906	05/06/2015	20:33	05/06/2015	23:13	1	159	159	Animal related	Lightning Arrestor			VI
151266420	J67134	05/06/2015	20:39	05/06/2015	21:05	1	26	25	Overhead equipment	Connector			III
5009125	X57545	05/06/2015	21:22	05/06/2015	22:30	1	67	67	Animal related	Fuse	Replace - Same Size		IV
151266463	V39001	05/06/2015	21:28	05/06/2015	23:43	33	4455	135	Tree related-tree broken	Overhead Primary	Trim	Repair	II
151266464	U90572	05/06/2015	21:42	05/06/2015	22:30	1	48	47	Overhead equipment	Transformer Fuse	Repair	Repair	II
151266484	D55001	05/06/2015	23:48	05/07/2015	1:21	1	93	92	Unknown				I
151266485	A91003	05/06/2015	23:49	05/07/2015	4:35	1	286	285	Unknown				I
151266487	B00008	05/06/2015	23:50	05/07/2015	6:15	1	385	384	Overhead equipment	Overhead Primary	Repair	Repair	I
151270117	T06504	05/07/2015	0:21	05/07/2015	1:40	1	79	79	Other				VI
151271367	337003	05/07/2015	2:46	05/07/2015	4:49	6	738	123	Overhead equipment	Overhead Primary	Raise		VI
5009133	Y34596	05/07/2015	3:09	05/07/2015	4:11	1	61	61	Animal related	Transformer Fuse	Replace - Same Size		IV
5009135	Z10500	05/07/2015	3:54	05/07/2015	4:40	1	45	45	Tree related-tree broken	Transformer Fuse			IV
151272761	N18211	05/07/2015	5:19	05/07/2015	6:59	1	100	100	Animal related	Transformer Fuse	Replace - Same Size		III
5009141	A68001	05/07/2015	5:55	05/07/2015	6:51	1	55	55	Unknown	Fuse	Patrol/Test/Inspect	Replace - Same Size	I
5009143	P26280	05/07/2015	6:06	05/07/2015	9:25	1	198	198	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Repair	I
5009145	Y51506	05/07/2015	6:08	05/07/2015	7:54	18	1909	106	Animal related	Fuse	Replace - Same Size		IV
151272842	L17102	05/07/2015	7:05	05/07/2015	8:12	1	67	66	Animal related	Transformer Fuse	Replace - Same Size		III
5009149	K52400	05/07/2015	7:07	05/07/2015	7:54	1	46	46	Animal related	Fuse	Replace - Same Size	Replace - Same Size	V
5009151	K11373	05/07/2015	7:22	05/07/2015	8:27	8	518	64	Animal related	Fuse	Replace - Same Size		V
151272936	V41533	05/07/2015	7:40	05/07/2015	8:40	26	1560	59	Animal related	Fuse			II
151273062	J47178	05/07/2015	7:41	05/07/2015	8:20	10	390	38	Animal related	Fuse	Repair	Repair	III
151273009	J47178	05/07/2015	8:02	05/07/2015	8:23	1	21	21	Animal related	Fuse	Repair	Repair	III
5009173	D48001	05/07/2015	8:11	05/07/2015	10:05	94	10652	113	Animal related	Fuse	Replace - Same Size		I
5009175	X91510	05/07/2015	8:17	05/07/2015	9:37	1	79	79	Overhead equipment	Transformer Fuse	Repair	Replace - Same Size	IV
5009183	R04407	05/07/2015	8:23	05/07/2015	11:22	44	7826	178	Underground equipment	Underground Primary	Disconnect		V
5009187	R04407	05/07/2015	9:01	05/07/2015	9:50	47	2328	49	Underground equipment				V
5009189	J86108	05/07/2015	9:02	05/07/2015	9:45	3	128	42	Animal related	Transformer Fuse			VI
151273277	V74513	05/07/2015	9:10	05/07/2015	9:36	1	26	26	Animal related	Transformer Fuse	Replace - Same Size		II
151273330		05/07/2015	9:25	05/07/2015	10:15	1	50	50	Overhead equipment	Overhead Service	Repair		III
151273375	U35554	05/07/2015	9:33	05/07/2015	9:52	1	19	18	Animal related	Transformer Fuse	Replace - Same Size		II
5009217	R68900	05/07/2015	10:26	05/07/2015	11:36	1	69	69	Animal related	Fuse	Replace - Same Size		I
151273676	D90004	05/07/2015	10:35	05/07/2015	11:55	1	80	80	Other	Overhead Service	Tie/Tighten	Patrol/Test/Inspect	III
5009223	D53001	05/07/2015	10:36	05/07/2015	11:26	1	49	49	Animal related	Fuse	Replace - Same Size		I
151273755	Q71846	05/07/2015	10:37	05/07/2015	11:35	388	22504	58	Public	Pole			V
5009229	M36184	05/07/2015	10:59	05/07/2015	12:00	9	548	60	Jurisdictional	Transformer Fuse	Replace - Same Size		I
151273978	U99515	05/07/2015	11:04	05/07/2015	11:55	85	4335	51	Public	Fuse	Replace - Same Size		II
5009233	Q11517	05/07/2015	11:06	05/07/2015	12:07	1	60	60	Animal related	Fuse	Replace - Same Size		I
151274015	351001	05/07/2015	11:37	05/07/2015	12:14	1	37	37	Public	Meter	Repair		VI
151274092	V95586	05/07/2015	11:52	05/07/2015	13:15	1	83	83	Animal related	Transformer Fuse	Repair		II
151274169	B27009	05/07/2015	12:13	05/07/2015	12:24	1	11	11	Tree related-tree contact	Other	Patrol/Test/Inspect		I
151274223	J12166	05/07/2015	12:20	05/07/2015	14:10	13	1430	110	Animal related	Transformer Fuse	Repair		III
151274199	R59417	05/07/2015	12:21	05/07/2015	14:35	1	134	134	Jurisdictional	Overhead Service			IV
5009263	Q14390	05/07/2015	13:05	05/07/2015	14:07	4	247	61	Underground equipment	Underground Primary	Repair		I
151274491	K73361	05/07/2015	13:17	05/07/2015	16:20	1	183	182	Tree related-tree contact	Overhead Secondary	Patrol/Test/Inspect	Repair	IV
5009269	J99127	05/07/2015	13:19	05/07/2015	13:46	1	26	26	Animal related	Transformer Fuse			VI
151274566	P62112	05/07/2015	13:33	05/07/2015	14:37	1	64	63	Other	Connector	Repair		VI
5009275	X49568	05/07/2015	13:39	05/07/2015	15:18	1	98	98	Public	Overhead Service	Repair		IV
5009287	J01118	05/07/2015	13:50	05/07/2015	15:26	6	575	95	Overhead equipment	Fuse	Repair	Replace - Same Size	I
151274657	P62138	05/07/2015	13:52	05/07/2015	15:02	1	70	69	Overhead equipment	Overhead Service			VI
5009289	N60181	05/07/2015	14:02	05/07/2015	16:19	1	136	136	Unknown	Fuse	Repair	Replace - Same Size	I
5009295	R49275	05/07/2015	14:25	05/08/2015	4:45	1	859	859	Underground equipment	Underground Service	Patrol/Test/Inspect	Repair	VI
151274842	R06209	05/07/2015	14:32	05/07/2015	15:16	11	484	43	Unknown	Fuse	Replace - Same Size		II
5009297	J01118	05/07/2015	14:32	05/07/2015	15:30	1	57	57	Unknown	Fuse	Repair	Replace - Same Size	I
151274879	D72003	05/07/2015	14:41	05/07/2015	15:41	1	60	59	Underground equipment	Meter	Patrol/Test/Inspect		I

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
151274936	C52001	05/07/2015	14:42	05/07/2015	15:03	366	7686	20	Overhead equipment	Overhead Primary	Switch/Reset		III
5009307	A85001	05/07/2015	14:56	05/07/2015	15:39	1	42	42	Weather	Fuse	Replace - Same Size		I
5009311	D28123	05/07/2015	15:31	05/07/2015	17:10	1	98	98	Overhead equipment	Connector	Repair		I
5009317	J71128	05/07/2015	16:04	05/07/2015	21:18	1	313	313	Tree related-tree broken	Overhead Transformer	Repair	Replace - Same Size	I
5009321	J71128	05/07/2015	16:12	05/07/2015	21:32	1	319	319	Tree related-tree broken	Overhead Service			I
5009385	J71128	05/07/2015	16:17	05/07/2015	20:17	189	45322	239	Tree related-tree broken	Overhead Primary	Repair	Replace - Same Size	I
151275289	J56341	05/07/2015	16:23	05/07/2015	17:43	7	560	79	Animal related	Fuse			III
151275390	M09144	05/07/2015	16:34	05/07/2015	17:35	17	1037	60	Animal related	Fuse	Replace - Same Size		VI
5009337	J71128	05/07/2015	16:54	05/07/2015	20:58	1	243	243	Tree related-tree broken	Overhead Service	Repair	Replace - Same Size	I
151275504	S19553	05/07/2015	16:59	05/07/2015	18:30	156	14196	91	Overhead equipment				VI
151275507	U92593	05/07/2015	17:04	05/07/2015	18:15	95	6745	71	Weather	Fuse	Replace - Same Size		II
151275473	S19552	05/07/2015	17:13	05/07/2015	19:26	1	133	132	Overhead equipment	Substation Misc.		Repair	VI
5009343	J07135	05/07/2015	17:15	05/07/2015	19:05	2	218	109	Unknown	Fuse	Replace - Same Size		I
5009371	X64501	05/07/2015	17:19	05/07/2015	18:14	87	4851	55	Other	Recloser			IV
151275518	R58961	05/07/2015	17:29	05/07/2015	18:06	1	37	36	Jurisdictional				IV
5009365	Y11555	05/07/2015	17:33	05/07/2015	19:15	11	1117	101	Overhead equipment	Transformer Fuse	Repair	Replace - Same Size	IV
5009373	J71128	05/07/2015	17:38	05/07/2015	18:02	50	1191	23	Overhead equipment				I
5009383	B93003	05/07/2015	18:09	05/07/2015	19:20	1	70	70	Animal related	Transformer Fuse	Replace - Same Size		I
151275623	U68581	05/07/2015	18:14	05/07/2015	22:08	4	936	233	Weather	Fuse	Replace - Same Size		II
5009393	B57001	05/07/2015	18:19	05/07/2015	22:35	65	16660	256	Overhead equipment				I
151275634	A91002	05/07/2015	18:20	05/07/2015	19:12	1	52	52	Weather	Fuse	Replace - Same Size		I
5009395	R16511	05/07/2015	18:31	05/08/2015	0:07	1	335	335	Tree related-tree contact	Overhead Secondary	Repair		I
5009397	R16510	05/07/2015	18:34	05/07/2015	20:14	1	99	99	Other	Overhead Primary			I
151275685	N35851	05/07/2015	18:47	05/07/2015	20:44	21	2457	117	Tree related-tree broken	Overhead Primary	Repair	Patrol/Test/Inspect	V
151276175	U31598	05/07/2015	18:56	05/08/2015	4:30	18	10332	573	Underground equipment	Underground Primary	Replace - Same Size		II
151275849	U31598	05/07/2015	18:56	05/07/2015	21:40	15	2460	164	Underground equipment	Underground Primary	Repair	Repair	II
151275871	M07236	05/07/2015	19:01	05/07/2015	20:19	50	3900	78	Overhead equipment	Overhead Transformer	Switch/Reset		III
5009407	R50910	05/07/2015	19:33	05/07/2015	21:43	5	648	129	Weather	Fuse	Repair	Repair	I
5009411	R50910	05/07/2015	19:39	05/07/2015	21:43	1	123	123	Weather	Fuse	Repair	Repair	I
5009413	R16511	05/07/2015	19:54	05/08/2015	0:07	1	252	252	Tree related-tree contact	Overhead Secondary	Repair		I
151276107	C36001	05/07/2015	20:20	05/07/2015	21:50	1	90	90	Overhead equipment	Disconnect Switch	Repair	Replace - Same Size	III
5009415	J07135	05/07/2015	20:20	05/08/2015	0:45	1	264	264	Overhead equipment	Overhead Transformer		Replace - Same Size	I
5009417	J15303	05/07/2015	20:30	05/08/2015	3:32	657	141929	421	Overhead equipment	Pole			I
5009419	J71128	05/07/2015	21:26	05/08/2015	3:05	1	338	338	Tree related-tree broken	Overhead Secondary	Replace - New Size	Repair	I
151276229	M51275	05/07/2015	21:39	05/07/2015	23:29	740	81400	110	Transmission outage	Other			III
151276271	N93260	05/07/2015	21:39	05/07/2015	23:29	1385	152350	110	Transmission outage	Other			III
5009431	J15303	05/07/2015	21:57	05/08/2015	3:32	80	26721	334	Overhead equipment	Pole	Repair		I
151276306	C66001	05/07/2015	23:24	05/08/2015	4:52	79	25912	328	Tree related-tree broken	Overhead Primary	Cut in Clear	Cut in Clear	III
5009433	J15303	05/07/2015	23:29	05/08/2015	3:32	1	242	242	Overhead equipment	Pole	Repair		I
151276320	B00005	05/07/2015	23:34	05/08/2015	2:21	65	10855	166	Overhead equipment	Crossarm		Repair	I
5009435	A49002	05/07/2015	23:57	05/08/2015	0:12	3	43	14	Unknown	Fuse	Replace - Same Size	Replace - Same Size	I
151280122	L17102	05/08/2015	0:31	05/08/2015	1:05	1	34	34	Unknown	Transformer Fuse	Replace - Same Size		III
5009439	J15303	05/08/2015	1:27	05/08/2015	3:32	1	124	124	Overhead equipment	Pole	Repair		I
5009445	R95520	05/08/2015	3:08	05/08/2015	5:21	56	7396	132	Overhead equipment	Pole	Patrol/Test/Inspect	Repair	I
5009447	J15303	05/08/2015	3:26	05/08/2015	3:33	1	6	6	Overhead equipment	Pole	Repair		I
5009449	J15303	05/08/2015	3:29	05/08/2015	3:32	1	2	2	Overhead equipment	Pole	Repair		I
5009451	J15303	05/08/2015	4:59	05/08/2015	7:39	1	159	159	Overhead equipment	Recloser	Replace - Same Size		I
151283180	J14140	05/08/2015	6:03	05/08/2015	7:46	1	103	103	Tree related-tree contact	Overhead Secondary	Replace - Same Size		VI
151283189	D41002	05/08/2015	6:10	05/08/2015	11:08	1	298	297	Underground equipment	Underground Service	Replace - Same Size	Replace - Same Size	I
5009457	J15303	05/08/2015	6:13	05/08/2015	7:41	1	87	87	Overhead equipment	Recloser	Replace - Same Size		I
151283245	D81001	05/08/2015	6:27	05/08/2015	9:53	15	3090	206	Tree related-tree broken	Overhead Service	Repair	Repair	I
151283213	S86581	05/08/2015	6:51	05/08/2015	8:37	1	106	105	Animal related	Disconnect Switch	Repair		VI
151283216	S43512	05/08/2015	6:52	05/08/2015	8:20	1	88	87	Animal related	Transformer Fuse	Repair	Replace - Same Size	VI
151283223	M09144	05/08/2015	6:59	05/08/2015	7:30	1	31	30	Animal related	Fuse	Replace - Same Size		VI
151283264	A80001	05/08/2015	7:15	05/08/2015	8:59	1	104	103	Weather	Transformer Fuse	Replace - Same Size	Replace - Same Size	I
151283288	S93553	05/08/2015	7:22	05/08/2015	8:17	1	55	55	Overhead equipment	Fuse	Replace - Same Size		VI

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5009463	R84148	05/08/2015	7:26	05/08/2015	8:27	1	60	60	Unknown	Fuse	Patrol/Test/Inspect	Replace - Same Size	I
5009465	M81403	05/08/2015	7:34	05/08/2015	10:57	1	203	203	Underground equipment	Underground Service	Patrol/Test/Inspect	Repair	V
5009467	B28004	05/08/2015	7:36	05/08/2015	10:35	1	178	178	Overhead equipment				I
151283329	D66001	05/08/2015	7:39	05/08/2015	8:15	1	36	36	Animal related	Transformer Fuse	Repair		IV
151283364	U64521	05/08/2015	7:51	05/08/2015	9:25	2	188	94	Weather	Disconnect Switch	Repair	Replace - Same Size	II
5009469	X69554	05/08/2015	7:59	05/08/2015	10:25	1	145	145	Animal related	Transformer Fuse			IV
5009471	J15303	05/08/2015	8:15	05/08/2015	10:30	1	134	134	Overhead equipment	Recloser	Replace - Same Size		I
151283569	D41003	05/08/2015	8:47	05/08/2015	10:14	26	2262	87	Tree related-tree broken	Fuse	Repair		I
5009477	P82290	05/08/2015	8:48	05/08/2015	10:05	1	76	76	Animal related	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
151283570	N44216	05/08/2015	8:51	05/08/2015	9:44	1	53	52	Overhead equipment	Fuse			III
151283628	L79159	05/08/2015	9:05	05/08/2015	10:05	5	300	60	Animal related	Transformer Fuse			IV
151283669	Q01281	05/08/2015	9:08	05/08/2015	9:40	11	352	31	Overhead equipment	Fuse			III
5009485	P47120	05/08/2015	9:40	05/08/2015	11:13	1	92	92	Unknown	Transformer Fuse			I
151283753		05/08/2015	9:41	05/08/2015	10:18	1	37	37	Animal related	Transformer Fuse	Replace - Same Size		VI
5009487	Y34596	05/08/2015	9:48	05/08/2015	10:43	1	54	54	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
151283792	K09863	05/08/2015	9:50	05/08/2015	10:47	1	57	57	Animal related	Transformer Fuse	Replace - Same Size	Repair	V
151283982	Q15845	05/08/2015	10:10	05/08/2015	10:41	146	4526	31	Unknown	Recloser	Replace - Same Size		V
5009529	J15303	05/08/2015	10:27	05/08/2015	12:09	1	101	101	Underground equipment				I
5009535	J15303	05/08/2015	10:30	05/08/2015	12:10	1	99	99	Underground equipment				I
5009499	J15303	05/08/2015	10:30	05/08/2015	12:27	1	116	116	Underground equipment				I
5009501	J15303	05/08/2015	10:31	05/08/2015	12:29	1	117	117	Underground equipment	Recloser	Replace - Same Size	Replace - Same Size	I
5009533	J15303	05/08/2015	10:32	05/08/2015	12:12	1	99	99	Underground equipment	Recloser	Replace - Same Size	Replace - Same Size	I
5009505	J15303	05/08/2015	10:32	05/08/2015	11:59	1	86	86	Underground equipment				I
5009531	J15303	05/08/2015	10:33	05/08/2015	12:48	1	134	134	Underground equipment	Underground Primary			I
5009509	J15303	05/08/2015	10:33	05/08/2015	11:59	1	85	85	Underground equipment	Recloser	Replace - Same Size	Replace - Same Size	I
5009513	J15303	05/08/2015	10:35	05/08/2015	10:40	1	4	4	Underground equipment	Underground Primary			I
5009537	J15303	05/08/2015	10:36	05/08/2015	12:10	1	93	93	Underground equipment	Underground Primary			I
151283992	328120	05/08/2015	10:37	05/08/2015	11:30	8	424	52	Tree related-tree contact	Fuse	Replace - Same Size		V
151284051	328120	05/08/2015	10:51	05/08/2015	11:25	4	136	34	Tree related-tree contact	Tree	Trim	Trim	V
151284042	T16527	05/08/2015	10:51	05/08/2015	11:55	1	64	64	Overhead equipment	Disconnect Switch	Replace - Same Size	Patrol/Test/Inspect	VI
151284068	328120	05/08/2015	10:55	05/08/2015	11:30	1	35	34	Tree related-tree contact	Fuse	Replace - Same Size		V
5009523	J15303	05/08/2015	10:57	05/08/2015	11:46	9	437	48	Underground equipment				I
151284210	L42158	05/08/2015	11:27	05/08/2015	13:30	1	123	123	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Repair	III
151284243	U68581	05/08/2015	11:36	05/08/2015	14:28	8	1376	172	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Repair	II
151284383	B65004	05/08/2015	12:19	05/08/2015	14:07	1	108	107	Overhead equipment	Overhead Service	Repair	Reconnect	I
5009543	B93003	05/08/2015	12:20	05/08/2015	19:00	1	399	399	Underground equipment	Overhead Service			I
5009545	D48003	05/08/2015	12:21	05/08/2015	13:05	1	43	43	Animal related	Transformer Fuse	Replace - Same Size		I
5009549	J71128	05/08/2015	12:25	05/08/2015	13:35	1	69	69	Tree related-tree contact	Overhead Service	Repair		I
5009553	K32932	05/08/2015	12:33	05/08/2015	14:55	1	141	141	Tree related-tree contact	Overhead Service	Repair		VI
151284465	V74513	05/08/2015	12:40	05/08/2015	13:40	4	240	59	Weather	Transformer Fuse	Repair	Repair	II
151284475	D16001	05/08/2015	12:50	05/08/2015	13:47	19	1083	57	Unknown	Fuse	Replace - Same Size		I
5009557	J15303	05/08/2015	12:53	05/08/2015	13:16	1	23	23	Underground equipment	Underground Primary			I
5009559	P83710	05/08/2015	13:03	05/08/2015	14:05	1	61	61	Overhead equipment	Overhead Secondary	Repair		I
5009571	Q24312	05/08/2015	13:04	05/08/2015	16:30	22	4530	205	Overhead equipment	Bracket		Replace - Same Size	VI
5009575	Y20522	05/08/2015	13:12	05/08/2015	14:15	20	1253	62	Overhead equipment	Fuse	Repair		IV
5009587	D88001	05/08/2015	13:14	05/08/2015	17:10	29	6827	235	Weather				I
151284641	D36002	05/08/2015	13:17	05/08/2015	16:04	47	7849	166	Unknown				I
5009569	D88001	05/08/2015	13:19	05/08/2015	17:35	1	255	255	Weather	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	I
151284645	B45005	05/08/2015	13:27	05/08/2015	15:15	390	42120	107	Animal related	Fuse	Replace - Same Size		I
5009573	B93002	05/08/2015	13:28	05/08/2015	17:20	1	231	231	Overhead equipment	Overhead Transformer			I
151284659	B00003	05/08/2015	13:34	05/08/2015	17:39	7	1715	245	Overhead equipment	Disconnect Switch	Patrol/Test/Inspect	Replace - Same Size	I
151284885	D31018	05/08/2015	13:38	05/08/2015	15:05	14	1218	86	Weather	Fuse	Replace - Same Size	Patrol/Test/Inspect	III
5009577	J71128	05/08/2015	13:38	05/08/2015	14:24	1	45	45	Unknown	Transformer Fuse	Replace - Same Size		I
5009579	G10001	05/08/2015	13:39	05/08/2015	15:00	6	482	80	Overhead equipment	Fuse	Replace - Same Size		I
151284711	B19002	05/08/2015	13:47	05/08/2015	14:57	1	70	69	Weather	Transformer Fuse	Replace - Same Size		I
5009581	B81001	05/08/2015	13:47	05/08/2015	15:30	1	102	102	Overhead equipment	Fuse	Replace - Same Size		I

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5009585	B81001	05/08/2015	13:50	05/08/2015	18:49	1	298	298	Overhead equipment	Overhead Primary	Switch/Reset	Repair	I
151284837	S61575	05/08/2015	14:00	05/08/2015	15:12	42	3024	71	Tree related-tree broken	Overhead Primary	Repair	Repair	VI
5009591	Z05549	05/08/2015	14:00	05/08/2015	15:23	121	10079	83	Weather	Crossarm	Replace - Same Size		IV
5009593	Y45506	05/08/2015	14:02	05/08/2015	20:17	1	375	374	Underground equipment	Underground Transformer	Repair	Replace - Same Size	IV
151284785	J47176	05/08/2015	14:02	05/08/2015	15:14	66	4752	72	Underground equipment	Underground Primary			III
151284802	S64501	05/08/2015	14:08	05/08/2015	15:18	1	70	69	Overhead equipment	Fuse			VI
151284818	S64501	05/08/2015	14:13	05/08/2015	14:35	1	22	21	Overhead equipment	Fuse			VI
151284867	T12528	05/08/2015	14:23	05/08/2015	20:10	1	347	346	Tree related-tree broken	Pole	Repair	Repair	VI
151284861	M07235	05/08/2015	14:23	05/08/2015	15:00	1	37	36	Weather	Transformer Fuse	Replace - Same Size		III
151284950	P62138	05/08/2015	14:23	05/08/2015	16:11	863	93204	107	Overhead equipment				VI
151284924	R41132	05/08/2015	14:26	05/08/2015	15:40	9	666	74	Weather	Recloser			VI
5009595	B81001	05/08/2015	14:31	05/08/2015	15:30	1	58	58	Overhead equipment	Fuse	Replace - Same Size		I
151284928	P60161	05/08/2015	14:35	05/08/2015	16:20	1	105	104	Tree related-tree broken	Overhead Service	Raise	Raise	VI
151285072	N95824	05/08/2015	14:48	05/08/2015	17:13	103	14935	145	Overhead equipment	Jumper	Repair		V
5009597	R50910	05/08/2015	14:57	05/08/2015	16:00	5	312	62	Overhead equipment	Fuse	Repair	Repair	I
151285130	R41131	05/08/2015	14:59	05/08/2015	16:00	8	488	60	Tree related-tree broken	Transformer Fuse	Replace - Same Size		VI
5009599	N22295	05/08/2015	15:04	05/08/2015	16:17	1	72	72	Overhead equipment	Fuse	Replace - Same Size		VI
151285119	R73841	05/08/2015	15:15	05/08/2015	17:23	159	20352	128	Weather	Lightning Arrestor	Disconnect		V
151285074	337003	05/08/2015	15:17	05/08/2015	16:17	1	60	59	Tree related-tree broken	Tree	Trim		VI
5009605	N22296	05/08/2015	15:22	05/08/2015	19:00	1	217	217	Weather	Disconnect Switch	Replace - Same Size		VI
151285094	R73841	05/08/2015	15:24	05/08/2015	17:31	1	127	126	Weather	Lightning Arrestor	Disconnect		V
5009611	Y45506	05/08/2015	15:44	05/08/2015	16:56	4	285	71	Underground equipment				IV
5009613	L93135	05/08/2015	15:50	05/08/2015	16:24	4	134	33	Animal related	Fuse	Replace - Same Size		VI
5009655	P82291	05/08/2015	15:50	05/08/2015	20:27	20	5526	276	Tree related-tree contact	Overhead Primary	Disconnect	Repair	VI
5009617	X49568	05/08/2015	15:51	05/08/2015	22:56	16	6796	424	Tree related-tree broken	Tree	Trim		IV
5009623	P82291	05/08/2015	15:53	05/08/2015	17:56	17	2080	122	Tree related-tree contact	Fuse	Replace - Same Size		VI
151285176	D31018	05/08/2015	15:58	05/08/2015	16:52	1	54	53	Overhead equipment	Disconnect Switch	Replace - Same Size		III
5009631	A81004	05/08/2015	16:11	05/08/2015	22:51	1	399	399	Underground equipment	Underground Transformer	Disconnect	Repair	I
5009633	X82003	05/08/2015	16:13	05/08/2015	18:32	1	138	138	Tree related-tree broken	Overhead Service	Repair		IV
151285205	T05539	05/08/2015	16:15	05/08/2015	16:35	1	20	19	Unknown				VI
5009637	Y20522	05/08/2015	16:16	05/08/2015	17:25	20	1366	68	Overhead equipment	Disconnect Switch	Replace - Same Size		IV
151285224	M47802	05/08/2015	16:21	05/08/2015	17:05	1	44	43	Animal related	Fuse	Repair	Repair	V
151285237	R02121	05/08/2015	16:28	05/08/2015	18:18	1	110	109	Tree related-tree broken	Fuse	Replace - Same Size		VI
151285276	E10001	05/08/2015	16:29	05/08/2015	17:26	5	285	57	Weather	Fuse	Replace - Same Size		III
151285243	P57102	05/08/2015	16:31	05/08/2015	17:39	1	68	68	Public	Meter	Replace - Same Size		VI
151285269	R73841	05/08/2015	16:49	05/08/2015	17:25	1	36	36	Weather	Lightning Arrestor	Disconnect		V
5009641	Y50004	05/08/2015	16:49	05/08/2015	17:45	12	663	55	Tree related-tree broken	Overhead Secondary	Repair		IV
5154907	R39934	05/08/2015	16:57	05/08/2015	20:58	319	76958	241	Overhead equipment				VI
5009647	X77586	05/08/2015	17:06	05/08/2015	21:15	1	248	248	Overhead equipment	Overhead Transformer	Replace - Same Size	Replace - Same Size	IV
5009651	D88001	05/08/2015	17:29	05/08/2015	23:13	1	343	343	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	I
151285345	E10001	05/08/2015	17:33	05/08/2015	17:41	1	8	8	Weather	Fuse	Replace - Same Size		III
151285352	D35003	05/08/2015	17:35	05/08/2015	19:20	1	105	104	Overhead equipment	Fuse	Replace - Same Size		I
5009657	Q36412	05/08/2015	17:47	05/08/2015	20:05	1	137	137	Public	Overhead Service	Cut in Clear	Disconnect	I
5009659	B93003	05/08/2015	17:50	05/08/2015	19:15	1	84	84	Weather	Fuse	Replace - Same Size		I
5009661	Y45506	05/08/2015	17:57	05/08/2015	20:12	1	134	134	Underground equipment				IV
5009663	R68903	05/08/2015	18:02	05/09/2015	5:00	1	657	657	Underground equipment	Underground Service	Repair	Repair	I
5009667	B10001	05/08/2015	18:09	05/09/2015	4:40	1	630	630	Underground equipment	Vault	Disconnect	Repair	I
151285431	L12125	05/08/2015	18:38	05/08/2015	19:25	1	47	47	Tree related-tree contact	Overhead Service	Repair		III
151285438	328120	05/08/2015	18:42	05/08/2015	19:25	1	43	43	Overhead equipment	Fuse	Replace - New Size		V
151285445	P57102	05/08/2015	19:00	05/08/2015	20:58	1	118	118	Tree related-tree broken	Overhead Service	Reconnect		VI
5009691	R50910	05/08/2015	19:11	05/08/2015	21:21	1	129	129	Overhead equipment	Insulator	Repair		I
5009671	R50910	05/08/2015	19:13	05/08/2015	21:21	1	127	127	Overhead equipment	Insulator	Repair		I
5009669	R50910	05/08/2015	19:18	05/08/2015	21:00	4	407	101	Overhead equipment	Insulator	Repair	Repair	I
151285485	A12034	05/08/2015	19:21	05/08/2015	20:47	1151	98986	85	Tree related-tree broken	Crossarm	Replace - Same Size		I
151285660	D32211	05/08/2015	19:21	05/09/2015	0:17	395	116920	296	Tree related-tree broken	Crossarm	Repair	Repair	I
151285475	E10002	05/08/2015	19:21	05/09/2015	8:44	1	803	802	Overhead equipment	Overhead Transformer			III

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5009673	K32932	05/08/2015	19:31	05/08/2015	20:35	1	63	63	Animal related	Fuse	Replace - Same Size		VI
151285607	K91115	05/08/2015	19:40	05/08/2015	20:35	13	715	55	Overhead equipment	Overhead Primary	Repair		III
5009755	Q11517	05/08/2015	19:59	05/09/2015	0:08	2	497	248	Tree related-tree contact	Overhead Primary		Repair	I
5009681	Q11517	05/08/2015	20:02	05/08/2015	22:31	197	29280	148	Tree related-tree contact	Overhead Primary	Repair		I
151285664	P05825	05/08/2015	20:23	05/09/2015	0:30	1	247	246	Overhead equipment	Overhead Transformer	Replace - Same Size	Repair	V
5009683	N05172	05/08/2015	20:32	05/08/2015	22:45	1	132	132	Weather	Fuse	Repair	Repair	I
151285669	P62138	05/08/2015	20:37	05/08/2015	22:20	1	103	103	Weather	Transformer Fuse	Replace - Same Size		VI
5009687	R39934	05/08/2015	21:00	05/08/2015	21:10	1	9	9	Overhead equipment				VI
151285689	U02597	05/08/2015	21:03	05/08/2015	23:40	1	157	156	Animal related	Transformer Fuse			II
151285688	S25551	05/08/2015	21:03	05/08/2015	22:24	1	81	81	Overhead equipment	Transformer Fuse	Repair		VI
5009717	J13108	05/08/2015	21:29	05/09/2015	0:40	951	181098	190	Substation equipment	Substation Misc.	Repair		I
5009723	R39934	05/08/2015	21:35	05/09/2015	9:00	1	684	684	Public	Overhead Secondary	Repair		VI
5009753	B81003	05/08/2015	22:07	05/08/2015	23:39	1	91	91	Overhead equipment	Overhead Service		Repair	I
5009757	R39934	05/08/2015	22:33	05/09/2015	0:33	1	119	119	Tree related-tree broken	Overhead Service	Cut in Clear		VI
5009761	N05172	05/08/2015	22:59	05/09/2015	4:00	1	300	300	Weather	Pole	Repair	Repair	I
5009765	Y24523	05/09/2015	5:25	05/09/2015	6:47	5	408	81	Overhead equipment	Fuse	Replace - Same Size		IV
5009829	Q82906	05/09/2015	6:24	05/09/2015	8:49	363	52435	144	Animal related	Lightning Arrestor	Repair		VI
151290067	F03003	05/09/2015	6:29	05/09/2015	8:06	1	97	97	Overhead equipment	Overhead Service	Replace - Same Size		III
5009831	Q82906	05/09/2015	6:30	05/09/2015	8:49	3	416	138	Animal related	Lightning Arrestor	Repair		VI
5009801	Q32170	05/09/2015	6:38	05/09/2015	11:28	1	289	289	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	I
5009833	Q82906	05/09/2015	6:38	05/09/2015	8:49	1	130	130	Animal related	Lightning Arrestor	Repair		VI
151290091	Q01281	05/09/2015	6:43	05/09/2015	7:12	34	986	29	Animal related	Fuse			III
5009819	Y11556	05/09/2015	7:02	05/09/2015	8:35	5	464	92	Animal related	Transformer Fuse	Repair	Replace - Same Size	IV
5009835	Q82906	05/09/2015	7:07	05/09/2015	8:49	1	101	101	Animal related	Lightning Arrestor	Repair		VI
151290111	D61001	05/09/2015	7:17	05/09/2015	9:45	1	148	148	Overhead equipment	Overhead Primary			III
151290141	L14232	05/09/2015	8:04	05/09/2015	11:04	10	1800	180	Overhead equipment	Overhead Secondary	Repair		III
151290143	L17101	05/09/2015	8:06	05/09/2015	8:56	1	50	49	Other	Other			III
151290146	B35002	05/09/2015	8:13	05/09/2015	9:44	1	91	90	Animal related	Transformer Fuse	Replace - Same Size		I
5009837	J88163	05/09/2015	8:24	05/09/2015	9:14	1	49	49	Animal related	Fuse	Replace - Same Size		VI
151290176	A17021	05/09/2015	8:29	05/09/2015	9:39	42	2940	69	Unknown	Fuse	Replace - Same Size	Replace - Same Size	I
151290201	D69009	05/09/2015	9:04	05/09/2015	10:21	1	77	76	Unknown	Fuse	Replace - Same Size	Replace - Same Size	I
151290203	D32212	05/09/2015	9:05	05/09/2015	13:15	2	500	250	Overhead equipment	Overhead Secondary	Advise Customer	Repair	I
151290227	S47589	05/09/2015	9:29	05/09/2015	11:00	1	91	91	Overhead equipment				VI
151290246	L17102	05/09/2015	9:49	05/09/2015	11:31	1	102	101	Animal related	Transformer Fuse	Replace - Same Size		III
5009843	D92002	05/09/2015	9:59	05/09/2015	15:06	1	306	306	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
151290261	J58380	05/09/2015	10:06	05/09/2015	10:48	2	84	42	Animal related	Fuse			III
151290271	U33586	05/09/2015	10:16	05/09/2015	10:59	1	43	43	Overhead equipment	Transformer Fuse	Replace - Same Size		II
151290284	U92593	05/09/2015	10:26	05/09/2015	14:48	1	262	262	Underground equipment	Underground Service	Repair	Repair	II
151290291	U61572	05/09/2015	10:34	05/09/2015	11:35	1	61	60	Animal related	Transformer Fuse	Replace - Same Size		II
151290290	N95823	05/09/2015	10:34	05/09/2015	11:25	1	51	50	Overhead equipment	Fuse	Replace - Same Size		V
5009849	N58144	05/09/2015	10:35	05/09/2015	12:10	1	94	94	Weather	Fuse	Replace - Same Size		I
5009853	R94269	05/09/2015	10:38	05/09/2015	12:17	4	394	98	Animal related	Fuse	Replace - Same Size		VI
5009857	A97001	05/09/2015	10:58	05/09/2015	12:05	16	1057	66	Tree related-tree broken	Tree	Remove		I
151290323	C52002	05/09/2015	11:03	05/09/2015	14:47	1	224	223	Overhead equipment	Overhead Service	Replace - New Size		III
151290341	A45003	05/09/2015	11:07	05/09/2015	11:52	1	45	45	Weather	Disconnect Switch	Replace - Same Size	Replace - Same Size	I
151290437	S07535	05/09/2015	11:20	05/09/2015	12:45	4	340	85	Tree related-tree broken	Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
151290371	V39001	05/09/2015	11:30	05/09/2015	12:52	1	82	82	Overhead equipment	Overhead Service	Repair		II
5009859	X72535	05/09/2015	11:33	05/09/2015	11:37	1	3	3	Overhead equipment	Fuse	Replace - Same Size		IV
151290390	K91115	05/09/2015	11:46	05/09/2015	13:09	1	83	83	Animal related	Transformer Fuse	Replace - Same Size		III
151290428	P62138	05/09/2015	11:52	05/09/2015	16:10	28	7224	258	Tree related-tree broken	Overhead Primary	Patrol/Test/Inspect	Repair	VI
5009863	Q24313	05/09/2015	11:52	05/09/2015	13:15	1	82	82	Weather	Fuse	Repair		VI
5009865	Q24313	05/09/2015	11:55	05/09/2015	13:15	2	159	79	Weather	Fuse	Replace - Same Size		VI
151290475	K26136	05/09/2015	12:07	05/09/2015	14:45	48	7584	158	Overhead equipment	Recloser	Disconnect		VI
151290445	K26136	05/09/2015	12:11	05/09/2015	14:50	1	159	158	Overhead equipment	Recloser			VI
151290454	K26136	05/09/2015	12:22	05/09/2015	15:06	1	164	164	Overhead equipment	Recloser	Disconnect		VI
151290457	R41132	05/09/2015	12:23	05/09/2015	13:35	1	72	71	Weather	Overhead Primary	Cut in Clear		VI

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5009873	X69556	05/09/2015	12:24	05/09/2015	15:50	26	5344	205	Tree related-tree broken	Fuse	Replace - Same Size		IV
151290472	M12151	05/09/2015	12:31	05/09/2015	16:52	10	2610	261	Overhead equipment	Overhead Primary	Tie/Tighten	Repair	VI
151290467	J14140	05/09/2015	12:33	05/09/2015	14:03	1	90	90	Weather	Recloser	Replace - Same Size		VI
151290466	P05826	05/09/2015	12:33	05/09/2015	13:27	1	54	53	Animal related	Transformer Fuse	Replace - Same Size		V
151290474	K22173	05/09/2015	12:39	05/09/2015	15:07	1	148	148	Overhead equipment	Recloser			VI
151290480	L74197	05/09/2015	12:44	05/09/2015	13:38	1	54	54	Public				IV
5009879	Y48002	05/09/2015	13:06	05/09/2015	14:14	1	67	67	Tree related-tree contact	Overhead Service	Repair	Replace - Same Size	IV
151290514	U62510	05/09/2015	13:24	05/09/2015	14:33	4	276	68	Overhead equipment	Transformer Fuse	Replace - Same Size		II
151290530	S09520	05/09/2015	13:40	05/09/2015	15:00	1	80	79	Overhead equipment	Overhead Secondary	Repair	Repair	VI
5009885	M36184	05/09/2015	13:52	05/09/2015	15:00	52	3510	67	Animal related	Fuse	Replace - Same Size		I
5009893	B76003	05/09/2015	14:12	05/09/2015	20:12	9	3241	360	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
151290587	L86176	05/09/2015	14:18	05/09/2015	15:15	1	57	56	Animal related	Fuse		Replace - Same Size	IV
5009895	Q23256	05/09/2015	14:26	05/09/2015	16:15	1	108	108	Tree related-tree broken	Overhead Secondary	Repair		VI
5009899	Y51506	05/09/2015	14:42	05/09/2015	20:20	1	337	337	Overhead equipment	Pole	Patrol/Test/Inspect	Replace - Same Size	IV
5009905	Y51506	05/09/2015	14:44	05/09/2015	15:41	12	681	56	Other	Fuse	Replace - Same Size		IV
151290621	C52001	05/09/2015	14:51	05/09/2015	17:27	1	156	155	Overhead equipment	Overhead Service	Replace - Same Size		III
5009907	L62928	05/09/2015	14:51	05/09/2015	16:43	1	111	111	Tree related-tree broken	Overhead Service	Repair	Repair	VI
5009911	X88510	05/09/2015	15:11	05/09/2015	16:59	6	644	107	Weather	Fuse	Replace - Same Size		IV
5009917	J01118	05/09/2015	15:18	05/09/2015	16:20	8	488	61	Overhead equipment	Disconnect Switch	Replace - Same Size		I
151290652	307002	05/09/2015	15:24	05/09/2015	16:50	1	86	85	Overhead equipment	Overhead Service	Repair	Replace - New Size	VI
151290668	P98193	05/09/2015	15:45	05/09/2015	18:52	1	187	187	Overhead equipment	Overhead Transformer			III
5009921	R07381	05/09/2015	15:57	05/09/2015	18:25	1	147	147	Overhead equipment	Connector	Replace - Same Size	Repair	I
151290681	341001	05/09/2015	16:01	05/09/2015	21:20	58	18502	319	Tree related-tree broken	Overhead Primary	Patrol/Test/Inspect	Repair	VI
151290694	342001	05/09/2015	16:21	05/09/2015	22:40	2	758	378	Tree related-tree broken	Tree	Patrol/Test/Inspect	Remove	VI
151290703	Q71846	05/09/2015	16:28	05/09/2015	19:03	1	155	154	Overhead equipment	Transformer Fuse		Replace - Same Size	V
5009925	R04407	05/09/2015	16:47	05/09/2015	18:29	2	203	101	Animal related	Transformer Fuse	Repair		V
5009947	M20221	05/09/2015	16:53	05/09/2015	18:48	15	1721	114	Tree related-tree contact	Fuse	Replace - Same Size		VI
151290717	L35283	05/09/2015	16:57	05/09/2015	22:01	1	304	303	Overhead equipment	Overhead Service	Repair		III
5009939	Y66557	05/09/2015	17:00	05/09/2015	19:03	92	11244	122	Overhead equipment	Fuse	Replace - Same Size		IV
151290726	307001	05/09/2015	17:05	05/10/2015	0:05	1	420	419	Tree related-tree broken	Overhead Service	Patrol/Test/Inspect	Replace - New Size	VI
151290736	M45212	05/09/2015	17:07	05/09/2015	18:23	25	1900	76	Overhead equipment				IV
151290741	L24123	05/09/2015	17:17	05/09/2015	19:04	1	107	107	Unknown	Fuse	Replace - Same Size		III
151290749	K30204	05/09/2015	17:25	05/09/2015	19:40	1	135	135	Tree related-tree contact	Overhead Service	Repair		III
5009951	Y66557	05/09/2015	17:53	05/09/2015	19:04	2	140	70	Animal related	Transformer Fuse	Replace - Same Size		IV
151290920	P17108	05/09/2015	18:26	05/09/2015	21:55	36	7524	209	Underground equipment	Underground Primary	Repair		IV
5009993	R49261	05/09/2015	18:38	05/09/2015	23:54	31	9772	315	Underground equipment	Underground Transformer	Replace - Same Size	Replace - Same Size	VI
151290906	P17108	05/09/2015	18:54	05/09/2015	20:00	253	16698	66	Underground equipment				IV
5009963	H14342	05/09/2015	19:35	05/09/2015	21:40	37	4608	124	Animal related	Fuse	Repair		V
151290869	L00133	05/09/2015	19:46	05/09/2015	23:14	1	208	207	Underground equipment	Underground Service		Repair	III
151290877	N44216	05/09/2015	19:49	05/09/2015	20:34	18	810	45	Overhead equipment	Fuse			III
5009967	R16513	05/09/2015	19:59	05/10/2015	2:20	1	380	380	Tree related-tree contact	Overhead Service	Repair	Repair	I
5009973	H11338	05/09/2015	20:13	05/09/2015	20:50	1	36	36	Animal related	Fuse	Repair		V
5009977	Q93522	05/09/2015	20:30	05/10/2015	6:34	3	1811	603	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
151290899	D31015	05/09/2015	20:36	05/09/2015	21:17	8	328	41	Overhead equipment	Transformer Fuse	Replace - Same Size		III
5009979	R71285	05/09/2015	20:49	05/09/2015	22:50	1	120	120	Weather	Fuse			VI
5009991	R71285	05/09/2015	20:50	05/09/2015	22:58	1	127	127	Weather	Fuse			VI
151290918	311002	05/09/2015	20:59	05/10/2015	1:20	1	261	261	Overhead equipment	Overhead Service	Patrol/Test/Inspect	Replace - New Size	VI
151290917	U04550	05/09/2015	20:59	05/09/2015	22:23	1	84	84	Animal related	Fuse	Replace - Same Size	Repair	II
5010015	X23516	05/09/2015	21:09	05/10/2015	7:28	26	16078	618	Tree related-tree broken	Pole	Repair		IV
5010005	X23516	05/09/2015	21:12	05/10/2015	3:00	32	11129	347	Tree related-tree broken	Fuse			IV
5009999	X23516	05/09/2015	21:12	05/10/2015	1:55	69	19509	282	Tree related-tree broken	Overhead Primary			IV
5010009	X23516	05/09/2015	21:14	05/09/2015	22:37	1	82	82	Tree related-tree broken	Overhead Service			IV
5010011	R71285	05/09/2015	21:14	05/09/2015	22:57	1	102	102	Weather	Fuse			VI
5010017	X23516	05/09/2015	21:17	05/10/2015	8:00	1	642	642	Tree related-tree broken	Tree	Remove		IV
5010019	X23516	05/09/2015	21:17	05/10/2015	8:42	1	684	684	Overhead equipment	Pole	Repair	Patrol/Test/Inspect	IV
5010021	X23516	05/09/2015	21:19	05/10/2015	3:28	1	368	368	Tree related-tree broken	Overhead Service			IV

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
151290942	P17108	05/09/2015	21:20	05/09/2015	21:56	1	36	36	Overhead equipment	Other			IV
5010027	X23516	05/09/2015	21:26	05/10/2015	5:55	1	508	508	Tree related-tree broken	Overhead Service	Replace - New Size		IV
5010029	Q18242	05/09/2015	21:31	05/10/2015	3:52	1	380	380	Underground equipment	Underground Secondary		Repair	VI
5010031	X23516	05/09/2015	21:53	05/10/2015	1:30	1	216	216	Tree related-tree broken	Overhead Service			IV
5010037	X23516	05/09/2015	22:24	05/10/2015	4:13	1	348	348	Tree related-tree broken	Overhead Service			IV
151290976	U99578	05/09/2015	22:32	05/10/2015	2:34	1	242	242	Weather	Overhead Transformer	Replace - Same Size		II
151300014	B19001	05/10/2015	0:35	05/10/2015	3:51	1	196	195	Underground equipment	Underground Service	Replace - Same Size	Replace - Same Size	I
5010041	J07135	05/10/2015	1:58	05/10/2015	3:15	1	76	76	Animal related	Transformer Fuse	Replace - Same Size		I
151300034	U35554	05/10/2015	2:47	05/10/2015	4:29	1	102	101	Overhead equipment				II
5010043	R68903	05/10/2015	3:40	05/10/2015	6:56	15	2940	196	Other	Overhead Primary	Raise		I
151300059	E10003	05/10/2015	4:46	05/10/2015	5:53	1	67	66	Overhead equipment	Transformer Fuse	Replace - Same Size		III
151300064	L12125	05/10/2015	5:02	05/10/2015	9:28	41	10906	265	Underground equipment	Underground Primary		Repair	III
151300069	U41545	05/10/2015	5:43	05/10/2015	6:53	1	70	70	Overhead equipment	Transformer Fuse	Repair		II
5010051	B21004	05/10/2015	6:16	05/10/2015	9:40	62	12643	203	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
151300088	T08501	05/10/2015	7:06	05/10/2015	8:25	5	395	79	Animal related	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
5010057	L93135	05/10/2015	7:09	05/10/2015	8:15	36	2368	65	Animal related	Fuse			VI
5010061	Y37593	05/10/2015	7:24	05/10/2015	8:25	1	60	60	Tree related-tree broken	Overhead Service			IV
5010063	K01239	05/10/2015	7:35	05/10/2015	8:42	1	66	66	Animal related	Transformer Fuse			VI
5010067	P42230	05/10/2015	7:57	05/10/2015	9:37	1	99	99	Animal related	Transformer Fuse			VI
5010069	J87150	05/10/2015	8:22	05/10/2015	9:10	4	188	47	Animal related	Transformer Fuse			VI
5010071	X23516	05/10/2015	8:24	05/10/2015	9:47	1	83	82	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
5010073	M19222	05/10/2015	8:45	05/10/2015	10:15	1	89	89	Animal related	Transformer Fuse			VI
5010075	Y63539	05/10/2015	8:56	05/10/2015	9:46	1	49	49	Other	Other			IV
5010077	P20930	05/10/2015	8:57	05/10/2015	10:28	1	90	90	Animal related	Fuse	Replace - Same Size	Replace - Same Size	VI
5010095	M81403	05/10/2015	9:07	05/10/2015	20:19	20	8473	672	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	V
5010085	B21001	05/10/2015	9:14	05/10/2015	10:10	1	55	55	Unknown	Transformer Fuse	Replace - Same Size		I
151300148	U09540	05/10/2015	9:18	05/10/2015	11:13	1	115	115	Unknown	Transformer Fuse	Replace - Same Size		II
5010087	X75571	05/10/2015	9:25	05/10/2015	10:50	1	84	84	Animal related	Transformer Fuse	Replace - Same Size	Replace - Same Size	IV
5010089	M54292	05/10/2015	9:45	05/10/2015	11:02	3	228	76	Animal related	Transformer Fuse	Replace - Same Size	Replace - Same Size	V
151300161	V23530	05/10/2015	9:53	05/10/2015	10:48	1	55	54	Animal related	Transformer Fuse	Repair	Replace - Same Size	II
151300162	R66470	05/10/2015	9:55	05/10/2015	11:44	1	109	108	Tree related-tree contact	Overhead Service			IV
151300175	S28551	05/10/2015	10:35	05/10/2015	12:18	1	103	103	Animal related	Transformer Fuse	Replace - Same Size	Replace - Same Size	VI
5010101	D28123	05/10/2015	11:11	05/10/2015	12:05	123	6639	53	Unknown				I
5010103	J97113	05/10/2015	11:31	05/10/2015	13:36	4	498	124	Tree related-tree contact	Transformer Fuse	Replace - Same Size		VI
5010115	Y28598	05/10/2015	12:01	05/10/2015	13:32	24	2189	91	Overhead equipment	Fuse	Patrol/Test/Inspect	Replace - Same Size	IV
151300202	U16522	05/10/2015	12:02	05/10/2015	14:55	1	173	173	Overhead equipment	Transformer Fuse	Replace - Same Size	Repair	II
5010119	Y28598	05/10/2015	13:32	05/10/2015	14:22	2	98	49	Animal related	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	IV
151300282	S62523	05/10/2015	13:53	05/10/2015	21:15	1	442	441	Underground equipment	Underground Service		Repair	VI
151300291	M45212	05/10/2015	14:21	05/10/2015	15:42	1	81	81	Animal related	Transformer Fuse	Repair		IV
5010125	Y39521	05/10/2015	14:48	05/10/2015	15:55	1	66	66	Animal related	Transformer Fuse	Replace - Same Size		IV
151300300	R20501	05/10/2015	14:51	05/10/2015	16:02	1	71	71	Animal related	Transformer Fuse	Replace - Same Size		IV
151300305	R58961	05/10/2015	15:07	05/10/2015	16:25	1	78	78	Overhead equipment	Transformer Fuse	Repair		IV
151300313	J63172	05/10/2015	15:56	05/10/2015	17:08	1	72	71	Overhead equipment	Connector			III
151300314	S07535	05/10/2015	15:59	05/10/2015	17:30	1	91	90	Overhead equipment	Transformer Fuse	Repair	Repair	VI
5010129	X23516	05/10/2015	16:15	05/10/2015	17:30	1	74	74	Tree related-tree broken	Other			IV
151300349	S60581	05/10/2015	16:38	05/10/2015	21:37	1	299	298	Overhead equipment	Overhead Service	Patrol/Test/Inspect	Repair	VI
151300365	T08501	05/10/2015	16:47	05/10/2015	18:30	47	4841	103	Weather	Crossarm	Patrol/Test/Inspect	Patrol/Test/Inspect	VI
151300528	334004	05/10/2015	17:33	05/10/2015	22:15	1	282	282	Overhead equipment	Tree	Patrol/Test/Inspect	Remove	VI
5010167	J85161	05/10/2015	17:33	05/10/2015	20:14	43	6915	160	Tree related-tree broken	Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
151300584	U35511	05/10/2015	17:34	05/10/2015	18:55	14	1134	81	Weather	Fuse	Replace - Same Size		II
5010137	J89125	05/10/2015	17:35	05/10/2015	21:44	17	4232	248	Tree related-tree broken	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
5010139	N22295	05/10/2015	17:35	05/11/2015	0:09	1	393	393	Weather	Transformer Fuse	Replace - Same Size		VI
5010141	N22295	05/10/2015	17:36	05/10/2015	23:48	3	1113	371	Weather	Fuse	Replace - Same Size		VI
151310159	306001	05/10/2015	17:39	05/11/2015	3:15	4	2304	575	Overhead equipment	Overhead Primary	Advise Customer	Repair	VI
5010145	J99127	05/10/2015	17:39	05/11/2015	0:17	4	1590	397	Overhead equipment				VI
5010163	J87111	05/10/2015	17:39	05/10/2015	19:58	14	1941	138	Tree related-tree contact				VI

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5010149	K15207	05/10/2015	17:40	05/11/2015	0:35	3	1242	414	Overhead equipment	Fuse	Patrol/Test/Inspect		VI
151300711	342004	05/10/2015	17:41	05/10/2015	20:10	4	596	149	Tree related-tree broken	Tree	Trim		VI
5010233	Q21294	05/10/2015	17:41	05/11/2015	18:29	1220	176656	1488	Overhead equipment	Pole			VI
5010617	J87111	05/10/2015	17:42	05/11/2015	6:36	26	20111	773	Tree related-tree contact	Pole		Repair	VI
5010169	K01241	05/10/2015	17:43	05/11/2015	8:45	24	21641	901	Weather	Underground Primary		Repair	VI
5010175	J98130	05/10/2015	17:44	05/11/2015	18:35	1	1490	1490	Weather	Pole		Replace - Same Size	VI
5010199	J87119	05/10/2015	17:44	05/10/2015	18:56	436	31313	71	Tree related-tree contact	Tree	Remove		VI
151300728	P98190	05/10/2015	17:45	05/10/2015	20:00	12	1620	135	Underground equipment	Underground Primary		Repair	III
151300635	348116	05/10/2015	17:46	05/10/2015	18:53	29	1943	67	Overhead equipment	Disconnect Switch	Patrol/Test/Inspect	Replace - Same Size	V
5010263	M19222	05/10/2015	17:49	05/10/2015	19:17	323	28327	87	Overhead equipment				VI
151300615	T09530	05/10/2015	17:50	05/10/2015	19:20	5	450	90	Weather	Fuse	Patrol/Test/Inspect	Repair	VI
5010261	Q18244	05/10/2015	17:51	05/10/2015	21:57	16	3934	245	Weather				VI
5010273	Q18245	05/10/2015	17:52	05/10/2015	22:53	1	300	300	Tree related-tree broken	Transformer Fuse			VI
5010291	M54292	05/10/2015	17:52	05/10/2015	19:19	1	86	86	Weather	Fuse	Repair		V
5010289	M54292	05/10/2015	17:52	05/10/2015	19:03	1	70	70	Weather	Fuse	Repair		V
5010307	J97103	05/10/2015	17:53	05/11/2015	0:25	9	3524	391	Tree related-tree broken	Pole	Patrol/Test/Inspect	Replace - Same Size	VI
5010315	J87120	05/10/2015	17:53	05/11/2015	1:01	1	427	427	Tree related-tree broken	Tree	Remove		VI
5010317	R29905	05/10/2015	17:53	05/11/2015	4:05	6	3667	611	Overhead equipment	Pole	Patrol/Test/Inspect	Replace - Same Size	VI
5010349	J99128	05/10/2015	17:56	05/11/2015	14:10	1	1213	1213	Tree related-tree broken	Tree		Remove	VI
5010351	J98104	05/10/2015	17:57	05/11/2015	2:44	1	527	526	Tree related-tree broken	Overhead Service	Patrol/Test/Inspect	Cut in Clear	VI
5010365	M78322	05/10/2015	17:58	05/11/2015	1:17	6	2629	438	Tree related-tree broken	Overhead Secondary	Patrol/Test/Inspect	Repair	V
151300691	306001	05/10/2015	17:59	05/11/2015	1:28	43	19307	449	Tree related-tree broken	Overhead Primary	Advise Customer	Repair	VI
151300863	307001	05/10/2015	17:59	05/11/2015	0:02	18	6534	362	Overhead equipment	Fuse	Replace - Same Size		VI
5010391	J87119	05/10/2015	18:02	05/10/2015	23:30	1	327	327	Tree related-tree contact	Overhead Service	Repair		VI
5010397	N86225	05/10/2015	18:03	05/10/2015	23:50	1	346	346	Tree related-tree contact	Overhead Service	Patrol/Test/Inspect		VI
5010503	J99127	05/10/2015	18:04	05/11/2015	0:17	17	6334	372	Overhead equipment	Fuse		Replace - Same Size	VI
5010431	Q91141	05/10/2015	18:06	05/10/2015	21:15	228	42879	188	Overhead equipment	Jumper	Patrol/Test/Inspect	Repair	I
5010413	K67924	05/10/2015	18:09	05/10/2015	22:20	1	250	250	Tree related-tree broken	Overhead Service	Repair	Repair	VI
5010589	Q54908	05/10/2015	18:11	05/10/2015	21:13	37	6739	182	Tree related-tree broken	Overhead Primary	Patrol/Test/Inspect	Repair	VI
151300756	P05826	05/10/2015	18:13	05/10/2015	19:10	1	57	56	Weather	Transformer Fuse	Replace - Same Size		V
151300762	U52516	05/10/2015	18:15	05/10/2015	19:15	2	120	60	Weather	Fuse	Replace - Same Size		II
5010435	N86225	05/10/2015	18:18	05/10/2015	21:26	3	563	187	Weather	Fuse	Replace - Same Size		VI
151316183	V16501	05/10/2015	18:20	05/12/2015	21:00	1	3040	3039	Overhead equipment	Pole	Replace - Same Size		II
151300791	U73759	05/10/2015	18:20	05/11/2015	19:13	5	7465	1492	Overhead equipment	Pole	Switch/Reset	Repair	II
151301312	U73759	05/10/2015	18:20	05/10/2015	20:29	1	129	129	Overhead equipment	Pole	Switch/Reset		II
151300785	341001	05/10/2015	18:21	05/10/2015	23:50	1	329	329	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - New Size	VI
151300795	307005	05/10/2015	18:23	05/10/2015	20:56	1	153	152	Overhead equipment	Overhead Transformer	Switch/Reset		VI
151300794	Q27185	05/10/2015	18:23	05/11/2015	3:41	5	2790	557	Overhead equipment	Pole		Replace - Same Size	VI
5010465	J82117	05/10/2015	18:27	05/11/2015	3:50	1	562	562	Tree related-tree broken	Overhead Service	Patrol/Test/Inspect	Repair	VI
5010475	Q23256	05/10/2015	18:29	05/11/2015	6:23	5	3566	713	Tree related-tree broken	Tree			VI
5010479	HD5254	05/10/2015	18:30	05/11/2015	3:03	1	512	512	Weather	Disconnect Switch	Switch/Reset	Switch/Reset	VI
5010575	M19222	05/10/2015	18:31	05/10/2015	23:03	9	2443	271	Tree related-tree broken	Overhead Primary	Patrol/Test/Inspect	Repair	VI
5010485	J87120	05/10/2015	18:32	05/11/2015	6:18	1	705	705	Tree related-tree broken	Overhead Service	Reconnect		VI
5010491	M15375	05/10/2015	18:35	05/10/2015	20:39	1	123	123	Overhead equipment				V
5010493	Q21294	05/10/2015	18:36	05/10/2015	20:57	1	140	140	Weather				VI
151300873	U31003	05/10/2015	18:47	05/10/2015	19:58	10	710	71	Tree related-tree broken	Transformer Fuse	Replace - Same Size		II
151300876	U68001	05/10/2015	18:47	05/11/2015	1:38	1	411	411	Overhead equipment	Overhead Secondary	Repair		II
151300941	C52001	05/10/2015	18:47	05/10/2015	22:04	815	160555	197	Overhead equipment	Overhead Primary	Repair		III
151301436	P58155	05/10/2015	18:49	05/10/2015	21:35	166	27556	165	Overhead equipment	Tree			VI
151301439	P58155	05/10/2015	18:49	05/10/2015	20:52	291	35793	122	Overhead equipment	Tree			VI
151300963	P58155	05/10/2015	18:49	05/11/2015	7:27	181	137198	757	Tree related-tree broken	Pole		Replace - Same Size	VI
151301147	P60170	05/10/2015	18:52	05/11/2015	5:45	120	78360	653	Overhead equipment	Pole	Replace - Same Size		VI
151301109	P60170	05/10/2015	18:52	05/11/2015	0:14	707	227654	322	Overhead equipment	Overhead Primary	Patrol/Test/Inspect	Repair	VI
5010515	Q18244	05/10/2015	18:54	05/10/2015	21:25	1	150	150	Weather				VI
5010517	K11372	05/10/2015	18:55	05/11/2015	2:01	1	426	426	Tree related-tree broken	Pole	Patrol/Test/Inspect	Repair	V
151300943	P05826	05/10/2015	18:58	05/10/2015	19:23	1	25	24	Weather	Transformer Fuse	Replace - Same Size		V

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
151301000	P62112	05/10/2015	18:58	05/11/2015	10:52	22	20988	953	Tree related-tree broken	Pole	Repair		VI
151300956	N13860	05/10/2015	18:59	05/10/2015	22:00	8	1448	180	Tree related-tree broken	Transformer Fuse	Replace - Same Size		V
151300961	S86597	05/10/2015	18:59	05/10/2015	19:25	26	676	26	Overhead equipment	Overhead Primary	Repair		VI
151301122	J74125	05/10/2015	19:00	05/10/2015	23:55	272	80240	295	Weather	Recloser	Patrol/Test/Inspect		VI
151301011	Q47833	05/10/2015	19:00	05/11/2015	0:40	5	1700	340	Weather	Fuse	Replace - Same Size		V
151300990	P60161	05/10/2015	19:03	05/11/2015	1:30	1	387	387	Overhead equipment				VI
5010527	J82117	05/10/2015	19:03	05/10/2015	23:16	4	1008	252	Overhead equipment	Overhead Secondary	Patrol/Test/Inspect	Repair	VI
151301004	U16522	05/10/2015	19:05	05/10/2015	20:30	1	85	84	Weather	Transformer Fuse	Replace - Same Size	Repair	II
5010713	A85001	05/10/2015	19:06	05/11/2015	0:17	31	9627	310	Overhead equipment	Overhead Primary		Repair	I
5010531	Y89540	05/10/2015	19:06	05/11/2015	5:25	1	618	618	Tree related-tree contact	Pole	Repair	Replace - Same Size	IV
5010619	A85001	05/10/2015	19:07	05/10/2015	21:04	316	36750	116	Overhead equipment	Overhead Primary	Cut in Clear		I
151300970	T02543	05/10/2015	19:10	05/10/2015	21:11	1	121	121	Tree related-tree broken	Overhead Service	Patrol/Test/Inspect	Repair	VI
151301039	332001	05/10/2015	19:12	05/10/2015	21:12	1	120	119	Tree related-tree broken	Tree	Trim		VI
151301043	K27122	05/10/2015	19:13	05/10/2015	22:20	1	187	187	Tree related-tree broken	Pole	Replace - Same Size	Replace - Same Size	VI
5010547	Y37592	05/10/2015	19:16	05/10/2015	22:14	1	177	177	Tree related-tree broken	Overhead Service			IV
5010561	J89125	05/10/2015	19:20	05/10/2015	22:31	1	190	190	Tree related-tree broken	Overhead Service	Patrol/Test/Inspect	Replace - Same Size	VI
5010569	Y89540	05/10/2015	19:23	05/11/2015	5:25	7	4210	601	Tree related-tree contact	Pole	Repair	Replace - Same Size	IV
151301095	P54827	05/10/2015	19:25	05/10/2015	22:43	1	198	197	Tree related-tree broken	Overhead Service	Repair		V
5010607	Y89540	05/10/2015	19:40	05/11/2015	5:25	10	5844	584	Tree related-tree contact	Pole	Repair	Replace - Same Size	IV
151301146	F10002	05/10/2015	19:41	05/10/2015	20:35	1	54	53	Overhead equipment	Customer Equipment	Cut in Clear		III
5010759	A85001	05/10/2015	19:47	05/10/2015	21:28	1	100	100	Overhead equipment				I
151301523	E10001	05/10/2015	19:48	05/11/2015	1:50	17	6154	362	Tree related-tree broken	Overhead Primary	Repair		III
151301183	C10002	05/10/2015	19:55	05/10/2015	23:40	1	225	225	Weather	Fuse			III
151301185	S88503	05/10/2015	19:56	05/10/2015	23:08	1	192	191	Tree related-tree broken	Overhead Secondary	Repair		VI
151301188	L95110	05/10/2015	19:56	05/10/2015	23:10	1	194	194	Tree related-tree contact	Overhead Service	Repair		III
151301384	K91115	05/10/2015	19:57	05/10/2015	23:45	11	2508	227	Tree related-tree contact	Overhead Primary	Repair		III
151301216	S16597	05/10/2015	19:58	05/10/2015	22:05	60	7620	127	Tree related-tree broken	Tree	Patrol/Test/Inspect	Remove	VI
151301202	T02543	05/10/2015	20:01	05/11/2015	2:12	43	15953	371	Overhead equipment				VI
5010653	M19222	05/10/2015	20:02	05/11/2015	1:43	4	1362	340	Jurisdictional				VI
151301211	S16596	05/10/2015	20:03	05/10/2015	22:15	1	132	132	Tree related-tree contact	Tree	Patrol/Test/Inspect	Remove	VI
5010655	Q21294	05/10/2015	20:04	05/10/2015	21:10	1	65	65	Weather				VI
5010657	Q21294	05/10/2015	20:04	05/10/2015	21:14	1	69	69	Weather				VI
151301212	U73583	05/10/2015	20:05	05/10/2015	21:44	1	99	98	Tree related-tree broken	Overhead Service	Repair		II
5010661	Q21294	05/10/2015	20:06	05/10/2015	20:41	1	34	34	Weather				VI
151301263	K28180	05/10/2015	20:09	05/10/2015	22:02	4	452	113	Overhead equipment	Fuse	Replace - Same Size		III
151301224	J39392	05/10/2015	20:10	05/10/2015	23:48	2	436	217	Tree related-tree contact	Overhead Transformer			III
5010669	Z17503	05/10/2015	20:11	05/10/2015	22:20	1	128	128	Tree related-tree broken	Overhead Service	Repair	Repair	IV
151301233	N50332	05/10/2015	20:13	05/10/2015	22:00	1	107	106	Tree related-tree broken	Overhead Service	Repair		II
151301238	S86597	05/10/2015	20:14	05/11/2015	1:50	1	336	336	Tree related-tree contact	Overhead Primary	Patrol/Test/Inspect	Repair	VI
151301242	E10001	05/10/2015	20:15	05/10/2015	22:30	5	675	135	Overhead equipment	Fuse	Replace - Same Size		III
5010671	Q54908	05/10/2015	20:16	05/11/2015	2:09	1	352	352	Tree related-tree contact	Overhead Service	Patrol/Test/Inspect	Replace - New Size	VI
5010673	Q21294	05/10/2015	20:16	05/10/2015	20:56	1	39	39	Weather				VI
151301255	V84531	05/10/2015	20:21	05/10/2015	23:16	1	175	175	Weather	Transformer Fuse	Replace - Same Size		II
151301423	Q01282	05/10/2015	20:22	05/10/2015	21:20	383	22214	58	Tree related-tree broken	Overhead Primary			III
5010681	Y86595	05/10/2015	20:22	05/10/2015	22:25	1	122	122	Tree related-tree broken	Overhead Service	Raise		IV
151301319	Q01282	05/10/2015	20:23	05/10/2015	21:41	1394	108732	77	Tree related-tree contact	Tree			III
151301262		05/10/2015	20:23	05/11/2015	2:32	1	369	368	Weather	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	III
5010687	Q21294	05/10/2015	20:25	05/10/2015	21:17	1	51	51	Weather				VI
151301285	N93260	05/10/2015	20:26	05/10/2015	21:25	1	59	58	Overhead equipment	Other			III
151301273	J50185	05/10/2015	20:34	05/10/2015	22:04	1	90	90	Overhead equipment				III
5010689	Q21294	05/10/2015	20:37	05/10/2015	21:20	1	42	42	Weather				VI
5010693	J82117	05/10/2015	20:41	05/11/2015	3:51	1	429	429	Tree related-tree broken	Overhead Service	Patrol/Test/Inspect	Repair	VI
151301348	P52306	05/10/2015	20:43	05/11/2015	5:30	32	16864	526	Tree related-tree contact	Overhead Primary	Patrol/Test/Inspect	Repair	IV
5010695	X02548	05/10/2015	20:45	05/11/2015	0:15	4	842	210	Tree related-tree broken	Tree	Trim		IV
5010777	Y28598	05/10/2015	20:47	05/10/2015	23:16	343	50849	148	Overhead equipment				IV
5010709	Y51506	05/10/2015	20:57	05/10/2015	23:25	1	147	147	Tree related-tree broken	Overhead Service	Repair		IV

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5010717	X99538	05/10/2015	21:01	05/11/2015	1:20	1	258	258	Weather	Overhead Transformer	Replace - Same Size	Replace - Same Size	IV
151310139	M12151	05/10/2015	21:08	05/11/2015	2:45	12	4044	336	Overhead equipment	Overhead Primary	Tie/Tighten	Repair	VI
5010737	Y05001	05/10/2015	21:12	05/11/2015	0:54	1	221	221	Tree related-tree broken	Overhead Service	Repair		IV
5010745	M19222	05/10/2015	21:15	05/10/2015	21:28	441	5635	12	Overhead equipment				VI
5010749	Q54908	05/10/2015	21:16	05/11/2015	0:29	3	579	193	Tree related-tree broken	Overhead Primary	Patrol/Test/Inspect	Repair	VI
5010779	Y28598	05/10/2015	21:21	05/10/2015	23:10	16	1735	108	Overhead equipment				IV
151301425	C10001	05/10/2015	21:25	05/11/2015	0:05	1	160	159	Overhead equipment				III
151301434	P67183	05/10/2015	21:27	05/11/2015	3:26	3	1077	358	Weather				VI
5010769	Q91141	05/10/2015	21:29	05/10/2015	21:55	8	204	25	Weather	Fuse	Replace - Same Size		I
5010773	K11372	05/10/2015	21:50	05/11/2015	2:01	1	251	251	Overhead equipment				V
151301469	K28180	05/10/2015	21:56	05/10/2015	22:48	1	52	51	Overhead equipment	Jumper	Repair		III
151301505	C52001	05/10/2015	22:13	05/10/2015	23:17	35	2240	63	Tree related-tree broken	Tree	Trim		III
151301512	C52001	05/10/2015	22:50	05/10/2015	23:24	1	34	33	Tree related-tree broken	Tree	Trim		III
151301517	B65004	05/10/2015	22:56	05/10/2015	23:30	1	34	33	Overhead equipment	Overhead Service	Repair		I
5010789	Y28598	05/10/2015	23:16	05/11/2015	5:54	343	136479	397	Overhead equipment	Pole	Patrol/Test/Inspect	Replace - Same Size	IV
151301539	A45001	05/10/2015	23:39	05/11/2015	2:45	1	186	185	Overhead equipment	Crossarm	Replace - Same Size	Repair	I
151301142	J74125	05/11/2015	0:06	05/11/2015	4:12	72	17712	246	Tree related-tree broken	Overhead Primary	Patrol/Test/Inspect	Raise	VI
151310150	S07535	05/11/2015	1:03	05/11/2015	4:11	79	14852	188	Substation equipment	Other	Repair	Repair	VI
5010813	B62003	05/11/2015	1:22	05/11/2015	10:51	8	4551	568	Tree related-tree broken	Pole	Replace - Same Size		I
5010793	B62003	05/11/2015	1:42	05/11/2015	2:55	10	732	73	Tree related-tree broken	Pole	Replace - Same Size		I
5010799	K11372	05/11/2015	2:02	05/11/2015	8:31	2	777	388	Tree related-tree broken				V
151310158	M09144	05/11/2015	2:12	05/11/2015	4:57	10	1650	165	Tree related-tree broken	Overhead Primary	Replace - Same Size	Repair	VI
151310162	L11242	05/11/2015	2:18	05/11/2015	3:54	15	1440	95	Unknown	Fuse	Replace - Same Size		III
5010811	B10002	05/11/2015	2:52	05/11/2015	6:45	1	232	232	Overhead equipment	Pole	Patrol/Test/Inspect	Replace - Same Size	I
5010833	M19222	05/11/2015	3:42	05/11/2015	4:06	271	6563	24	Overhead equipment				VI
5010843	M19222	05/11/2015	3:45	05/11/2015	4:06	170	3583	21	Overhead equipment				VI
5010845	Y93543	05/11/2015	3:59	05/11/2015	5:00	1	60	60	Animal related	Fuse	Repair	Replace - Same Size	IV
151312739	B71002	05/11/2015	4:30	05/11/2015	7:17	8	1336	166	Overhead equipment	Fuse		Repair	I
151312737	J74125	05/11/2015	5:00	05/11/2015	6:05	1	65	64	Overhead equipment	Transformer Fuse	Repair	Replace - Same Size	VI
5010851	A36001	05/11/2015	5:12	05/11/2015	7:58	1	165	165	Overhead equipment	Fuse	Replace - Same Size		I
151312997	M45211	05/11/2015	5:20	05/11/2015	8:20	13	2340	180	Weather	Jumper	Repair		IV
5010855	B10002	05/11/2015	5:32	05/11/2015	6:37	66	4303	65	Overhead equipment	Pole	Replace - Same Size		I
151312756	C10002	05/11/2015	5:37	05/11/2015	6:25	1	48	47	Overhead equipment	Overhead Primary			III
5010889	Y08552	05/11/2015	5:52	05/11/2015	7:39	465	49606	106	Overhead equipment	Recloser	Patrol/Test/Inspect	Switch/Reset	IV
151312933	S47576	05/11/2015	5:54	05/11/2015	7:50	6	696	116	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	VI
5010863	K32915	05/11/2015	5:54	05/11/2015	10:20	2	531	265	Tree related-tree broken				VI
5010865	P20930	05/11/2015	5:55	05/11/2015	9:46	17	3924	230	Tree related-tree contact	Tree	Trim	Remove	VI
151312771	K27150	05/11/2015	6:00	05/11/2015	8:30	1	150	149	Weather				VI
5010957	Q11517	05/11/2015	6:05	05/11/2015	8:15	86	11207	130	Overhead equipment	Connector		Replace - Same Size	I
5010877	Q11517	05/11/2015	6:05	05/11/2015	8:10	11	1374	124	Overhead equipment	Connector		Replace - Same Size	I
5010915	K46422	05/11/2015	6:16	05/11/2015	8:14	1	117	117	Overhead equipment				V
5010921	J87111	05/11/2015	6:20	05/11/2015	6:36	14	219	15	Overhead equipment				VI
151312805	E10002	05/11/2015	6:21	05/11/2015	9:09	2	336	168	Overhead equipment	Other	Replace - Same Size	Patrol/Test/Inspect	III
5010935	X60598	05/11/2015	6:28	05/11/2015	8:40	1	131	131	Overhead equipment	Jumper	Repair	Repair	IV
5010945	A36001	05/11/2015	6:34	05/11/2015	7:58	1	83	83	Overhead equipment	Fuse	Replace - Same Size		I
151312836	D72003	05/11/2015	6:41	05/11/2015	11:15	1	274	274	Tree related-tree broken	Other		Repair	I
151312837	B77003	05/11/2015	6:41	05/11/2015	11:33	1	292	291	Underground equipment	Other	Replace - Same Size	Replace - Same Size	I
151312852	P58155	05/11/2015	6:52	05/11/2015	7:16	1	24	23	Other				VI
151312851	K28183	05/11/2015	6:52	05/11/2015	13:26	31	12214	393	Overhead equipment	Tree	Trim		III
5010953	Y51506	05/11/2015	6:54	05/11/2015	7:52	7	405	57	Animal related	Fuse	Replace - Same Size		IV
5010955	J87111	05/11/2015	7:00	05/11/2015	11:54	9	2640	293	Overhead equipment				VI
151312917	K69117	05/11/2015	7:20	05/11/2015	12:30	1	310	310	Underground equipment	Underground Service	Repair		IV
5010959	D92001	05/11/2015	7:22	05/11/2015	8:50	2	174	87	Underground equipment	Underground Transformer	Replace - Same Size		I
151312963	P58155	05/11/2015	7:31	05/11/2015	9:06	1	95	94	Tree related-tree broken	Overhead Service	Reconnect		VI
151312995	P58155	05/11/2015	7:34	05/11/2015	10:11	18	2826	156	Tree related-tree broken	Fuse	Replace - Same Size		VI
5011063	J84145	05/11/2015	7:57	05/11/2015	8:52	1085	59729	55	Overhead equipment	Overhead Primary		Repair	VI

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5011067	J84146	05/11/2015	8:03	05/11/2015	12:38	1	274	274	Overhead equipment	Overhead Primary	Repair		VI
151313001	R48166	05/11/2015	8:06	05/11/2015	10:19	1	133	132	Tree related-tree broken	Tree	Remove		IV
5011077	J87111	05/11/2015	8:14	05/11/2015	9:04	9	443	49	Overhead equipment				VI
151313172	M21133	05/11/2015	8:28	05/11/2015	10:30	1	122	121	Tree related-tree broken	Overhead Primary	Repair	Repair	VI
5011081	J84145	05/11/2015	8:39	05/11/2015	11:44	90	16567	184	Tree related-tree broken	Overhead Primary	Repair	Repair	VI
151313255	A73002	05/11/2015	8:49	05/11/2015	10:03	29	2146	74	Tree related-tree broken	Fuse	Replace - Same Size		I
5011083	D28124	05/11/2015	8:54	05/11/2015	11:53	1	178	178	Overhead equipment	Overhead Service	Repair		I
5011087	J84145	05/11/2015	9:00	05/11/2015	9:12	1	11	11	Overhead equipment				VI
5011089	J01118	05/11/2015	9:00	05/11/2015	16:27	1	446	446	Underground equipment	Underground Primary	Repair	Replace - Urgent	I
5011095	J84145	05/11/2015	9:14	05/11/2015	10:16	1	61	61	Overhead equipment				VI
151313412	U04571	05/11/2015	9:31	05/11/2015	10:41	2	140	70	Tree related-tree broken	Transformer Fuse	Repair		II
151313435	Q75145	05/11/2015	9:32	05/11/2015	10:41	40	2760	69	Weather	Fuse	Replace - Same Size		VI
5011099	J89125	05/11/2015	9:34	05/11/2015	10:23	1	48	48	Other	Meter		Repair	VI
151313470	J14142	05/11/2015	9:41	05/11/2015	10:05	1	24	24	Animal related	Fuse	Replace - Same Size		VI
5011115	J86108	05/11/2015	9:42	05/11/2015	11:49	73	9214	126	Overhead equipment	Fuse	Repair	Repair	VI
5011107	J99141	05/11/2015	9:43	05/11/2015	12:10	1	146	146	Overhead equipment	Overhead Transformer		Replace - Same Size	VI
5011105	J84123	05/11/2015	9:43	05/11/2015	12:56	1	192	192	Overhead equipment	Overhead Service	Patrol/Test/Inspect		VI
5011111	B21001	05/11/2015	9:45	05/11/2015	11:50	1	124	124	Overhead equipment	Overhead Transformer	Replace - Same Size		I
151313513	U62510	05/11/2015	9:51	05/11/2015	10:26	2	70	34	Animal related	Transformer Fuse	Replace - Same Size		II
5011117	J87111	05/11/2015	9:51	05/11/2015	12:04	9	1189	132	Overhead equipment				VI
151313739	P73182	05/11/2015	9:54	05/11/2015	10:45	170	8670	50	Overhead equipment				VI
5011123	Y66557	05/11/2015	9:57	05/11/2015	10:34	16	593	37	Tree related-tree contact	Overhead Primary	Replace - Same Size		IV
5011127	Y66557	05/11/2015	9:59	05/11/2015	10:34	64	2227	34	Overhead equipment	Overhead Primary	Repair		IV
5011131	Y66557	05/11/2015	9:59	05/11/2015	11:16	1	76	76	Overhead equipment				IV
5011129	J86108	05/11/2015	9:59	05/11/2015	11:48	1	108	108	Overhead equipment	Transformer Fuse	Repair	Repair	VI
151313560	U62521	05/11/2015	10:00	05/11/2015	10:58	4	232	58	Animal related	Transformer Fuse	Replace - Same Size		II
5011135	Y66557	05/11/2015	10:00	05/11/2015	11:04	1	63	63	Overhead equipment	Overhead Primary	Replace - Same Size		IV
5011139	K32916	05/11/2015	10:08	05/11/2015	11:24	148	10462	75	Tree related-tree contact	Overhead Primary	Repair	Repair	VI
5011141	J87111	05/11/2015	10:11	05/11/2015	11:05	1	53	53	Overhead equipment	Transformer Fuse	Replace - Same Size		VI
151313709	S93507	05/11/2015	10:18	05/11/2015	11:00	30	1260	42	Overhead equipment	Disconnect Switch	Replace - Same Size		VI
151313740	N95823	05/11/2015	10:28	05/11/2015	12:16	13	1404	107	Animal related	Fuse	Replace - Same Size		V
5011149	A81003	05/11/2015	10:32	05/11/2015	12:05	74	6857	92	Animal related				I
151313781	M26164	05/11/2015	10:39	05/11/2015	11:35	1	56	56	Weather	Fuse	Replace - Same Size		III
5011151	Y66557	05/11/2015	10:39	05/11/2015	11:06	80	2144	26	Overhead equipment	Overhead Primary	Repair	Replace - Same Size	IV
5011155	J84145	05/11/2015	11:07	05/11/2015	12:34	1	86	86	Overhead equipment	Overhead Service	Patrol/Test/Inspect		VI
5011157	Y69553	05/11/2015	11:09	05/11/2015	11:33	11	256	23	Tree related-tree contact	Overhead Service	Repair	Repair	IV
151313957	V20512	05/11/2015	11:13	05/11/2015	12:19	3	198	65	Unknown	Transformer Fuse	Replace - Same Size		II
5011161	K32916	05/11/2015	11:24	05/11/2015	12:26	51	3173	62	Overhead equipment	Overhead Primary	Repair		VI
151314074	R66472	05/11/2015	11:34	05/11/2015	12:40	44	2904	66	Animal related	Fuse	Replace - Same Size		IV
151314069	T46003	05/11/2015	11:36	05/11/2015	12:34	1	58	58	Overhead equipment	Other	Patrol/Test/Inspect		VI
151314149	K89143	05/11/2015	11:44	05/11/2015	15:23	30	6570	219	Tree related-tree broken	Overhead Primary	Patrol/Test/Inspect	Repair	III
5011185	R10903	05/11/2015	12:16	05/11/2015	14:30	1	133	133	Tree related-tree broken	Tree	Trim		VI
5011187	K57211	05/11/2015	12:18	05/11/2015	14:20	1	121	121	Overhead equipment	Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
5011193	B58001	05/11/2015	12:29	05/11/2015	14:36	5	630	126	Unknown	Fuse	Replace - Same Size		I
5011197	N60181	05/11/2015	12:38	05/11/2015	14:45	1	126	126	Animal related	Transformer Fuse	Replace - Same Size	Patrol/Test/Inspect	I
5011201	M15375	05/11/2015	12:44	05/11/2015	13:51	1	66	66	Tree related-tree broken	Overhead Service	Repair		V
5011203	R23332	05/11/2015	12:50	05/11/2015	13:58	1	67	67	Underground equipment	Underground Service		Repair	V
5011205	D89003	05/11/2015	12:52	05/11/2015	13:55	1	62	62	Animal related	Transformer Fuse	Replace - Same Size		I
151314450	R66470	05/11/2015	12:55	05/11/2015	13:45	1	50	49	Animal related	Transformer Fuse	Replace - Same Size		IV
151314530	S47576	05/11/2015	13:06	05/11/2015	13:57	1	51	51	Overhead equipment	Transformer Fuse	Reconnect	Patrol/Test/Inspect	VI
151314610	Q75145	05/11/2015	13:23	05/11/2015	18:02	2	558	278	Overhead equipment	Overhead Transformer		Repair	VI
151314690	C10002	05/11/2015	13:39	05/11/2015	15:03	1	84	84	Tree related-tree contact	Other	Replace - Same Size	Patrol/Test/Inspect	III
5011209	P83710	05/11/2015	13:40	05/11/2015	15:12	1	91	91	Animal related	Transformer Fuse	Patrol/Test/Inspect	Repair	I
5011213	P09307	05/11/2015	13:48	05/11/2015	15:01	1	72	72	Tree related-tree contact	Overhead Service	Repair		V
151314759	P58159	05/11/2015	13:51	05/11/2015	14:42	1	51	51	Other	Connector	Tie/Tighten		VI
5011215	T42525	05/11/2015	13:51	05/11/2015	14:58	1	66	66	Animal related	Transformer Fuse	Replace - Same Size		IV

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5011217	Y07576	05/11/2015	13:54	05/11/2015	15:00	1	65	65	Underground equipment	Underground Service	Patrol/Test/Inspect	Patrol/Test/Inspect	IV
5011221	X96524	05/11/2015	14:01	05/11/2015	14:16	10	153	15	Overhead equipment	Overhead Primary	Replace - Same Size		IV
151314869	K78351	05/11/2015	14:13	05/11/2015	15:18	1	65	64	Overhead equipment	Connector	Repair		IV
151314950	342001	05/11/2015	14:33	05/11/2015	15:07	5	170	34	Overhead equipment	Overhead Transformer	Repair		VI
5011225	R08910	05/11/2015	14:33	05/11/2015	15:48	1	74	74	Weather	Fuse	Replace - Same Size		VI
5011229	J06167	05/11/2015	15:02	05/11/2015	17:10	1	127	127	Overhead equipment	Lightning Arrestor	Replace - Same Size		I
151315627	P58155	05/11/2015	15:14	05/11/2015	16:33	637	50323	78	Substation equipment				VI
151315289	P58155	05/11/2015	15:14	05/11/2015	16:53	953	94347	98	Substation equipment	Recloser		Replace - Same Size	VI
5011237	N05172	05/11/2015	15:22	05/11/2015	16:35	1	72	72	Animal related	Fuse	Repair	Repair	I
151315353	P58159	05/11/2015	15:34	05/11/2015	18:15	1	161	161	Substation equipment				VI
151315379	L17104	05/11/2015	15:41	05/11/2015	16:08	1	27	27	Tree related-tree contact	Fuse	Replace - Same Size		III
5011243	K43386	05/11/2015	15:44	05/11/2015	17:00	1	75	75	Animal related	Fuse	Replace - Same Size		V
151315401	B65003	05/11/2015	15:47	05/11/2015	17:17	1	90	90	Overhead equipment	Overhead Service	Repair		I
151315408	U01514	05/11/2015	15:50	05/11/2015	16:00	1	10	10	Overhead equipment				II
5011249	N05172	05/11/2015	16:18	05/11/2015	20:08	1	229	229	Overhead equipment	Overhead Transformer	Repair	Repair	I
151315530	M26164	05/11/2015	16:28	05/11/2015	17:30	1	62	61	Overhead equipment	Fuse	Repair		III
151315542	M26164	05/11/2015	16:31	05/11/2015	17:30	1	59	58	Overhead equipment	Fuse	Replace - Same Size		III
5011253	Y04504	05/11/2015	16:36	05/11/2015	18:30	1	113	113	Animal related	Transformer Fuse	Replace - Same Size		IV
151315574	M26164	05/11/2015	16:38	05/11/2015	17:30	10	520	51	Overhead equipment	Fuse	Repair		III
151315613	L68115	05/11/2015	16:58	05/11/2015	18:25	1	87	87	Tree related-tree broken	Overhead Service	Remove		IV
151315646	P58155	05/11/2015	17:06	05/11/2015	18:32	1	86	85	Substation equipment				VI
151315664	K09863	05/11/2015	17:12	05/11/2015	19:15	1	123	123	Underground equipment	Underground Service		Repair	V
151315682	S08548	05/11/2015	17:19	05/11/2015	19:56	1	157	156	Overhead equipment	Overhead Secondary	Repair		VI
5011259	K32935	05/11/2015	17:34	05/11/2015	21:34	13	3109	239	Tree related-tree broken	Overhead Primary	Replace - Same Size		VI
151315850	R24832	05/11/2015	17:45	05/11/2015	19:05	1	80	79	Overhead equipment	Connector	Replace - Same Size	Repair	V
5011261	D92001	05/11/2015	17:52	05/12/2015	4:29	1	636	636	Underground equipment	Underground Service	Patrol/Test/Inspect	Repair	I
151315989		05/11/2015	18:00	05/11/2015	18:52	4919	255788	52	Tree related-tree broken	Tree	Remove		IV
151316249	P73182	05/11/2015	18:44	05/11/2015	21:08	1	144	144	Other				VI
5011273	P26283	05/11/2015	18:46	05/11/2015	20:16	1	89	89	Overhead equipment	Jumper	Repair		I
151316592	L86175	05/11/2015	18:54	05/11/2015	19:17	628	14444	23	Overhead equipment	Substation Breaker	Switch/Reset		IV
151316283	N44215	05/11/2015	18:56	05/11/2015	20:48	1	112	111	Tree related-tree broken	Overhead Service	Repair		III
5011281	J71129	05/11/2015	19:39	05/11/2015	19:56	1	16	16	Overhead equipment	Overhead Service	Cut in Clear		I
5011283	K31124	05/11/2015	19:43	05/11/2015	20:45	1	61	61	Unknown	Overhead Transformer	Switch/Reset	Switch/Reset	I
5011287	R94269	05/11/2015	19:46	05/11/2015	21:03	1	76	76	Overhead equipment	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
151316683	309139	05/11/2015	20:34	05/12/2015	4:56	11	5522	502	Public	Pole	Patrol/Test/Inspect	Replace - Same Size	V
151316691	V65549	05/11/2015	20:42	05/12/2015	4:20	1	458	457	Underground equipment	Underground Service		Repair	II
5011291	K32935	05/11/2015	20:51	05/11/2015	21:34	1	42	42	Tree related-tree broken				VI
151316705	N44215	05/11/2015	20:57	05/11/2015	21:40	1	43	43	Tree related-tree broken	Overhead Service	Repair		III
5011295	N05173	05/11/2015	23:24	05/12/2015	1:10	1	105	105	Tree related-tree broken	Overhead Service	Repair	Repair	I
5011297	Y31589	05/11/2015	23:36	05/12/2015	0:20	1	43	43	Animal related	Fuse	Replace - Same Size		IV
5011299	J07135	05/12/2015	0:20	05/12/2015	1:25	1	64	64	Animal related	Transformer Fuse	Replace - Same Size		I
5011309	Q18244	05/12/2015	1:06	05/12/2015	4:52	10	2262	226	Underground equipment	Underground Primary			VI
151320163	P69174	05/12/2015	1:07	05/12/2015	4:10	38	6954	182	Underground equipment	Underground Primary		Repair	III
5011307	Q18244	05/12/2015	1:11	05/12/2015	4:59	7	1592	227	Underground equipment	Underground Primary			VI
5011311	Q18244	05/12/2015	1:33	05/12/2015	4:42	4	752	188	Underground equipment	Underground Primary	Repair	Replace - Same Size	VI
151320161	L70128	05/12/2015	1:40	05/12/2015	3:01	1	81	81	Overhead equipment	Tree	Remove		IV
151323064	U37579	05/12/2015	5:55	05/12/2015	7:00	6	390	64	Overhead equipment	Transformer Fuse			II
151323077	U01514	05/12/2015	6:24	05/12/2015	7:00	1	36	35	Animal related	Transformer Fuse	Replace - Same Size	Replace - Same Size	II
5011317	Y68-XTR1	05/12/2015	6:55	05/12/2015	6:58	763	1831	2	Unknown				IV
5011331	X83-XTR1	05/12/2015	6:55	05/12/2015	6:58	1129	2562	2	Overhead equipment				IV
5011327	Z29579	05/12/2015	6:55	05/12/2015	6:58	739	1677	2	Unknown				IV
5011329	B80002	05/12/2015	7:18	05/12/2015	12:00	1	281	281	Underground equipment	Underground Service	Patrol/Test/Inspect	Repair	I
5011333	Q18244	05/12/2015	7:34	05/12/2015	8:25	1	50	50	Animal related	Transformer Fuse			VI
151323226	U73583	05/12/2015	7:44	05/12/2015	9:00	1	76	75	Overhead equipment	Fuse	Replace - Same Size		II
151323494	U80511	05/12/2015	7:50	05/12/2015	10:20	12	1800	149	Underground equipment	Underground Primary			II
151323367	U80511	05/12/2015	7:50	05/12/2015	8:40	20	1000	49	Underground equipment	Underground Primary	Switch/Reset		II

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
151323288	B65004	05/12/2015	8:01	05/12/2015	9:38	1	97	97	Overhead equipment				I
5011345	Z37530	05/12/2015	8:07	05/12/2015	9:01	7	382	54	Public	Underground Primary	Repair	Repair	IV
151323320	U86500	05/12/2015	8:10	05/12/2015	9:53	7	721	103	Overhead equipment	Transformer Fuse	Repair	Repair	II
151323379	V29001	05/12/2015	8:21	05/12/2015	9:50	1	89	88	Tree related-tree contact	Overhead Service	Repair		II
151323420	V20512	05/12/2015	8:33	05/12/2015	9:54	1	81	81	Overhead equipment	Transformer Fuse	Repair		II
151323705	Q06132	05/12/2015	9:36	05/12/2015	15:14	1	338	338	Underground equipment	Underground Service	Repair		IV
151324013	L12125	05/12/2015	9:38	05/12/2015	10:54	18	1368	76	Animal related	Fuse	Replace - Same Size		III
151323768	M22812	05/12/2015	9:47	05/12/2015	11:27	1	100	100	Weather	Transformer Fuse	Replace - Same Size		V
151323814	J76804	05/12/2015	9:55	05/12/2015	11:26	1	91	91	Overhead equipment	Overhead Service	Repair	Repair	V
5011367	M31201	05/12/2015	10:16	05/12/2015	12:07	1	110	110	Tree related-tree broken	Overhead Service	Repair		I
151324034	A17021	05/12/2015	10:37	05/12/2015	11:32	1	55	55	Tree related-tree broken	Tree	Patrol/Test/Inspect		I
5011381	D88001	05/12/2015	10:40	05/12/2015	11:15	1	34	34	Animal related	Fuse	Replace - Same Size		I
151324302	J76805	05/12/2015	10:56	05/12/2015	13:18	18	2556	142	Tree related-tree broken	Overhead Primary	Repair	Repair	V
151324214	H10843	05/12/2015	11:07	05/12/2015	15:41	1	274	274	Underground equipment	Underground Service	Repair	Patrol/Test/Inspect	V
151324243	L79158	05/12/2015	11:14	05/12/2015	12:38	1	84	84	Overhead equipment	Transformer Fuse	Repair		IV
5011389	D92002	05/12/2015	11:32	05/12/2015	12:48	1	75	75	Overhead equipment	Fuse	Replace - Same Size		I
5011393	Q70161	05/12/2015	11:55	05/12/2015	13:22	1	86	86	Overhead equipment	Fuse	Repair		I
151324672	310122	05/12/2015	12:26	05/12/2015	14:45	7	973	139	Underground equipment	Underground Primary	Switch/Reset	Repair	V
151324627	B35002	05/12/2015	12:28	05/12/2015	12:50	1	22	21	Animal related	Fuse	Repair	Replace - Same Size	I
151324637	S27599	05/12/2015	12:31	05/12/2015	13:21	1	50	50	Overhead equipment	Transformer Fuse	Repair	Replace - Same Size	VI
5011399	Y73504	05/12/2015	12:45	05/12/2015	15:10	20	2900	145	Underground equipment	Underground Primary		Repair	IV
5011403	X66582	05/12/2015	12:48	05/12/2015	13:34	1	45	45	Animal related				IV
5011405	M15375	05/12/2015	12:55	05/12/2015	13:39	1	43	43	Tree related-tree broken	Customer Equipment	Cut in Clear	Repair	V
5011415	P49188	05/12/2015	13:37	05/12/2015	17:29	10	2325	232	Underground equipment	Underground Primary	Patrol/Test/Inspect	Switch/Reset	I
151325046	U60559	05/12/2015	13:57	05/12/2015	14:35	1	38	37	Overhead equipment				II
5011419	A97003	05/12/2015	14:07	05/12/2015	15:30	1	82	82	Overhead equipment	Connector	Replace - Same Size		I
5011423	L93149	05/12/2015	14:16	05/12/2015	19:09	1	292	292	Underground equipment	Underground Service	Disconnect	Repair	VI
151325160	D32212	05/12/2015	14:17	05/12/2015	15:00	1	43	43	Unknown	Fuse	Repair		I
151325243	M21134	05/12/2015	14:30	05/12/2015	15:57	1	87	87	Animal related	Transformer Fuse	Replace - Same Size		VI
151325340	Q28141	05/12/2015	14:52	05/12/2015	16:00	1	68	68	Animal related	Fuse	Replace - Same Size		VI
151325378	L70127	05/12/2015	14:58	05/12/2015	16:19	1	81	80	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
5011433	X99538	05/12/2015	15:13	05/12/2015	16:25	1	71	71	Overhead equipment	Fuse			IV
151325569	L12125	05/12/2015	15:44	05/12/2015	16:38	1	54	54	Animal related	Fuse	Repair	Replace - Same Size	III
151325647	U52516	05/12/2015	16:05	05/12/2015	17:31	1	86	85	Animal related	Transformer Fuse	Replace - Same Size		II
5011441	B93002	05/12/2015	16:06	05/12/2015	17:34	1	87	87	Animal related	Transformer Fuse	Replace - Same Size		I
5011443	C01001	05/12/2015	16:11	05/12/2015	17:15	1	63	63	Animal related	Fuse	Replace - Same Size		I
5011447	P49180	05/12/2015	16:11	05/12/2015	18:17	51	3468	125	Public	Underground Primary	Repair	Replace - Same Size	I
151325847	K91117	05/12/2015	17:09	05/12/2015	17:55	1	46	46	Tree related-tree broken	Tree	Remove		III
151325870	U99593	05/12/2015	17:21	05/12/2015	18:24	2	126	63	Animal related	Transformer Fuse	Repair		II
151325937	F03003	05/12/2015	17:55	05/12/2015	18:20	1	25	24	Animal related	Transformer Fuse	Replace - Same Size		III
151325960	D72003	05/12/2015	18:08	05/12/2015	18:56	1	48	47	Animal related	Transformer Fuse	Replace - Same Size	Replace - Same Size	I
151325962	A45002	05/12/2015	18:12	05/12/2015	19:21	1	69	69	Animal related	Fuse	Replace - Same Size		I
151325998	N44215	05/12/2015	18:33	05/12/2015	19:30	1	57	56	Unknown	Fuse	Replace - Same Size		III
5011461	P49180	05/12/2015	18:43	05/12/2015	19:41	4	229	57	Overhead equipment	Overhead Primary	Raise	Tie/Tighten	I
5011465	X66582	05/12/2015	18:50	05/12/2015	22:17	4	827	206	Animal related	Transformer Fuse	Replace - Same Size		IV
5011471	Q95249	05/12/2015	19:10	05/12/2015	19:37	1	26	26	Animal related	Transformer Fuse			VI
5011473	Q32170	05/12/2015	19:31	05/12/2015	20:45	1	73	73	Animal related	Transformer Fuse	Replace - Same Size	Patrol/Test/Inspect	I
5011475	Y69565	05/12/2015	20:54	05/13/2015	2:48	29	10263	353	Overhead equipment	Overhead Primary	Repair	Repair	IV
5011485	Y51506	05/12/2015	22:52	05/12/2015	23:42	1	49	49	Animal related	Transformer Fuse	Replace - Same Size		IV
5011487	K01240	05/12/2015	23:18	05/13/2015	0:18	1	59	59	Animal related	Transformer Fuse	Replace - Same Size		VI
5011489	M41113	05/13/2015	0:40	05/13/2015	1:55	9	671	74	Public	Pole	Cut in Clear		I
151330249	D36002	05/13/2015	2:33	05/13/2015	3:40	19	1273	67	Animal related	Fuse	Replace - Same Size		I
151332812	L24123	05/13/2015	3:15	05/13/2015	5:29	1	134	134	Overhead equipment	Fuse	Replace - Same Size		III
151332816	310124	05/13/2015	3:28	05/13/2015	10:40	1	432	432	Tree related-tree broken	Overhead Primary		Repair	V
151332821	K89143	05/13/2015	4:06	05/13/2015	6:02	1	116	116	Animal related	Transformer Fuse	Replace - Same Size		III
5011503	P49188	05/13/2015	5:50	05/13/2015	11:30	1	339	339	Underground equipment	Underground Secondary	Patrol/Test/Inspect	Advise Customer	I

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5011505	Q91141	05/13/2015	6:11	05/13/2015	7:00	1	49	48	Animal related	Transformer Fuse	Replace - Same Size		I
151332847	M07236	05/13/2015	6:35	05/13/2015	7:42	1	67	66	Animal related	Transformer Fuse	Replace - Same Size		III
5011507	D87001	05/13/2015	6:38	05/13/2015	14:13	1	454	454	Underground equipment	Underground Service	Patrol/Test/Inspect	Replace - Urgent	I
151332855	P58156	05/13/2015	6:41	05/13/2015	6:53	1	12	12	Animal related	Fuse	Repair	Repair	VI
5011509	X88510	05/13/2015	6:56	05/13/2015	8:00	1	63	63	Overhead equipment	Overhead Service	Repair		IV
151332905	P05825	05/13/2015	7:19	05/13/2015	8:20	4	244	60	Animal related	Transformer Fuse	Replace - Same Size		V
5011511	HB6283	05/13/2015	7:28	05/13/2015	8:49	2	162	80	Animal related	Fuse	Repair		VI
5011513	A85002	05/13/2015	7:33	05/13/2015	9:26	1	112	112	Unknown	Fuse	Replace - Same Size		I
151332958	S49549	05/13/2015	7:41	05/13/2015	8:34	1	53	52	Underground equipment				VI
151332969	B19002	05/13/2015	7:47	05/13/2015	9:43	1	116	116	Animal related	Fuse	Replace - Same Size		I
5011515	HB6283	05/13/2015	7:57	05/13/2015	8:49	1	51	51	Animal related	Fuse	Repair		VI
151333142	301052	05/13/2015	8:30	05/13/2015	9:10	1	40	40	Animal related	Fuse	Repair		VI
151333268	D69005	05/13/2015	8:50	05/13/2015	11:21	41	6191	150	Underground equipment	Underground Primary	Repair	Repair	I
151333231	J39391	05/13/2015	8:51	05/13/2015	13:50	1	299	299	Underground equipment	Underground Secondary			III
5011521	P82291	05/13/2015	9:03	05/13/2015	10:49	1	105	105	Overhead equipment	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
151333364	A17026	05/13/2015	9:17	05/13/2015	16:38	1	441	441	Underground equipment	Other	Repair	Repair	I
151333462	T08502	05/13/2015	9:36	05/13/2015	10:08	1	32	31	Animal related	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
151333469	L00133	05/13/2015	9:37	05/13/2015	10:58	1	81	81	Animal related	Fuse			III
151333505	V45526	05/13/2015	9:47	05/13/2015	10:44	10	570	57	Animal related	Transformer Fuse	Replace - Same Size		II
5011547	M49411	05/13/2015	10:10	05/13/2015	11:39	33	2908	88	Weather	Fuse	Replace - Same Size		V
151333638	B38002	05/13/2015	10:11	05/13/2015	11:35	1	84	84	Overhead equipment	Jumper	Replace - Same Size		I
151333694	C36001	05/13/2015	10:25	05/13/2015	12:46	1	141	140	Underground equipment	Underground Service	Repair		III
5011563	N86228	05/13/2015	11:56	05/13/2015	13:51	1	114	114	Overhead equipment	Overhead Service	Patrol/Test/Inspect	Repair	VI
151334240	T09559	05/13/2015	12:24	05/13/2015	13:15	1	51	50	Tree related-tree contact	Overhead Service	Patrol/Test/Inspect	Repair	VI
151334253	K27153	05/13/2015	12:27	05/13/2015	13:05	1	38	37	Overhead equipment	Overhead Service	Repair		VI
151334262	R48166	05/13/2015	12:30	05/13/2015	13:26	1	56	55	Animal related	Fuse			IV
5011567	X34531	05/13/2015	13:04	05/13/2015	15:07	1	122	122	Animal related	Fuse	Replace - New Size	Replace - New Size	IV
5011569	B93002	05/13/2015	13:08	05/13/2015	14:00	1	51	51	Overhead equipment	Fuse			I
151334531	S41565	05/13/2015	13:23	05/13/2015	14:19	1	56	56	Overhead equipment	Connector	Repair	Replace - Same Size	VI
151334580	J50186	05/13/2015	13:35	05/13/2015	14:06	1	31	31	Animal related	Fuse			III
5011581	K48380	05/13/2015	13:35	05/13/2015	14:28	1	52	52	Overhead equipment	Connector	Repair		V
151334672	S31532	05/13/2015	13:53	05/13/2015	21:16	1	443	442	Underground equipment	Underground Primary	Repair	Repair	VI
151334689	K79651	05/13/2015	13:57	05/13/2015	14:42	1	45	45	Underground equipment				IV
5011591	Z11536	05/13/2015	14:15	05/13/2015	15:20	1	64	64	Animal related	Transformer Fuse	Repair		IV
151334813	J75272	05/13/2015	14:20	05/13/2015	19:00	1	280	280	Underground equipment	Underground Secondary	Patrol/Test/Inspect	Repair	IV
5011597	P09307	05/13/2015	14:25	05/13/2015	17:18	1	172	172	Tree related-tree broken	Connector	Repair		V
5011609	X66582	05/13/2015	15:20	05/13/2015	16:12	1	51	51	Animal related	Transformer Fuse	Replace - Same Size		IV
151335303	L95110	05/13/2015	15:39	05/13/2015	16:14	102	3570	34	Public				III
151335178	L95110	05/13/2015	15:39	05/13/2015	17:00	5	405	81	Public	Tree	Patrol/Test/Inspect	Remove	III
5011619	N94180	05/13/2015	15:43	05/13/2015	17:45	1	121	121	Overhead equipment	Overhead Service	Repair	Repair	I
5011625	L59929	05/13/2015	16:48	05/13/2015	21:14	1	265	265	Underground equipment	Underground Service	Repair	Repair	VI
5011627	Y37592	05/13/2015	16:56	05/13/2015	18:25	1	88	88	Overhead equipment	Fuse	Repair		IV
151335411	L81141	05/13/2015	16:57	05/13/2015	18:38	1	101	100	Animal related	Transformer Fuse	Replace - Same Size		IV
151335434	U10547	05/13/2015	17:08	05/13/2015	18:40	1	92	92	Overhead equipment	Transformer Fuse	Replace - Same Size	Patrol/Test/Inspect	II
151335470	J47178	05/13/2015	17:32	05/13/2015	23:57	1	385	384	Underground equipment	Underground Secondary			III
151335580	D70001	05/13/2015	17:41	05/13/2015	23:50	1	369	368	Underground equipment	Underground Service	Repair	Repair	I
5011629	X36550	05/13/2015	17:43	05/13/2015	20:50	5	931	186	Overhead equipment	Overhead Transformer	Replace - Same Size	Replace - Same Size	IV
151335586	S43512	05/13/2015	17:46	05/13/2015	20:15	1	149	149	Overhead equipment	Connector	Patrol/Test/Inspect	Repair	VI
5011635	J86118	05/13/2015	19:11	05/13/2015	22:32	1	200	200	Overhead equipment	Transformer Fuse		Replace - Same Size	VI
5011641	Z04002	05/13/2015	19:53	05/13/2015	20:06	7	86	12	Overhead equipment				IV
151335981	M09143	05/13/2015	20:16	05/13/2015	21:30	1	74	74	Unknown				VI
5011645	Z06537	05/13/2015	20:42	05/13/2015	22:17	46	4385	95	Underground equipment	Underground Primary	Repair	Repair	IV
5011651	Z06537	05/13/2015	20:45	05/14/2015	1:48	39	9647	303	Underground equipment	Underground Primary	Repair	Repair	IV
151336174	B19002	05/13/2015	21:54	05/14/2015	4:34	1	400	400	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
151336320	N50334	05/13/2015	23:10	05/14/2015	0:23	1	73	72	Overhead equipment	Connector	Replace - Same Size		II
151340110	U73599	05/14/2015	2:10	05/14/2015	4:40	1	150	149	Animal related	Transformer Fuse	Replace - Same Size		II

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
151342156	V69546	05/14/2015	3:15	05/14/2015	4:51	1	96	95	Animal related	Transformer Fuse	Repair		II
5011659	P82291	05/14/2015	3:23	05/14/2015	5:10	1	106	106	Animal related	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
151342169	U10525	05/14/2015	4:17	05/14/2015	6:00	1	103	103	Overhead equipment	Transformer Fuse	Replace - Same Size	Patrol/Test/Inspect	II
151342222	C52002	05/14/2015	6:16	05/14/2015	6:28	1	12	11	Unknown				III
5011663	K46388	05/14/2015	6:41	05/14/2015	7:27	1	45	45	Animal related	Fuse	Replace - Same Size	Replace - Same Size	V
151342247	S07536	05/14/2015	6:50	05/14/2015	7:55	1	65	65	Animal related	Fuse	Patrol/Test/Inspect	Repair	VI
151342290	L35138	05/14/2015	7:03	05/14/2015	7:40	23	851	37	Animal related	Fuse	Replace - Same Size		III
5011665	K46388	05/14/2015	7:05	05/14/2015	7:29	1	23	23	Animal related	Fuse	Replace - Same Size	Replace - Same Size	V
151342285	Q83171	05/14/2015	7:07	05/14/2015	9:24	1	137	137	Overhead equipment	Overhead Secondary	Replace - Same Size	Replace - Same Size	VI
5011679	R60551	05/14/2015	7:28	05/14/2015	8:20	2	103	51	Animal related	Transformer Fuse	Replace - Same Size		IV
5011685	Q16867	05/14/2015	7:31	05/14/2015	8:47	1	75	75	Animal related	Transformer Fuse	Replace - Same Size		V
151342419		05/14/2015	8:09	05/14/2015	9:26	1	77	76	Overhead equipment	Transformer Fuse	Repair		II
5011691	K94223	05/14/2015	8:22	05/14/2015	9:15	5	263	52	Other	Other			III
151342472	S14511	05/14/2015	8:26	05/14/2015	9:47	1	81	80	Animal related	Transformer Fuse	Replace - Same Size		VI
151342507	U37579	05/14/2015	8:37	05/14/2015	9:17	1	40	40	Overhead equipment	Overhead Secondary	Repair		II
151342680	S14511	05/14/2015	9:29	05/14/2015	9:55	1	26	26	Animal related	Transformer Fuse	Replace - Same Size		VI
5011713	Y66557	05/14/2015	9:49	05/14/2015	13:21	4	844	211	Public				IV
5011719	Z57516	05/14/2015	10:21	05/14/2015	11:58	3	290	96	Animal related	Transformer Fuse			IV
5011727	H06135	05/14/2015	10:52	05/14/2015	12:20	14	1233	88	Underground equipment	Underground Primary			IV
5011741	L82187	05/14/2015	11:18	05/14/2015	13:27	1	128	128	Animal related	Transformer Fuse	Replace - Same Size		IV
5011743	D60001	05/14/2015	11:19	05/14/2015	13:24	1	124	124	Underground equipment	Underground Service	Repair		III
151343189	D70004	05/14/2015	11:27	05/14/2015	12:05	1	38	37	Other	Meter	Reconnect		I
5011751	D87001	05/14/2015	11:35	05/14/2015	14:56	1	200	200	Underground equipment	Underground Service	Patrol/Test/Inspect	Repair	I
151343341	C40002	05/14/2015	11:45	05/14/2015	15:03	25	4950	197	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
5011767	M81404	05/14/2015	12:41	05/14/2015	14:25	304	31777	104	Overhead equipment	Substation Misc.			V
5011797	R59415	05/14/2015	12:54	05/14/2015	14:06	1	71	71	Other				IV
151343531	D35002	05/14/2015	12:55	05/14/2015	13:47	1	52	52	Overhead equipment	Disconnect Switch	Replace - Same Size	Replace - Same Size	I
5011811	N60181	05/14/2015	13:13	05/14/2015	14:30	56	4262	76	Animal related	Recloser	Patrol/Test/Inspect	Switch/Reset	I
5011833	R94269	05/14/2015	13:43	05/14/2015	16:50	1	187	187	Public	Underground Service	Patrol/Test/Inspect	Repair	VI
5011843	H10843	05/14/2015	14:36	05/14/2015	15:56	1	79	79	Overhead equipment	Transformer Fuse	Replace - Same Size		V
5011857	C70001	05/14/2015	15:17	05/14/2015	16:15	1	57	57	Overhead equipment	Fuse	Replace - Same Size		III
5011859	Y79500	05/14/2015	15:18	05/14/2015	17:30	1	131	131	Overhead equipment	Connector	Replace - Same Size		IV
5011863	342002	05/14/2015	16:25	05/14/2015	17:32	7	464	66	Tree related-tree contact	Tree	Patrol/Test/Inspect		VI
5011871	L23148	05/14/2015	16:44	05/14/2015	18:12	1	87	87	Tree related-tree broken	Overhead Service	Repair		III
151344426	U13551	05/14/2015	16:53	05/14/2015	22:36	18	6174	342	Overhead equipment	Pole	Replace - New Size	Patrol/Test/Inspect	II
151344781	U13551	05/14/2015	16:53	05/14/2015	18:33	101	10100	100	Overhead equipment	Pole	Replace - Same Size		II
151344513	V04716	05/14/2015	17:42	05/14/2015	19:14	1	92	91	Tree related-tree broken	Substation Breaker		Patrol/Test/Inspect	II
151344544	D81002	05/14/2015	18:20	05/14/2015	19:20	1	60	59	Animal related	Fuse	Replace - Same Size		I
5011879	Q91175	05/14/2015	18:25	05/14/2015	20:00	1	94	94	Animal related	Transformer Fuse	Replace - Same Size		I
151344557	T04512	05/14/2015	18:29	05/14/2015	21:35	1	186	185	Overhead equipment	Overhead Service	Repair	Replace - Same Size	VI
5011883	L23145	05/14/2015	19:48	05/14/2015	20:50	1	61	61	Overhead equipment	Jumper	Repair		III
5011887	R42914	05/14/2015	21:46	05/14/2015	23:17	1	90	90	Animal related	Fuse	Patrol/Test/Inspect		VI
5011889	Y68582	05/14/2015	22:03	05/14/2015	23:53	5	547	109	Overhead equipment	Disconnect Switch	Replace - New Size		IV
5011917	M07236	05/14/2015	23:17	05/15/2015	0:56	94	9338	99	Overhead equipment	Jumper	Repair		III
5011905	B93002	05/14/2015	23:25	05/15/2015	1:08	29	2964	102	Underground equipment	Fuse	Replace - Same Size		I
5011909	B93002	05/14/2015	23:36	05/15/2015	5:07	2	432	331	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
5011911	M07236	05/14/2015	23:40	05/15/2015	0:59	1	78	78	Overhead equipment	Jumper	Repair		III
5011923	R42914	05/15/2015	0:45	05/15/2015	5:15	1	269	269	Overhead equipment	Overhead Transformer		Replace - Same Size	VI
5011925	R05115	05/15/2015	1:38	05/15/2015	2:27	1	48	48	Animal related	Transformer Fuse	Replace - Same Size		I
5011929	Q91141	05/15/2015	2:31	05/15/2015	5:47	1	195	195	Unknown	Fuse	Patrol/Test/Inspect	Replace - Same Size	I
151353442	D01002	05/15/2015	4:59	05/15/2015	6:16	4	308	76	Animal related	Fuse	Replace - Same Size		I
5011933	L17101	05/15/2015	6:17	05/15/2015	7:00	4	171	42	Animal related	Fuse	Replace - Same Size	Repair	III
151353472	N50334	05/15/2015	6:26	05/15/2015	6:58	37	1184	31	Animal related	Fuse	Replace - Same Size		II
5011935	P26284	05/15/2015	6:40	05/15/2015	7:56	1	75	75	Animal related	Fuse	Replace - Same Size	Repair	I
151353483	S49550	05/15/2015	6:47	05/15/2015	7:52	1	65	65	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	VI
5011941	P52305	05/15/2015	7:20	05/15/2015	8:40	1	80	79	Animal related	Transformer Fuse	Replace - Same Size		IV

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
151353565	N54107	05/15/2015	7:34	05/15/2015	8:25	7	357	50	Animal related	Fuse	Replace - Same Size		II
151353640	K27153	05/15/2015	7:55	05/15/2015	8:34	29	1131	39	Animal related	Fuse	Replace - Same Size		VI
5011949	P20930	05/15/2015	8:25	05/15/2015	9:21	1	55	55	Animal related	Fuse	Replace - Same Size		VI
151353786	D81002	05/15/2015	8:44	05/15/2015	9:30	1	46	46	Animal related	Fuse	Replace - Same Size		I
151354008	A45003	05/15/2015	9:35	05/15/2015	10:50	1	75	75	Animal related	Fuse	Replace - Same Size		I
151354054	U80564	05/15/2015	9:48	05/15/2015	10:20	1	32	31	Animal related	Transformer Fuse	Replace - Same Size		II
5011979	R08910	05/15/2015	10:33	05/15/2015	11:21	1	47	47	Tree related-tree broken	Fuse	Replace - Same Size		VI
5011989	R59422	05/15/2015	11:23	05/15/2015	12:15	63	3241	51	Animal related	Fuse	Replace - Same Size		IV
5011993	D89002	05/15/2015	11:33	05/15/2015	12:25	1	51	51	Animal related	Transformer Fuse	Replace - Same Size		I
5011999	N94180	05/15/2015	11:41	05/15/2015	13:00	1	78	78	Unknown	Fuse	Replace - Same Size		I
5012007	Q34360	05/15/2015	11:55	05/15/2015	16:59	1	303	303	Underground equipment	Underground Service	Patrol/Test/Inspect	Repair	I
151354636	V41568	05/15/2015	12:21	05/15/2015	16:12	1	231	231	Underground equipment	Underground Primary			II
151354733	T28562	05/15/2015	12:46	05/15/2015	15:25	1	159	158	Overhead equipment	Fuse	Repair	Replace - Same Size	VI
5012033	J82106	05/15/2015	13:19	05/15/2015	13:57	1	37	37	Overhead equipment	Fuse	Replace - Same Size		VI
5012035	Q82906	05/15/2015	13:40	05/15/2015	18:18	1	277	277	Weather	Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
5012037	N93260	05/15/2015	13:41	05/15/2015	14:57	39	2958	75	Overhead equipment				III
5012051	308004	05/15/2015	13:51	05/15/2015	15:38	32	3396	106	Weather	Fuse	Replace - Same Size		VI
5012047	P69174	05/15/2015	13:52	05/15/2015	15:00	1	67	67	Overhead equipment	Fuse	Repair	Replace - Same Size	III
5012055	P20930	05/15/2015	13:57	05/15/2015	15:08	383	27277	71	Public				VI
5012057	302002	05/15/2015	13:57	05/15/2015	15:19	20	1622	81	Weather	Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
5012063	HB6283	05/15/2015	14:01	05/15/2015	14:55	1	53	53	Weather	Transformer Fuse	Replace - Same Size		VI
5012061	M61302	05/15/2015	14:01	05/15/2015	15:13	30	2137	71	Tree related-tree broken	Fuse	Repair		V
5012087	303001	05/15/2015	14:03	05/15/2015	22:15	68	18785	491	Overhead equipment	Overhead Primary	Patrol/Test/Inspect	Repair	VI
5012069	P20930	05/15/2015	14:05	05/15/2015	15:00	1	54	54	Overhead equipment				VI
5012071	M54314	05/15/2015	14:05	05/15/2015	16:00	1	114	114	Tree related-tree broken	Overhead Service	Repair		V
5012073	P20930	05/15/2015	14:06	05/15/2015	15:00	1	54	53	Overhead equipment				VI
5012075	P20930	05/15/2015	14:06	05/15/2015	15:00	1	53	53	Overhead equipment				VI
5012077	J82116	05/15/2015	14:06	05/15/2015	16:12	1	125	125	Overhead equipment	Lightning Arrestor	Replace - Same Size		VI
5012369	342004	05/15/2015	14:06	05/16/2015	1:11	4	2656	664	Tree related-tree broken	Overhead Secondary	Patrol/Test/Inspect	Repair	VI
5012083	337003	05/15/2015	14:06	05/15/2015	17:40	3	639	213	Weather	Fuse	Replace - Same Size		VI
5012081	P20930	05/15/2015	14:07	05/15/2015	15:00	1	53	53	Overhead equipment				VI
5012085	M54314	05/15/2015	14:08	05/15/2015	16:50	1	161	161	Tree related-tree broken	Overhead Service	Repair		V
5012089	IP9009	05/15/2015	14:10	05/15/2015	16:30	7	974	139	Tree related-tree broken	Overhead Transformer	Patrol/Test/Inspect		VI
5012091	303004	05/15/2015	14:10	05/16/2015	5:35	10	9240	924	Tree related-tree broken	Overhead Secondary	Patrol/Test/Inspect		VI
5012093	303004	05/15/2015	14:11	05/16/2015	5:25	5	4568	913	Tree related-tree broken	Overhead Secondary	Patrol/Test/Inspect	Trim	VI
5012097	303005	05/15/2015	14:11	05/15/2015	16:15	15	1849	123	Overhead equipment	Disconnect Switch	Replace - Same Size		VI
5012107	302003	05/15/2015	14:16	05/15/2015	17:00	58	9459	163	Overhead equipment				VI
5012103	J20931	05/15/2015	14:17	05/15/2015	15:17	1	59	59	Weather	Fuse	Replace - Same Size		VI
151355332	V36001	05/15/2015	14:18	05/15/2015	18:14	1	236	236	Underground equipment	Underground Service		Repair	II
5012105	M73330	05/15/2015	14:18	05/15/2015	15:47	1	88	88	Tree related-tree broken	Overhead Service	Cut in Clear		V
5012115	303005	05/15/2015	14:20	05/15/2015	17:45	4	816	204	Overhead equipment	Fuse	Replace - Same Size		VI
5012127	K71821	05/15/2015	14:26	05/15/2015	16:04	107	10391	97	Overhead equipment	Jumper	Repair		IV
5012121	P20930	05/15/2015	14:28	05/15/2015	15:00	1	31	31	Overhead equipment				VI
5012123	342004	05/15/2015	14:28	05/15/2015	17:36	3	561	187	Weather	Overhead Transformer	Switch/Reset		VI
5012129	R58962	05/15/2015	14:32	05/16/2015	0:14	1	581	581	Underground equipment	Underground Transformer	Replace - Same Size		IV
5012133	P20930	05/15/2015	14:32	05/15/2015	15:00	4	109	27	Overhead equipment				VI
5012139	325007	05/15/2015	14:34	05/15/2015	19:30	1	295	295	Weather	Overhead Primary	Patrol/Test/Inspect		VI
5012141	P42230	05/15/2015	14:37	05/15/2015	16:25	1	107	107	Weather	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
5012147	P20930	05/15/2015	14:45	05/15/2015	15:00	1	14	14	Overhead equipment				VI
5012227	Q15844	05/15/2015	14:45	05/15/2015	18:22	16	3467	216	Weather	Fuse	Replace - Same Size		V
5012161	341001	05/15/2015	14:46	05/15/2015	18:34	24	5463	227	Weather	Overhead Primary	Patrol/Test/Inspect	Repair	VI
5012155	P20930	05/15/2015	14:48	05/15/2015	15:00	1	11	11	Overhead equipment				VI
5012157	303005	05/15/2015	14:50	05/15/2015	15:18	1	27	27	Weather	Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
5012167	303004	05/15/2015	15:00	05/15/2015	17:00	1	119	119	Tree related-tree broken	Overhead Secondary	Patrol/Test/Inspect	Repair	VI
151355642	U91599	05/15/2015	15:01	05/15/2015	17:15	1	134	133	Underground equipment	Underground Primary	Repair		II
151355835	V25513	05/15/2015	15:03	05/15/2015	17:15	16	2112	132	Weather	Fuse		Replace - New Size	II

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
151355827	V25513	05/15/2015	15:04	05/15/2015	17:10	17	2142	126	Weather				II
151355687	U60518	05/15/2015	15:07	05/15/2015	16:56	26	2834	108	Tree related-tree broken	Fuse		Replace - New Size	II
5012173	P05825	05/15/2015	15:11	05/15/2015	19:50	4	1115	278	Weather	Fuse	Replace - Same Size		V
5012175	K28180	05/15/2015	15:12	05/15/2015	19:12	3	718	239	Public	Pole	Replace - Same Size	Replace - New Size	III
151356583	U60518	05/15/2015	15:14	05/15/2015	20:08	27	7938	293	Tree related-tree broken	Fuse		Replace - New Size	II
5012181	P20930	05/15/2015	15:23	05/15/2015	15:26	1	2	2	Unknown				VI
5012183	M22812	05/15/2015	15:37	05/15/2015	17:15	20	1948	97	Weather	Fuse	Replace - Same Size		V
151355887	T06505	05/15/2015	15:38	05/15/2015	16:49	56	3976	71	Tree related-tree broken	Overhead Primary	Trim		VI
151355896	T12527	05/15/2015	15:41	05/15/2015	18:45	1	184	184	Tree related-tree broken	Overhead Service	Patrol/Test/Inspect	Repair	VI
151355954	M21133	05/15/2015	15:53	05/15/2015	16:30	1	37	36	Tree related-tree broken	Overhead Service	Repair	Repair	VI
5012377	342004	05/15/2015	15:53	05/16/2015	1:11	1	557	557	Tree related-tree broken	Tree	Trim	Remove	VI
151355958	T06537	05/15/2015	15:54	05/15/2015	17:00	2	132	66	Weather	Fuse	Patrol/Test/Inspect	Repair	VI
151355965	T06537	05/15/2015	15:55	05/15/2015	16:58	6	378	62	Weather	Fuse	Repair	Repair	VI
5012199	J01118	05/15/2015	15:57	05/15/2015	16:13	1	15	15	Jurisdictional				I
5012201	M81402	05/15/2015	16:00	05/15/2015	18:47	4	666	166	Tree related-tree broken	Overhead Secondary	Patrol/Test/Inspect	Repair	V
5012211	J01118	05/15/2015	16:00	05/15/2015	17:04	94	6003	63	Jurisdictional				I
151356058	T06537	05/15/2015	16:02	05/15/2015	17:09	4	268	66	Overhead equipment	Fuse	Repair	Repair	VI
5012205	J01118	05/15/2015	16:02	05/15/2015	17:04	96	6007	62	Jurisdictional				I
5012213	J01118	05/15/2015	16:04	05/15/2015	16:13	4	32	8	Jurisdictional				I
151356445	HD0573	05/15/2015	16:17	05/15/2015	16:50	2	66	33	Weather	Fuse	Replace - Same Size	Replace - Same Size	VI
5012279	C52002	05/15/2015	16:21	05/15/2015	20:04	5	1113	222	Tree related-tree broken	Overhead Primary	Repair		III
5012235	C52002	05/15/2015	16:21	05/15/2015	17:41	39	3090	79	Overhead equipment	Fuse	Replace - Same Size		III
5012237	N93260	05/15/2015	16:39	05/15/2015	17:50	1	70	70	Animal related	Transformer Fuse	Replace - Same Size		III
5012241	308004	05/15/2015	16:46	05/16/2015	2:35	8	4708	588	Weather	Overhead Transformer	Patrol/Test/Inspect		VI
5012243	L35138	05/15/2015	16:51	05/15/2015	18:12	10	809	80	Transmission outage	Fuse	Repair	Replace - Same Size	III
5012245	J07173	05/15/2015	16:53	05/15/2015	19:30	1	156	156	Animal related	Transformer Fuse	Replace - Same Size		I
5012247	K94223	05/15/2015	16:59	05/15/2015	17:39	1	39	39	Weather	Jumper	Repair	Replace - Same Size	III
5012253	M48815	05/15/2015	17:05	05/15/2015	18:55	13	1429	109	Animal related	Recloser	Repair	Repair	V
151356607	U84534	05/15/2015	17:09	05/15/2015	18:27	3	234	78	Weather	Underground Transformer	Replace - Same Size		II
151356623	T06537	05/15/2015	17:11	05/15/2015	19:06	2	230	114	Weather	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	VI
151356624	U60518	05/15/2015	17:12	05/15/2015	18:08	20	1120	56	Tree related-tree broken	Fuse		Replace - New Size	II
5012255	X95003	05/15/2015	17:14	05/15/2015	20:05	1	170	170	Tree related-tree broken	Overhead Service	Raise		IV
151356648	K19117	05/15/2015	17:19	05/15/2015	18:29	1	70	69	Tree related-tree broken	Overhead Service	Cut in Clear	Repair	VI
5012257	L24123	05/15/2015	17:23	05/15/2015	19:40	3	411	136	Unknown	Transformer Fuse	Replace - Same Size		III
151356659	S03530	05/15/2015	17:24	05/15/2015	19:05	1	101	101	Tree related-tree broken	Overhead Service	Repair	Repair	VI
151356805	U79726	05/15/2015	17:25	05/15/2015	18:15	1778	88900	49	Public	Substation Breaker	Switch/Reset		II
5012261	J46183	05/15/2015	17:26	05/15/2015	19:15	1	108	108	Overhead equipment	Overhead Service	Repair		III
5012263	L00133	05/15/2015	17:27	05/15/2015	19:39	4	525	131	Transmission outage	Fuse	Repair	Replace - Same Size	III
5012265	L95110	05/15/2015	17:27	05/15/2015	19:28	9	1081	120	Unknown	Fuse	Repair		III
151356810	U19534	05/15/2015	17:28	05/15/2015	18:23	273	15015	55	Public	Recloser	Switch/Reset	Repair	II
5012267	P20930	05/15/2015	17:29	05/15/2015	20:23	1	173	173	Overhead equipment	Insulator	Replace - Same Size		VI
5012271	K95204	05/15/2015	17:33	05/15/2015	22:25	1	291	291	Tree related-tree broken	Overhead Service	Patrol/Test/Inspect	Repair	III
5012273	K95205	05/15/2015	17:34	05/15/2015	18:28	1	53	53	Unknown	Fuse	Replace - Same Size		III
5012277	C30001	05/15/2015	17:35	05/15/2015	19:25	1	109	109	Weather	Fuse	Replace - Same Size		III
5012283	Y07575	05/15/2015	17:40	05/15/2015	19:45	1	124	124	Overhead equipment	Overhead Service	Repair		IV
5012285	K95204	05/15/2015	17:41	05/15/2015	22:27	3	855	285	Overhead equipment	Overhead Secondary	Repair		III
5012287	D66001	05/15/2015	17:44	05/16/2015	5:30	1	706	706	Underground equipment	Underground Transformer	Replace - Same Size		IV
5012293	N22295	05/15/2015	17:51	05/15/2015	18:10	1	18	18	Weather	Transformer Fuse	Replace - Same Size		VI
5012295	M25143	05/15/2015	17:52	05/15/2015	23:50	2	715	357	Weather	Lightning Arrestor	Replace - Same Size		IV
5012297	L86175	05/15/2015	17:52	05/15/2015	18:27	314	10990	34	Tree related-tree broken				IV
5012299	L86175	05/15/2015	17:53	05/15/2015	18:27	156	5374	34	Tree related-tree broken				IV
5012301	L86175	05/15/2015	17:53	05/15/2015	18:27	60	2067	34	Tree related-tree broken				IV
5012449	L68113	05/15/2015	17:56	05/15/2015	23:58	12	4340	361	Tree related-tree broken	Overhead Primary			IV
5012319	L68113	05/15/2015	17:57	05/15/2015	21:30	286	60660	212	Tree related-tree broken				IV
5012307	K76546	05/15/2015	17:58	05/15/2015	22:25	1	266	266	Tree related-tree broken	Overhead Service	Patrol/Test/Inspect	Replace - New Size	IV
151356895	T15570	05/15/2015	17:59	05/15/2015	19:30	4	364	91	Overhead equipment	Transformer Fuse	Repair	Repair	VI

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5012335	L68113	05/15/2015	18:12	05/16/2015	0:42	1	389	389	Tree related-tree broken	Overhead Primary			IV
5012375	342004	05/15/2015	18:18	05/16/2015	1:11	2	824	412	Tree related-tree broken	Pole	Patrol/Test/Inspect	Replace - New Size	VI
5012339	Q34365	05/15/2015	18:22	05/15/2015	23:03	1	280	280	Underground equipment	Underground Service	Repair	Repair	I
5012409	P07179	05/15/2015	18:22	05/15/2015	22:03	89	19651	220	Overhead equipment	Overhead Transformer			I
5012349	K95204	05/15/2015	18:27	05/15/2015	22:28	1	240	240	Tree related-tree broken	Overhead Secondary	Repair		III
5012401	L86175	05/15/2015	18:29	05/15/2015	21:42	1	192	192	Overhead equipment				IV
5012389	L86175	05/15/2015	18:29	05/15/2015	19:13	51	2265	44	Tree related-tree broken				IV
5012363	L73156	05/15/2015	18:32	05/15/2015	21:12	1	159	159	Tree related-tree broken	Overhead Service			IV
5012385	P07179	05/15/2015	18:45	05/15/2015	22:00	1	194	194	Unknown	Overhead Transformer		Replace - Same Size	I
5012393	K95201	05/15/2015	18:50	05/15/2015	22:27	1	216	216	Tree related-tree contact	Overhead Secondary	Repair		III
5012399	L73160	05/15/2015	19:01	05/15/2015	23:14	1	252	252	Tree related-tree contact				IV
5012407	R08910	05/15/2015	19:15	05/15/2015	20:20	1	64	64	Overhead equipment				VI
151357259	Q85162	05/15/2015	19:16	05/15/2015	19:58	1	42	42	Animal related	Transformer Fuse	Repair	Repair	VI
5012417	D92001	05/15/2015	19:23	05/15/2015	23:42	152	39226	258	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
151357284	U80001	05/15/2015	19:30	05/15/2015	20:58	1	88	88	Tree related-tree broken	Overhead Service	Repair		II
5012423	302001	05/15/2015	19:31	05/16/2015	2:24	7	2890	412	Tree related-tree broken	Overhead Service	Cut in Clear	Replace - New Size	VI
5012427	J63172	05/15/2015	19:37	05/15/2015	20:45	1	67	67	Tree related-tree broken	Overhead Service	Repair		III
5012431	L86175	05/15/2015	19:45	05/16/2015	0:55	1	309	309	Tree related-tree broken	Overhead Service	Repair		IV
5012433	K91117	05/15/2015	19:49	05/15/2015	20:04	1	14	14	Unknown	Fuse	Replace - Same Size		III
5012439	C15002	05/15/2015	19:54	05/15/2015	20:34	1	39	39	Overhead equipment	Fuse	Replace - Same Size		III
5012441	341001	05/15/2015	20:01	05/15/2015	21:33	10	919	91	Weather	Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
5012457	C10002	05/15/2015	20:26	05/15/2015	21:47	1	80	80	Overhead equipment	Fuse	Replace - Same Size		III
5012465	L82187	05/15/2015	20:50	05/16/2015	2:53	1	362	362	Overhead equipment	Overhead Transformer			IV
5012471	J08205	05/15/2015	21:11	05/16/2015	2:29	1	317	317	Overhead equipment	Overhead Transformer	Replace - Same Size		I
5012477	L73160	05/15/2015	21:36	05/15/2015	22:27	8	405	50	Tree related-tree broken				IV
5012479	L73160	05/15/2015	21:44	05/16/2015	2:27	1	282	282	Tree related-tree contact	Overhead Service	Tie/Tighten		IV
151357428	U93001	05/15/2015	21:57	05/16/2015	0:01	1	124	124	Tree related-tree broken	Overhead Service	Repair	Repair	II
5012487	L74193	05/15/2015	22:19	05/16/2015	1:04	1	165	165	Overhead equipment	Fuse	Replace - Same Size		IV
5012495	L68113	05/15/2015	23:43	05/16/2015	0:15	6	186	31	Tree related-tree broken	Tree			IV
5012499	D92001	05/15/2015	23:55	05/16/2015	0:37	88	3672	41	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
151360008	T16528	05/16/2015	0:02	05/16/2015	4:49	1	287	287	Overhead equipment	Disconnect Switch	Replace - Urgent	Replace - Same Size	VI
5012501	L68113	05/16/2015	0:47	05/16/2015	1:06	19	351	18	Tree related-tree broken				IV
5012507	L73156	05/16/2015	0:53	05/16/2015	1:36	5	212	42	Tree related-tree broken	Overhead Secondary			IV
5012509	342004	05/16/2015	1:41	05/16/2015	3:39	1	117	117	Tree related-tree broken	Overhead Secondary		Replace - Same Size	VI
151360109	U84534	05/16/2015	2:38	05/16/2015	3:55	1	77	76	Animal related	Fuse	Replace - Same Size		II
5012513	D66001	05/16/2015	5:07	05/16/2015	8:00	19	3278	172	Tree related-tree broken	Overhead Primary	Repair		IV
5012517	M41112	05/16/2015	6:01	05/16/2015	8:20	1	138	138	Animal related	Transformer Fuse	Replace - Same Size		I
5012519	M40116	05/16/2015	6:07	05/16/2015	8:10	1	122	122	Weather	Lightning Arrestor	Replace - Same Size		I
5012521	D66001	05/16/2015	6:08	05/16/2015	7:50	1	101	101	Tree related-tree broken				IV
5012523	M40116	05/16/2015	6:09	05/16/2015	7:20	6	420	70	Animal related	Transformer Fuse	Replace - Same Size		I
151360139	B77003	05/16/2015	6:23	05/16/2015	8:56	1	153	152	Overhead equipment	Overhead Transformer	Replace - Same Size	Repair	I
151360141	T06505	05/16/2015	6:29	05/16/2015	7:45	1	76	75	Animal related	Transformer Fuse	Replace - Same Size	Replace - Same Size	VI
5012527	L12125	05/16/2015	6:38	05/16/2015	8:59	1	140	140	Public	Underground Service	Patrol/Test/Inspect	Repair	III
5012529	342004	05/16/2015	6:39	05/16/2015	7:03	1	23	23	Overhead equipment				VI
151360152	M09143	05/16/2015	6:53	05/16/2015	7:52	1	59	58	Overhead equipment	Connector	Replace - Same Size		VI
151360165	U11531	05/16/2015	7:13	05/16/2015	7:40	1	27	27	Animal related	Transformer Fuse	Replace - Same Size		II
5012533	Z08509	05/16/2015	7:40	05/16/2015	9:50	1	129	129	Overhead equipment	Transformer Fuse	Repair	Replace - Same Size	IV
5012535	L00133	05/16/2015	7:42	05/16/2015	13:12	1	329	329	Overhead equipment	Overhead Transformer	Replace - New Size		III
5012537	B28004	05/16/2015	7:46	05/16/2015	8:30	35	1523	43	Animal related	Fuse	Replace - Same Size		I
5012539	D66004	05/16/2015	7:48	05/16/2015	8:40	1	51	51	Overhead equipment	Fuse	Replace - Same Size		IV
5012545	K11376	05/16/2015	7:54	05/16/2015	11:23	1	208	208	Overhead equipment	Overhead Transformer	Disconnect	Replace - Same Size	V
151360206	U84566	05/16/2015	8:03	05/16/2015	8:52	3	147	48	Animal related	Fuse	Replace - Same Size		II
5012549	M40116	05/16/2015	8:11	05/16/2015	9:15	1	63	63	Overhead equipment	Overhead Secondary	Replace - Same Size		I
5012555	L24124	05/16/2015	8:25	05/16/2015	9:35	5	345	69	Animal related	Transformer Fuse	Repair		III
5012557	D66004	05/16/2015	8:26	05/16/2015	8:45	1	18	18	Overhead equipment	Fuse	Replace - Same Size		IV
5012561	P42230	05/16/2015	8:38	05/16/2015	11:13	1	154	154	Animal related	Fuse	Repair		VI

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
151360298	S88503	05/16/2015	8:46	05/16/2015	14:33	16	5552	346	Overhead equipment	Overhead Transformer		Repair	VI
5012565	H01190	05/16/2015	8:49	05/16/2015	11:44	3	523	174	Overhead equipment	Overhead Primary		Replace - Same Size	III
5012569	N70330	05/16/2015	9:06	05/16/2015	13:20	1	253	253	Underground equipment	Underground Service	Reconnect		I
151360275	Q83171	05/16/2015	9:08	05/16/2015	10:27	86	6794	78	Animal related	Fuse	Replace - Same Size		VI
151360281	D16002	05/16/2015	9:20	05/16/2015	10:34	1	74	74	Overhead equipment				I
5012571	K91115	05/16/2015	9:23	05/16/2015	10:48	1	84	84	Unknown				III
5012575	D90003	05/16/2015	9:40	05/16/2015	13:33	12	2798	233	Underground equipment	Underground Service			III
5012577	N05172	05/16/2015	10:03	05/16/2015	14:00	1	236	236	Weather	Overhead Transformer	Repair	Repair	I
151360324	P58155	05/16/2015	10:08	05/16/2015	10:25	1	17	17	Animal related	Transformer Fuse	Repair	Replace - Same Size	VI
5012579	K67912	05/16/2015	10:09	05/16/2015	14:00	1	230	230	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	VI
5012589	K95202	05/16/2015	10:47	05/16/2015	11:45	1	57	57	Overhead equipment	Connector	Repair		III
5012593	Q93522	05/16/2015	10:59	05/16/2015	15:27	1	267	267	Overhead equipment	Overhead Transformer	Replace - Same Size	Replace - Same Size	I
5012597	L73160	05/16/2015	11:21	05/16/2015	12:06	1	44	44	Overhead equipment	Overhead Service			IV
5012601	M07235	05/16/2015	11:27	05/16/2015	13:37	1	129	129	Weather	Transformer Fuse	Replace - Same Size		III
5012599	R16511	05/16/2015	11:27	05/16/2015	13:15	1	107	107	Weather	Disconnect Switch	Repair	Repair	I
5012627	K32915	05/16/2015	11:35	05/16/2015	13:37	2	243	121	Overhead equipment	Fuse			VI
5012609	J68402	05/16/2015	11:54	05/16/2015	12:36	20	839	41	Weather	Fuse			III
151360421	U91584	05/16/2015	11:55	05/16/2015	15:06	1	191	190	Overhead equipment	Overhead Transformer	Replace - Same Size		II
5012611	Q14392	05/16/2015	12:04	05/16/2015	13:33	1	88	88	Weather	Fuse	Replace - Same Size	Replace - Same Size	I
5012613	P05825	05/16/2015	12:08	05/16/2015	14:00	1	111	111	Weather	Fuse	Replace - Same Size		V
5012615	A81001	05/16/2015	12:26	05/16/2015	13:30	146	9219	63	Tree related-tree broken	Overhead Primary			I
5012617	L11242	05/16/2015	12:27	05/16/2015	14:28	1	120	120	Overhead equipment	Connector	Repair		III
5012623	A81001	05/16/2015	12:33	05/16/2015	17:45	1	311	311	Underground equipment	Underground Service	Patrol/Test/Inspect	Repair	I
5012631	A81001	05/16/2015	13:13	05/16/2015	13:30	1	16	16	Tree related-tree broken	Fuse	Replace - Same Size		I
5012633	K32916	05/16/2015	13:16	05/16/2015	17:15	1	239	239	Overhead equipment	Disconnect Switch	Patrol/Test/Inspect	Replace - Same Size	VI
151360472		05/16/2015	13:18	05/16/2015	14:35	1	77	76	Overhead equipment	Overhead Service	Repair	Patrol/Test/Inspect	II
5012635	X77586	05/16/2015	13:31	05/16/2015	14:30	4	232	58	Weather	Fuse	Replace - Same Size		IV
151360552	Q75145	05/16/2015	14:10	05/16/2015	15:22	5	360	71	Animal related	Fuse	Replace - Same Size		VI
5012639	X75512	05/16/2015	14:16	05/16/2015	18:27	1	250	250	Weather	Overhead Transformer	Replace - Same Size	Repair	IV
5012645	R09225	05/16/2015	15:32	05/16/2015	16:30	1	57	57	Overhead equipment	Transformer Fuse	Replace - Same Size		III
5012647	B81002	05/16/2015	15:45	05/16/2015	21:19	1	334	334	Unknown	Underground Transformer	Patrol/Test/Inspect	Replace - Same Size	I
5012655	M25144	05/16/2015	16:25	05/16/2015	19:53	5	1035	207	Overhead equipment	Fuse	Repair		IV
5012657	D66001	05/16/2015	16:33	05/16/2015	18:23	1	109	109	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
151360608	U62521	05/16/2015	16:54	05/16/2015	17:57	1	63	62	Overhead equipment	Connector	Repair		II
151360617	S62523	05/16/2015	17:17	05/16/2015	17:50	1	33	33	Animal related	Transformer Fuse	Replace - Same Size	Replace - Same Size	VI
5012661	J86108	05/16/2015	17:19	05/16/2015	19:00	5	505	100	Overhead equipment	Disconnect Switch	Patrol/Test/Inspect	Replace - Same Size	VI
5012663	K94601	05/16/2015	17:36	05/16/2015	19:45	1	128	128	Overhead equipment	Connector	Replace - New Size		III
151360712	N54214	05/16/2015	19:53	05/17/2015	0:30	1	277	277	Underground equipment	Underground Transformer	Replace - Same Size		II
5012679	Q34360	05/16/2015	20:25	05/17/2015	1:03	1	277	277	Underground equipment	Underground Service	Repair	Repair	I
5012681	C37001	05/16/2015	20:28	05/17/2015	1:23	1	295	295	Underground equipment	Underground Primary			III
5012683	K67911	05/16/2015	20:45	05/16/2015	22:33	1	107	107	Underground equipment	Underground Service	Replace - Same Size		VI
5012689	R60552	05/16/2015	22:39	05/16/2015	23:14	21	725	34	Overhead equipment	Pole	Replace - Same Size		IV
151360759	V69558	05/16/2015	22:49	05/17/2015	0:53	5	620	124	Overhead equipment	Transformer Fuse	Replace - New Size		II
151370008		05/17/2015	0:12	05/17/2015	1:12	1	60	60	Other	Meter			II
5012703	Z06538	05/17/2015	2:39	05/17/2015	6:32	33	7714	233	Public	Underground Transformer	Replace - Same Size	Replace - Same Size	IV
151370124	A17025	05/17/2015	4:19	05/17/2015	7:51	38	8056	211	Overhead equipment	Pole		Replace - New Size	I
5012707	K32932	05/17/2015	4:46	05/17/2015	6:30	1	103	103	Unknown	Fuse			VI
5012709	L00134	05/17/2015	6:44	05/17/2015	7:58	1	73	73	Overhead equipment	Jumper	Repair		III
5012711	L35137	05/17/2015	6:55	05/17/2015	9:20	1	144	144	Unknown	Other	Patrol/Test/Inspect		III
5012719	HB6283	05/17/2015	7:06	05/17/2015	9:41	27	4185	155	Public	Overhead Primary	Repair		VI
5012725	K57212	05/17/2015	7:41	05/17/2015	9:44	1	122	122	Overhead equipment	Overhead Service	Reconnect		VI
5012729	M42107	05/17/2015	7:41	05/17/2015	10:19	79	12421	157	Overhead equipment	Fuse	Patrol/Test/Inspect	Replace - Same Size	I
151370219	B00001	05/17/2015	7:49	05/17/2015	8:29	6	240	40	Animal related	Transformer Fuse	Replace - Same Size	Replace - Same Size	I
5012731	X78536	05/17/2015	7:50	05/17/2015	9:20	1	89	89	Animal related	Fuse	Replace - Same Size		IV
151370268	A91003	05/17/2015	8:36	05/17/2015	12:20	1	224	224	Underground equipment	Underground Service	Replace - Same Size	Replace - Same Size	I
5012735	L81141	05/17/2015	8:37	05/17/2015	10:20	1	102	102	Tree related-tree contact	Transformer Fuse	Replace - Same Size		IV

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
151370306	R06211	05/17/2015	9:02	05/17/2015	10:25	62	5146	83	Unknown	Other	Patrol/Test/Inspect		II
151370297		05/17/2015	9:06	05/17/2015	10:29	1	83	82	Unknown	Recloser	Patrol/Test/Inspect		II
5012851	N15849	05/17/2015	9:14	05/17/2015	11:14	17	2024	119	Animal related	Fuse	Replace - Same Size		V
5012825	D88001	05/17/2015	9:18	05/17/2015	10:50	108	9844	91	Animal related	Fuse	Replace - Same Size		I
5012817	M37191	05/17/2015	9:20	05/17/2015	11:04	63	6490	103	Overhead equipment	Fuse	Patrol/Test/Inspect	Replace - Same Size	I
151370469	U09569	05/17/2015	10:00	05/17/2015	11:12	4	288	72	Animal related	Transformer Fuse	Replace - Same Size		II
5012871	J84145	05/17/2015	10:02	05/17/2015	11:34	42	3843	91	Unknown	Fuse	Patrol/Test/Inspect		VI
5012873	X86546	05/17/2015	10:04	05/17/2015	15:32	1	178	327	Underground equipment	Underground Transformer	Replace - Same Size	Replace - Same Size	IV
5012875		05/17/2015	10:06	05/17/2015	12:10	1	123	123	Overhead equipment	Fuse	Replace - Same Size		VI
5012879	M26164	05/17/2015	10:07	05/17/2015	18:59	5	2659	531	Animal related	Transformer Fuse	Repair		III
5012885	J99141	05/17/2015	10:31	05/17/2015	22:26	5	3572	714	Underground equipment	Underground Secondary	Patrol/Test/Inspect	Repair	VI
5012889	A85002	05/17/2015	10:55	05/17/2015	16:00	1	305	304	Underground equipment	Other			I
5012893	X29547	05/17/2015	10:56	05/17/2015	12:36	21	2110	100	Overhead equipment	Fuse	Repair		IV
5012897	303001	05/17/2015	11:01	05/17/2015	12:15	1	73	73	Tree related-tree contact	Overhead Secondary	Patrol/Test/Inspect	Cut in Clear	VI
151370584	D35001	05/17/2015	11:19	05/17/2015	12:45	1	86	85	Tree related-tree broken	Overhead Service	Replace - Same Size	Replace - Same Size	I
5012903	J63172	05/17/2015	11:20	05/17/2015	14:05	1	164	164	Overhead equipment	Overhead Secondary			III
5012911	K46389	05/17/2015	11:24	05/17/2015	12:26	67	4115	61	Tree related-tree broken	Fuse	Replace - Same Size	Replace - Same Size	V
5012909	N15849	05/17/2015	11:26	05/17/2015	12:00	1	33	33	Animal related				V
5012925	R05115	05/17/2015	12:06	05/17/2015	13:40	313	29134	93	Unknown				I
5012955	J86118	05/17/2015	12:21	05/17/2015	18:45	1	383	383	Tree related-tree broken	Pole	Patrol/Test/Inspect	Replace - New Size	VI
5012957	303001	05/17/2015	12:22	05/17/2015	13:50	1	87	87	Tree related-tree broken	Overhead Service	Repair		VI
5012959	L73160	05/17/2015	12:22	05/17/2015	13:23	15	921	61	Overhead equipment	Overhead Transformer			IV
5012961	R05114	05/17/2015	12:23	05/17/2015	13:47	1	83	83	Unknown				I
5012967	K79212	05/17/2015	12:34	05/17/2015	15:11	15	2341	156	Overhead equipment	Overhead Service	Raise		IV
5012971	K79212	05/17/2015	12:41	05/17/2015	14:37	1	115	115	Overhead equipment	Overhead Secondary	Raise		IV
5012977	X09534	05/17/2015	12:51	05/17/2015	15:10	1	138	138	Tree related-tree broken	Overhead Service	Repair	Repair	IV
151370686	N54213	05/17/2015	13:04	05/17/2015	17:45	13	3653	281	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	II
5012987	J58381	05/17/2015	13:22	05/17/2015	15:55	23	3504	152	Tree related-tree contact	Overhead Primary	Repair		III
5013003	J13108	05/17/2015	13:34	05/17/2015	16:10	1	155	155	Overhead equipment	Overhead Service	Repair		I
5013011	K32915	05/17/2015	13:37	05/17/2015	17:39	7	1690	241	Overhead equipment	Overhead Transformer		Replace - Same Size	VI
151370787	V65549	05/17/2015	13:46	05/17/2015	16:24	1	158	158	Tree related-tree broken	Overhead Service	Raise		II
5013025	P69174	05/17/2015	13:59	05/17/2015	18:00	6	1440	240	Overhead equipment	Lightning Arrestor	Repair		III
5013051	Q34360	05/17/2015	14:00	05/17/2015	15:10	178	12379	69	Tree related-tree contact	Fuse	Patrol/Test/Inspect	Repair	I
5013053	M07236	05/17/2015	14:46	05/17/2015	19:13	7	1867	266	Overhead equipment	Pole		Replace - New Size	III
5013063	X88507	05/17/2015	15:12	05/17/2015	16:55	1	102	102	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
5013069	Q11516	05/17/2015	15:25	05/17/2015	18:28	8	1461	182	Tree related-tree contact	Overhead Secondary	Repair		I
5013073	R60551	05/17/2015	15:27	05/17/2015	17:45	1	137	137	Tree related-tree contact	Overhead Primary	Repair	Replace - Same Size	IV
151370871	D81003	05/17/2015	15:33	05/17/2015	20:10	1	277	277	Tree related-tree broken	Overhead Primary	Replace - Same Size	Repair	I
5013077	D37001	05/17/2015	15:58	05/17/2015	22:05	1	366	366	Tree related-tree contact	Overhead Service	Patrol/Test/Inspect	Reconnect	I
5013081	R60551	05/17/2015	16:19	05/17/2015	17:44	1	84	84	Tree related-tree contact				IV
5013085	H14342	05/17/2015	16:46	05/17/2015	20:02	1	195	195	Public	Overhead Secondary	Patrol/Test/Inspect	Repair	V
151370910	V61584	05/17/2015	16:56	05/17/2015	18:56	7	840	120	Unknown	Transformer Fuse	Replace - Same Size		II
5013087	R53390	05/17/2015	16:56	05/17/2015	19:07	1	130	130	Tree related-tree contact	Transformer Fuse	Replace - Same Size	Replace - Same Size	V
151370916	U66515	05/17/2015	17:04	05/17/2015	18:34	1	90	90	Overhead equipment	Transformer Fuse	Replace - Same Size		II
5013089	Q70161	05/17/2015	17:07	05/17/2015	18:30	1	82	82	Overhead equipment	Overhead Service	Repair		I
5013097	P17107	05/17/2015	18:21	05/17/2015	19:01	3	118	39	Overhead equipment	Fuse	Replace - Same Size		IV
5013101	P17107	05/17/2015	18:35	05/17/2015	19:01	1	25	25	Overhead equipment	Fuse	Repair		IV
5013107	R95520	05/17/2015	19:10	05/17/2015	21:04	1	113	113	Tree related-tree broken	Transformer Fuse	Repair		I
151370991	D96002	05/17/2015	20:31	05/17/2015	21:52	1	81	81	Unknown	Fuse	Repair	Replace - Same Size	I
5013113	R49263	05/17/2015	21:18	05/17/2015	23:21	1	122	122	Animal related	Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
5013115	D31016	05/17/2015	21:22	05/17/2015	23:00	1	97	97	Overhead equipment	Fuse	Replace - Same Size		III
5013117	N14880	05/17/2015	21:39	05/17/2015	22:27	1	47	47	Overhead equipment	Jumper	Repair		V
5013119	L79157	05/17/2015	21:57	05/18/2015	3:00	1	302	302	Underground equipment	Underground Service	Patrol/Test/Inspect	Repair	IV
151371115	S43511	05/17/2015	22:05	05/17/2015	23:45	548	54800	100	Substation equipment				VI
151371119	S43512	05/17/2015	22:05	05/17/2015	23:40	949	90155	94	Substation equipment				VI
151371130	S31561	05/17/2015	23:53	05/18/2015	1:31	1	98	98	Other	Transformer Fuse	Repair		VI

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5013127	Y20522	05/18/2015	0:49	05/18/2015	2:15	1	85	85	Animal related	Transformer Fuse	Replace - Same Size		IV
5013133	X57566	05/18/2015	4:19	05/18/2015	9:59	45	15280	339	Underground equipment	Underground Primary	Switch/Reset	Repair	IV
5013135	N03299	05/18/2015	4:59	05/18/2015	9:23	7	1843	263	Overhead equipment	Overhead Transformer	Replace - Same Size	Replace - Same Size	V
5013137	B62003	05/18/2015	5:12	05/18/2015	5:53	2	80	40	Unknown	Transformer Fuse	Replace - Same Size		I
151382784	S02502	05/18/2015	6:28	05/18/2015	12:00	1	332	332	Overhead equipment	Overhead Transformer	Repair	Repair	VI
5013145	J71129	05/18/2015	6:34	05/18/2015	7:54	1	79	79	Unknown	Transformer Fuse	Replace - Same Size		I
151382835	V49001	05/18/2015	7:03	05/18/2015	8:02	2	118	59	Overhead equipment	Transformer Fuse	Repair		II
5013151	P71830	05/18/2015	7:04	05/18/2015	8:50	8	842	105	Overhead equipment	Fuse	Replace - Same Size		V
5013153	H07106	05/18/2015	7:23	05/18/2015	9:15	5	558	111	Overhead equipment	Overhead Primary		Repair	IV
5013155	H07106	05/18/2015	7:29	05/18/2015	9:15	1	105	105	Underground equipment				IV
5013157	Y59520	05/18/2015	7:34	05/18/2015	9:16	1	101	101	Overhead equipment	Fuse	Replace - Same Size		IV
5013183	H07106	05/18/2015	7:42	05/18/2015	10:57	12	2333	194	Overhead equipment	Overhead Primary	Repair		IV
5013169	H07106	05/18/2015	7:46	05/18/2015	10:57	8	1525	190	Overhead equipment	Overhead Primary	Repair		IV
151382993	A91002	05/18/2015	7:52	05/18/2015	12:11	28	7252	259	Public	Pole	Patrol/Test/Inspect	Replace - Same Size	I
5013171	A85001	05/18/2015	8:39	05/18/2015	12:00	1	200	200	Animal related	Fuse	Replace - Same Size		I
151383155	U84566	05/18/2015	8:45	05/18/2015	12:34	1	229	228	Weather	Overhead Transformer		Replace - Same Size	II
5013185	B93002	05/18/2015	9:13	05/18/2015	11:00	1	107	107	Unknown	Transformer Fuse	Replace - Same Size		I
5013199	J80806	05/18/2015	9:39	05/18/2015	11:45	1	125	125	Animal related	Overhead Transformer	Repair	Repair	V
5013205	B62004	05/18/2015	10:01	05/18/2015	11:51	1	109	109	Animal related	Fuse	Replace - Same Size		I
5013213	Y98561	05/18/2015	10:18	05/18/2015	11:15	1	56	56	Overhead equipment	Jumper	Repair		IV
5013219	Y39515	05/18/2015	10:28	05/18/2015	11:57	1	88	88	Overhead equipment	Overhead Service	Repair		IV
5013229	K67912	05/18/2015	10:50	05/18/2015	15:30	1	279	279	Overhead equipment	Pole	Replace - New Size	Repair	VI
151383912	S84535	05/18/2015	10:55	05/18/2015	11:44	3	147	49	Weather	Fuse	Repair	Replace - Same Size	VI
5013237	L59929	05/18/2015	11:08	05/18/2015	13:31	1	143	143	Overhead equipment	Disconnect Switch		Replace - Same Size	VI
5013241	F03004	05/18/2015	11:22	05/18/2015	12:31	1	68	68	Animal related	Fuse	Replace - Same Size		III
5013245	L24123	05/18/2015	11:28	05/18/2015	13:23	1	114	114	Tree related-tree contact	Overhead Service	Repair		III
5013253	Q10702	05/18/2015	12:13	05/18/2015	22:10	1	596	596	Overhead equipment	Pole	Advise Customer	Replace - Same Size	V
151384734	V25513	05/18/2015	13:10	05/18/2015	14:02	1	52	52	Overhead equipment				II
5013277	J75271	05/18/2015	13:23	05/18/2015	13:47	2	49	24	Other				IV
151385032	T09559	05/18/2015	14:00	05/18/2015	15:16	1	76	75	Unknown				VI
5013293	L17105	05/18/2015	14:05	05/18/2015	14:55	1	49	49	Overhead equipment	Connector	Replace - Same Size		III
5013301	B81002	05/18/2015	14:40	05/18/2015	19:17	1	276	276	Underground equipment	Underground Primary	Patrol/Test/Inspect	Reconnect	I
5013303	P54827	05/18/2015	14:46	05/18/2015	16:09	1	83	83	Overhead equipment	Connector	Replace - New Size		V
5013305	R20501	05/18/2015	14:51	05/18/2015	15:45	1	53	53	Animal related	Fuse	Repair		IV
5013313	K95207	05/18/2015	15:21	05/18/2015	16:45	1	83	83	Overhead equipment	Transformer Fuse	Replace - Same Size		III
5013317	N67309	05/18/2015	15:29	05/18/2015	16:54	3	254	84	Unknown	Fuse	Replace - Same Size	Replace - Same Size	I
5013321	J84145	05/18/2015	15:39	05/18/2015	17:04	3	252	84	Weather	Fuse	Replace - Same Size		VI
5013323	J84145	05/18/2015	15:48	05/18/2015	17:04	4	301	75	Weather	Fuse	Replace - Same Size		VI
5013325	P71830	05/18/2015	16:06	05/18/2015	16:56	1	49	49	Animal related	Fuse	Replace - Same Size		V
5013333	J84145	05/18/2015	16:12	05/18/2015	17:07	1	54	54	Weather	Fuse	Replace - Same Size		VI
5013339	C36002	05/18/2015	16:40	05/18/2015	17:47	1	66	66	Animal related	Fuse	Replace - Same Size		III
5013341	J84145	05/18/2015	16:51	05/18/2015	17:08	1	16	16	Weather	Fuse	Replace - Same Size		VI
5013343	J84145	05/18/2015	17:16	05/18/2015	17:47	4	120	30	Weather	Transformer Fuse	Replace - Same Size		VI
5013345	Y51505	05/18/2015	17:17	05/18/2015	20:12	6	1048	174	Overhead equipment	Overhead Transformer	Replace - Same Size	Replace - Same Size	IV
151385875	D16001	05/18/2015	17:25	05/18/2015	19:11	1	106	105	Tree related-tree contact	Overhead Service	Repair		I
151386102	Q47833	05/18/2015	17:26	05/18/2015	19:06	251	25100	99	Overhead equipment				V
5013347	341002	05/18/2015	17:52	05/18/2015	19:10	1	77	77	Tree related-tree broken	Overhead Service	Repair		VI
5013349	D67001	05/18/2015	18:07	05/18/2015	19:00	1	52	52	Weather	Transformer Fuse	Repair		IV
5013355	X69554	05/18/2015	18:27	05/18/2015	19:20	1	52	52	Weather	Fuse	Repair		IV
5013361	L50215	05/18/2015	18:28	05/18/2015	20:29	123	14830	120	Overhead equipment	Jumper	Repair		VI
5013367	350104	05/18/2015	19:28	05/18/2015	20:44	1	75	75	Underground equipment	Underground Secondary	Patrol/Test/Inspect	Repair	V
151386570	V69546	05/18/2015	20:56	05/18/2015	22:15	2	158	79	Overhead equipment	Transformer Fuse	Replace - Same Size		II
5013379	L70125	05/18/2015	20:57	05/18/2015	22:40	1	102	102	Overhead equipment	Connector	Replace - Same Size		IV
5013381	L35138	05/18/2015	21:13	05/19/2015	1:30	1	256	256	Overhead equipment	Overhead Transformer	Replace - Same Size		III
151386606	T22508	05/18/2015	22:04	05/19/2015	5:00	6	2496	416	Overhead equipment	Overhead Transformer	Repair	Repair	VI
5013389	J61110	05/18/2015	22:28	05/18/2015	23:26	1	57	57	Overhead equipment	Overhead Service			III

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5013391	P42229	05/18/2015	22:46	05/19/2015	0:17	1	90	90	Tree related-tree contact	Tree	Remove		VI
151386627	S01560	05/18/2015	22:54	05/19/2015	1:20	10	1460	145	Overhead equipment	Overhead Secondary	Repair		VI
5013395	N05173	05/19/2015	0:09	05/19/2015	4:22	1	252	252	Animal related	Fuse			I
5013399	R66470	05/19/2015	0:37	05/19/2015	6:59	13	4960	381	Animal related	Fuse	Patrol/Test/Inspect		IV
5013403	R66470	05/19/2015	0:38	05/19/2015	6:59	7	2660	380	Animal related	Transformer Fuse	Patrol/Test/Inspect		IV
151390160	T01534	05/19/2015	1:08	05/19/2015	5:30	1	262	261	Overhead equipment	Overhead Transformer	Repair	Repair	VI
151390174	S28552	05/19/2015	1:53	05/19/2015	3:23	1	90	90	Overhead equipment	Transformer Fuse	Patrol/Test/Inspect		VI
151393036	V14579	05/19/2015	4:08	05/19/2015	5:47	5	495	98	Animal related	Transformer Fuse	Replace - Same Size		II
5013419	J89125	05/19/2015	5:04	05/19/2015	7:12	53	6766	127	Underground equipment	Underground Primary		Repair	VI
5013421	J83137	05/19/2015	5:35	05/19/2015	7:35	1	119	119	Overhead equipment	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
5013687	L90359	05/19/2015	5:42	05/19/2015	9:38	24	5668	236	Overhead equipment	Fuse	Repair		V
5013447	N19371	05/19/2015	5:43	05/19/2015	9:09	428	74766	205	Tree related-tree contact	Overhead Primary	Cut in Clear	Repair	V
5013469	X12526	05/19/2015	6:13	05/19/2015	9:55	3	666	222	Overhead equipment	Underground Primary	Patrol/Test/Inspect	Repair	IV
5013475	K57211	05/19/2015	6:48	05/19/2015	7:50	5	308	61	Animal related	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
5013481	S01501	05/19/2015	7:01	05/19/2015	7:18	590	9634	16	Overhead equipment	Disconnect Switch	Replace - Same Size		VI
5013477	M22812	05/19/2015	7:06	05/19/2015	8:23	1	76	76	Overhead equipment	Fuse	Replace - Same Size		V
5013479	K11372	05/19/2015	7:09	05/19/2015	7:57	6	282	47	Animal related	Fuse	Replace - Same Size		V
5013501	V44511	05/19/2015	7:30	05/19/2015	9:53	1	142	142	Underground equipment	Underground Service		Repair	II
5013521	T59942	05/19/2015	7:40	05/19/2015	8:59	1	78	78	Animal related	Fuse	Replace - Same Size		VI
5013533	312112	05/19/2015	7:45	05/19/2015	9:14	1	88	88	Overhead equipment	Overhead Service	Repair		V
5013541	P98193	05/19/2015	7:53	05/19/2015	11:14	71	14201	200	Underground equipment	Underground Primary	Repair	Repair	III
5013549	X24536	05/19/2015	7:58	05/19/2015	10:19	20	2826	141	Overhead equipment	Disconnect Switch	Replace - Same Size		IV
5013547	X24536	05/19/2015	8:03	05/19/2015	9:54	1	110	110	Overhead equipment	Disconnect Switch	Replace - Same Size		IV
5013551	M05361	05/19/2015	8:10	05/19/2015	9:32	1	81	81	Overhead equipment	Jumper	Repair		V
5013557	V24583	05/19/2015	8:22	05/19/2015	14:24	1	361	361	Underground equipment	Underground Primary	Repair	Replace - Same Size	II
5013569	M45211	05/19/2015	8:48	05/19/2015	9:31	1	42	42	Animal related	Transformer Fuse	Replace - Same Size		IV
5154909	Q83171	05/19/2015	8:50	05/19/2015	9:21	450	13626	30	Animal related				VI
5013589	S60581	05/19/2015	8:55	05/19/2015	9:32	1	36	36	Animal related	Transformer Fuse	Replace - Same Size		VI
5013621	M20221	05/19/2015	9:04	05/19/2015	10:21	1	76	76	Weather	Fuse	Repair		VI
5014057	N19371	05/19/2015	9:09	05/19/2015	15:12	107	38801	362	Tree related-tree contact				V
5013689	L90359	05/19/2015	9:40	05/19/2015	10:09	1	28	28	Underground equipment				V
5013693	T04513	05/19/2015	9:47	05/19/2015	10:50	1	62	62	Animal related	Transformer Fuse	Replace - Same Size	Replace - Same Size	VI
5013697	S47576	05/19/2015	9:51	05/19/2015	11:22	95	8566	90	Tree related-tree broken	Tree	Trim		VI
5013701	K76542	05/19/2015	9:53	05/19/2015	11:22	26	2296	88	Underground equipment	Underground Primary	Switch/Reset	Repair	IV
5013729	F03003	05/19/2015	10:10	05/19/2015	11:17	123	8177	66	Animal related	Fuse	Replace - Same Size		III
5013727	N50331	05/19/2015	10:14	05/19/2015	11:22	2	134	67	Public	Overhead Secondary	Repair		II
5013759	S15558	05/19/2015	11:03	05/19/2015	12:01	50	2899	57	Overhead equipment				VI
5013761	X39542	05/19/2015	11:03	05/19/2015	12:38	1	94	94	Tree related-tree contact	Overhead Service	Repair		IV
5013767	N50331	05/19/2015	11:14	05/19/2015	12:10	5	276	55	Unknown	Fuse	Replace - Same Size		II
5013769	N19371	05/19/2015	11:18	05/19/2015	12:27	1	68	68	Tree related-tree broken				V
5013777	U02597	05/19/2015	11:57	05/19/2015	13:30	5	461	92	Overhead equipment	Transformer Fuse	Replace - Same Size		II
5013783	N60172	05/19/2015	12:08	05/19/2015	15:10	1	181	181	Overhead equipment	Connector	Repair	Tie/Tighten	I
5013789	B76001	05/19/2015	12:18	05/19/2015	17:42	1	323	323	Underground equipment	Underground Service	Repair		I
5013813	Y97512	05/19/2015	13:23	05/19/2015	14:00	1	36	36	Public	Fuse			IV
5013815	N58144	05/19/2015	13:24	05/19/2015	14:24	1	59	59	Unknown	Fuse	Repair	Replace - Same Size	I
5013825	X95001	05/19/2015	14:18	05/19/2015	14:59	1	40	40	Overhead equipment	Connector	Repair		IV
5013831	L24121	05/19/2015	15:00	05/19/2015	15:42	34	1419	41	Animal related	Fuse	Replace - Same Size		III
5013837	S43501	05/19/2015	15:20	05/19/2015	17:41	1	140	140	Tree related-tree broken	Overhead Service	Raise		VI
5013845	L82188	05/19/2015	15:51	05/19/2015	22:23	8	3134	391	Underground equipment	Underground Transformer	Replace - Same Size		IV
5013847	T16526	05/19/2015	16:03	05/19/2015	20:23	1	259	259	Underground equipment	Underground Service			VI
5013851	V23530	05/19/2015	16:08	05/19/2015	17:17	1	68	68	Unknown	Transformer Fuse	Replace - Same Size		II
5013857	J39392	05/19/2015	16:21	05/19/2015	20:18	1	236	236	Underground equipment	Underground Service			III
5013859	V23530	05/19/2015	16:38	05/19/2015	18:00	1	81	81	Underground equipment	Underground Service	Repair		II
5013867	B21003	05/19/2015	17:08	05/19/2015	18:18	1	69	69	Overhead equipment	Fuse	Repair		I
5013873	D70002	05/19/2015	17:45	05/19/2015	20:23	21	3315	157	Underground equipment	Underground Primary	Switch/Reset	Repair	I
5013875	Q32171	05/19/2015	17:53	05/19/2015	20:26	1	152	152	Tree related-tree broken	Overhead Service	Replace - Same Size	Patrol/Test/Inspect	I

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5013877	B68002	05/19/2015	17:58	05/19/2015	19:13	1	74	74	Animal related	Transformer Fuse			III
5013881	Q27185	05/19/2015	18:00	05/19/2015	19:52	1	111	111	Overhead equipment	Transformer Fuse	Replace - Same Size		VI
5013887	P47120	05/19/2015	18:44	05/19/2015	20:23	7	689	98	Public	Overhead Primary	Repair		I
5013893	N54214	05/19/2015	19:07	05/19/2015	22:01	5	867	173	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	II
5013903	P05826	05/19/2015	20:50	05/20/2015	2:29	2	676	338	Public	Pole	Replace - Same Size		V
5013907	X60595	05/19/2015	21:09	05/19/2015	22:15	4	262	65	Overhead equipment	Transformer Fuse	Replace - Same Size	Replace - Same Size	IV
5013911	Q70161	05/19/2015	21:53	05/19/2015	23:32	1	98	98	Animal related	Transformer Fuse	Repair		I
5013919	D69008	05/19/2015	22:44	05/20/2015	5:12	1	387	387	Underground equipment	Underground Primary	Repair	Repair	I
5013923	M40132	05/19/2015	23:05	05/20/2015	0:01	1	55	55	Animal related	Transformer Fuse	Replace - Same Size		I
5013925	L82188	05/19/2015	23:13	05/20/2015	4:50	1	336	336	Underground equipment	Underground Service	Repair	Repair	IV
5013929	D89002	05/19/2015	23:43	05/20/2015	6:12	24	5580	389	Underground equipment	Underground Primary	Patrol/Test/Inspect	Replace - Urgent	I
5013933	U93563	05/20/2015	0:51	05/20/2015	2:20	1	88	88	Animal related	Transformer Fuse	Replace - Same Size	Replace - Same Size	II
5013939	H07106	05/20/2015	5:52	05/20/2015	7:40	1	107	107	Underground equipment	Underground Primary	Repair	Repair	IV
5013943	N15850	05/20/2015	6:42	05/20/2015	7:27	1	44	44	Animal related	Transformer Fuse	Replace - Same Size		V
5013949	S88502	05/20/2015	8:05	05/20/2015	10:04	1	118	118	Animal related	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
5013953	Q82907	05/20/2015	8:13	05/20/2015	9:43	1	89	89	Animal related	Fuse	Replace - Same Size		VI
5013959	P77235	05/20/2015	8:36	05/20/2015	10:13	1	96	96	Animal related	Fuse	Replace - Same Size		VI
5013965	A36002	05/20/2015	8:48	05/20/2015	9:41	1	52	52	Overhead equipment	Transformer Fuse	Replace - Same Size		I
5013967	V41533	05/20/2015	8:49	05/20/2015	9:51	11	678	61	Overhead equipment	Transformer Fuse	Replace - Same Size		II
5013975	T17581	05/20/2015	9:13	05/20/2015	9:41	1	27	27	Animal related	Transformer Fuse	Replace - Same Size		VI
5013981	D36001	05/20/2015	9:31	05/20/2015	10:31	1	59	59	Unknown	Fuse	Repair		I
5013989	X88510	05/20/2015	9:53	05/20/2015	10:40	1	46	46	Animal related	Transformer Fuse	Replace - Same Size		IV
5013993	A26005	05/20/2015	9:56	05/20/2015	10:47	7	351	50	Animal related	Fuse	Replace - Same Size		I
5014005	D36001	05/20/2015	10:22	05/20/2015	10:57	56	1925	34	Animal related	Fuse	Repair		I
5014009	B93002	05/20/2015	10:26	05/20/2015	16:00	1	333	333	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
5014015	P69174	05/20/2015	10:45	05/20/2015	11:46	1	60	60	Unknown	Fuse	Replace - Same Size		III
5014021	Q04410	05/20/2015	11:11	05/20/2015	12:05	4	214	53	Overhead equipment	Transformer Fuse		Replace - Same Size	III
5014029	R33126	05/20/2015	11:33	05/20/2015	12:43	1	69	69	Overhead equipment	Transformer Fuse	Replace - Same Size	Patrol/Test/Inspect	I
5014033	HB6283	05/20/2015	11:41	05/20/2015	14:30	1	168	168	Tree related-tree broken	Overhead Secondary			VI
5014043	L35138	05/20/2015	11:58	05/20/2015	12:52	79	4242	53	Animal related	Fuse	Replace - Same Size		III
5014055	V36001	05/20/2015	12:35	05/20/2015	15:08	1	152	152	Underground equipment	Underground Primary	Repair	Repair	II
5014071	Q64919	05/20/2015	13:38	05/20/2015	14:39	12	720	60	Overhead equipment	Fuse	Replace - Same Size		VI
5014077	S20555	05/20/2015	13:51	05/20/2015	14:33	1	41	41	Animal related	Underground Primary	Replace - Same Size		VI
5014083	F22001	05/20/2015	14:31	05/20/2015	15:15	5	216	43	Overhead equipment	Overhead Transformer			IV
5014085	D96002	05/20/2015	14:32	05/20/2015	16:00	1	87	87	Animal related	Transformer Fuse	Replace - Same Size		I
5014101	B35002	05/20/2015	15:10	05/20/2015	16:43	63	5857	92	Overhead equipment	Fuse	Repair		I
5014107	H00163	05/20/2015	15:19	05/20/2015	16:25	1	65	65	Unknown	Other			III
5014113	K15207	05/20/2015	16:08	05/20/2015	16:16	1	7	7	Underground equipment	Underground Secondary			VI
5014123	S21529	05/20/2015	17:07	05/20/2015	18:12	2	129	64	Overhead equipment	Transformer Fuse	Replace - Same Size		VI
5014129	N95823	05/20/2015	17:42	05/20/2015	19:25	1	102	102	Overhead equipment	Connector	Replace - New Size		V
5014131	Y13044	05/20/2015	17:49	05/20/2015	18:45	1	55	55	Overhead equipment	Overhead Service	Repair		IV
5014133	L59929	05/20/2015	17:51	05/20/2015	19:10	1	78	78	Animal related	Connector	Repair		VI
5014135	K28183	05/20/2015	18:09	05/20/2015	19:14	4	259	64	Overhead equipment	Fuse	Replace - Same Size		III
5014145	S03531	05/20/2015	18:57	05/20/2015	22:00	5	912	182	Tree related-tree broken	Tree	Remove	Remove	VI
5014147	S03531	05/20/2015	19:08	05/20/2015	22:00	1	171	171	Tree related-tree broken	Overhead Service	Patrol/Test/Inspect	Repair	VI
5014149	A45001	05/20/2015	19:08	05/20/2015	22:11	8	1461	182	Overhead equipment	Connector	Patrol/Test/Inspect	Repair	I
5014151	M81404	05/20/2015	19:18	05/20/2015	20:22	4	255	63	Animal related	Transformer Fuse	Repair		V
5014157	U04571	05/20/2015	20:01	05/20/2015	20:55	1	53	53	Animal related	Transformer Fuse	Replace - Same Size		II
5014165	D53002	05/20/2015	21:10	05/21/2015	0:43	1	212	212	Underground equipment	Underground Primary	Disconnect	Repair	I
5014171	P19395	05/20/2015	22:01	05/20/2015	22:55	1	53	53	Animal related	Transformer Fuse	Replace - Same Size		V
5014177	309143	05/20/2015	22:41	05/21/2015	3:30	11	3178	288	Public	Pole			V
5014179	309143	05/20/2015	22:45	05/21/2015	7:50	6	3265	544	Public	Pole			V
5014181	309143	05/20/2015	22:45	05/21/2015	3:28	8	2258	282	Public	Pole			V
5014187	X82004	05/21/2015	0:56	05/21/2015	2:44	1	107	107	Tree related-tree contact	Tree	Trim		IV
5014195	U44568	05/21/2015	2:53	05/21/2015	5:13	1	139	139	Animal related	Disconnect Switch	Repair	Repair	II
5014203	CW1004	05/21/2015	4:42	05/21/2015	6:41	3	356	118	Overhead equipment	Fuse	Replace - Same Size		III

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5014205	M41111	05/21/2015	6:01	05/21/2015	8:05	1	123	123	Underground equipment	Overhead Service		Repair	I
5014213	B21002	05/21/2015	6:40	05/21/2015	8:07	1	86	86	Animal related	Fuse	Patrol/Test/Inspect	Replace - Same Size	I
5014261	S14511	05/21/2015	8:54	05/21/2015	9:37	1	42	42	Unknown	Customer Equipment	Replace - Same Size		VI
5014273	J97113	05/21/2015	9:12	05/21/2015	9:35	310	7074	22	Other	Substation Breaker	Switch/Reset		VI
5014281	J87150	05/21/2015	9:18	05/21/2015	9:38	1	19	19	Overhead equipment	Recloser	Reconnect		VI
5014289	Q06141	05/21/2015	9:29	05/21/2015	14:55	21	6828	325	Underground equipment	Underground Primary	Repair		IV
5014293	Q83148	05/21/2015	9:32	05/21/2015	11:30	1	117	117	Overhead equipment	Overhead Service	Repair	Repair	VI
5014303	P18104	05/21/2015	9:45	05/21/2015	10:15	3	88	29	Tree related-tree broken	Overhead Service	Replace - New Size		IV
5014305	X96543	05/21/2015	9:46	05/21/2015	11:15	3	265	88	Overhead equipment	Overhead Service			IV
5014317	X29548	05/21/2015	10:02	05/21/2015	10:58	1	55	55	Tree related-tree broken	Overhead Service			IV
5014339	Q06141	05/21/2015	10:36	05/21/2015	11:45	1	68	68	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	IV
5014343	B27008	05/21/2015	10:40	05/21/2015	14:20	14	3066	219	Public	Overhead Service	Remove		I
5014355	Y37592	05/21/2015	10:52	05/21/2015	12:20	1	87	87	Tree related-tree contact	Overhead Service			IV
5014359	T23527	05/21/2015	10:58	05/21/2015	12:45	1	106	106	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	VI
5014431	B27008	05/21/2015	11:04	05/21/2015	14:20	1	195	195	Public	Overhead Service	Remove		I
5014363	L35139	05/21/2015	11:11	05/21/2015	11:55	4	172	43	Animal related	Transformer Fuse	Replace - Same Size		III
5014367	D31018	05/21/2015	11:13	05/21/2015	12:25	1	71	71	Overhead equipment	Connector	Repair		III
5014371	338003	05/21/2015	11:26	05/21/2015	11:33	5	32	6	Jurisdictional	Overhead Secondary	Replace - Same Size		VI
5014375	Q85162	05/21/2015	11:28	05/21/2015	13:43	1	134	134	Overhead equipment	Overhead Service	Repair	Repair	VI
5014443	L35137	05/21/2015	12:27	05/21/2015	15:16	166	27916	168	Overhead equipment	Overhead Primary	Repair		III
5014439	V23592	05/21/2015	13:13	05/21/2015	14:51	1	97	97	Overhead equipment	Disconnect Switch	Repair	Replace - Same Size	II
5014445	Z21564	05/21/2015	13:26	05/21/2015	14:05	99	3813	38	Overhead equipment	Overhead Primary	Repair	Replace - Same Size	IV
5014483	L86175	05/21/2015	14:13	05/21/2015	15:20	365	14495	67	Overhead equipment	Overhead Primary	Repair		IV
5014491	L86175	05/21/2015	14:15	05/21/2015	15:20	1	64	64	Public				IV
5014495	Q47833	05/21/2015	14:16	05/21/2015	15:36	15	1199	79	Animal related	Recloser	Replace - Same Size	Replace - Same Size	V
5014497	Q47833	05/21/2015	14:16	05/21/2015	15:00	1	43	43	Animal related	Recloser	Replace - Same Size	Replace - Same Size	V
5014541	L86175	05/21/2015	14:21	05/21/2015	14:36	380	5840	15	Overhead equipment	Overhead Primary	Cut in Clear	Repair	IV
5014517	P17108	05/21/2015	14:38	05/21/2015	17:33	1	174	174	Overhead equipment	Disconnect Switch		Replace - Same Size	IV
5014525	332001	05/21/2015	14:50	05/21/2015	15:45	1	54	54	Overhead equipment	Overhead Service	Repair		VI
5014529	HD5254	05/21/2015	14:53	05/21/2015	17:05	25	3289	131	Underground equipment	Underground Primary		Repair	VI
5014551	M31203	05/21/2015	15:15	05/21/2015	15:44	1	28	28	Unknown				I
5014557	K09864	05/21/2015	15:16	05/21/2015	20:31	45	3005	314	Public				V
5014583	S42579	05/21/2015	15:47	05/21/2015	16:30	1	42	42	Overhead equipment	Connector	Replace - Same Size		VI
5014669	S19552	05/21/2015	15:48	05/21/2015	16:57	4	276	69	Underground equipment	Underground Primary		Replace - Same Size	VI
5014591	S19552	05/21/2015	15:50	05/21/2015	16:52	27	1669	61	Underground equipment	Underground Primary			VI
5014597	HE3303	05/21/2015	15:55	05/21/2015	16:35	1	39	39	Animal related	Transformer Fuse	Replace - Same Size		VI
5014599	R33127	05/21/2015	15:56	05/21/2015	18:15	299	41441	138	Animal related	Recloser			I
5014623	X88507	05/21/2015	16:02	05/21/2015	16:59	1	56	56	Animal related	Transformer Fuse	Replace - Same Size		IV
5014631	R33127	05/21/2015	16:07	05/21/2015	18:16	1	128	128	Animal related	Recloser	Replace - Same Size	Patrol/Test/Inspect	I
5014635	R33127	05/21/2015	16:12	05/21/2015	18:15	12	1464	122	Animal related	Recloser	Repair	Repair	I
5014677	L35137	05/21/2015	16:14	05/21/2015	17:57	22	2249	102	Overhead equipment	Fuse	Replace - Same Size		III
5014645	S88553	05/21/2015	16:18	05/21/2015	18:55	1	156	156	Unknown	Customer Equipment	Replace - Same Size		VI
5014649	J07135	05/21/2015	16:25	05/21/2015	19:28	1	182	182	Animal related	Recloser	Switch/Reset		I
5014653	R33127	05/21/2015	16:26	05/21/2015	18:15	1	108	108	Animal related	Recloser			I
5014663	P49180	05/21/2015	16:52	05/21/2015	19:26	1	153	153	Overhead equipment	Overhead Service	Replace - Same Size	Repair	I
5014673	P60161	05/21/2015	17:05	05/21/2015	17:46	3	121	40	Animal related	Transformer Fuse	Replace - Same Size		VI
5014685	L17102	05/21/2015	18:05	05/21/2015	18:53	26	1225	47	Animal related	Fuse	Replace - Same Size		III
5014691	S19553	05/21/2015	18:27	05/21/2015	20:14	1	107	106	Other				VI
5014693	K67912	05/21/2015	18:33	05/21/2015	19:20	1	46	46	Animal related	Transformer Fuse	Replace - Same Size		VI
5014699	B19001	05/21/2015	19:30	05/21/2015	20:50	1	79	79	Unknown	Transformer Fuse	Replace - Same Size		I
5014725	N44216	05/21/2015	21:36	05/21/2015	23:15	118	11593	98	Other	Fuse			III
5014711	K69112	05/21/2015	21:56	05/22/2015	3:23	6	1961	326	Underground equipment	Underground Secondary	Repair		IV
5014737	N44216	05/21/2015	22:03	05/21/2015	23:41	1	97	97	Unknown	Fuse			III
5014749	Y97513	05/21/2015	23:24	05/22/2015	1:55	85	12866	151	Overhead equipment	Overhead Primary	Replace - Same Size		IV
5014771	J06167	05/22/2015	0:50	05/22/2015	3:03	159	21102	132	Unknown				I
5014773	V37537	05/22/2015	3:30	05/22/2015	4:43	1	72	72	Animal related	Transformer Fuse	Repair		II

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5014775	N14879	05/22/2015	3:33	05/22/2015	4:24	1	50	50	Public	Meter	Disconnect		V
5014859	B21004	05/22/2015	3:47	05/22/2015	11:23	33	15061	456	Underground equipment	Underground Primary	Replace - Same Size	Replace - Same Size	I
5014779	B21004	05/22/2015	3:49	05/22/2015	9:13	73	23627	323	Underground equipment	Underground Primary	Repair	Repair	I
5014783	E10002	05/22/2015	5:13	05/22/2015	8:05	1	171	171	Overhead equipment	Fuse	Replace - Same Size		III
5014785	B68004	05/22/2015	6:20	05/22/2015	7:02	1	41	41	Overhead equipment	Fuse	Replace - Same Size		III
5014787	R09225	05/22/2015	6:57	05/22/2015	8:27	1	89	89	Animal related	Transformer Fuse			III
5014789	X69554	05/22/2015	7:06	05/22/2015	10:05	1	178	178	Animal related	Transformer Fuse			IV
5014797	L73160	05/22/2015	7:19	05/22/2015	8:09	35	1734	49	Overhead equipment	Fuse			IV
5014799	B62003	05/22/2015	7:24	05/22/2015	17:05	1	580	580	Underground equipment	Underground Service	Patrol/Test/Inspect	Repair	I
5014801	D53001	05/22/2015	7:25	05/22/2015	9:23	6	704	117	Overhead equipment				I
5014803	P26280	05/22/2015	7:30	05/22/2015	8:31	10	603	60	Animal related	Transformer Fuse	Repair		I
5014807	X75573	05/22/2015	8:13	05/22/2015	11:36	1	202	202	Underground equipment	Underground Service	Repair		IV
5014823	310123	05/22/2015	8:42	05/22/2015	9:37	1	54	54	Animal related	Fuse	Replace - Same Size		V
5014825	S78551	05/22/2015	8:43	05/22/2015	15:16	1	392	392	Underground equipment	Underground Primary		Repair	VI
5014843	R01153	05/22/2015	9:04	05/22/2015	10:38	1	93	93	Tree related-tree contact	Overhead Service	Repair	Repair	III
5014855	B21004	05/22/2015	9:11	05/22/2015	9:13	33	76	2	Underground equipment				I
5014857	J07135	05/22/2015	9:11	05/22/2015	17:48	1	516	516	Public	Pole	Patrol/Test/Inspect	Patrol/Test/Inspect	I
5014861	J08207	05/22/2015	9:12	05/22/2015	10:47	1	94	94	Animal related	Transformer Fuse	Replace - Same Size		I
5014865	V41527	05/22/2015	9:20	05/22/2015	10:19	1	58	58	Animal related	Transformer Fuse	Replace - Same Size		II
5014871	U42512	05/22/2015	9:29	05/22/2015	10:15	1	45	45	Animal related	Transformer Fuse	Replace - Same Size	Replace - Same Size	II
5014883	B65003	05/22/2015	9:48	05/22/2015	10:40	8	411	51	Animal related	Fuse	Replace - Same Size		I
5014889	D72003	05/22/2015	9:52	05/22/2015	12:44	1	171	171	Overhead equipment				I
5014895	L35138	05/22/2015	10:16	05/22/2015	11:11	1	54	54	Animal related	Transformer Fuse	Replace - Same Size		III
5014901	K25164	05/22/2015	10:33	05/22/2015	12:15	1	101	101	Overhead equipment	Fuse	Repair	Repair	VI
5014905	P58159	05/22/2015	10:37	05/22/2015	12:21	9	935	103	Underground equipment	Underground Primary	Repair	Repair	VI
5014909	U93563	05/22/2015	10:42	05/22/2015	12:50	1	127	127	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	II
5014923	Y84552	05/22/2015	11:16	05/22/2015	16:29	1	313	313	Public				IV
5014929	U97520	05/22/2015	11:27	05/22/2015	12:24	7	399	57	Public	Overhead Primary	Switch/Reset		II
5014933	A49001	05/22/2015	11:46	05/22/2015	13:30	18	1863	103	Overhead equipment	Lightning Arrestor	Replace - Same Size	Replace - Same Size	I
5014947	S61530	05/22/2015	12:01	05/22/2015	14:45	4	655	163	Overhead equipment	Overhead Transformer	Replace - Same Size	Replace - Same Size	VI
5014955	U97520	05/22/2015	12:14	05/22/2015	13:47	2	184	92	Public	Overhead Primary	Repair		II
5014961	N58144	05/22/2015	12:28	05/22/2015	13:15	1	46	46	Animal related	Fuse	Repair	Replace - Same Size	I
5014971	N35851	05/22/2015	13:25	05/22/2015	14:12	1	46	46	Weather	Transformer Fuse	Replace - Same Size		V
5014975	U91599	05/22/2015	13:49	05/22/2015	14:50	1	60	60	Animal related	Transformer Fuse	Replace - Same Size		II
5014981	L24123	05/22/2015	13:52	05/22/2015	15:35	1	102	102	Underground equipment	Underground Service		Repair	III
5014985	340101	05/22/2015	14:08	05/22/2015	15:43	1	94	94	Overhead equipment				V
5015087	D90002	05/22/2015	15:01	05/22/2015	16:27	39	3342	85	Overhead equipment	Disconnect Switch	Replace - Same Size		III
5015065	N35852	05/22/2015	15:02	05/22/2015	15:20	1546	27085	17	Public				V
5015039	K80382	05/22/2015	15:06	05/22/2015	16:47	1	100	100	Public	Underground Service	Repair	Repair	IV
5015091	N35852	05/22/2015	15:36	05/22/2015	15:47	1	10	10	Public	Meter	Patrol/Test/Inspect		V
5015115	D70004	05/22/2015	16:04	05/22/2015	19:38	29	6179	213	Underground equipment	Underground Primary	Repair	Repair	I
5015111	S22593	05/22/2015	16:49	05/22/2015	22:12	1	322	322	Underground equipment	Underground Service		Repair	VI
5015117	S42579	05/22/2015	17:11	05/22/2015	18:35	3	251	83	Animal related	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
5015121	J84145	05/22/2015	17:33	05/22/2015	18:10	1	36	36	Unknown	Customer Equipment			VI
5015123	K32935	05/22/2015	17:42	05/22/2015	19:16	6	562	93	Overhead equipment	Jumper			VI
5015127	H10843	05/22/2015	17:52	05/23/2015	0:05	1	372	372	Public	Pole			V
5015139	N74241	05/22/2015	18:55	05/22/2015	19:48	13	690	53	Tree related-tree broken	Pole	Repair		I
5015147	L73155	05/22/2015	19:41	05/22/2015	21:47	4	500	125	Overhead equipment	Overhead Transformer	Switch/Reset		IV
5015155	U64521	05/22/2015	20:24	05/22/2015	21:15	1	50	50	Unknown	Transformer Fuse	Replace - Same Size		II
5015171	Y20522	05/22/2015	21:12	05/23/2015	5:30	12	5974	497	Overhead equipment	Underground Primary			IV
5015161	Y20522	05/22/2015	21:13	05/22/2015	22:39	28	2386	85	Overhead equipment	Fuse		Replace - Same Size	IV
5015165	A45002	05/22/2015	21:27	05/22/2015	23:25	1	117	117	Overhead equipment	Overhead Secondary	Repair		I
5015179	M42105	05/23/2015	1:21	05/23/2015	7:17	1	355	355	Underground equipment	Underground Primary		Repair	I
5015185	K55398	05/23/2015	3:35	05/23/2015	5:20	1	104	104	Tree related-tree broken	Overhead Service	Cut in Clear		V
5015187	D69006	05/23/2015	3:56	05/23/2015	4:38	1	42	42	Animal related				I
5015189	P17108	05/23/2015	6:20	05/23/2015	8:11	82	9075	110	Animal related	Fuse	Replace - Same Size		IV