Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5041083	R93351	06/16/2015	9:14	06/16/2015	10:40	13	1117	85	Weather	Fuse	Replace - Same Size		V
5041089	M41111	06/16/2015	9:21	06/16/2015	10:50	1	88	88	Overhead equipment	Fuse	Patrol/Test/Inspect	Replace - Same Size	I
5041095	R93351	06/16/2015	9:22	06/16/2015	12:55	1	212	212	Overhead equipment	Overhead Transformer	Replace - Same Size	Advise Customer	V
5041097	M47802	06/16/2015	9:24	06/16/2015	9:45	1	20	20	Animal related	Fuse	Repair	Repair	V
5041101	A36002	06/16/2015	9:29	06/16/2015	11:15	1	105	105	Tree related-tree contact	Fuse	Repair	Patrol/Test/Inspect	I
5041109	Q83172	06/16/2015	9:37	06/16/2015	13:25	1	228	228	Overhead equipment	Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
5041107	C36002	06/16/2015	9:37	06/16/2015	11:32	1	115	115	Tree related-tree broken	Overhead Service	Repair		III
5041117	A17021	06/16/2015	9:37	06/16/2015	11:39	48	5854	121	Tree related-tree broken	Overhead Primary	Remove		I
5041121	S09521	06/16/2015	9:49	06/16/2015	12:24	54	8142	155	Underground equipment	Underground Primary	Repair		VI
5041123	S04545	06/16/2015	9:49	06/16/2015	11:35	1	105	105	Overhead equipment	Overhead Primary	Replace - Same Size	Replace - Same Size	VI
5041131	D69008	06/16/2015	9:55	06/16/2015	14:24	46	12394	269	Tree related-tree contact	Overhead Primary		Repair	I
5041143	K76541	06/16/2015	10:03	06/16/2015	10:12	1	8	8	Overhead equipment				IV
5041149	303007	06/16/2015	10:09	06/16/2015	13:15	6	1111	185	Tree related-tree broken	Overhead Secondary	Patrol/Test/Inspect	Repair	VI
5041151	Y82590	06/16/2015	10:12	06/16/2015	11:55	1	102	102	Animal related	Fuse	Replace - Same Size		IV
5041155	T23528	06/16/2015	10:14	06/16/2015	13:04	1	169	169	Overhead equipment	Overhead Transformer		Replace - New Size	VI
5041161	Y45503	06/16/2015	10:20	06/16/2015	11:15	1	54	54	Overhead equipment	Transformer Fuse	Repair	Replace - Same Size	IV
5041201	J83-UNIT-1	06/16/2015	10:25	06/16/2015	11:02	1587	58401	36	Overhead equipment	Lightning Arrestor	Replace - Same Size		VI
5041181	J87150	06/16/2015	10:26	06/16/2015	11:18	1	51	51	Overhead equipment				VI
5041263	K30204	06/16/2015	10:31	06/16/2015	11:08	23	846	36	Unknown	Fuse	Replace - Same Size		III
5041267	N05172	06/16/2015	10:31	06/16/2015	11:20	1	48	48	Weather	Transformer Fuse	Replace - Same Size		I
5041271	K02-UNIT-1	06/16/2015	10:33	06/16/2015	11:02	1	28	28	Overhead equipment	Lightning Arrestor	Replace - Same Size		VI
5041277	J99121	06/16/2015	10:35	06/16/2015	12:06	1	90	90	Overhead equipment				VI
5041281	K06-UNIT-1	06/16/2015	10:37	06/16/2015	11:02	1	24	24	Overhead equipment	Lightning Arrestor	Replace - Same Size		VI
5041289	K69112	06/16/2015	10:44	06/16/2015	11:48	1	63	63	Underground equipment	Underground Primary	Switch/Reset		IV
5041293	P26283	06/16/2015	10:46	06/16/2015	19:31	1	524	524	Underground equipment	Underground Secondary	Patrol/Test/Inspect	Repair	I
5041307	X88510	06/16/2015	10:59	06/16/2015	12:01	48	2944	61	Animal related	Fuse	Replace - Same Size		IV
5041311	J83139	06/16/2015	11:02	06/16/2015	11:28	1	25	25	Overhead equipment				VI
5041315	L93149	06/16/2015	11:03	06/16/2015	11:34	4	122	30	Animal related	Transformer Fuse	Replace - Same Size		VI
5041321	J83139	06/16/2015	11:05	06/16/2015	11:32	1	26	26	Overhead equipment				VI
5041323	Q82907	06/16/2015	11:06	06/16/2015	12:07	1	60	60	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	VI
5041325	J83137	06/16/2015	11:07	06/16/2015	11:40	1	32	32	Overhead equipment				VI
5041333	T08502	06/16/2015	11:24	06/16/2015	12:04	25	996	39	Overhead equipment	Fuse	Patrol/Test/Inspect	Repair	VI
5041335	C00001	06/16/2015	11:25	06/16/2015	13:20	1	114	114	Underground equipment	Pedestal	Repair		I
5041339	J83137	06/16/2015	11:27	06/16/2015	11:36	1	8	8	Overhead equipment				VI
5041341	M05360	06/16/2015	11:28	06/16/2015	12:28	1	59	59	Intentional				V
5041345	E10001	06/16/2015	11:37	06/16/2015	12:31	1	53	53	Overhead equipment	Transformer Fuse	Replace - Same Size		III
5041349	V61563	06/16/2015	11:43	06/16/2015	16:06	31	8135	262	Tree related-tree broken	Overhead Primary	Raise		II
5041351	R73839	06/16/2015	11:45	06/16/2015	14:00	9	1210	134	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	V
5041359	L24122	06/16/2015	11:50	06/16/2015	13:06	1	75	75	Animal related	Fuse	Replace - Same Size		III
5041365	L24122	06/16/2015	11:56	06/16/2015	13:05	2	137	68	Animal related	Fuse	Replace - Same Size		III
5041369	N78244	06/16/2015	11:57	06/16/2015	13:00	9	563	62	Animal related	Fuse	Replace - Same Size		I
5041375	N78244	06/16/2015	12:00	06/16/2015	13:00	1	59	59	Animal related	Fuse	Replace - Same Size		I
5041377	P62138	06/16/2015	12:00	06/16/2015	12:48	1	47	47	Other	Transformer Fuse	Replace - Same Size		VI
5041381	N78244	06/16/2015	12:02	06/16/2015	13:00	107	6107	57	Animal related	Fuse	Replace - Same Size		I
5041387	K39153	06/16/2015	12:17	06/16/2015	12:23	7	39	5	Overhead equipment				III
5041409	S09521	06/16/2015	12:22	06/16/2015	13:00	19	712	37	Overhead equipment	Fuse	Repair		VI
5041403	C00001	06/16/2015	12:28	06/16/2015	13:21	1	52	52	Underground equipment	Pedestal	Repair		I
5041405	K39153	06/16/2015	12:29	06/16/2015	12:47	4	71	17	Overhead equipment				III
5041413	K69113	06/16/2015	12:35	06/16/2015	12:44	1	9	9	Underground equipment				IV
5041415	J87111	06/16/2015	12:36	06/16/2015	13:12	1	35	35	Overhead equipment	Transformer Fuse	Replace - Same Size		VI
5041425	K73366	06/16/2015	12:52	06/16/2015	15:00	38	4840	127	Public	Underground Primary		Repair	IV
5041429	J83137	06/16/2015	12:59	06/16/2015	13:35	1	35	35	Overhead equipment				VI
5041433	M20221	06/16/2015	13:06	06/16/2015	14:02	1	55	55	Overhead equipment	Overhead Service	Repair		VI
5041449	K73366	06/16/2015	13:24	06/16/2015	15:00	1	95	95	Public	Underground Primary	Patrol/Test/Inspect	Repair	IV
5041455	B82001	06/16/2015	13:27	06/16/2015	14:33	1	65	65	Overhead equipment	Fuse	Repair		I
5041459	K73366	06/16/2015	13:31	06/16/2015	15:00	1	88	88	Public	Underground Primary	Patrol/Test/Inspect	Repair	IV

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5041467	M21134	06/16/2015	13:36	06/16/2015	14:44	1	67	67	Overhead equipment	Transformer Fuse	Replace - Same Size		VI
5041471	K01241	06/16/2015	13:46	06/16/2015	14:38	1	51	51	Animal related	Transformer Fuse	Replace - Same Size		VI
5041481	K76541	06/16/2015	13:49	06/16/2015	15:33	7	721	103	Animal related	Transformer Fuse	Replace - Same Size		IV
5041485	Q82907	06/16/2015	14:12	06/16/2015	15:12	1	59	59	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	VI
5041487	Y37592	06/16/2015	14:13	06/16/2015	15:30	1	76	76	Animal related	Fuse	Replace - Same Size		IV
5041493	U66524	06/16/2015	14:21	06/16/2015	16:18	1	116	116	Weather	Transformer Fuse	Replace - Same Size		II
5041513	V65549	06/16/2015	14:57	06/16/2015	18:01	7	1286	183	Animal related	Transformer Fuse	Replace - Same Size		II
5041523	P77233	06/16/2015	15:02	06/16/2015	22:20	1	437	437	Weather	Overhead Transformer		Replace - Same Size	VI
5041527	L50217	06/16/2015	15:12	06/16/2015	19:25	5	1263	252	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	VI
5041535	Q82907	06/16/2015	15:16	06/16/2015	15:44	1	27	27	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	VI
5041543	Q23258	06/16/2015	15:17	06/17/2015	9:00	535	228507	1063	Other	Pole	Repair	Replace - Same Size	VI
5041575	U04538	06/16/2015	15:26	06/16/2015	17:20	1	113	113	Animal related	Transformer Fuse	Replace - Same Size	Repair	II
5041583	Q27185	06/16/2015	15:31	06/16/2015	17:26	22	2527	114	Weather	Fuse	Replace - Same Size		VI
5041585	M21133	06/16/2015	15:31	06/16/2015	19:08	1	216	216	Overhead equipment	Overhead Transformer		Replace - Same Size	VI
5041589	D69003	06/16/2015	15:32	06/16/2015	17:17	49	5114	104	Underground equipment	Underground Primary	Repair	Repair	I
5041595	R84148	06/16/2015	15:35	06/16/2015	17:31	1	115	115	Overhead equipment	Disconnect Switch	Disconnect	Replace - Same Size	I
5041603	D69003	06/16/2015	15:41	06/16/2015	16:51	1	69	69	Underground equipment	Underground Primary			I
5041605	D69003	06/16/2015	15:42	06/16/2015	16:46	42	2688	63	Underground equipment	Underground Primary	Repair		I
5041607	P19395	06/16/2015	15:42	06/16/2015	16:18	1	35	35	Weather	Transformer Fuse	Replace - Same Size		V
5041621	M19222	06/16/2015	16:03	06/16/2015	19:15	1	191	191	Weather	Transformer Fuse	Replace - Same Size		VI
5041623	K94601	06/16/2015	16:03	06/16/2015	16:20	1	16	16	Jurisdictional	Other			III
5041627	D69005	06/16/2015	16:13	06/16/2015	18:14	32	3866	120	Underground equipment	Underground Primary	Repair	Repair	I
5041637	L36215	06/16/2015	16:18	06/16/2015	16:21	1	2	2	Jurisdictional	Other			III
5041661	S86580	06/16/2015	16:46	06/16/2015	19:01	2	268	134	Animal related	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
5041673	Q82907	06/16/2015	17:11	06/16/2015	21:57	1	285	285	Weather	Fuse	Replace - Same Size	Repair	VI
5041675	M19222	06/16/2015	17:16	06/16/2015	18:45	1	88	88	Weather	Fuse	Replace - Same Size		VI
5041677	Q27185	06/16/2015	17:22	06/16/2015	19:58	1	155	155	Weather	Overhead Transformer	Replace - Same Size	Replace - Same Size	VI
5041679	K57212	06/16/2015	17:22	06/16/2015	21:51	1	268	268	Tree related-tree broken				VI
5041689	K07320	06/16/2015	17:54	06/16/2015	18:50	1	55	55	Other	Other			I
5041691	K08909	06/16/2015	17:56	06/16/2015	19:07	1	70	70	Animal related	Transformer Fuse	Replace - Same Size		VI
5041701	K08909	06/16/2015	18:02	06/16/2015	19:07	1	64	64	Animal related	Transformer Fuse	Replace - Same Size		VI
5041703	U80564	06/16/2015	18:03	06/16/2015	21:43	1	219	219	Weather	Transformer Fuse	Replace - Same Size	Replace - Same Size	II
5041711	K08909	06/16/2015	18:10	06/16/2015	19:07	1	56	56	Animal related	Transformer Fuse	Replace - Same Size		VI
5041719	Q82907	06/16/2015	18:16	06/16/2015	18:54	1	37	37	Weather	Fuse	Replace - Same Size		VI
5041721	S34528	06/16/2015	18:17	06/16/2015	20:21	1	123	123	Tree related-tree broken	Other			VI
5041727	P77233	06/16/2015	18:24	06/16/2015	19:49	1	84	84	Weather	Transformer Fuse	Replace - Same Size		VI
5041729	Q23256	06/16/2015	18:26	06/17/2015	4:37	1	610	610	Tree related-tree broken	Overhead Service	Patrol/Test/Inspect	Repair	VI
5041735	Z06538	06/16/2015	18:55	06/16/2015	20:12	1	76	76	Overhead equipment	Fuse	Replace - Same Size		IV
5041791	B00002	06/16/2015	19:05	06/16/2015	20:47	303	30942	102	Overhead equipment	Disconnect Switch	Replace - Same Size	Replace - Same Size	I
5041755	Y28598	06/16/2015	19:20	06/16/2015	21:10	1	109	109	Overhead equipment	Overhead Service	Repair		IV
5041875	M09143	06/16/2015	19:27	06/17/2015	3:36	338	165004	488	Unknown	Regulator	Repair	Replace - Same Size	VI
5041763	T12528	06/16/2015	19:33	06/16/2015	21:30	1	116	116	Animal related	Transformer Fuse	Repair	Repair	VI
5041765	P82291	06/16/2015	19:33	06/16/2015	20:57	1	83	83	Weather	Transformer Fuse	Replace - Same Size		VI
5041767	M81402	06/16/2015	19:35	06/17/2015	1:05	1	329	329	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	V
5041771	U66524	06/16/2015	19:58	06/16/2015	22:30	1	151	151	Overhead equipment	Overhead Service	Repair		II
5041773	HA5431	06/16/2015	20:02	06/16/2015	22:13	1	130	130	Tree related-tree broken	Overhead Service	Cut in Clear	Repair	V
5041799	302002	06/16/2015	20:57	06/17/2015	3:25	3	1161	387	Overhead equipment	Overhead Primary	Cut in Clear	Repair	VI
5041797	P77233	06/16/2015	20:57	06/16/2015	22:20	1	82	82	Weather	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	VI
5041949	302002	06/16/2015	21:05	06/17/2015	3:25	6	2279	379	Overhead equipment				VI
5041811	M40132	06/16/2015	21:46	06/16/2015	23:55	45	5795	128	Underground equipment	Underground Primary	Switch/Reset	Repair	I
5041815	D39002	06/16/2015	22:02	06/17/2015	2:35	5	1364	272	Overhead equipment	Overhead Transformer	Replace - Same Size	Repair	I
5041817	J84123	06/16/2015	22:08	06/16/2015	22:23	6	84	14	Tree related-tree contact	Fuse			VI
5041819	B93003	06/16/2015	22:09	06/16/2015	23:59	1	109	109	Unknown	Fuse	Replace - Same Size		I
5041823	X72535	06/16/2015	22:35	06/16/2015	23:47	1	71	71	Animal related	Transformer Fuse	Replace - Same Size		IV
5041825	P60170	06/16/2015	22:40	06/17/2015	4:22	1	341	341	Tree related-tree contact	Overhead Primary	Reconnect	Reconnect	VI
5041827	Q23256	06/16/2015	23:13	06/16/2015	23:58	1	44	44	Tree related-tree broken	Customer Equipment	Disconnect		VI

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5041829	M20221	06/16/2015	23:23	06/17/2015	12:28	1	784	784	Overhead equipment	Pole	Replace - New Size	Repair	VI
5041831	S50544	06/16/2015	23:23	06/17/2015	5:30	7	2562	366	Overhead equipment	Overhead Transformer		Replace - New Size	VI
5041833	M20221	06/16/2015	23:24	06/17/2015	11:57	9	6782	753	Overhead equipment				VI
5041841	HB6283	06/16/2015	23:42	06/17/2015	0:50	22	1474	67	Overhead equipment	Disconnect Switch			VI
5041843	HB6283	06/16/2015	23:47	06/17/2015	0:59	1	71	71	Overhead equipment	Disconnect Switch			VI
5041847	P60170	06/16/2015	23:48	06/17/2015	4:45	1	296	296	Tree related-tree contact	Overhead Primary	Repair	Repair	VI
5041845	312112	06/16/2015	23:48	06/17/2015	3:45	1	236	236	Tree related-tree contact	Overhead Service	Patrol/Test/Inspect	Repair	V
5041849	S25551	06/16/2015	23:49	06/17/2015	2:18	19	2831	149	Overhead equipment	Overhead Primary	Repair	Repair	VI
5041853	Q94-UNIT-1	06/16/2015	23:55	06/17/2015	2:54	1	179	179	Overhead equipment	Overhead Primary			VI
5041857	HB6283	06/16/2015	23:58	06/17/2015	0:23	1	24	24	Overhead equipment	Disconnect Switch			VI
5041859	350103	06/17/2015	0:05	06/17/2015	5:10	1	304	304	Tree related-tree broken	Overhead Primary		Repair	V
5041867	S61575	06/17/2015	0:38	06/17/2015	4:00	36	7269	201	Tree related-tree broken	Overhead Primary	Repair		VI
5041871	M05362	06/17/2015	0:45	06/17/2015	3:34	1	168	168	Tree related-tree contact	Customer Equipment	Patrol/Test/Inspect	Advise Customer	V
5041873	HB6283	06/17/2015	0:46	06/17/2015	1:00	1	14	13	Overhead equipment	Disconnect Switch			VI
5041891	M09144	06/17/2015	1:10	06/17/2015	5:31	8	2084	260	Weather	Disconnect Switch	Repair	Replace - Same Size	VI
5041977	Q75146	06/17/2015	1:13	06/17/2015	6:20	443	136200	307	Overhead equipment	Overhead Primary	Repair	Repair	VI
5041895	Q23258	06/17/2015	1:16	06/17/2015	9:00	4	1857	464	Overhead equipment				VI
5041899	S41565	06/17/2015	1:23	06/17/2015	4:40	10	1961	196	Tree related-tree broken	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
5041921	Q69926	06/17/2015	1:26	06/17/2015	7:41	13	4863	374	Tree related-tree broken	Tree	Trim		VI
5041959	Q28141	06/17/2015	1:29	06/17/2015	3:36	4	509	127	Overhead equipment				VI
5041911	S83533	06/17/2015	1:37	06/17/2015	3:58	9	1265	140	Weather				VI
5041915	B58001	06/17/2015	1:42	06/17/2015	4:36	6	1042	173	Overhead equipment	Overhead Primary	Repair	Repair	I
5041907	Q28141	06/17/2015	1:46	06/17/2015	9:03	17	2528	437	Tree related-tree broken	Pole	Replace - New Size	Replace - New Size	VI
5041925	S83533	06/17/2015	1:52	06/17/2015	3:58	3	376	125	Weather				VI
5041927	S83533	06/17/2015	1:52	06/17/2015	3:58	2	250	125	Weather				VI
5041929	M09144	06/17/2015	1:53	06/17/2015	5:36	1	222	222	Weather	Overhead Transformer	Repair	Replace - Same Size	VI
5041937	346002	06/17/2015	2:10	06/17/2015	10:47	5	2584	516	Overhead equipment	Overhead Transformer		Replace - Same Size	VI
5041943	Q64919	06/17/2015	2:12	06/17/2015	4:01	15	1624	108	Weather	Fuse	Replace - Same Size	Replace - Same Size	VI
5041951	S43501	06/17/2015	2:41	06/17/2015	3:00	443	8461	19	Other	Other			VI
5041953	B57001	06/17/2015	2:59	06/17/2015	5:12	1	132	132	Tree related-tree broken	Overhead Service	Cut in Clear	Cut in Clear	I
5041957	V58507	06/17/2015	3:15	06/17/2015	6:35	3	598	199	Overhead equipment	Disconnect Switch	Replace - Same Size		II
5041967	S04545	06/17/2015	4:25	06/17/2015	7:30	1	184	184	Overhead equipment	Overhead Primary	Repair	Repair	VI
5041993	Q11517	06/17/2015	4:51	06/17/2015	9:49	29	8632	297	Public	Pole	Replace - Same Size		I
5041979	Y51506	06/17/2015	5:15	06/17/2015	6:09	1	53	53	Public	Overhead Secondary	Repair		IV
5041985	Q16867	06/17/2015	5:30	06/17/2015	8:00	4	599	149	Tree related-tree broken	Transformer Fuse	Replace - Same Size		V
5041987	M09143	06/17/2015	5:31	06/17/2015	10:30	6	1793	298	Overhead equipment	Overhead Transformer	Replace - Same Size	Repair	VI
5041995	M09144	06/17/2015	5:58	06/17/2015	7:37	1	98	98	Tree related-tree broken	Overhead Secondary	Repair		VI
5154999	X66582	06/17/2015	6:05	06/17/2015	8:35	64	7589	149	Tree related-tree broken				IV
5042003	Q04411	06/17/2015	6:14	06/17/2015	7:00	1	45	45	Overhead equipment	Transformer Fuse	Repair	Repair	III
5042005	T05539	06/17/2015	6:19	06/17/2015	7:04	1	44	44	Unknown	Fuse			VI
5042009	HD5254	06/17/2015	6:33	06/17/2015	8:27	47	5336	113	Overhead equipment	Lightning Arrestor	Patrol/Test/Inspect	Repair	VI
5042011	Q75146	06/17/2015	6:35	06/17/2015	7:36	1	60	60	Overhead equipment				VI
5042013	R58961	06/17/2015	6:38	06/17/2015	7:31	10	523	52	Animal related	Transformer Fuse	Repair	Repair	IV
5042015	M09143	06/17/2015	6:50	06/17/2015	7:34	1	43	43	Weather	Transformer Fuse	Repair	Replace - Same Size	VI
5042017	Q75146	06/17/2015	6:55	06/17/2015	7:23	1	27	27	Tree related-tree broken	Tree		Trim	VI
5042019	J50185	06/17/2015	6:56	06/17/2015	8:55	1	118	118	Underground equipment	Underground Primary	Repair	Repair	III
5042021	M51275	06/17/2015	6:57	06/17/2015	13:22	1	384	384	Overhead equipment	Overhead Service		Repair	III
5042025	D36003	06/17/2015	6:59	06/17/2015	11:51	1	292	292	Underground equipment	Underground Primary	Repair	Repair	I
5042027	S43502	06/17/2015	7:00	06/17/2015	7:49	1	48	48	Weather	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
5042033	M78323	06/17/2015	7:07	06/17/2015	8:31	5	419	83	Animal related	Transformer Fuse	Replace - Same Size		V
5042043	K67924	06/17/2015	7:15	06/17/2015	9:52	18	2818	156	Tree related-tree broken	Overhead Primary	Repair	Repair	VI
5042041	D69004	06/17/2015	7:19	06/17/2015	11:08	1	228	228	Underground equipment	Other	Repair	Repair	I
5042047	Q75145	06/17/2015	7:32	06/17/2015	8:43	1	70	70	Tree related-tree broken	Overhead Service	Replace - New Size		VI
5042049	T11508	06/17/2015	7:36	06/17/2015	13:00	1	323	323	Weather	Overhead Transformer	Replace - Same Size	Replace - Same Size	VI
5042051	M09143	06/17/2015	7:36	06/17/2015	8:09	1	32	32	Tree related-tree contact	Fuse	Replace - Same Size	Repair	VI
5042057	N18211	06/17/2015	7:50	06/17/2015	10:00	1	129	129	Public	Pole	Patrol/Test/Inspect	Replace - New Size	III

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5042063	348117	06/17/2015	8:07	06/17/2015	10:10	1	122	122	Overhead equipment	Disconnect Switch	Patrol/Test/Inspect	Replace - New Size	V
5042065	K32916	06/17/2015	8:08	06/17/2015	10:28	1	139	139	Tree related-tree contact	Overhead Service	Repair		VI
5042067	U57561	06/17/2015	8:09	06/17/2015	10:00	1	110	110	Weather	Disconnect Switch	Replace - Same Size		II
5042077	M09175	06/17/2015	8:16	06/17/2015	9:59	1	102	102	Overhead equipment	Fuse	Replace - Same Size		VI
5042081	J83140	06/17/2015	8:20	06/17/2015	9:19	1	58	58	Tree related-tree broken	Overhead Service	Cut in Clear		VI
5042087	D69004	06/17/2015	8:23	06/17/2015	14:45	1	381	381	Underground equipment	Underground Secondary	Repair	Replace - Same Size	I
5042091	K82202	06/17/2015	8:24	06/17/2015	9:40	89	6710	75	Overhead equipment	Recloser			III
5042097	Y63527	06/17/2015	8:25	06/17/2015	8:59	1	33	33	Animal related	Transformer Fuse			IV
5042101	K82202	06/17/2015	8:27	06/17/2015	10:10	4	410	102	Animal related				III
5042103	U57561	06/17/2015	8:28	06/17/2015	10:01	1	92	92	Weather	Disconnect Switch	Repair		II
5042105	K82202	06/17/2015	8:30	06/17/2015	10:10	1	99	99	Animal related	Disconnect Switch	Replace - Same Size		III
5042113	N18211	06/17/2015	8:44	06/17/2015	10:01	1	76	76	Public	Pole	Patrol/Test/Inspect	Repair	III
5042121	K08909	06/17/2015	8:51	06/17/2015	13:40	4	1152	288	Tree related-tree broken	Fuse		Repair	VI
5042125	D41002	06/17/2015	8:53	06/17/2015	10:22	1	88	88	Unknown	Fuse	Replace - Same Size		I
5042133	Q28141	06/17/2015	9:03	06/17/2015	10:25	2	162	81	Overhead equipment				VI
5042149	U66515	06/17/2015	9:07	06/17/2015	10:26	320	25273	78	Tree related-tree broken	Tree			II
5042145	R48165	06/17/2015	9:09	06/17/2015	10:08	1	58	58	Overhead equipment	Fuse			IV
5042147	302001	06/17/2015	9:10	06/17/2015	11:10	1	119	119	Tree related-tree contact	Overhead Service	Repair		VI
5042155	M09175	06/17/2015	9:11	06/17/2015	9:57	1	45	45	Overhead equipment	Overhead Primary		Replace - Same Size	VI
5042173	B61001	06/17/2015	9:16	06/17/2015	11:46	124	18479	149	Overhead equipment	Fuse	Replace - Same Size		I
5042195	K82202	06/17/2015	9:25	06/17/2015	10:10	1	44	44	Animal related				III
5042207	N93260	06/17/2015	9:35	06/17/2015	10:47	11	791	71	Animal related	Fuse		Replace - Same Size	III
5042215	070058	06/17/2015	9:39	06/17/2015	19:26	1	586	586	Public	Overhead Primary	Patrol/Test/Inspect	Replace - Same Size	VI
5042219	M09143	06/17/2015	9:41	06/17/2015	10:30	1	48	48	Overhead equipment	Lightning Arrestor	Replace - Same Size		VI
5042221	X69555	06/17/2015	9:42	06/17/2015	11:23	1	100	100	Animal related	Fuse	Replace - Same Size		IV
5042229	A36002	06/17/2015	9:46	06/17/2015	11:06	89	7091	79	Unknown	Fuse	Replace - Same Size		I
5042233	L95110	06/17/2015	9:51	06/17/2015	10:08	1	16	16	Tree related-tree contact	Overhead Secondary		Trim	III
5042243	M09144	06/17/2015	9:58	06/17/2015	13:21	1	203	203	Weather	Underground Transformer	Replace - Same Size	Replace - Same Size	VI
5042249	J63174	06/17/2015	10:00	06/17/2015	16:52	12	4932	411	Underground equipment	Underground Service	Repair	Repair	III
5042259	B00002	06/17/2015	10:02	06/17/2015	13:11	20	3767	188	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
5042261	Q21293	06/17/2015	10:15	06/17/2015	11:50	21	1989	94	Animal related	Fuse	Replace - Same Size	Replace - Same Size	VI
5042267	M09175	06/17/2015	10:20	06/17/2015	11:21	1	60	60	Overhead equipment	Connector	Repair		VI
5042279	K82202	06/17/2015	10:27	06/17/2015	10:30	1	2	2	Unknown				III
5042281	J56341	06/17/2015	10:28	06/17/2015	11:46	4	310	77	Animal related	Transformer Fuse			III
5042283	M47802	06/17/2015	10:34	06/17/2015	11:20	1	45	45	Animal related	Transformer Fuse	Repair		V
5042293	Q82907	06/17/2015	10:46	06/17/2015	12:15	1	88	88	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	VI
5042297	D66004	06/17/2015	10:51	06/17/2015	11:38	1	46	46	Animal related	Transformer Fuse	Replace - Same Size		IV
5042303	339162	06/17/2015	10:55	06/17/2015	12:50	1	114	114	Underground equipment	Overhead Service	Repair	Repair	V
5042311	B80003	06/17/2015	11:01	06/17/2015	11:42	10	404	40	Animal related	Fuse	Replace - Same Size		I
5042313	N93260	06/17/2015	11:01	06/17/2015	13:49	11	1849	168	Animal related	Fuse		Repair	III
5042317	N93260	06/17/2015	11:06	06/17/2015	11:47	2	81	40	Animal related	Fuse			III
5042319	K15205	06/17/2015	11:10	06/17/2015	14:17	1	186	186	Tree related-tree broken	Tree	Trim		VI
5042327	V23001	06/17/2015	11:22	06/17/2015	11:45	1	22	22	Overhead equipment				II
5042333	L95110	06/17/2015	11:28	06/17/2015	12:48	1	79	79	Tree related-tree contact	Overhead Service	Repair		III
5042335	X19561	06/17/2015	11:31	06/17/2015	13:05	1	93	93	Overhead equipment	Disconnect Switch	Replace - Same Size		IV
5042337	A48004	06/17/2015	11:34	06/17/2015	12:15	11	446	40	Overhead equipment				I
5042341	M07235	06/17/2015	11:44	06/17/2015	14:55	1	190	190	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	III
5042349	X69555	06/17/2015	12:08	06/17/2015	13:00	1	51	51	Animal related	Fuse	Replace - Same Size		IV
5042361	K09863	06/17/2015	12:19	06/17/2015	13:43	6	503	83	Overhead equipment	Disconnect Switch	Replace - Same Size	Repair	V
5042367	L95110	06/17/2015	12:24	06/17/2015	12:48	14	335	23	Tree related-tree contact	Overhead Service	Repair		III
5042371	S43501	06/17/2015	12:29	06/17/2015	14:46	1	136	136	Overhead equipment	Connector	Patrol/Test/Inspect	Repair	VI
5042377	B81003	06/17/2015	12:43	06/17/2015	13:53	4	277	69	Animal related	Fuse	Replace - Same Size		I
5042501	R33127	06/17/2015	12:43	06/17/2015	16:50	9	2216	246	Overhead equipment	Overhead Transformer		Replace - Same Size	I
5042381	Q75146	06/17/2015	12:47	06/17/2015	14:20	1	92	92	Tree related-tree contact				VI
5042383	R07381	06/17/2015	12:49	06/17/2015	13:16	65	1750	26	Animal related	Fuse	Replace - Same Size	Repair	I
5042387	R33127	06/17/2015	12:50	06/17/2015	16:04	174	12617	194	Overhead equipment	Disconnect Switch	Replace - Same Size	Replace - Same Size	I

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5042389	A97006	06/17/2015	12:50	06/17/2015	15:15	1	144	144	Animal related	Fuse	Replace - Same Size		I
5042401	R01152	06/17/2015	13:07	06/17/2015	15:39	1	151	151	Underground equipment	Underground Service	Repair	Repair	III
5042403	S57518	06/17/2015	13:12	06/17/2015	16:26	1	193	193	Other	Overhead Service	Repair	Repair	VI
5042405	Q11516	06/17/2015	13:12	06/17/2015	14:28	1	75	75	Other	Other	Repair		I
5042407	U31003	06/17/2015	13:16	06/17/2015	14:40	1	83	83	Overhead equipment	Transformer Fuse	Replace - Same Size		II
5042421	J39392	06/17/2015	13:43	06/17/2015	15:30	1	106	106	Overhead equipment	Overhead Transformer		Replace - Same Size	III
5042429	X96543	06/17/2015	13:52	06/17/2015	14:41	90	4426	49	Tree related-tree contact	Overhead Primary	Repair		IV
5042431	K58213	06/17/2015	14:01	06/17/2015	18:40	1	278	278	Underground equipment	Underground Secondary	Patrol/Test/Inspect	Repair	VI
5042433	R33127	06/17/2015	14:09	06/17/2015	15:30	1	80	80	Tree related-tree contact	Overhead Service			I
5042437	K48384	06/17/2015	14:14	06/17/2015	15:14	4	237	59	Tree related-tree broken				V
5042441	K48384	06/17/2015	14:20	06/17/2015	18:39	5	1295	259	Tree related-tree broken	Overhead Secondary	Patrol/Test/Inspect	Repair	V
5042443	J15302	06/17/2015	14:28	06/17/2015	15:22	1	53	53	Overhead equipment	Connector	Replace - Same Size	Replace - Same Size	I
5042453	P42230	06/17/2015	14:38	06/17/2015	18:09	9	1891	210	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	VI
5042465	340100	06/17/2015	14:58	06/17/2015	16:08	1	69	69	Overhead equipment	Overhead Secondary	Repair		V
5042467	B44002	06/17/2015	15:08	06/17/2015	18:23	1	194	194	Tree related-tree broken	Tree	Advise Customer		I
5042471	Q54908	06/17/2015	15:24	06/17/2015	16:23	1	58	58	Overhead equipment	Connector		Replace - Same Size	VI
5042495	Q64939	06/17/2015	15:39	06/17/2015	16:36	37	2098	56	Weather	Fuse	Replace - Same Size		VI
5042487	B35002	06/17/2015	15:51	06/17/2015	17:45	1	113	113	Overhead equipment	Overhead Service	Repair		I
5042503	S47537	06/17/2015	16:04	06/17/2015	17:27	7	580	82	Overhead equipment				VI
5042507	S47537	06/17/2015	16:09	06/17/2015	17:27	6	465	77	Overhead equipment				VI
5042509	Q32170	06/17/2015	16:10	06/17/2015	18:00	1	109	109	Animal related	Transformer Fuse	Replace - Same Size	Replace - Same Size	I
5042513	S07536	06/17/2015	16:14	06/17/2015	18:02	1	107	107	Tree related-tree broken	Overhead Service	Repair	Repair	VI
5042519	V92555	06/17/2015	16:33	06/17/2015	18:20	1	106	106	Other	Overhead Service	Repair	Patrol/Test/Inspect	II
5042523	Q63835	06/17/2015	16:35	06/17/2015	19:32	1	176	176	Public	Underground Transformer	Patrol/Test/Inspect	Straighten	V
5042531	S04545	06/17/2015	17:02	06/17/2015	19:56	1	173	173	Tree related-tree broken	Overhead Service	Patrol/Test/Inspect	Repair	VI
5042539	X83541	06/17/2015	17:20	06/17/2015	19:40	2	278	139	Animal related	Transformer Fuse	Replace - Same Size		IV
5042543	D01002	06/17/2015	17:53	06/18/2015	1:10	1	436	436	Underground equipment	Underground Primary	Repair	Repair	I
5042605	M49424	06/17/2015	18:12	06/17/2015	21:46	36	7684	213	Overhead equipment				V
5042557	D69008	06/17/2015	18:33	06/17/2015	23:06	5	1360	272	Underground equipment	Other	Repair	Repair	I
5042563	M19222	06/17/2015	19:05	06/17/2015	22:47	1	221	221	Tree related-tree broken	Fuse	Replace - Same Size		VI
5042565	K46389	06/17/2015	19:09	06/17/2015	23:59	1	289	289	Underground equipment	Underground Service		Repair	V
5042567	303007	06/17/2015	19:34	06/17/2015	21:22	1	107	107	Tree related-tree contact	Overhead Service	Repair		VI
5042569	H10843	06/17/2015	19:37	06/17/2015	21:03	1	85	85	Weather	Transformer Fuse	Replace - Same Size		V
5042573	V59561	06/17/2015	19:51	06/17/2015	20:41	1	49	49	Animal related	Transformer Fuse	Replace - Same Size		II
5042585	A68002	06/17/2015	21:00	06/17/2015	22:33	1	92	92	Other	Other			I
5042591	A48004	06/17/2015	21:10	06/17/2015	22:04	22	1178	53	Animal related	Fuse	Patrol/Test/Inspect		I
5042595	J47178	06/17/2015	21:18	06/18/2015	2:19	30	9030	301	Underground equipment	Underground Secondary			III
5042597	Z29579	06/17/2015	21:18	06/18/2015	2:19	1	300	300	Tree related-tree contact	Overhead Service	Repair		IV
5042603	M09144	06/17/2015	21:35	06/17/2015	21:55	1	19	19	Other	Fuse	Replace - Same Size		VI
5042611	U66515	06/17/2015	21:51	06/18/2015	2:00	6	1492	248	Tree related-tree broken	Overhead Primary	Repair		II
5042617	M36184	06/17/2015	22:35	06/18/2015	0:05	61	5451	89	Underground equipment	Underground Primary	Switch/Reset	Repair	I
5042637	L00134	06/18/2015	0:31	06/18/2015	3:34	42	6815	182	Underground equipment	Underground Primary		Repair	III
5042643	L00134	06/18/2015	0:31	06/18/2015	3:05	5	765	153	Underground equipment	Underground Primary	Repair		III
5042627	L00134	06/18/2015	0:39	06/18/2015	3:09	1	149	149	Underground equipment	Underground Primary		Repair	III
5042629	L00134	06/18/2015	0:53	06/18/2015	3:10	1	136	136	Underground equipment	Underground Primary	Repair		III
5042631	P26283	06/18/2015	1:08	06/18/2015	3:15	1	126	126	Overhead equipment	Transformer Fuse	Repair	Repair	I
5042633	L86175	06/18/2015	1:10	06/18/2015	2:43	10	927	92	Tree related-tree broken	Transformer Fuse	Replace - Same Size		IV
5042635	L86175	06/18/2015	1:15	06/18/2015	2:15	1	59	59	Tree related-tree broken	Overhead Service			IV
5042639	F10002	06/18/2015	1:57	06/18/2015	3:12	1	74	74	Tree related-tree broken	Fuse	Replace - Same Size		III
5042641	J89125	06/18/2015	3:02	06/18/2015	5:15	1	132	132	Tree related-tree broken	Overhead Service			VI
5042647	D31018	06/18/2015	3:48	06/18/2015	6:47	1	179	179	Overhead equipment	Overhead Transformer			III
5042649	P49187	06/18/2015	4:42	06/18/2015	6:23	18	1803	100	Unknown	Fuse	Replace - Same Size	Replace - Same Size	I
5042653	B93003	06/18/2015	5:13	06/18/2015	6:50	1	96	96	Tree related-tree broken	Fuse	Replace - Same Size		I
5042655	Q82906	06/18/2015	5:56	06/18/2015	8:12	31	4228	136	Tree related-tree broken	Overhead Primary		Repair	VI
5042827	Q82906	06/18/2015	5:58	06/18/2015	9:30	10	2118	211	Tree related-tree broken	Tree		Trim	VI
5042677	R61241	06/18/2015	6:25	06/18/2015	8:14	1	108	108	Overhead equipment	Connector	Repair		IV

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5042679	L24121	06/18/2015	6:27	06/18/2015	7:05	7	259	37	Unknown	Fuse	Replace - Same Size		III
5042681	S52515	06/18/2015	6:48	06/18/2015	8:05	1	76	76	Overhead equipment	Overhead Primary	Replace - Same Size	Replace - Same Size	VI
5042683	S22594	06/18/2015	6:49	06/18/2015	7:45	7	388	55	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	VI
5042685	B93003	06/18/2015	6:52	06/18/2015	9:26	1	153	153	Overhead equipment	Overhead Transformer	Repair		I
5042691	V78001	06/18/2015	7:27	06/18/2015	9:10	1	102	102	Weather	Disconnect Switch			II
5042813	U37579	06/18/2015	7:46	06/18/2015	9:13	943	53702	87	Overhead equipment	Overhead Primary	Repair		II
5042831	J99121	06/18/2015	8:16	06/18/2015	9:01	1	44	44	Overhead equipment	Transformer Fuse	Repair		VI
5042829	J75271	06/18/2015	8:16	06/18/2015	11:27	1	190	190	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	IV
5042843	J15302	06/18/2015	8:43	06/18/2015	11:48	1	184	184	Overhead equipment	Overhead Transformer	Replace - Same Size	Replace - Same Size	I
5042845	Q14390	06/18/2015	8:47	06/18/2015	13:42	1	294	294	Other	Underground Service	Repair	Repair	I
5042865	J63174	06/18/2015	9:15	06/18/2015	10:00	10	445	44	Animal related	Transformer Fuse	Repair	Repair	III
5042867	B25002	06/18/2015	9:18	06/18/2015	10:32	1	73	73	Overhead equipment	Lightning Arrestor	Replace - Same Size	Replace - Same Size	I
5042875	N15850	06/18/2015	9:21	06/18/2015	10:25	2	126	63	Weather	Transformer Fuse	Replace - Same Size		V
5042883	J99141	06/18/2015	9:29	06/18/2015	10:06	1	36	36	Overhead equipment	Transformer Fuse	Replace - Same Size		VI
5042885	L24124	06/18/2015	9:29	06/18/2015	11:14	44	4610	104	Animal related	Fuse	Replace - Same Size		III
5042889	B08003	06/18/2015	9:30	06/18/2015	15:11	1	340	340	Underground equipment	Underground Secondary	Patrol/Test/Inspect	Repair	I
5042897	Q82906	06/18/2015	9:46	06/18/2015	12:29	10	1636	163	Tree related-tree broken	Overhead Primary	Repair		VI
5042901	S42578	06/18/2015	9:54	06/18/2015	10:41	1	46	46	Overhead equipment	Connector	Repair	Replace - Same Size	VI
5042909	L81141	06/18/2015	9:57	06/18/2015	10:49	5	259	51	Overhead equipment	Fuse			IV
5042919	L24124	06/18/2015	10:11	06/18/2015	11:13	82	5134	62	Animal related				III
5042925	L24124	06/18/2015	10:12	06/18/2015	10:30	224	3991	17	Animal related				III
5042927	N70330	06/18/2015	10:12	06/18/2015	11:38	3	255	85	Overhead equipment	Overhead Secondary	Reconnect		I
5042937	M45212	06/18/2015	10:15	06/18/2015	13:58	1	222	222	Underground equipment	Underground Service		Repair	IV
5042947	L82187	06/18/2015	10:19	06/18/2015	12:32	1	132	132	Overhead equipment	Overhead Transformer			IV
5042973	M21133	06/18/2015	11:10	06/18/2015	13:00	1	109	109	Overhead equipment	Fuse	Repair	Replace - Same Size	VI
5042983	N67309	06/18/2015	11:23	06/18/2015	12:07	1	43	43	Overhead equipment	Overhead Service	Reconnect		I
5042993	Y45503	06/18/2015	11:38	06/18/2015	13:31	1	112	112	Tree related-tree broken	Overhead Service	Repair	Replace - New Size	IV
5043059	Q71846	06/18/2015	11:44	06/18/2015	15:25	14	3087	220	Tree related-tree broken	Tree	Remove		V
5043003	K27150	06/18/2015	11:52	06/18/2015	13:35	1	102	102	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	VI
5043005	B81001	06/18/2015	12:01	06/18/2015	13:19	1	77	77	Unknown	Transformer Fuse	Replace - Same Size		I
5043015	V14579	06/18/2015	12:24	06/18/2015	13:25	1	60	60	Weather				II
5043021	L95110	06/18/2015	12:29	06/18/2015	14:12	1	102	102	Tree related-tree contact	Overhead Service	Repair		III
5043023	Y45001	06/18/2015	12:35	06/18/2015	14:06	31	2819	90	Tree related-tree broken	Overhead Primary	Repair	Replace - Same Size	IV
5043031	N90245	06/18/2015	12:55	06/18/2015	14:54	8	950	118	Animal related	Fuse		Replace - Same Size	III
5043037	N90245	06/18/2015	12:56	06/18/2015	14:55	1	118	118	Animal related	Fuse			III
5043043	K80386	06/18/2015	13:06	06/18/2015	14:58	58	6462	111	Weather	Fuse	Replace - Same Size		IV
5043045	Y97512	06/18/2015	13:06	06/18/2015	17:14	27	5832	248	Tree related-tree broken	Overhead Primary	Repair	Repair	IV
5043047	Q74148	06/18/2015	13:06	06/18/2015	14:45	1	98	98	Overhead equipment	Overhead Secondary		Repair	IV
5043055	Z04520	06/18/2015	13:08	06/18/2015	14:22	1	73	73	Weather	Fuse	Replace - Same Size	Repair	IV
5043057	R65451	06/18/2015	13:09	06/18/2015	15:03	1	113	113	Weather	Transformer Fuse	Replace - Same Size		IV
5043071	R60551	06/18/2015	13:11	06/18/2015	14:50	14	1399	99	Overhead equipment				IV
5043073	R65451	06/18/2015	13:11	06/18/2015	15:03	1	111	111	Weather	Transformer Fuse	Replace - Same Size		IV
5043075	K80386	06/18/2015	13:11	06/18/2015	15:00	1	108	108	Overhead equipment	Fuse	Replace - Same Size		IV
5043079	Q74149	06/18/2015	13:12	06/18/2015	14:06	1	53	53	Weather	Fuse	Replace - Same Size		IV
5043081	Q74148	06/18/2015	13:12	06/18/2015	13:47	1	34	34	Overhead equipment	Overhead Service		Repair	IV
5043085	T12527	06/18/2015	13:14	06/18/2015	13:58	1	43	43	Overhead equipment	Disconnect Switch	Patrol/Test/Inspect	Replace - Same Size	VI
5043099	K75312	06/18/2015	13:14	06/18/2015	16:12	26	4607	177	Tree related-tree broken	Overhead Primary	Repair		IV
5043093	K80381	06/18/2015	13:15	06/18/2015	15:36	22	3109	141	Underground equipment	Underground Primary		Switch/Reset	IV
5043091	K74166	06/18/2015	13:15	06/18/2015	16:05	1	169	169	Tree related-tree broken	Overhead Service	Repair		IV
5043095	Z04520	06/18/2015	13:18	06/18/2015	14:45	3	260	86	Weather	Crossarm	Repair	Repair	IV
5043097	303004	06/18/2015	13:18	06/18/2015	18:19	4	1202	300	Public	Pole	Repair	Replace - Same Size	VI
5043101	F22001	06/18/2015	13:19	06/18/2015	13:55	1	35	35	Weather	Transformer Fuse	Repair		IV
5043115	D67001	06/18/2015	13:19	06/18/2015	14:21	10	615	61	Weather	Fuse	Repair		IV
5043119	N90245	06/18/2015	13:36	06/18/2015	14:55	1	78	78	Animal related	Fuse			III
5043121	Y68581	06/18/2015	13:42	06/18/2015	17:16	1	213	213	Tree related-tree broken	Overhead Service	Repair		IV
5043135	L71171	06/18/2015	13:47	06/18/2015	17:57	34	8473	249	Tree related-tree broken	Pole	Replace - Same Size	Replace - Same Size	IV

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5043131	X66582	06/18/2015	13:49	06/18/2015	16:39	1	169	169	Tree related-tree broken	Overhead Service	Replace - New Size	Replace - New Size	IV
5043129	K76542	06/18/2015	13:49	06/18/2015	19:20	1	330	330	Tree related-tree broken	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	IV
5043137	K73361	06/18/2015	13:53	06/18/2015	15:05	9	645	71	Tree related-tree contact	Overhead Secondary	Patrol/Test/Inspect	Repair	IV
5043217	D70001	06/18/2015	13:55	06/18/2015	16:47	76	13068	171	Underground equipment	Underground Primary			I
5043145	Z04520	06/18/2015	13:56	06/18/2015	14:45	1	48	48	Weather	Fuse	Replace - Same Size	Repair	IV
5043299	D70001	06/18/2015	14:02	06/19/2015	5:01	1	899	899	Underground equipment	Underground Primary	Repair	Repair	I
5043151	R49261	06/18/2015	14:02	06/18/2015	14:40	1	37	37	Weather	Transformer Fuse	Replace - Same Size		VI
5043155	Y97512	06/18/2015	14:06	06/18/2015	17:15	1	188	188	Tree related-tree broken	Overhead Primary	Repair	Repair	IV
5043157	R49261	06/18/2015	14:09	06/18/2015	14:48	1	38	38	Weather	Transformer Fuse	Replace - Same Size		VI
5043159	H01194	06/18/2015	14:13	06/18/2015	14:58	1	44	44	Animal related	Fuse	Replace - Same Size		III
5043163	R66470	06/18/2015	14:15	06/18/2015	15:51	1	95	95	Tree related-tree broken	Overhead Service	Repair		IV
5043167	B65003	06/18/2015	14:16	06/18/2015	15:11	46	2527	54	Animal related	Fuse	Patrol/Test/Inspect		I
5043169	L68114	06/18/2015	14:17	06/18/2015	15:50	1	92	92	Tree related-tree broken	Overhead Service	Repair		IV
5043171	S95570	06/18/2015	14:17	06/18/2015	18:10	1	232	232	Tree related-tree broken	Tree	Remove		VI
5043177	V40556	06/18/2015	14:29	06/18/2015	20:08	1	338	338	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Advise Customer	II
5043179	K80386	06/18/2015	14:33	06/18/2015	15:07	1	33	33	Weather	Fuse	Replace - Same Size		IV
5043183	K80386	06/18/2015	14:43	06/18/2015	15:00	1	16	16	Overhead equipment	Fuse	Replace - Same Size		IV
5043187	X82004	06/18/2015	14:47	06/18/2015	18:15	1	207	207	Tree related-tree broken	Overhead Service	Repair		IV
5043189	D88002	06/18/2015	14:47	06/18/2015	17:29	1	161	161	Overhead equipment				I
5043191	L23145	06/18/2015	14:48	06/18/2015	16:17	1	88	88	Tree related-tree broken	Overhead Service	Replace - Same Size		III
5043221	A50002	06/18/2015	14:50	06/18/2015	18:40	1	229	229	Underground equipment	Underground Primary	Repair		I
5043193	K80386	06/18/2015	14:50	06/18/2015	15:15	1	24	24	Weather	Fuse	Replace - Same Size		IV
5043197	B93003	06/18/2015	15:07	06/18/2015	17:31	1	143	143	Weather	Fuse	Replace - Same Size		I
5043203	Y11555	06/18/2015	15:19	06/18/2015	15:45	1	25	25	Animal related	Fuse	Replace - Same Size		IV
5043205	Y37592	06/18/2015	15:20	06/18/2015	16:19	1	58	58	Tree related-tree broken	Overhead Service	Repair		IV
5043215	Q71846	06/18/2015	15:31	06/18/2015	16:26	1	54	54	Weather	Transformer Fuse	Replace - Same Size		V
5043229	K73361	06/18/2015	15:43	06/18/2015	17:21	1	97	97	Tree related-tree contact	Overhead Service	Repair		IV
5043231	M45212	06/18/2015	15:44	06/18/2015	17:30	1	105	105	Overhead equipment	Crossarm		Repair	IV
5043235	B62004	06/18/2015	15:49	06/18/2015	16:02	5	63	12	Overhead equipment	Fuse	Replace - Same Size		I
5043239	L42158	06/18/2015	15:54	06/18/2015	18:26	245	37232	151	Tree related-tree broken	Tree	Remove		III
5043271	X72535	06/18/2015	16:11	06/18/2015	18:05	7	791	113	Weather	Fuse	Replace - Same Size		IV
5043269	K73361	06/18/2015	16:12	06/18/2015	18:39	1	146	146	Weather	Overhead Transformer	Replace - Same Size		IV
5043273	HC9327	06/18/2015	16:13	06/18/2015	19:47	1	213	213	Overhead equipment	Disconnect Switch	Disconnect	Replace - Same Size	VI
5043275	X72535	06/18/2015	16:14	06/18/2015	18:05	1	110	110	Weather	Fuse	Replace - Same Size		IV
5043277	L81141	06/18/2015	16:14	06/18/2015	16:46	18	559	31	Weather	Fuse	Replace - Same Size		IV
5043291	N91255	06/18/2015	16:32	06/18/2015	17:37	7	453	64	Tree related-tree contact	Overhead Transformer			III
5043295	X02547	06/18/2015	16:34	06/18/2015	18:20	2	211	105	Weather	Fuse	Repair	Replace - Same Size	IV
5043297	T01534	06/18/2015	16:34	06/18/2015	17:40	1	65	65	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Repair	VI
5043303	Q71846	06/18/2015	16:45	06/18/2015	22:05	1	319	319	Weather	Overhead Transformer	Patrol/Test/Inspect	Replace - New Size	V
5043305	Y37010	06/18/2015	16:49	06/18/2015	17:38	6	293	48	Tree related-tree contact	Transformer Fuse	Replace - Same Size		IV
5043307	A45003	06/18/2015	16:49	06/18/2015	18:28	1	98	98	Animal related	Other	Replace - Same Size		I
5043339	V63570	06/18/2015	16:53	06/18/2015	18:50	55	6396	116	Tree related-tree broken	Fuse			II
5043315	K69117	06/18/2015	16:56	06/18/2015	18:59	1	122	122	Tree related-tree broken	Overhead Service	Repair		IV
5043319	Y97512	06/18/2015	17:03	06/18/2015	17:14	7	81	11	Overhead equipment				IV
5043325	X72535	06/18/2015	17:08	06/18/2015	18:05	1	56	56	Weather	Fuse	Replace - Same Size		IV
5043327	329149	06/18/2015	17:12	06/18/2015	18:12	21	1255	59	Overhead equipment	Overhead Primary			V
5043371	329149	06/18/2015	17:13	06/18/2015	19:38	12	1735	144	Overhead equipment	Overhead Primary	Cut in Clear	Repair	V
5043335	329149	06/18/2015	17:16	06/18/2015	18:12	6	333	55	Overhead equipment	Overhead Primary			V
5043337	L50214	06/18/2015	17:16	06/18/2015	19:30	1	133	133	Tree related-tree broken	Overhead Service	Repair		VI
5043343	Y55003	06/18/2015	17:19	06/18/2015	19:00	1	100	100	Tree related-tree broken	Overhead Service	Repair		IV
5043347	D87002	06/18/2015	17:29	06/18/2015	23:06	1	336	336	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	I
5043353	U35511	06/18/2015	17:42	06/18/2015	19:20	13	1269	97	Weather	Tree			II
5043357	U16522	06/18/2015	17:50	06/18/2015	20:02	3	394	131	Tree related-tree broken				II
5043361	Y28598	06/18/2015	17:55	06/18/2015	18:40	1	44	44	Weather	Fuse	Replace - Same Size		IV
5043373	L62927	06/18/2015	18:25	06/18/2015	22:12	17	3854	226	Tree related-tree broken	Overhead Primary	Repair	Repair	VI
5043375	V20502	06/18/2015	18:28	06/18/2015	20:45	1	136	136	Overhead equipment	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	II

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5043383	C36002	06/18/2015	18:36	06/18/2015	21:51	1	194	194	Underground equipment	Underground Service	Switch/Reset	Repair	III
5043385	X72536	06/18/2015	18:40	06/18/2015	21:20	1	159	159	Tree related-tree broken	Overhead Service	Raise		IV
5043503	J83-UNIT-1	06/18/2015	18:41	06/18/2015	19:52	1588	112382	70	Tree related-tree contact				VI
5043509	A45002	06/18/2015	18:49	06/18/2015	23:54	1	304	304	Overhead equipment	Overhead Transformer	Replace - Same Size	Repair	I
5043585	J86108	06/18/2015	18:58	06/18/2015	22:57	463	110541	238	Tree related-tree contact	Tree			VI
5043523	R39934	06/18/2015	19:10	06/18/2015	20:15	1	64	64	Animal related	Fuse	Replace - Same Size		VI
5043529	X83533	06/18/2015	19:16	06/18/2015	21:17	10	1206	120	Overhead equipment	Jumper	Repair		IV
5043531	Q80353	06/18/2015	19:25	06/18/2015	23:45	1	259	259	Underground equipment	Underground Service	Patrol/Test/Inspect	Repair	V
5043535	329149	06/18/2015	19:34	06/18/2015	19:48	1	13	13	Overhead equipment	Overhead Transformer			V
5043537	V63570	06/18/2015	19:36	06/18/2015	19:48	1	11	11	Tree related-tree broken	Fuse	Repair		II
5043541	V63570	06/18/2015	19:41	06/18/2015	19:59	37	636	17	Tree related-tree broken	Fuse	Repair		II
5043543	T02543	06/18/2015	19:45	06/18/2015	19:58	104	1292	12	Tree related-tree broken				VI
5043545	HB5891	06/18/2015	20:08	06/18/2015	23:43	1	214	214	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	I
5043551	B82001	06/18/2015	20:20	06/19/2015	10:30	1	849	849	Other	Customer Equipment	Replace - Same Size	Repair	I
5043555	D32212	06/18/2015	20:43	06/18/2015	23:17	4	615	153	Tree related-tree broken	Overhead Primary		Repair	I
5043563	B61001	06/18/2015	21:24	06/19/2015	2:15	1	290	290	Overhead equipment	Fuse	Replace - Same Size	Repair	I
5043617	J76804	06/18/2015	21:52	06/19/2015	0:20	1	147	147	Underground equipment	Underground Service	Repair	Repair	V
5043625	M07235	06/18/2015	22:03	06/18/2015	23:56	9	1021	113	Overhead equipment				III
5043649	M07235	06/18/2015	22:05	06/18/2015	23:46	304	30618	100	Overhead equipment				III
5043667	X96524	06/18/2015	22:33	06/19/2015	0:13	1	99	99	Tree related-tree broken	Overhead Service	Repair		IV
5043683	J99127	06/18/2015	23:30	06/19/2015	2:09	1	158	158	Overhead equipment	Transformer Fuse	Replace - Same Size		VI
5043685	Q15844	06/19/2015	0:07	06/19/2015	1:08	1	60	60	Animal related	Fuse	Replace - Same Size		V
5043703	J20931	06/19/2015	0:21	06/19/2015	3:18	26	4598	176	Overhead equipment	Fuse	Replace - Same Size	Patrol/Test/Inspect	VI
5043693	A50002	06/19/2015	0:30	06/19/2015	1:23	1	52	52	Unknown	Other			I
5043695	349001	06/19/2015	0:37	06/19/2015	5:30	9	2635	292	Tree related-tree broken	Tree	Trim	Remove	VI
5043697	349001	06/19/2015	0:37	06/19/2015	5:30	1	292	292	Tree related-tree broken				VI
5043699	349001	06/19/2015	0:38	06/19/2015	5:30	1	291	291	Tree related-tree broken				VI
5043705	L59929	06/19/2015	1:22	06/19/2015	3:32	1	129	129	Weather	Fuse	Replace - Same Size		VI
5043707	B71002	06/19/2015	1:49	06/19/2015	4:21	1	151	151	Tree related-tree broken	Overhead Service		Repair	I
5043715	J87150	06/19/2015	3:39	06/19/2015	4:56	1	76	76	Animal related	Transformer Fuse			VI
5043717	Q64919	06/19/2015	3:49	06/19/2015	4:30	1	40	40	Animal related	Fuse	Replace - Same Size		VI
5043719	Z43549	06/19/2015	4:13	06/20/2015	11:17	21	8998	1863	Underground equipment	Underground Transformer	Repair	Replace - Same Size	IV
5043723	H07106	06/19/2015	5:02	06/19/2015	6:40	1	97	97	Overhead equipment	Overhead Transformer	Replace - Same Size		IV
5043727	Y61002	06/19/2015	6:11	06/19/2015	8:25	1	133	133	Tree related-tree broken	Overhead Service	Repair		IV
5043743	Y26580	06/19/2015	6:34	06/19/2015	7:54	384	30912	80	Overhead equipment	Overhead Transformer			IV
5043801	Y26580	06/19/2015	6:37	06/19/2015	8:13	3	286	95	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
5043749	K62102	06/19/2015	6:53	06/19/2015	9:13	12	1682	140	Underground equipment	Underground Primary	Switch/Reset	Repair	II
5043789	U66515	06/19/2015	6:56	06/19/2015	10:33	208	18981	216	Public	Overhead Primary			II
5043819	U66515	06/19/2015	6:57	06/19/2015	8:17	108	8623	79	Public	Fuse	Replace - Same Size		II
5043755	P09306	06/19/2015	6:57	06/19/2015	7:47	1	49	49	Tree related-tree contact	Overhead Service	Repair	Repair	V
5043767	S64501	06/19/2015	7:05	06/19/2015	7:48	1	42	42	Overhead equipment	Fuse			VI
5043769	A91004	06/19/2015	7:05	06/19/2015	8:15	2	138	69	Jurisdictional	Fuse	Reconnect		I
5043771	S62523	06/19/2015	7:08	06/19/2015	8:02	1	53	53	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	VI
5043773	J76804	06/19/2015	7:11	06/19/2015	9:17	1	125	125	Underground equipment	Underground Service	Repair	Repair	V
5043777	M78322	06/19/2015	7:16	06/19/2015	8:55	1	98	98	Overhead equipment	Connector	Repair	Repair	V
5043787	S47589	06/19/2015	7:23	06/19/2015	9:00	1	96	96	Animal related	Transformer Fuse			VI
5043791	M81402	06/19/2015	7:26	06/19/2015	8:37	44	3118	70	Tree related-tree contact	Fuse	Replace - Same Size		V
5043799	Q83171	06/19/2015	7:43	06/19/2015	8:45	4	247	61	Overhead equipment	Fuse	Repair	Replace - Same Size	VI
5043815	S19553	06/19/2015	7:56	06/19/2015	8:58	69	4219	61	Overhead equipment	Overhead Primary	Patrol/Test/Inspect	Repair	VI
5043817	P60161	06/19/2015	8:05	06/19/2015	9:21	1	75	75	Tree related-tree broken	Overhead Secondary	Repair	Repair	VI
5043821	V20502	06/19/2015	8:12	06/19/2015	13:18	1	305	305	Underground equipment	Underground Primary	Repair	Repair	II
5043829	R48165	06/19/2015	8:27	06/19/2015	10:44	7	960	137	Underground equipment	Underground Primary			IV
5043827	R71285	06/19/2015	8:32	06/19/2015	12:15	10	2225	222	Overhead equipment	Crossarm	Patrol/Test/Inspect	Repair	VI
5044003	R48165	06/19/2015	8:33	06/19/2015	12:29	7	1653	236	Underground equipment	Underground Primary			IV
5043833	B38002	06/19/2015	8:45	06/19/2015	14:20	1	334	334	Unknown	Fuse			I
5043837	D66001	06/19/2015	8:54	06/19/2015	10:30	5	478	95	Tree related-tree broken	Tree	Remove		IV

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5043905	K71812	06/19/2015	8:58	06/19/2015	9:55	272	15618	57	Animal related	Overhead Primary			IV
5043855	K71812	06/19/2015	8:58	06/19/2015	9:55	309	17588	56	Animal related				IV
5043903	K71812	06/19/2015	8:58	06/19/2015	9:55	464	26332	56	Animal related				IV
5043885	D70005	06/19/2015	9:02	06/19/2015	18:08	4	2183	545	Tree related-tree broken	Tree	Patrol/Test/Inspect	Trim	I
5043895	K76541	06/19/2015	9:06	06/19/2015	10:01	16	868	54	Animal related				IV
5043893	A81001	06/19/2015	9:06	06/19/2015	14:30	1	323	323	Underground equipment	Underground Service	Patrol/Test/Inspect	Repair	I
5043899	V74513	06/19/2015	9:11	06/19/2015	9:46	1	34	34	Overhead equipment	Overhead Service	Repair		II
5043919	307004	06/19/2015	9:15	06/19/2015	13:15	8	1915	239	Tree related-tree broken	Overhead Primary	Patrol/Test/Inspect		VI
5043927	M20221	06/19/2015	9:19	06/19/2015	20:06	6	3881	646	Tree related-tree broken	Overhead Primary		Replace - Same Size	VI
5043915	HC9327	06/19/2015	9:23	06/19/2015	19:44	3	1863	621	Tree related-tree broken	Pole	Patrol/Test/Inspect	Replace - Same Size	VI
5043921	J86118	06/19/2015	9:29	06/19/2015	10:42	1114	81132	72	Tree related-tree broken				VI
5043929	B38001	06/19/2015	9:34	06/19/2015	17:30	1	475	475	Underground equipment	Underground Service	Replace - Same Size	Repair	I
5043931	U99515	06/19/2015	9:34	06/19/2015	10:23	7	337	48	Animal related	Transformer Fuse	Replace - Same Size		II
5043945	307004	06/19/2015	9:34	06/19/2015	13:30	17	3998	235	Tree related-tree broken	Overhead Primary	Repair	Repair	VI
5043947	M04364	06/19/2015	9:47	06/19/2015	13:10	8	1623	202	Overhead equipment	Disconnect Switch	Patrol/Test/Inspect	Replace - Same Size	V
5043955	M81402	06/19/2015	9:54	06/19/2015	11:10	1	75	75	Tree related-tree broken	Overhead Service	Repair	Repair	V
5043957	HA5431	06/19/2015	9:55	06/19/2015	10:21	1	25	25	Tree related-tree broken	Overhead Service	Cut in Clear	Reconnect	V
5043959	K71812	06/19/2015	9:55	06/19/2015	10:04	1	8	8	Animal related				IV
5043961	K71812	06/19/2015	9:56	06/19/2015	10:03	1	6	6	Animal related				IV
5043977	K11376	06/19/2015	10:09	06/19/2015	13:30	1	200	200	Tree related-tree broken	Overhead Service	Cut in Clear		V
5043969	K11376	06/19/2015	10:10	06/19/2015	10:59	37	1806	48	Tree related-tree broken	Fuse	Replace - Same Size		V
5043979	J86108	06/19/2015	10:14	06/19/2015	16:00	142	17167	345	Tree related-tree contact	Tree			VI
5043993	U45585	06/19/2015	10:25	06/19/2015	12:02	1	97	96	Overhead equipment	Connector	Repair		II
5043995	K15205	06/19/2015	10:33	06/19/2015	15:27	1	293	293	Tree related-tree broken	Overhead Service	Repair		VI
5044951	J87150	06/19/2015	10:34	06/19/2015	22:30	6	4293	715	Underground equipment				VI
5044561	J87150	06/19/2015	10:42	06/19/2015	22:37	15	10693	714	Underground equipment	Underground Primary			VI
5044015	J86118	06/19/2015	10:48	06/19/2015	10:59	1	10	10	Overhead equipment				VI
5044017	J86108	06/19/2015	10:50	06/19/2015	13:16	1	145	145	Tree related-tree contact	Overhead Primary			VI
5044035	S19553	06/19/2015	11:07	06/19/2015	11:35	1	27	27	Animal related	Fuse	Replace - Same Size		VI
5044079	J84145	06/19/2015	11:16	06/20/2015	1:36	90	70321	859	Tree related-tree broken	Pole	Patrol/Test/Inspect	Replace - Same Size	VI
5044045	J84145	06/19/2015	11:20	06/19/2015	15:58	444	123019	277	Overhead equipment	Overhead Primary	Repair		VI
5044053	Q36410	06/19/2015	11:22	06/19/2015	12:20	1	57	57	Public	Overhead Service	Tie/Tighten	Repair	I
5044071	M20221	06/19/2015	11:23	06/19/2015	20:06	49	25646	523	Tree related-tree broken	Overhead Primary	Patrol/Test/Inspect		VI
5044065	J84123	06/19/2015	11:26	06/19/2015	16:34	1	307	307	Underground equipment	Underground Transformer			VI
5044089	H11339	06/19/2015	11:43	06/19/2015	13:08	1	84	84	Tree related-tree broken				V
5044093	332004	06/19/2015	11:46	06/19/2015	13:30	1	103	103	Overhead equipment	Overhead Service	Repair		VI
5044135	HE3303	06/19/2015	11:53	06/19/2015	14:11	75	10332	137	Overhead equipment	Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
5044167	J80-UNIT-1	06/19/2015	11:56	06/19/2015	13:09	1942	141766	73	Unknown				V
5044289	J76-UNIT-1	06/19/2015	11:56	06/19/2015	13:13	1529	118008	77	Unknown				V
5044229	H22346	06/19/2015	11:59	06/19/2015	15:35	1	215	215	Overhead equipment				V
5044287	A49003	06/19/2015	12:01	06/19/2015	12:53	16	830	51	Public	Pole	Straighten		I
5044359	K57211	06/19/2015	12:06	06/19/2015	23:00	145	92466	653	Tree related-tree broken	Overhead Primary	Patrol/Test/Inspect	Repair	VI
5044435	B71001	06/19/2015	12:07	06/19/2015	17:06	10	2977	298	Underground equipment	Underground Primary	Repair	Replace - Same Size	I
5044337	Q23255	06/19/2015	12:12	06/19/2015	18:15	1	362	362	Tree related-tree broken	Overhead Primary	Patrol/Test/Inspect	Tie/Tighten	VI
5044339	K57211	06/19/2015	12:12	06/19/2015	16:49	59	12292	276	Tree related-tree broken	Tree	Remove		VI
5044347	H22346	06/19/2015	12:14	06/19/2015	15:35	1	200	200	Overhead equipment				V
5044349	K57211	06/19/2015	12:15	06/19/2015	14:58	3	488	162	Animal related	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
5044355	H22348	06/19/2015	12:24	06/19/2015	15:35	1	190	190	Overhead equipment				V
5044377	343006	06/19/2015	12:32	06/19/2015	17:40	21	6460	307	Overhead equipment	Overhead Primary	Patrol/Test/Inspect	Repair	VI
5044381	L71171	06/19/2015	12:33	06/19/2015	13:18	3	134	44	Animal related	Fuse			IV
5044385	343008	06/19/2015	12:35	06/19/2015	15:41	3	558	186	Tree related-tree contact	Tree	Trim		VI
5044389	Z11536	06/19/2015	12:37	06/19/2015	13:40	4	249	62	Overhead equipment	Transformer Fuse	Repair		IV
5044391	343004	06/19/2015	12:40	06/19/2015	20:00	7	3074	439	Tree related-tree broken	Overhead Secondary	Patrol/Test/Inspect	Repair	VI
5044395	N05173	06/19/2015	12:46	06/19/2015	13:40	1	53	53	Other				I
5044397	338007	06/19/2015	12:49	06/19/2015	14:10	1	80	80	Overhead equipment	Fuse	Repair		VI
5044399	H06135	06/19/2015	12:50	06/19/2015	13:29	1	38	38	Animal related	Fuse	Repair		IV

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5044401	H17878	06/19/2015	12:52	06/19/2015	15:35	1	162	162	Overhead equipment				V
5044405	HB6283	06/19/2015	12:56	06/19/2015	20:16	1	439	439	Tree related-tree broken				VI
5044439	J88163	06/19/2015	12:57	06/19/2015	17:39	54	14589	281	Tree related-tree broken	Overhead Primary	Repair	Repair	VI
5044417	U16522	06/19/2015	13:02	06/19/2015	16:30	13	2703	207	Underground equipment	Underground Primary	Repair	Repair	II
5044441	R41131	06/19/2015	13:34	06/19/2015	18:57	1	322	322	Tree related-tree broken	Pole		Replace - Same Size	VI
5044449	342003	06/19/2015	13:42	06/19/2015	19:00	1	317	317	Tree related-tree broken	Overhead Service	Patrol/Test/Inspect	Repair	VI
5044453	D28123	06/19/2015	13:49	06/19/2015	15:45	1	115	115	Unknown	Fuse	Replace - Same Size		I
5044475	L90358	06/19/2015	14:11	06/19/2015	15:38	1	86	86	Overhead equipment				V
5044485	T06505	06/19/2015	14:21	06/19/2015	15:07	1	45	45	Overhead equipment	Fuse	Replace - Same Size	Patrol/Test/Inspect	VI
5044495	312113	06/19/2015	14:26	06/19/2015	16:30	16	1974	123	Tree related-tree broken	Overhead Primary		Repair	V
5044497	X16511	06/19/2015	14:26	06/19/2015	15:55	1	88	88	Weather	Transformer Fuse	Replace - Same Size		IV
5044501	343008	06/19/2015	14:28	06/19/2015	15:41	1	72	72	Tree related-tree contact				VI
5044503	H22349	06/19/2015	14:28	06/19/2015	15:00	1	31	31	Overhead equipment				V
5044505	343008	06/19/2015	14:28	06/19/2015	15:41	3	219	73	Tree related-tree contact				VI
5044513	T06505	06/19/2015	14:35	06/19/2015	15:08	1	32	32	Overhead equipment	Fuse	Replace - New Size		VI
5044517	H22349	06/19/2015	14:38	06/19/2015	15:37	1	58	58	Overhead equipment				V
5044553	Z51551	06/19/2015	14:41	06/19/2015	16:29	59	6367	107	Tree related-tree broken	Disconnect Switch	Replace - New Size		IV
5044791	J63173	06/19/2015	14:42	06/19/2015	16:52	120	15540	129	Underground equipment				III
5044537	B73003	06/19/2015	14:49	06/19/2015	15:20	4	120	30	Overhead equipment	Overhead Transformer	Repair	Replace - Same Size	I
5044541	X92508	06/19/2015	14:57	06/19/2015	16:11	1	73	73	Public				IV
5044543	J89126	06/19/2015	15:00	06/19/2015	20:41	10	3410	341	Tree related-tree broken	Overhead Secondary	Patrol/Test/Inspect	Repair	VI
5044549	328119	06/19/2015	15:07	06/19/2015	15:50	1	42	42	Tree related-tree broken	Overhead Service	Repair		V
5044563	Q54908	06/19/2015	15:17	06/19/2015	17:29	6	786	131	Weather	Disconnect Switch	Patrol/Test/Inspect	Repair	VI
5044565	P18103	06/19/2015	15:20	06/19/2015	18:30	1	189	189	Animal related	Transformer Fuse	Replace - Same Size		IV
5044567	X92508	06/19/2015	15:25	06/19/2015	17:35	5	646	129	Public	Pole	Repair	Replace - Same Size	IV
5044569	R10903	06/19/2015	15:28	06/19/2015	17:38	1	129	129	Overhead equipment	Fuse	Replace - Same Size	Patrol/Test/Inspect	VI
5044573	L90358	06/19/2015	15:30	06/19/2015	15:39	1	8	8	Overhead equipment				V
5044585	S55-XTR1	06/19/2015	15:39	06/19/2015	16:05	1448	37401	25	Unknown				VI
5044613	HE3303	06/19/2015	15:43	06/19/2015	21:11	8	2623	327	Overhead equipment	Fuse	Replace - Same Size		VI
5044647	K32932	06/19/2015	15:48	06/19/2015	17:21	1	92	92	Tree related-tree broken	Tree			VI
5044675	K32932	06/19/2015	15:51	06/19/2015	18:56	1	184	184	Tree related-tree broken	Overhead Primary	Repair		VI
5044681	P60161	06/19/2015	15:52	06/19/2015	17:04	1	71	71	Tree related-tree contact	Overhead Service	Reconnect		VI
5044747	S21529	06/19/2015	16:03	06/19/2015	17:40	125	12037	96	Tree related-tree broken	Tree	Trim		VI
5044753	R61241	06/19/2015	16:16	06/19/2015	17:30	55	4054	73	Animal related	Fuse	Replace - Same Size		IV
5044757	R53390	06/19/2015	16:26	06/19/2015	18:09	1	102	102	Underground equipment	Overhead Service	Patrol/Test/Inspect	Repair	V
5044829	S21529	06/19/2015	16:27	06/19/2015	18:50	31	4402	142	Tree related-tree broken				VI
5044769	Y34596	06/19/2015	16:31	06/19/2015	17:45	21	1548	73	Tree related-tree broken	Tree	Remove		IV
5044771	L81141	06/19/2015	16:35	06/19/2015	18:36	1	120	120	Tree related-tree broken	Overhead Service	Repair		IV
5044775	J84123	06/19/2015	16:36	06/19/2015	18:11	1	94	94	Tree related-tree broken				VI
5044777	Y60548	06/19/2015	16:49	06/19/2015	18:29	1	99	99	Public	Overhead Service	Repair		IV
5044793	K57211	06/19/2015	16:56	06/19/2015	17:11	1	14	14	Other	Other			VI
5044857	J99141	06/19/2015	16:58	06/20/2015	4:41	23	16151	702	Tree related-tree contact	Fuse			VI
5044823	S30518	06/19/2015	17:00	06/19/2015	19:05	17	2108	124	Overhead equipment	Fuse	Replace - Same Size		VI
5044795	J99141	06/19/2015	17:01	06/19/2015	18:26	26	2204	84	Tree related-tree contact	Tree	Trim		VI
5044803	S86582	06/19/2015	17:04	06/19/2015	19:17	1	132	132	Overhead equipment	Disconnect Switch	Repair		VI
5044807	S04545	06/19/2015	17:09	06/19/2015	23:13	1	364	364	Tree related-tree broken	Overhead Service	Repair	Repair	VI
5044813	K57211	06/19/2015	17:11	06/19/2015	17:20	1	8	8	Overhead equipment				VI
5044817	Q18242	06/19/2015	17:12	06/19/2015	19:12	1	119	119	Tree related-tree contact	Fuse	Replace - Same Size		VI
5044819	K57211	06/19/2015	17:13	06/19/2015	22:44	40	13251	331	Overhead equipment	Overhead Primary	Repair		VI
5044827	S86582	06/19/2015	17:18	06/19/2015	19:19	2	240	120	Overhead equipment	Disconnect Switch	Repair		VI
5044831	B21001	06/19/2015	17:23	06/19/2015	20:00	33	5167	156	Underground equipment	Other	Repair	Repair	I
5044837	S07536	06/19/2015	17:26	06/19/2015	22:01	1	274	274	Tree related-tree broken	Overhead Service	Repair	Repair	VI
5044843	Y06573	06/19/2015	17:35	06/19/2015	19:10	1	94	94	Weather	Transformer Fuse	Replace - Same Size		IV
5044845	T06503	06/19/2015	17:36	06/19/2015	20:00	29	4154	143	Overhead equipment	Overhead Primary	Repair	Repair	VI
5044849	Y34596	06/19/2015	17:38	06/19/2015	19:11	2	185	92	Tree related-tree contact	Overhead Primary	Repair		IV
5044855	342001	06/19/2015	18:08	06/19/2015	20:30	1	141	141	Tree related-tree contact	Overhead Service	Repair		VI

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5044861	J15303	06/19/2015	18:22	06/19/2015	19:08	1	45	45	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	I
5044867	K27122	06/19/2015	18:30	06/19/2015	21:11	1	160	160	Tree related-tree broken	Overhead Service	Repair		VI
5044869	342003	06/19/2015	18:31	06/19/2015	19:00	4	113	28	Overhead equipment				VI
5044871	X42502	06/19/2015	18:34	06/19/2015	20:25	1	110	110	Overhead equipment	Overhead Service	Repair		IV
5044873	J14140	06/19/2015	18:39	06/19/2015	19:12	4	129	32	Weather	Pole	Repair	Replace - Same Size	VI
5044885	K32932	06/19/2015	19:11	06/19/2015	20:09	8	458	57	Tree related-tree broken				VI
5044889	J07173	06/19/2015	19:26	06/19/2015	20:35	1	68	68	Jurisdictional	Customer Equipment	Cut in Clear		I
5044895	Q75146	06/19/2015	19:37	06/19/2015	21:37	1	119	119	Tree related-tree broken	Overhead Secondary			VI
5044897	J83138	06/19/2015	19:37	06/20/2015	6:28	8	5210	651	Overhead equipment	Overhead Primary	Replace - Same Size	Replace - Same Size	VI
5044911	S36570	06/19/2015	19:44	06/20/2015	1:17	10	3329	332	Tree related-tree broken	Overhead Primary	Patrol/Test/Inspect	Cut in Clear	VI
5044901	S60581	06/19/2015	19:48	06/20/2015	1:03	1	314	314	Tree related-tree broken	Overhead Service	Repair		VI
5044905	S21529	06/19/2015	19:53	06/19/2015	23:35	4	885	221	Weather	Disconnect Switch	Repair	Replace - Same Size	VI
5044913	B21001	06/19/2015	20:08	06/19/2015	20:10	2	4	2	Unknown				I
5044915	M20221	06/19/2015	20:09	06/19/2015	20:18	1	8	8	Tree related-tree broken	Tree	Trim		VI
5044923	R20502	06/19/2015	20:27	06/20/2015	1:20	1	292	292	Underground equipment	Underground Service	Repair	Repair	IV
5044947	HA5432	06/19/2015	22:02	06/19/2015	23:53	14	1540	110	Overhead equipment	Fuse	Replace - Same Size		V
5044969	J84123	06/19/2015	22:53	06/20/2015	1:00	1	126	126	Tree related-tree broken	Overhead Primary	Patrol/Test/Inspect	Repair	VI
5044971	A81004	06/19/2015	22:57	06/20/2015	7:52	1	534	534	Underground equipment	Underground Service	Disconnect	Repair	I
5044973	S43502	06/19/2015	23:10	06/20/2015	1:25	1	134	134	Overhead equipment	Overhead Secondary	Repair		VI
5044975	S43502	06/19/2015	23:12	06/20/2015	1:29	4	547	136	Overhead equipment	Connector	Repair	Replace - Same Size	VI
5044977	S24598	06/19/2015	23:14	06/20/2015	0:40	1	85	85	Tree related-tree broken	Overhead Service	Tie/Tighten	Tie/Tighten	VI
5044979	J87150	06/19/2015	23:20	06/20/2015	7:29	7	3418	488	Underground equipment	Underground Service	Repair	Replace - Same Size	VI
5044981	J06167	06/19/2015	23:50	06/20/2015	1:30	1	99	99	Overhead equipment	Overhead Service	Repair		I
5044983	S24598	06/19/2015	23:52	06/20/2015	0:26	7	236	33	Overhead equipment	Overhead Service	Tie/Tighten	Tie/Tighten	VI
5045021	S19543	06/20/2015	1:17	06/20/2015	3:23	155	19475	125	Unknown				VI
5045023	S19543	06/20/2015	1:28	06/20/2015	10:03	4	2056	514	Overhead equipment	Overhead Primary			VI
5045013	K46388	06/20/2015	1:42	06/20/2015	9:46	11	5322	483	Tree related-tree broken	Overhead Primary	Cut in Clear	Repair	V
5045015	P47120	06/20/2015	1:50	06/20/2015	3:30	1	99	99	Unknown	Overhead Service	Patrol/Test/Inspect		I
5045017	Q80353	06/20/2015	2:02	06/20/2015	11:48	3	1759	586	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	V
5045019	R04409	06/20/2015	2:13	06/20/2015	5:04	1	170	170	Overhead equipment	Fuse	Replace - Same Size		V
5045025	Y05001	06/20/2015	2:57	06/20/2015	5:15	10	1379	137	Tree related-tree broken	Fuse	Replace - Same Size		IV
5045031	A26002	06/20/2015	4:43	06/20/2015	6:05	1	81	81	Overhead equipment	Connector	Replace - Same Size		I
5045033	S83503	06/20/2015	4:50	06/20/2015	10:31	5	1704	340	Overhead equipment	Overhead Transformer	Replace - New Size	Replace - New Size	VI
5045037	K89142	06/20/2015	6:14	06/20/2015	7:13	1	58	58	Overhead equipment	Fuse	Repair		III
5045039	J89126	06/20/2015	6:16	06/20/2015	8:34	1	137	137	Tree related-tree broken	Overhead Service	Repair		VI
5045043	V45526	06/20/2015	6:39	06/20/2015	7:50	14	985	70	Overhead equipment	Transformer Fuse	Repair		II
5045045	X86-XTR1	06/20/2015	6:40	06/20/2015	7:53	999	73546	73	Overhead equipment	Overhead Primary		Patrol/Test/Inspect	IV
5045123	Y34-XTR1	06/20/2015	6:42	06/20/2015	8:54	1038	137586	132	Tree related-tree broken	Pole	Patrol/Test/Inspect	Replace - Same Size	IV
5045133	Y86-XTR1	06/20/2015	6:43	06/20/2015	8:56	394	52394	132	Overhead equipment				IV
5045231	U06524	06/20/2015	6:57	06/20/2015	9:56	106	18929	178	Animal related	Fuse	Replace - Same Size		II
5045217	U06524	06/20/2015	7:00	06/20/2015	10:01	1	180	180	Animal related	Fuse	Replace - Same Size		II
5045227	U06524	06/20/2015	7:03	06/20/2015	10:02	1	178	178	Animal related	Fuse	Replace - Same Size		II
5045241	K32916	06/20/2015	7:14	06/20/2015	8:45	1	90	90	Tree related-tree broken	Overhead Service	Repair		VI
5045257	K32916	06/20/2015	7:35	06/20/2015	11:16	4	886	221	Overhead equipment	Overhead Primary		Repair	VI
5045259	D36002	06/20/2015	7:46	06/20/2015	10:02	1	135	135	Overhead equipment	Fuse	Replace - Same Size		I
5045265	P12290	06/20/2015	8:05	06/20/2015	13:52	1	346	346	Overhead equipment	Overhead Primary	Patrol/Test/Inspect	Repair	V
5045267	N58144	06/20/2015	8:14	06/20/2015	10:51	1	156	156	Unknown	Transformer Fuse	Replace - Same Size		I
5045269	J76804	06/20/2015	8:16	06/20/2015	9:07	1	50	50	Animal related	Overhead Transformer	Repair	Repair	V
5045275	J84145	06/20/2015	8:41	06/20/2015	10:30	1	108	108	Overhead equipment	Fuse			VI
5045285	P26281	06/20/2015	9:15	06/20/2015	10:48	1	92	92	Animal related	Fuse	Replace - Same Size	Replace - Same Size	I
5045287	M18131	06/20/2015	9:17	06/20/2015	10:00	2	84	42	Animal related	Fuse	Replace - Same Size		III
5045289	P26283	06/20/2015	9:20	06/20/2015	10:48	5	437	87	Animal related	Fuse	Replace - Same Size	Replace - Same Size	I
5045293	K73365	06/20/2015	9:27	06/20/2015	10:28	1	60	60	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
5045297	M31204	06/20/2015	9:35	06/20/2015	10:58	68	5615	82	Overhead equipment	Pole	Replace - New Size	Replace - New Size	I
5045307	R10943	06/20/2015	9:46	06/20/2015	11:24	44	4268	97	Overhead equipment	Fuse	Replace - Same Size		VI
5045321	R10943	06/20/2015	10:07	06/20/2015	11:24	1	76	76	Overhead equipment	Fuse	Replace - Same Size		VI

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5045325	K48379	06/20/2015	10:16	06/20/2015	16:49	1	392	392	Tree related-tree broken	Overhead Service	Repair	Repair	V
5045329	R33127	06/20/2015	10:21	06/20/2015	11:03	1	41	41	Overhead equipment	Transformer Fuse	Replace - Same Size	Patrol/Test/Inspect	I
5045331	H14343	06/20/2015	10:25	06/20/2015	11:03	1	37	37	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	V
5045343	Q10702	06/20/2015	10:55	06/20/2015	12:25	1	89	89	Animal related	Fuse	Repair		V
5045347	L68115	06/20/2015	11:08	06/20/2015	17:57	1	408	408	Tree related-tree broken	Overhead Service		Repair	IV
5045353	Q10702	06/20/2015	11:17	06/20/2015	12:25	1	67	67	Animal related	Fuse	Replace - Same Size		V
5045359	K71812	06/20/2015	11:26	06/20/2015	14:02	1	155	155	Overhead equipment	Overhead Secondary	Repair		IV
5045361	K36151	06/20/2015	11:26	06/20/2015	11:50	1	23	23	Underground equipment				III
5045371	L81141	06/20/2015	11:53	06/20/2015	14:55	1	181	181	Overhead equipment	Fuse		Replace - Same Size	IV
5045377	S43511	06/20/2015	11:54	06/20/2015	12:56	7	431	61	Public	Overhead Service	Cut in Clear		VI
5045375	L68113	06/20/2015	11:55	06/22/2015	7:45	1	2630	2629	Tree related-tree broken	Tree	Remove		IV
5045383	Y06573	06/20/2015	12:16	06/20/2015	13:20	1	63	63	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
5045389	M05360	06/20/2015	12:53	06/20/2015	13:45	1	51	51	Overhead equipment	Transformer Fuse	Replace - Same Size	Replace - Same Size	V
5045395	Q04411	06/20/2015	13:19	06/20/2015	16:08	1	168	168	Underground equipment	Underground Transformer			III
5045399	J39391	06/20/2015	13:20	06/20/2015	16:23	105	17956	182	Underground equipment	Underground Transformer			III
5045401	Z19547	06/20/2015	13:21	06/20/2015	14:50	1	88	88	Animal related	Transformer Fuse	Replace - Same Size		IV
5045403	K30204	06/20/2015	13:33	06/20/2015	15:00	1	86	86	Unknown	Fuse	Replace - Same Size		III
5045405	J39391	06/20/2015	13:41	06/20/2015	16:11	1	149	149	Underground equipment	Underground Transformer			III
5045407	P17108	06/20/2015	13:41	06/20/2015	16:57	1	195	195	Underground equipment	Underground Secondary	Repair		IV
5045427	310122	06/20/2015	15:15	06/20/2015	18:30	1	194	194	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	V
5045429	R33127	06/20/2015	15:15	06/20/2015	17:35	1	139	139	Other	Transformer Fuse	Replace - Same Size		I
5045435	HB6283	06/20/2015	15:42	06/20/2015	16:55	1	72	72	Overhead equipment	Connector	Repair		VI
5045439	B08002	06/20/2015	16:12	06/20/2015	19:00	98	16383	167	Overhead equipment	Overhead Primary	Patrol/Test/Inspect	Repair	I
5045441	L71171	06/20/2015	16:20	06/20/2015	17:30	1	69	69	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
5045445	L93134	06/20/2015	16:30	06/20/2015	18:35	1	124	124	Tree related-tree broken	Overhead Service	Repair		VI
5045453	D66004	06/20/2015	16:43	06/20/2015	18:44	7	847	121	Overhead equipment	Fuse	Replace - Same Size		IV
5045449	F10001	06/20/2015	16:46	06/20/2015	18:17	1	90	90	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	III
5045451	V18582	06/20/2015	16:49	06/20/2015	20:00	1	190	190	Underground equipment	Underground Secondary	Repair	Repair	II
5045455	B08002	06/20/2015	16:50	06/20/2015	19:00	1	129	129	Overhead equipment	Overhead Primary	Patrol/Test/Inspect		I
5045459	D66004	06/20/2015	16:54	06/20/2015	18:44	3	331	110	Overhead equipment	Fuse	Replace - Same Size		IV
5045463	J63173	06/20/2015	17:08	06/20/2015	20:15	1	186	186	Underground equipment	Underground Service			III
5045465	HB6283	06/20/2015	17:08	06/20/2015	22:00	1	291	291	Underground equipment	Underground Service	Patrol/Test/Inspect	Repair	VI
5045471	S84535	06/20/2015	17:58	06/20/2015	19:00	1	61	61	Overhead equipment	Connector	Tie/Tighten		VI
5045475	U10569	06/20/2015	18:23	06/21/2015	1:25	1	421	421	Unknown	Overhead Secondary	Repair		II
5045477	M73331	06/20/2015	18:38	06/20/2015	19:43	15	971	64	Animal related	Fuse	Replace - Same Size		V
5045481	T41556	06/20/2015	19:07	06/20/2015	23:30	1	262	262	Overhead equipment	Overhead Transformer	Replace - Same Size	Repair	IV
5045495	H07106	06/20/2015	19:41	06/20/2015	19:52	21	223	10	Tree related-tree contact				IV
5045499	N05172	06/20/2015	19:43	06/20/2015	20:20	14	511	36	Animal related	Fuse	Replace - Same Size		I
5045661	W03570	06/20/2015	19:44	06/21/2015	7:11	771	284182	687	Overhead equipment	Overhead Primary	Repair		II
5045595	U37579	06/20/2015	19:50	06/21/2015	8:05	71	33331	734	Overhead equipment	Overhead Primary	Repair	Patrol/Test/Inspect	II
5045943	Q32170	06/20/2015	19:57	06/21/2015	8:28	221	166121	751	Tree related-tree broken	Overhead Primary	Repair	Replace - Same Size	I
5045543	Q32170	06/20/2015	19:57	06/21/2015	8:28	184	138270	751	Jurisdictional	Overhead Primary	Repair	Trim	I
5045535	H07106	06/20/2015	19:57	06/20/2015	23:05	21	2795	188	Underground equipment	Underground Primary	Repair		IV
5045539	P44324	06/20/2015	19:57	06/20/2015	21:31	1	93	93	Overhead equipment	Overhead Secondary	Repair		I
5045651	P07179	06/20/2015	19:59	06/21/2015	7:38	131	91507	698	Tree related-tree broken	Tree	Remove		I
5045655	P07179	06/20/2015	20:01	06/21/2015	4:11	33	16146	489	Tree related-tree broken	Overhead Primary	Repair		I
5045567	X60595	06/20/2015	20:02	06/20/2015	21:40	7	686	98	Underground equipment	Underground Primary	Repair	Repair	IV
5048715	R33127	06/20/2015	20:02	06/21/2015	11:37	127	118639	934	Tree related-tree contact	Tree	Trim	Trim	I
5045871	R33127	06/20/2015	20:05	06/21/2015	16:55	175	171111	1250	Overhead equipment	Pole	Repair	Replace - Same Size	I
5045597	J13108	06/20/2015	20:07	06/21/2015	5:09	1	541	541	Tree related-tree broken	Fuse	Replace - Same Size	Replace - Same Size	I
5045605	Q32170	06/20/2015	20:08	06/20/2015	23:15	10	1868	186	Tree related-tree broken	Recloser	Repair	Patrol/Test/Inspect	I
5046525	Q32170	06/20/2015	20:08	06/20/2015	22:50	193	31250	161	Tree related-tree broken	Overhead Primary	Cut in Clear	Repair	I
5045621	V99562	06/20/2015	20:09	06/21/2015	14:10	1	1080	1080	Unknown	Fuse	Replace - Same Size		II
5045635	Q91175	06/20/2015	20:10	06/21/2015	5:02	7	3719	531	Tree related-tree broken	Overhead Primary	Repair		I
5045527	P07179	06/20/2015	20:12	06/22/2015	12:18	9	21651	2405	Tree related-tree broken	Fuse	Replace - Same Size		I
5045663	C60001	06/20/2015	20:12	06/21/2015	9:55	1	822	822	Overhead equipment	Fuse	Replace - Same Size	Repair	III

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5045669	Q32170	06/20/2015	20:13	06/20/2015	23:19	6	1114	185	Tree related-tree broken	Overhead Primary	Repair	Patrol/Test/Inspect	I
5045667	J13108	06/20/2015	20:13	06/21/2015	4:24	1	490	490	Tree related-tree broken	Tree	Remove		I
5045685	B27009	06/20/2015	20:15	06/21/2015	7:58	1	702	702	Unknown	Overhead Service	Repair	Repair	I
5045739	Q32170	06/20/2015	20:15	06/21/2015	4:35	19	9482	499	Tree related-tree contact	Overhead Primary	Raise	Patrol/Test/Inspect	I
5045703	R33127	06/20/2015	20:18	06/21/2015	1:53	1	334	334	Overhead equipment	Pole	Replace - Same Size		I
5045705	N60181	06/20/2015	20:20	06/21/2015	9:50	1	809	809	Unknown	Overhead Secondary	Patrol/Test/Inspect		I
5045717	N58144	06/20/2015	20:22	06/21/2015	2:21	1	358	358	Tree related-tree broken	Tree	Remove		I
5045801	J71129	06/20/2015	20:22	06/21/2015	8:32	102	74421	729	Overhead equipment	Pole	Replace - Same Size	Replace - Same Size	I
5045725	J01119	06/20/2015	20:24	06/21/2015	11:05	1	880	880	Overhead equipment	Overhead Service	Patrol/Test/Inspect		I
5045731	Y37010	06/20/2015	20:25	06/20/2015	21:45	6	477	79	Tree related-tree contact	Fuse	Repair	Replace - Same Size	IV
5045735	U42512	06/20/2015	20:26	06/21/2015	1:40	7	2195	313	Tree related-tree broken	Tree	Trim	Trim	II
5045737	R48167	06/20/2015	20:26	06/20/2015	21:37	5	352	70	Overhead equipment	Fuse	Replace - Same Size		IV
5045743	Q32170	06/20/2015	20:28	06/21/2015	1:39	6	1860	310	Tree related-tree broken	Overhead Primary	Repair	Patrol/Test/Inspect	I
5045755	R33127	06/20/2015	20:30	06/21/2015	10:11	47	38577	820	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	I
5045765	Q91141	06/20/2015	20:30	06/21/2015	0:10	314	68860	219	Weather	Recloser	Switch/Reset		I
5045767	Q32170	06/20/2015	20:34	06/21/2015	3:09	1	394	394	Tree related-tree broken	Recloser	Repair	Patrol/Test/Inspect	I
5045777	R33127	06/20/2015	20:36	06/21/2015	13:29	1	1012	1012	Weather	Fuse	Replace - Same Size	Patrol/Test/Inspect	I
5045833	J01118	06/20/2015	20:37	06/21/2015	2:24	259	89751	346	Weather	Recloser	Switch/Reset	Replace - Same Size	I
5045785	U42001	06/20/2015	20:38	06/21/2015	3:50	1	431	431	Tree related-tree broken	Tree	Remove		II
5045915	J06167	06/20/2015	20:40	06/21/2015	7:00	8	4955	619	Tree related-tree broken	Fuse	Replace - Same Size		I
5045953	J06167	06/20/2015	20:43	06/21/2015	5:55	13	7171	551	Tree related-tree broken	Fuse	Replace - Same Size		I
5045823	S83533	06/20/2015	20:43	06/21/2015	1:19	1	275	275	Tree related-tree contact	Overhead Service	Repair		VI
5045825	J07135	06/20/2015	20:43	06/21/2015	1:55	24	7466	311	Tree related-tree broken	Fuse	Replace - Same Size	Repair	I
5045831	M40117	06/20/2015	20:45	06/21/2015	8:22	10	6969	696	Overhead equipment	Overhead Service	Repair	Replace - Same Size	I
5045841	P47123	06/20/2015	20:47	06/21/2015	13:09	5	4908	981	Tree related-tree broken	Fuse	Replace - Same Size	Repair	I
5045847	J71129	06/20/2015	20:47	06/21/2015	9:25	1	757	757	Overhead equipment	Meter	Repair	Disconnect	I
5045855	U42512	06/20/2015	20:49	06/21/2015	1:40	69	20050	290	Tree related-tree broken	Recloser	Switch/Reset		II
5045857	M41111	06/20/2015	20:50	06/21/2015	6:51	1	600	600	Weather	Transformer Fuse	Replace - Same Size		I
5045859	M42107	06/20/2015	20:51	06/21/2015	12:20	1	928	928	Tree related-tree broken	Customer Equipment	Advise Customer		I
5045861	M41182	06/20/2015	20:53	06/21/2015	6:57	31	18724	604	Tree related-tree broken	Overhead Primary	Repair	Replace - Same Size	I
5045863	R05115	06/20/2015	20:54	06/21/2015	7:50	1	655	655	Tree related-tree broken	Overhead Service	Repair		I
5045865	R84148	06/20/2015	20:55	06/21/2015	2:50	1	354	354	Unknown	Overhead Service	Patrol/Test/Inspect		I
5045987	J07135	06/20/2015	20:56	06/21/2015	9:32	14	10577	755	Tree related-tree broken	Tree	Remove		I
5045879	N35851	06/20/2015	20:58	06/21/2015	0:39	1	220	220	Weather	Overhead Transformer	Replace - Same Size	Patrol/Test/Inspect	V
5046463	U05-XBK3	06/20/2015	20:58	06/20/2015	22:18	710	56430	79	Overhead equipment	Substation Relay	Repair		II
5045937	V63-XTR1	06/20/2015	20:59	06/20/2015	22:35	181	17366	95	Overhead equipment	Substation Breaker	Replace - Same Size		II
5045887	P07179	06/20/2015	20:59	06/21/2015	14:17	1	1037	1037	Tree related-tree contact	Overhead Transformer	Switch/Reset		I
5045895	M41111	06/20/2015	21:00	06/21/2015	5:50	5	2645	529	Tree related-tree broken	Tree	Remove		I
5045899	U42001	06/20/2015	21:00	06/21/2015	4:40	1	459	459	Overhead equipment	Jumper	Repair		II
5045903	R84148	06/20/2015	21:01	06/21/2015	3:30	1	388	388	Other	Transformer Fuse	Replace - Same Size		I
5045911	U78001	06/20/2015	21:02	06/21/2015	7:30	1	627	627	Overhead equipment	Pole	Replace - Same Size		II
5045919	Q32170	06/20/2015	21:04	06/21/2015	13:48	1	1003	1003	Other	Other	Patrol/Test/Inspect		I
5045925	HD5254	06/20/2015	21:05	06/20/2015	23:30	15	2170	144	Underground equipment	Underground Primary	Repair	Repair	VI
5045941	M41111	06/20/2015	21:06	06/21/2015	12:33	1	926	926	Tree related-tree broken	Overhead Primary	Repair	Replace - Same Size	I
5045947	V44511	06/20/2015	21:07	06/21/2015	6:08	17	9193	540	Tree related-tree broken	Fuse	Replace - Same Size		II
5045949	U01514	06/20/2015	21:08	06/20/2015	23:10	1	121	121	Tree related-tree broken	Pole	Replace - Same Size		II
5045957	N67312	06/20/2015	21:09	06/20/2015	22:56	21	2243	106	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	I
5045955	J08207	06/20/2015	21:09	06/21/2015	8:00	1	650	650	Overhead equipment	Pole	Replace - Same Size		I
5045959	V44511	06/20/2015	21:09	06/21/2015	6:01	11	5846	531	Tree related-tree broken	Tree	Trim		II
5045969	P07179	06/20/2015	21:13	06/21/2015	5:15	1	481	481	Tree related-tree broken	Tree	Remove		I
5045975	309142	06/20/2015	21:14	06/20/2015	22:36	5	407	81	Overhead equipment	Fuse	Replace - Same Size		V
5045977	B25002	06/20/2015	21:14	06/20/2015	22:39	1	84	84	Weather	Transformer Fuse	Replace - Same Size	Replace - Same Size	I
5045993	D96001	06/20/2015	21:17	06/21/2015	10:50	1	812	812	Tree related-tree broken	Fuse	Replace - Same Size		I
5045991	A80001	06/20/2015	21:17	06/21/2015	3:34	32	12051	376	Weather	Recloser	Repair	Replace - Same Size	I
5046573	B61001	06/20/2015	21:18	06/20/2015	23:38	15	2086	139	Weather	Disconnect Switch	Replace - Same Size	Replace - Same Size	I
5046011	R50910	06/20/2015	21:19	06/21/2015	3:00	1	340	340	Weather	Overhead Transformer	Repair	Repair	I

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5046017	V45526	06/20/2015	21:20	06/21/2015	5:24	1	483	483	Tree related-tree broken	Overhead Secondary	Repair		II
5046191	M41111	06/20/2015	21:21	06/21/2015	0:08	76	12718	167	Tree related-tree broken	Overhead Primary	Repair	Replace - Same Size	I
5046027	D88002	06/20/2015	21:21	06/21/2015	16:45	3	3490	1163	Underground equipment	Underground Service	Patrol/Test/Inspect	Repair	I
5046029	B25001	06/20/2015	21:21	06/21/2015	10:08	1	766	766	Tree related-tree broken	Overhead Primary	Repair	Repair	I
5046031	V40549	06/20/2015	21:21	06/21/2015	3:15	53	18723	353	Tree related-tree broken	Overhead Primary	Repair		II
5046035	D41002	06/20/2015	21:22	06/21/2015	1:01	1207	264314	219	Weather	Substation Breaker	Switch/Reset		I
5046465	A91-X2	06/20/2015	21:23	06/21/2015	0:21	2589	460660	177	Weather	Substation Breaker	Switch/Reset		I
5046103	A91-X1	06/20/2015	21:23	06/21/2015	0:44	2428	477284	201	Weather	Substation Breaker	Switch/Reset		I
5046053	V61584	06/20/2015	21:23	06/21/2015	0:50	4	825	206	Tree related-tree broken	Overhead Service	Repair		II
5046057	J08205	06/20/2015	21:23	06/21/2015	2:27	1	303	303	Overhead equipment	Fuse	Replace - Same Size		I
5047661	B65001	06/20/2015	21:24	06/21/2015	1:33	596	148165	248	Overhead equipment	Substation Relay	Switch/Reset		I
5046207	D72003	06/20/2015	21:26	06/21/2015	7:58	969	611778	631	Tree related-tree broken	Tree	Trim		I
5046541	D70005	06/20/2015	21:27	06/21/2015	3:00	192	63797	332	Tree related-tree contact	Ground Wire	Replace - Same Size		I
5046323	J08207	06/20/2015	21:29	06/21/2015	0:04	1	154	154	Tree related-tree broken	Pole	Replace - Same Size		I
5046409	B00005	06/20/2015	21:30	06/21/2015	7:14	51	29742	583	Unknown	Fuse	Replace - Same Size		I
5047773	V23-XTR1	06/20/2015	21:31	06/21/2015	2:43	1747	544190	311	Overhead equipment	Crossarm	Replace - Same Size		II
5046455	D39002	06/20/2015	21:33	06/21/2015	8:50	1	676	676	Unknown	Fuse	Replace - Same Size	Replace - Same Size	I
5046467	D69006	06/20/2015	21:34	06/21/2015	1:02	43	8923	207	Overhead equipment	Fuse	Replace - Same Size		I
5046481	B00005	06/20/2015	21:35	06/21/2015	3:00	67	21773	324	Tree related-tree broken	Tree	Remove		I
5047359	J08207	06/20/2015	21:35	06/21/2015	4:07	210	82305	391	Overhead equipment	Pole	Replace - New Size		I
5046495	B00002	06/20/2015	21:35	06/21/2015	7:19	21	12246	583	Tree related-tree broken	Overhead Secondary	Cut in Clear	Repair	I
5046533	B82002	06/20/2015	21:37	06/21/2015	11:34	31	25510	836	Tree related-tree broken	Overhead Primary	Repair		I
5046531	D70005	06/20/2015	21:39	06/21/2015	2:23	1	283	283	Unknown	Other	Patrol/Test/Inspect		I
5047603	N50331	06/20/2015	21:40	06/21/2015	1:45	76	18574	244	Overhead equipment	Overhead Primary	Repair	Repair	II
5046551	D41003	06/20/2015	21:42	06/21/2015	8:38	1	655	655	Unknown	Other	Patrol/Test/Inspect		I
5046555	U33586	06/20/2015	21:43	06/21/2015	7:42	4	2395	598	Weather	Overhead Transformer	Repair	Repair	II
5046563	D87001	06/20/2015	21:43	06/21/2015	9:50	1	726	726	Tree related-tree contact	Overhead Service	Repair		I
5046569	D55002	06/20/2015	21:44	06/21/2015	9:11	1	686	686	Overhead equipment	Overhead Secondary	Repair		I
5046669	B93002	06/20/2015	21:45	06/21/2015	7:35	306	133124	589	Tree related-tree broken	Overhead Primary	Repair	Raise	I
5046589	D72001	06/20/2015	21:47	06/21/2015	9:15	1	687	687	Overhead equipment	Overhead Secondary	Repair		I
5046591	B21002	06/20/2015	21:48	06/21/2015	11:10	1	801	801	Tree related-tree broken	Overhead Service	Repair		I
5046599	V59001	06/20/2015	21:48	06/21/2015	3:05	1	316	316	Weather	Lightning Arrestor	Replace - Same Size		II
5046617	D36002	06/20/2015	21:49	06/21/2015	7:59	12	7319	609	Tree related-tree broken	Overhead Primary	Repair		I
5046637	J08207	06/20/2015	21:49	06/20/2015	23:30	130	13032	100	Overhead equipment	Recloser	Switch/Reset		I
5046675	D55001	06/20/2015	21:54	06/21/2015	9:55	6	4321	720	Tree related-tree broken	Overhead Service	Repair		I
5046689	D55002	06/20/2015	21:56	06/21/2015	12:09	12	10233	852	Tree related-tree contact	Fuse	Replace - Same Size	Replace - Same Size	I
5046701	C66001	06/20/2015	21:57	06/21/2015	9:42	26	18332	705	Overhead equipment	Fuse	Replace - Same Size		III
5046703	V46563	06/20/2015	21:58	06/21/2015	6:54	1	535	535	Tree related-tree broken	Customer Equipment	Advise Customer	Advise Customer	II
5046707	J08207	06/20/2015	21:59	06/21/2015	2:27	1	267	267	Other	Other	Patrol/Test/Inspect		I
5046711	J07135	06/20/2015	21:59	06/21/2015	10:44	1	764	764	Tree related-tree broken	Tree	Remove		I
5047299	A45003	06/20/2015	22:01	06/21/2015	9:00	8	5271	658	Weather	Fuse	Replace - Same Size	Replace - Same Size	I
5046749	V45526	06/20/2015	22:01	06/21/2015	2:18	324	83187	256	Overhead equipment	Overhead Primary	Repair		II
5046721	D36001	06/20/2015	22:01	06/21/2015	12:24	5	4312	862	Overhead equipment	Pole	Replace - Same Size		I
5047089	C52-X1	06/20/2015	22:03	06/21/2015	10:49	2110	728707	765	Tree related-tree broken	Tree	Remove	Remove	III
5046743	U12540	06/20/2015	22:04	06/21/2015	1:08	1	183	183	Tree related-tree broken	Tree	Remove		II
5046739	N05172	06/20/2015	22:04	06/21/2015	1:11	1	186	186	Weather	Fuse	Replace - Same Size		I
5046755	D41001	06/20/2015	22:05	06/21/2015	10:00	1	714	714	Unknown	Fuse	Replace - Same Size	Replace - Same Size	I
5046761	N05172	06/20/2015	22:06	06/21/2015	3:27	1	320	320	Weather	Overhead Transformer	Replace - Same Size	Replace - Same Size	I
5046937	C36001	06/20/2015	22:06	06/21/2015	5:30	491	217719	443	Overhead equipment	Overhead Primary	Repair	Replace - Same Size	III
5046771	J08205	06/20/2015	22:06	06/20/2015	23:49	1	102	102	Tree related-tree broken	Overhead Service	Cut in Clear	Repair	I
5046779	B21002	06/20/2015	22:07	06/21/2015	9:12	40	26570	664	Tree related-tree broken	Overhead Primary	Repair	Repair	I
5047043	C36002	06/20/2015	22:08	06/21/2015	13:04	131	21588	895	Overhead equipment	Overhead Primary	Repair		III
5046831	V23530	06/20/2015	22:10	06/21/2015	8:08	1	597	597	Tree related-tree contact	Tree	Remove		II
5046863	D35003	06/20/2015	22:13	06/21/2015	8:15	2	1203	601	Overhead equipment	Overhead Primary	Repair		I
5046883	V20502	06/20/2015	22:14	06/21/2015	3:36	1	321	321	Tree related-tree broken	Transformer Fuse	Replace - Same Size		II
5046881	N74230	06/20/2015	22:14	06/21/2015	0:40	12	1749	145	Weather	Transformer Fuse	Replace - Same Size	Repair	I

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5046957	C15002	06/20/2015	22:14	06/21/2015	11:14	82	63947	779	Tree related-tree broken	Pole	Replace - Same Size	Repair	III
5046915	D72001	06/20/2015	22:14	06/21/2015	2:19	1	244	244	Tree related-tree broken	Tree	Patrol/Test/Inspect		I
5046961	V99562	06/20/2015	22:19	06/21/2015	14:38	8	7830	978	Unknown	Fuse	Replace - Same Size		II
5046991	B93003	06/20/2015	22:21	06/21/2015	6:35	1	493	493	Tree related-tree contact	Overhead Service	Repair		I
5046999	J56341	06/20/2015	22:22	06/20/2015	22:50	3	82	27	Weather	Transformer Fuse	Replace - Same Size		III
5047047	C36002	06/20/2015	22:22	06/21/2015	2:22	287	68880	239	Tree related-tree contact	Tree	Trim	Trim	III
5047009	J63172	06/20/2015	22:23	06/20/2015	23:30	3	199	66	Weather	Fuse	Replace - Same Size		III
5047045	V21500	06/20/2015	22:29	06/21/2015	6:26	8	3811	476	Tree related-tree broken	Overhead Primary	Repair		II
5047057	D28123	06/20/2015	22:30	06/21/2015	8:17	1	586	586	Weather	Transformer Fuse	Replace - Same Size		I
5047167	J08205	06/20/2015	22:33	06/20/2015	23:08	1	34	34	Tree related-tree broken	Overhead Service	Cut in Clear	Repair	I
5047175	J56341	06/20/2015	22:34	06/20/2015	23:00	1	25	25	Weather	Transformer Fuse	Replace - Same Size		III
5047181	C66001	06/20/2015	22:34	06/21/2015	4:34	1	359	359	Overhead equipment	Transformer Fuse	Replace - Same Size	Replace - Same Size	III
5047207	V18553	06/20/2015	22:34	06/21/2015	2:00	28	5765	205	Tree related-tree broken	Tree	Remove		II
5047171	B19002	06/20/2015	22:34	06/21/2015	9:32	11	7236	657	Tree related-tree broken	Fuse	Replace - Same Size	Trim	I
5047179	C66002	06/20/2015	22:34	06/21/2015	8:59	1	624	624	Other	Transformer Fuse	Replace - Same Size		III
5047197	K39153	06/20/2015	22:38	06/21/2015	7:00	1	501	501	Tree related-tree broken	Overhead Secondary	Repair		III
5047201	R09225	06/20/2015	22:39	06/21/2015	2:50	1	250	250	Weather	Transformer Fuse	Replace - Same Size		III
5047211	K32932	06/20/2015	22:40	06/21/2015	0:22	1	101	101	Overhead equipment	Other	Patrol/Test/Inspect		VI
5047213	D53002	06/20/2015	22:40	06/21/2015	4:45	1	364	364	Weather	Fuse	Replace - Same Size		I
5047219	K65221	06/20/2015	22:41	06/21/2015	0:20	8	786	98	Weather	Transformer Fuse	Replace - Same Size		III
5047227	J12166	06/20/2015	22:43	06/21/2015	2:37	38	8867	233	Weather	Fuse	Replace - Same Size		III
5047229	P49180	06/20/2015	22:44	06/21/2015	10:53	1	728	728	Unknown	Overhead Service	Patrol/Test/Inspect		I
5047237	J76804	06/20/2015	22:44	06/21/2015	1:29	453	74600	164	Overhead equipment	Recloser	Switch/Reset		V
5047243	K39153	06/20/2015	22:45	06/21/2015	8:03	1	557	557	Weather	Overhead Transformer	Replace - Same Size		III
5047245	K65221	06/20/2015	22:45	06/21/2015	1:15	1	149	149	Tree related-tree broken	Tree	Remove		III
5047249	J63172	06/20/2015	22:46	06/20/2015	23:30	1	43	43	Weather	Transformer Fuse	Replace - Same Size		III
5047261	N95821	06/20/2015	22:51	06/21/2015	2:55	85	20701	243	Weather	Overhead Primary	Repair	Repair	V
5047263	374058	06/20/2015	22:51	06/21/2015	3:46	3	864	294	Weather	Substation Breaker	Switch/Reset		VI
5047317	Q24313	06/20/2015	22:52	06/21/2015	11:15	46	34207	743	Tree related-tree broken	Overhead Primary	Cut in Clear	Repair	VI
5047271	K39156	06/20/2015	22:52	06/21/2015	7:11	1	498	498	Tree related-tree contact	Overhead Service	Repair		III
5048261	V31002	06/20/2015	22:52	06/21/2015	8:40	382	195714	587	Overhead equipment	Overhead Transformer	Replace - Same Size	Replace - Same Size	II
5047717	K09864	06/20/2015	22:53	06/21/2015	1:30	1	156	156	Tree related-tree broken	Tree	Remove	Remove	V
5047279	328120	06/20/2015	22:56	06/21/2015	1:02	6	753	125	Tree related-tree contact	Fuse	Replace - Same Size		V
5047281	328120	06/20/2015	22:57	06/21/2015	2:07	8	1519	189	Tree related-tree broken	Fuse	Replace - Same Size		V
5047287	N95821	06/20/2015	22:57	06/21/2015	4:17	6	1918	319	Weather	Jumper	Repair		V
5047491	V25504	06/20/2015	22:58	06/21/2015	2:50	44	10199	231	Tree related-tree broken	Fuse	Replace - Same Size		II
5047291	Y23513	06/20/2015	22:58	06/21/2015	3:33	3	826	275	Tree related-tree broken	Overhead Primary	Repair		IV
5047297	Q32170	06/20/2015	22:59	06/21/2015	6:33	1	453	453	Tree related-tree broken	Recloser	Repair	Patrol/Test/Inspect	I
5047307	J12166	06/20/2015	23:01	06/21/2015	2:48	1	226	226	Weather	Fuse	Replace - Same Size		III
5047305	K39153	06/20/2015	23:01	06/21/2015	5:10	6	2208	368	Tree related-tree broken	Overhead Secondary	Repair		III
5047309	R33127	06/20/2015	23:02	06/21/2015	11:26	1	743	743	Tree related-tree broken	Tree	Remove		I
5047311	A85002	06/20/2015	23:03	06/21/2015	3:25	1	261	261	Overhead equipment	Transformer Fuse	Replace - Same Size	Replace - Same Size	I
5047313	328120	06/20/2015	23:03	06/21/2015	1:02	1	118	118	Tree related-tree contact	Fuse	Replace - Same Size		V
5047321	309142	06/20/2015	23:06	06/21/2015	3:32	42	3924	266	Tree related-tree broken	Overhead Primary	Repair	Repair	V
5047325	H10843	06/20/2015	23:06	06/21/2015	2:42	4	861	215	Weather	Overhead Transformer	Replace - Same Size		V
5047327	310124	06/20/2015	23:06	06/21/2015	3:28	25	6528	261	Tree related-tree contact	Overhead Primary	Repair	Repair	V
5047331	328120	06/20/2015	23:07	06/21/2015	1:02	4	457	114	Tree related-tree contact	Fuse	Replace - Same Size		V
5047335	H10843	06/20/2015	23:07	06/21/2015	0:19	6	426	71	Tree related-tree broken	Overhead Transformer	Switch/Reset		V
5047367	B45-X2	06/20/2015	23:09	06/21/2015	3:50	714	200157	280	Unknown	Bracket	Tie/Tighten	Repair	I
5047341	Z61524	06/20/2015	23:09	06/21/2015	6:27	5	2186	437	Overhead equipment	Overhead Transformer	Replace - Same Size		IV
5047363	M31204	06/20/2015	23:11	06/21/2015	3:14	1	242	242	Other	Other	Patrol/Test/Inspect		I
5047419	M04365	06/20/2015	23:14	06/21/2015	2:02	453	75922	167	Tree related-tree broken	Recloser	Switch/Reset		V
5047401	Y45503	06/20/2015	23:15	06/21/2015	0:40	1	84	84	Overhead equipment	Transformer Fuse	Replace - Same Size	Replace - Same Size	IV
5047399	V44511	06/20/2015	23:16	06/21/2015	4:58	10	3419	341	Weather	Fuse	Replace - Same Size		II
5047449	Y77002	06/20/2015	23:24	06/21/2015	2:28	1	183	183	Overhead equipment	Overhead Service	Cut in Clear	Repair	IV
5047451	R73840	06/20/2015	23:25	06/21/2015	11:35	8	5836	729	Tree related-tree broken	Overhead Primary	Repair	Repair	V

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5047459	K73362	06/20/2015	23:26	06/21/2015	1:02	35	3326	95	Weather	Fuse	Replace - Same Size		IV
5047455	R73840	06/20/2015	23:27	06/21/2015	1:32	1	124	124	Tree related-tree broken	Tree	Remove		V
5047461	V44511	06/20/2015	23:29	06/21/2015	5:30	11	3970	360	Weather	Fuse	Replace - Same Size		II
5047463	328120	06/20/2015	23:29	06/21/2015	1:02	1	92	92	Tree related-tree contact	Fuse	Replace - Same Size		V
5047465	U37579	06/20/2015	23:31	06/21/2015	9:30	1	598	598	Overhead equipment	Disconnect Switch	Replace - Same Size	Patrol/Test/Inspect	II
5047477	M49411	06/20/2015	23:36	06/21/2015	10:50	1	673	673	Weather	Fuse	Replace - Same Size	Patrol/Test/Inspect	V
5047769	V95-XTR1	06/20/2015	23:37	06/21/2015	4:15	277	76875	277	Overhead equipment	Crossarm	Replace - Same Size		II
5047487	Y97514	06/20/2015	23:39	06/21/2015	3:57	90	23227	258	Overhead equipment	Crossarm	Replace - New Size	Repair	IV
5047485	D72001	06/20/2015	23:40	06/21/2015	9:20	1	579	579	Overhead equipment	Transformer Fuse	Replace - Same Size		I
5047495	X39530	06/20/2015	23:43	06/21/2015	3:28	1	224	224	Tree related-tree broken	Overhead Service	Cut in Clear	Repair	IV
5047497	X39530	06/20/2015	23:43	06/21/2015	3:25	1	221	221	Tree related-tree broken	Overhead Service	Cut in Clear	Repair	IV
5047549	HA5430	06/20/2015	23:44	06/21/2015	6:35	56	22988	410	Weather	Recloser	Switch/Reset		V
5047535	Z29579	06/20/2015	23:44	06/21/2015	4:35	23	6679	290	Overhead equipment	Overhead Primary	Repair		IV
5047513	HA5430	06/20/2015	23:47	06/21/2015	6:35	1	407	407	Weather	Transformer Fuse	Replace - Same Size		V
5047515	N58144	06/20/2015	23:47	06/21/2015	4:19	1	271	271	Tree related-tree contact	Fuse	Replace - Same Size		I
5047517	N95823	06/20/2015	23:48	06/21/2015	4:06	1	257	257	Weather	Customer Equipment	Advise Customer		V
5047547	X19561	06/20/2015	23:49	06/21/2015	10:24	31	19042	634	Weather	Underground Primary	Repair		IV
5047523	X82003	06/20/2015	23:50	06/21/2015	6:50	11	4618	419	Tree related-tree contact	Transformer Fuse	Replace - Same Size		IV
5047563	X19561	06/20/2015	23:50	06/21/2015	3:12	73	14716	201	Weather	Fuse	Replace - Same Size		IV
5047541	L82187	06/20/2015	23:51	06/21/2015	2:10	1	138	138	Weather	Fuse	Replace - Same Size		IV
5047545	346003	06/20/2015	23:52	06/21/2015	3:12	1	199	199	Tree related-tree broken	Overhead Service	Cut in Clear	Repair	VI
5047569	B00003	06/20/2015	23:57	06/21/2015	7:01	71	30061	423	Underground equipment	Underground Primary	Repair		I
5047571	341001	06/20/2015	23:58	06/21/2015	5:00	1	301	301	Overhead equipment	Overhead Secondary	Cut in Clear	Repair	VI
5047575	HA5430	06/21/2015	0:00	06/21/2015	6:35	1	394	394	Weather	Recloser	Switch/Reset		V
5047579	Y77002	06/21/2015	0:01	06/21/2015	4:55	1	293	293	Tree related-tree broken	Overhead Service	Replace - Same Size	Repair	IV
5047581	X72535	06/21/2015	0:02	06/21/2015	3:30	23	4774	207	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	IV
5047587	B93002	06/21/2015	0:05	06/21/2015	4:16	1	250	250	Tree related-tree broken	Fuse	Replace - Same Size		I
5047589	X72535	06/21/2015	0:05	06/21/2015	3:30	1	204	204	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	IV
5047639	X83533	06/21/2015	0:06	06/21/2015	5:23	58	18349	316	Tree related-tree broken	Overhead Primary	Repair		IV
5047595	N95823	06/21/2015	0:08	06/21/2015	3:41	1	212	212	Weather	Lightning Arrestor	Replace - New Size		V
5047597	Q16867	06/21/2015	0:09	06/21/2015	3:52	6	1340	223	Weather	Fuse	Replace - Same Size		V
5047599	D31016	06/21/2015	0:12	06/21/2015	1:37	1	84	84	Overhead equipment	Fuse	Replace - Same Size		III
5047601	J99128	06/21/2015	0:14	06/21/2015	3:35	1	200	200	Tree related-tree broken	Fuse	Replace - Same Size		VI
5047605	X99538	06/21/2015	0:17	06/21/2015	1:09	24	1246	51	Tree related-tree broken	Fuse	Replace - Same Size		IV
5047611	Q83171	06/21/2015	0:18	06/21/2015	2:40	1	141	141	Tree related-tree broken	Overhead Service	Repair	Replace - Same Size	VI
5047615	IP9009	06/21/2015	0:21	06/21/2015	3:10	1	168	168	Tree related-tree broken	Overhead Service	Repair		VI
5047621	309142	06/21/2015	0:25	06/21/2015	2:58	8	1218	152	Tree related-tree broken	Overhead Primary	Repair	Repair	V
5047623	K30204	06/21/2015	0:27	06/21/2015	3:00	1	152	152	Weather	Fuse	Replace - Same Size		III
5047631	J08205	06/21/2015	0:30	06/21/2015	1:28	18	1044	58	Jurisdictional	Overhead Primary	Repair		I
5047625	P54828	06/21/2015	0:33	06/21/2015	5:05	1	271	271	Weather	Overhead Secondary	Repair		V
5047627	B93002	06/21/2015	0:34	06/21/2015	4:18	1	223	223	Tree related-tree broken	Fuse	Replace - Same Size		I
5047635	U11531	06/21/2015	0:36	06/21/2015	9:14	9	4656	517	Weather	Overhead Transformer	Repair	Repair	II
5047637	B93001	06/21/2015	0:37	06/21/2015	1:52	1	74	74	Tree related-tree broken	Overhead Service	Repair		I
5047645	J76804	06/21/2015	0:42	06/21/2015	6:08	7	2277	325	Tree related-tree broken	Overhead Primary	Repair	Repair	V
5047647	Z29579	06/21/2015	0:45	06/21/2015	4:30	1	224	224	Overhead equipment	Overhead Primary	Repair		IV
5047649	X39530	06/21/2015	0:45	06/21/2015	3:25	1	159	159	Tree related-tree broken	Overhead Service	Cut in Clear	Repair	IV
5047653	J74125	06/21/2015	0:47	06/21/2015	2:50	24	2944	122	Tree related-tree broken	Overhead Primary	Patrol/Test/Inspect	Repair	VI
5047693	E10001	06/21/2015	0:56	06/21/2015	2:30	1	93	93	Overhead equipment	Fuse	Replace - Same Size		III
5047695	F10001	06/21/2015	0:57	06/21/2015	4:41	1	223	223	Overhead equipment	Transformer Fuse	Replace - Same Size		III
5047697	309142	06/21/2015	0:59	06/21/2015	3:32	1	152	152	Tree related-tree broken				V
5047877	A91002	06/21/2015	1:07	06/21/2015	8:34	1	446	446	Tree related-tree broken	Tree	Remove		I
5047705	Y45003	06/21/2015	1:11	06/21/2015	2:57	1	105	105	Tree related-tree contact	Transformer Fuse	Replace - Same Size	Replace - Same Size	IV
5047709	A26005	06/21/2015	1:12	06/21/2015	6:36	38	12283	323	Tree related-tree broken	Tree	Trim		I
5047711	Q71846	06/21/2015	1:14	06/21/2015	5:37	1	262	262	Overhead equipment	Transformer Fuse	Replace - Same Size	Repair	V
5047713	V44511	06/21/2015	1:20	06/21/2015	5:29	10	2485	248	Weather	Fuse	Replace - Same Size		II
5047715	V10551	06/21/2015	1:25	06/21/2015	4:09	1	163	163	Tree related-tree broken	Overhead Primary	Repair		II

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5047719	W03570	06/21/2015	1:27	06/21/2015	13:01	51	35345	693	Overhead equipment	Overhead Primary	Repair		II
5047721	J08205	06/21/2015	1:28	06/21/2015	14:30	2	1564	782	Tree related-tree broken	Tree	Remove	Remove	I
5047725	L86176	06/21/2015	1:29	06/21/2015	8:48	4	1757	439	Overhead equipment	Pole	Replace - Same Size		IV
5047723	V30004	06/21/2015	1:29	06/21/2015	5:31	1	241	241	Overhead equipment	Substation Transformer	Repair	Repair	II
5047727	V30004	06/21/2015	1:29	06/21/2015	5:23	57	13351	234	Weather	Lightning Arrestor	Replace - Same Size	Replace - Same Size	II
5047729	328120	06/21/2015	1:35	06/21/2015	3:05	1	89	89	Weather	Fuse	Replace - Same Size		V
5047731	Y54591	06/21/2015	1:38	06/21/2015	3:48	1	129	129	Tree related-tree broken	Overhead Service	Repair		IV
5047841	A91002	06/21/2015	1:41	06/21/2015	5:47	1	245	245	Tree related-tree broken	Overhead Secondary	Repair	Repair	I
5047733	B25001	06/21/2015	1:41	06/21/2015	10:10	1	508	508	Tree related-tree broken	Overhead Primary	Repair		I
5047739	V44511	06/21/2015	1:45	06/21/2015	4:57	9	1726	191	Weather	Fuse			II
5047905	Y06546	06/21/2015	1:47	06/21/2015	7:03	28	8761	316	Tree related-tree broken	Overhead Primary	Cut in Clear	Repair	IV
5047751	V23-XTR2	06/21/2015	1:49	06/21/2015	2:40	810	40880	50	Overhead equipment	Crossarm	Replace - Same Size		II
5047907	V24583	06/21/2015	1:49	06/21/2015	4:58	737	139366	189	Overhead equipment	Crossarm	Replace - Same Size		II
5047755	Y06546	06/21/2015	1:50	06/21/2015	4:06	94	12755	135	Tree related-tree broken	Overhead Primary	Cut in Clear	Repair	IV
5047845	U45-XTR1	06/21/2015	1:53	06/21/2015	4:52	448	80057	178	Tree related-tree broken	Crossarm	Replace - Same Size		II
5047775	V23-XTR3	06/21/2015	1:55	06/21/2015	2:40	148	6534	44	Overhead equipment	Crossarm	Replace - Same Size		II
5047939	U66515	06/21/2015	1:57	06/21/2015	8:21	25	9593	383	Tree related-tree broken	Overhead Primary			II
5047811	U51-XTR1	06/21/2015	2:06	06/21/2015	4:15	58	7472	128	Overhead equipment	Crossarm	Replace - Same Size		II
5047903	D70005	06/21/2015	2:07	06/21/2015	4:00	307	34568	112	Overhead equipment	Overhead Primary			I
5047835	D70005	06/21/2015	2:08	06/21/2015	3:14	37	2439	65	Tree related-tree contact	Overhead Primary	Remove		I
5048267	B00003	06/21/2015	2:15	06/21/2015	10:21	3	1456	485	Underground equipment	Underground Connector	Repair		I
5047853	K95204	06/21/2015	2:22	06/21/2015	3:28	6	394	65	Weather	Transformer Fuse	Replace - Same Size		III
5047857	J01118	06/21/2015	2:24	06/21/2015	2:45	1	20	20	Weather	Overhead Primary			I
5047859	Q32170	06/21/2015	2:28	06/21/2015	5:35	1	186	186	Overhead equipment	Overhead Service			I
5047861	C36002	06/21/2015	2:28	06/21/2015	6:08	5	1098	219	Overhead equipment				III
5047915	C36002	06/21/2015	2:32	06/21/2015	9:00	188	56587	388	Overhead equipment	Fuse	Replace - Same Size		III
5047867	HE3303	06/21/2015	2:32	06/21/2015	10:32	1	479	479	Tree related-tree broken	Tree	Patrol/Test/Inspect	Trim	VI
5047881	A91002	06/21/2015	2:37	06/21/2015	6:50	125	31535	252	Tree related-tree contact	Tree	Remove		I
5047885	L35139	06/21/2015	2:41	06/21/2015	4:45	1	123	123	Tree related-tree contact	Overhead Service	Cut in Clear		III
5047895	C36002	06/21/2015	2:49	06/21/2015	3:06	1	16	16	Tree related-tree broken	Tree		Trim	III
5047901	X69555	06/21/2015	2:54	06/21/2015	4:58	1	123	123	Tree related-tree broken	Overhead Service	Repair		IV
5047913	V10551	06/21/2015	3:02	06/21/2015	4:07	1	64	64	Tree related-tree broken	Other			II
5047911	P25150	06/21/2015	3:02	06/21/2015	5:14	1	131	131	Tree related-tree broken	Overhead Service	Patrol/Test/Inspect		III
5047919	V19001	06/21/2015	3:03	06/21/2015	10:06	6	2536	422	Weather	Fuse	Replace - Same Size		II
5047925	U49-XBK1	06/21/2015	3:08	06/21/2015	4:15	3	200	66	Overhead equipment	Crossarm	Replace - Same Size		II
5047993	N03296	06/21/2015	3:15	06/21/2015	3:54	655	25400	38	Unknown				V
5047999	V40549	06/21/2015	3:36	06/21/2015	11:48	1	491	491	Tree related-tree broken	Tree		Remove	II
5048001	Z29579	06/21/2015	3:39	06/21/2015	4:30	1	50	50	Overhead equipment	Overhead Primary	Repair		IV
5048005	B45004	06/21/2015	3:50	06/21/2015	5:26	711	67950	95	Unknown	Bracket	Repair	Repair	I
5048007	Q16867	06/21/2015	3:53	06/21/2015	4:55	8	494	61	Overhead equipment	Overhead Primary	Tie/Tighten	Tie/Tighten	V
5048013	Q16867	06/21/2015	3:59	06/21/2015	4:55	6	332	55	Overhead equipment	Overhead Primary	Tie/Tighten	Tie/Tighten	V
5048015	Y82587	06/21/2015	3:59	06/21/2015	7:41	1	221	221	Overhead equipment	Overhead Transformer	Replace - Same Size		IV
5048017	W03570	06/21/2015	4:02	06/21/2015	5:27	39	3284	84	Overhead equipment	Overhead Primary	Repair	Patrol/Test/Inspect	II
5048025	Y35001	06/21/2015	4:04	06/21/2015	6:05	33	4000	121	Overhead equipment	Overhead Primary	Repair		IV
5048139	V44511	06/21/2015	4:06	06/21/2015	8:41	46	12647	274	Weather	Fuse	Replace - Same Size		II
5048061	B65001	06/21/2015	4:06	06/21/2015	4:40	596	20204	33	Overhead equipment				I
5048027	X99538	06/21/2015	4:06	06/21/2015	7:03	1	176	176	Tree related-tree contact	Overhead Primary	Cut in Clear	Repair	IV
5048029	X99538	06/21/2015	4:07	06/21/2015	7:03	1	175	175	Tree related-tree contact	Overhead Primary	Cut in Clear	Repair	IV
5048317	Z29579	06/21/2015	4:13	06/21/2015	8:03	9	2064	229	Tree related-tree broken	Overhead Primary	Repair		IV
5048059	X92508	06/21/2015	4:20	06/21/2015	7:20	710	127139	179	Tree related-tree broken	Tree	Trim		IV
5048083	V30003	06/21/2015	4:30	06/21/2015	5:23	42	2217	52	Weather	Lightning Arrestor		Replace - Same Size	II
5048087	V30001	06/21/2015	4:31	06/21/2015	5:23	4	209	52	Weather	Lightning Arrestor		Replace - Same Size	II
5048125	J07135	06/21/2015	4:42	06/21/2015	6:17	2	190	95	Overhead equipment				I
5048161	R24832	06/21/2015	4:46	06/21/2015	7:44	19	3378	177	Overhead equipment				V
5048141	V23522	06/21/2015	5:05	06/21/2015	7:24	14	1936	138	Tree related-tree broken	Tree			II
5048145	S43502	06/21/2015	5:08	06/21/2015	6:26	5	389	77	Overhead equipment	Transformer Fuse	Repair	Replace - Same Size	VI

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5048151	J34356	06/21/2015	5:14	06/21/2015	14:42	19	5685	568	Underground equipment				V
5048155	R24832	06/21/2015	5:14	06/21/2015	7:53	1	158	158	Overhead equipment				V
5048157	V29002	06/21/2015	5:17	06/21/2015	7:16	1	118	118	Overhead equipment	Overhead Service	Repair	Repair	II
5048163	Z08509	06/21/2015	5:29	06/21/2015	9:00	1	210	210	Tree related-tree broken	Overhead Service	Raise		IV
5048167	P07179	06/21/2015	5:49	06/21/2015	15:21	1	571	571	Tree related-tree broken	Overhead Service	Replace - Same Size		I
5048169	M49411	06/21/2015	5:54	06/21/2015	10:50	1	295	295	Tree related-tree broken				V
5048173	D87001	06/21/2015	6:01	06/21/2015	8:00	6	709	118	Overhead equipment	Overhead Secondary	Tie/Tighten		I
5048175	W03570	06/21/2015	6:02	06/21/2015	8:05	1	122	122	Overhead equipment	Jumper	Repair		II
5048177	Q32170	06/21/2015	6:10	06/21/2015	10:06	1	235	235	Overhead equipment	Overhead Primary	Cut in Clear	Patrol/Test/Inspect	I
5048183	E10001	06/21/2015	6:24	06/21/2015	8:10	1	105	105	Overhead equipment	Jumper	Replace - Same Size	Repair	III
5048185	J08207	06/21/2015	6:25	06/21/2015	7:57	2	184	92	Overhead equipment	Overhead Secondary	Replace - Same Size	Replace - Same Size	I
5048187	B61001	06/21/2015	6:35	06/21/2015	8:57	1	141	141	Overhead equipment	Disconnect Switch	Replace - Same Size		I
5048669	P62138	06/21/2015	6:38	06/21/2015	12:36	256	67211	358	Tree related-tree broken	Overhead Primary	Replace - Same Size	Replace - Same Size	VI
5048195	P62138	06/21/2015	6:39	06/21/2015	12:36	133	32119	356	Tree related-tree broken	Overhead Primary	Replace - Same Size	Replace - Same Size	VI
5048217	M37191	06/21/2015	6:43	06/21/2015	8:14	1	90	90	Tree related-tree broken	Tree			I
5048251	U45536	06/21/2015	7:04	06/21/2015	10:50	1	225	225	Weather	Transformer Fuse	Replace - Same Size		II
5048253	327157	06/21/2015	7:05	06/21/2015	9:35	1	149	149	Tree related-tree broken	Overhead Secondary	Cut in Clear	Repair	V
5048255	D88001	06/21/2015	7:05	06/21/2015	17:48	1	642	642	Underground equipment	Underground Service	Patrol/Test/Inspect	Repair	I
5048269	B25001	06/21/2015	7:09	06/21/2015	10:10	1	180	180	Tree related-tree broken	Overhead Primary	Repair		I
5048273	A26005	06/21/2015	7:10	06/21/2015	7:20	8	77	9	Tree related-tree contact	Overhead Primary	Repair		I
5048289	A17025	06/21/2015	7:14	06/21/2015	10:18	6	1102	183	Overhead equipment	Transformer Fuse	Replace - Same Size		I
5048809	W03570	06/21/2015	7:21	06/21/2015	17:26	38	22971	604	Tree related-tree broken				II
5048319	329148	06/21/2015	7:25	06/21/2015	10:35	1	189	189	Tree related-tree broken	Overhead Service	Patrol/Test/Inspect	Replace - Same Size	V
5048323	X72535	06/21/2015	7:25	06/21/2015	8:44	3	234	78	Animal related	Fuse	Replace - Same Size		IV
5048325	M41111	06/21/2015	7:28	06/21/2015	12:04	1	275	275	Tree related-tree broken	Overhead Primary	Repair		I
5048327	314166	06/21/2015	7:29	06/21/2015	10:54	1	204	204	Tree related-tree contact				V
5048329	X72535	06/21/2015	7:29	06/21/2015	8:44	6	447	74	Animal related	Fuse	Replace - Same Size		IV
5048733	Y08552	06/21/2015	7:31	06/21/2015	12:20	13	3760	289	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	IV
5048339	C66002	06/21/2015	7:33	06/21/2015	9:18	1	104	104	Other				III
5048341	P49187	06/21/2015	7:36	06/21/2015	12:50	4	1254	313	Animal related	Fuse		Repair	I
5048571	HA5430	06/21/2015	7:39	06/21/2015	9:01	896	73400	81	Overhead equipment				V
5048651	HA5432	06/21/2015	7:39	06/21/2015	9:46	485	61255	126	Animal related				V
5048649	HA5431	06/21/2015	7:40	06/21/2015	9:45	641	79823	124	Animal related				V
5048383	C30002	06/21/2015	7:42	06/21/2015	11:30	1	227	227	Weather	Overhead Transformer			III
5048407	J71129	06/21/2015	7:43	06/21/2015	8:40	1	56	56	Overhead equipment	Fuse	Replace - Same Size		I
5048435	Q91141	06/21/2015	7:45	06/21/2015	15:05	1	439	439	Tree related-tree broken				I
5048593	P07179	06/21/2015	7:46	06/21/2015	9:04	105	8176	77	Overhead equipment				I
5048459	HE3304	06/21/2015	7:46	06/21/2015	10:11	1	144	144	Animal related	Transformer Fuse	Replace - Same Size		VI
5048471	343006	06/21/2015	7:47	06/21/2015	8:46	1	58	58	Tree related-tree broken	Overhead Transformer	Patrol/Test/Inspect		VI
5048491	P26284	06/21/2015	7:48	06/21/2015	10:30	1	161	161	Animal related	Fuse	Replace - Same Size	Replace - Same Size	I
5048497	B71001	06/21/2015	7:51	06/21/2015	9:59	1	127	127	Tree related-tree broken	Overhead Service			I
5048503	Q74150	06/21/2015	7:52	06/21/2015	12:20	5	1339	267	Weather	Transformer Fuse	Replace - Same Size		IV
5048505	A97002	06/21/2015	7:56	06/21/2015	12:00	1	243	243	Tree related-tree broken	Overhead Service	Raise		I
5048595	P07179	06/21/2015	7:59	06/21/2015	14:05	1	365	365	Tree related-tree contact				I
5048515	343005	06/21/2015	8:04	06/21/2015	9:49	55	5729	104	Animal related				VI
5048525	Q32171	06/21/2015	8:07	06/21/2015	12:52	11	3137	285	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	I
5048529	N50331	06/21/2015	8:11	06/21/2015	14:36	1	384	384	Weather	Fuse	Replace - Same Size	Replace - Same Size	II
5048531	V31002	06/21/2015	8:12	06/21/2015	8:43	1	30	30	Overhead equipment	Overhead Transformer			II
5048537	341001	06/21/2015	8:13	06/21/2015	13:15	7	2108	301	Overhead equipment	Tree	Advise Customer	Trim	VI
5048541	S31532	06/21/2015	8:14	06/21/2015	10:31	1	136	136	Overhead equipment	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
5048543	J47176	06/21/2015	8:16	06/21/2015	9:32	6	452	75	Animal related				III
5048545	J07135	06/21/2015	8:16	06/21/2015	15:35	1	438	438	Overhead equipment	Fuse	Patrol/Test/Inspect	Replace - Same Size	I
5048549	M81403	06/21/2015	8:18	06/21/2015	11:31	3	576	192	Overhead equipment	Fuse	Repair	Repair	V
5048619	R59415	06/21/2015	8:24	06/21/2015	10:36	326	42992	131	Overhead equipment	Fuse	Replace - Same Size		IV
5048555	A36002	06/21/2015	8:26	06/21/2015	10:58	1	151	151	Unknown	Fuse	Replace - Same Size		I
5048557	J47176	06/21/2015	8:26	06/21/2015	9:32	1	65	65	Animal related				III

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5048573	Q32170	06/21/2015	8:29	06/21/2015	10:10	31	3118	100	Tree related-tree broken	Fuse	Repair	Patrol/Test/Inspect	I
5048563	P07179	06/21/2015	8:29	06/21/2015	14:08	5	1691	338	Overhead equipment	Overhead Transformer	Replace - Same Size		I
5048567	M40117	06/21/2015	8:31	06/21/2015	9:45	10	731	73	Tree related-tree broken	Fuse	Replace - Same Size		I
5048569	C60001	06/21/2015	8:35	06/21/2015	9:55	1	79	79	Overhead equipment	Fuse	Replace - Same Size	Repair	III
5048577	U49101	06/21/2015	8:39	06/21/2015	11:49	1	189	189	Overhead equipment	Transformer Fuse	Repair	Replace - Same Size	II
5048575	U49101	06/21/2015	8:39	06/21/2015	11:49	1	189	189	Overhead equipment	Transformer Fuse	Repair	Replace - Same Size	II
5048579	Q36410	06/21/2015	8:40	06/21/2015	12:02	1	201	201	Overhead equipment	Connector	Repair	Repair	I
5048581	U54503	06/21/2015	8:43	06/21/2015	15:59	1	435	435	Weather	Lightning Arrestor	Replace - Same Size		II
5048811	W03570	06/21/2015	8:56	06/21/2015	11:28	19	2892	152	Overhead equipment	Pole	Repair	Replace - Same Size	II
5048591	N05170	06/21/2015	9:01	06/21/2015	9:41	1	39	39	Animal related	Transformer Fuse	Replace - Same Size		I
5048599	Q80353	06/21/2015	9:04	06/21/2015	9:54	1	49	49	Overhead equipment	Pole	Replace - Same Size	Replace - Same Size	V
5048601	P07179	06/21/2015	9:04	06/21/2015	13:06	30	7271	242	Other	Jumper		Reconnect	I
5048603	B82001	06/21/2015	9:04	06/21/2015	10:30	1	85	85	Overhead equipment	Fuse	Repair		I
5048609	D72003	06/21/2015	9:09	06/21/2015	11:15	1	125	125	Tree related-tree contact	Overhead Primary	Repair		I
5048611	V03529	06/21/2015	9:09	06/21/2015	11:45	76	11833	155	Tree related-tree contact	Tree	Remove		II
5048623	P07179	06/21/2015	9:12	06/21/2015	16:00	7	2855	407	Overhead equipment	Overhead Primary	Replace - Same Size	Replace - Same Size	I
5048629	D90004	06/21/2015	9:13	06/21/2015	9:41	1	27	27	Animal related				III
5048631	K62102	06/21/2015	9:13	06/21/2015	15:12	1	358	358	Weather	Fuse	Replace - Same Size	Replace - Same Size	II
5048635	N58144	06/21/2015	9:14	06/21/2015	15:00	1	345	345	Tree related-tree broken	Fuse	Replace - Same Size		I
5048639	R59415	06/21/2015	9:16	06/21/2015	10:35	1	78	78	Overhead equipment	Fuse	Replace - Same Size		IV
5048641	C36002	06/21/2015	9:16	06/21/2015	11:29	1	132	132	Overhead equipment	Fuse	Repair	Replace - Same Size	III
5048645	V03529	06/21/2015	9:20	06/21/2015	12:07	1	166	166	Overhead equipment	Overhead Service	Replace - Same Size	Replace - Same Size	II
5048655	329148	06/21/2015	9:23	06/21/2015	10:01	1	37	37	Overhead equipment	Fuse	Replace - Same Size		V
5048659	L81142	06/21/2015	9:27	06/21/2015	9:54	49	1339	27	Tree related-tree contact	Overhead Primary	Repair	Repair	IV
5048661	N15849	06/21/2015	9:27	06/21/2015	11:48	1	140	140	Animal related	Fuse	Replace - Same Size		V
5048665	V03529	06/21/2015	9:29	06/21/2015	11:45	1	135	135	Tree related-tree contact				II
5048677	Q32171	06/21/2015	9:42	06/21/2015	12:53	4	762	190	Animal related	Fuse	Replace - Same Size		I
5048679	Y26520	06/21/2015	9:44	06/21/2015	14:36	1	291	291	Underground equipment	Underground Service	Patrol/Test/Inspect	Repair	IV
5048681	L23145	06/21/2015	9:44	06/21/2015	11:08	7	583	83	Tree related-tree broken	Overhead Primary	Repair		III
5048683	341001	06/21/2015	9:45	06/21/2015	11:21	1	95	95	Tree related-tree contact	Tree	Trim		VI
5048687	J14140	06/21/2015	9:47	06/21/2015	15:10	1	322	322	Animal related	Fuse	Replace - Same Size		VI
5048689	C52002	06/21/2015	9:47	06/21/2015	11:53	1	125	125	Other				III
5048691	C52001	06/21/2015	9:47	06/21/2015	11:42	1	114	114	Other				III
5048697	K95204	06/21/2015	9:51	06/21/2015	11:28	1	96	96	Tree related-tree contact	Overhead Service	Repair		III
5048701	S86597	06/21/2015	10:01	06/21/2015	12:24	1	142	142	Tree related-tree broken	Overhead Service	Patrol/Test/Inspect	Repair	VI
5048703	B21002	06/21/2015	10:05	06/21/2015	14:47	40	11246	281	Tree related-tree contact	Tree	Remove		I
5048707	V03529	06/21/2015	10:09	06/21/2015	11:45	1	95	95	Overhead equipment				II
5048713	B44001	06/21/2015	10:20	06/21/2015	14:00	1	219	219	Weather	Fuse	Patrol/Test/Inspect		I
5048719	H01192	06/21/2015	10:24	06/21/2015	11:57	1	92	92	Animal related	Transformer Fuse	Repair		III
5048721	V41527	06/21/2015	10:26	06/21/2015	11:10	35	1551	44	Tree related-tree contact	Tree	Trim		II
5048731	N50331	06/21/2015	10:38	06/21/2015	14:02	1	203	203	Tree related-tree broken	Overhead Service	Repair	Repair	II
5048737	X77543	06/21/2015	10:39	06/21/2015	12:59	10	1390	139	Tree related-tree contact	Fuse	Replace - Same Size		IV
5048761	B80004	06/21/2015	10:48	06/21/2015	15:08	747	193525	259	Animal related	Overhead Primary	Patrol/Test/Inspect	Repair	I
5048749	L35139	06/21/2015	10:50	06/21/2015	13:02	1	131	131	Tree related-tree broken	Overhead Service	Repair		III
5048769	C52001	06/21/2015	10:57	06/21/2015	11:39	53	2211	41	Weather	Fuse	Replace - Same Size		III
5048771	C52001	06/21/2015	10:57	06/21/2015	12:33	34	3237	95	Overhead equipment	Fuse	Repair	Replace - Same Size	III
5048789	S50541	06/21/2015	11:09	06/21/2015	13:51	3	483	161	Overhead equipment	Transformer Fuse	Patrol/Test/Inspect	Replace - New Size	VI
5048795	R68900	06/21/2015	11:12	06/21/2015	14:34	1	201	201	Unknown	Transformer Fuse	Replace - Same Size		I
5048933	K76546	06/21/2015	11:15	06/21/2015	21:36	351	70775	621	Underground equipment	Underground Transformer	Disconnect	Replace - Same Size	IV
5048797	U10547	06/21/2015	11:15	06/21/2015	12:28	1	72	72	Overhead equipment	Fuse	Replace - Same Size		II
5048819	L93135	06/21/2015	11:39	06/21/2015	15:08	8	1669	208	Underground equipment	Underground Secondary	Patrol/Test/Inspect	Repair	VI
5048823	C52001	06/21/2015	11:40	06/21/2015	13:26	53	5600	105	Overhead equipment	Fuse	Repair	Replace - Same Size	III
5048825	Q82906	06/21/2015	11:42	06/21/2015	13:07	1	84	84	Overhead equipment	Fuse	Replace - Same Size	Repair	VI
5048833	B25001	06/21/2015	11:47	06/21/2015	13:20	1	92	92	Tree related-tree broken	Overhead Service	Cut in Clear		I
5048835	H01190	06/21/2015	11:48	06/21/2015	13:40	1	111	111	Tree related-tree contact	Overhead Service	Repair		III
5048853	D66004	06/21/2015	11:54	06/21/2015	13:13	23	1818	79	Tree related-tree broken	Overhead Primary	Switch/Reset	Tie/Tighten	IV

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5048847	U44568	06/21/2015	11:55	06/21/2015	13:55	1	119	119	Overhead equipment	Fuse	Repair		II
5048857	HD0573	06/21/2015	12:02	06/21/2015	13:23	184	14936	81	Tree related-tree broken	Overhead Primary			VI
5048865	F10001	06/21/2015	12:02	06/21/2015	13:55	19	2139	112	Overhead equipment	Disconnect Switch	Replace - New Size	Repair	III
5048863	HD0573	06/21/2015	12:02	06/21/2015	13:23	149	12028	80	Tree related-tree broken	Overhead Primary			VI
5048873	P44324	06/21/2015	12:16	06/21/2015	18:55	1	398	398	Tree related-tree contact	Overhead Service	Replace - New Size		I
5048877	V51002	06/21/2015	12:20	06/21/2015	13:33	18	1324	73	Tree related-tree contact	Tree	Trim		II
5048901	D89002	06/21/2015	12:41	06/21/2015	16:22	1	220	220	Tree related-tree contact	Overhead Service	Repair		I
5048905	D66004	06/21/2015	12:47	06/21/2015	15:19	2	303	151	Tree related-tree broken	Overhead Primary	Switch/Reset	Repair	IV
5048909	P26280	06/21/2015	12:52	06/21/2015	16:50	1	237	237	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Repair	I
5048913	X36550	06/21/2015	13:03	06/21/2015	14:16	1	72	72	Overhead equipment	Fuse	Replace - Same Size		IV
5048915	H32370	06/21/2015	13:05	06/21/2015	16:15	1	189	189	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	V
5048917	B81001	06/21/2015	13:22	06/21/2015	17:19	1	236	236	Weather	Fuse	Repair		I
5048925	V25504	06/21/2015	13:30	06/21/2015	15:00	1	89	89	Unknown	Other			II
5048927	C36002	06/21/2015	13:31	06/21/2015	14:35	8	508	63	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	III
5048943	J61114	06/21/2015	13:52	06/21/2015	15:10	1	77	77	Overhead equipment				III
5048945	R33127	06/21/2015	13:53	06/21/2015	14:51	1	57	57	Tree related-tree broken	Tree			I
5048947	K52401	06/21/2015	13:55	06/21/2015	18:04	8	1989	248	Underground equipment	Underground Secondary	Patrol/Test/Inspect	Repair	V
5048949	Q16868	06/21/2015	13:56	06/21/2015	15:07	1	70	70	Animal related	Transformer Fuse	Replace - Same Size		V
5049139	B84005	06/21/2015	14:06	06/21/2015	20:17	633	234304	370	Underground equipment	Underground Primary	Patrol/Test/Inspect	Reconnect	I
5048957	Q32170	06/21/2015	14:14	06/21/2015	16:16	1	122	121	Tree related-tree broken	Transformer Fuse	Replace - Same Size	Repair	I
5048961	L14232	06/21/2015	14:22	06/21/2015	15:19	1	56	56	Tree related-tree contact	Overhead Service	Repair		III
5049001	S62520	06/21/2015	14:26	06/21/2015	15:30	654	41712	63	Tree related-tree broken	Recloser			VI
5048973	B93002	06/21/2015	14:27	06/21/2015	15:22	1	54	54	Weather	Fuse	Replace - Same Size		I
5049005	K69117	06/21/2015	14:30	06/21/2015	20:15	1	344	344	Underground equipment	Underground Secondary	Patrol/Test/Inspect	Repair	IV
5049011	S62520	06/21/2015	14:35	06/21/2015	15:50	1	74	74	Tree related-tree broken	Tree			VI
5049013	E10001	06/21/2015	14:39	06/21/2015	16:12	1	92	92	Underground equipment	Fuse	Replace - Same Size	Repair	III
5049019	K09864	06/21/2015	14:41	06/21/2015	15:40	80	4685	58	Weather	Fuse	Replace - Same Size	Repair	V
5049043	N67309	06/21/2015	15:15	06/21/2015	17:08	1	112	112	Other	Other			I
5049051	Q63835	06/21/2015	15:33	06/21/2015	20:42	1	308	308	Weather	Pole	Replace - New Size	Replace - New Size	V
5049053	P74-UNIT-1	06/21/2015	15:36	06/21/2015	21:36	1	359	359	Overhead equipment	Fuse		Replace - Same Size	VI
5049057	R58951	06/21/2015	15:37	06/21/2015	17:05	85	7406	87	Weather	Fuse	Replace - Same Size		IV
5049063	L11241	06/21/2015	15:47	06/21/2015	17:24	1	96	96	Tree related-tree contact	Overhead Service	Reconnect		III
5049069	U12540	06/21/2015	16:10	06/21/2015	17:40	74	6725	90	Weather	Fuse	Repair	Replace - Same Size	II
5049077	Q01282	06/21/2015	16:25	06/21/2015	17:05	9	358	39	Weather				III
5049081	U60518	06/21/2015	16:30	06/21/2015	19:22	15	2570	171	Tree related-tree contact	Tree	Remove		II
5049089	Y28597	06/21/2015	16:53	06/21/2015	19:00	1	126	126	Weather	Fuse	Replace - Same Size	Repair	IV
5049099	S07536	06/21/2015	17:01	06/21/2015	23:11	90	33282	369	Tree related-tree broken	Crossarm	Patrol/Test/Inspect	Replace - New Size	VI
5049097	S24598	06/21/2015	17:03	06/21/2015	18:50	12	1272	106	Overhead equipment	Fuse		Replace - Same Size	VI
5049103	R33127	06/21/2015	17:06	06/21/2015	18:28	1	81	81	Unknown	Other			I
5049107	Y51506	06/21/2015	17:16	06/21/2015	18:20	21	1342	63	Overhead equipment	Fuse	Replace - Same Size		IV
5049147	U93507	06/21/2015	17:34	06/21/2015	20:10	1	155	155	Tree related-tree broken	Overhead Service	Repair	Repair	II
5049157	U54503	06/21/2015	17:40	06/21/2015	17:46	101	590	5	Tree related-tree contact	Tree	Trim		II
5049163	S07536	06/21/2015	17:47	06/21/2015	19:11	1	83	83	Tree related-tree broken	Overhead Service	Patrol/Test/Inspect	Repair	VI
5049165	K43382	06/21/2015	17:55	06/21/2015	20:07	1	131	131	Public	Underground Service	Repair	Repair	V
5049167	H22346	06/21/2015	17:56	06/21/2015	21:41	1	224	224	Underground equipment	Underground Service	Patrol/Test/Inspect	Repair	V
5049171	S25551	06/21/2015	18:03	06/21/2015	19:39	1	95	95	Overhead equipment	Fuse		Replace - Same Size	VI
5049173	T14576	06/21/2015	18:06	06/21/2015	20:50	5	816	163	Overhead equipment	Transformer Fuse	Repair	Repair	VI
5049175	M04364	06/21/2015	18:09	06/21/2015	20:32	6	854	142	Tree related-tree broken	Overhead Service	Patrol/Test/Inspect	Repair	V
5049189	M04364	06/21/2015	18:24	06/21/2015	20:43	1	138	138	Tree related-tree broken	Overhead Service	Patrol/Test/Inspect	Repair	V
5049179	T14576	06/21/2015	18:26	06/21/2015	20:50	1	143	143	Overhead equipment	Transformer Fuse	Repair	Repair	VI
5049181	K62102	06/21/2015	18:28	06/21/2015	19:57	31	2758	88	Overhead equipment	Overhead Primary	Patrol/Test/Inspect	Repair	II
5049185	314167	06/21/2015	18:29	06/21/2015	19:26	1	57	56	Overhead equipment	Overhead Service	Repair	Replace - New Size	V
5049193	Q01282	06/21/2015	18:43	06/21/2015	23:05	9	2355	261	Weather	Overhead Transformer		Replace - Same Size	III
5049197	S42579	06/21/2015	19:03	06/21/2015	20:50	1	106	106	Tree related-tree broken	Other			VI
5049207	Y55555	06/21/2015	19:35	06/21/2015	20:47	1	71	71	Weather	Overhead Service	Repair		IV
5049211	Q32170	06/21/2015	19:41	06/22/2015	3:30	1	468	468	Tree related-tree broken				I

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5049213	D87001	06/21/2015	19:47	06/22/2015	11:12	1	924	924	Tree related-tree contact	Customer Equipment	Patrol/Test/Inspect		I
5049217	K15207	06/21/2015	20:12	06/22/2015	2:03	1	350	350	Overhead equipment	Overhead Service	Repair		VI
5049219	S07535	06/21/2015	20:12	06/21/2015	21:00	1	47	47	Overhead equipment	Fuse	Patrol/Test/Inspect	Repair	VI
5049231	S66590	06/21/2015	20:25	06/22/2015	0:35	1	249	249	Underground equipment	Underground Service	Patrol/Test/Inspect	Repair	VI
5049233	Q16867	06/21/2015	20:27	06/21/2015	21:52	1	84	84	Tree related-tree broken				V
5049239	X16511	06/21/2015	20:45	06/21/2015	23:10	1	144	144	Overhead equipment				IV
5049241	K09863	06/21/2015	20:49	06/22/2015	0:29	7	1538	219	Overhead equipment	Transformer Fuse	Replace - Same Size	Replace - Same Size	V
5049247	S61529	06/21/2015	21:00	06/22/2015	0:28	68	10672	207	Underground equipment	Underground Primary	Switch/Reset	Repair	VI
5049253	S61529	06/21/2015	21:16	06/22/2015	0:45	1	208	208	Underground equipment				VI
5049255	Q32171	06/21/2015	21:26	06/22/2015	5:47	1	500	500	Tree related-tree contact	Fuse	Repair	Patrol/Test/Inspect	I
5049259	P07179	06/21/2015	21:43	06/21/2015	23:15	1	91	91	Tree related-tree contact	Fuse	Replace - Same Size		I
5049299	X60598	06/21/2015	23:08	06/22/2015	1:47	9	1422	158	Weather	Disconnect Switch	Replace - Same Size	Repair	IV
5049275	J07135	06/21/2015	23:23	06/22/2015	3:55	1	271	271	Other	Transformer Fuse	Replace - Same Size		I
5049287	Y36541	06/22/2015	0:09	06/22/2015	0:50	1	40	40	Weather	Fuse	Replace - Same Size		IV
5049293	X60595	06/22/2015	0:30	06/22/2015	1:31	6	363	60	Weather	Transformer Fuse	Replace - Same Size		IV
5049295	X60595	06/22/2015	0:32	06/22/2015	1:43	6	421	70	Weather	Transformer Fuse	Replace - Same Size		IV
5049301	Y86593	06/22/2015	1:44	06/22/2015	4:23	1	158	158	Weather	Overhead Transformer		Replace - Same Size	IV
5049303	Y35515	06/22/2015	2:03	06/22/2015	3:19	45	3395	75	Tree related-tree contact	Overhead Primary	Repair		IV
5049309	Y35515	06/22/2015	2:09	06/22/2015	3:19	59	4078	69	Tree related-tree contact	Overhead Primary	Replace - New Size		IV
5049311	X02546	06/22/2015	2:16	06/22/2015	4:10	1	113	113	Weather	Fuse	Repair		IV
5049313	X60598	06/22/2015	2:40	06/22/2015	3:38	5	290	58	Overhead equipment				IV
5049315	X24-XTR1	06/22/2015	3:04	06/22/2015	4:33	659	58802	89	Tree related-tree broken	Overhead Primary	Repair	Repair	IV
5049317	X23-XTR1	06/22/2015	3:04	06/22/2015	18:36	1370	509574	931	Overhead equipment				IV
5049319	Z08509	06/22/2015	3:28	06/22/2015	4:55	1	86	86	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
5049321	X60598	06/22/2015	3:38	06/22/2015	4:23	1	44	44	Overhead equipment	Overhead Primary	Repair		IV
5049323	Y61001	06/22/2015	3:47	06/22/2015	4:44	1	56	56	Weather				IV
5049329	J99121	06/22/2015	4:11	06/22/2015	12:17	8	3885	485	Underground equipment	Underground Primary		Repair	VI
5049337	Q37370	06/22/2015	4:49	06/22/2015	6:59	1	129	129	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	I
5049341	T14575	06/22/2015	4:53	06/22/2015	6:25	1	91	91	Overhead equipment	Transformer Fuse	Replace - Same Size	Replace - Same Size	VI
5049339	X23505	06/22/2015	4:53	06/22/2015	5:30	7	255	36	Overhead equipment	Overhead Primary			IV
5049343	X23505	06/22/2015	5:16	06/22/2015	5:30	1	13	13	Overhead equipment	Overhead Primary	Repair	Patrol/Test/Inspect	IV
5049419	J87120	06/22/2015	6:13	06/22/2015	8:10	1	116	116	Unknown				VI
5049463	X23505	06/22/2015	6:22	06/22/2015	9:25	26	4756	182	Overhead equipment	Overhead Primary	Repair	Patrol/Test/Inspect	IV
5049445	K89142	06/22/2015	6:36	06/22/2015	7:21	1	44	44	Animal related	Fuse	Replace - Same Size		III
5049451	Y51505	06/22/2015	6:55	06/22/2015	7:30	6	209	34	Overhead equipment	Fuse	Replace - Same Size		IV
5049455	Y89541	06/22/2015	6:58	06/22/2015	12:10	1	312	312	Underground equipment	Underground Transformer	Repair	Replace - Same Size	IV
5049457	J87150	06/22/2015	6:58	06/22/2015	7:03	373	2077	5	Animal related				VI
5049465	P69174	06/22/2015	7:03	06/22/2015	8:32	1	88	88	Weather	Fuse	Replace - Same Size		III
5049467	B38001	06/22/2015	7:03	06/22/2015	9:45	1	161	161	Tree related-tree broken	Tree	Remove	Remove	I
5049473	J75272	06/22/2015	7:07	06/22/2015	8:20	1	72	72	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
5049477	B84002	06/22/2015	7:15	06/22/2015	9:11	36	4150	115	Animal related	Fuse	Replace - Same Size		I
5049479	J87150	06/22/2015	7:19	06/22/2015	8:57	1	97	97	Overhead equipment				VI
5049481	J87150	06/22/2015	7:21	06/22/2015	7:41	4	78	19	Overhead equipment	Transformer Fuse			VI
5049489	P20930	06/22/2015	7:29	06/22/2015	8:25	289	16415	56	Overhead equipment				VI
5049373	P20930	06/22/2015	7:29	06/22/2015	8:25	290	16205	55	Overhead equipment	Overhead Primary	Repair		VI
5049491	R59415	06/22/2015	7:35	06/22/2015	8:47	1	71	71	Animal related	Transformer Fuse	Replace - Same Size		IV
5049495	L35137	06/22/2015	7:41	06/22/2015	9:05	6	498	83	Animal related	Fuse	Repair		III
5049501	X64501	06/22/2015	7:48	06/22/2015	9:20	1	91	91	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
5049505	C52001	06/22/2015	7:56	06/22/2015	9:12	1	75	75	Other				III
5049507	R09226	06/22/2015	7:56	06/22/2015	9:01	7	448	64	Overhead equipment	Fuse		Replace - Same Size	III
5049513	V46552	06/22/2015	8:00	06/22/2015	12:16	1	255	255	Weather	Underground Transformer		Replace - Same Size	II
5049517	K31120	06/22/2015	8:14	06/22/2015	9:50	7	676	96	Underground equipment	Underground Primary	Disconnect	Repair	I
5049519	X02549	06/22/2015	8:14	06/22/2015	9:16	1	61	61	Animal related	Transformer Fuse	Replace - Same Size		IV
5049521	P19395	06/22/2015	8:15	06/22/2015	9:24	1	68	68	Weather	Fuse	Replace - Same Size		V
5049523	R09226	06/22/2015	8:16	06/22/2015	9:02	1	45	45	Overhead equipment				III
5049529	347001	06/22/2015	8:18	06/22/2015	10:34	4	543	135	Public	Pole	Patrol/Test/Inspect		VI

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5049535	V65549	06/22/2015	8:25	06/22/2015	12:49	1	263	263	Unknown	Transformer Fuse	Replace - Same Size		II
5049553	R48165	06/22/2015	8:31	06/22/2015	13:18	1	286	286	Overhead equipment	Overhead Transformer	Replace - Same Size		IV
5049555	C10002	06/22/2015	8:34	06/22/2015	9:11	1	36	36	Animal related	Fuse	Replace - Same Size	Patrol/Test/Inspect	III
5049569	L35282	06/22/2015	8:46	06/22/2015	10:15	1	88	88	Tree related-tree contact	Overhead Service	Repair		III
5049585	L74193	06/22/2015	9:01	06/22/2015	9:43	1	41	41	Overhead equipment	Fuse	Replace - Same Size		IV
5049587	R23334	06/22/2015	9:03	06/22/2015	11:38	1	154	154	Overhead equipment				V
5049589	J84145	06/22/2015	9:03	06/22/2015	11:13	1	129	129	Overhead equipment	Transformer Fuse	Replace - Same Size		VI
5049607	N72240	06/22/2015	9:25	06/22/2015	11:30	1	124	124	Overhead equipment	Overhead Service		Repair	III
5049611	N86226	06/22/2015	9:35	06/22/2015	12:51	1	195	195	Tree related-tree contact	Overhead Service	Patrol/Test/Inspect	Repair	VI
5049737	U35554	06/22/2015	9:40	06/22/2015	11:03	703	58257	82	Tree related-tree contact	Tree	Trim		II
5049657	M31204	06/22/2015	9:48	06/22/2015	10:38	1	49	49	Overhead equipment	Overhead Secondary	Repair		I
5049681	J07173	06/22/2015	9:59	06/22/2015	11:29	1	89	89	Weather	Transformer Fuse	Replace - Same Size	Replace - Same Size	I
5049685	U10002	06/22/2015	10:04	06/22/2015	12:35	1	150	150	Tree related-tree broken	Tree	Trim	Patrol/Test/Inspect	II
5049699	310122	06/22/2015	10:08	06/22/2015	11:21	1	72	72	Overhead equipment	Overhead Service	Repair	Replace - New Size	V
5049701	X09594	06/22/2015	10:09	06/22/2015	12:30	1	140	140	Overhead equipment	Fuse	Replace - Same Size		IV
5049709	B93002	06/22/2015	10:24	06/22/2015	11:59	1	94	94	Unknown	Overhead Primary	Patrol/Test/Inspect		I
5049715	B93002	06/22/2015	10:48	06/22/2015	12:28	1	99	99	Animal related	Fuse	Replace - Same Size	Replace - Same Size	I
5049729	M40131	06/22/2015	10:55	06/22/2015	15:09	5	1271	254	Tree related-tree broken	Overhead Service			I
5049741	Q82906	06/22/2015	11:04	06/22/2015	11:21	1	16	16	Other				VI
5049747	L70127	06/22/2015	11:19	06/22/2015	12:55	1	95	95	Overhead equipment				IV
5049751	S07536	06/22/2015	11:21	06/22/2015	12:52	3	271	90	Public	Overhead Service	Repair	Repair	VI
5049765	X92508	06/22/2015	11:32	06/22/2015	13:00	1	87	87	Overhead equipment	Overhead Service	Repair	Replace - Same Size	IV
5049775	L68111	06/22/2015	11:43	06/22/2015	13:48	1	124	124	Underground equipment	Underground Service			IV
5049791	P62112	06/22/2015	11:55	06/22/2015	13:12	1	76	76	Other				VI
5049793	B76001	06/22/2015	11:56	06/22/2015	14:35	2	317	158	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	I
5049799	B68003	06/22/2015	12:09	06/22/2015	14:30	9	1265	140	Tree related-tree broken	Overhead Primary	Patrol/Test/Inspect	Repair	III
5049803	U92593	06/22/2015	12:17	06/22/2015	13:25	1	67	67	Overhead equipment	Overhead Service	Repair	Repair	II
5049809	N22295	06/22/2015	12:29	06/22/2015	14:03	1	93	93	Animal related	Transformer Fuse			VI
5049833	A56013	06/22/2015	12:43	06/22/2015	13:55	1	71	71	Animal related	Fuse			I
5049835	V42572	06/22/2015	12:44	06/22/2015	14:12	10	875	87	Public	Underground Primary	Repair		II
5049947	P07179	06/22/2015	13:20	06/22/2015	20:26	3	1278	426	Tree related-tree broken	Overhead Primary	Cut in Clear	Repair	I
5049873	L24124	06/22/2015	13:26	06/22/2015	14:55	1	88	88	Overhead equipment	Overhead Service	Repair		III
5049875	N35852	06/22/2015	13:27	06/22/2015	13:55	1	27	27	Overhead equipment	Fuse	Replace - Same Size		V
5049877	D37003	06/22/2015	13:28	06/22/2015	15:55	7	1028	146	Tree related-tree broken	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	I
5049879	HC9325	06/22/2015	13:29	06/22/2015	15:58	2	297	148	Overhead equipment				VI
5049893	E10002	06/22/2015	13:30	06/22/2015	16:07	7	1096	156	Overhead equipment	Pole	Patrol/Test/Inspect	Replace - Same Size	III
5049883	C52001	06/22/2015	13:32	06/22/2015	14:07	1	34	34	Other				III
5049887	X92507	06/22/2015	13:34	06/22/2015	14:15	1	40	40	Overhead equipment	Jumper	Repair	Replace - Same Size	IV
5049889	B19002	06/22/2015	13:39	06/22/2015	15:57	1	137	137	Animal related	Fuse	Replace - Same Size		I
5049909	K09863	06/22/2015	14:02	06/22/2015	15:26	1	83	83	Tree related-tree broken	Overhead Secondary	Remove	Repair	V
5049925	K07320	06/22/2015	14:33	06/22/2015	16:30	1	116	116	Other	Other			I
5049933	Y63527	06/22/2015	14:37	06/22/2015	15:46	1	68	68	Tree related-tree broken	Overhead Secondary	Replace - Same Size		IV
5049935	B28006	06/22/2015	14:39	06/22/2015	16:42	1	122	122	Unknown				I
5049937	J63172	06/22/2015	14:40	06/22/2015	16:18	1	97	97	Tree related-tree contact	Overhead Secondary			III
5049939	L43153	06/22/2015	14:41	06/22/2015	15:34	2	107	53	Weather	Fuse	Replace - Same Size		I
5049945	K09863	06/22/2015	14:44	06/22/2015	15:31	1	46	46	Tree related-tree broken	Transformer Fuse	Replace - Same Size	Repair	V
5049949	P58155	06/22/2015	14:52	06/22/2015	15:49	1	56	56	Intentional				VI
5049951	Y63527	06/22/2015	14:52	06/22/2015	15:47	1	54	54	Tree related-tree broken	Overhead Service			IV
5049953	D66002	06/22/2015	15:01	06/22/2015	15:42	1	40	40	Public				IV
5049955	A73002	06/22/2015	15:05	06/22/2015	20:16	1	310	310	Unknown	Pole	Replace - Same Size	Repair	I
5049959	R34920	06/22/2015	15:10	06/22/2015	21:48	1	397	397	Tree related-tree broken	Pole	Replace - Same Size	Repair	VI
5049969	J08205	06/22/2015	15:16	06/22/2015	16:15	106	6208	58	Tree related-tree broken	Fuse	Replace - Same Size		I
5049975	Y06546	06/22/2015	15:21	06/22/2015	17:05	1	103	103	Tree related-tree broken	Overhead Service			IV
5049987	N67309	06/22/2015	15:35	06/22/2015	15:56	1	20	20	Overhead equipment	Overhead Primary			I
5049989	N86225	06/22/2015	15:44	06/22/2015	21:47	6	2174	362	Overhead equipment	Overhead Transformer	Disconnect	Replace - Same Size	VI
5049995	J84124	06/22/2015	15:51	06/22/2015	18:40	1	168	168	Underground equipment	Underground Secondary		Repair	VI

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5050009	W01528	06/22/2015	16:03	06/22/2015	17:07	1	63	63	Animal related	Transformer Fuse	Replace - Same Size		II
5050011	A48005	06/22/2015	16:04	06/22/2015	19:00	17	2982	175	Tree related-tree contact	Overhead Secondary	Repair	Repair	I
5050025	B25002	06/22/2015	16:13	06/22/2015	18:20	1	126	126	Other				I
5050051	B25002	06/22/2015	16:17	06/22/2015	18:24	1	126	126	Other				I
5050059	R06211	06/22/2015	16:35	06/22/2015	19:37	1	181	181	Tree related-tree contact	Overhead Secondary	Replace - New Size	Replace - New Size	II
5050063	K80388	06/22/2015	16:39	06/22/2015	17:30	2	100	50	Public	Underground Primary	Switch/Reset	Repair	IV
5050071	P57104	06/22/2015	16:47	06/22/2015	17:06	1	18	18	Intentional				VI
5050085	Z06538	06/22/2015	17:24	06/22/2015	18:50	1	85	85	Overhead equipment				IV
5050089	J06168	06/22/2015	17:31	06/22/2015	18:38	1	66	66	Animal related	Transformer Fuse	Replace - Same Size	Patrol/Test/Inspect	I
5050093	K48381	06/22/2015	17:39	06/22/2015	21:40	1	240	240	Overhead equipment	Overhead Transformer	Replace - Same Size	Advise Customer	V
5050095	K67924	06/22/2015	17:39	06/22/2015	18:49	1	69	69	Overhead equipment	Fuse	Replace - Same Size	Patrol/Test/Inspect	VI
5050111	Y20002	06/22/2015	17:53	06/22/2015	19:53	1	119	119	Tree related-tree broken	Tree	Remove		IV
5050117	N86225	06/22/2015	17:58	06/22/2015	22:29	1	270	270	Weather	Overhead Service	Patrol/Test/Inspect	Replace - Same Size	VI
5050123	M31204	06/22/2015	18:19	06/22/2015	20:14	1	114	114	Overhead equipment	Connector	Replace - Same Size	Replace - Same Size	I
5050127	M21134	06/22/2015	18:23	06/23/2015	1:30	1	426	426	Underground equipment	Underground Service	Patrol/Test/Inspect	Repair	VI
5050129	303006	06/22/2015	18:27	06/22/2015	19:45	1	77	77	Tree related-tree contact	Tree	Trim		VI
5050131	T59902	06/22/2015	18:32	06/22/2015	19:44	1	71	71	Overhead equipment	Fuse	Replace - Same Size	Patrol/Test/Inspect	VI
5050137	J33803	06/22/2015	18:34	06/22/2015	19:45	58	4106	70	Overhead equipment	Fuse	Repair	Repair	V
5050135	D81002	06/22/2015	18:34	06/22/2015	21:45	1	190	190	Overhead equipment	Overhead Service	Replace - Same Size	Replace - Same Size	I
5050139	D90004	06/22/2015	18:43	06/22/2015	19:20	1	36	36	Overhead equipment	Disconnect Switch	Replace - Same Size	Repair	III
5050141	S61531	06/22/2015	18:45	06/22/2015	19:25	1	39	39	Overhead equipment	Transformer Fuse	Replace - Same Size		VI
5050147	P58154	06/22/2015	18:53	06/22/2015	21:37	2	327	163	Tree related-tree broken	Overhead Primary	Reconnect	Reconnect	VI
5050151	U62510	06/22/2015	18:59	06/22/2015	21:55	1	175	175	Tree related-tree broken	Overhead Service	Raise		II
5050155	Q70161	06/22/2015	19:07	06/22/2015	19:42	1	34	34	Weather	Transformer Fuse	Replace - Same Size		I
5050157	U30003	06/22/2015	19:21	06/22/2015	20:04	9	383	42	Overhead equipment	Transformer Fuse	Replace - Same Size		II
5050169	X95003	06/22/2015	19:26	06/22/2015	21:35	106	13571	128	Overhead equipment	Fuse		Replace - Same Size	IV
5050163	R42914	06/22/2015	19:27	06/22/2015	20:17	5	248	49	Overhead equipment	Fuse	Replace - Same Size	Patrol/Test/Inspect	VI
5050173	X95003	06/22/2015	19:27	06/22/2015	21:47	18	2502	139	Overhead equipment	Fuse		Replace - Same Size	IV
5050185	K39156	06/22/2015	19:42	06/22/2015	20:46	1	63	63	Overhead equipment	Connector	Replace - Same Size		III
5050213	K89143	06/22/2015	20:03	06/22/2015	22:57	367	63619	173	Tree related-tree broken	Tree	Patrol/Test/Inspect	Remove	III
5050199	U60559	06/22/2015	20:04	06/22/2015	21:10	2	130	65	Animal related	Fuse	Replace - Same Size		II
5050215	K89143	06/22/2015	20:07	06/22/2015	23:00	1	172	172	Tree related-tree broken	Tree	Remove		III
5050259	V69546	06/22/2015	20:33	06/23/2015	2:40	194	54436	367	Tree related-tree broken	Tree	Trim		II
5050283	N70332	06/22/2015	20:52	06/22/2015	21:36	1	43	43	Other	Other			I
5051027	R95520	06/22/2015	20:59	06/23/2015	3:20	73	27770	380	Weather	Recloser	Switch/Reset		I
5050389	N70332	06/22/2015	21:10	06/22/2015	22:30	11	870	79	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	I
5051037	R95520	06/22/2015	21:14	06/23/2015	4:35	4	1762	440	Tree related-tree contact	Overhead Primary			I
5050313	K89143	06/22/2015	21:14	06/22/2015	23:00	1	105	105	Tree related-tree broken	Tree	Remove		III
5050415	Q14392	06/22/2015	21:15	06/23/2015	6:18	26	14093	542	Overhead equipment	Pole	Replace - Same Size	Repair	I
5050375	R95520	06/22/2015	21:24	06/23/2015	3:04	52	17659	339	Other	Recloser	Switch/Reset		I
5050333	Q14392	06/22/2015	21:25	06/22/2015	23:32	15	1893	126	Tree related-tree contact	Fuse	Patrol/Test/Inspect	Repair	I
5050337	R95520	06/22/2015	21:26	06/23/2015	4:30	1	423	423	Weather	Transformer Fuse	Repair	Repair	I
5050339	V46563	06/22/2015	21:28	06/23/2015	4:14	3	1216	405	Tree related-tree broken	Overhead Primary	Repair	Repair	II
5050355	Q37370	06/22/2015	21:32	06/23/2015	2:10	1	277	277	Weather	Transformer Fuse	Replace - Same Size	Repair	I
5050379	V40556	06/22/2015	21:37	06/23/2015	2:25	21	6034	287	Tree related-tree contact	Fuse			II
5050385	Q36410	06/22/2015	21:44	06/23/2015	1:11	45	9305	206	Weather	Fuse	Replace - Same Size	Replace - Same Size	I
5050387	U92593	06/22/2015	21:44	06/23/2015	1:45	1	240	240	Tree related-tree broken	Overhead Service	Repair	Repair	II
5050399	V45526	06/22/2015	21:51	06/23/2015	3:27	10	3352	335	Tree related-tree contact	Fuse			II
5050401	U93001	06/22/2015	21:53	06/22/2015	23:50	1	116	116	Tree related-tree broken	Overhead Service	Repair	Repair	II
5050403	U93001	06/22/2015	22:07	06/22/2015	23:50	1	102	102	Tree related-tree broken	Overhead Service	Repair	Repair	II
5050405	V40556	06/22/2015	22:19	06/23/2015	5:09	2	819	409	Tree related-tree contact	Overhead Transformer	Repair	Repair	II
5050407	V20512	06/22/2015	22:19	06/23/2015	7:49	1	569	569	Underground equipment	Underground Primary			II
5050419	R95520	06/22/2015	22:19	06/23/2015	3:00	1	280	280	Weather	Disconnect Switch	Repair	Repair	I
5050413	U30003	06/22/2015	22:23	06/23/2015	8:07	9	5255	583	Overhead equipment	Overhead Transformer	Repair		II
5050417	R95520	06/22/2015	22:34	06/23/2015	4:09	1	334	334	Weather	Fuse	Replace - Same Size		I
5050423	V20512	06/22/2015	22:42	06/23/2015	7:48	1	545	545	Underground equipment				II

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5050425	A17021	06/22/2015	22:47	06/22/2015	23:20	14	459	32	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	I
5050431	HB5890	06/22/2015	23:03	06/23/2015	1:15	1	131	131	Weather	Fuse			I
5050435	U64521	06/22/2015	23:19	06/23/2015	10:07	1	647	647	Tree related-tree broken	Overhead Service	Repair		II
5050437	V01001	06/22/2015	23:23	06/23/2015	11:00	1	696	696	Overhead equipment	Overhead Primary			II
5051013	N93260	06/22/2015	23:27	06/23/2015	2:04	6	923	156	Tree related-tree broken	Fuse	Replace - Same Size	Replace - Same Size	III
5051015	N93260	06/22/2015	23:28	06/23/2015	1:32	12	1481	123	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	III
5050759	Y96-XTR1	06/22/2015	23:45	06/23/2015	0:54	924	63598	68	Animal related				IV
5050621	Z17-XTR1	06/22/2015	23:46	06/23/2015	0:53	1165	78555	67	Animal related				IV
5050875	Z41528	06/22/2015	23:46	06/23/2015	0:54	945	63882	67	Animal related	Substation Breaker			IV
5050665	X60-XTR1	06/22/2015	23:46	06/23/2015	0:53	1395	93423	66	Animal related				IV
5050877	X60597	06/22/2015	23:48	06/23/2015	0:54	683	45098	66	Animal related				IV
5051003	R95520	06/23/2015	0:04	06/23/2015	1:41	228	21967	96	Overhead equipment	Regulator	Remove		I
5050805	R95520	06/23/2015	0:05	06/23/2015	4:48	3	846	282	Weather				I
5050841	R95520	06/23/2015	0:09	06/23/2015	4:23	15	3800	253	Weather				I
5050983	Z41536	06/23/2015	0:29	06/23/2015	0:55	28	714	25	Animal related				IV
5051007	M45211	06/23/2015	0:59	06/23/2015	5:34	1	274	274	Overhead equipment	Overhead Transformer			IV
5051021	J86118	06/23/2015	2:03	06/23/2015	4:12	1	128	128	Overhead equipment	Fuse	Repair	Repair	VI
5051023	N93260	06/23/2015	2:04	06/23/2015	5:50	2	452	226	Overhead equipment	Overhead Primary	Repair		III
5051025	J86118	06/23/2015	2:13	06/23/2015	4:10	1	116	116	Overhead equipment	Fuse	Repair	Repair	VI
5051031	Q14392	06/23/2015	2:29	06/23/2015	6:00	1	210	210	Overhead equipment	Overhead Primary	Replace - Same Size	Replace - Same Size	I
5051033	Q47833	06/23/2015	2:36	06/23/2015	3:58	9	732	81	Overhead equipment	Pole	Repair		V
5051051	C66002	06/23/2015	2:43	06/23/2015	8:15	1	331	331	Overhead equipment	Tree	Trim		III
5051043	V20512	06/23/2015	3:25	06/23/2015	7:43	11	2829	257	Underground equipment				II
5051057	A17026	06/23/2015	5:12	06/23/2015	5:51	1	38	38	Tree related-tree broken	Overhead Service	Raise		I
5051067	D70004	06/23/2015	6:16	06/23/2015	7:33	47	3607	76	Animal related	Fuse	Replace - Same Size		I
5051065	R96-UNIT-1	06/23/2015	6:18	06/23/2015	13:12	1	413	413	Weather	Crossarm	Repair	Repair	I
5051069	P26284	06/23/2015	6:41	06/23/2015	8:20	1	98	98	Animal related	Fuse	Replace - Same Size	Replace - Same Size	I
5051071	R95520	06/23/2015	6:53	06/23/2015	8:35	1	101	101	Tree related-tree contact	Overhead Service	Repair		I
5051073	310123	06/23/2015	6:54	06/23/2015	9:08	1	133	133	Overhead equipment	Overhead Service	Repair		V
5051075	K27153	06/23/2015	7:14	06/23/2015	8:05	4	200	50	Overhead equipment	Transformer Fuse	Replace - Same Size	Replace - Same Size	VI
5051077	R53391	06/23/2015	7:16	06/23/2015	8:43	1	86	86	Underground equipment	Underground Service	Disconnect	Repair	V
5051081	V41527	06/23/2015	7:21	06/23/2015	7:49	1	27	27	Underground equipment				II
5051085	M37191	06/23/2015	7:33	06/23/2015	8:20	1	46	46	Overhead equipment	Transformer Fuse	Replace - Same Size	Replace - Same Size	I
5051087	B73002	06/23/2015	7:47	06/23/2015	11:15	1	208	207	Overhead equipment	Overhead Transformer	Replace - Same Size	Repair	I
5051089	K69116	06/23/2015	7:48	06/23/2015	8:31	1	42	42	Animal related	Fuse	Replace - Same Size		IV
5051099	K58213	06/23/2015	7:49	06/23/2015	12:10	19	4954	260	Overhead equipment	Overhead Primary	Patrol/Test/Inspect	Repair	VI
5051093	U68002	06/23/2015	7:50	06/23/2015	10:35	1	164	164	Overhead equipment	Connector	Repair		II
5051095	K76545	06/23/2015	7:51	06/23/2015	8:41	1	49	49	Jurisdictional				IV
5051101	N54214	06/23/2015	7:58	06/23/2015	10:15	1	137	137	Underground equipment	Underground Service	Install	Repair	II
5051203	Q93522	06/23/2015	8:17	06/23/2015	13:57	10	3393	339	Overhead equipment	Overhead Primary	Replace - Same Size		I
5051117	K69116	06/23/2015	8:21	06/23/2015	8:33	1	11	11	Animal related	Fuse	Replace - Same Size		IV
5051125	S86597	06/23/2015	8:29	06/23/2015	9:46	1	76	76	Other				VI
5051123	Q01282	06/23/2015	8:29	06/23/2015	14:27	1	357	357	Underground equipment	Underground Primary	Repair	Repair	III
5051127	V41527	06/23/2015	8:34	06/23/2015	10:28	1	113	113	Overhead equipment	Overhead Service	Repair	Repair	II
5051131	P53341	06/23/2015	8:36	06/23/2015	13:05	4	1075	268	Public	Fuse	Patrol/Test/Inspect	Replace - Same Size	IV
5051147	M09175	06/23/2015	8:36	06/23/2015	10:08	20	1820	91	Overhead equipment	Disconnect Switch	Replace - Same Size	Replace - Same Size	VI
5051137	P53341	06/23/2015	8:41	06/23/2015	10:54	1	132	132	Public	Pole	Patrol/Test/Inspect	Replace - Same Size	IV
5051141	Q23258	06/23/2015	8:42	06/23/2015	10:59	1	136	136	Underground equipment	Underground Service			VI
5051153	R95520	06/23/2015	8:49	06/23/2015	12:20	7	346	210	Weather	Crossarm	Repair	Repair	I
5051171	V35001	06/23/2015	9:09	06/23/2015	11:30	1	140	140	Tree related-tree contact	Overhead Service	Patrol/Test/Inspect	Repair	II
5051179	X57001	06/23/2015	9:34	06/23/2015	10:16	1	41	41	Overhead equipment	Connector	Replace - New Size		IV
5051185	U01514	06/23/2015	9:48	06/23/2015	17:05	1	436	436	Overhead equipment	Overhead Service	Repair	Repair	II
5051187	N70332	06/23/2015	9:49	06/23/2015	10:13	1	23	23	Weather	Transformer Fuse	Replace - Same Size		I
5051207	R05114	06/23/2015	10:20	06/23/2015	10:54	1	33	33	Other	Overhead Service			I
5051215	V92542	06/23/2015	10:27	06/23/2015	15:45	1	317	317	Tree related-tree broken	Overhead Secondary	Repair	Repair	II
5051221	J34377	06/23/2015	10:29	06/23/2015	10:32	38	99	2	Unknown				V

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5051227	329147	06/23/2015	10:36	06/23/2015	12:12	5	476	95	Overhead equipment	Fuse	Replace - Same Size		V
5051229	T15570	06/23/2015	10:36	06/23/2015	17:00	1	383	383	Underground equipment	Underground Service	Repair	Repair	VI
5051233	F10002	06/23/2015	10:41	06/23/2015	11:23	1	41	41	Overhead equipment	Transformer Fuse	Replace - Same Size		III
5051235	Q27185	06/23/2015	10:42	06/23/2015	11:33	1	50	50	Animal related	Transformer Fuse	Replace - Same Size		VI
5051243	A85001	06/23/2015	10:57	06/23/2015	12:47	1	109	109	Unknown	Fuse	Replace - Same Size		I
5051245	A17026	06/23/2015	10:58	06/23/2015	12:34	12	1143	95	Public	Overhead Secondary	Patrol/Test/Inspect	Patrol/Test/Inspect	I
5051255	K58213	06/23/2015	11:14	06/23/2015	12:10	74	4092	55	Overhead equipment	Overhead Primary	Patrol/Test/Inspect	Repair	VI
5051257	U35511	06/23/2015	11:19	06/23/2015	13:22	1	122	122	Overhead equipment	Overhead Service	Repair		II
5051275	D67001	06/23/2015	11:36	06/23/2015	18:06	6	2145	390	Underground equipment	Underground Primary	Repair		IV
5051281	C40002	06/23/2015	11:36	06/23/2015	14:07	91	13663	150	Unknown	Underground Primary	Repair	Repair	I
5051283	Q83149	06/23/2015	11:47	06/23/2015	12:30	6	256	42	Unknown	Transformer Fuse	Replace - Same Size	Replace - Same Size	VI
5051285	Q93522	06/23/2015	11:55	06/23/2015	13:57	4	484	121	Overhead equipment	Overhead Primary	Replace - Same Size		I
5051287	V40556	06/23/2015	11:56	06/23/2015	13:42	1	105	105	Tree related-tree contact	Overhead Service	Repair		II
5051291	P62138	06/23/2015	12:10	06/23/2015	15:00	1	169	169	Overhead equipment	Overhead Transformer	Repair	Replace - Same Size	VI
5051303	348116	06/23/2015	12:19	06/23/2015	13:37	1	77	77	Overhead equipment	Overhead Service	Repair		V
5051311	K48384	06/23/2015	12:26	06/23/2015	13:17	1	50	50	Overhead equipment	Overhead Service	Repair		V
5051315	R58961	06/23/2015	12:35	06/23/2015	13:46	33	2340	70	Underground equipment	Underground Primary	Switch/Reset	Repair	IV
5051321	U09517	06/23/2015	12:43	06/23/2015	13:58	1	74	74	Weather	Transformer Fuse	Replace - Same Size		II
5051333	M54316	06/23/2015	12:55	06/23/2015	17:06	1	250	250	Overhead equipment	Overhead Transformer		Replace - Same Size	V
5051355	A26002	06/23/2015	13:21	06/23/2015	14:40	1	78	78	Overhead equipment				I
5051361	L35283	06/23/2015	13:26	06/23/2015	14:28	1	61	61	Tree related-tree contact	Overhead Service	Repair		III
5051363	J01118	06/23/2015	13:27	06/23/2015	16:00	1	152	152	Public	Guy Wire	Cut in Clear		I
5051369	R95520	06/23/2015	13:34	06/23/2015	16:45	1	190	190	Weather	Overhead Transformer			I
5051371	M47802	06/23/2015	13:38	06/23/2015	15:50	18	2376	131	Overhead equipment	Fuse	Repair	Repair	V
5051503	N22295	06/23/2015	13:50	06/23/2015	15:20	473	42272	89	Substation equipment				VI
5051387	N22296	06/23/2015	13:52	06/23/2015	15:25	286	26432	92	Overhead equipment	Fuse		Patrol/Test/Inspect	VI
5051405	C40002	06/23/2015	13:58	06/23/2015	14:36	23	868	37	Underground equipment				I
5051453	M05360	06/23/2015	14:06	06/23/2015	15:20	1	73	73	Animal related	Transformer Fuse	Replace - Same Size		V
5051553	G10002	06/23/2015	14:13	06/23/2015	19:32	4	1275	318	Overhead equipment	Pole	Replace - Same Size		I
5051485	G10002	06/23/2015	14:16	06/23/2015	17:33	37	7274	196	Overhead equipment	Pole	Patrol/Test/Inspect	Replace - Urgent	I
5051513	N70330	06/23/2015	14:17	06/23/2015	15:32	1	74	74	Other	Overhead Service	Replace - Same Size	Replace - Same Size	I
5051529	U99593	06/23/2015	14:45	06/23/2015	17:00	7	944	134	Overhead equipment	Overhead Transformer	Replace - Same Size	Replace - Same Size	II
5051541	L50215	06/23/2015	14:58	06/23/2015	15:14	3	47	15	Overhead equipment	Overhead Transformer	Repair		VI
5051551	G10002	06/23/2015	15:20	06/23/2015	19:33	1	252	252	Overhead equipment	Pole	Replace - Same Size		I
5051557	P77237	06/23/2015	15:25	06/23/2015	15:55	1	29	29	Overhead equipment	Substation Transformer	Switch/Reset		VI
5051559	U01523	06/23/2015	15:25	06/23/2015	17:36	1	130	130	Overhead equipment	Overhead Transformer	Replace - Same Size	Replace - Same Size	II
5051575	B68003	06/23/2015	15:41	06/23/2015	16:55	1	73	73	Overhead equipment	Fuse	Replace - Same Size		III
5051577	R33127	06/23/2015	15:44	06/24/2015	1:14	1	569	569	Overhead equipment	Fuse	Repair	Replace - Same Size	I
5051587	Y57001	06/23/2015	16:03	06/23/2015	17:45	1	101	101	Tree related-tree contact	Overhead Service	Repair	Advise Customer	IV
5051627	K80381	06/23/2015	16:07	06/23/2015	17:07	18	1086	60	Underground equipment				IV
5051593	R95520	06/23/2015	16:09	06/23/2015	18:14	1	124	124	Weather	Overhead Transformer			I
5051597	K78352	06/23/2015	16:18	06/23/2015	18:02	1	103	103	Other				IV
5051619	B80002	06/23/2015	17:02	06/23/2015	22:44	1	341	341	Underground equipment	Overhead Primary	Repair		I
5051621	R42914	06/23/2015	17:06	06/23/2015	19:09	1	122	122	Tree related-tree broken	Overhead Service	Replace - New Size	Repair	VI
5051633	A91001	06/23/2015	17:20	06/23/2015	18:29	1	69	69	Tree related-tree broken	Overhead Service	Repair		I
5051637	P47120	06/23/2015	17:29	06/23/2015	18:51	1	81	81	Animal related	Transformer Fuse	Replace - Same Size	Replace - Same Size	I
5051639	C00002	06/23/2015	17:33	06/23/2015	19:06	2	185	92	Unknown	Fuse	Repair		I
5051651	Q93522	06/23/2015	18:01	06/23/2015	20:00	1	118	118	Tree related-tree contact	Overhead Service	Repair		I
5051657	R16511	06/23/2015	18:21	06/23/2015	18:54	9	294	32	Overhead equipment	Connector	Repair		I
5051659	P54828	06/23/2015	18:23	06/23/2015	20:07	1	103	103	Animal related	Transformer Fuse	Replace - Same Size		V
5051673	U13551	06/23/2015	18:40	06/23/2015	22:47	27	6656	246	Overhead equipment	Disconnect Switch	Replace - Same Size		II
5051675	S86594	06/23/2015	18:51	06/23/2015	20:30	1	98	98	Overhead equipment	Overhead Service	Replace - New Size		VI
5051781	J07-UNIT-1	06/23/2015	18:51	06/23/2015	21:47	1881	328062	176	Substation equipment	Substation Misc.			I
5051763	N70330	06/23/2015	18:59	06/23/2015	19:37	1	37	37	Other	Other			I
5051859	M40132	06/23/2015	20:30	06/24/2015	0:11	24	5316	221	Underground equipment	Underground Primary	Switch/Reset	Repair	I
5051865	J79305	06/23/2015	20:55	06/23/2015	21:50	5	270	54	Overhead equipment	Transformer Fuse	Replace - Same Size	Replace - Same Size	I

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5051869	N70331	06/23/2015	21:24	06/23/2015	22:58	1	93	93	Overhead equipment	Transformer Fuse	Replace - Same Size	Replace - Same Size	I
5051871	M05368	06/23/2015	21:43	06/23/2015	22:46	1	62	62	Tree related-tree broken	Overhead Service	Repair		V
5051889	J07173	06/23/2015	22:36	06/24/2015	1:00	9	1291	143	Overhead equipment	Transformer Fuse	Replace - Same Size		I
5051901	F03004	06/24/2015	0:10	06/24/2015	2:03	10	1123	112	Animal related	Recloser	Switch/Reset		III
5051899	F03004	06/24/2015	0:11	06/24/2015	1:59	1	107	107	Animal related	Recloser	Switch/Reset		III
5051905	F03004	06/24/2015	0:13	06/24/2015	2:04	29	3215	110	Animal related	Recloser	Switch/Reset		III
5051907	F03004	06/24/2015	0:15	06/24/2015	2:12	1	116	116	Animal related	Recloser	Switch/Reset		III
5051909	D88001	06/24/2015	0:24	06/24/2015	5:00	10	2759	275	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	I
5051919	B80001	06/24/2015	3:38	06/24/2015	6:32	3	378	173	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
5051933	K30204	06/24/2015	7:04	06/24/2015	9:13	1	128	128	Overhead equipment	Fuse	Replace - Same Size		III
5051939	K82202	06/24/2015	7:21	06/24/2015	8:26	4	259	64	Overhead equipment				III
5051941	K82202	06/24/2015	7:34	06/24/2015	8:25	1	50	50	Overhead equipment				III
5051959	P73182	06/24/2015	7:56	06/24/2015	9:07	1	70	70	Animal related	Fuse	Replace - Same Size		VI
5052097	N70332	06/24/2015	8:07	06/24/2015	9:45	44	4268	97	Overhead equipment	Crossarm	Replace - Same Size		I
5051977	B25002	06/24/2015	8:08	06/24/2015	12:50	1	281	281	Tree related-tree broken	Overhead Service	Repair		I
5051995	N70332	06/24/2015	8:10	06/24/2015	8:54	39	1705	43	Overhead equipment	Crossarm	Repair		I
5051993	B00001	06/24/2015	8:14	06/24/2015	12:17	1	242	242	Underground equipment	Disconnect Switch	Replace - Same Size		I
5051997	Y04504	06/24/2015	8:17	06/24/2015	9:27	8	557	69	Animal related	Fuse	Replace - Same Size		IV
5051999	B19002	06/24/2015	8:18	06/24/2015	9:55	1	96	96	Overhead equipment	Transformer Fuse	Replace - Same Size		I
5052001	U16500	06/24/2015	8:19	06/24/2015	11:56	102	12455	216	Weather	Disconnect Switch	Replace - Same Size	Repair	II
5052003	J07135	06/24/2015	8:19	06/24/2015	9:04	1	44	44	Overhead equipment	Transformer Fuse	Replace - Same Size	Patrol/Test/Inspect	I
5052233	B00001	06/24/2015	8:27	06/24/2015	12:17	8	1834	229	Underground equipment	Other	Replace - Same Size	Replace - Same Size	I
5052015	V69532	06/24/2015	8:33	06/24/2015	10:20	5	532	106	Unknown	Fuse	Replace - Same Size		II
5052017	H88104	06/24/2015	8:34	06/24/2015	10:00	535	46213	86	Weather	Substation Breaker	Switch/Reset		II
5052079	H88-X1	06/24/2015	8:36	06/24/2015	10:00	979	82940	84	Weather	Substation Breaker	Switch/Reset		II
5052027	B57001	06/24/2015	8:37	06/24/2015	9:37	5	295	59	Animal related	Transformer Fuse	Replace - Same Size		I
5222609	374052	06/24/2015	8:42	06/24/2015	9:45	25	1558	62	Substation equipment				VI
5052081	Q34360	06/24/2015	8:46	06/24/2015	10:06	2	159	79	Unknown	Fuse	Patrol/Test/Inspect	Repair	I
5052107	M40132	06/24/2015	8:53	06/24/2015	10:40	1	106	106	Animal related	Transformer Fuse	Replace - Same Size	Patrol/Test/Inspect	I
5052111	V69532	06/24/2015	9:02	06/24/2015	10:20	1	77	77	Unknown	Fuse	Replace - Same Size		II
5052115	N70332	06/24/2015	9:04	06/24/2015	10:23	1	78	78	Weather	Crossarm	Replace - Same Size		I
5052119	J56341	06/24/2015	9:05	06/24/2015	9:37	3	95	31	Animal related	Transformer Fuse	Repair	Repair	III
5052223	R48166	06/24/2015	9:06	06/24/2015	11:03	11	1291	117	Animal related	Fuse			IV
5052143	B00001	06/24/2015	9:08	06/24/2015	12:17	6	1131	188	Underground equipment	Other	Replace - Same Size	Replace - Same Size	I
5052129	374069	06/24/2015	9:10	06/24/2015	10:04	1	53	53	Overhead equipment	Jumper	Repair	Replace - Same Size	VI
5052133	V10551	06/24/2015	9:15	06/24/2015	10:30	8	594	74	Weather	Fuse	Replace - Same Size		II
5052157	K48384	06/24/2015	9:26	06/24/2015	10:04	624	23181	37	Overhead equipment	Lightning Arrestor	Replace - Same Size		V
5052293	R04407	06/24/2015	9:37	06/24/2015	10:49	33	2361	71	Overhead equipment	Underground Primary	Repair		V
5052325	U16500	06/24/2015	9:44	06/24/2015	15:27	1	343	343	Weather	Fuse			II
5052187	N94180	06/24/2015	9:48	06/24/2015	10:51	1	62	62	Unknown	Transformer Fuse	Replace - Same Size		I
5052215	N70332	06/24/2015	9:56	06/24/2015	10:40	1	43	43	Weather	Crossarm	Replace - Same Size		I
5052219	P07179	06/24/2015	10:01	06/24/2015	17:25	1	443	443	Tree related-tree contact	Overhead Primary	Repair		I
5052247	A45002	06/24/2015	10:24	06/24/2015	12:10	63	6670	105	Overhead equipment	Fuse	Replace - Same Size		I
5052257	A80001	06/24/2015	10:28	06/24/2015	11:40	1	71	71	Overhead equipment	Fuse	Replace - Same Size		I
5052277	Y45504	06/24/2015	10:40	06/24/2015	12:20	17	1698	99	Overhead equipment	Jumper	Repair		IV
5052281	T29561	06/24/2015	10:41	06/24/2015	14:54	1	253	253	Public	Underground Primary	Repair	Repair	VI
5052279	X30505	06/24/2015	10:41	06/24/2015	11:41	8	476	59	Animal related	Transformer Fuse	Replace - Same Size		IV
5052299	D87001	06/24/2015	10:57	06/24/2015	13:33	1	155	155	Tree related-tree contact	Overhead Service	Repair		I
5052305	Q24313	06/24/2015	11:04	06/24/2015	12:08	174	10080	64	Overhead equipment	Overhead Primary			VI
5052309	R48166	06/24/2015	11:13	06/24/2015	11:39	1	25	25	Animal related	Fuse			IV
5052313	Y20522	06/24/2015	11:29	06/24/2015	14:30	1	180	180	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	IV
5052319	R02120	06/24/2015	11:47	06/24/2015	16:15	1	267	267	Underground equipment	Underground Service	Repair	Repair	VI
5052345	N54214	06/24/2015	12:07	06/24/2015	14:10	7	860	122	Weather	Overhead Transformer	Replace - Same Size		II
5052347	U42512	06/24/2015	12:07	06/24/2015	14:15	6	766	127	Overhead equipment	Bracket	Repair		II
5052353	R07382	06/24/2015	12:12	06/24/2015	13:33	1	80	80	Unknown	Fuse	Patrol/Test/Inspect	Repair	I
5052361	343006	06/24/2015	12:27	06/24/2015	14:20	1	112	112	Overhead equipment	Overhead Service	Repair		VI

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5052363	P69174	06/24/2015	12:27	06/24/2015	13:31	1	63	63	Other	Overhead Service			III
5052373	D92002	06/24/2015	12:44	06/24/2015	14:55	42	5493	130	Tree related-tree contact	Fuse	Replace - Same Size		I
5052377	D92002	06/24/2015	12:49	06/24/2015	15:16	1	146	146	Overhead equipment	Fuse	Replace - Same Size		I
5052381	D31016	06/24/2015	13:01	06/24/2015	13:35	1	33	33	Overhead equipment	Fuse	Replace - Same Size	Repair	III
5052385	P73158	06/24/2015	13:05	06/24/2015	13:39	1	34	33	Overhead equipment	Overhead Secondary	Replace - Same Size		VI
5052387	Z11506	06/24/2015	13:05	06/24/2015	14:00	3	162	54	Overhead equipment	Pole	Repair	Replace - Same Size	IV
5052393	R07382	06/24/2015	13:10	06/24/2015	13:36	1	25	25	Unknown	Fuse	Patrol/Test/Inspect	Repair	I
5052407	D92002	06/24/2015	13:47	06/24/2015	15:23	65	4631	96	Overhead equipment	Disconnect Switch	Patrol/Test/Inspect	Replace - Same Size	I
5052409	Y51506	06/24/2015	13:52	06/24/2015	14:20	1	27	27	Animal related	Transformer Fuse	Replace - Same Size		IV
5052415	K39156	06/24/2015	13:59	06/24/2015	14:54	8	433	54	Animal related	Transformer Fuse	Replace - Same Size		III
5052423	K07320	06/24/2015	14:23	06/24/2015	15:19	1	55	55	Other	Other			I
5052425	D01002	06/24/2015	14:25	06/24/2015	16:16	1	110	110	Overhead equipment	Fuse	Repair	Replace - Same Size	I
5052433	A68001	06/24/2015	14:30	06/24/2015	15:55	1	84	84	Overhead equipment	Overhead Service	Repair		I
5052435	N86227	06/24/2015	14:31	06/24/2015	15:26	5	275	55	Tree related-tree contact	Fuse	Replace - Same Size		VI
5052439	E10001	06/24/2015	14:57	06/24/2015	17:15	17	2335	137	Unknown	Fuse	Replace - Same Size	Repair	III
5052505	R60551	06/24/2015	15:00	06/24/2015	16:30	35	3151	90	Underground equipment	Underground Primary	Switch/Reset	Repair	IV
5052453	R60551	06/24/2015	15:10	06/24/2015	16:32	1	81	81	Other				IV
5052461	M45212	06/24/2015	15:31	06/24/2015	17:27	1	115	115	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
5052463	A45001	06/24/2015	15:33	06/24/2015	16:56	1	82	82	Overhead equipment	Connector	Replace - Same Size		I
5052471	L74191	06/24/2015	15:49	06/24/2015	17:27	26	2527	97	Overhead equipment	Connector	Replace - Same Size		IV
5052473	J07173	06/24/2015	15:49	06/24/2015	16:55	1	65	65	Animal related	Transformer Fuse	Replace - Same Size		I
5052481	P77235	06/24/2015	16:06	06/24/2015	17:57	5	557	111	Public				VI
5052485	Q64918	06/24/2015	16:06	06/24/2015	18:25	1	138	138	Overhead equipment	Overhead Service	Repair		VI
5052495	J05139	06/24/2015	16:22	06/24/2015	17:30	1	67	67	Weather	Fuse	Patrol/Test/Inspect	Replace - Same Size	I
5052497	H10843	06/24/2015	16:24	06/24/2015	17:15	1	50	50	Animal related	Fuse	Replace - Same Size		V
5052499	Q32170	06/24/2015	16:25	06/24/2015	17:54	31	2731	88	Tree related-tree broken	Fuse	Repair	Patrol/Test/Inspect	I
5052513	J05139	06/24/2015	16:32	06/24/2015	17:25	1	52	52	Weather	Fuse	Patrol/Test/Inspect	Replace - Same Size	I
5052521	B19002	06/24/2015	16:57	06/24/2015	18:46	8	870	109	Public	Underground Primary	Patrol/Test/Inspect	Patrol/Test/Inspect	I
5052527	T12527	06/24/2015	17:08	06/24/2015	19:25	1	136	136	Animal related	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
5052531	R08910	06/24/2015	17:17	06/24/2015	19:34	1	136	136	Overhead equipment	Fuse		Replace - Same Size	VI
5052533	H10843	06/24/2015	17:22	06/24/2015	18:04	1	41	41	Animal related	Fuse	Replace - Same Size		V
5052535	J63172	06/24/2015	17:32	06/24/2015	18:32	1	59	59	Tree related-tree contact	Overhead Service			III
5052541	D88001	06/24/2015	17:32	06/24/2015	21:07	141	30338	215	Overhead equipment	Pole	Patrol/Test/Inspect	Replace - Same Size	I
5052555	Q64918	06/24/2015	17:40	06/24/2015	18:22	14	583	41	Overhead equipment	Overhead Secondary	Repair		VI
5052559	L74191	06/24/2015	17:49	06/25/2015	6:25	1	755	755	Overhead equipment	Meter	Replace - Same Size		IV
5052561	P77235	06/24/2015	17:55	06/24/2015	23:49	3	1061	353	Public	Pole	Patrol/Test/Inspect	Replace - Same Size	VI
5052563	P49188	06/24/2015	18:02	06/24/2015	19:28	2	172	86	Underground equipment	Underground Primary	Switch/Reset	Replace - Same Size	I
5052583	B27007	06/24/2015	18:53	06/24/2015	21:25	11	1668	151	Overhead equipment	Fuse	Replace - Same Size		I
5052587	A17021	06/24/2015	19:00	06/24/2015	20:13	7	509	72	Overhead equipment	Fuse	Replace - Same Size		I
5052589	B27007	06/24/2015	19:02	06/25/2015	1:50	1	407	407	Overhead equipment	Overhead Transformer	Replace - Same Size	Repair	I
5052591	HB6251	06/24/2015	19:05	06/24/2015	20:38	1	92	92	Weather	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
5052595	B10001	06/24/2015	19:10	06/24/2015	20:15	3	192	64	Weather	Fuse	Patrol/Test/Inspect	Repair	I
5052597	A17021	06/24/2015	19:10	06/24/2015	20:13	1	62	62	Overhead equipment	Fuse	Replace - Same Size		I
5052599	Q24310	06/24/2015	19:15	06/24/2015	21:28	2	265	132	Animal related	Fuse	Replace - Same Size		VI
5052605	D72001	06/24/2015	19:23	06/24/2015	23:49	11	2933	266	Weather	Overhead Transformer	Patrol/Test/Inspect	Repair	I
5052609	S41563	06/24/2015	19:43	06/24/2015	22:04	5	702	140	Overhead equipment	Overhead Transformer	Replace - Same Size	Replace - Same Size	VI
5052611	K36151	06/24/2015	19:47	06/24/2015	20:55	1	67	67	Overhead equipment	Fuse	Repair		III
5052617	A49003	06/24/2015	20:43	06/25/2015	3:45	23	9680	422	Underground equipment	Underground Primary	Switch/Reset	Repair	I
5052629	S88503	06/24/2015	20:54	06/24/2015	22:25	17	1547	91	Underground equipment	Underground Primary	Repair	Repair	VI
5052625	D72001	06/24/2015	20:55	06/24/2015	23:49	1	174	174	Weather	Overhead Transformer		Replace - Same Size	I
5052631	K82202	06/24/2015	21:25	06/24/2015	22:28	1	62	62	Overhead equipment	Overhead Transformer			III
5052961	L79180	06/24/2015	21:40	06/25/2015	5:04	17	6234	444	Underground equipment	Underground Primary		Repair	IV
5052787	HC9-X1	06/24/2015	22:07	06/24/2015	23:11	385	24678	64	Animal related	Substation Breaker	Switch/Reset		VI
5052915	P42-UNIT-1	06/24/2015	22:07	06/24/2015	23:16	2135	147250	68	Animal related				VI
5052709	HC9327	06/24/2015	22:08	06/24/2015	23:03	1	54	54	Animal related	Substation Breaker			VI
5052713	HC9327	06/24/2015	22:08	06/24/2015	23:23	80	5998	74	Animal related				VI

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5052711	HC9327	06/24/2015	22:09	06/24/2015	23:23	38	2845	74	Animal related				VI
5052715	HC9327	06/24/2015	22:09	06/24/2015	23:23	57	4267	74	Animal related				VI
5052731	HC9327	06/24/2015	22:09	06/24/2015	23:11	38	2357	62	Animal related				VI
5052727	HC9327	06/24/2015	22:09	06/24/2015	23:11	68	4218	62	Animal related				VI
5052953	V18553	06/24/2015	22:42	06/25/2015	0:22	2	198	99	Animal related	Fuse	Replace - Same Size		II
5052959	R48167	06/24/2015	23:21	06/25/2015	2:30	1	188	188	Overhead equipment	Overhead Service	Repair		IV
5052969	R33127	06/25/2015	0:49	06/25/2015	4:15	1	205	205	Tree related-tree contact	Fuse	Replace - Same Size	Repair	I
5052971	J01118	06/25/2015	1:02	06/25/2015	4:54	1	231	231	Tree related-tree contact	Overhead Service	Repair	Repair	I
5052975	P07179	06/25/2015	1:04	06/25/2015	9:55	1	531	531	Tree related-tree contact	Overhead Primary	Repair		I
5052977	P49180	06/25/2015	1:11	06/25/2015	3:45	1	153	153	Weather	Fuse	Patrol/Test/Inspect	Replace - Same Size	I
5052981	R39934	06/25/2015	1:21	06/25/2015	5:02	2	441	220	Transmission outage	Lightning Arrestor	Replace - Same Size		VI
5052983	R09225	06/25/2015	1:25	06/25/2015	5:20	1	234	234	Overhead equipment	Overhead Transformer			III
5053069	K31120	06/25/2015	1:25	06/25/2015	3:34	8	1026	128	Weather	Fuse	Replace - Same Size		I
5052991	M36185	06/25/2015	1:29	06/25/2015	2:15	121	5481	45	Weather	Fuse	Replace - Same Size		I
5052993	R05115	06/25/2015	1:33	06/25/2015	3:00	1	86	86	Weather	Fuse	Replace - Same Size		I
5052995	V92540	06/25/2015	1:38	06/25/2015	3:23	1	104	104	Weather	Transformer Fuse			II
5052997	B82002	06/25/2015	1:38	06/25/2015	4:24	1	165	165	Unknown	Fuse			I
5053001	B73001	06/25/2015	1:43	06/25/2015	7:21	368	124354	337	Weather	Regulator	Replace - Same Size	Repair	I
5053003	P07179	06/25/2015	1:43	06/25/2015	6:20	14	3871	276	Tree related-tree contact	Overhead Primary	Repair		I
5053093	U92593	06/25/2015	1:43	06/25/2015	4:00	10	1362	136	Weather	Fuse	Replace - Same Size		II
5053007	R05186	06/25/2015	1:44	06/25/2015	3:25	1	100	100	Weather	Fuse	Replace - Same Size		I
5053009	P42229	06/25/2015	1:49	06/25/2015	2:43	1	53	53	Animal related	Transformer Fuse	Replace - Same Size		VI
5053011	R05186	06/25/2015	1:51	06/25/2015	3:27	1	95	95	Weather	Fuse	Replace - Same Size		I
5053025	B68-X1	06/25/2015	1:59	06/25/2015	2:02	3194	12073	3	Weather	Substation Breaker	Replace - Same Size		III
5053017	U37579	06/25/2015	1:59	06/25/2015	4:36	1	156	156	Weather	Fuse			II
5053019	N60181	06/25/2015	1:59	06/25/2015	8:23	1	383	383	Weather	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	I
5053021	R99180	06/25/2015	2:00	06/25/2015	6:21	1	260	260	Weather	Disconnect Switch		Replace - Same Size	IV
5053027	U90566	06/25/2015	2:03	06/25/2015	3:10	1	66	66	Overhead equipment	Fuse	Replace - Same Size		II
5053039	D31018	06/25/2015	2:06	06/25/2015	3:30	80	6674	83	Overhead equipment	Fuse	Replace - Same Size	Repair	III
5053033	H00163	06/25/2015	2:08	06/25/2015	6:08	9	2157	239	Weather	Overhead Transformer	Repair	Repair	III
5053313	B57001	06/25/2015	2:11	06/25/2015	6:20	19	4727	248	Overhead equipment	Disconnect Switch	Replace - Same Size		I
5053037	V39001	06/25/2015	2:12	06/25/2015	5:46	1	213	213	Tree related-tree broken	Overhead Service	Repair		II
5053043	P17107	06/25/2015	2:16	06/25/2015	6:49	5	1361	272	Weather	Overhead Transformer		Replace - New Size	IV
5053047	B68004	06/25/2015	2:18	06/25/2015	4:26	9	1151	127	Tree related-tree broken	Overhead Service			III
5053157	J08205	06/25/2015	2:21	06/25/2015	5:04	219	35758	163	Overhead equipment	Jumper	Repair		I
5053055	P18103	06/25/2015	2:25	06/25/2015	5:30	1	184	184	Weather	Transformer Fuse	Replace - Same Size		IV
5053235	C10002	06/25/2015	2:25	06/25/2015	4:50	52	7491	144	Overhead equipment	Fuse	Replace - Same Size		III
5053073	B73001	06/25/2015	2:33	06/25/2015	5:25	1	171	171	Overhead equipment	Regulator	Disconnect	Replace - Same Size	I
5053083	B58001	06/25/2015	2:33	06/25/2015	4:08	77	7251	94	Weather	Fuse	Replace - Same Size		I
5053095	Q32171	06/25/2015	2:36	06/25/2015	6:48	1	251	251	Weather	Pole	Repair	Patrol/Test/Inspect	I
5053097	C10002	06/25/2015	2:36	06/25/2015	3:38	8	490	61	Overhead equipment	Transformer Fuse	Replace - Same Size		III
5053103	K71811	06/25/2015	2:39	06/25/2015	5:04	46	6668	144	Weather	Fuse	Replace - Same Size		IV
5053111	M40132	06/25/2015	2:43	06/25/2015	4:50	27	3417	126	Other	Fuse	Replace - Same Size		I
5053115	D53001	06/25/2015	2:50	06/25/2015	4:51	1	120	120	Weather	Transformer Fuse	Replace - Same Size		I
5053127	K74164	06/25/2015	2:53	06/25/2015	4:18	90	7641	84	Overhead equipment	Overhead Transformer	Replace - Same Size		IV
5053121	R60552	06/25/2015	2:54	06/25/2015	7:51	1	296	296	Overhead equipment	Fuse	Replace - Same Size		IV
5053307	Q32171	06/25/2015	2:55	06/25/2015	6:48	51	11904	233	Weather	Recloser	Replace - Same Size		I
5053315	K69112	06/25/2015	2:59	06/25/2015	5:58	2	357	178	Weather	Fuse	Replace - Same Size		IV
5053135	Q74150	06/25/2015	3:00	06/25/2015	7:20	1	259	259	Weather	Overhead Transformer			IV
5053137	R60552	06/25/2015	3:00	06/25/2015	7:51	1	290	290	Overhead equipment	Fuse	Replace - Same Size		IV
5053269	G10002	06/25/2015	3:00	06/25/2015	5:57	6	1059	176	Weather	Disconnect Switch	Replace - Same Size		I
5053395	K78351	06/25/2015	3:03	06/25/2015	9:45	220	79979	401	Overhead equipment	Regulator	Switch/Reset	Replace - Same Size	IV
5053145	D67001	06/25/2015	3:03	06/25/2015	3:59	1	55	55	Weather	Fuse	Repair		IV
5053147	K71812	06/25/2015	3:04	06/25/2015	8:00	4	1182	295	Weather	Overhead Transformer	Replace - Same Size		IV
5053149	R60552	06/25/2015	3:04	06/25/2015	7:16	1	251	251	Overhead equipment	Lightning Arrestor	Repair		IV
5053151	R60552	06/25/2015	3:05	06/25/2015	7:51	1	285	285	Overhead equipment	Fuse	Replace - Same Size		IV

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5053321	Q06142	06/25/2015	3:13	06/25/2015	6:16	21	3782	182	Overhead equipment	Fuse	Replace - Same Size		IV
5053163	P07179	06/25/2015	3:16	06/25/2015	10:02	28	11360	405	Tree related-tree contact	Overhead Primary	Repair		I
5053171	Q06142	06/25/2015	3:19	06/25/2015	6:16	8	1414	176	Overhead equipment	Fuse	Replace - Same Size		IV
5053177	M40132	06/25/2015	3:30	06/25/2015	5:17	1	106	106	Other	Fuse	Replace - Same Size		I
5053179	R20501	06/25/2015	3:33	06/25/2015	5:00	1	86	86	Weather	Transformer Fuse	Repair		IV
5053181	D01002	06/25/2015	3:37	06/25/2015	11:45	3	1463	487	Overhead equipment	Pole	Replace - Same Size	Repair	I
5053183	R05186	06/25/2015	3:37	06/25/2015	5:18	9	900	100	Weather	Lightning Arrestor	Disconnect		I
5053189	H01190	06/25/2015	3:43	06/25/2015	5:31	1	107	107	Weather	Fuse	Repair		III
5053191	Q32171	06/25/2015	3:44	06/25/2015	13:10	1	565	565	Tree related-tree broken	Overhead Primary	Cut in Clear	Repair	I
5053197	H01190	06/25/2015	3:48	06/25/2015	5:32	1	103	103	Weather	Fuse	Repair		III
5053199	D31018	06/25/2015	3:49	06/25/2015	10:36	10	4067	406	Weather	Overhead Transformer			III
5053201	H01194	06/25/2015	3:49	06/25/2015	6:29	3	478	159	Weather	Transformer Fuse	Repair		III
5053215	L23146	06/25/2015	3:56	06/25/2015	5:38	106	10730	101	Weather	Fuse	Replace - Same Size		III
5053211	U31598	06/25/2015	3:57	06/25/2015	5:21	1	83	83	Overhead equipment	Disconnect Switch	Repair	Repair	II
5053217	L23146	06/25/2015	3:59	06/25/2015	5:39	1	99	99	Weather	Fuse	Replace - Same Size		III
5053219	A45001	06/25/2015	4:00	06/25/2015	13:18	1	557	557	Overhead equipment	Overhead Primary	Patrol/Test/Inspect	Repair	I
5053223	Q32171	06/25/2015	4:01	06/25/2015	7:21	1	199	199	Weather	Recloser	Repair	Patrol/Test/Inspect	I
5053225	Q74149	06/25/2015	4:03	06/25/2015	5:52	1	108	108	Weather	Transformer Fuse	Replace - Same Size		IV
5053231	R58961	06/25/2015	4:08	06/25/2015	7:11	1	182	182	Weather	Fuse	Replace - Same Size		IV
5053883	C50003	06/25/2015	4:09	06/25/2015	13:11	3	1627	542	Overhead equipment				III
5053233	K28183	06/25/2015	4:09	06/25/2015	8:21	1	251	251	Weather	Overhead Transformer		Repair	III
5053247	R33127	06/25/2015	4:26	06/25/2015	4:28	7	14	2	Unknown	Fuse			I
5053253	U90566	06/25/2015	4:36	06/25/2015	8:03	1	206	206	Weather	Overhead Transformer	Repair	Repair	II
5053261	D87001	06/25/2015	4:41	06/25/2015	7:25	73	11951	163	Unknown	Fuse	Replace - Same Size	Replace - Same Size	I
5053385	V95586	06/25/2015	4:52	06/25/2015	7:43	277	47145	170	Tree related-tree broken	Overhead Primary	Cut in Clear		II
5053279	Y11556	06/25/2015	4:54	06/25/2015	10:17	73	23555	322	Tree related-tree broken	Overhead Primary	Repair	Replace - Same Size	IV
5053275	J08205	06/25/2015	4:55	06/25/2015	6:48	1	112	112	Overhead equipment	Jumper	Replace - Same Size	Replace - Same Size	I
5053285	A91002	06/25/2015	5:13	06/25/2015	8:10	47	8282	176	Tree related-tree broken	Tree		Remove	I
5053289	K39156	06/25/2015	5:18	06/25/2015	8:27	1	188	188	Weather	Fuse	Replace - Same Size		III
5053291	U62510	06/25/2015	5:18	06/25/2015	6:21	1	62	62	Weather	Fuse	Replace - Same Size		II
5053293	C10001	06/25/2015	5:19	06/25/2015	6:50	1	90	90	Overhead equipment	Fuse	Replace - Same Size		III
5053297	Y55594	06/25/2015	5:20	06/25/2015	6:41	1	80	80	Weather	Fuse	Replace - Same Size		IV
5053301	B21002	06/25/2015	5:28	06/25/2015	8:16	23	3856	167	Tree related-tree broken	Fuse	Replace - Same Size		I
5053305	V10551	06/25/2015	5:31	06/25/2015	9:29	5	1188	237	Tree related-tree contact	Recloser	Replace - Same Size		II
5053311	L17104	06/25/2015	5:38	06/25/2015	7:34	1	115	115	Other	Fuse	Replace - Same Size		III
5053317	R60551	06/25/2015	5:43	06/25/2015	11:31	1	347	347	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Repair	IV
5053319	B68003	06/25/2015	5:45	06/25/2015	7:22	1	96	96	Weather	Other	Replace - Same Size	Patrol/Test/Inspect	III
5053325	K09863	06/25/2015	5:46	06/25/2015	7:11	53	4455	84	Weather	Fuse	Replace - Same Size	Repair	V
5053327	P49180	06/25/2015	5:49	06/25/2015	7:52	6	733	122	Weather	Fuse	Replace - Same Size	Replace - Same Size	I
5053331	Y45504	06/25/2015	5:54	06/25/2015	7:40	1	105	105	Tree related-tree broken	Overhead Primary	Repair	Replace - Same Size	IV
5053333	Y45504	06/25/2015	5:54	06/25/2015	7:40	1	105	105	Tree related-tree broken	Overhead Primary	Trim	Trim	IV
5053339	K89143	06/25/2015	5:56	06/25/2015	7:08	1	71	71	Weather	Fuse	Replace - Same Size		III
5053345	V10551	06/25/2015	5:59	06/25/2015	9:29	1	209	209	Tree related-tree contact	Recloser	Replace - Same Size		II
5053349	328120	06/25/2015	6:08	06/25/2015	7:35	1	86	86	Tree related-tree broken	Overhead Service	Repair		V
5053351	A80001	06/25/2015	6:10	06/25/2015	11:20	1	309	309	Weather	Overhead Transformer	Replace - Same Size	Replace - Same Size	I
5053353	U99578	06/25/2015	6:12	06/25/2015	6:58	1	45	45	Weather	Fuse	Replace - Same Size		II
5053355	R20501	06/25/2015	6:13	06/25/2015	11:30	1	316	316	Weather	Overhead Transformer		Repair	IV
5053359	R33127	06/25/2015	6:16	06/25/2015	9:11	1	174	174	Tree related-tree contact	Overhead Service	Repair	Patrol/Test/Inspect	I
5053363	L93149	06/25/2015	6:17	06/25/2015	11:23	91	27870	306	Overhead equipment	Underground Primary	Repair	Repair	VI
5053791	L93149	06/25/2015	6:17	06/25/2015	11:47	14	4606	329	Underground equipment				VI
5053367	D90002	06/25/2015	6:20	06/25/2015	7:20	1	59	59	Overhead equipment	Fuse	Replace - Same Size		III
5053369	V10551	06/25/2015	6:25	06/25/2015	12:35	30	11097	369	Tree related-tree contact	Tree	Trim		II
5053373	341003	06/25/2015	6:26	06/25/2015	13:15	1	408	408	Overhead equipment	Tree	Advise Customer	Remove	VI
5053375	R60552	06/25/2015	6:28	06/25/2015	7:51	10	829	82	Overhead equipment	Fuse	Replace - Same Size		IV
5053377	P17107	06/25/2015	6:29	06/25/2015	8:46	3	409	136	Tree related-tree broken	Overhead Primary		Repair	IV
5053379	D87001	06/25/2015	6:30	06/25/2015	8:05	16	1515	94	Unknown	Transformer Fuse	Replace - Same Size		I

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5053381	D90002	06/25/2015	6:32	06/25/2015	7:50	1	77	77	Overhead equipment	Fuse	Replace - Same Size		III
5053403	K74162	06/25/2015	6:57	06/25/2015	8:00	1	62	62	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
5053407	J99128	06/25/2015	6:57	06/25/2015	8:18	49	3922	80	Animal related	Fuse	Replace - Same Size		VI
5053409	U31001	06/25/2015	6:59	06/25/2015	11:45	1	285	285	Underground equipment	Underground Service			II
5053411	P69173	06/25/2015	6:59	06/25/2015	8:49	1	109	109	Tree related-tree contact	Disconnect Switch	Repair		III
5053415	P47123	06/25/2015	7:03	06/25/2015	12:05	1	301	301	Weather	Fuse		Repair	I
5053417	Q06142	06/25/2015	7:05	06/25/2015	8:29	1	83	83	Weather	Fuse	Replace - Same Size		IV
5053421	L17104	06/25/2015	7:13	06/25/2015	7:36	1	22	22	Other	Fuse	Replace - Same Size		III
5053423	K09863	06/25/2015	7:15	06/25/2015	8:24	8	545	68	Weather	Overhead Transformer	Replace - New Size	Repair	V
5053425	P49180	06/25/2015	7:16	06/25/2015	9:14	1	117	117	Weather	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	I
5053427	K76547	06/25/2015	7:16	06/25/2015	8:16	1	59	59	Animal related	Fuse	Replace - Same Size		IV
5053431	Q32170	06/25/2015	7:19	06/25/2015	10:17	1	177	177	Tree related-tree broken	Tree			I
5053433	L17104	06/25/2015	7:22	06/25/2015	8:24	1	61	61	Weather	Fuse	Replace - Same Size		III
5053435	C30001	06/25/2015	7:24	06/25/2015	8:40	1	75	75	Underground equipment	Underground Transformer	Patrol/Test/Inspect		III
5053439	K39156	06/25/2015	7:26	06/25/2015	8:56	1	89	89	Weather	Fuse	Repair		III
5053443	Q63835	06/25/2015	7:32	06/25/2015	9:20	1	107	107	Overhead equipment	Overhead Primary	Patrol/Test/Inspect	Repair	V
5053445	C66001	06/25/2015	7:34	06/25/2015	8:44	1	69	69	Overhead equipment	Fuse	Replace - Same Size		III
5053447	K76547	06/25/2015	7:34	06/25/2015	8:13	1	38	38	Animal related	Fuse	Replace - Same Size		IV
5053449	K76542	06/25/2015	7:35	06/25/2015	10:40	1	184	184	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	IV
5053451	R48167	06/25/2015	7:38	06/25/2015	8:31	18	942	52	Overhead equipment	Fuse	Repair		IV
5053453	K39156	06/25/2015	7:40	06/25/2015	8:29	1	48	48	Weather	Fuse	Replace - Same Size		III
5053457	D55001	06/25/2015	7:43	06/25/2015	9:40	14	1635	116	Unknown	Fuse	Replace - Same Size		I
5053461	P07179	06/25/2015	7:45	06/25/2015	13:00	53	16676	314	Tree related-tree broken	Overhead Primary	Tie/Tighten	Repair	I
5053467	K69112	06/25/2015	7:46	06/25/2015	8:50	1	63	63	Animal related	Fuse	Replace - Same Size		IV
5053471	B53001	06/25/2015	7:49	06/25/2015	13:57	1	367	367	Underground equipment	Underground Secondary	Patrol/Test/Inspect	Patrol/Test/Inspect	III
5053473	M36185	06/25/2015	7:49	06/25/2015	12:34	3	852	284	Overhead equipment	Overhead Transformer	Replace - Same Size	Replace - Urgent	I
5053485	U86002	06/25/2015	7:54	06/25/2015	14:38	1	403	403	Tree related-tree contact	Customer Equipment			II
5053491	C10002	06/25/2015	7:59	06/25/2015	10:28	1	148	148	Weather	Other	Replace - Same Size	Patrol/Test/Inspect	III
5053531	J56341	06/25/2015	8:00	06/25/2015	8:57	27	1517	56	Animal related	Fuse	Repair	Repair	III
5053501	U97520	06/25/2015	8:07	06/25/2015	9:40	2	185	92	Overhead equipment				II
5053503	K74162	06/25/2015	8:08	06/25/2015	10:35	1	146	146	Overhead equipment	Overhead Transformer	Replace - Same Size		IV
5053519	K48384	06/25/2015	8:09	06/25/2015	8:21	624	7094	11	Substation equipment	Lightning Arrestor	Replace - Same Size	Replace - Same Size	V
5053529	V36001	06/25/2015	8:15	06/25/2015	10:30	1	134	134	Tree related-tree broken	Overhead Service			II
5053533	K48380	06/25/2015	8:18	06/25/2015	8:23	636	2652	4	Overhead equipment	Lightning Arrestor	Replace - Same Size	Replace - Same Size	V
5053549	K48384	06/25/2015	8:29	06/25/2015	8:41	1	11	11	Substation equipment	Substation Misc.	Repair	Replace - Same Size	V
5053555	B58002	06/25/2015	8:32	06/25/2015	13:44	1	311	311	Overhead equipment	Disconnect Switch	Patrol/Test/Inspect	Replace - Same Size	I
5053561	D90002	06/25/2015	8:35	06/25/2015	10:10	1	94	94	Overhead equipment	Overhead Service	Repair		III
5053565	U51539	06/25/2015	8:40	06/25/2015	10:21	1	100	100	Weather	Transformer Fuse	Replace - Same Size		II
5053571	V58507	06/25/2015	8:41	06/25/2015	10:14	1	92	92	Weather	Transformer Fuse	Replace - Same Size		II
5053581	S01501	06/25/2015	8:50	06/25/2015	9:40	1	49	49	Animal related	Transformer Fuse			VI
5053597	L93132	06/25/2015	8:54	06/25/2015	11:52	450	79830	177	Public	Overhead Primary	Patrol/Test/Inspect	Repair	VI
5053627	V46552	06/25/2015	8:55	06/25/2015	11:35	82	13145	160	Underground equipment	Underground Secondary		Repair	II
5053633	K78351	06/25/2015	9:04	06/25/2015	9:18	1	13	13	Overhead equipment				IV
5053637	B19002	06/25/2015	9:05	06/25/2015	15:12	1	366	366	Weather	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	I
5053643	R05186	06/25/2015	9:06	06/25/2015	13:29	1	262	262	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	I
5053645	Q32170	06/25/2015	9:08	06/25/2015	10:35	1	86	86	Tree related-tree broken	Overhead Primary	Trim		I
5053649	K48384	06/25/2015	9:10	06/25/2015	9:33	1	22	22	Substation equipment	Substation Misc.	Repair	Replace - Same Size	V
5053673	N18210	06/25/2015	9:29	06/25/2015	10:44	1	74	74	Overhead equipment	Fuse	Replace - Same Size		III
5053685	D67001	06/25/2015	9:49	06/25/2015	10:37	1	47	47	Weather	Transformer Fuse	Repair		IV
5053687	L93149	06/25/2015	9:53	06/25/2015	12:43	1	169	169	Other				VI
5053691	B68004	06/25/2015	9:59	06/25/2015	12:00	1	120	120	Overhead equipment	Overhead Service	Repair		III
5053697	A97002	06/25/2015	10:03	06/25/2015	12:25	16	2266	141	Unknown	Fuse	Replace - Same Size		I
5053699	E10001	06/25/2015	10:03	06/25/2015	11:15	1	71	71	Overhead equipment	Disconnect Switch	Replace - Same Size		III
5053701	Z11506	06/25/2015	10:10	06/25/2015	10:48	4	150	37	Animal related	Fuse	Repair		IV
5053707	L35139	06/25/2015	10:19	06/25/2015	10:56	7	253	36	Other	Overhead Secondary	Raise		III
5053729	C70004	06/25/2015	10:30	06/25/2015	11:57	85	7373	86	Overhead equipment	Overhead Primary	Replace - Same Size		III

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5053723	U80564	06/25/2015	10:31	06/25/2015	11:18	1	46	46	Animal related	Fuse	Replace - Same Size		II
5053727	K69112	06/25/2015	10:33	06/25/2015	11:01	1	27	27	Weather	Fuse	Replace - Same Size		IV
5053735	U52516	06/25/2015	10:37	06/25/2015	10:44	6	37	6	Overhead equipment	Overhead Secondary	Replace - Same Size		II
5053747	Z05550	06/25/2015	10:50	06/25/2015	11:50	1	59	59	Tree related-tree broken				IV
5053749	V95586	06/25/2015	10:55	06/25/2015	11:54	1	58	58	Tree related-tree broken	Overhead Service	Repair		II
5053757	F03003	06/25/2015	10:58	06/25/2015	12:26	1	87	87	Other				III
5053761	B00002	06/25/2015	10:59	06/25/2015	12:14	1	75	75	Tree related-tree broken	Overhead Service	Tie/Tighten		I
5053765	Q01282	06/25/2015	11:00	06/25/2015	12:08	1	67	67	Intentional				III
5053769	D36001	06/25/2015	11:01	06/25/2015	11:35	1	33	33	Other				I
5053775	C37002	06/25/2015	11:12	06/25/2015	13:03	1	110	110	Overhead equipment	Fuse	Replace - Same Size		III
5053785	B77001	06/25/2015	11:14	06/25/2015	14:00	69	11440	165	Overhead equipment	Overhead Primary	Repair		I
5053781	L71171	06/25/2015	11:14	06/25/2015	11:54	1	39	39	Animal related	Fuse			IV
5053787	D66003	06/25/2015	11:17	06/25/2015	20:20	1	542	542	Overhead equipment	Overhead Transformer	Replace - Same Size		IV
5053813	A45001	06/25/2015	11:48	06/25/2015	13:18	1	89	89	Overhead equipment	Pole	Repair	Replace - Same Size	I
5053823	H88104	06/25/2015	11:51	06/25/2015	12:49	41	2361	57	Overhead equipment				II
5053829	L93132	06/25/2015	11:56	06/25/2015	12:00	1	3	3	Public				VI
5053831	B57002	06/25/2015	11:57	06/25/2015	12:35	1	37	37	Animal related	Transformer Fuse	Replace - Same Size		I
5053835	Q32170	06/25/2015	12:02	06/25/2015	12:53	1	50	50	Overhead equipment	Fuse	Repair	Replace - Same Size	I
5053839	G50002	06/25/2015	12:04	06/25/2015	13:15	1	70	70	Tree related-tree broken	Tree	Trim		IV
5053841	K74162	06/25/2015	12:06	06/25/2015	12:45	133	4891	38	Animal related				IV
5053857	N86225	06/25/2015	12:11	06/25/2015	13:45	1	93	93	Tree related-tree contact	Overhead Secondary	Tie/Tighten	Repair	VI
5053867	R58961	06/25/2015	12:40	06/25/2015	12:51	1	10	10	Animal related				IV
5053901	J71128	06/25/2015	13:21	06/25/2015	14:42	1	81	81	Tree related-tree broken	Overhead Service	Raise	Reconnect	I
5053915	K01238	06/25/2015	13:47	06/25/2015	17:25	1	217	217	Overhead equipment	Overhead Service	Patrol/Test/Inspect	Replace - New Size	VI
5053921	N54214	06/25/2015	13:50	06/25/2015	16:03	35	4648	132	Underground equipment	Underground Primary	Switch/Reset		II
5053925	L68112	06/25/2015	14:09	06/25/2015	14:57	1	47	47	Weather	Transformer Fuse	Replace - Same Size		IV
5053929	N54214	06/25/2015	14:19	06/25/2015	16:02	8	822	102	Unknown				II
5053931	Q32170	06/25/2015	14:21	06/25/2015	17:17	3	527	175	Animal related	Transformer Fuse	Replace - Same Size	Repair	I
5053937	X09534	06/25/2015	14:24	06/25/2015	15:30	1	65	65	Overhead equipment	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	IV
5053941	P26284	06/25/2015	14:31	06/25/2015	15:36	7	452	64	Animal related	Transformer Fuse	Replace - Same Size	Repair	I
5053943	A85002	06/25/2015	14:34	06/25/2015	15:38	1	63	63	Animal related	Transformer Fuse	Replace - Same Size		I
5053967	R65451	06/25/2015	15:16	06/25/2015	19:13	1	236	236	Tree related-tree contact	Tree	Patrol/Test/Inspect	Trim	IV
5053969	Z51551	06/25/2015	15:16	06/25/2015	16:40	2	166	83	Overhead equipment	Overhead Primary	Repair	Patrol/Test/Inspect	IV
5054049	R95520	06/25/2015	15:24	06/25/2015	18:02	14	2204	157	Animal related	Fuse	Patrol/Test/Inspect	Repair	I
5053979	H06135	06/25/2015	15:28	06/25/2015	16:45	1	76	76	Overhead equipment	Fuse			IV
5053981	J08205	06/25/2015	15:31	06/25/2015	16:40	1	68	68	Overhead equipment	Transformer Fuse	Replace - Same Size	Replace - Same Size	I
5053985	M18216	06/25/2015	15:42	06/25/2015	16:45	1	62	62	Tree related-tree contact	Overhead Secondary	Patrol/Test/Inspect	Trim	III
5053993	B10001	06/25/2015	15:52	06/25/2015	23:17	4	1776	444	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
5054069	Q06131	06/25/2015	16:28	06/25/2015	17:42	824	60498	73	Animal related	Substation Breaker	Switch/Reset		IV
5054057	E10001	06/25/2015	17:04	06/25/2015	18:10	1	65	65	Overhead equipment	Fuse	Replace - Same Size		III
5054107	U13551	06/25/2015	17:10	06/25/2015	19:29	23	3191	138	Tree related-tree broken	Fuse	Replace - Same Size	Replace - Same Size	II
5054091	B19002	06/25/2015	17:13	06/26/2015	0:01	1	407	407	Underground equipment	Customer Equipment		Repair	I
5054093	V33006	06/25/2015	17:16	06/25/2015	19:17	8	964	120	Overhead equipment				II
5054095	Q32171	06/25/2015	17:25	06/25/2015	22:00	1	274	274	Underground equipment	Underground Service	Advise Customer	Disconnect	I
5054097	B62004	06/25/2015	17:28	06/25/2015	18:50	6	487	81	Overhead equipment	Transformer Fuse	Replace - Same Size		I
5054111	U13551	06/25/2015	17:40	06/25/2015	19:30	1	109	109	Tree related-tree broken	Fuse			II
5054123	R60552	06/25/2015	18:03	06/25/2015	20:05	13	1580	121	Underground equipment	Underground Primary	Switch/Reset	Repair	IV
5054127	B21002	06/25/2015	18:11	06/25/2015	19:33	1	81	81	Animal related	Transformer Fuse	Replace - Same Size		I
5054129	X42501	06/25/2015	18:17	06/25/2015	22:15	1	237	237	Underground equipment	Underground Secondary		Replace - Same Size	IV
5054131	Y13042	06/25/2015	18:17	06/25/2015	19:20	1	62	62	Tree related-tree broken	Overhead Service	Repair		IV
5054139	U13551	06/25/2015	18:33	06/25/2015	19:30	1	56	56	Tree related-tree broken	Fuse			II
5054143	N50334	06/25/2015	18:36	06/25/2015	19:15	15	578	38	Animal related	Fuse	Replace - Same Size		II
5054149	Y45504	06/25/2015	18:44	06/25/2015	20:02	1	77	77	Overhead equipment	Overhead Service	Repair	Replace - Same Size	IV
5054153	324002	06/25/2015	18:50	06/26/2015	3:22	1	511	511	Tree related-tree broken	Overhead Primary	Replace - Same Size		VI
5054157	306001	06/25/2015	18:58	06/26/2015	1:42	1	403	403	Tree related-tree broken				VI
5054159	350103	06/25/2015	18:58	06/26/2015	0:30	1	331	331	Overhead equipment	Overhead Primary	Cut in Clear	Repair	V

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5056191	M78325	06/25/2015	18:59	06/26/2015	0:27	306	100132	327	Overhead equipment	Pole			V
5054163	H14342	06/25/2015	19:00	06/25/2015	20:08	56	3776	67	Weather	Fuse	Replace - Same Size		V
5054165	306003	06/25/2015	19:01	06/26/2015	13:35	7	7796	1113	Weather	Overhead Transformer	Switch/Reset		VI
5054167	306001	06/25/2015	19:01	06/26/2015	1:43	10	4013	401	Tree related-tree broken				VI
5054171	N03296	06/25/2015	19:03	06/26/2015	3:24	4	2000	500	Weather	Transformer Fuse	Replace - Same Size		V
5054173	M83408	06/25/2015	19:03	06/26/2015	1:58	8	3312	414	Weather	Fuse	Replace - Same Size		V
5054189	R78301	06/25/2015	19:04	06/26/2015	9:25	30	25800	860	Overhead equipment	Tree	Remove	Remove	V
5054291	V40-XTR1	06/25/2015	19:08	06/25/2015	20:18	1352	94464	69	Tree related-tree broken	Overhead Primary			II
5054187	B68003	06/25/2015	19:08	06/25/2015	20:00	1	51	51	Overhead equipment	Transformer Fuse	Replace - Same Size		III
5054253	R78301	06/25/2015	19:11	06/26/2015	9:40	1	868	868	Overhead equipment	Tree	Remove	Remove	V
5054305	349001	06/25/2015	19:14	06/26/2015	2:00	12	4867	405	Overhead equipment	Disconnect Switch		Replace - New Size	VI
5054379	342-UNIT-1	06/25/2015	19:14	06/26/2015	0:10	1821	539416	296	Tree related-tree broken				VI
5054313	V53-XTR1	06/25/2015	19:14	06/25/2015	20:15	7	429	61	Tree related-tree broken				II
5054355	L62927	06/25/2015	19:14	06/25/2015	21:14	48	5722	119	Overhead equipment	Fuse	Replace - Same Size		VI
5056953	M54292	06/25/2015	19:15	06/25/2015	23:25	108	26985	249	Overhead equipment	Pole			V
5054323	M54314	06/25/2015	19:15	06/26/2015	1:39	9	3451	383	Tree related-tree contact	Overhead Service	Cut in Clear	Reconnect	V
5054347	Q10703	06/25/2015	19:17	06/26/2015	6:01	1	643	643	Tree related-tree broken	Overhead Service	Reconnect		V
5054571	334001	06/25/2015	19:18	06/26/2015	7:18	325	233805	719	Overhead equipment	Tree	Trim		VI
5054779	303-UNIT-2	06/25/2015	19:19	06/26/2015	0:20	1549	466822	301	Tree related-tree broken				VI
5054361	M22812	06/25/2015	19:20	06/25/2015	20:29	1	68	68	Weather	Fuse	Replace - Same Size		V
5054483	J84146	06/25/2015	19:24	06/26/2015	0:40	282	89061	315	Tree related-tree broken	Overhead Primary	Patrol/Test/Inspect	Repair	VI
5054887	J86-UNIT-1	06/25/2015	19:25	06/25/2015	21:52	1970	290437	147	Tree related-tree broken	Tree		Remove	VI
5054401	349001	06/25/2015	19:25	06/26/2015	2:46	10	4401	440	Tree related-tree broken	Overhead Secondary	Replace - Same Size		VI
5054399	306001	06/25/2015	19:25	06/26/2015	1:44	10	3781	378	Tree related-tree broken				VI
5054411	346003	06/25/2015	19:26	06/26/2015	20:03	4	5911	1477	Tree related-tree broken	Overhead Primary			VI
5054407	R93350	06/25/2015	19:26	06/25/2015	21:44	6	827	137	Weather	Fuse	Replace - Same Size		V
5054415	R78301	06/25/2015	19:26	06/26/2015	9:40	1	853	853	Overhead equipment				V
5054423	J84123	06/25/2015	19:26	06/26/2015	9:35	48	18637	849	Tree related-tree broken	Overhead Primary		Repair	VI
5056915	J84146	06/25/2015	19:26	06/26/2015	0:40	55	17281	314	Overhead equipment				VI
5055111	344002	06/25/2015	19:27	06/26/2015	14:34	300	340355	1147	Tree related-tree broken				VI
5054425	J84146	06/25/2015	19:27	06/26/2015	0:48	10	3209	320	Tree related-tree broken	Overhead Primary	Patrol/Test/Inspect	Repair	VI
5054697	K55398	06/25/2015	19:27	06/25/2015	21:40	371	49231	132	Tree related-tree broken	Overhead Primary			V
5055263	IP9009	06/25/2015	19:27	06/26/2015	5:45	35	21605	617	Tree related-tree broken	Overhead Primary	Repair		VI
5054533	J84124	06/25/2015	19:27	06/26/2015	16:28	159	200464	1260	Tree related-tree broken	Tree	Remove		VI
5054463	J84145	06/25/2015	19:28	06/26/2015	5:25	3	1789	596	Overhead equipment	Overhead Primary	Repair	Repair	VI
5054837	347001	06/25/2015	19:28	06/26/2015	2:41	355	153537	432	Tree related-tree broken	Tree	Remove		VI
5054477	J84123	06/25/2015	19:28	06/26/2015	9:35	3	2541	847	Tree related-tree broken	Overhead Primary	Patrol/Test/Inspect	Repair	VI
5055029	J85-UNIT-1	06/25/2015	19:28	06/25/2015	21:59	1180	177212	150	Tree related-tree broken				VI
5054569	J84145	06/25/2015	19:29	06/26/2015	2:15	136	55206	405	Overhead equipment				VI
5054503	307003	06/25/2015	19:29	06/26/2015	11:50	1	980	980	Tree related-tree broken	Overhead Service	Repair		VI
5054549	M49424	06/25/2015	19:30	06/26/2015	2:47	12	5238	436	Weather	Fuse	Replace - Same Size		V
5054553	337003	06/25/2015	19:30	06/26/2015	11:14	3	2830	943	Tree related-tree broken	Overhead Secondary	Repair		VI
5055779	343004	06/25/2015	19:31	06/26/2015	16:00	1	1228	1228	Tree related-tree broken	Tree	Trim	Trim	VI
5054833	P19395	06/25/2015	19:31	06/26/2015	1:19	25	8678	347	Tree related-tree broken	Overhead Primary	Repair		V
5054637	P09306	06/25/2015	19:32	06/26/2015	1:40	1	367	367	Overhead equipment	Overhead Service	Repair		V
5055481	302-UNIT-1	06/25/2015	19:32	06/26/2015	0:43	654	203371	311	Tree related-tree broken				VI
5054663	346004	06/25/2015	19:32	06/26/2015	9:50	1	857	857	Tree related-tree broken	Overhead Service			VI
5054667	M54292	06/25/2015	19:32	06/26/2015	0:29	5	1480	296	Weather	Fuse	Replace - Same Size		V
5055079	J99141	06/25/2015	19:33	06/26/2015	4:30	194	104139	536	Tree related-tree broken	Overhead Primary	Patrol/Test/Inspect	Repair	VI
5054695	J97115	06/25/2015	19:33	06/26/2015	3:33	6	2875	479	Tree related-tree broken	Overhead Primary	Disconnect	Replace - Same Size	VI
5054839	303-UNIT-1	06/25/2015	19:33	06/26/2015	0:20	1259	360917	286	Tree related-tree broken				VI
5055035	335-UNIT-1	06/25/2015	19:34	06/25/2015	20:17	695	29752	42	Tree related-tree broken				VI
5054785	J89126	06/25/2015	19:34	06/26/2015	13:35	68	73514	1081	Tree related-tree broken	Overhead Primary	Patrol/Test/Inspect	Repair	VI
5054765	343004	06/25/2015	19:35	06/26/2015	16:40	24	30348	1264	Tree related-tree broken	Overhead Primary	Patrol/Test/Inspect	Repair	VI
5054809	341002	06/25/2015	19:36	06/26/2015	11:05	3	2785	928	Tree related-tree contact	Transformer Fuse	Replace - Same Size		VI
5054825	J84146	06/25/2015	19:36	06/26/2015	5:59	57	35504	622	Tree related-tree broken	Overhead Primary	Repair		VI

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5054873	346004	06/25/2015	19:38	06/26/2015	14:41	1	1142	1142	Tree related-tree contact	Overhead Service			VI
5054877	K48379	06/25/2015	19:38	06/26/2015	7:15	25	17412	696	Overhead equipment	Overhead Primary		Repair	V
5054955	Q21293	06/25/2015	19:39	06/26/2015	6:25	7	4519	645	Tree related-tree broken	Overhead Primary	Replace - Same Size	Repair	VI
5057595	HD5254	06/25/2015	19:39	06/26/2015	5:45	23	13927	605	Overhead equipment				VI
5054979	346002	06/25/2015	19:39	06/26/2015	13:30	11	11770	1070	Tree related-tree broken	Overhead Secondary	Repair		VI
5055451	H14342	06/25/2015	19:40	06/25/2015	20:56	6	455	75	Weather	Fuse	Replace - Same Size		V
5055785	349001	06/25/2015	19:40	06/26/2015	10:53	19	17345	912	Tree related-tree broken				VI
5057651	349002	06/25/2015	19:40	06/26/2015	15:05	10	11641	1164	Overhead equipment	Tree		Trim	VI
5055017	343008	06/25/2015	19:41	06/26/2015	11:58	1	976	976	Tree related-tree contact	Overhead Service			VI
5058165	351001	06/25/2015	19:41	06/26/2015	10:48	8	7250	906	Tree related-tree broken	Tree	Remove		VI
5055033	J89126	06/25/2015	19:42	06/26/2015	4:18	11	5680	516	Overhead equipment				VI
5055043	HA5431	06/25/2015	19:43	06/26/2015	2:38	1	414	414	Weather	Fuse	Replace - Same Size		V
5055433	K52401	06/25/2015	19:44	06/25/2015	23:07	50	10139	202	Weather	Fuse	Replace - Same Size		V
5055067	IP9009	06/25/2015	19:44	06/26/2015	6:11	8	5014	626	Weather				VI
5055057	B19002	06/25/2015	19:44	06/26/2015	0:15	3	812	270	Overhead equipment	Tree	Patrol/Test/Inspect	Trim	I
5055771	349001	06/25/2015	19:44	06/26/2015	21:30	3	4637	1545	Tree related-tree broken	Overhead Primary		Repair	VI
5055077	351001	06/25/2015	19:44	06/26/2015	8:27	51	37273	762	Overhead equipment	Overhead Primary	Repair		VI
5055099	K55398	06/25/2015	19:44	06/26/2015	13:24	1	1059	1059	Overhead equipment	Pole	Cut in Clear	Replace - Same Size	V
5055453	Q63835	06/25/2015	19:45	06/26/2015	0:52	18	5512	306	Tree related-tree broken				V
5057593	J83137	06/25/2015	19:46	06/26/2015	10:06	16	13768	860	Overhead equipment	Pole			VI
5055137	351001	06/25/2015	19:46	06/26/2015	8:28	8	6092	761	Weather	Overhead Transformer			VI
5057655	349002	06/25/2015	19:47	06/26/2015	14:58	36	41465	1151	Tree related-tree broken	Tree		Trim	VI
5055205	HD5253	06/25/2015	19:49	06/26/2015	7:15	20	13715	685	Tree related-tree broken	Tree		Remove	VI
5055503	L93132	06/25/2015	19:50	06/26/2015	1:56	209	76427	365	Tree related-tree broken	Overhead Primary	Repair	Repair	VI
5055229	307003	06/25/2015	19:51	06/26/2015	11:50	1	958	958	Tree related-tree broken	Overhead Service			VI
5058627	341002	06/25/2015	19:51	06/26/2015	12:24	8	7944	993	Overhead equipment				VI
5055241	HB6281	06/25/2015	19:53	06/26/2015	6:25	16	10110	631	Overhead equipment				VI
5055251	J83138	06/25/2015	19:54	06/26/2015	4:31	416	1295	517	Tree related-tree broken	Overhead Primary	Patrol/Test/Inspect	Repair	VI
5055253	J83138	06/25/2015	19:54	06/26/2015	16:05	355	234207	1211	Tree related-tree broken	Tree	Trim		VI
5057439	342004	06/25/2015	19:54	06/25/2015	21:12	486	37665	77	Overhead equipment	Overhead Primary		Repair	VI
5055277	349003	06/25/2015	19:54	06/26/2015	12:33	10	9981	998	Unknown				VI
5055281	308004	06/25/2015	19:55	06/26/2015	15:14	6	6953	1158	Tree related-tree contact	Fuse			VI
5055285	J83138	06/25/2015	19:55	06/26/2015	16:05	235	74006	1210	Tree related-tree broken	Tree	Trim		VI
5055297	K15205	06/25/2015	19:57	06/26/2015	11:17	1	919	919	Tree related-tree broken	Overhead Secondary	Repair	Repair	VI
5058169	K43386	06/25/2015	19:58	06/26/2015	10:00	68	57218	841	Overhead equipment				V
5055521	V40556	06/25/2015	19:58	06/25/2015	22:06	217	27650	127	Tree related-tree broken	Overhead Primary	Replace - Same Size	Replace - Same Size	II
5055309	341002	06/25/2015	19:58	06/26/2015	11:00	7	6308	901	Tree related-tree broken	Overhead Primary	Repair	Repair	VI
5055313	D35002	06/25/2015	19:59	06/26/2015	2:35	1	396	396	Underground equipment	Underground Primary		Repair	I
5055329	341002	06/25/2015	19:59	06/26/2015	14:00	11	11888	1080	Tree related-tree broken	Overhead Primary	Repair	Repair	VI
5055349	332004	06/25/2015	19:59	06/26/2015	14:00	30	32412	1080	Tree related-tree broken	Overhead Primary	Patrol/Test/Inspect	Repair	VI
5055357	J87111	06/25/2015	19:59	06/26/2015	5:02	1	542	542	Overhead equipment	Transformer Fuse	Repair	Repair	VI
5055459	325010	06/25/2015	19:59	06/26/2015	10:56	878	787671	897	Underground equipment	Underground Primary			VI
5055367	341001	06/25/2015	20:00	06/26/2015	20:15	9	13090	1454	Tree related-tree broken	Overhead Secondary	Patrol/Test/Inspect		VI
5055383	344003	06/25/2015	20:02	06/26/2015	11:41	1	938	938	Tree related-tree broken	Overhead Service			VI
5055389	333001	06/25/2015	20:02	06/25/2015	22:09	44	5580	126	Tree related-tree broken				VI
5055393	J87150	06/25/2015	20:03	06/26/2015	10:02	1	838	838	Tree related-tree contact	Overhead Service	Patrol/Test/Inspect	Repair	VI
5055395	K11376	06/25/2015	20:03	06/26/2015	5:32	1	568	568	Tree related-tree broken	Overhead Service	Repair		V
5055397	L99392	06/25/2015	20:03	06/26/2015	6:31	3	1882	627	Overhead equipment	Overhead Transformer	Replace - Same Size	Replace - Same Size	V
5055409	Z57516	06/25/2015	20:04	06/25/2015	21:58	1	113	113	Weather	Fuse	Repair		IV
5055417	J88163	06/25/2015	20:04	06/26/2015	8:53	1	768	768	Overhead equipment	Overhead Transformer		Repair	VI
5055407	V50001	06/25/2015	20:04	06/25/2015	20:45	1	40	40	Other	Meter	Patrol/Test/Inspect	Reconnect	II
5055431	M54314	06/25/2015	20:05	06/26/2015	5:00	1	534	534	Tree related-tree broken	Overhead Service	Cut in Clear	Reconnect	V
5055441	Q63835	06/25/2015	20:06	06/25/2015	23:52	1	225	225	Weather	Overhead Primary	Patrol/Test/Inspect	Repair	V
5055443	341002	06/25/2015	20:06	06/26/2015	10:04	7	5863	837	Tree related-tree contact	Overhead Service	Repair		VI
5058051	302001	06/25/2015	20:07	06/27/2015	17:52	7	19212	2744	Tree related-tree broken	Pole			VI
5055487	333-UNIT-W	06/25/2015	20:09	06/25/2015	21:59	36	3968	110	Tree related-tree broken				VI

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5055489	M53312	06/25/2015	20:09	06/25/2015	22:37	1	147	147	Tree related-tree broken	Pole		Replace - Same Size	V
5055493	351002	06/25/2015	20:10	06/26/2015	8:52	4	3045	761	Overhead equipment	Overhead Transformer	Switch/Reset		VI
5057929	351001	06/25/2015	20:11	06/26/2015	8:38	1	746	746	Weather				VI
5055505	346002	06/25/2015	20:12	06/26/2015	6:56	1	643	643	Unknown				VI
5055509	K46388	06/25/2015	20:13	06/26/2015	7:58	1	704	704	Overhead equipment	Tree	Remove	Remove	V
5055511	307002	06/25/2015	20:13	06/26/2015	7:10	1	656	656	Tree related-tree contact	Other			VI
5055513	349001	06/25/2015	20:13	06/26/2015	6:38	1	624	624	Unknown				VI
5055515	RIG-76	06/25/2015	20:13	06/26/2015	7:20	1	666	666	Tree related-tree contact	Other			VI
5055519	GEO-6-XW	06/25/2015	20:13	06/26/2015	8:12	1	718	718	Tree related-tree contact	Other			VI
5055527	337003	06/25/2015	20:14	06/27/2015	9:26	4	8927	2231	Tree related-tree contact	Overhead Secondary	Patrol/Test/Inspect	Repair	VI
5057643	349002	06/25/2015	20:14	06/26/2015	11:54	17	15978	939	Overhead equipment				VI
5055531	338005	06/25/2015	20:14	06/26/2015	16:27	2	2425	1212	Tree related-tree contact	Fuse			VI
5057661	349002	06/25/2015	20:14	06/26/2015	17:01	7	8728	1246	Tree related-tree broken	Overhead Primary			VI
5055539	351001	06/25/2015	20:15	06/26/2015	10:46	1	870	870	Overhead equipment	Tree	Remove		VI
5055653	Q27185	06/25/2015	20:15	06/25/2015	23:43	117	23393	207	Overhead equipment	Overhead Primary		Replace - Same Size	VI
5057635	344002	06/25/2015	20:15	06/26/2015	11:03	1	888	888	Tree related-tree broken				VI
5055547	J99128	06/25/2015	20:16	06/26/2015	16:22	1	1205	1205	Tree related-tree broken	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	VI
5055551	H14342	06/25/2015	20:17	06/26/2015	0:55	5	1389	277	Weather	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	V
5055549	335001	06/25/2015	20:17	06/26/2015	2:17	1	359	359	Overhead equipment				VI
5055553	335002	06/25/2015	20:17	06/26/2015	12:39	205	201283	981	Overhead equipment				VI
5057657	349002	06/25/2015	20:17	06/26/2015	12:53	9	8960	995	Overhead equipment	Overhead Secondary	Patrol/Test/Inspect		VI
5055555	335003	06/25/2015	20:17	06/26/2015	2:18	466	168379	361	Overhead equipment				VI
5055561	335004	06/25/2015	20:17	06/26/2015	2:20	23	8353	363	Overhead equipment				VI
5055563	307001	06/25/2015	20:17	06/26/2015	3:20	1	422	422	Tree related-tree broken	Overhead Service	Repair		VI
5055569	V40556	06/25/2015	20:19	06/25/2015	21:00	1	40	40	Tree related-tree broken	Tree		Advise Customer	II
5055877	J83138	06/25/2015	20:19	06/26/2015	16:05	77	77479	1186	Tree related-tree broken	Overhead Primary	Repair	Repair	VI
5055587	Q95247	06/25/2015	20:19	06/26/2015	6:40	1	620	620	Overhead equipment	Fuse		Repair	VI
5057931	T46003	06/25/2015	20:19	06/26/2015	11:55	9	8422	935	Underground equipment	Underground Primary	Disconnect	Repair	VI
5055583	D70004	06/25/2015	20:19	06/25/2015	22:15	1	115	115	Overhead equipment	Connector	Replace - Same Size		I
5055585	K43385	06/25/2015	20:19	06/26/2015	2:18	1	358	358	Overhead equipment				V
5055601	341001	06/25/2015	20:19	06/26/2015	16:31	4	4846	1211	Overhead equipment	Pole			VI
5055595	V40556	06/25/2015	20:19	06/25/2015	22:16	1	116	116	Tree related-tree broken				II
5058491	J85161	06/25/2015	20:21	06/26/2015	11:55	3	2803	934	Overhead equipment				VI
5057403	303005	06/25/2015	20:21	06/26/2015	20:15	613	560443	1433	Overhead equipment	Overhead Primary			VI
5055611	J84146	06/25/2015	20:21	06/26/2015	0:36	5	1274	254	Overhead equipment				VI
5055613	334001	06/25/2015	20:22	06/26/2015	6:45	1	622	622	Tree related-tree broken	Crossarm	Repair		VI
5055619	IP9009	06/25/2015	20:24	06/26/2015	7:35	1	670	670	Tree related-tree broken	Overhead Service	Repair		VI
5055629	J82117	06/25/2015	20:28	06/26/2015	3:30	3	1265	421	Tree related-tree contact	Tree	Trim		VI
5055633	K01236	06/25/2015	20:28	06/26/2015	10:48	1	859	859	Overhead equipment				VI
5055637	351001	06/25/2015	20:29	06/26/2015	8:05	1	695	695	Overhead equipment	Transformer Fuse	Replace - Same Size		VI
5055639	338007	06/25/2015	20:29	06/26/2015	8:08	1	698	698	Tree related-tree contact	Other			VI
5055657	J85-UNIT-2	06/25/2015	20:31	06/25/2015	21:52	5	403	80	Overhead equipment				VI
5057533	303006	06/25/2015	20:31	06/26/2015	12:31	42	40284	959	Tree related-tree broken	Tree			VI
5055667	K15207	06/25/2015	20:34	06/26/2015	9:21	1	766	766	Tree related-tree broken	Overhead Secondary	Patrol/Test/Inspect	Reconnect	VI
5055671	P09307	06/25/2015	20:35	06/26/2015	4:10	1	454	454	Tree related-tree broken	Overhead Secondary	Patrol/Test/Inspect	Repair	V
5057659	349002	06/25/2015	20:35	06/27/2015	12:00	4	9457	2364	Tree related-tree broken	Tree	Patrol/Test/Inspect	Remove	VI
5055675	P77233	06/25/2015	20:37	06/26/2015	3:59	9	3972	441	Tree related-tree broken	Tree			VI
5059375	J84145	06/25/2015	20:38	06/26/2015	16:53	3	3645	1215	Tree related-tree contact				VI
151766925		06/25/2015	20:39	06/26/2015	17:13	1	1234	1233	Tree related-tree broken	Tree	Remove		VI
5055687	P77233	06/25/2015	20:39	06/26/2015	5:17	3	1553	517	Weather	Fuse	Replace - Same Size		VI
5055693	K55398	06/25/2015	20:39	06/26/2015	12:35	1	955	955	Overhead equipment	Overhead Primary	Patrol/Test/Inspect	Repair	V
5055697	J87150	06/25/2015	20:41	06/26/2015	9:20	26	19715	758	Tree related-tree broken	Tree	Trim		VI
5056797	K43386	06/25/2015	20:48	06/26/2015	10:36	18	14902	827	Overhead equipment	Pole	Patrol/Test/Inspect	Replace - Same Size	V
5055713	342004	06/25/2015	20:49	06/26/2015	14:14	17	17768	1045	Tree related-tree broken	Pole			VI
5058319	302001	06/25/2015	20:50	06/26/2015	19:37	9	12306	1367	Overhead equipment	Pole			VI
5055717	K11376	06/25/2015	20:51	06/26/2015	4:57	1	486	486	Tree related-tree broken	Overhead Service	Advise Customer	Repair	V

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5055721	H92418	06/25/2015	20:51	06/26/2015	5:14	1	502	502	Substation equipment				V
5055719	Z57516	06/25/2015	20:51	06/25/2015	22:30	6	592	98	Tree related-tree broken	Overhead Service	Repair		IV
5055725	K46388	06/25/2015	20:51	06/26/2015	4:30	1	458	458	Tree related-tree broken	Overhead Secondary	Patrol/Test/Inspect	Repair	V
5055727	P71830	06/25/2015	20:51	06/25/2015	21:57	1	65	65	Weather	Transformer Fuse	Replace - Same Size		V
5055747	K17-UNIT-1	06/25/2015	20:51	06/25/2015	20:58	825	5321	6	Weather				VI
5055733	M15375	06/25/2015	20:53	06/26/2015	3:12	1	378	378	Tree related-tree broken	Overhead Service	Repair		V
5058479	351001	06/25/2015	20:56	06/26/2015	13:35	10	9987	998	Tree related-tree broken	Tree	Remove		VI
5055739	J83137	06/25/2015	20:57	06/26/2015	8:30	1	692	692	Tree related-tree contact	Tree	Trim		VI
5055741	IP9009	06/25/2015	20:57	06/26/2015	8:15	1	677	677	Tree related-tree broken	Overhead Service	Repair		VI
5055755	J89112	06/25/2015	21:00	06/26/2015	5:52	1	531	531	Tree related-tree broken	Overhead Secondary	Raise	Repair	VI
5055759	R41131	06/25/2015	21:03	06/26/2015	0:10	1	186	186	Overhead equipment	Jumper	Repair	Repair	VI
5055763	M20221	06/25/2015	21:06	06/26/2015	17:15	1	1208	1208	Tree related-tree broken	Overhead Service	Patrol/Test/Inspect	Cut in Clear	VI
5055767	Q27185	06/25/2015	21:09	06/25/2015	21:43	49	1659	33	Weather				VI
5057495	342004	06/25/2015	21:12	06/26/2015	6:28	227	126137	555	Overhead equipment				VI
5055783	335003	06/25/2015	21:14	06/26/2015	5:41	1	506	506	Tree related-tree broken				VI
5055787	K52400	06/25/2015	21:15	06/26/2015	3:20	6	2186	364	Weather	Overhead Secondary	Patrol/Test/Inspect	Repair	V
5055789	J83137	06/25/2015	21:16	06/26/2015	16:03	16	18034	1127	Overhead equipment				VI
5055793	J18267	06/25/2015	21:18	06/26/2015	4:22	28	11841	423	Tree related-tree broken	Overhead Primary	Patrol/Test/Inspect	Repair	VI
5055795	303006	06/25/2015	21:18	06/26/2015	5:27	1	488	488	Tree related-tree contact				VI
5055803	M54314	06/25/2015	21:19	06/26/2015	0:04	1	164	164	Weather	Overhead Service	Patrol/Test/Inspect		V
5055805	M81404	06/25/2015	21:19	06/26/2015	8:14	270	176863	655	Underground equipment	Underground Transformer	Patrol/Test/Inspect	Replace - Same Size	V
5055809	P73182	06/25/2015	21:19	06/26/2015	1:55	1	275	275	Weather				VI
5055813	P73182	06/25/2015	21:20	06/26/2015	1:55	1	274	274	Weather	Fuse	Replace - Same Size	Replace - Same Size	VI
5055817	J99128	06/25/2015	21:23	06/26/2015	17:30	1	1206	1206	Overhead equipment	Overhead Service	Patrol/Test/Inspect	Repair	VI
5057663	349002	06/25/2015	21:24	06/26/2015	8:30	1	665	665	Overhead equipment	Overhead Secondary	Repair		VI
5055865	P57108	06/25/2015	21:25	06/25/2015	22:57	57	5200	91	Tree related-tree contact	Tree	Remove	Remove	VI
5055825	J18268	06/25/2015	21:27	06/26/2015	1:00	1	212	212	Weather				VI
5055827	346003	06/25/2015	21:27	06/26/2015	9:41	1	733	733	Overhead equipment	Tree			VI
5055829	351001	06/25/2015	21:28	06/26/2015	8:05	1	636	636	Tree related-tree broken	Overhead Service	Repair		VI
5055833		06/25/2015	21:30	06/26/2015	2:22	1	291	291	Tree related-tree broken				VI
5055837	M78323	06/25/2015	21:32	06/25/2015	22:24	62	3199	51	Weather	Fuse	Patrol/Test/Inspect	Replace - Same Size	V
5055849	J74125	06/25/2015	21:32	06/26/2015	2:10	153	42414	277	Overhead equipment	Lightning Arrestor	Patrol/Test/Inspect	Replace - Same Size	VI
5055839	Z57516	06/25/2015	21:32	06/26/2015	0:15	6	973	162	Tree related-tree broken	Fuse	Repair		IV
5055845	Q18243	06/25/2015	21:33	06/26/2015	11:00	1	806	806	Tree related-tree broken	Overhead Service	Patrol/Test/Inspect	Repair	VI
5055851	HC9327	06/25/2015	21:34	06/26/2015	9:12	1	697	697	Overhead equipment				VI
5055819	P57108	06/25/2015	21:35	06/25/2015	22:57	58	4722	81	Weather	Recloser	Repair	Repair	VI
5055857	Q24311	06/25/2015	21:37	06/26/2015	9:28	1	710	710	Overhead equipment	Transformer Fuse	Patrol/Test/Inspect	Repair	VI
5055917	S02501	06/25/2015	21:38	06/26/2015	6:20	199	78194	522	Tree related-tree broken	Overhead Primary	Patrol/Test/Inspect	Repair	VI
5055867	J74125	06/25/2015	21:39	06/26/2015	0:09	24	3588	149	Tree related-tree broken	Fuse	Repair	Repair	VI
5055871	349001	06/25/2015	21:40	06/26/2015	2:30	1	289	289	Overhead equipment	Overhead Transformer		Switch/Reset	VI
5055879	P62138	06/25/2015	21:43	06/26/2015	2:40	1	296	296	Overhead equipment	Overhead Transformer		Replace - Same Size	VI
5055903	J74125	06/25/2015	21:45	06/25/2015	23:02	12	920	76	Tree related-tree broken	Tree	Patrol/Test/Inspect	Remove	VI
5055897	S02502	06/25/2015	21:47	06/26/2015	7:50	30	18089	602	Tree related-tree broken	Overhead Primary	Patrol/Test/Inspect	Repair	VI
5055899	J74125	06/25/2015	21:47	06/26/2015	0:10	1	142	142	Tree related-tree broken	Tree	Patrol/Test/Inspect	Remove	VI
5055901	306001	06/25/2015	21:48	06/26/2015	1:38	44	10098	229	Tree related-tree contact				VI
5055905	K55398	06/25/2015	21:49	06/25/2015	22:51	9	556	61	Tree related-tree broken				V
5055919	J84145	06/25/2015	21:50	06/26/2015	2:02	1	251	251	Tree related-tree broken	Tree			VI
5055923	V23530	06/25/2015	21:51	06/25/2015	23:38	1	106	106	Overhead equipment	Overhead Service	Repair	Replace - Same Size	II
5055925	S02502	06/25/2015	21:52	06/26/2015	1:25	96	20411	212	Tree related-tree broken	Overhead Primary	Patrol/Test/Inspect	Repair	VI
5055927	K43386	06/25/2015	21:52	06/26/2015	8:48	68	26174	655	Tree related-tree broken	Overhead Primary		Repair	V
5056313	P12290	06/25/2015	21:53	06/26/2015	1:58	67	16388	244	Tree related-tree broken	Tree			V
5055943	K46388	06/25/2015	21:55	06/26/2015	8:30	1	634	634	Overhead equipment	Overhead Service			V
5056061	329-XD	06/25/2015	21:55	06/25/2015	23:15	2159	171381	79	Weather	Lightning Arrestor	Replace - Same Size		V
5056073	329-XW	06/25/2015	21:55	06/25/2015	23:15	1554	123045	79	Weather	Lightning Arrestor	Replace - Same Size		V
5056307	313-UNIT-1	06/25/2015	21:55	06/25/2015	23:15	1580	124867	79	Weather	Lightning Arrestor	Replace - Same Size		V
5056177	328-UNIT-1	06/25/2015	21:56	06/25/2015	23:15	868	68415	78	Weather	Lightning Arrestor	Replace - Same Size		V

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5056251	350-UNIT-1	06/25/2015	21:56	06/25/2015	23:15	1292	100801	78	Weather	Lightning Arrestor	Replace - Same Size		V
5056597	315-UNIT-1	06/25/2015	21:57	06/25/2015	23:15	984	76683	77	Weather	Lightning Arrestor	Replace - Same Size		V
5055969	Q27185	06/25/2015	21:57	06/25/2015	23:43	48	5082	105	Overhead equipment	Overhead Primary	Replace - Same Size		VI
5056907	M78325	06/25/2015	21:58	06/26/2015	8:39	28	17941	640	Overhead equipment	Overhead Primary		Replace - Same Size	V
5057075	S86-XTR1	06/25/2015	22:01	06/26/2015	1:15	1861	360885	193	Tree related-tree broken	Tree			VI
5057675	307004	06/25/2015	22:01	06/26/2015	7:47	30	17570	585	Tree related-tree broken	Overhead Primary			VI
5056905	M78325	06/25/2015	22:02	06/26/2015	7:30	1	567	567	Overhead equipment				V
5056479	339-X1	06/25/2015	22:04	06/25/2015	23:37	2226	206906	92	Substation equipment				V
5056295	K15205	06/25/2015	22:04	06/26/2015	9:29	27	18487	684	Tree related-tree broken	Overhead Primary			VI
5056385	N22295	06/25/2015	22:06	06/26/2015	4:56	42	17229	410	Tree related-tree broken	Fuse		Patrol/Test/Inspect	VI
5056665	K52400	06/25/2015	22:07	06/26/2015	0:49	31	4998	161	Weather	Fuse	Replace - Same Size		V
5056419	Y34596	06/25/2015	22:08	06/25/2015	23:07	1	58	58	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
5056435	333-UNIT-W	06/25/2015	22:08	06/25/2015	23:14	80	5253	65	Tree related-tree broken				VI
5057687	N22295	06/25/2015	22:14	06/26/2015	13:02	6	5327	887	Tree related-tree broken	Tree		Trim	VI
5056903	M78325	06/25/2015	22:14	06/26/2015	4:26	1	371	371	Overhead equipment				V
5056619	K58213	06/25/2015	22:15	06/26/2015	6:05	1	469	469	Overhead equipment	Fuse	Replace - Same Size		VI
5057671	R94271	06/25/2015	22:16	06/26/2015	5:08	24	9871	411	Overhead equipment	Lightning Arrestor	Replace - Same Size		VI
5056667	332004	06/25/2015	22:19	06/26/2015	15:08	1	1008	1008	Tree related-tree contact	Overhead Service			VI
5056813	L50215	06/25/2015	22:19	06/26/2015	5:59	13	5972	459	Overhead equipment				VI
5056777	J86108	06/25/2015	22:19	06/26/2015	8:58	24	15320	638	Tree related-tree contact				VI
5056687	J87111	06/25/2015	22:19	06/26/2015	3:08	1	288	288	Tree related-tree broken	Fuse	Replace - Same Size		VI
5056701	J86118	06/25/2015	22:20	06/26/2015	12:19	1	838	838	Tree related-tree broken				VI
5058567		06/25/2015	22:22	06/26/2015	13:52	1874	1716231	930	Tree related-tree broken	Tree			VI
5056709	J86118	06/25/2015	22:22	06/26/2015	12:17	18	15035	835	Tree related-tree broken	Fuse	Patrol/Test/Inspect		VI
5056713	J83140	06/25/2015	22:22	06/26/2015	7:26	1	543	543	Tree related-tree contact	Tree	Patrol/Test/Inspect	Trim	VI
5057173	Q69926	06/25/2015	22:23	06/26/2015	6:33	131	64148	489	Tree related-tree broken	Tree		Remove	VI
5056727	R78301	06/25/2015	22:24	06/26/2015	3:05	1	280	280	Overhead equipment	Overhead Secondary	Patrol/Test/Inspect	Repair	V
5056731	J86118	06/25/2015	22:25	06/26/2015	12:45	6	5156	859	Tree related-tree broken	Tree	Trim		VI
5056737	S02502	06/25/2015	22:27	06/26/2015	2:55	1	267	267	Tree related-tree broken	Overhead Secondary	Patrol/Test/Inspect	Repair	VI
5056743	J87111	06/25/2015	22:29	06/26/2015	3:08	1	278	278	Tree related-tree broken	Fuse	Replace - Same Size		VI
5056753	S92559	06/25/2015	22:30	06/26/2015	4:49	3	1134	378	Tree related-tree contact	Overhead Primary	Remove		VI
5057461	S92559	06/25/2015	22:31	06/26/2015	4:47	204	66406	375	Tree related-tree broken	Tree	Remove		VI
5056829	Q69926	06/25/2015	22:32	06/26/2015	9:25	104	67929	653	Overhead equipment	Overhead Primary		Repair	VI
5056779	X78536	06/25/2015	22:34	06/25/2015	23:47	1	72	72	Tree related-tree broken	Overhead Service	Repair		IV
5056781	R05115	06/25/2015	22:34	06/26/2015	0:13	1	98	98	Animal related	Transformer Fuse	Replace - Same Size		I
5056783	S92559	06/25/2015	22:34	06/26/2015	4:48	1	373	373	Overhead equipment	Overhead Primary	Remove		VI
5056789	J84123	06/25/2015	22:36	06/26/2015	7:48	1	551	551	Overhead equipment				VI
5056791	374052	06/25/2015	22:37	06/26/2015	1:45	20	3771	188	Overhead equipment	Pole	Repair		VI
5056793	342002	06/25/2015	22:37	06/26/2015	20:00	1	1282	1282	Tree related-tree broken	Overhead Service			VI
5056795	X60596	06/25/2015	22:39	06/25/2015	23:08	4	115	28	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
5056807	UE2001	06/25/2015	22:39	06/26/2015	2:17	2	434	217	Substation equipment	Substation Misc.	Repair		V
5056809	S02502	06/25/2015	22:40	06/26/2015	5:21	1	400	400	Tree related-tree broken	Overhead Primary		Repair	VI
5056819	J89112	06/25/2015	22:44	06/26/2015	6:30	1	465	465	Unknown				VI
5056823	X02548	06/25/2015	22:44	06/26/2015	1:20	14	2180	155	Tree related-tree broken	Fuse	Replace - Same Size		IV
5056825	J86118	06/25/2015	22:44	06/26/2015	12:09	7	5635	805	Tree related-tree broken	Fuse	Patrol/Test/Inspect		VI
5056827	S02502	06/25/2015	22:44	06/26/2015	5:40	1	415	415	Tree related-tree broken	Overhead Primary	Patrol/Test/Inspect	Repair	VI
5056833	Q27185	06/25/2015	22:46	06/26/2015	1:58	1	191	191	Weather	Fuse	Replace - Same Size		VI
5056837	K55398	06/25/2015	22:46	06/25/2015	23:17	1	30	30	Tree related-tree broken				V
5056839	P57103	06/25/2015	22:48	06/26/2015	1:02	1	133	133	Tree related-tree contact				VI
5056843	R73841	06/25/2015	22:50	06/26/2015	1:50	1	179	179	Weather	Overhead Primary	Repair		V
5056859	Q54908	06/25/2015	22:51	06/26/2015	5:09	110	41621	378	Overhead equipment	Ground Wire	Repair		VI
5056851	342003	06/25/2015	22:53	06/26/2015	14:18	1	924	924	Transmission outage	Overhead Primary			VI
5056853	Y66557	06/25/2015	22:53	06/25/2015	23:40	1	46	46	Weather	Transformer Fuse	Replace - Same Size		IV
5057463	S92559	06/25/2015	22:53	06/26/2015	5:24	1	390	390	Overhead equipment	Overhead Primary	Replace - Same Size	Repair	VI
5056871	J86118	06/25/2015	22:56	06/26/2015	12:01	1	784	784	Overhead equipment	Crossarm	Replace - Same Size		VI
5056873	Q54908	06/25/2015	22:56	06/26/2015	5:00	1	363	363	Overhead equipment	Overhead Primary	Replace - Same Size	Replace - Same Size	VI

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5056877	Y35513	06/25/2015	22:58	06/26/2015	1:20	1	141	141	Weather	Fuse	Repair		IV
5056879	349001	06/25/2015	22:59	06/26/2015	13:03	1	843	843	Tree related-tree contact	Overhead Transformer		Replace - Same Size	VI
5058473	351001	06/25/2015	23:02	06/26/2015	13:35	59	51494	872	Tree related-tree broken	Tree	Remove		VI
5056961	M54292	06/25/2015	23:04	06/26/2015	8:20	50	27757	555	Tree related-tree broken	Pole		Replace - Same Size	V
5056897	Q64919	06/25/2015	23:05	06/26/2015	4:26	7	2242	320	Tree related-tree broken	Overhead Primary	Remove		VI
5056895	K32915	06/25/2015	23:06	06/26/2015	0:43	1	96	96	Tree related-tree broken	Fuse			VI
5056899	K55398	06/25/2015	23:07	06/25/2015	23:21	1	13	13	Tree related-tree broken				V
5056901	J74125	06/25/2015	23:08	06/26/2015	2:15	1	186	186	Tree related-tree broken	Tree	Patrol/Test/Inspect	Remove	VI
5056909	Q54908	06/25/2015	23:09	06/26/2015	5:00	1	350	350	Overhead equipment	Overhead Primary	Repair	Repair	VI
5056921	Q64919	06/25/2015	23:13	06/26/2015	5:01	1	347	347	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	VI
5056927	Q64919	06/25/2015	23:15	06/26/2015	5:01	1	345	345	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	VI
5056933	328119	06/25/2015	23:19	06/26/2015	1:33	1	133	133	Substation equipment	Substation Misc.	Repair		V
5056937	K32915	06/25/2015	23:19	06/26/2015	8:10	1	530	530	Tree related-tree broken	Fuse	Replace - Same Size		VI
5056939	Q64919	06/25/2015	23:19	06/26/2015	5:01	1	341	341	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	VI
5057707	K15205	06/25/2015	23:20	06/26/2015	6:04	29	11740	404	Overhead equipment				VI
5056943	Q64919	06/25/2015	23:20	06/26/2015	5:01	1	340	340	Overhead equipment				VI
5056945	329146	06/25/2015	23:20	06/26/2015	1:29	1	128	128	Substation equipment	Substation Misc.	Repair		V
5056947	Q64919	06/25/2015	23:21	06/26/2015	5:01	1	339	339	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	VI
5056951	374068	06/25/2015	23:21	06/26/2015	1:58	1	156	156	Overhead equipment				VI
5056973	R28870	06/25/2015	23:22	06/26/2015	3:02	46	9990	219	Weather	Overhead Primary	Repair	Repair	V
5056967	341002	06/25/2015	23:23	06/26/2015	10:26	1	662	662	Overhead equipment	Overhead Service	Repair		VI
5056969	K55398	06/25/2015	23:23	06/26/2015	1:54	6	903	150	Tree related-tree contact				V
5057281	S86-XTR2	06/25/2015	23:23	06/26/2015	1:15	1225	136489	111	Tree related-tree broken	Tree			VI
5056993	K32915	06/25/2015	23:26	06/26/2015	0:56	1	89	89	Tree related-tree broken	Fuse	Replace - Same Size		VI
5057003	K55398	06/25/2015	23:26	06/26/2015	1:57	1	150	150	Tree related-tree contact				V
5057037	S88503	06/25/2015	23:28	06/26/2015	4:05	4	1105	276	Tree related-tree contact	Tree			VI
5057459	S52515	06/25/2015	23:30	06/26/2015	3:40	294	73441	249	Tree related-tree broken	Overhead Primary	Patrol/Test/Inspect	Repair	VI
5057127	K15205	06/25/2015	23:34	06/26/2015	7:34	1	479	479	Tree related-tree broken	Overhead Primary	Trim		VI
5057373	S04512	06/25/2015	23:36	06/26/2015	4:40	8	2428	303	Tree related-tree broken	Overhead Primary	Raise	Raise	VI
5057187	S22-XTR2	06/25/2015	23:40	06/26/2015	0:48	722	49059	67	Tree related-tree broken				VI
5057207	S09-XTR1	06/25/2015	23:40	06/26/2015	0:49	1837	126293	68	Tree related-tree broken				VI
5057215	S22-XTR1	06/25/2015	23:40	06/26/2015	0:49	1630	111981	68	Tree related-tree broken				VI
5057203	329145	06/25/2015	23:40	06/26/2015	1:31	1	110	110	Substation equipment	Substation Misc.	Repair		V
5057211	Q64919	06/25/2015	23:41	06/26/2015	5:01	1	319	319	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	VI
5057209	339160	06/25/2015	23:41	06/26/2015	1:00	1	78	78	Substation equipment	Substation Misc.	Repair		V
5057279	HD0-X-1	06/25/2015	23:41	06/26/2015	8:08	1012	144423	507	Tree related-tree broken	Tree		Remove	VI
5057229	S15560	06/25/2015	23:41	06/26/2015	6:00	8	3027	378	Weather	Fuse	Replace - Same Size		VI
5057247	S87542	06/25/2015	23:42	06/26/2015	3:17	1	214	214	Tree related-tree broken	Tree			VI
5057257	328120	06/25/2015	23:43	06/26/2015	4:00	8	2056	256	Overhead equipment	Fuse	Replace - Same Size		V
5057267	339161	06/25/2015	23:43	06/26/2015	1:00	1	76	76	Substation equipment	Substation Misc.	Repair		V
5057303	J87150	06/25/2015	23:49	06/26/2015	6:18	33	12816	388	Tree related-tree contact	Tree	Trim	Trim	VI
5057919	L62928	06/25/2015	23:52	06/26/2015	12:19	41	30588	746	Tree related-tree broken	Overhead Primary	Repair	Repair	VI
5057319	J74125	06/25/2015	23:53	06/26/2015	2:15	1	141	141	Tree related-tree broken	Tree	Patrol/Test/Inspect	Remove	VI
5057321	T22508	06/25/2015	23:53	06/26/2015	6:40	54	21928	406	Tree related-tree broken	Overhead Primary	Repair	Replace - Same Size	VI
5057333	S47575	06/25/2015	23:56	06/26/2015	2:55	1	178	178	Weather				VI
5058103	J86118	06/25/2015	23:56	06/26/2015	8:29	26	13340	513	Tree related-tree contact				VI
5057371	S01501	06/25/2015	23:59	06/26/2015	8:59	42	22654	539	Tree related-tree broken	Tree	Trim		VI
5057357	S55534	06/26/2015	0:00	06/26/2015	2:25	3	434	144	Tree related-tree broken	Fuse			VI
5057359	340101	06/26/2015	0:00	06/26/2015	1:19	1	78	78	Overhead equipment				V
5057363	339161	06/26/2015	0:04	06/26/2015	1:35	1	90	90	Substation equipment	Substation Misc.	Repair		V
5057365	S55534	06/26/2015	0:04	06/26/2015	2:31	1	146	146	Tree related-tree broken	Overhead Primary			VI
5057377	S03529	06/26/2015	0:07	06/26/2015	7:20	1	432	432	Tree related-tree broken	Overhead Service	Repair	Replace - Same Size	VI
5057379	HB6283	06/26/2015	0:07	06/26/2015	4:46	22	6138	279	Tree related-tree contact				VI
5057429	351002	06/26/2015	0:09	06/26/2015	9:00	25	13258	530	Overhead equipment	Tree	Trim		VI
5057387	342003	06/26/2015	0:10	06/26/2015	5:27	590	186812	316	Tree related-tree broken	Overhead Primary	Patrol/Test/Inspect		VI
5057389	S55534	06/26/2015	0:11	06/26/2015	2:33	1	141	141	Tree related-tree broken	Overhead Primary			VI

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5057399	T05539	06/26/2015	0:18	06/26/2015	4:20	8	1930	241	Overhead equipment				VI
151770146	S22593	06/26/2015	0:19	06/26/2015	0:45	1	26	26	Tree related-tree broken	Tree			VI
5057433	303004	06/26/2015	0:20	06/26/2015	13:40	29	23174	799	Tree related-tree broken	Overhead Primary	Repair		VI
5057407	K55398	06/26/2015	0:23	06/26/2015	1:46	1	82	82	Tree related-tree broken				V
5057413	303004	06/26/2015	0:29	06/27/2015	19:05	1	2555	2555	Tree related-tree broken				VI
5057415	303007	06/26/2015	0:32	06/26/2015	19:59	13	15171	1167	Tree related-tree broken	Tree	Remove	Remove	VI
5057421	P09307	06/26/2015	0:34	06/26/2015	3:50	1	195	195	Overhead equipment				V
5057423	342001	06/26/2015	0:34	06/26/2015	19:00	1	1105	1105	Tree related-tree broken	Tree	Remove		VI
5057447	HB6281	06/26/2015	0:55	06/26/2015	6:00	17	5179	304	Overhead equipment				VI
5057473	L93132	06/26/2015	0:55	06/26/2015	1:56	241	14657	60	Overhead equipment				VI
5057467	M09143	06/26/2015	1:00	06/26/2015	6:10	1	309	309	Overhead equipment	Fuse	Replace - Same Size	Repair	VI
5057477	302004	06/26/2015	1:04	06/26/2015	10:22	1	557	557	Tree related-tree broken	Overhead Secondary			VI
5057485	K27150	06/26/2015	1:10	06/26/2015	3:47	51	7976	156	Overhead equipment	Overhead Primary	Repair	Repair	VI
5057487	K55398	06/26/2015	1:18	06/26/2015	2:00	1	41	41	Tree related-tree broken				V
5057497	J87111	06/26/2015	1:26	06/26/2015	3:08	1	101	101	Tree related-tree broken	Fuse	Replace - Same Size		VI
5057501	302004	06/26/2015	1:31	06/26/2015	18:00	1	988	988	Tree related-tree broken	Overhead Service			VI
5057503	303001	06/26/2015	1:32	06/26/2015	17:36	1	963	963	Tree related-tree contact	Tree		Remove	VI
5057505	HA5431	06/26/2015	1:32	06/26/2015	2:43	1	70	70	Weather	Transformer Fuse	Replace - Same Size		V
5057509	K32915	06/26/2015	1:36	06/26/2015	8:10	1	393	393	Tree related-tree broken	Overhead Primary	Repair		VI
5057511	S88502	06/26/2015	1:39	06/26/2015	2:06	212	5660	26	Tree related-tree broken				VI
5057513	S88502	06/26/2015	1:39	06/26/2015	2:06	263	7022	26	Tree related-tree broken				VI
5057515	S88502	06/26/2015	1:39	06/26/2015	2:06	447	11934	26	Tree related-tree broken				VI
5057681	303007	06/26/2015	1:40	06/26/2015	16:00	20	17192	859	Overhead equipment	Overhead Primary			VI
5057521	306003	06/26/2015	1:46	06/26/2015	15:03	1	797	796	Tree related-tree contact	Overhead Service			VI
5057527	303007	06/26/2015	1:50	06/26/2015	6:06	34	8720	256	Tree related-tree broken				VI
5057529	T16528	06/26/2015	1:52	06/26/2015	2:42	200	9900	49	Tree related-tree broken				VI
5057541	S88502	06/26/2015	2:08	06/26/2015	6:19	1	250	250	Overhead equipment	Overhead Primary			VI
5057543	K55398	06/26/2015	2:13	06/26/2015	4:38	1	144	144	Tree related-tree broken				V
5057547	S22593	06/26/2015	2:15	06/26/2015	3:50	1	94	94	Weather	Transformer Fuse			VI
5057549	T16528	06/26/2015	2:15	06/26/2015	3:24	1	68	68	Overhead equipment				VI
5057551	S88502	06/26/2015	2:15	06/26/2015	6:16	1	240	240	Overhead equipment	Overhead Primary	Repair		VI
5057555	S88502	06/26/2015	2:19	06/26/2015	6:36	1	256	256	Overhead equipment	Overhead Primary			VI
5057559	J84145	06/26/2015	2:25	06/26/2015	8:17	7	2461	351	Tree related-tree contact	Fuse	Replace - Same Size	Replace - Same Size	VI
5057565	K15205	06/26/2015	2:27	06/26/2015	7:46	1	318	318	Overhead equipment				VI
5057567	J97115	06/26/2015	2:27	06/26/2015	3:30	2	126	63	Overhead equipment				VI
5057569	J84145	06/26/2015	2:29	06/26/2015	8:17	2	695	347	Tree related-tree contact	Fuse	Replace - Same Size	Replace - Same Size	VI
5057573	T12528	06/26/2015	2:36	06/26/2015	5:30	1	173	173	Weather				VI
5057575	K55398	06/26/2015	2:38	06/26/2015	8:10	21	6965	331	Weather	Overhead Primary			V
5057587	M78325	06/26/2015	2:44	06/26/2015	4:14	2	178	89	Weather	Transformer Fuse	Replace - Same Size		V
5057601	S86580	06/26/2015	2:56	06/26/2015	5:28	1	152	152	Tree related-tree broken	Tree			VI
5057603	P42230	06/26/2015	2:59	06/26/2015	16:30	1	810	810	Overhead equipment	Overhead Primary	Replace - Same Size		VI
5057615	B84002	06/26/2015	3:09	06/26/2015	4:51	14	1427	101	Overhead equipment	Pole	Repair		I
5057617	Q54908	06/26/2015	3:10	06/26/2015	5:09	202	24102	119	Overhead equipment	Overhead Primary	Repair	Repair	VI
5057619	K43386	06/26/2015	3:13	06/26/2015	4:44	1	90	90	Weather				V
5057621	K55398	06/26/2015	3:17	06/26/2015	4:32	1	74	74	Overhead equipment	Overhead Service			V
5057625	303001	06/26/2015	3:23	06/26/2015	12:31	1	547	547	Tree related-tree contact	Overhead Service			VI
5057627	J86118	06/26/2015	3:26	06/26/2015	16:15	1	768	768	Tree related-tree broken	Overhead Secondary	Patrol/Test/Inspect	Repair	VI
5057629	S55535	06/26/2015	3:32	06/26/2015	7:40	1	247	247	Tree related-tree broken	Overhead Secondary			VI
5057637	S88503	06/26/2015	3:50	06/26/2015	4:04	1	13	13	Tree related-tree broken	Tree			VI
5057645	349002	06/26/2015	4:06	06/26/2015	9:00	6	1762	293	Overhead equipment	Overhead Primary			VI
5057647	L99392	06/26/2015	4:06	06/26/2015	5:41	1	94	94	Overhead equipment	Fuse	Replace - Same Size		V
5057667	311001	06/26/2015	4:20	06/26/2015	15:38	1	677	677	Overhead equipment	Fuse			VI
5057669	302001	06/26/2015	4:25	06/26/2015	14:44	6	3712	618	Overhead equipment				VI
5057677	Q64919	06/26/2015	4:45	06/26/2015	5:02	2	33	16	Tree related-tree broken				VI
5057683	R73841	06/26/2015	4:49	06/26/2015	7:38	1	168	168	Weather	Transformer Fuse	Replace - Same Size		V
5057685	H06135	06/26/2015	4:55	06/26/2015	8:00	1	184	184	Overhead equipment	Overhead Transformer			IV

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5058649	307001	06/26/2015	5:18	06/26/2015	22:07	62	62597	1009	Overhead equipment	Pole			VI
5057701	P42230	06/26/2015	5:30	06/26/2015	6:35	1	64	64	Tree related-tree broken	Fuse		Patrol/Test/Inspect	VI
5057705	X86543	06/26/2015	5:31	06/26/2015	7:21	1	109	109	Weather	Transformer Fuse	Replace - Same Size		IV
5057713	Q69926	06/26/2015	5:41	06/26/2015	9:25	71	15875	223	Tree related-tree broken	Overhead Primary	Repair		VI
5058083	302002	06/26/2015	5:42	06/26/2015	15:18	12	6906	575	Tree related-tree contact	Other	Patrol/Test/Inspect		VI
5057723	U84587	06/26/2015	5:47	06/26/2015	6:40	1	52	52	Weather	Fuse	Replace - Same Size		II
5057727	K46389	06/26/2015	5:53	06/26/2015	8:05	1	131	131	Weather	Fuse	Replace - Same Size		V
5057731	J86118	06/26/2015	5:56	06/26/2015	8:27	19	2869	151	Tree related-tree contact				VI
5057733	J86118	06/26/2015	6:01	06/26/2015	11:21	1	319	319	Overhead equipment				VI
5057755	301052	06/26/2015	6:03	06/26/2015	14:26	534	221384	502	Weather	Overhead Primary	Patrol/Test/Inspect	Repair	VI
5057757	303006	06/26/2015	6:09	06/26/2015	12:26	1	376	376	Tree related-tree broken	Transformer Fuse			VI
5057759	303006	06/26/2015	6:10	06/26/2015	10:20	1	249	249	Tree related-tree broken	Overhead Secondary			VI
5057769	B25002	06/26/2015	6:18	06/26/2015	6:33	352	5096	14	Substation equipment				I
5058269	342003	06/26/2015	6:19	06/26/2015	17:20	1	660	660	Tree related-tree contact	Overhead Service			VI
5057765	335003	06/26/2015	6:20	06/26/2015	12:49	12	4667	388	Tree related-tree broken	Overhead Primary	Repair		VI
5057771	S86582	06/26/2015	6:20	06/26/2015	6:57	1	36	36	Weather	Disconnect Switch	Repair		VI
5057779	Q69926	06/26/2015	6:23	06/26/2015	6:28	32	157	4	Weather				VI
5057781	J86118	06/26/2015	6:23	06/26/2015	12:08	15	2452	345	Overhead equipment				VI
5057787	Q74150	06/26/2015	6:25	06/26/2015	7:25	1	59	59	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
5057797	B25002	06/26/2015	6:35	06/26/2015	6:38	1	2	2	Unknown				I
5057809	J86118	06/26/2015	6:41	06/26/2015	15:56	1	554	554	Tree related-tree broken	Fuse			VI
5057813	311003	06/26/2015	6:43	06/26/2015	15:38	21	11225	534	Overhead equipment	Fuse			VI
5057815	B25002	06/26/2015	6:48	06/26/2015	9:40	1	171	171	Other				I
5057827	A68001	06/26/2015	6:49	06/26/2015	9:44	34	5945	174	Overhead equipment	Jumper	Patrol/Test/Inspect	Repair	I
5057819	J74125	06/26/2015	6:50	06/26/2015	8:35	1	104	104	Overhead equipment	Overhead Service			VI
5057823	J74125	06/26/2015	6:51	06/26/2015	9:08	1	136	136	Overhead equipment	Overhead Transformer			VI
5057829	B25002	06/26/2015	6:55	06/26/2015	9:19	1	143	143	Other				I
5057831	R73841	06/26/2015	6:57	06/26/2015	8:00	1	62	62	Weather	Transformer Fuse	Replace - Same Size		V
5057851	349002	06/26/2015	7:05	06/26/2015	9:00	8	912	114	Overhead equipment	Overhead Service	Repair		VI
5057943	IP9009	06/26/2015	7:09	06/26/2015	12:19	483	149309	309	Other				VI
5057867	351001	06/26/2015	7:10	06/26/2015	9:03	1	112	112	Overhead equipment	Overhead Primary	Repair		VI
5058295	M15375	06/26/2015	7:10	06/26/2015	10:16	443	82331	185	Tree related-tree broken				V
5057871	D36001	06/26/2015	7:10	06/26/2015	8:53	4	408	102	Overhead equipment	Fuse	Replace - Same Size		I
5057903	340102	06/26/2015	7:16	06/26/2015	8:54	1	97	97	Overhead equipment	Overhead Primary	Repair		V
5057909	Q21293	06/26/2015	7:16	06/26/2015	20:10	7	5415	773	Overhead equipment	Fuse		Replace - Same Size	VI
5057983	R73841	06/26/2015	7:19	06/26/2015	9:16	11	1278	116	Weather	Transformer Fuse	Replace - Same Size		V
5057921	B76001	06/26/2015	7:20	06/26/2015	10:33	1	192	192	Underground equipment	Underground Service	Patrol/Test/Inspect	Repair	I
5057923	K67912	06/26/2015	7:21	06/26/2015	8:20	4	235	58	Tree related-tree broken	Tree	Remove		VI
5058177	M15375	06/26/2015	7:28	06/26/2015	10:15	13	2169	166	Overhead equipment	Overhead Primary	Replace - Same Size		V
5057951	X86543	06/26/2015	7:29	06/26/2015	10:30	1	180	180	Weather	Overhead Transformer	Replace - Same Size	Replace - Same Size	IV
5057961	341002	06/26/2015	7:35	06/26/2015	20:30	1	774	774	Tree related-tree broken	Tree	Trim	Trim	VI
5057965	349002	06/26/2015	7:35	06/26/2015	8:30	1	54	54	Overhead equipment	Overhead Secondary	Repair		VI
5057967	303006	06/26/2015	7:37	06/26/2015	10:05	1	147	147	Unknown				VI
5057975	N93260	06/26/2015	7:41	06/26/2015	8:28	1	46	46	Overhead equipment	Transformer Fuse		Replace - Same Size	III
5057979	J85160	06/26/2015	7:41	06/26/2015	9:10	1	88	88	Weather	Fuse	Replace - Same Size		VI
5057981	S02501	06/26/2015	7:41	06/26/2015	8:30	1	48	48	Tree related-tree broken	Overhead Service	Patrol/Test/Inspect	Repair	VI
5057987	351002	06/26/2015	7:42	06/26/2015	9:20	1	97	97	Tree related-tree broken				VI
5058267	342004	06/26/2015	7:45	06/26/2015	10:16	486	73716	151	Tree related-tree contact				VI
5058283	342004	06/26/2015	7:45	06/26/2015	16:56	17	9368	551	Tree related-tree contact	Tree	Trim		VI
5058003	R41131	06/26/2015	7:46	06/26/2015	8:44	1	57	57	Overhead equipment	Overhead Primary			VI
5058009	V82551	06/26/2015	7:50	06/26/2015	10:44	1	173	173	Tree related-tree broken	Overhead Primary	Repair	Repair	II
5058031	S88553	06/26/2015	7:59	06/26/2015	12:01	1	241	241	Overhead equipment	Overhead Service	Patrol/Test/Inspect	Repair	VI
5058041	S88553	06/26/2015	8:00	06/26/2015	12:19	1	258	258	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	VI
5058089	M78325	06/26/2015	8:00	06/26/2015	8:36	32	1149	35	Tree related-tree contact				V
5058045	351002	06/26/2015	8:01	06/26/2015	9:00	1	58	58	Overhead equipment	Overhead Secondary	Repair		VI
5058047	M21134	06/26/2015	8:02	06/26/2015	14:35	8	3141	392	Overhead equipment	Pole	Patrol/Test/Inspect	Replace - Same Size	VI

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5058057	341002	06/26/2015	8:09	06/26/2015	9:22	1	72	72	Tree related-tree broken	Overhead Service	Cut in Clear	Repair	VI
5058059	J86118	06/26/2015	8:09	06/26/2015	12:12	1	242	242	Overhead equipment				VI
5058277	342004	06/26/2015	8:10	06/26/2015	17:02	1	531	531	Tree related-tree contact	Overhead Service	Repair		VI
5058061	P57108	06/26/2015	8:10	06/26/2015	9:37	1	86	86	Other	Connector	Repair		VI
5058073	Q83149	06/26/2015	8:15	06/26/2015	11:18	1	182	182	Weather	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	VI
5058419	342004	06/26/2015	8:19	06/26/2015	13:03	20	5673	283	Tree related-tree contact	Overhead Primary	Replace - Same Size		VI
5058085	347001	06/26/2015	8:20	06/26/2015	9:26	2	131	65	Tree related-tree contact				VI
5058087	K15205	06/26/2015	8:21	06/26/2015	9:29	159	10689	67	Overhead equipment	Recloser	Repair	Repair	VI
5058099	M81404	06/26/2015	8:26	06/26/2015	8:44	1	17	17	Weather	Overhead Service			V
5058105	M54292	06/26/2015	8:29	06/26/2015	9:40	1	70	70	Tree related-tree broken	Overhead Service	Patrol/Test/Inspect	Repair	V
5058107	J89126	06/26/2015	8:32	06/26/2015	10:25	1	112	112	Tree related-tree broken	Overhead Service	Repair		VI
5058109	M81404	06/26/2015	8:33	06/26/2015	8:49	1	15	15	Weather	Overhead Service			V
5058111	Q27185	06/26/2015	8:34	06/26/2015	11:31	1	176	176	Tree related-tree broken	Overhead Service			VI
5058199	X60596	06/26/2015	8:40	06/26/2015	10:04	35	2923	83	Overhead equipment	Fuse	Replace - Same Size		IV
5058141	L93133	06/26/2015	8:51	06/26/2015	15:56	4	1699	424	Overhead equipment	Overhead Primary	Patrol/Test/Inspect	Repair	VI
5058387	302001	06/26/2015	8:52	06/27/2015	12:43	6	10021	1670	Tree related-tree broken	Tree	Trim		VI
5058153	P47122	06/26/2015	8:54	06/26/2015	13:35	5	1404	280	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	I
5058155	346002	06/26/2015	8:54	06/26/2015	16:59	1	484	484	Tree related-tree contact	Overhead Service	Patrol/Test/Inspect		VI
5058173	P73157	06/26/2015	9:02	06/26/2015	10:18	1	75	75	Overhead equipment				VI
5058179	S01501	06/26/2015	9:07	06/26/2015	10:02	42	2302	54	Tree related-tree broken	Pole	Repair	Replace - Same Size	VI
5058181	J39392	06/26/2015	9:07	06/26/2015	11:26	1	138	138	Animal related	Fuse		Replace - Same Size	III
5058185	T16528	06/26/2015	9:13	06/26/2015	9:40	1	26	26	Overhead equipment	Fuse		Replace - Same Size	VI
5058189	K55398	06/26/2015	9:17	06/26/2015	10:24	1	66	66	Tree related-tree broken	Pole		Replace - Same Size	V
5058193	M81404	06/26/2015	9:19	06/26/2015	15:17	1	357	357	Weather	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	V
5058203	Z57516	06/26/2015	9:22	06/26/2015	10:55	1	92	92	Weather	Transformer Fuse			IV
5058207	346004	06/26/2015	9:26	06/26/2015	15:32	1	365	365	Weather	Fuse			VI
5058211	Q04411	06/26/2015	9:28	06/26/2015	13:41	1	252	252	Underground equipment	Underground Service	Repair	Repair	III
5058217	V82551	06/26/2015	9:32	06/26/2015	10:43	36	2526	70	Overhead equipment	Overhead Primary	Replace - Same Size		II
5058223	J87120	06/26/2015	9:38	06/26/2015	16:17	1	398	398	Tree related-tree broken	Pole	Patrol/Test/Inspect	Repair	VI
5058399	J84145	06/26/2015	9:39	06/26/2015	21:08	3	2065	688	Overhead equipment	Pole	Patrol/Test/Inspect		VI
5058227	303001	06/26/2015	9:41	06/26/2015	11:12	1	90	90	Tree related-tree contact	Other			VI
5058229	Y83-XTR2	06/26/2015	9:42	06/26/2015	10:42	8	475	59	Tree related-tree broken	Tree	Remove		IV
5058233	IP9009	06/26/2015	9:44	06/26/2015	18:15	1	510	510	Tree related-tree broken	Overhead Service			VI
5058235	335003	06/26/2015	9:45	06/26/2015	15:00	4	1259	314	Weather	Overhead Transformer	Patrol/Test/Inspect	Replace - New Size	VI
5058237	342003	06/26/2015	9:45	06/26/2015	12:28	1	162	162	Tree related-tree contact	Overhead Secondary	Repair		VI
5058279	342004	06/26/2015	9:46	06/26/2015	11:30	1	103	103	Unknown				VI
5058243	Y83-XBK1	06/26/2015	9:50	06/26/2015	10:42	1	51	51	Tree related-tree broken	Tree	Remove		IV
5058247	303006	06/26/2015	9:53	06/26/2015	10:27	1	33	33	Tree related-tree broken	Overhead Secondary			VI
5058249	R05186	06/26/2015	9:55	06/26/2015	10:30	51	1778	34	Overhead equipment	Fuse	Replace - Same Size	Patrol/Test/Inspect	I
5058251	X60596	06/26/2015	9:55	06/26/2015	10:44	10	483	48	Overhead equipment				IV
5058255	Q10702	06/26/2015	9:57	06/26/2015	20:19	1	621	621	Weather	Overhead Transformer		Replace - Same Size	V
5058257	303006	06/26/2015	9:59	06/26/2015	17:22	1	442	442	Tree related-tree contact				VI
5058259	R66470	06/26/2015	10:00	06/26/2015	11:47	1	106	106	Tree related-tree broken	Overhead Service	Raise	Reconnect	IV
5058263	S01501	06/26/2015	10:07	06/26/2015	14:09	42	10152	241	Tree related-tree broken	Pole			VI
5058291	303004	06/26/2015	10:13	06/26/2015	14:14	1	240	240	Tree related-tree contact	Transformer Fuse			VI
5058293	D92002	06/26/2015	10:15	06/26/2015	11:45	41	3688	89	Overhead equipment				I
5058303	334001	06/26/2015	10:21	06/26/2015	11:21	1	59	59	Tree related-tree contact	Other			VI
5058305	K95204	06/26/2015	10:22	06/26/2015	11:27	1	64	64	Overhead equipment	Overhead Service	Repair		III
5058311	324002	06/26/2015	10:25	06/26/2015	13:46	1	200	200	Overhead equipment	Overhead Primary	Replace - Same Size	Replace - Same Size	VI
5058787	342004	06/26/2015	10:26	06/26/2015	14:20	11	2565	233	Tree related-tree broken	Fuse	Replace - Same Size		VI
5058313	M15375	06/26/2015	10:26	06/26/2015	12:00	1	93	93	Overhead equipment				V
5058329	K55398	06/26/2015	10:32	06/26/2015	10:47	1	14	14	Tree related-tree broken	Pole	Patrol/Test/Inspect		V
5058333	337002	06/26/2015	10:33	06/26/2015	10:50	11	176	16	Overhead equipment	Overhead Primary	Repair		VI
5058337	J89125	06/26/2015	10:34	06/26/2015	17:24	12	4917	409	Underground equipment	Underground Secondary	Repair		VI
5058343	K43386	06/26/2015	10:37	06/26/2015	10:48	18	193	10	Overhead equipment				V
5058347	L70127	06/26/2015	10:38	06/26/2015	12:22	7	723	103	Overhead equipment	Fuse	Replace - Same Size		IV

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5058345	Q32170	06/26/2015	10:38	06/26/2015	12:52	1	133	133	Weather	Transformer Fuse	Replace - Same Size	Repair	I
5058351	L70127	06/26/2015	10:40	06/26/2015	12:21	9	907	100	Overhead equipment	Fuse	Replace - Same Size		IV
5058357	M78325	06/26/2015	10:41	06/26/2015	15:15	5	1365	273	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	V
5058361	347001	06/26/2015	10:44	06/26/2015	14:20	36	7754	215	Tree related-tree broken	Overhead Primary	Repair		VI
5058365	A91003	06/26/2015	10:46	06/26/2015	15:55	36	11107	308	Underground equipment	Fuse		Replace - Same Size	I
5058369	303007	06/26/2015	10:47	06/26/2015	14:40	1	232	232	Tree related-tree broken	Overhead Service	Patrol/Test/Inspect	Cut in Clear	VI
5058377	R49275	06/26/2015	10:50	06/26/2015	20:40	2	1178	589	Overhead equipment	Other			VI
5058375	R73841	06/26/2015	10:50	06/26/2015	11:39	2	98	49	Weather	Transformer Fuse	Replace - Same Size		V
5058383	Q63835	06/26/2015	10:53	06/26/2015	14:23	1	210	210	Overhead equipment	Other			V
5058389	K43386	06/26/2015	10:56	06/26/2015	13:32	18	2794	155	Overhead equipment	Pole	Repair	Replace - Same Size	V
5058391	303007	06/26/2015	10:58	06/27/2015	12:38	5	7698	1539	Tree related-tree broken	Overhead Service		Replace - Same Size	VI
5058395	P73182	06/26/2015	10:58	06/26/2015	12:26	1	87	87	Overhead equipment	Transformer Fuse	Replace - Same Size		VI
5058393	339162	06/26/2015	10:58	06/26/2015	11:48	1	49	49	Tree related-tree broken	Overhead Service	Repair		V
5058397	T46003	06/26/2015	10:59	06/26/2015	12:25	1	86	85	Tree related-tree contact	Other			VI
5058409	T46003	06/26/2015	11:01	06/26/2015	12:59	1	117	117	Tree related-tree contact	Other			VI
5058433	J97115	06/26/2015	11:08	06/26/2015	12:02	1	53	53	Weather	Overhead Service		Repair	VI
5058435	T46003	06/26/2015	11:09	06/26/2015	13:13	1	123	123	Tree related-tree contact	Other			VI
5058443	307004	06/26/2015	11:10	06/26/2015	14:30	1	199	199	Overhead equipment	Overhead Service			VI
5058445	335003	06/26/2015	11:11	06/26/2015	12:50	1	98	98	Tree related-tree contact	Overhead Secondary			VI
5058455	R33126	06/26/2015	11:11	06/26/2015	13:39	22	3245	147	Overhead equipment				I
5058451	R33126	06/26/2015	11:13	06/26/2015	13:38	1	144	144	Overhead equipment	Fuse	Replace - Same Size	Patrol/Test/Inspect	I
5058463	P62112	06/26/2015	11:19	06/26/2015	15:15	8	1883	235	Tree related-tree broken	Overhead Service		Repair	VI
5058481	349001	06/26/2015	11:24	06/26/2015	13:54	6	898	149	Tree related-tree contact	Overhead Service	Repair		VI
5058483	342003	06/26/2015	11:24	06/26/2015	17:11	1	346	346	Tree related-tree broken	Overhead Primary			VI
5058487	R33126	06/26/2015	11:25	06/26/2015	13:38	1	132	132	Overhead equipment	Fuse	Replace - Same Size	Patrol/Test/Inspect	I
5058489	IP9009	06/26/2015	11:25	06/26/2015	11:58	1	32	32	Other				VI
5058625	Q74149	06/26/2015	11:36	06/26/2015	16:05	4	1074	268	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
5058631	T46003	06/26/2015	11:41	06/26/2015	15:43	1	241	241	Underground equipment				VI
5058637	J84123	06/26/2015	11:45	06/27/2015	0:07	1	741	741	Tree related-tree broken	Overhead Service	Replace - Same Size		VI
5058731	Y04504	06/26/2015	11:51	06/26/2015	13:18	42	3661	87	Overhead equipment	Fuse			IV
5059037	J85-UNIT-1	06/26/2015	12:09	06/26/2015	13:54	1180	124112	105	Substation equipment				VI
5058679	303005	06/26/2015	12:12	06/26/2015	14:55	1	162	162	Other	Other			VI
5058683	J83139	06/26/2015	12:14	06/26/2015	16:21	1	246	246	Overhead equipment	Overhead Service		Repair	VI
5058693	Q27185	06/26/2015	12:19	06/26/2015	14:12	1	112	112	Overhead equipment	Fuse	Replace - Same Size		VI
5059359	342001	06/26/2015	12:22	06/26/2015	19:00	53	21043	397	Tree related-tree broken				VI
5058709	Q27185	06/26/2015	12:29	06/26/2015	14:13	1	103	103	Overhead equipment	Fuse	Replace - Same Size		VI
5058713	303005	06/26/2015	12:31	06/26/2015	19:00	32	12433	388	Tree related-tree broken	Tree	Trim	Trim	VI
5058777	Y04504	06/26/2015	12:40	06/26/2015	13:23	31	1307	42	Overhead equipment	Fuse	Replace - Same Size		IV
5058733	Q27185	06/26/2015	12:41	06/26/2015	14:50	1	128	128	Overhead equipment	Fuse	Replace - Same Size		VI
5058743	J84145	06/26/2015	12:49	06/26/2015	18:00	1	310	310	Tree related-tree contact	Tree			VI
5058749	342004	06/26/2015	12:55	06/27/2015	15:00	1	1564	1564	Tree related-tree broken	Tree			VI
5058763	346003	06/26/2015	13:01	06/26/2015	21:00	1	478	478	Tree related-tree contact	Tree	Trim		VI
5058765	M54292	06/26/2015	13:01	06/26/2015	13:30	1	28	28	Overhead equipment	Connector	Repair		V
5058791	D96001	06/26/2015	13:15	06/26/2015	15:09	25	2835	113	Animal related	Fuse	Replace - Same Size		I
5058803	K46388	06/26/2015	13:20	06/26/2015	15:34	1	133	133	Tree related-tree broken	Overhead Service	Cut in Clear	Disconnect	V
5058817	Q83168	06/26/2015	13:22	06/26/2015	19:15	1	352	352	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	VI
5058821	M54315	06/26/2015	13:24	06/26/2015	14:15	1	50	50	Tree related-tree broken	Overhead Service	Reconnect	Reconnect	V
5058825	342001	06/26/2015	13:25	06/26/2015	15:52	1	146	146	Overhead equipment	Overhead Secondary	Patrol/Test/Inspect		VI
5058829	303004	06/26/2015	13:29	06/26/2015	17:51	7	1831	261	Tree related-tree contact	Overhead Service	Cut in Clear		VI
5058831	328120	06/26/2015	13:30	06/26/2015	16:09	1	158	158	Overhead equipment	Fuse	Replace - Same Size		V
5058839	J83140	06/26/2015	13:32	06/26/2015	14:30	12	687	57	Overhead equipment				VI
5058841	B81001	06/26/2015	13:32	06/26/2015	14:50	3	231	77	Animal related	Transformer Fuse	Replace - Same Size		I
5058865	V92540	06/26/2015	13:34	06/26/2015	16:41	4	747	186	Tree related-tree contact	Tree	Trim		II
5058873	303005	06/26/2015	13:34	06/26/2015	14:32	1	57	57	Tree related-tree broken	Fuse			VI
5058953	342004	06/26/2015	13:38	06/26/2015	15:30	1	111	111	Tree related-tree broken	Overhead Primary	Repair		VI
5059023	M45212	06/26/2015	13:42	06/26/2015	16:53	1	190	190	Tree related-tree broken	Overhead Primary			IV

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5059089	J85-UNIT-2	06/26/2015	13:49	06/26/2015	13:54	5	25	5	Overhead equipment				VI
5059113	J86108	06/26/2015	13:53	06/26/2015	15:42	48	5230	108	Overhead equipment	Overhead Primary	Repair		VI
5059115	J86118	06/26/2015	13:53	06/26/2015	15:53	1	119	119	Tree related-tree contact	Other			VI
5059125	J86118	06/26/2015	13:55	06/26/2015	15:36	1	100	100	Tree related-tree contact	Other			VI
5059127	Q24312	06/26/2015	13:56	06/26/2015	14:35	6	238	39	Tree related-tree contact				VI
5059129	J86118	06/26/2015	13:56	06/26/2015	15:38	1	101	101	Tree related-tree contact	Other			VI
5059137	J99128	06/26/2015	13:58	06/26/2015	15:18	10	795	79	Tree related-tree contact				VI
5059165	J86118	06/26/2015	14:08	06/26/2015	15:40	1	91	91	Tree related-tree contact	Other			VI
5059163	V99562	06/26/2015	14:08	06/26/2015	15:25	3	228	76	Overhead equipment	Transformer Fuse	Replace - Same Size	Patrol/Test/Inspect	II
5059191	Y24523	06/26/2015	14:09	06/26/2015	15:25	44	3310	75	Overhead equipment	Disconnect Switch	Replace - Same Size		IV
5059171	P60170	06/26/2015	14:10	06/26/2015	16:00	1	109	109	Overhead equipment	Transformer Fuse	Repair	Replace - Same Size	VI
5059181	N50331	06/26/2015	14:13	06/26/2015	15:06	1	52	52	Tree related-tree broken	Overhead Service	Install		II
5059185	Y59520	06/26/2015	14:15	06/26/2015	15:05	1	49	49	Tree related-tree broken	Overhead Service	Repair		IV
5059189	S01501	06/26/2015	14:17	06/26/2015	16:01	1	103	103	Tree related-tree broken				VI
5059195	V40556	06/26/2015	14:18	06/26/2015	16:01	1	102	102	Tree related-tree contact	Overhead Service	Patrol/Test/Inspect	Repair	II
5059193	M21133	06/26/2015	14:19	06/26/2015	21:50	1	450	450	Tree related-tree broken	Overhead Service	Patrol/Test/Inspect	Replace - Same Size	VI
5059197	332005	06/26/2015	14:19	06/26/2015	18:55	1	275	275	Overhead equipment	Overhead Secondary	Repair	Replace - Same Size	VI
5059209	R02121	06/26/2015	14:23	06/26/2015	15:45	1	81	81	Weather	Transformer Fuse	Replace - Same Size		VI
5059205	347003	06/26/2015	14:23	06/26/2015	15:23	16	955	59	Tree related-tree broken	Overhead Primary	Repair		VI
5059211	349002	06/26/2015	14:24	06/26/2015	17:40	1	195	195	Tree related-tree broken	Overhead Service	Replace - Same Size		VI
5059219	J86118	06/26/2015	14:31	06/26/2015	15:21	3	149	49	Overhead equipment				VI
5059223	342003	06/26/2015	14:31	06/26/2015	16:15	1	103	103	Tree related-tree broken				VI
5059221	T46003	06/26/2015	14:31	06/26/2015	18:07	7	1509	215	Overhead equipment	Disconnect Switch	Replace - Same Size		VI
5059225	J86108	06/26/2015	14:32	06/26/2015	18:00	1	207	207	Overhead equipment				VI
5059227	347003	06/26/2015	14:39	06/26/2015	16:01	17	1392	81	Tree related-tree contact	Overhead Primary			VI
5059231	R41131	06/26/2015	14:42	06/26/2015	20:16	1	333	333	Weather	Overhead Primary	Patrol/Test/Inspect	Repair	VI
5059233	301052	06/26/2015	14:42	06/26/2015	15:37	1	54	54	Other	Fuse	Replace - Same Size		VI
5059235	J86108	06/26/2015	14:44	06/26/2015	17:55	1	190	190	Overhead equipment	Overhead Primary	Replace - Same Size		VI
5059237	R78301	06/26/2015	14:45	06/26/2015	19:00	1	254	254	Tree related-tree broken	Overhead Service	Reconnect		V
5059239	A45002	06/26/2015	14:46	06/26/2015	21:12	1	385	385	Underground equipment	Overhead Service	Repair	Repair	I
5059249	A49001	06/26/2015	14:49	06/26/2015	20:14	1	324	324	Overhead equipment	Disconnect Switch	Replace - New Size		I
5059257	P60170	06/26/2015	14:53	06/26/2015	16:20	3	260	86	Overhead equipment	Transformer Fuse	Repair	Replace - Same Size	VI
5059265	P49183	06/26/2015	14:59	06/26/2015	17:40	2	321	160	Overhead equipment	Overhead Primary			I
5059281	Q32171	06/26/2015	15:02	06/26/2015	16:30	52	4532	87	Tree related-tree contact	Recloser	Disconnect	Patrol/Test/Inspect	I
5059275	335002	06/26/2015	15:03	06/26/2015	18:30	4	827	206	Tree related-tree broken	Overhead Transformer			VI
5059591	342001	06/26/2015	15:05	06/26/2015	19:10	17	4151	244	Other				VI
5059283	342004	06/26/2015	15:07	06/26/2015	18:18	1	191	190	Tree related-tree broken	Tree	Remove		VI
5059285	S86582	06/26/2015	15:08	06/26/2015	15:51	1	42	42	Tree related-tree broken	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
5059289	J63171	06/26/2015	15:13	06/26/2015	15:59	7	321	45	Animal related	Fuse			III
5059291	S86582	06/26/2015	15:13	06/26/2015	16:35	4	329	82	Underground equipment	Underground Primary	Patrol/Test/Inspect	Switch/Reset	VI
5059303	344002	06/26/2015	15:17	06/26/2015	21:00	19	6507	342	Overhead equipment	Fuse	Replace - Same Size		VI
5059307	J83137	06/26/2015	15:23	06/26/2015	15:30	16	98	6	Tree related-tree contact	Overhead Primary	Repair	Repair	VI
5059315	S34527	06/26/2015	15:30	06/26/2015	19:20	1	229	229	Weather				VI
5059321	344002	06/26/2015	15:36	06/26/2015	16:59	1	82	82	Overhead equipment				VI
5059323	P26284	06/26/2015	15:36	06/26/2015	17:27	1	110	110	Unknown	Transformer Fuse	Repair		I
5059325	349002	06/26/2015	15:37	06/26/2015	17:15	1	97	97	Tree related-tree broken	Overhead Service	Repair		VI
5059327	302002	06/26/2015	15:39	06/26/2015	17:27	12	1292	107	Tree related-tree contact	Overhead Secondary	Repair		VI
5059603	P98190	06/26/2015	15:41	06/26/2015	19:14	11	2338	212	Tree related-tree contact				III
5059335	K32915	06/26/2015	15:42	06/26/2015	16:55	1	72	72	Unknown	Fuse	Replace - Same Size		VI
5059337	P49183	06/26/2015	15:43	06/26/2015	17:44	1	120	120	Overhead equipment	Overhead Primary	Raise	Tie/Tighten	I
5059341	349002	06/26/2015	15:44	06/26/2015	21:11	13	4238	326	Overhead equipment	Overhead Transformer	Repair	Replace - Same Size	VI
5059345	P49183	06/26/2015	15:50	06/26/2015	17:43	1	112	112	Overhead equipment	Overhead Primary	Raise	Tie/Tighten	I
5059361	R99180	06/26/2015	16:05	06/26/2015	17:35	1	89	89	Weather	Fuse	Replace - Same Size		IV
5059371	J83139	06/26/2015	16:22	06/26/2015	17:33	1	70	70	Overhead equipment	Overhead Secondary	Replace - Same Size		VI
5059377	J84145	06/26/2015	16:30	06/26/2015	17:32	1	61	61	Overhead equipment	Overhead Service	Replace - Same Size		VI
5059381	303004	06/26/2015	16:33	06/26/2015	18:41	1	127	127	Other				VI

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5059385	L50215	06/26/2015	16:38	06/26/2015	17:58	1	79	79	Overhead equipment	Overhead Service	Reconnect		VI
5059387	J84124	06/26/2015	16:39	06/26/2015	16:52	1	12	12	Overhead equipment				VI
5059389	345002	06/26/2015	16:47	06/26/2015	18:08	1	80	80	Weather	Fuse		Replace - Same Size	VI
5059393	302001	06/26/2015	16:53	06/26/2015	19:00	1	126	126	Tree related-tree broken				VI
5059395	B77003	06/26/2015	16:56	06/26/2015	19:15	1	138	138	Tree related-tree contact	Tree	Patrol/Test/Inspect		I
5059397	Q18244	06/26/2015	16:59	06/26/2015	20:24	119	24287	204	Overhead equipment	Fuse	Patrol/Test/Inspect		VI
5059405	343004	06/26/2015	17:03	06/26/2015	17:59	1	55	55	Other				VI
5059415	J83140	06/26/2015	17:11	06/26/2015	17:23	381	1291	11	Overhead equipment				VI
5059417	J83140	06/26/2015	17:11	06/26/2015	17:23	303	900	11	Overhead equipment				VI
5179931	J83140	06/26/2015	17:13	06/26/2015	17:50	501	18396	36	Overhead equipment				VI
5179933	J84146	06/26/2015	17:13	06/26/2015	17:50	773	28384	36	Overhead equipment				VI
5059435	C50001	06/26/2015	17:14	06/26/2015	21:56	1	281	281	Overhead equipment	Fuse			III
5059551	P60170	06/26/2015	17:21	06/27/2015	2:15	1	533	533	Overhead equipment	Overhead Transformer	Repair	Replace - Same Size	VI
5059561	M07236	06/26/2015	17:24	06/26/2015	20:45	1	200	200	Tree related-tree broken	Overhead Service		Repair	III
5059571	344003	06/26/2015	17:28	06/26/2015	19:38	5	646	129	Overhead equipment	Overhead Transformer	Repair		VI
5059573	P58154	06/26/2015	17:30	06/26/2015	18:10	1	39	39	Animal related	Fuse	Repair	Replace - Same Size	VI
5059575	J86108	06/26/2015	17:37	06/26/2015	18:05	3	83	27	Overhead equipment				VI
5059577	302002	06/26/2015	17:40	06/26/2015	20:10	12	1796	149	Tree related-tree broken	Pole			VI
5059579	J84124	06/26/2015	17:42	06/26/2015	20:25	1	162	162	Tree related-tree broken	Overhead Service	Patrol/Test/Inspect		VI
5059581	S04512	06/26/2015	17:45	06/26/2015	20:18	1	152	152	Tree related-tree broken	Overhead Service	Patrol/Test/Inspect	Repair	VI
5059583	R78300	06/26/2015	17:45	06/26/2015	19:30	1	104	104	Overhead equipment	Connector	Repair		V
5059589	347001	06/26/2015	17:48	06/26/2015	18:45	1	56	56	Tree related-tree broken	Overhead Service	Replace - Same Size	Replace - Same Size	VI
5059607	B65003	06/26/2015	17:52	06/26/2015	19:37	32	3330	104	Overhead equipment				I
5059605	J84146	06/26/2015	18:02	06/26/2015	18:26	1	23	23	Overhead equipment	Overhead Primary	Replace - Same Size		VI
5059611	K74166	06/26/2015	18:08	06/26/2015	20:44	1	155	155	Tree related-tree broken	Overhead Service	Repair		IV
5059613	Y55594	06/26/2015	18:12	06/26/2015	19:58	4	422	105	Animal related	Transformer Fuse	Replace - Same Size		IV
5059615	J30201	06/26/2015	18:14	06/26/2015	20:30	8	1082	135	Tree related-tree broken	Fuse		Repair	VI
5059621	342001	06/26/2015	18:20	06/26/2015	19:41	25	2012	80	Overhead equipment	Overhead Primary			VI
5059623	V95586	06/26/2015	18:22	06/26/2015	19:30	1	67	67	Overhead equipment	Fuse	Replace - Same Size	Repair	II
5059629	335002	06/26/2015	18:26	06/26/2015	19:42	1	75	75	Overhead equipment				VI
5059631	C10001	06/26/2015	18:29	06/26/2015	22:29	1	239	239	Overhead equipment	Fuse			III
5059635	335003	06/26/2015	18:36	06/26/2015	20:24	1	107	107	Tree related-tree broken	Overhead Secondary			VI
5059637	334004	06/26/2015	18:38	06/26/2015	20:30	1	111	111	Tree related-tree contact	Overhead Service	Repair		VI
5059641	R04409	06/26/2015	18:39	06/27/2015	2:30	1	470	470	Underground equipment	Underground Secondary	Patrol/Test/Inspect	Repair	V
5059647	342001	06/26/2015	18:45	06/26/2015	19:25	3	118	39	Overhead equipment				VI
5059649	J86118	06/26/2015	18:45	06/26/2015	19:21	1	35	35	Weather	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
5059657	V78513	06/26/2015	18:48	06/26/2015	20:53	13	1629	125	Tree related-tree broken	Overhead Primary	Replace - Same Size		II
5059663	A36002	06/26/2015	19:10	06/27/2015	0:44	1	333	333	Overhead equipment	Disconnect Switch	Patrol/Test/Inspect	Replace - Same Size	I
5059677	J30203	06/26/2015	19:44	06/26/2015	21:49	1	124	124	Overhead equipment	Transformer Fuse	Replace - Same Size		VI
5059679	Q27185	06/26/2015	19:50	06/26/2015	21:40	1	109	109	Overhead equipment	Overhead Primary		Advise Customer	VI
5059685	M45212	06/26/2015	20:10	06/26/2015	23:20	1	189	189	Tree related-tree broken	Fuse	Replace - Same Size		IV
5059689	S86582	06/26/2015	20:10	06/27/2015	4:05	1	474	474	Underground equipment	Underground Primary	Repair	Repair	VI
5059691	J87111	06/26/2015	20:12	06/26/2015	21:10	1	57	57	Overhead equipment	Overhead Service			VI
5059693	303005	06/26/2015	20:14	06/26/2015	20:29	32	488	15	Tree related-tree contact				VI
5059695	303005	06/26/2015	20:15	06/27/2015	9:51	22	17957	816	Animal related				VI
5059705	V69546	06/26/2015	20:25	06/26/2015	23:57	33	6984	211	Underground equipment	Underground Primary	Repair		II
5059717	J74125	06/26/2015	20:39	06/26/2015	23:48	13	2446	188	Overhead equipment	Fuse	Repair	Replace - Same Size	VI
5059715	J79305	06/26/2015	20:41	06/27/2015	0:58	3	772	257	Weather	Underground Transformer		Replace - Same Size	I
5059719	303005	06/26/2015	20:45	06/27/2015	8:17	1	691	691	Tree related-tree broken	Overhead Service	Replace - Same Size	Replace - Same Size	VI
5059721	V78513	06/26/2015	21:01	06/26/2015	23:43	1	161	161	Tree related-tree broken	Overhead Primary		Repair	II
5059723	M15375	06/26/2015	21:07	06/27/2015	1:19	1	251	251	Tree related-tree broken	Overhead Service	Patrol/Test/Inspect	Install	V
5059725	303005	06/26/2015	21:16	06/27/2015	9:22	1	725	725	Tree related-tree broken	Overhead Service	Replace - Same Size	Replace - Same Size	VI
5059731	342004	06/26/2015	21:21	06/27/2015	8:20	1	658	658	Tree related-tree broken	Overhead Service	Repair	Repair	VI
5059733	L68114	06/26/2015	21:21	06/26/2015	22:12	7	353	50	Overhead equipment	Overhead Secondary	Raise		IV
5059735	302001	06/26/2015	21:21	06/27/2015	18:00	1	1238	1238	Overhead equipment				VI
5059741	J39392	06/26/2015	21:48	06/27/2015	1:13	1	204	204	Tree related-tree contact	Overhead Primary			III

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5059751	J83140	06/26/2015	22:05	06/27/2015	0:23	1	137	137	Weather	Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
5059755	J79305	06/26/2015	22:27	06/26/2015	22:50	2	46	23	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	I
5059763	303005	06/26/2015	22:53	06/27/2015	8:45	1	592	592	Tree related-tree contact	Overhead Service	Repair		VI
5059765	J39392	06/27/2015	0:16	06/27/2015	0:45	2	57	28	Weather	Fuse	Replace - Same Size	Replace - Same Size	III
5059769	J83137	06/27/2015	0:57	06/27/2015	2:18	1	80	80	Tree related-tree broken	Overhead Service	Patrol/Test/Inspect	Repair	VI
5059773	J99141	06/27/2015	1:18	06/27/2015	9:33	9	4453	494	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	VI
5059797		06/27/2015	2:16	06/27/2015	9:15	7	2930	418	Tree related-tree broken	Fuse	Replace - Same Size	Replace - Same Size	II
5059783	K52400	06/27/2015	4:20	06/27/2015	9:28	31	9517	307	Underground equipment	Underground Primary		Repair	V
5059795	R48166	06/27/2015	4:26	06/27/2015	9:42	139	20526	316	Public	Recloser	Switch/Reset		IV
5059787	Y63539	06/27/2015	4:28	06/27/2015	5:35	1	66	66	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
5059799	X92507	06/27/2015	5:08	06/27/2015	6:34	1	85	85	Overhead equipment	Transformer Fuse	Repair	Replace - Same Size	IV
5059811	R04409	06/27/2015	5:29	06/27/2015	8:24	37	6444	174	Animal related	Fuse			V
5059913	P26284	06/27/2015	6:42	06/27/2015	8:20	7	684	97	Animal related	Fuse	Repair		I
5059885	S20-XTR1	06/27/2015	6:47	06/27/2015	8:19	933	85574	91	Animal related				VI
5059901	R01152	06/27/2015	7:03	06/27/2015	8:30	1	86	86	Animal related	Transformer Fuse	Repair	Repair	III
5059999	Y63527	06/27/2015	7:20	06/27/2015	8:49	89	7896	88	Unknown				IV
5059925	R01152	06/27/2015	7:22	06/27/2015	8:28	1	65	65	Animal related	Transformer Fuse	Repair	Repair	III
5059939	P69174	06/27/2015	7:48	06/27/2015	16:09	6	2488	500	Underground equipment	Underground Primary	Replace - Same Size		III
5059963	J99128	06/27/2015	7:52	06/27/2015	15:02	178	16882	430	Tree related-tree broken	Pole	Patrol/Test/Inspect		VI
5059983	J99128	06/27/2015	7:52	06/27/2015	8:50	59	3379	57	Tree related-tree broken				VI
5059951	R66470	06/27/2015	7:55	06/27/2015	8:18	1	22	22	Animal related	Transformer Fuse	Replace - Same Size		IV
5059965	P49187	06/27/2015	7:55	06/27/2015	10:45	14	2370	169	Overhead equipment	Fuse	Replace - Same Size	Patrol/Test/Inspect	I
5059955	R66470	06/27/2015	7:55	06/27/2015	8:19	10	233	23	Animal related	Transformer Fuse	Replace - Same Size		IV
5059957	P83710	06/27/2015	7:55	06/27/2015	10:13	1	137	137	Animal related	Transformer Fuse	Patrol/Test/Inspect	Repair	I
5059975	P07179	06/27/2015	8:01	06/27/2015	11:58	1	236	236	Overhead equipment	Fuse	Replace - Same Size	Patrol/Test/Inspect	I
5059977	M41112	06/27/2015	8:06	06/27/2015	10:15	12	1538	128	Tree related-tree contact	Overhead Transformer	Repair		I
5059979	B08003	06/27/2015	8:09	06/27/2015	9:07	529	30602	57	Overhead equipment	Fuse	Replace - Same Size		I
5059981	334001	06/27/2015	8:10	06/27/2015	9:22	1	71	71	Tree related-tree broken	Overhead Service	Repair		VI
5060019	B08003	06/27/2015	8:14	06/27/2015	9:31	15	1154	76	Overhead equipment				I
5059985	P52305	06/27/2015	8:18	06/27/2015	13:24	1	305	305	Underground equipment	Underground Service		Repair	IV
5059987	S20555	06/27/2015	8:20	06/27/2015	8:28	431	3275	7	Animal related	Substation Transformer		Replace - Same Size	VI
5059989	J99128	06/27/2015	8:22	06/27/2015	8:50	7	193	27	Tree related-tree broken				VI
5059991	P62138	06/27/2015	8:22	06/27/2015	10:15	1	112	112	Tree related-tree broken	Overhead Service	Repair	Replace - Same Size	VI
5059993	327155	06/27/2015	8:24	06/27/2015	9:54	1	89	89	Tree related-tree contact	Customer Equipment	Advise Customer		V
5060001	R28871	06/27/2015	8:34	06/27/2015	11:49	1	194	194	Animal related	Transformer Fuse			V
5060007	J14142	06/27/2015	8:38	06/27/2015	9:53	1	74	74	Overhead equipment	Connector	Repair		VI
5060011	R04409	06/27/2015	8:42	06/27/2015	9:08	1	25	25	Animal related	Fuse			V
5060015	K76545	06/27/2015	8:47	06/27/2015	9:17	55	1648	29	Animal related	Fuse	Replace - Same Size		IV
5060017	L17105	06/27/2015	8:47	06/27/2015	13:40	1	292	292	Overhead equipment	Overhead Primary	Repair		III
5060021	P77237	06/27/2015	8:51	06/27/2015	10:20	1	88	88	Animal related	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
5060023	K30204	06/27/2015	8:59	06/27/2015	10:50	16	1771	110	Unknown	Fuse	Replace - Same Size		III
5060035	A50001	06/27/2015	9:08	06/27/2015	10:30	30	2447	81	Animal related	Fuse	Replace - Same Size		I
5060041	A56013	06/27/2015	9:23	06/27/2015	10:00	1	36	36	Overhead equipment	Fuse	Replace - Same Size		I
5060043	303007	06/27/2015	9:27	06/27/2015	10:43	1	75	75	Tree related-tree contact	Overhead Service	Repair	Replace - Same Size	VI
5060045	K76545	06/27/2015	9:28	06/27/2015	9:41	17	215	12	Animal related	Fuse	Replace - Same Size		IV
5060047	L17105	06/27/2015	9:38	06/27/2015	13:24	1	225	225	Overhead equipment	Overhead Primary	Repair		III
5060059	V61584	06/27/2015	9:39	06/27/2015	12:34	44	7670	174	Overhead equipment				II
5060063	V61584	06/27/2015	9:41	06/27/2015	12:37	298	47024	175	Overhead equipment				II
5060061	Y36541	06/27/2015	9:45	06/27/2015	10:20	1	34	34	Animal related	Fuse	Repair		IV
5060067	Z51551	06/27/2015	9:45	06/27/2015	11:02	11	840	76	Overhead equipment	Fuse	Replace - Same Size		IV
5060099	Q24312	06/27/2015	9:46	06/27/2015	12:53	140	22770	186	Tree related-tree contact				VI
5060111	K76547	06/27/2015	9:54	06/27/2015	12:28	1	153	153	Overhead equipment	Overhead Service	Repair		IV
5060127	R04409	06/27/2015	10:08	06/27/2015	11:45	1	96	96	Overhead equipment	Overhead Transformer			V
5060129	U45536	06/27/2015	10:09	06/27/2015	17:00	1	410	410	Overhead equipment	Tree			II
5060139	P85145	06/27/2015	10:17	06/27/2015	11:10	1	52	52	Overhead equipment	Connector	Repair	Repair	III
5060143	R04409	06/27/2015	10:17	06/27/2015	11:46	1	88	88	Underground equipment	Underground Transformer		Replace - Same Size	V

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5060151	N05-UNIT-2	06/27/2015	10:19	06/27/2015	11:17	822	48111	58	Animal related	Substation Misc.	Repair		I
5060161	U45536	06/27/2015	10:26	06/27/2015	16:55	1	388	388	Tree related-tree broken				II
5060167	U45536	06/27/2015	10:45	06/27/2015	16:55	1	369	369	Tree related-tree broken				II
5154987	Y06573	06/27/2015	10:54	06/27/2015	13:35	17	2376	160	Underground equipment				IV
5060177	B73001	06/27/2015	10:55	06/27/2015	15:17	1	261	261	Overhead equipment				I
5060179	R02121	06/27/2015	10:57	06/27/2015	12:08	6	423	70	Animal related	Transformer Fuse	Replace - Same Size		VI
5060181	Q18245	06/27/2015	10:57	06/27/2015	13:33	2	310	155	Animal related	Transformer Fuse	Replace - Same Size		VI
5060193	J76804	06/27/2015	11:10	06/27/2015	12:32	1	81	81	Animal related	Transformer Fuse			V
5060195	M09144	06/27/2015	11:15	06/27/2015	17:16	1	361	361	Underground equipment	Underground Primary	Replace - Same Size	Repair	VI
5060207	307003	06/27/2015	11:43	06/27/2015	13:05	1	81	81	Tree related-tree broken	Tree	Remove		VI
5060209	P20930	06/27/2015	11:45	06/27/2015	13:51	1	125	125	Overhead equipment	Overhead Service	Replace - New Size		VI
5060211	R04409	06/27/2015	11:47	06/27/2015	15:46	6	1433	238	Underground equipment	Underground Transformer	Patrol/Test/Inspect	Replace - New Size	V
5060219	X09534	06/27/2015	12:25	06/27/2015	13:20	49	2691	54	Public				IV
5060231	M83408	06/27/2015	12:48	06/27/2015	18:02	1	313	313	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - New Size	V
5060233	302001	06/27/2015	12:51	06/27/2015	18:00	6	1849	308	Tree related-tree broken	Overhead Primary			VI
5060237	Y54591	06/27/2015	12:58	06/27/2015	13:35	1	36	36	Overhead equipment	Overhead Secondary	Repair		IV
5060239	B76001	06/27/2015	13:03	06/27/2015	13:55	15	777	51	Unknown	Transformer Fuse	Replace - Same Size		I
5060249	K89142	06/27/2015	13:09	06/27/2015	15:03	1	113	113	Overhead equipment	Lightning Arrestor	Replace - Same Size		III
5060251	X09534	06/27/2015	13:15	06/28/2015	1:52	1	756	756	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	IV
5060253	J71129	06/27/2015	13:18	06/27/2015	17:00	1	221	221	Overhead equipment	Transformer Fuse	Replace - Same Size	Patrol/Test/Inspect	I
5060255	M09144	06/27/2015	13:19	06/27/2015	13:47	12	327	27	Overhead equipment	Fuse	Replace - Same Size		VI
5060257	K89142	06/27/2015	13:20	06/27/2015	15:01	1	100	100	Overhead equipment	Overhead Primary	Repair		III
5060261	L68114	06/27/2015	13:26	06/27/2015	15:03	1	96	96	Tree related-tree broken	Overhead Service	Repair		IV
5060263	B81003	06/27/2015	13:35	06/28/2015	0:40	29	8616	664	Underground equipment	Underground Transformer	Replace - Same Size		I
5060267	S60581	06/27/2015	13:40	06/27/2015	15:51	1	130	130	Animal related	Fuse	Replace - Same Size		VI
5060369	J30-UNIT-1	06/27/2015	13:53	06/27/2015	14:11	876	15478	17	Tree related-tree broken	Pole	Replace - New Size	Replace - Urgent	VI
5060317	M21-UNIT-1	06/27/2015	13:54	06/27/2015	14:06	806	9091	11	Overhead equipment				VI
5060287	P83710	06/27/2015	13:56	06/27/2015	16:22	1	145	145	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Repair	I
5060367	B81003	06/27/2015	14:02	06/27/2015	16:31	9	1334	148	Underground equipment	Underground Primary	Repair		I
5060385	M21133	06/27/2015	14:06	06/27/2015	14:15	1	8	8	Overhead equipment				VI
5060389	M21133	06/27/2015	14:08	06/27/2015	14:14	1	5	5	Overhead equipment				VI
5060391	M21133	06/27/2015	14:08	06/27/2015	14:15	1	6	6	Overhead equipment				VI
5060397	M21133	06/27/2015	14:13	06/27/2015	14:22	1	8	8	Overhead equipment				VI
5060399	A50001	06/27/2015	14:27	06/27/2015	18:09	36	8017	222	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
5060427	J30203	06/27/2015	14:38	06/27/2015	17:01	21	2372	142	Tree related-tree contact				VI
5060405	U61001	06/27/2015	14:44	06/27/2015	19:50	1	305	305	Overhead equipment	Overhead Secondary	Repair	Replace - Same Size	II
5060413	J87120	06/27/2015	14:46	06/27/2015	20:07	12	3855	321	Overhead equipment	Pole		Replace - New Size	VI
5060431	N93260	06/27/2015	15:08	06/27/2015	16:25	1	76	76	Overhead equipment	Fuse			III
5060435	U45536	06/27/2015	15:23	06/27/2015	16:45	7	575	82	Overhead equipment				II
5060437	U73583	06/27/2015	15:29	06/27/2015	18:50	9	1805	200	Overhead equipment	Transformer Fuse	Replace - Same Size		II
5060439	T59925	06/27/2015	15:30	06/27/2015	16:20	1	49	49	Public	Pole	Cut in Clear	Replace - Same Size	VI
5060441	D72003	06/27/2015	15:31	06/27/2015	15:33	972	2430	2	Unknown				I
5060449	D72003	06/27/2015	15:33	06/27/2015	15:49	36	547	15	Tree related-tree contact	Overhead Primary	Remove		I
5060445	D72003	06/27/2015	15:34	06/27/2015	15:49	1	14	14	Tree related-tree contact	Overhead Primary	Remove		I
5060453	D72003	06/27/2015	15:34	06/27/2015	15:49	13	186	14	Tree related-tree contact	Overhead Primary	Remove		I
5060481	S03529	06/27/2015	16:19	06/27/2015	18:00	1	100	100	Tree related-tree broken	Overhead Secondary	Repair	Repair	VI
5060495	X34531	06/27/2015	16:41	06/27/2015	17:50	1	68	68	Animal related	Overhead Service	Repair		IV
5060497	R65451	06/27/2015	16:52	06/27/2015	20:08	1	196	195	Underground equipment	Underground Primary	Patrol/Test/Inspect	Switch/Reset	IV
5060515	S16502	06/27/2015	18:02	06/27/2015	22:33	1	270	270	Overhead equipment	Transformer Fuse	Repair	Replace - Same Size	VI
5060519	V76001	06/27/2015	18:13	06/27/2015	22:15	6	1446	241	Overhead equipment	Overhead Transformer	Replace - Same Size	Repair	II
5060533	U60559	06/27/2015	18:22	06/27/2015	22:52	82	22125	269	Overhead equipment	Crossarm	Repair		II
5060549	N60181	06/27/2015	19:01	06/28/2015	1:00	1	358	358	Overhead equipment	Overhead Transformer	Replace - New Size	Patrol/Test/Inspect	I
5060553	K73366	06/27/2015	19:07	06/28/2015	0:03	1	295	295	Underground equipment	Underground Service	Patrol/Test/Inspect	Repair	IV
5060555	C70001	06/27/2015	19:07	06/27/2015	20:00	1	52	52	Overhead equipment	Overhead Transformer	Switch/Reset		III
5060571	J58381	06/27/2015	19:52	06/27/2015	22:25	1	152	152	Overhead equipment	Fuse			III
5060577	B35002	06/27/2015	20:09	06/27/2015	21:34	1	84	84	Overhead equipment				I

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5060579	K32916	06/27/2015	20:22	06/27/2015	21:45	1	82	82	Animal related	Fuse	Replace - Same Size		VI
5060585	S13548	06/27/2015	20:36	06/27/2015	23:19	1	162	162	Overhead equipment	Overhead Service	Repair	Repair	VI
5060583	U60559	06/27/2015	20:36	06/27/2015	22:52	128	17395	135	Overhead equipment	Pole	Repair		II
5060589	R53391	06/27/2015	20:40	06/27/2015	22:26	1	105	105	Animal related	Fuse	Patrol/Test/Inspect	Replace - Same Size	V
5060591	302002	06/27/2015	20:43	06/28/2015	0:15	1	211	211	Overhead equipment	Overhead Primary	Patrol/Test/Inspect		VI
5060599	B65001	06/27/2015	21:45	06/28/2015	1:37	1	231	231	Overhead equipment	Connector	Replace - Same Size		I
5060603	R04409	06/27/2015	22:08	06/28/2015	1:30	1	201	201	Underground equipment	Underground Service	Patrol/Test/Inspect	Repair	V
5060611	E10002	06/27/2015	22:49	06/28/2015	3:08	11	2842	258	Unknown	Fuse	Replace - Same Size		III
5060613	D16002	06/27/2015	22:57	06/28/2015	10:58	17	9640	721	Underground equipment	Fuse		Replace - Same Size	I
5060675	D16002	06/27/2015	22:58	06/28/2015	10:52	3	2141	713	Underground equipment	Underground Primary	Repair	Repair	I
5060619	J47175	06/27/2015	23:09	06/27/2015	23:52	1	42	42	Overhead equipment	Fuse			III
5060621	303007	06/27/2015	23:16	06/28/2015	0:47	9	812	90	Overhead equipment	Overhead Transformer	Repair		VI
5060623	303007	06/27/2015	23:21	06/28/2015	0:47	12	1029	85	Overhead equipment	Overhead Transformer	Repair		VI
5060625	L62928	06/27/2015	23:22	06/28/2015	0:28	1	65	65	Tree related-tree broken	Overhead Service	Repair		VI
5060639	J98131	06/27/2015	23:31	06/28/2015	0:50	295	23254	78	Animal related	Overhead Transformer			VI
5060641	J98130	06/27/2015	23:46	06/28/2015	0:54	73	4962	67	Overhead equipment	Substation Transformer			VI
5060643	U32594	06/27/2015	23:50	06/28/2015	3:35	1	224	224	Overhead equipment	Lightning Arrestor	Replace - Same Size	Replace - Same Size	II
5060647	E10002	06/28/2015	2:26	06/28/2015	3:08	95	3953	41	Unknown	Fuse	Replace - Same Size		III
5060651	E10002	06/28/2015	3:37	06/28/2015	12:01	11	2948	503	Underground equipment	Underground Primary			III
5060655	S49550	06/28/2015	3:48	06/28/2015	4:40	1	51	51	Overhead equipment	Fuse		Replace - Same Size	VI
5060657	D16002	06/28/2015	4:00	06/28/2015	4:45	50	2213	44	Underground equipment	Underground Primary	Repair	Replace - Same Size	I
5060661	Y59520	06/28/2015	4:52	06/28/2015	6:12	1	79	79	Overhead equipment	Fuse	Replace - Same Size		IV
5060671	K30205	06/28/2015	5:53	06/28/2015	7:27	98	9156	93	Unknown	Fuse	Replace - Same Size		III
5060689	J15302	06/28/2015	7:57	06/28/2015	9:22	1	84	84	Overhead equipment	Fuse	Replace - Same Size		I
5060691	S15559	06/28/2015	8:01	06/28/2015	11:19	3	591	197	Animal related	Transformer Fuse	Repair	Replace - Same Size	VI
5060705	B45003	06/28/2015	8:47	06/28/2015	17:11	3	1048	503	Underground equipment	Underground Primary	Repair	Repair	I
5060699	H14343	06/28/2015	9:13	06/28/2015	10:45	1	91	91	Animal related	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	V
5060703	N18210	06/28/2015	9:18	06/28/2015	14:21	2	606	303	Underground equipment	Underground Transformer	Repair		III
5060707	302001	06/28/2015	9:28	06/28/2015	11:41	1	132	132	Tree related-tree broken	Tree	Trim		VI
5060723	D70004	06/28/2015	10:02	06/28/2015	23:35	30	5207	812	Underground equipment	Underground Primary	Repair	Replace - Same Size	I
5060711	Q37370	06/28/2015	10:06	06/28/2015	12:00	1	113	113	Overhead equipment	Transformer Fuse	Repair	Repair	I
5060715	B62004	06/28/2015	10:19	06/28/2015	17:02	1	402	402	Underground equipment	Underground Service	Patrol/Test/Inspect	Repair	I
5060717	V92542	06/28/2015	10:19	06/28/2015	13:15	29	5080	175	Other	Transformer Fuse	Repair		II
5060725	B45004	06/28/2015	10:44	06/28/2015	15:00	1	255	255	Overhead equipment	Overhead Transformer	Replace - Same Size	Replace - Same Size	I
5060727	341002	06/28/2015	10:47	06/28/2015	12:30	1	102	102	Tree related-tree broken	Tree	Patrol/Test/Inspect		VI
5060729	Q70161	06/28/2015	10:50	06/28/2015	13:30	1	159	159	Weather	Transformer Fuse	Repair	Repair	I
5060731	X75571	06/28/2015	10:52	06/28/2015	12:45	1	112	112	Overhead equipment	Overhead Service	Repair	Repair	IV
5060735	Q27185	06/28/2015	11:09	06/28/2015	20:30	1	560	560	Tree related-tree broken	Overhead Primary	Patrol/Test/Inspect	Cut in Clear	VI
5060739	A97002	06/28/2015	11:12	06/28/2015	14:26	1	193	193	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
5060745	M25144	06/28/2015	11:16	06/28/2015	13:18	1	121	121	Weather	Fuse			IV
5060747	X60596	06/28/2015	11:16	06/28/2015	14:00	1	163	163	Underground equipment	Underground Service	Repair	Repair	IV
5060753	HB6283	06/28/2015	11:29	06/28/2015	12:38	1	68	68	Animal related	Underground Primary	Patrol/Test/Inspect	Replace - Same Size	VI
5060757	M36189	06/28/2015	11:32	06/28/2015	15:38	70	11396	246	Underground equipment	Overhead Primary	Patrol/Test/Inspect	Switch/Reset	I
5060759	X34531	06/28/2015	11:56	06/28/2015	12:24	1	27	27	Overhead equipment	Transformer Fuse	Repair	Replace - Same Size	IV
5060761	Q11517	06/28/2015	11:57	06/28/2015	14:40	1	162	162	Overhead equipment	Fuse	Repair	Repair	I
5060765	R49275	06/28/2015	12:45	06/28/2015	18:49	1	363	363	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	VI
5060771	A97002	06/28/2015	13:43	06/28/2015	13:51	1	7	7	Underground equipment	Underground Primary			I
5060773	B45004	06/28/2015	13:43	06/28/2015	14:00	6	98	16	Overhead equipment	Overhead Transformer	Repair	Repair	I
5060775	C36001	06/28/2015	13:51	06/28/2015	15:53	1	121	121	Overhead equipment	Disconnect Switch			III
5060779	Q27185	06/28/2015	14:09	06/28/2015	20:31	10	3824	382	Overhead equipment	Overhead Primary		Cut in Clear	VI
5060781	346003	06/28/2015	14:11	06/28/2015	15:35	6	502	83	Overhead equipment	Tree	Remove		VI
5060785	L50214	06/28/2015	14:12	06/28/2015	20:00	1	347	347	Underground equipment	Underground Service	Patrol/Test/Inspect	Repair	VI
5060787	P49183	06/28/2015	14:19	06/28/2015	17:25	1	185	185	Underground equipment	Underground Service			I
5060789	Q27185	06/28/2015	14:21	06/28/2015	14:49	6	167	27	Overhead equipment	Overhead Primary		Cut in Clear	VI
5060795	N54214	06/28/2015	15:30	06/28/2015	18:20	49	8315	169	Underground equipment	Underground Primary	Switch/Reset	Repair	II
5060801	M05360	06/28/2015	16:03	06/28/2015	18:17	1	133	133	Overhead equipment	Fuse	Replace - Same Size		V

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5060805	M41182	06/28/2015	16:08	06/28/2015	21:23	7	2204	314	Tree related-tree contact	Overhead Secondary	Replace - Same Size		I
5060807	M41182	06/28/2015	16:09	06/28/2015	21:23	4	1256	314	Tree related-tree contact	Overhead Secondary	Replace - Same Size		I
5060815	K28183	06/28/2015	17:02	06/28/2015	18:21	1	78	78	Animal related	Fuse	Replace - Same Size		III
5060843	P58156	06/28/2015	17:03	06/28/2015	19:10	9	1136	126	Overhead equipment	Fuse	Repair	Repair	VI
5060819	R33127	06/28/2015	17:11	06/28/2015	18:50	1	98	98	Overhead equipment	Connector	Replace - Same Size	Repair	I
5060833	M41182	06/28/2015	18:39	06/29/2015	1:29	53	8742	409	Underground equipment	Underground Transformer	Replace - Same Size	Patrol/Test/Inspect	I
5060845	U05595	06/28/2015	18:55	06/28/2015	23:00	5	1224	244	Overhead equipment	Overhead Transformer	Replace - Same Size	Replace - Same Size	II
5060849	B62003	06/28/2015	18:57	06/28/2015	20:27	23	2048	89	Overhead equipment	Disconnect Switch	Replace - Same Size		I
5060857	D36002	06/28/2015	19:10	06/28/2015	21:21	8	1045	130	Underground equipment	Underground Primary	Repair		I
5060859	K76546	06/28/2015	19:10	06/28/2015	20:17	1	66	66	Tree related-tree contact	Overhead Service	Repair		IV
5060943	C52002	06/28/2015	19:16	06/28/2015	20:43	69	5983	86	Overhead equipment	Fuse	Replace - Same Size		III
5060881	C52002	06/28/2015	19:17	06/28/2015	21:45	23	3420	148	Overhead equipment	Fuse	Replace - Same Size		III
5060921	C52002	06/28/2015	19:19	06/28/2015	20:06	19	893	47	Tree related-tree broken	Overhead Primary	Repair		III
5060875	C52002	06/28/2015	19:24	06/28/2015	21:00	1	95	95	Overhead equipment	Fuse	Replace - Same Size		III
5060889	L59933	06/28/2015	19:39	06/28/2015	20:10	475	14668	30	Overhead equipment	Recloser			VI
5060895	L59933	06/28/2015	19:41	06/28/2015	20:25	1	43	43	Overhead equipment				VI
5060907	C52002	06/28/2015	19:43	06/29/2015	2:06	2	765	382	Overhead equipment	Tree	Trim		III
5060909	350104	06/28/2015	19:50	06/28/2015	20:45	34	1851	54	Overhead equipment	Fuse	Replace - Same Size		V
5060917		06/28/2015	19:56	06/28/2015	21:45	1	108	108	Overhead equipment	Transformer Fuse	Replace - Same Size		II
5060919	L59933	06/28/2015	19:57	06/28/2015	21:50	1	112	112	Overhead equipment				VI
5060927	J34357	06/28/2015	20:14	06/28/2015	21:55	35	3517	100	Weather	Fuse	Replace - Same Size		V
5060953	L59933	06/28/2015	20:16	06/28/2015	22:50	54	8312	153	Weather	Lightning Arrestor	Disconnect		VI
5060935		06/28/2015	20:17	06/29/2015	7:36	1	678	678	Tree related-tree broken	Overhead Primary			II
5060967	D36002	06/28/2015	20:18	06/28/2015	20:50	22	704	32	Overhead equipment	Fuse	Replace - Same Size		I
5060955	N44215	06/28/2015	20:22	06/29/2015	1:45	1	322	322	Weather	Overhead Transformer		Replace - New Size	III
5060961	B57002	06/28/2015	20:32	06/29/2015	1:38	6	1830	305	Overhead equipment	Disconnect Switch	Patrol/Test/Inspect	Replace - Same Size	I
5060963	U33586	06/28/2015	20:40	06/28/2015	22:45	1	124	124	Overhead equipment	Lightning Arrestor	Repair		II
5060969	313134	06/28/2015	20:45	06/28/2015	21:40	1	54	54	Overhead equipment	Fuse	Replace - Same Size		V
5060987	308004	06/28/2015	20:50	06/28/2015	22:30	40	3963	99	Overhead equipment	Overhead Primary	Patrol/Test/Inspect		VI
5060981	308004	06/28/2015	20:56	06/28/2015	22:44	6	643	107	Overhead equipment	Overhead Primary	Repair		VI
5060983	C52002	06/28/2015	20:56	06/29/2015	2:06	32	9912	309	Tree related-tree broken	Overhead Primary	Replace - Same Size		III
5060985	308004	06/28/2015	21:05	06/28/2015	23:15	1	129	129	Overhead equipment	Overhead Primary	Repair		VI
5060989	311001	06/28/2015	21:07	06/28/2015	23:33	7	1019	145	Overhead equipment	Fuse	Repair		VI
5060991	B68003	06/28/2015	21:13	06/28/2015	23:20	1	126	126	Overhead equipment	Fuse	Replace - Same Size		III
5060993	D35001	06/28/2015	21:17	06/28/2015	22:14	1	56	56	Overhead equipment	Fuse	Repair		I
5060995	U44529	06/28/2015	21:18	06/28/2015	23:30	1	131	131	Overhead equipment	Fuse	Replace - Same Size		II
5060997	B19002	06/28/2015	21:24	06/29/2015	2:30	1	305	305	Underground equipment	Underground Secondary	Replace - Same Size	Repair	I
5060999	K36151	06/28/2015	21:32	06/29/2015	1:00	1	207	207	Tree related-tree contact	Fuse	Replace - Same Size		III
5061001	B68003	06/28/2015	21:32	06/28/2015	23:35	1	122	122	Overhead equipment	Fuse	Replace - Same Size		III
5061003	B68003	06/28/2015	21:38	06/28/2015	23:25	1	106	106	Overhead equipment	Fuse	Replace - Same Size		III
5061005	P42230	06/28/2015	21:41	06/28/2015	23:27	5	530	106	Weather	Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
5061073	U62521	06/28/2015	21:44	06/29/2015	16:01	287	296751	1096	Overhead equipment	Pole	Repair		II
5061013	X36550	06/28/2015	21:46	06/28/2015	22:15	1	29	29	Weather	Lightning Arrestor	Replace - Same Size	Replace - Same Size	IV
5061027	303007	06/28/2015	21:55	06/28/2015	23:51	1	115	115	Overhead equipment	Overhead Secondary	Repair		VI
5061049	K62102	06/28/2015	22:02	06/29/2015	1:03	1	180	180	Unknown	Fuse	Replace - Same Size		II
5061059	B68003	06/28/2015	22:14	06/28/2015	23:29	1	74	74	Overhead equipment	Fuse	Replace - Same Size		III
5061065	HB6283	06/28/2015	22:19	06/29/2015	4:03	1	343	343	Weather	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
5061075	Q21321	06/28/2015	22:33	06/29/2015	1:40	1	186	186	Weather	Transformer Fuse		Replace - Same Size	VI
5061079	HB6283	06/28/2015	22:37	06/29/2015	4:03	1	325	325	Weather	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
5061081	Z11506	06/28/2015	22:47	06/29/2015	2:05	1	197	197	Tree related-tree broken	Tree	Trim		IV
5061131	Z11506	06/28/2015	22:48	06/29/2015	7:26	403	109677	518	Tree related-tree broken	Pole	Repair	Replace - Same Size	IV
5061099	M18217	06/28/2015	22:53	06/29/2015	6:41	8	3738	467	Weather	Overhead Transformer		Replace - Same Size	III
5061103	M18217	06/28/2015	22:54	06/29/2015	5:19	3	1154	384	Weather	Overhead Transformer	Replace - Same Size	Replace - Same Size	III
5061121	U68581	06/28/2015	23:09	06/29/2015	8:20	17	9353	550	Tree related-tree broken	Overhead Primary	Raise	Raise	II
5061141	U33586	06/28/2015	23:19	06/29/2015	1:15	1	115	115	Weather	Overhead Transformer	Replace - New Size	Replace - New Size	II
5061143	T05539	06/28/2015	23:22	06/29/2015	0:08	1	45	45	Overhead equipment	Disconnect Switch	Repair	Repair	VI

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5061155	S21529	06/28/2015	23:33	06/29/2015	7:38	7	2381	484	Underground equipment	Underground Primary		Replace - Same Size	VI
5061165	V37509	06/28/2015	23:46	06/29/2015	1:20	271	25536	94	Tree related-tree broken	Recloser	Switch/Reset		II
5061191	J74125	06/28/2015	23:59	06/29/2015	0:55	13	724	55	Tree related-tree broken	Lightning Arrestor			VI
5061193	N50334	06/29/2015	0:27	06/29/2015	2:12	1	104	104	Public	Pole	Repair		II
5061197	S88553	06/29/2015	0:42	06/29/2015	2:05	1	82	82	Tree related-tree broken	Overhead Service	Repair		VI
5061199	R66470	06/29/2015	0:46	06/29/2015	2:39	1	112	112	Tree related-tree broken	Overhead Service	Repair		IV
5061211	Y37592	06/29/2015	1:25	06/29/2015	6:33	14	4313	308	Overhead equipment	Pole	Replace - Same Size	Replace - Same Size	IV
5061207	S20554	06/29/2015	1:52	06/29/2015	6:00	18	4470	248	Underground equipment	Underground Primary		Patrol/Test/Inspect	VI
5061231	Q24312	06/29/2015	2:16	06/29/2015	6:47	6	1623	270	Tree related-tree broken	Fuse	Replace - Same Size		VI
5061293	S20554	06/29/2015	2:28	06/29/2015	6:45	1	256	256	Overhead equipment	Other	Advise Customer	Advise Customer	VI
5061217	M25144	06/29/2015	3:10	06/29/2015	4:58	1	107	107	Underground equipment	Underground Primary	Replace - Same Size		IV
5061219	X87576	06/29/2015	3:28	06/29/2015	5:28	8	952	119	Overhead equipment	Fuse	Replace - Same Size		IV
5061221	H88110	06/29/2015	3:57	06/29/2015	6:58	6	1085	180	Overhead equipment	Fuse	Replace - Same Size		II
5061223	P20913	06/29/2015	4:03	06/29/2015	5:56	64	7175	112	Overhead equipment	Fuse	Replace - Same Size		VI
5061243	B62003	06/29/2015	4:48	06/29/2015	7:34	170	10826	165	Tree related-tree broken	Overhead Primary	Switch/Reset	Trim	I
5061249	P73182	06/29/2015	4:53	06/29/2015	5:58	1	64	64	Overhead equipment	Fuse	Repair	Repair	VI
5061261	J68402	06/29/2015	5:27	06/29/2015	7:03	4	383	95	Overhead equipment	Fuse	Repair	Repair	III
5061265	U06551	06/29/2015	5:41	06/29/2015	7:05	1	83	83	Weather	Transformer Fuse	Replace - Same Size		II
5061267	M09143	06/29/2015	5:43	06/29/2015	6:55	15	1075	71	Animal related	Fuse	Replace - Same Size		VI
5061329	L17104	06/29/2015	6:44	06/29/2015	12:21	12	4047	337	Underground equipment	Underground Primary	Repair	Replace - Same Size	III
5061289	V20502	06/29/2015	6:46	06/29/2015	8:29	1	102	102	Overhead equipment	Fuse	Replace - Same Size		II
5061295	J88163	06/29/2015	7:09	06/29/2015	9:09	2	238	119	Animal related	Fuse	Replace - Same Size		VI
5061297	N15850	06/29/2015	7:11	06/29/2015	8:29	6	465	77	Tree related-tree broken	Fuse	Replace - Same Size		V
5061307	C65001	06/29/2015	7:36	06/29/2015	10:01	1	144	144	Overhead equipment	Fuse	Repair	Replace - Same Size	III
5061309	J99151	06/29/2015	7:39	06/29/2015	8:18	5	191	38	Animal related	Fuse	Replace - Same Size		VI
5061317	V20502	06/29/2015	7:52	06/29/2015	13:56	23	6034	363	Underground equipment	Underground Primary			II
5061327	R73841	06/29/2015	8:03	06/29/2015	10:08	1	124	124	Overhead equipment	Regulator	Patrol/Test/Inspect	Repair	V
5061331	A45002	06/29/2015	8:10	06/29/2015	9:45	1	94	94	Animal related	Fuse	Replace - Same Size		I
5061333	A45002	06/29/2015	8:12	06/29/2015	9:45	1	92	92	Animal related	Fuse	Replace - Same Size		I
5061489	A85001	06/29/2015	8:13	06/29/2015	10:53	1	159	159	Overhead equipment				I
5061341	X02547	06/29/2015	8:14	06/29/2015	9:50	2	191	95	Overhead equipment	Fuse	Repair		IV
5061345	K09864	06/29/2015	8:25	06/29/2015	10:06	1	100	100	Weather	Disconnect Switch	Repair		V
5061361	Z61565	06/29/2015	9:03	06/29/2015	10:31	1	87	87	Animal related	Transformer Fuse	Replace - Same Size		IV
5061367	G30001	06/29/2015	9:10	06/29/2015	9:50	1	39	39	Other	Other	Replace - Same Size	Patrol/Test/Inspect	III
5061389	V45526	06/29/2015	9:24	06/29/2015	12:56	128	11973	212	Overhead equipment	Lightning Arrestor	Replace - Same Size		II
5061397	R16510	06/29/2015	9:30	06/29/2015	11:05	3	283	94	Animal related	Fuse	Replace - Same Size		I
5061401	V74513	06/29/2015	9:39	06/29/2015	11:22	1	102	102	Underground equipment	Underground Service	Repair		II
5061403	V45526	06/29/2015	9:39	06/29/2015	10:46	10	660	66	Overhead equipment	Lightning Arrestor	Replace - Same Size		II
5061405	S49550	06/29/2015	9:40	06/29/2015	10:12	1	31	31	Animal related	Transformer Fuse	Replace - New Size	Patrol/Test/Inspect	VI
5061465	D28124	06/29/2015	9:52	06/29/2015	11:10	7	542	77	Unknown	Fuse	Replace - Same Size		I
5061421	J61117	06/29/2015	9:58	06/29/2015	11:22	1	83	83	Overhead equipment	Jumper	Repair	Repair	III
5061431	Y68581	06/29/2015	10:06	06/29/2015	11:36	1	89	89	Overhead equipment	Disconnect Switch		Install	IV
5061441	D66002	06/29/2015	10:16	06/29/2015	13:27	1	190	190	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
5061443	X60598	06/29/2015	10:16	06/29/2015	11:50	5	465	93	Animal related	Transformer Fuse	Replace - Same Size		IV
5061449	R49275	06/29/2015	10:20	06/29/2015	12:58	1	157	157	Overhead equipment	Fuse	Replace - Same Size		VI
5061451	U92593	06/29/2015	10:20	06/29/2015	11:01	1	40	40	Animal related	Disconnect Switch			II
5061453	P47120	06/29/2015	10:22	06/29/2015	11:21	1	58	58	Overhead equipment	Transformer Fuse	Replace - Same Size	Replace - Same Size	I
5061459	B08004	06/29/2015	10:25	06/29/2015	11:47	1	81	81	Overhead equipment	Connector	Replace - Same Size		I
5061463	342001	06/29/2015	10:26	06/29/2015	12:50	1	143	143	Overhead equipment	Connector	Repair		VI
5061475	U60559	06/29/2015	10:40	06/29/2015	11:40	1	59	59	Tree related-tree broken	Overhead Service			II
5061479	P20913	06/29/2015	10:45	06/29/2015	12:08	1	82	82	Animal related	Disconnect Switch	Replace - Same Size		VI
5061485	Y66557	06/29/2015	10:50	06/29/2015	11:21	1	30	30	Animal related	Transformer Fuse	Replace - Same Size		IV
5061487	U92593	06/29/2015	10:51	06/29/2015	11:14	1	22	22	Animal related				II
5061491	R05115	06/29/2015	10:53	06/29/2015	11:59	1	65	65	Other	Overhead Service			I
5061495	M51275	06/29/2015	10:59	06/29/2015	16:07	1	307	307	Underground equipment	Underground Service		Repair	III
5061497	Q06141	06/29/2015	11:06	06/29/2015	12:07	16	968	60	Animal related	Transformer Fuse	Replace - Same Size		IV

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5061513	338003	06/29/2015	11:30	06/29/2015	13:03	1	92	92	Unknown	Meter	Reconnect		VI
5061521	U92593	06/29/2015	11:38	06/29/2015	13:44	1	125	125	Overhead equipment	Overhead Primary			II
5061523	Z51551	06/29/2015	11:50	06/29/2015	12:35	1	44	44	Animal related	Fuse			IV
5061527	HD0574	06/29/2015	11:53	06/29/2015	13:22	1	88	88	Overhead equipment	Disconnect Switch	Replace - New Size	Patrol/Test/Inspect	VI
5061547	L17104	06/29/2015	12:21	06/29/2015	13:13	1	51	51	Underground equipment	Underground Primary	Switch/Reset		III
5061559	Q95247	06/29/2015	12:57	06/29/2015	14:30	1	92	92	Animal related	Transformer Fuse	Replace - Same Size		VI
5061561	B27009	06/29/2015	13:02	06/29/2015	13:54	9	466	51	Overhead equipment	Disconnect Switch	Replace - Same Size	Replace - Same Size	I
5061565	B27009	06/29/2015	13:03	06/29/2015	14:00	1	56	56	Overhead equipment	Disconnect Switch	Replace - Same Size	Replace - Same Size	I
5061575	B27009	06/29/2015	13:03	06/29/2015	13:58	40	2185	54	Overhead equipment	Disconnect Switch	Replace - Same Size	Replace - Same Size	I
5061569	B65004	06/29/2015	13:03	06/29/2015	13:44	5	202	40	Animal related	Transformer Fuse	Replace - Same Size		I
5061577	Q36412	06/29/2015	13:09	06/29/2015	13:40	7	212	30	Animal related	Transformer Fuse	Repair	Repair	I
5061579	M40131	06/29/2015	13:12	06/29/2015	17:10	1	237	237	Underground equipment	Underground Service	Repair		I
5061583	K26136	06/29/2015	13:19	06/29/2015	13:55	1	35	35	Overhead equipment	Fuse	Repair	Replace - Same Size	VI
5061585	V24583	06/29/2015	13:22	06/29/2015	15:06	1	103	103	Tree related-tree broken	Tree			II
5061591	A97001	06/29/2015	13:28	06/29/2015	15:04	1	95	95	Overhead equipment	Overhead Service			I
5061595	B19002	06/29/2015	13:31	06/29/2015	20:01	1	389	389	Other	Overhead Transformer		Repair	I
5061597	Q21294	06/29/2015	13:32	06/29/2015	13:45	11	147	13	Overhead equipment	Fuse			VI
5061599	J46180	06/29/2015	13:32	06/29/2015	14:51	1	78	78	Unknown	Other			III
5061617	S62521	06/29/2015	13:52	06/29/2015	15:17	1	84	84	Overhead equipment				VI
5061619	Q32171	06/29/2015	13:52	06/29/2015	14:48	1	55	55	Weather	Transformer Fuse	Replace - Same Size	Patrol/Test/Inspect	I
5061655	S86592	06/29/2015	13:54	06/29/2015	15:25	365	33452	91	Overhead equipment	Regulator	Patrol/Test/Inspect	Switch/Reset	VI
5061635	V80001	06/29/2015	14:00	06/29/2015	15:31	1	90	90	Tree related-tree broken	Overhead Service	Replace - Same Size		II
5061647	S88553	06/29/2015	14:02	06/29/2015	15:15	1	72	72	Other	Other	Patrol/Test/Inspect	Advise Customer	VI
5061653	D32211	06/29/2015	14:03	06/29/2015	15:07	2	126	63	Public	Underground Primary	Repair	Repair	I
5061673	S86595	06/29/2015	14:20	06/29/2015	15:39	1	78	78	Overhead equipment				VI
5061687	V39001	06/29/2015	14:41	06/29/2015	17:57	6	1173	195	Overhead equipment	Overhead Transformer	Replace - Same Size	Replace - Same Size	II
5061693	M40132	06/29/2015	14:49	06/29/2015	17:40	1	170	170	Weather	Transformer Fuse	Replace - Same Size		I
5061697	M40132	06/29/2015	14:55	06/29/2015	17:40	1	164	164	Weather	Transformer Fuse	Replace - Same Size		I
5061699	M45211	06/29/2015	14:56	06/29/2015	17:41	1	164	164	Overhead equipment	Overhead Transformer		Replace - Same Size	IV
5061703	D96001	06/29/2015	15:11	06/29/2015	16:59	1	107	107	Animal related	Fuse	Replace - Same Size		I
5061715	S86595	06/29/2015	15:29	06/29/2015	15:43	1	13	13	Overhead equipment	Regulator	Patrol/Test/Inspect		VI
5061717	P58155	06/29/2015	15:36	06/29/2015	16:35	1	58	58	Overhead equipment	Connector	Repair		VI
5061725	X09557	06/29/2015	15:46	06/29/2015	19:20	1	213	213	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	IV
5061741	L93149	06/29/2015	16:07	06/29/2015	16:54	4	189	47	Underground equipment	Disconnect Switch	Switch/Reset		VI
5061747	P58155	06/29/2015	16:09	06/29/2015	17:31	1	81	81	Overhead equipment	Connector	Repair		VI
5061753	L70127	06/29/2015	16:17	06/29/2015	17:42	1	84	84	Underground equipment	Underground Secondary		Repair	IV
5061755	X34530	06/29/2015	16:18	06/29/2015	17:35	3	228	76	Animal related	Transformer Fuse	Replace - Same Size		IV
5061759	P25150	06/29/2015	16:39	06/29/2015	18:05	82	6994	85	Overhead equipment	Fuse	Replace - Same Size		III
5061769	N72240	06/29/2015	16:48	06/29/2015	18:00	1	71	71	Unknown	Other			III
5061773	B45004	06/29/2015	16:54	06/29/2015	20:50	1	235	235	Overhead equipment	Connector	Repair		I
5061793	K39153	06/29/2015	17:46	06/29/2015	19:00	1	73	73	Tree related-tree contact	Overhead Service	Repair		III
5061799	L70127	06/29/2015	17:51	06/29/2015	20:42	1	170	170	Underground equipment	Underground Secondary		Repair	IV
5061797	M45211	06/29/2015	17:52	06/29/2015	19:35	1	102	102	Overhead equipment	Overhead Transformer			IV
5061803	P25150	06/29/2015	18:16	06/29/2015	18:24	1	7	7	Overhead equipment	Fuse	Replace - Same Size		III
5061807	B81003	06/29/2015	18:37	06/29/2015	19:45	244	16457	67	Overhead equipment	Jumper		Repair	I
5061825	V92555	06/29/2015	19:04	06/29/2015	22:15	14	2662	190	Tree related-tree broken	Overhead Secondary	Repair	Patrol/Test/Inspect	II
5061863	J07173	06/29/2015	20:07	06/29/2015	20:55	33	1591	48	Weather	Fuse	Replace - Same Size	Repair	I
5061853	308004	06/29/2015	20:16	06/29/2015	21:00	60	2635	43	Animal related	Fuse	Repair		VI
5061843	338005	06/29/2015	20:19	06/29/2015	21:03	1	43	43	Tree related-tree broken	Tree	Trim		VI
5061855	U62521	06/29/2015	20:25	06/29/2015	22:00	1	94	94	Overhead equipment	Connector	Repair		II
5061871	B65003	06/29/2015	21:51	06/29/2015	22:55	1	63	63	Other	Connector			I
5061881	334003	06/29/2015	23:04	06/30/2015	0:45	11	1109	100	Overhead equipment	Fuse	Replace - Same Size		VI
5061885	HD5254	06/29/2015	23:24	06/30/2015	2:44	34	6769	199	Weather	Fuse	Replace - Same Size		VI
5061889	D96001	06/29/2015	23:36	06/30/2015	1:55	1	138	138	Overhead equipment	Fuse	Replace - Same Size		I
5061891	D96001	06/29/2015	23:38	06/30/2015	1:55	1	136	136	Overhead equipment	Fuse	Replace - Same Size		I
5061899	Q04411	06/29/2015	23:46	06/30/2015	4:39	26	7629	293	Underground equipment	Underground Primary			III

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5061901	D55001	06/29/2015	23:47	06/30/2015	0:43	47	2602	55	Animal related	Fuse	Replace - Same Size		I
5061905	D96001	06/30/2015	0:04	06/30/2015	1:48	1	103	103	Overhead equipment	Fuse	Replace - Same Size	Repair	I
5061907	D53001	06/30/2015	0:05	06/30/2015	1:11	1	65	65	Weather	Transformer Fuse	Replace - Same Size		I
5061927	J68401	06/30/2015	0:34	06/30/2015	3:03	608	90671	149	Overhead equipment	Overhead Primary	Replace - Same Size	Replace - Same Size	III
5061955	J68401	06/30/2015	0:35	06/30/2015	4:53	220	22078	258	Weather	Overhead Primary			III
5061929	J74125	06/30/2015	0:37	06/30/2015	1:49	1	71	71	Overhead equipment	Transformer Fuse	Replace - Same Size		VI
5061941	R39934	06/30/2015	0:53	06/30/2015	3:11	2	274	137	Weather	Pole	Replace - Same Size	Replace - Same Size	VI
5061943	B58001	06/30/2015	0:53	06/30/2015	2:02	11	751	68	Overhead equipment	Fuse	Replace - Same Size		I
5061947	L82187	06/30/2015	0:59	06/30/2015	2:54	1	114	114	Weather	Transformer Fuse	Replace - Same Size		IV
5061951	M40132	06/30/2015	1:49	06/30/2015	6:21	47	12314	271	Underground equipment	Underground Primary	Repair	Replace - Same Size	I
5061953	R20502	06/30/2015	1:57	06/30/2015	3:03	1	65	65	Weather	Fuse	Repair		IV
5061959	R20501	06/30/2015	2:00	06/30/2015	3:28	1	87	87	Weather	Transformer Fuse	Repair		IV
5061961	Y55505	06/30/2015	2:36	06/30/2015	3:55	1	78	78	Weather	Disconnect Switch	Replace - Same Size	Replace - Same Size	IV
5061963	Y55505	06/30/2015	2:47	06/30/2015	4:00	1	72	72	Weather	Fuse	Replace - Same Size		IV
5061965	R20501	06/30/2015	3:11	06/30/2015	4:03	1	52	51	Weather	Transformer Fuse	Repair		IV
5061971	R20502	06/30/2015	4:30	06/30/2015	5:25	1	54	54	Weather	Transformer Fuse	Repair		IV
5061977	R20502	06/30/2015	5:29	06/30/2015	5:45	1	15	15	Weather	Transformer Fuse	Repair		IV
5061981	R29904	06/30/2015	5:48	06/30/2015	11:27	1	338	338	Underground equipment	Underground Service	Repair	Repair	VI
5061983	M09175	06/30/2015	6:46	06/30/2015	7:58	1	71	71	Animal related	Fuse	Replace - Same Size		VI
5061987	P69174	06/30/2015	6:49	06/30/2015	7:42	1	52	52	Animal related	Fuse	Replace - Same Size		III
5061989	B68002	06/30/2015	6:56	06/30/2015	7:31	1	34	34	Animal related	Other			III
5061991	M07236	06/30/2015	6:57	06/30/2015	8:40	1	102	102	Overhead equipment	Connector	Repair		III
5061993	B68002	06/30/2015	6:57	06/30/2015	7:32	1	34	34	Animal related	Other			III
5061995	L99392	06/30/2015	7:00	06/30/2015	9:55	1	174	174	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Patrol/Test/Inspect	V
5061997	B68002	06/30/2015	7:05	06/30/2015	7:31	1	25	25	Animal related	Fuse	Replace - Same Size		III
5061999	Q74149	06/30/2015	7:06	06/30/2015	8:20	1	73	73	Overhead equipment	Fuse	Replace - Same Size		IV
5062001	327155	06/30/2015	7:08	06/30/2015	9:00	1	111	111	Tree related-tree broken	Overhead Service	Disconnect		V
5062003	Q21423	06/30/2015	7:08	06/30/2015	8:18	1	69	69	Other				VI
5062007	M09175	06/30/2015	7:19	06/30/2015	8:00	1	40	40	Animal related	Fuse	Replace - Same Size		VI
5062009	D53001	06/30/2015	7:21	06/30/2015	8:09	5	237	47	Animal related	Transformer Fuse	Replace - Same Size		I
5062011	P18102	06/30/2015	7:31	06/30/2015	8:57	1	85	85	Animal related	Transformer Fuse	Replace - Same Size		IV
5062013	K39153	06/30/2015	7:38	06/30/2015	9:37	1	118	118	Tree related-tree broken	Overhead Service	Repair		III
5062017	S62523	06/30/2015	7:45	06/30/2015	8:20	1	34	34	Animal related	Fuse	Repair		VI
5062019	B73003	06/30/2015	7:47	06/30/2015	9:34	5	531	106	Unknown	Fuse	Replace - Same Size		I
5062021	S62523	06/30/2015	7:48	06/30/2015	8:31	1	42	42	Animal related	Fuse		Replace - Same Size	VI
5062023	U84587	06/30/2015	7:49	06/30/2015	11:05	1	195	195	Weather	Fuse	Replace - Same Size		II
5062029	B68004	06/30/2015	8:01	06/30/2015	8:24	186	4281	23	Jurisdictional				III
5062025	B68004	06/30/2015	8:01	06/30/2015	8:24	381	3657	23	Jurisdictional				III
5062027	B68004	06/30/2015	8:01	06/30/2015	8:24	188	1804	23	Jurisdictional				III
5062031	K31124	06/30/2015	8:03	06/30/2015	8:42	1	38	38	Unknown	Transformer Fuse	Replace - Same Size		I
5062033	Q70161	06/30/2015	8:09	06/30/2015	9:15	1	65	65	Animal related	Transformer Fuse	Repair	Replace - Same Size	I
5062125	B68004	06/30/2015	8:10	06/30/2015	8:24	1	13	13	Jurisdictional				III
5062039	B68004	06/30/2015	8:11	06/30/2015	8:23	1	11	11	Jurisdictional				III
5062041	B68004	06/30/2015	8:11	06/30/2015	9:17	6	390	65	Jurisdictional	Other			III
5062047	B68004	06/30/2015	8:12	06/30/2015	8:24	1	11	11	Jurisdictional	Other			III
5062049	A68002	06/30/2015	8:12	06/30/2015	9:34	15	1224	81	Animal related	Fuse	Replace - Same Size		I
5062051	B68004	06/30/2015	8:12	06/30/2015	8:25	1	12	12	Jurisdictional				III
5062053	B68004	06/30/2015	8:12	06/30/2015	8:24	1	11	11	Jurisdictional				III
5062055	B68004	06/30/2015	8:12	06/30/2015	8:25	1	12	12	Jurisdictional				III
5062061	B68004	06/30/2015	8:13	06/30/2015	8:25	1	11	11	Jurisdictional				III
5062063	B68004	06/30/2015	8:14	06/30/2015	8:24	1	9	9	Jurisdictional				III
5062073	R94269	06/30/2015	8:22	06/30/2015	10:08	1	105	105	Animal related	Transformer Fuse	Replace - Same Size		VI
5062085	B61001	06/30/2015	8:27	06/30/2015	18:33	1	605	605	Underground equipment	Underground Primary	Repair	Repair	I
5062089	S61530	06/30/2015	8:31	06/30/2015	10:00	1	88	88	Overhead equipment	Overhead Transformer		Replace - Same Size	VI
5062093	R68900	06/30/2015	8:33	06/30/2015	12:07	1	213	213	Underground equipment	Underground Secondary	Repair	Replace - Same Size	I
5062099	B65004	06/30/2015	8:34	06/30/2015	9:34	62	3718	59	Unknown	Fuse	Replace - Same Size		I

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5062101	P26280	06/30/2015	8:43	06/30/2015	10:23	109	10853	99	Animal related	Fuse	Patrol/Test/Inspect		I
5062115	Q47833	06/30/2015	8:53	06/30/2015	10:00	56	3719	66	Unknown	Recloser		Replace - Same Size	V
5062133	Q27185	06/30/2015	9:16	06/30/2015	13:24	1	247	247	Overhead equipment	Overhead Transformer			VI
5062161	V50001	06/30/2015	9:33	06/30/2015	13:50	1	256	256	Underground equipment	Underground Secondary	Repair	Repair	II
5062145	Y45503	06/30/2015	9:34	06/30/2015	10:15	1	40	40	Overhead equipment	Fuse	Repair	Replace - Same Size	IV
5062157	C36002	06/30/2015	9:47	06/30/2015	13:31	1	223	223	Public	Underground Primary	Patrol/Test/Inspect	Repair	III
5062159	Q36410	06/30/2015	9:49	06/30/2015	10:10	42	872	20	Animal related	Fuse	Repair	Repair	I
5062173	K46388	06/30/2015	10:07	06/30/2015	13:50	5	1115	223	Overhead equipment	Customer Equipment	Advise Customer	Advise Customer	V
5062181	P07179	06/30/2015	10:18	06/30/2015	12:24	1	125	125	Tree related-tree broken				I
5062185	B45005	06/30/2015	10:22	06/30/2015	14:32	18	4488	249	Overhead equipment	Disconnect Switch			I
5062221	K46389	06/30/2015	10:25	06/30/2015	11:04	1	38	38	Weather	Fuse	Replace - Same Size	Replace - Same Size	V
5062237	T06505	06/30/2015	10:27	06/30/2015	11:22	1	54	54	Overhead equipment	Fuse	Patrol/Test/Inspect	Repair	VI
5062239	T06505	06/30/2015	10:28	06/30/2015	11:20	1	51	51	Overhead equipment	Fuse	Patrol/Test/Inspect	Repair	VI
5062275	Q36410	06/30/2015	10:36	06/30/2015	11:10	132	4538	34	Animal related	Fuse	Repair	Repair	I
5062263	H22349	06/30/2015	10:40	06/30/2015	13:16	1	155	155	Underground equipment	Underground Service		Repair	V
5062265	Q36410	06/30/2015	10:40	06/30/2015	14:15	5	1070	214	Overhead equipment	Overhead Primary	Replace - Same Size		I
5062279	L50215	06/30/2015	10:57	06/30/2015	11:55	1	57	57	Animal related	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
5062293	R10943	06/30/2015	11:05	06/30/2015	12:09	46	2937	63	Animal related	Fuse	Replace - Same Size		VI
5062303	R10943	06/30/2015	11:16	06/30/2015	12:08	1	52	52	Animal related	Fuse	Replace - Same Size		VI
5062305	D96002	06/30/2015	11:19	06/30/2015	12:24	1	64	64	Unknown	Fuse	Replace - Same Size		I
5062307	G30001	06/30/2015	11:21	06/30/2015	12:36	1	74	74	Other	Other	Replace - Same Size	Patrol/Test/Inspect	III
5062313	R20501	06/30/2015	11:26	06/30/2015	12:18	1	51	51	Weather	Transformer Fuse	Repair		IV
5062321	J14140	06/30/2015	11:48	06/30/2015	12:30	1	41	41	Overhead equipment	Transformer Fuse	Replace - Same Size		VI
5062327	B81003	06/30/2015	11:55	06/30/2015	15:23	1	207	207	Underground equipment	Other	Repair	Repair	I
5062401	Q14392	06/30/2015	12:08	06/30/2015	12:56	185	8966	48	Other	Overhead Primary	Replace - Same Size		I
5062361	D31016	06/30/2015	12:14	06/30/2015	13:17	59	3668	62	Overhead equipment	Overhead Primary	Patrol/Test/Inspect	Repair	III
5062365	M47802	06/30/2015	12:19	06/30/2015	12:50	1	30	30	Animal related	Fuse	Repair	Repair	V
5062369	M09143	06/30/2015	12:25	06/30/2015	14:28	2	244	122	Overhead equipment	Overhead Transformer	Replace - Same Size	Repair	VI
5062373	Q70161	06/30/2015	12:29	06/30/2015	13:56	1	86	86	Unknown	Transformer Fuse	Replace - Same Size		I
5062377	B38001	06/30/2015	12:35	06/30/2015	13:43	1	67	67	Unknown	Fuse	Replace - Same Size		I
5062387	V50001	06/30/2015	12:40	06/30/2015	13:53	8	582	72	Underground equipment	Underground Secondary	Repair		II
5062397	H01190	06/30/2015	12:49	06/30/2015	14:46	1	116	116	Animal related	Transformer Fuse	Replace - Same Size		III
5062413	N05172	06/30/2015	13:10	06/30/2015	14:03	1	52	52	Overhead equipment	Transformer Fuse	Repair	Replace - Same Size	I
5062419	J84123	06/30/2015	13:25	06/30/2015	14:31	1	65	65	Tree related-tree broken	Tree	Remove		VI
5062423	R65451	06/30/2015	13:33	06/30/2015	14:34	1	60	60	Tree related-tree broken	Overhead Secondary	Repair		IV
5062427	H10843	06/30/2015	13:41	06/30/2015	14:05	1	23	23	Weather	Fuse	Replace - Same Size		V
5062431	B38002	06/30/2015	13:51	06/30/2015	17:20	1	208	208	Overhead equipment	Fuse	Replace - Same Size		I
5062437	308003	06/30/2015	14:01	06/30/2015	15:55	1	113	113	Public	Overhead Service	Repair		VI
5062475	J15302	06/30/2015	14:37	06/30/2015	15:26	1	48	48	Overhead equipment	Other			I
5062501	IP9009	06/30/2015	15:50	06/30/2015	17:25	1	94	94	Overhead equipment	Overhead Service	Repair		VI
5062515	M42107	06/30/2015	16:21	06/30/2015	18:38	1	136	136	Overhead equipment	Fuse	Replace - Same Size		I
5062519	D36001	06/30/2015	16:24	06/30/2015	19:45	1	200	200	Tree related-tree contact	Overhead Service	Repair		I
5062523	B35002	06/30/2015	16:47	06/30/2015	18:00	1	72	72	Overhead equipment	Fuse	Replace - Same Size		I
5062539	E10002	06/30/2015	17:36	06/30/2015	18:42	1	65	65	Tree related-tree broken	Overhead Service	Disconnect	Cut in Clear	III
5062543	U66524	06/30/2015	17:40	06/30/2015	21:50	1	249	249	Overhead equipment	Overhead Transformer	Replace - New Size		II
5062553	Q64917	06/30/2015	18:06	06/30/2015	19:42	17	1620	95	Animal related	Fuse	Replace - Same Size		VI
5062559	U73583	06/30/2015	18:11	06/30/2015	22:51	9	2517	279	Overhead equipment	Transformer Fuse	Replace - Same Size		II
5062565	A97001	06/30/2015	18:20	06/30/2015	19:11	1	50	50	Overhead equipment	Fuse		Repair	I
5062569	L24124	06/30/2015	19:01	06/30/2015	19:49	7	333	47	Unknown	Transformer Fuse	Replace - Same Size		III
5062575	M51275	06/30/2015	19:50	06/30/2015	21:33	1	102	102	Overhead equipment	Fuse			III
5062577	M51275	06/30/2015	20:08	06/30/2015	21:34	1	85	85	Overhead equipment	Fuse			III
5062579	T06503	06/30/2015	20:09	06/30/2015	21:24	1	74	74	Overhead equipment	Overhead Primary	Repair	Repair	VI
5062581	M09144	06/30/2015	20:31	06/30/2015	21:08	1	36	36	Animal related	Fuse	Replace - Same Size		VI
5062627	J18267	06/30/2015	20:59	06/30/2015	23:39	2	318	159	Tree related-tree contact	Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
5062589	338004	06/30/2015	21:07	06/30/2015	21:55	1	47	47	Overhead equipment	Overhead Primary	Patrol/Test/Inspect	Reconnect	VI
5062591	X73001	06/30/2015	21:11	06/30/2015	23:01	1	109	109	Tree related-tree contact	Overhead Service	Repair	Repair	IV

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5062605	R61241	06/30/2015	22:11	07/01/2015	1:21	35	6656	190	Overhead equipment	Overhead Primary	Patrol/Test/Inspect	Repair	IV
5062613	R61241	06/30/2015	22:45	06/30/2015	23:20	1	34	34	Overhead equipment				IV
5062615	P18102	06/30/2015	22:46	07/01/2015	2:06	10	1993	199	Underground equipment	Underground Primary	Switch/Reset	Repair	IV
5062617	P58156	06/30/2015	22:49	07/01/2015	3:55	108	32983	305	Underground equipment	Underground Primary		Repair	VI
5062623	U01523	06/30/2015	23:18	07/01/2015	1:15	9	1049	116	Overhead equipment	Overhead Primary	Replace - Same Size		II
5062635	K39154	07/01/2015	0:31	07/01/2015	3:32	19	3415	180	Underground equipment	Underground Primary		Repair	III
5062643	L81141	07/01/2015	2:13	07/01/2015	3:57	1	103	103	Overhead equipment	Fuse	Replace - Same Size		IV
5062647	303004	07/01/2015	2:51	07/01/2015	4:10	1	78	78	Overhead equipment	Overhead Transformer	Switch/Reset		VI
5062661	B80002	07/01/2015	5:57	07/01/2015	8:55	48	8543	177	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
5062663	A45002	07/01/2015	6:51	07/01/2015	7:57	7	459	65	Animal related	Transformer Fuse	Replace - Same Size		I
5062667	Q34366	07/01/2015	7:09	07/01/2015	8:30	2	161	80	Animal related	Fuse	Repair	Repair	I
5062675	M31204	07/01/2015	7:38	07/01/2015	9:15	1	96	96	Animal related	Fuse	Replace - Same Size		I
5062679	343009	07/01/2015	7:48	07/01/2015	9:40	6	668	111	Overhead equipment	Disconnect Switch	Patrol/Test/Inspect	Replace - Same Size	VI
5062681	Q64939	07/01/2015	7:50	07/01/2015	9:40	1	109	109	Animal related	Fuse	Replace - Same Size		VI
5062693	Y66557	07/01/2015	8:11	07/01/2015	9:08	1	56	56	Unknown				IV
5062695	X34532	07/01/2015	8:13	07/01/2015	9:04	38	1901	50	Animal related	Fuse	Replace - Same Size		IV
5062709	B65001	07/01/2015	8:14	07/01/2015	9:28	57	4202	73	Overhead equipment				I
5062731	301051	07/01/2015	8:43	07/01/2015	11:25	1	161	161	Overhead equipment	Overhead Service	Repair		VI
5062741	J89105	07/01/2015	8:43	07/01/2015	9:45	8	489	61	Animal related	Fuse			VI
5062737	Y45504	07/01/2015	8:45	07/01/2015	9:40	1	54	54	Overhead equipment	Overhead Service	Repair	Replace - Same Size	IV
5062767	N50332	07/01/2015	9:18	07/01/2015	12:30	1	191	191	Underground equipment	Underground Secondary	Switch/Reset	Repair	II
5062773	P26283	07/01/2015	9:21	07/01/2015	14:00	1	278	278	Underground equipment	Underground Service	Patrol/Test/Inspect	Repair	I
5062779	U68581	07/01/2015	9:25	07/01/2015	10:32	4	267	66	Unknown	Fuse	Replace - Same Size		II
5062777	L71171	07/01/2015	9:26	07/01/2015	10:10	1	43	43	Animal related	Fuse			IV
5062839	T22508	07/01/2015	9:36	07/01/2015	10:30	719	38552	53	Tree related-tree broken				VI
5062873	P26283	07/01/2015	9:41	07/01/2015	11:18	98	9512	97	Animal related	Recloser	Switch/Reset		I
5062831	K69116	07/01/2015	9:41	07/01/2015	10:08	5	130	26	Animal related	Fuse	Replace - Same Size		IV
5062885	X02549	07/01/2015	9:58	07/01/2015	11:05	59	3898	66	Overhead equipment	Jumper	Repair		IV
5062903	K46389	07/01/2015	10:19	07/01/2015	11:01	1	41	41	Tree related-tree broken	Fuse	Replace - Same Size		V
5062907	K46389	07/01/2015	10:25	07/01/2015	11:00	1	34	34	Tree related-tree broken	Fuse	Replace - Same Size		V
5062909	N35851	07/01/2015	10:29	07/01/2015	11:09	1	39	39	Weather	Fuse	Replace - Same Size		V
5062915	334004	07/01/2015	10:35	07/01/2015	12:40	1	124	124	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	VI
5062947	B81003	07/01/2015	11:13	07/01/2015	11:50	1	36	36	Underground equipment	Customer Equipment			I
5062961	N54214	07/01/2015	11:37	07/01/2015	14:29	59	9403	172	Underground equipment	Underground Primary	Switch/Reset	Repair	II
5062971	R09226	07/01/2015	11:51	07/01/2015	12:05	1	13	13	Public				III
5062973	R09226	07/01/2015	11:55	07/01/2015	12:02	1	6	6	Public				III
5062975	W03570	07/01/2015	11:59	07/01/2015	14:00	1	120	120	Tree related-tree broken	Fuse	Replace - Same Size		II
5063001	S86582	07/01/2015	12:34	07/01/2015	13:44	4	276	69	Animal related	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
5063003	Q95247	07/01/2015	12:37	07/01/2015	13:18	1	40	40	Animal related	Fuse			VI
5063005	H01194	07/01/2015	12:52	07/01/2015	17:45	1	292	292	Public	Underground Service	Repair	Repair	III
5063015	M45212	07/01/2015	13:13	07/01/2015	13:39	4	106	26	Overhead equipment	Overhead Primary			IV
5063019	B61002	07/01/2015	13:35	07/01/2015	18:23	1	287	287	Underground equipment	Underground Primary	Repair	Repair	I
5063045	M81405	07/01/2015	14:02	07/01/2015	15:57	27	3084	114	Public	Fuse		Replace - Same Size	V
5063031	M47802	07/01/2015	14:03	07/01/2015	16:20	1	136	136	Animal related	Fuse	Repair	Repair	V
5063035	M47802	07/01/2015	14:06	07/01/2015	16:50	1	163	163	Animal related	Fuse	Repair	Repair	V
5063037	N54214	07/01/2015	14:08	07/01/2015	18:32	25	6598	263	Underground equipment	Underground Primary	Repair	Replace - Same Size	II
5063049	B21002	07/01/2015	14:34	07/01/2015	15:49	1	74	74	Overhead equipment	Overhead Service			I
5063051	L00133	07/01/2015	14:38	07/01/2015	15:41	4	248	62	Unknown	Fuse	Replace - Same Size		III
5063081	M47802	07/01/2015	15:12	07/01/2015	16:53	1	100	100	Animal related	Fuse	Repair	Repair	V
5063085	Q36410	07/01/2015	15:17	07/01/2015	16:00	1	42	42	Other	Other			I
5063091	A45003	07/01/2015	15:21	07/01/2015	17:55	1	153	153	Underground equipment	Underground Secondary	Repair	Repair	I
5063095	M47802	07/01/2015	15:25	07/01/2015	16:54	1	88	88	Animal related	Fuse	Repair	Repair	V
5063097	V92540	07/01/2015	15:26	07/01/2015	17:25	1	118	118	Other	Overhead Transformer	Replace - Same Size	Replace - Same Size	II
5063105	N70330	07/01/2015	15:44	07/01/2015	18:03	1	138	138	Overhead equipment	Connector	Replace - Same Size	Replace - Same Size	I
5063107	M37192	07/01/2015	15:47	07/01/2015	17:19	1	91	91	Overhead equipment	Overhead Service	Repair		I
5063113	M47802	07/01/2015	16:02	07/01/2015	16:57	1	54	54	Animal related	Fuse	Repair	Repair	V

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5063115	M47802	07/01/2015	16:05	07/01/2015	16:59	1	53	53	Animal related	Fuse	Repair	Repair	V
5063125	P07179	07/01/2015	16:46	07/01/2015	19:37	1	170	170	Overhead equipment	Fuse	Replace - Same Size		I
5063129	P62138	07/01/2015	17:07	07/01/2015	17:57	1	49	49	Overhead equipment	Connector	Repair		VI
5063135	D37004	07/01/2015	17:17	07/01/2015	23:27	11	4063	369	Underground equipment	Underground Service	Disconnect	Repair	I
5063155	K46388	07/01/2015	17:31	07/01/2015	19:27	1	115	115	Overhead equipment	Overhead Primary			V
5063157	D89003	07/01/2015	17:31	07/01/2015	19:35	1	123	123	Overhead equipment	Customer Equipment			I
5063167	S49549	07/01/2015	18:05	07/01/2015	18:31	1	25	25	Other				VI
5063169	K46388	07/01/2015	18:09	07/01/2015	19:27	1	77	77	Overhead equipment	Overhead Primary			V
5063173	D67001	07/01/2015	18:10	07/01/2015	19:39	1	88	88	Weather	Transformer Fuse	Repair		IV
5063175	346002	07/01/2015	18:18	07/01/2015	20:01	1	102	102	Overhead equipment	Overhead Service	Repair		VI
5063179	K58213	07/01/2015	18:31	07/01/2015	20:35	1	123	123	Overhead equipment	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
5063181	A81003	07/01/2015	18:37	07/02/2015	1:42	1	424	424	Underground equipment	Underground Primary	Disconnect	Repair	I
5063185	D88001	07/01/2015	18:55	07/02/2015	5:50	1	655	654	Underground equipment	Underground Primary	Patrol/Test/Inspect	Reconnect	I
5063193	Y73504	07/01/2015	19:36	07/01/2015	20:38	4	248	62	Animal related	Fuse	Replace - Same Size		IV
5063195	H00162	07/01/2015	19:47	07/01/2015	21:40	1	112	112	Tree related-tree contact	Overhead Service			III
5063197	HD5254	07/01/2015	19:58	07/01/2015	22:10	9	1179	131	Weather	Fuse	Replace - Same Size		VI
5063205	HB6283	07/01/2015	20:01	07/01/2015	21:19	27	2100	77	Weather	Fuse	Replace - Same Size		VI
5063207	D89001	07/01/2015	20:04	07/01/2015	21:52	1	107	107	Underground equipment	Underground Service	Patrol/Test/Inspect		I
5063223	K11373	07/01/2015	20:08	07/01/2015	23:51	8	1777	222	Tree related-tree broken	Tree	Remove		V
5063229	346002	07/01/2015	20:11	07/01/2015	21:40	11	968	88	Weather	Overhead Transformer	Switch/Reset		VI
5063233	HB6251	07/01/2015	20:12	07/01/2015	23:23	1	190	190	Weather	Fuse	Replace - Same Size		VI
5063265	K15205	07/01/2015	20:19	07/01/2015	23:24	101	18690	185	Overhead equipment				VI
5063249	308003	07/01/2015	20:20	07/01/2015	23:33	1	192	192	Tree related-tree broken	Overhead Service	Repair		VI
5063255	311002	07/01/2015	20:24	07/02/2015	0:50	8	2124	265	Tree related-tree broken	Overhead Secondary	Patrol/Test/Inspect	Repair	VI
5063257	S75505	07/01/2015	20:25	07/01/2015	22:00	1	94	94	Animal related	Transformer Fuse			VI
5063275	J84146	07/01/2015	20:35	07/02/2015	3:31	1	415	415	Weather	Overhead Transformer		Repair	VI
5063281	X23516	07/01/2015	20:44	07/01/2015	21:57	4	288	72	Tree related-tree broken	Transformer Fuse	Replace - Same Size		IV
5063285	M19222	07/01/2015	20:49	07/02/2015	5:32	63	18385	523	Weather	Fuse	Replace - Same Size		VI
5063311	374056	07/01/2015	21:23	07/01/2015	22:43	2	159	79	Weather	Substation Breaker			VI
5063313	M47816	07/01/2015	21:25	07/01/2015	22:23	1	57	57	Overhead equipment	Fuse	Replace - Same Size		V
5063319	HB6283	07/01/2015	21:26	07/01/2015	23:01	27	2561	94	Weather	Fuse	Replace - Same Size		VI
5063317	J89105	07/01/2015	21:26	07/02/2015	0:59	1	212	212	Weather	Overhead Transformer		Repair	VI
5063321	J89105	07/01/2015	21:29	07/01/2015	22:45	1	75	75	Weather	Fuse			VI
5063325	B80002	07/01/2015	21:39	07/01/2015	23:02	86	7099	82	Animal related	Underground Primary	Replace - Same Size		I
5063329	D28123	07/01/2015	21:59	07/01/2015	23:24	1	84	84	Animal related	Fuse	Replace - Same Size		I
5063479	Q95247	07/01/2015	22:55	07/02/2015	4:46	2	700	350	Weather				VI
5063337	K67924	07/01/2015	23:12	07/02/2015	1:53	2	320	160	Weather	Fuse		Patrol/Test/Inspect	VI
5063343	P82291	07/01/2015	23:20	07/02/2015	1:30	1	129	129	Weather				VI
5063345	P82291	07/01/2015	23:24	07/02/2015	1:49	1	144	144	Weather	Transformer Fuse			VI
5063347	Q82906	07/01/2015	23:29	07/02/2015	1:35	2	251	125	Weather	Fuse	Replace - Same Size	Replace - Same Size	VI
5063349	Q69926	07/01/2015	23:38	07/02/2015	7:33	1	474	474	Weather	Fuse		Patrol/Test/Inspect	VI
5063351	R29904	07/01/2015	23:42	07/02/2015	2:54	2	383	191	Weather	Fuse	Replace - Same Size	Repair	VI
5063353	L11244	07/01/2015	23:48	07/02/2015	0:36	6	283	47	Overhead equipment	Connector	Replace - Same Size		III
5063355	P82291	07/01/2015	23:50	07/02/2015	1:40	9	993	110	Weather	Lightning Arrestor	Replace - Same Size	Replace - Same Size	VI
5063357	Q82907	07/01/2015	23:53	07/02/2015	3:16	1	202	202	Weather	Fuse	Replace - Same Size	Patrol/Test/Inspect	VI
5063369	L08225	07/02/2015	0:29	07/02/2015	1:20	1	50	50	Tree related-tree contact	Overhead Service	Repair		III
5063371	J84146	07/02/2015	0:32	07/02/2015	3:29	6	1059	176	Overhead equipment	Overhead Transformer	Repair		VI
5063381	J76804	07/02/2015	1:11	07/02/2015	2:49	25	2441	97	Weather	Fuse	Replace - Same Size		V
5063377	S01501	07/02/2015	1:13	07/02/2015	6:00	1	286	286	Weather				VI
5063405	B19002	07/02/2015	1:15	07/02/2015	5:57	19	5010	281	Underground equipment	Fuse	Patrol/Test/Inspect	Repair	I
5063401	S15560	07/02/2015	1:19	07/02/2015	4:05	639	105799	165	Tree related-tree broken				VI
5063387	N35851	07/02/2015	1:20	07/02/2015	3:26	1	125	125	Weather	Fuse	Replace - Same Size		V
5063407	S55566	07/02/2015	1:28	07/02/2015	3:45	466	63716	136	Weather				VI
5063415	A16001	07/02/2015	1:29	07/02/2015	4:02	1	152	152	Overhead equipment	Fuse			I
5063417	B77003	07/02/2015	1:29	07/02/2015	6:12	6	1695	282	Underground equipment	Fuse	Patrol/Test/Inspect	Replace - Same Size	I
5063441	S19554	07/02/2015	1:37	07/02/2015	5:04	1	206	206	Weather	Fuse	Replace - Same Size		VI

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5063447	M09143	07/02/2015	1:39	07/02/2015	5:33	1	233	233	Weather	Fuse	Replace - Same Size	Repair	VI
5063503	S01501	07/02/2015	1:59	07/02/2015	6:00	59	14174	240	Weather				VI
5063477	S66578	07/02/2015	2:24	07/02/2015	7:30	1	306	306	Overhead equipment	Overhead Transformer	Repair	Repair	VI
5063489	S27599	07/02/2015	2:36	07/02/2015	6:00	20	4078	203	Overhead equipment	Overhead Primary		Repair	VI
5063491	Q67948	07/02/2015	2:40	07/02/2015	6:04	1	203	203	Weather	Underground Primary		Repair	VI
5063493	K32935	07/02/2015	2:54	07/02/2015	8:29	1	334	334	Overhead equipment	Overhead Transformer	Replace - Same Size	Repair	VI
5063495	P17109	07/02/2015	2:55	07/02/2015	4:55	17	2023	119	Underground equipment	Underground Primary			IV
5063509	S19554	07/02/2015	3:34	07/02/2015	5:04	19	1692	89	Overhead equipment	Fuse	Replace - Same Size		VI
5063511	B19002	07/02/2015	3:39	07/02/2015	6:23	2	329	164	Underground equipment	Fuse	Patrol/Test/Inspect	Replace - Same Size	I
5063575	Q67938	07/02/2015	4:23	07/02/2015	9:42	4	1279	319	Underground equipment	Underground Transformer		Replace - Same Size	VI
5063519	M36185	07/02/2015	4:42	07/02/2015	7:33	1	170	170	Public	Transformer Fuse			I
5063521	T04512	07/02/2015	4:42	07/02/2015	5:40	1	57	57	Unknown	Transformer Fuse			VI
5063529	B81002	07/02/2015	5:42	07/02/2015	11:16	1	333	333	Underground equipment	Underground Primary	Patrol/Test/Inspect	Replace - Urgent	I
5063531	Q82907	07/02/2015	5:47	07/02/2015	9:14	1	206	206	Weather	Fuse	Replace - Same Size		VI
5063533	S43512	07/02/2015	6:04	07/02/2015	7:10	1	65	65	Other	Other			VI
5063537	K76546	07/02/2015	6:12	07/02/2015	7:04	54	2803	51	Animal related	Overhead Transformer	Replace - Same Size		IV
5063539	K32915	07/02/2015	6:12	07/02/2015	6:40	1	27	27	Overhead equipment	Fuse	Replace - Same Size		VI
5063543	B19002	07/02/2015	6:23	07/02/2015	7:54	1	90	90	Underground equipment	Underground Primary	Repair		I
5063545	M22812	07/02/2015	6:26	07/02/2015	7:30	1	63	63	Weather	Fuse	Replace - Same Size		V
5063549	D28124	07/02/2015	6:45	07/02/2015	8:07	1	81	81	Animal related	Fuse	Replace - Same Size		I
5063553	S13550	07/02/2015	6:56	07/02/2015	7:40	15	655	43	Weather	Transformer Fuse	Replace - Same Size	Replace - Same Size	VI
5063555	H11340	07/02/2015	6:58	07/02/2015	9:44	4	663	165	Tree related-tree contact	Overhead Secondary		Repair	V
5063559	D92002	07/02/2015	6:59	07/02/2015	8:55	53	6101	115	Unknown	Fuse	Replace - Same Size		I
5063567	307003	07/02/2015	7:14	07/02/2015	11:41	8	2135	266	Tree related-tree broken	Overhead Transformer	Patrol/Test/Inspect		VI
5063569	D28124	07/02/2015	7:18	07/02/2015	8:07	1	48	48	Animal related	Fuse	Replace - Same Size		I
5063579	K32916	07/02/2015	7:36	07/02/2015	9:38	1	121	121	Overhead equipment	Fuse	Replace - Same Size	Repair	VI
5063587	N44217	07/02/2015	8:01	07/02/2015	8:58	7	394	56	Unknown	Fuse			III
5063593	S93504	07/02/2015	8:12	07/02/2015	9:35	15	1244	82	Tree related-tree broken	Overhead Primary	Repair		VI
5063597	A85002	07/02/2015	8:29	07/02/2015	11:00	1	150	150	Underground equipment	Underground Service	Patrol/Test/Inspect	Repair	I
5063737	B27007	07/02/2015	8:41	07/02/2015	11:33	4	687	171	Overhead equipment				I
5063609	D60001	07/02/2015	8:47	07/02/2015	8:50	5	13	2	Unknown				III
5063621	N22295	07/02/2015	9:00	07/02/2015	10:36	1	95	95	Animal related	Transformer Fuse	Replace - Same Size		VI
5063623	K30204	07/02/2015	9:05	07/02/2015	10:45	1	99	99	Unknown	Transformer Fuse	Replace - Same Size		III
5063645	H11340	07/02/2015	9:39	07/02/2015	9:44	4	17	4	Overhead equipment	Overhead Secondary	Replace - Same Size	Replace - Same Size	V
5063651	308003	07/02/2015	9:40	07/02/2015	10:35	1	54	54	Weather	Fuse	Patrol/Test/Inspect		VI
5063671	Q34366	07/02/2015	9:48	07/02/2015	11:06	93	7168	77	Overhead equipment	Recloser	Switch/Reset	Switch/Reset	I
5063667	Q34366	07/02/2015	9:52	07/02/2015	11:24	89	8219	92	Overhead equipment				I
5063683	K73366	07/02/2015	9:56	07/02/2015	11:02	1	65	65	Overhead equipment	Overhead Transformer		Replace - Same Size	IV
5063703	K69116	07/02/2015	10:24	07/02/2015	10:56	52	1640	31	Animal related	Fuse	Replace - Same Size		IV
5063709	K27150	07/02/2015	10:45	07/02/2015	13:50	1	184	184	Overhead equipment	Transformer Fuse			VI
5063761	R49275	07/02/2015	10:53	07/02/2015	13:11	479	66183	138	Overhead equipment	Recloser	Patrol/Test/Inspect	Replace - Same Size	VI
5063719	N54107	07/02/2015	10:54	07/02/2015	11:34	1	39	39	Overhead equipment	Connector	Replace - New Size		II
5063745	R49275	07/02/2015	10:59	07/02/2015	12:55	24	2784	116	Overhead equipment	Recloser			VI
5063757	R49275	07/02/2015	11:03	07/02/2015	12:55	1	111	111	Overhead equipment				VI
5063771	307003	07/02/2015	11:14	07/02/2015	16:10	14	4139	295	Overhead equipment	Disconnect Switch	Patrol/Test/Inspect	Replace - Same Size	VI
5063775	R49275	07/02/2015	11:19	07/02/2015	12:55	1	95	95	Overhead equipment				VI
5063777	P73158	07/02/2015	11:22	07/02/2015	13:16	1	113	113	Tree related-tree contact	Overhead Service	Repair		VI
5063785	D96001	07/02/2015	11:32	07/02/2015	12:48	1	75	75	Animal related	Fuse			I
5063799	Q28141	07/02/2015	12:07	07/02/2015	12:11	4	13	3	Overhead equipment				VI
5063811	R49275	07/02/2015	12:53	07/02/2015	12:55	647	1520	2	Unknown				VI
5063813	R49275	07/02/2015	12:53	07/02/2015	12:55	155	364	2	Unknown				VI
5063815	R49275	07/02/2015	12:53	07/02/2015	12:55	493	1158	2	Unknown				VI
5063823	HD5254	07/02/2015	13:09	07/02/2015	14:40	20	1811	90	Overhead equipment	Fuse	Replace - Same Size		VI
5063821	M19222	07/02/2015	13:09	07/02/2015	14:19	1	69	69	Overhead equipment				VI
5063827	S47576	07/02/2015	13:11	07/02/2015	13:47	1	35	35	Tree related-tree broken	Disconnect Switch	Patrol/Test/Inspect	Replace - New Size	VI
5063833	M21134	07/02/2015	13:18	07/02/2015	15:15	8	931	116	Tree related-tree broken	Fuse	Replace - Same Size	Replace - Same Size	VI

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5063835	N22296	07/02/2015	13:22	07/02/2015	15:03	1	100	100	Animal related	Transformer Fuse	Replace - Same Size		VI
5063849	S47537	07/02/2015	13:33	07/02/2015	14:55	67	5443	81	Tree related-tree broken	Overhead Primary		Patrol/Test/Inspect	VI
5063853	M47802	07/02/2015	13:35	07/02/2015	14:14	1	38	38	Animal related	Fuse	Repair	Repair	V
5063869	N58144	07/02/2015	14:03	07/02/2015	15:29	1	85	85	Overhead equipment	Transformer Fuse	Replace - Same Size	Replace - Same Size	I
5063873	Q21321	07/02/2015	14:07	07/02/2015	17:00	1	172	172	Underground equipment	Underground Secondary	Patrol/Test/Inspect	Repair	VI
5063883	U10001	07/02/2015	14:11	07/02/2015	15:23	1	71	71	Overhead equipment	Overhead Service	Repair	Patrol/Test/Inspect	II
5063893	Q28141	07/02/2015	14:41	07/02/2015	15:45	97	6205	63	Overhead equipment	Jumper	Repair	Replace - Same Size	VI
5063895	Q28141	07/02/2015	14:46	07/02/2015	16:05	1	78	78	Other				VI
5063899	Q28141	07/02/2015	14:54	07/02/2015	16:03	1	68	68	Other				VI
5063907	P73158	07/02/2015	15:00	07/02/2015	18:04	4	732	183	Other	Overhead Transformer	Replace - Same Size		VI
5063911	L50215	07/02/2015	15:09	07/02/2015	21:00	1	350	350	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	VI
5063915	Q80353	07/02/2015	15:11	07/02/2015	17:05	1	113	113	Overhead equipment	Connector	Replace - New Size		V
5063917	N18211	07/02/2015	15:18	07/02/2015	19:34	1	256	256	Public	Underground Transformer	Patrol/Test/Inspect	Replace - Same Size	III
5063919	Q28141	07/02/2015	15:19	07/02/2015	15:50	1	30	30	Other				VI
5063923	Q28141	07/02/2015	15:31	07/02/2015	17:24	2	225	112	Overhead equipment				VI
5063929	R50910	07/02/2015	15:49	07/02/2015	17:55	1	125	125	Overhead equipment	Overhead Transformer	Repair		I
5063937	Q04411	07/02/2015	16:02	07/02/2015	19:07	22	4068	184	Underground equipment	Underground Primary			III
5063943	S42578	07/02/2015	16:23	07/02/2015	18:33	1	129	129	Other	Other	Patrol/Test/Inspect		VI
5063953	M25144	07/02/2015	17:16	07/02/2015	18:49	1	92	92	Overhead equipment	Fuse	Replace - Same Size		IV
5063959	J87150	07/02/2015	17:50	07/03/2015	2:00	1	489	489	Jurisdictional	Underground Service	Patrol/Test/Inspect	Repair	VI
5063961	T06503	07/02/2015	17:59	07/02/2015	19:55	1	115	115	Overhead equipment	Overhead Service	Tie/Tighten	Tie/Tighten	VI
5063963	J71128	07/02/2015	18:06	07/02/2015	19:35	47	4169	88	Overhead equipment	Overhead Primary	Repair		I
5063969	J71128	07/02/2015	18:25	07/02/2015	19:49	1	83	83	Overhead equipment	Overhead Primary	Repair		I
5063973	J71128	07/02/2015	18:59	07/02/2015	19:51	1	51	51	Overhead equipment	Overhead Primary	Repair		I
5063977	V34001	07/02/2015	19:46	07/02/2015	21:00	1	73	73	Tree related-tree broken	Overhead Service			II
5063981	HC9327	07/02/2015	20:08	07/02/2015	21:20	1	71	71	Animal related	Transformer Fuse	Replace - Same Size		VI
5063985	R31-UNIT-1	07/02/2015	20:31	07/03/2015	0:50	1	258	258	Overhead equipment	Substation Misc.		Patrol/Test/Inspect	VI
5063997	L42158	07/02/2015	22:10	07/02/2015	23:19	1	68	68	Overhead equipment	Connector	Replace - Same Size		III
5064007	N15849	07/02/2015	23:22	07/03/2015	3:06	17	3796	223	Underground equipment	Underground Primary	Switch/Reset		V
5064009	M48814	07/02/2015	23:41	07/03/2015	1:10	1	88	88	Overhead equipment	Overhead Service			V
5064013	J63173	07/03/2015	0:13	07/03/2015	5:30	1	316	316	Underground equipment	Underground Secondary			III
5064015	S07536	07/03/2015	1:37	07/03/2015	4:17	297	47674	160	Underground equipment	Underground Primary			VI
5064017	S07536	07/03/2015	1:45	07/03/2015	6:23	6	1664	277	Other	Underground Primary			VI
5064019	S07536	07/03/2015	1:47	07/03/2015	6:20	1	272	272	Other	Underground Primary			VI
5064021	L24123	07/03/2015	1:51	07/03/2015	3:09	4	308	77	Animal related	Transformer Fuse	Replace - Same Size		III
5064023	S07536	07/03/2015	1:53	07/03/2015	6:08	1	254	254	Other	Underground Primary			VI
5064025	P09304	07/03/2015	1:58	07/03/2015	6:24	1	265	265	Overhead equipment	Overhead Service	Disconnect		V
5064027	S07536	07/03/2015	2:16	07/03/2015	6:06	8	1836	229	Other	Underground Primary			VI
5064031	S07536	07/03/2015	2:39	07/03/2015	6:09	1	209	209	Other	Underground Primary			VI
5064033	S07536	07/03/2015	3:54	07/03/2015	6:19	1	144	144	Other	Underground Primary			VI
5064035	S07536	07/03/2015	4:21	07/03/2015	5:01	297	11663	39	Underground equipment				VI
5064037	M36189	07/03/2015	4:22	07/03/2015	6:21	1	118	118	Unknown	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	I
5064041	S49549	07/03/2015	4:33	07/03/2015	5:23	1	49	49	Overhead equipment	Transformer Fuse	Replace - Same Size	Replace - Same Size	VI
5064043	S07536	07/03/2015	4:50	07/03/2015	5:23	1	32	32	Other	Underground Primary			VI
5064045	S07536	07/03/2015	4:50	07/03/2015	6:22	1	91	91	Other	Underground Primary			VI
5064047	S07536	07/03/2015	4:50	07/03/2015	6:14	1	83	83	Other	Underground Secondary			VI
5064049	S07536	07/03/2015	4:51	07/03/2015	6:15	1	83	83	Other	Underground Primary			VI
5064053	S07536	07/03/2015	4:51	07/03/2015	5:01	325	3048	9	Underground equipment				VI
5064051	S07536	07/03/2015	4:51	07/03/2015	5:01	265	2485	9	Underground equipment				VI
5064055	S04545	07/03/2015	5:08	07/03/2015	6:05	1	56	56	Other	Underground Primary			VI
5064135	S15560	07/03/2015	5:35	07/03/2015	7:53	639	87721	137	Substation equipment	Substation Transformer	Repair		VI
5064133	S15558	07/03/2015	5:36	07/03/2015	8:27	456	77944	170	Substation equipment	Substation Transformer	Repair		VI
5064131	S15559	07/03/2015	5:45	07/03/2015	8:08	590	84399	143	Substation equipment	Substation Transformer	Repair		VI
5064105	D41003	07/03/2015	6:38	07/03/2015	12:00	1	321	321	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
5064107	B62002	07/03/2015	6:48	07/03/2015	8:36	27	2806	107	Underground equipment	Underground Primary	Patrol/Test/Inspect	Replace - Urgent	I
5064111	E10001	07/03/2015	7:13	07/03/2015	8:57	17	1762	103	Unknown	Fuse	Replace - Same Size		III

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5064119	J05139	07/03/2015	7:17	07/03/2015	11:46	1	268	268	Overhead equipment	Fuse	Patrol/Test/Inspect	Replace - Same Size	I
5064123	M73328	07/03/2015	7:36	07/03/2015	9:21	5	524	104	Overhead equipment	Fuse	Repair	Repair	V
5064127	B25002	07/03/2015	7:36	07/03/2015	8:33	1	56	56	Weather	Transformer Fuse	Replace - Same Size	Replace - Same Size	I
5064141	X72535	07/03/2015	8:00	07/03/2015	9:32	3	273	91	Animal related	Transformer Fuse	Replace - Same Size		IV
5064143	S64506	07/03/2015	8:01	07/03/2015	11:45	1	223	223	Other				VI
5064147	V41533	07/03/2015	8:06	07/03/2015	9:53	26	2767	106	Unknown	Fuse	Patrol/Test/Inspect	Replace - Same Size	II
5064155	Q32170	07/03/2015	8:12	07/03/2015	9:40	1	87	87	Animal related	Transformer Fuse	Replace - Same Size		I
5064159	307001	07/03/2015	8:14	07/03/2015	11:05	1	170	170	Tree related-tree broken	Overhead Service	Patrol/Test/Inspect	Replace - Same Size	VI
5064163	Y45503	07/03/2015	8:22	07/03/2015	9:05	1	42	42	Overhead equipment	Fuse	Repair	Replace - Same Size	IV
5064165	Y45503	07/03/2015	8:31	07/03/2015	9:05	3	100	33	Overhead equipment	Fuse	Repair	Replace - Same Size	IV
5064173	S49549	07/03/2015	8:44	07/03/2015	10:20	4	311	95	Animal related	Fuse			VI
5064181	R05115	07/03/2015	8:59	07/03/2015	15:03	25	9107	364	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
5064187	X19561	07/03/2015	9:04	07/03/2015	12:33	1	208	208	Animal related	Disconnect Switch		Install	IV
5064195	B21004	07/03/2015	9:24	07/03/2015	14:57	1	332	332	Underground equipment	Underground Service	Patrol/Test/Inspect	Repair	I
5064203	A85001	07/03/2015	9:33	07/03/2015	10:58	1	84	84	Overhead equipment	Connector	Replace - Same Size		I
5064217	K26136	07/03/2015	10:05	07/03/2015	10:45	1	39	39	Public	Other	Disconnect	Disconnect	VI
5064223	M09144	07/03/2015	10:09	07/03/2015	11:34	1	84	84	Other				VI
5064225	B58002	07/03/2015	10:40	07/03/2015	11:54	1	73	73	Animal related	Transformer Fuse	Replace - Same Size		I
5064233	Q71846	07/03/2015	10:58	07/03/2015	14:35	1	216	216	Overhead equipment	Overhead Service	Replace - New Size		V
5064237	J58380	07/03/2015	11:00	07/03/2015	12:16	1	75	75	Overhead equipment	Connector	Repair	Repair	III
5064239	HB6283	07/03/2015	11:01	07/03/2015	11:31	1	29	29	Overhead equipment	Fuse			VI
5064241	S64506	07/03/2015	11:01	07/03/2015	11:45	2	88	44	Public	Underground Transformer	Repair		VI
5064247	Q93522	07/03/2015	11:20	07/03/2015	12:00	1	39	39	Other				I
5064257	Q32171	07/03/2015	11:51	07/03/2015	14:00	1	128	128	Weather	Fuse	Replace - Same Size		I
5064271	R05115	07/03/2015	12:24	07/03/2015	13:00	263	9357	35	Underground equipment	Underground Primary	Repair	Replace - Same Size	I
5064305	Q18244	07/03/2015	12:59	07/03/2015	15:11	1	131	131	Underground equipment	Underground Service	Patrol/Test/Inspect	Repair	VI
5064307	A81003	07/03/2015	13:01	07/03/2015	16:07	27	5008	185	Underground equipment	Underground Primary	Switch/Reset	Repair	I
5064317	T28561	07/03/2015	13:18	07/03/2015	16:28	1	189	189	Animal related	Transformer Fuse	Replace - Same Size		VI
5064319	L70127	07/03/2015	13:27	07/03/2015	14:56	6	528	88	Animal related	Fuse	Replace - Same Size		IV
5064329	J07173	07/03/2015	13:34	07/03/2015	15:20	1	105	105	Weather	Transformer Fuse	Replace - Same Size		I
5064335	X02549	07/03/2015	13:51	07/03/2015	17:29	1	217	217	Underground equipment	Underground Secondary	Patrol/Test/Inspect	Repair	IV
5064351	A80001	07/03/2015	14:55	07/03/2015	22:30	1	454	454	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
5064363	B65001	07/03/2015	15:22	07/03/2015	16:32	12	832	69	Underground equipment	Underground Primary	Repair	Repair	I
5064365	D90003	07/03/2015	15:24	07/03/2015	16:39	1	74	74	Overhead equipment	Connector	Tie/Tighten		III
5064367	R06211	07/03/2015	15:25	07/03/2015	17:12	1	106	106	Overhead equipment	Connector	Repair		II
5064395	B65001	07/03/2015	15:28	07/03/2015	17:50	2	283	141	Underground equipment	Underground Primary	Repair	Repair	I
5064371	T06505	07/03/2015	15:31	07/03/2015	17:00	1	88	88	Overhead equipment				VI
5064375	T06505	07/03/2015	15:40	07/03/2015	17:00	1	79	79	Overhead equipment				VI
5064377	T06505	07/03/2015	15:41	07/03/2015	17:00	1	78	78	Overhead equipment				VI
5064385	Q32170	07/03/2015	16:11	07/03/2015	18:20	1	128	128	Overhead equipment	Overhead Transformer	Switch/Reset		I
5064397	M09144	07/03/2015	17:20	07/03/2015	20:30	1	189	189	Animal related	Fuse	Replace - Same Size		VI
5064407	P83710	07/03/2015	17:44	07/03/2015	18:55	1	70	70	Animal related	Transformer Fuse	Repair		I
5064409	307003	07/03/2015	17:52	07/03/2015	19:22	8	712	89	Animal related	Fuse	Replace - Same Size		VI
5064417	J71128	07/03/2015	19:05	07/03/2015	20:00	1	54	54	Unknown	Other			I
5064429	Y37592	07/03/2015	19:47	07/03/2015	20:36	1	48	48	Weather	Transformer Fuse	Replace - Same Size		IV
5064443	U32594	07/03/2015	20:48	07/04/2015	1:35	14	4013	286	Public	Pole	Repair	Repair	II
5064449	N05172	07/03/2015	21:21	07/03/2015	22:33	1	71	71	Unknown	Transformer Fuse	Repair		I
5064453	Q32170	07/03/2015	21:31	07/04/2015	0:20	1	168	168	Overhead equipment	Overhead Transformer	Replace - Same Size		I
5064457	338004	07/03/2015	22:09	07/03/2015	22:33	1	23	23	Other	Overhead Transformer	Switch/Reset		VI
5064459	D87001	07/03/2015	22:31	07/04/2015	2:20	1	228	228	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Reconnect	I
5064465	J80807	07/04/2015	0:19	07/04/2015	7:43	2	887	443	Overhead equipment	Underground Primary		Repair	V
5064471	J80807	07/04/2015	4:36	07/04/2015	7:39	3	549	183	Underground equipment	Underground Primary	Repair		V
5064473	T08502	07/04/2015	5:31	07/04/2015	11:50	1	378	378	Underground equipment	Underground Service	Patrol/Test/Inspect	Disconnect	VI
5064475	B19001	07/04/2015	5:41	07/04/2015	6:45	4	255	63	Animal related	Transformer Fuse	Replace - Same Size		I
5064507	M41111	07/04/2015	5:52	07/04/2015	14:00	180	68211	487	Tree related-tree broken	Overhead Primary	Repair	Replace - Same Size	I
5064621	X88510	07/04/2015	7:01	07/04/2015	12:21	783	250716	320	Animal related				IV

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5064661	X88502	07/04/2015	7:02	07/04/2015	13:31	385	69443	389	Animal related				IV
5064603	X88507	07/04/2015	7:02	07/04/2015	13:32	975	135267	389	Animal related	Substation Misc.	Patrol/Test/Inspect	Repair	IV
5064571	K01239	07/04/2015	7:04	07/04/2015	8:35	21	1891	90	Animal related	Fuse	Replace - Same Size		VI
5064695	R10903	07/04/2015	7:32	07/04/2015	8:40	1	67	67	Animal related				VI
5064697	J07173	07/04/2015	7:34	07/04/2015	9:50	5	677	135	Overhead equipment	Overhead Primary	Repair		I
5064707	J07173	07/04/2015	7:36	07/04/2015	9:50	13	1737	133	Overhead equipment	Overhead Primary	Repair		I
5064709	K67911	07/04/2015	8:18	07/04/2015	13:46	10	3063	327	Underground equipment	Underground Primary	Repair	Repair	VI
5064715	R10903	07/04/2015	8:22	07/04/2015	9:12	8	397	49	Animal related	Fuse	Replace - Same Size	Patrol/Test/Inspect	VI
5064717	B73002	07/04/2015	8:27	07/04/2015	10:01	1	93	93	Unknown	Disconnect Switch	Replace - Same Size	Replace - Same Size	I
5064727	B73002	07/04/2015	8:30	07/04/2015	14:13	12	4106	342	Underground equipment	Underground Primary	Repair	Repair	I
5064721	K30204	07/04/2015	8:30	07/04/2015	9:45	7	518	74	Unknown	Fuse	Replace - Same Size		III
5064733	J89126	07/04/2015	9:17	07/04/2015	10:20	79	4963	62	Animal related	Fuse	Replace - Same Size		VI
5064735	J15303	07/04/2015	9:20	07/04/2015	11:43	1	142	142	Overhead equipment	Connector	Replace - Same Size		I
5064745	J07173	07/04/2015	9:28	07/04/2015	10:19	1	50	50	Overhead equipment	Overhead Service	Tie/Tighten		I
5064747	V92542	07/04/2015	9:36	07/04/2015	11:24	1	107	107	Public				II
5064751	K31124	07/04/2015	10:19	07/04/2015	13:32	1	192	192	Overhead equipment	Connector	Replace - New Size		I
5064767	Y20522	07/04/2015	12:12	07/04/2015	14:00	1	107	107	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
5064777	R34921	07/04/2015	13:10	07/04/2015	17:00	1	229	229	Overhead equipment	Disconnect Switch		Replace - New Size	VI
5064781	K74162	07/04/2015	13:33	07/04/2015	15:04	1	90	90	Overhead equipment	Overhead Service	Replace - Same Size		IV
5064783	D37001	07/04/2015	13:34	07/04/2015	14:21	10	467	46	Animal related	Fuse	Replace - Same Size		I
5064793	D88002	07/04/2015	13:51	07/04/2015	14:55	6	382	63	Unknown	Fuse	Replace - Same Size		I
5064799	L14232	07/04/2015	14:28	07/04/2015	15:50	1	81	81	Animal related	Fuse	Replace - Same Size		III
5064805	L80222	07/04/2015	14:54	07/04/2015	16:43	1	108	108	Overhead equipment	Overhead Service			IV
5064807	R60552	07/04/2015	14:56	07/04/2015	16:21	1	84	84	Overhead equipment	Transformer Fuse	Repair		IV
5064815	K31120	07/04/2015	16:02	07/04/2015	16:47	1	44	44	Unknown	Transformer Fuse	Repair		I
5064821	Y37010	07/04/2015	16:53	07/04/2015	17:39	6	274	45	Unknown	Transformer Fuse	Replace - Same Size		IV
5064833	B93002	07/04/2015	17:24	07/05/2015	0:01	1	396	396	Overhead equipment	Overhead Service	Repair		I
5064845	H65272	07/04/2015	18:10	07/04/2015	20:15	64	7937	124	Overhead equipment	Overhead Primary	Repair	Replace - Same Size	VI
5064837	J88166	07/04/2015	18:14	07/04/2015	22:20	1	245	245	Underground equipment	Underground Service	Advise Customer	Repair	VI
5064841	303002	07/04/2015	18:32	07/04/2015	19:20	1	47	47	Overhead equipment	Fuse	Replace - Same Size		VI
5064893	B84001	07/04/2015	18:43	07/05/2015	1:09	16	6168	385	Unknown				I
5064849	K57212	07/04/2015	19:05	07/04/2015	20:24	1	78	78	Overhead equipment				VI
5064851	J75271	07/04/2015	19:31	07/05/2015	0:30	1	298	298	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	IV
5064865	L79157	07/04/2015	20:11	07/04/2015	23:26	41	7996	195	Tree related-tree broken	Overhead Primary			IV
5064863	L79157	07/04/2015	20:15	07/04/2015	23:36	1	200	200	Tree related-tree broken	Overhead Primary			IV
5064883	B84001	07/04/2015	20:28	07/05/2015	1:09	1	280	280	Overhead equipment	Underground Transformer	Replace - Same Size		I
5064869	U80564	07/04/2015	21:19	07/04/2015	23:59	3	480	160	Overhead equipment	Overhead Primary			II
5064877	Y07558	07/04/2015	22:01	07/04/2015	23:55	1	113	113	Overhead equipment	Overhead Service	Repair		IV
5064885	B68001	07/05/2015	0:43	07/05/2015	8:00	1	436	436	Underground equipment	Underground Service	Repair		III
5064889	S15559	07/05/2015	0:48	07/05/2015	12:05	41	27746	676	Underground equipment	Underground Primary	Repair		VI
5064897	W03570	07/05/2015	1:05	07/05/2015	3:40	47	7259	154	Overhead equipment	Disconnect Switch	Replace - Same Size	Replace - Same Size	II
5064899	342001	07/05/2015	1:28	07/05/2015	3:00	7	638	91	Overhead equipment	Overhead Secondary	Repair		VI
5064903	B00002	07/05/2015	2:33	07/05/2015	6:23	39	8971	230	Underground equipment	Other	Patrol/Test/Inspect	Patrol/Test/Inspect	I
5064911	Q34360	07/05/2015	3:52	07/05/2015	8:36	1	283	283	Underground equipment	Underground Service	Repair		I
5064915	S19543	07/05/2015	4:32	07/05/2015	8:06	1	213	213	Underground equipment	Underground Primary	Repair		VI
5064927	U97528	07/05/2015	4:35	07/05/2015	8:39	17	3589	244	Underground equipment	Underground Primary	Switch/Reset	Repair	II
5064923	B81003	07/05/2015	4:48	07/05/2015	9:19	57	15405	270	Public	Pole	Patrol/Test/Inspect	Replace - Urgent	I
5064929	T23527	07/05/2015	6:04	07/05/2015	13:22	5	1240	438	Underground equipment	Underground Primary		Repair	VI
5064933	N44216	07/05/2015	6:10	07/05/2015	7:39	24	2113	88	Animal related	Fuse	Repair	Repair	III
5064939	J56341	07/05/2015	7:16	07/05/2015	8:03	24	1109	46	Animal related	Fuse	Repair	Repair	III
5064941	V38002	07/05/2015	7:17	07/05/2015	9:50	12	1825	152	Public	Overhead Primary		Repair	II
5064945	Q36412	07/05/2015	7:32	07/05/2015	9:12	3	297	99	Unknown	Transformer Fuse	Repair		I
5064947	S19543	07/05/2015	7:36	07/05/2015	8:05	4	115	28	Underground equipment	Underground Primary	Repair		VI
5064949	N22295	07/05/2015	7:40	07/05/2015	10:05	1	144	144	Animal related	Fuse	Replace - Same Size		VI
5064953	L50215	07/05/2015	8:18	07/05/2015	9:10	11	561	51	Animal related	Fuse	Replace - Same Size		VI
5064957	J20-UNIT-1	07/05/2015	8:40	07/05/2015	10:52	550	49402	132	Public				VI

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5064963	U39541	07/05/2015	8:41	07/05/2015	9:58	4	306	76	Animal related	Transformer Fuse	Replace - Same Size		II
5064975	Y60593	07/05/2015	8:42	07/05/2015	9:25	1	42	42	Animal related	Transformer Fuse	Replace - Same Size	Replace - Same Size	IV
5064999	HB3-UNIT-1	07/05/2015	8:44	07/05/2015	10:06	1	82	82	Public				VI
5065007	J24-UNIT-1	07/05/2015	8:44	07/05/2015	10:06	1	81	81	Public				VI
5065019	J25-UNIT-1	07/05/2015	8:45	07/05/2015	10:06	1	81	81	Public				VI
5065021	J27-UNIT-1	07/05/2015	8:45	07/05/2015	10:15	2	180	90	Public				VI
5065029	Q72-UNIT-1	07/05/2015	8:46	07/05/2015	11:31	1	165	165	Public	Pole	Replace - Same Size		VI
5065035	J28-UNIT-1	07/05/2015	8:46	07/05/2015	10:06	1	79	79	Public				VI
5065041	L86176	07/05/2015	8:57	07/05/2015	10:31	1	93	93	Overhead equipment	Fuse	Replace - Same Size		IV
5065053	L86175	07/05/2015	9:37	07/05/2015	10:58	1	80	80	Overhead equipment	Fuse	Replace - Same Size		IV
5065057	M25143	07/05/2015	10:11	07/05/2015	15:44	2	665	332	Underground equipment	Underground Primary			IV
5065067	R31-UNIT-1	07/05/2015	11:19	07/06/2015	4:20	1	1020	1020	Overhead equipment	Substation Transformer	Replace - New Size	Replace - New Size	VI
5065069	K07322	07/05/2015	12:07	07/05/2015	13:17	1	69	69	Animal related	Fuse	Replace - Same Size		I
5065073	Y69553	07/05/2015	12:45	07/05/2015	16:15	1	209	209	Underground equipment	Underground Service	Repair	Repair	IV
5065077	B00002	07/05/2015	13:05	07/05/2015	14:29	1	83	83	Tree related-tree broken	Overhead Service	Repair		I
5065079	S13546	07/05/2015	13:11	07/05/2015	14:10	1	58	58	Overhead equipment	Overhead Service	Replace - New Size		VI
5065087	T15570	07/05/2015	13:46	07/05/2015	17:25	2	437	218	Overhead equipment	Pole		Replace - Same Size	VI
5065091	S20555	07/05/2015	13:47	07/05/2015	14:50	1	62	62	Animal related	Fuse	Repair	Replace - Same Size	VI
5065101	N15850	07/05/2015	14:02	07/05/2015	16:06	1	123	123	Weather	Fuse	Replace - Same Size		V
5065109	351-UNIT-1	07/05/2015	14:03	07/05/2015	15:13	673	47009	69	Overhead equipment				VI
5065185	H00163	07/05/2015	15:01	07/05/2015	15:55	1	53	53	Animal related	Transformer Fuse	Replace - Same Size		III
5065189	J30203	07/05/2015	15:03	07/05/2015	16:45	1	101	101	Overhead equipment	Fuse	Replace - Same Size		VI
5065201	J30203	07/05/2015	15:41	07/05/2015	16:50	1	68	68	Underground equipment	Fuse	Replace - Same Size		VI
5065203	R73841	07/05/2015	15:46	07/05/2015	17:35	1	108	108	Overhead equipment	Fuse	Replace - Same Size		V
5065207	HD5254	07/05/2015	16:04	07/05/2015	20:20	1	255	255	Underground equipment	Underground Service	Patrol/Test/Inspect	Repair	VI
5065219	R01152	07/05/2015	17:02	07/05/2015	20:59	13	3078	236	Underground equipment	Underground Transformer	Replace - Same Size		III
5065225	B71002	07/05/2015	17:24	07/05/2015	21:04	537	118284	220	Underground equipment	Underground Primary	Patrol/Test/Inspect	Patrol/Test/Inspect	I
5065343	B19001	07/05/2015	17:35	07/05/2015	22:55	121	38695	319	Overhead equipment	Overhead Primary	Repair		I
5065235	K01240	07/05/2015	17:48	07/05/2015	22:15	1	266	266	Underground equipment	Connector	Replace - Same Size		VI
5065237	J76804	07/05/2015	18:01	07/05/2015	19:15	1	73	73	Overhead equipment	Overhead Service	Replace - Same Size	Replace - Same Size	V
5065241	Q27186	07/05/2015	18:03	07/05/2015	20:45	1	161	161	Other	Fuse	Replace - Same Size		VI
5065243	Q27186	07/05/2015	18:04	07/05/2015	20:46	1	161	161	Other	Fuse	Replace - Same Size		VI
5065245	338007	07/05/2015	18:06	07/05/2015	19:42	1	95	95	Overhead equipment	Jumper	Repair	Replace - Same Size	VI
5065249	S09520	07/05/2015	18:14	07/05/2015	19:09	9	493	54	Overhead equipment				VI
5065257	B19001	07/05/2015	18:42	07/05/2015	22:45	1	242	242	Overhead equipment	Overhead Primary	Patrol/Test/Inspect	Repair	I
5065259	B73002	07/05/2015	18:47	07/05/2015	23:45	1	297	297	Overhead equipment	Overhead Transformer	Repair	Repair	I
5065265	J86118	07/05/2015	20:05	07/05/2015	22:13	1	127	127	Tree related-tree broken	Overhead Service			VI
5065269	U35511	07/05/2015	20:07	07/06/2015	4:03	9	4283	475	Underground equipment	Underground Primary	Repair		II
5065271	Q27186	07/05/2015	20:09	07/05/2015	20:51	1	41	41	Other	Fuse	Replace - Same Size		VI
5065273	Q27186	07/05/2015	20:09	07/05/2015	20:18	4	35	8	Other	Fuse	Replace - Same Size		VI
5065279	L73160	07/05/2015	20:24	07/05/2015	22:09	1	104	104	Tree related-tree broken	Overhead Service			IV
5065281	X60596	07/05/2015	20:28	07/05/2015	21:20	1	51	51	Jurisdictional				IV
5065337	S61530	07/05/2015	21:08	07/05/2015	22:35	1	86	86	Other	Overhead Service	Patrol/Test/Inspect	Patrol/Test/Inspect	VI
5065353	X19561	07/05/2015	21:19	07/05/2015	23:32	85	11307	133	Overhead equipment	Disconnect Switch	Replace - Same Size		IV
5065357	X19561	07/05/2015	21:24	07/05/2015	23:32	55	7082	128	Overhead equipment	Disconnect Switch	Replace - Same Size	Replace - Same Size	IV
5065367	S83532	07/05/2015	21:40	07/06/2015	1:56	1	255	255	Animal related	Transformer Fuse	Repair	Replace - Same Size	VI
5065369	B76003	07/05/2015	21:49	07/06/2015	4:45	1	415	415	Underground equipment	Underground Service	Patrol/Test/Inspect	Repair	I
5065371	N74241	07/05/2015	21:54	07/06/2015	0:02	1	127	127	Overhead equipment	Overhead Service	Repair		I
5065425	M26161	07/05/2015	23:13	07/05/2015	23:57	2	86	43	Overhead equipment	Fuse	Replace - Same Size		III
5065427	X20001	07/05/2015	23:22	07/06/2015	1:00	7	685	97	Overhead equipment	Overhead Secondary	Raise	Repair	IV
5065881	M25144	07/05/2015	23:42	07/06/2015	7:19	3	1368	456	Underground equipment	Underground Transformer			IV
5065441	A85001	07/06/2015	1:42	07/06/2015	7:09	1	327	327	Underground equipment	Underground Primary			I
5065433	A85001	07/06/2015	1:42	07/06/2015	7:09	1	326	326	Underground equipment	Underground Primary			I
5065875	P26283	07/06/2015	1:51	07/06/2015	5:32	20	4412	220	Unknown	Underground Primary	Repair		I
5065879	P26283	07/06/2015	1:56	07/06/2015	5:32	8	1722	215	Unknown	Underground Primary	Repair		I
5065439	K30204	07/06/2015	2:53	07/06/2015	5:20	1	146	146	Unknown	Transformer Fuse	Replace - Same Size		III

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5065545	S22-XTR1	07/06/2015	4:13	07/06/2015	5:16	1628	101636	62	Tree related-tree broken	Overhead Primary	Repair		VI
5065525	S09-XTR1	07/06/2015	4:13	07/06/2015	5:16	1839	114698	62	Tree related-tree broken	Overhead Primary	Repair		VI
5065721	S22-XTR2	07/06/2015	4:15	07/06/2015	5:16	724	44142	60	Tree related-tree broken	Overhead Primary	Repair		VI
5065819	HD0-X-1	07/06/2015	4:15	07/06/2015	5:16	1014	61783	60	Tree related-tree broken	Overhead Primary	Repair		VI
5065805	332002	07/06/2015	4:32	07/06/2015	6:19	1	106	106	Tree related-tree broken	Overhead Service	Advise Customer	Repair	VI
5065883	HD0574	07/06/2015	5:26	07/06/2015	9:20	9	2108	234	Tree related-tree broken	Overhead Primary	Repair		VI
5065887	Q91175	07/06/2015	5:59	07/06/2015	8:24	1	144	144	Animal related	Transformer Fuse	Replace - Same Size	Replace - Same Size	I
5065895	S41565	07/06/2015	6:39	07/06/2015	9:16	4	625	156	Overhead equipment	Overhead Transformer	Repair	Replace - Same Size	VI
5065901	L71171	07/06/2015	6:46	07/06/2015	8:05	1	78	78	Unknown	Fuse			IV
5065903	L12128	07/06/2015	6:50	07/06/2015	7:43	1	52	52	Animal related	Transformer Fuse	Repair		III
5065911	A85001	07/06/2015	7:09	07/06/2015	8:00	2	100	50	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
5065913	J07135	07/06/2015	7:17	07/06/2015	8:23	1	65	65	Animal related	Fuse	Repair	Replace - Same Size	I
5065915	303005	07/06/2015	7:19	07/06/2015	9:23	32	3939	123	Overhead equipment	Disconnect Switch		Replace - New Size	VI
5065919	P17109	07/06/2015	7:27	07/06/2015	8:52	25	2103	84	Underground equipment	Underground Primary		Repair	IV
5065927	J82106	07/06/2015	7:46	07/06/2015	8:25	1	38	38	Other	Fuse			VI
5065931	X75558	07/06/2015	7:55	07/06/2015	9:50	1	114	114	Animal related	Fuse	Replace - Same Size	Replace - Same Size	IV
5065937	Q83172	07/06/2015	8:02	07/06/2015	8:37	1	34	34	Overhead equipment	Transformer Fuse	Repair	Repair	VI
5065943	Q63835	07/06/2015	8:04	07/06/2015	11:52	1	227	227	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	V
5065945	R41131	07/06/2015	8:04	07/06/2015	12:15	1	250	250	Underground equipment	Underground Service	Replace - Same Size	Replace - Same Size	VI
5065955	A80002	07/06/2015	8:12	07/06/2015	9:55	1	102	102	Unknown	Fuse	Repair		I
5155005	V17574	07/06/2015	8:24	07/06/2015	13:25	1	300	300	Underground equipment				II
5065965	N05172	07/06/2015	8:25	07/06/2015	9:30	1	64	64	Overhead equipment	Fuse	Replace - Same Size		I
5065969	N70332	07/06/2015	8:30	07/06/2015	9:04	1	33	33	Overhead equipment	Transformer Fuse	Replace - Same Size		I
5065977	P49187	07/06/2015	8:53	07/06/2015	10:35	1	101	101	Unknown	Transformer Fuse	Replace - Same Size	Replace - Same Size	I
5065979	R60552	07/06/2015	8:55	07/06/2015	9:49	1	53	53	Animal related	Transformer Fuse	Replace - Same Size		IV
5066003	Y20522	07/06/2015	9:31	07/06/2015	14:50	1	318	318	Underground equipment	Underground Secondary	Repair	Repair	IV
5066021	S62521	07/06/2015	9:53	07/06/2015	10:21	1	27	27	Overhead equipment	Overhead Service			VI
5066035	J33803	07/06/2015	10:11	07/06/2015	11:11	1	59	59	Jurisdictional	Overhead Service			V
5066041	V99562	07/06/2015	10:17	07/06/2015	11:50	1	92	92	Animal related	Fuse	Replace - Same Size		II
5066067	B28004	07/06/2015	10:52	07/06/2015	12:21	1	88	88	Overhead equipment	Overhead Service	Repair	Repair	I
5066109	J74125	07/06/2015	11:02	07/06/2015	13:40	197	31149	158	Public				VI
5066095	J74125	07/06/2015	11:05	07/06/2015	14:00	178	31037	174	Public	Overhead Secondary	Replace - Same Size		VI
5066145	R20502	07/06/2015	11:35	07/06/2015	15:54	1	259	259	Public	Underground Transformer		Repair	IV
5066149	K09864	07/06/2015	11:39	07/06/2015	15:51	5	1260	251	Tree related-tree broken	Overhead Primary			V
5066155	P26283	07/06/2015	11:59	07/06/2015	17:45	1	345	345	Underground equipment	Underground Secondary			I
5066159	B19002	07/06/2015	12:04	07/06/2015	17:56	1	351	351	Underground equipment	Underground Service	Patrol/Test/Inspect	Repair	I
5066163	D93001	07/06/2015	12:07	07/06/2015	17:24	1	316	316	Public	Pole	Repair		IV
5066167	Q18242	07/06/2015	12:11	07/06/2015	13:24	1	72	72	Overhead equipment	Overhead Service	Repair	Repair	VI
5066175	U26001	07/06/2015	12:29	07/06/2015	13:31	1	61	61	Overhead equipment	Transformer Fuse	Replace - Same Size		II
5066183	J05138	07/06/2015	12:54	07/06/2015	13:40	1	45	45	Overhead equipment	Connector	Replace - Same Size	Repair	I
5066213	A17021	07/06/2015	13:14	07/06/2015	16:16	1	181	181	Underground equipment	Underground Connector	Repair	Repair	I
5066209	Q91141	07/06/2015	13:16	07/06/2015	14:17	1	60	60	Animal related	Transformer Fuse	Replace - Same Size		I
5066217	H07106	07/06/2015	13:29	07/06/2015	17:07	1	217	217	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
5066239	K58210	07/06/2015	13:35	07/06/2015	16:50	156	29394	195	Overhead equipment	Overhead Primary	Repair	Repair	VI
5066351	K58210	07/06/2015	13:39	07/06/2015	16:50	852	152851	191	Overhead equipment	Overhead Primary	Replace - Same Size	Replace - Same Size	VI
5066237	M73328	07/06/2015	13:42	07/06/2015	15:36	1	113	113	Tree related-tree broken	Overhead Service	Repair		V
5066273	M49410	07/06/2015	14:05	07/06/2015	15:34	6	532	88	Weather	Fuse	Patrol/Test/Inspect		V
5066275	S53541	07/06/2015	14:06	07/06/2015	15:23	1	76	76	Public	Overhead Service			VI
5066277	351002	07/06/2015	14:06	07/06/2015	15:43	4	387	96	Overhead equipment	Overhead Secondary	Repair		VI
5066355	H11337	07/06/2015	14:06	07/06/2015	22:26	19	9508	500	Tree related-tree broken	Pole	Patrol/Test/Inspect	Replace - Same Size	V
5066285	H29-UNIT-1	07/06/2015	14:07	07/06/2015	17:27	1	200	200	Overhead equipment	Overhead Primary			V
5066289	J35-UNIT-1	07/06/2015	14:07	07/06/2015	17:27	1	199	199	Overhead equipment	Overhead Primary			V
5066359	H11337	07/06/2015	14:08	07/06/2015	16:43	3	463	154	Tree related-tree broken	Overhead Transformer	Patrol/Test/Inspect		V
5066293	K58213	07/06/2015	14:09	07/06/2015	21:47	1	457	457	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	VI
5066297	H14343	07/06/2015	14:20	07/06/2015	16:27	5	635	127	Tree related-tree broken	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	V
5066299	M49410	07/06/2015	14:20	07/06/2015	15:27	6	401	66	Weather	Fuse	Replace - Same Size		V

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5066303	T14575	07/06/2015	14:20	07/06/2015	16:58	1	157	157	Overhead equipment	Disconnect Switch	Patrol/Test/Inspect	Repair	VI
5066313	Y20522	07/06/2015	14:25	07/06/2015	14:27	3	6	2	Unknown				IV
5066353	Y39515	07/06/2015	14:44	07/06/2015	16:14	1	89	89	Tree related-tree broken	Overhead Service	Repair		IV
5066365	A91003	07/06/2015	14:52	07/06/2015	19:31	5	1390	278	Underground equipment	Underground Primary			I
5066371	Y37009	07/06/2015	14:55	07/06/2015	15:36	1	40	40	Other	Meter			IV
5066369	A91003	07/06/2015	14:55	07/06/2015	19:00	44	10761	244	Underground equipment	Underground Primary	Repair	Repair	I
5066373	A91003	07/06/2015	14:56	07/06/2015	19:26	40	10813	270	Underground equipment	Underground Primary	Repair	Replace - Same Size	I
5066379	R23334	07/06/2015	15:06	07/06/2015	17:36	1	149	149	Tree related-tree contact	Overhead Service	Repair		V
5066381	M05360	07/06/2015	15:07	07/07/2015	1:13	1	605	605	Animal related	Overhead Service	Patrol/Test/Inspect	Repair	V
5066383	P26284	07/06/2015	15:07	07/06/2015	17:31	2	287	143	Weather	Overhead Transformer	Replace - Same Size	Repair	I
5066385	X65540	07/06/2015	15:07	07/06/2015	21:34	1	386	386	Underground equipment	Underground Secondary	Repair		IV
5066387	A45002	07/06/2015	15:08	07/06/2015	15:56	1	47	47	Other	Transformer Fuse	Replace - Same Size		I
5066389	A91003	07/06/2015	15:08	07/06/2015	19:30	6	1566	261	Underground equipment	Underground Primary	Repair	Replace - Same Size	I
5066633	307003	07/06/2015	15:12	07/06/2015	18:00	1	167	167	Unknown				VI
5066397	P69175	07/06/2015	15:14	07/06/2015	16:00	1	45	45	Underground equipment	Lightning Arrestor	Replace - New Size		III
5066399	M25143	07/06/2015	15:16	07/06/2015	19:09	1	232	232	Tree related-tree broken	Overhead Secondary		Repair	IV
5066441	V18541	07/06/2015	15:24	07/06/2015	16:36	7	502	71	Tree related-tree contact	Transformer Fuse	Replace - Same Size		II
5066403	V18541	07/06/2015	15:24	07/06/2015	16:36	1	71	71	Tree related-tree contact	Transformer Fuse	Replace - Same Size		II
5066407	H10843	07/06/2015	15:26	07/06/2015	17:50	1	143	143	Weather	Meter	Patrol/Test/Inspect		V
5066409	H10843	07/06/2015	15:29	07/06/2015	17:25	1	115	115	Weather	Meter	Patrol/Test/Inspect		V
5066427	H10843	07/06/2015	15:29	07/06/2015	16:29	54	3225	59	Weather	Overhead Primary	Cut in Clear		V
5066413	Y24523	07/06/2015	15:29	07/06/2015	19:30	1	240	240	Underground equipment	Underground Service	Repair	Repair	IV
5066433	H10843	07/06/2015	15:36	07/06/2015	16:35	1	58	58	Weather	Meter	Patrol/Test/Inspect		V
5066435	H10843	07/06/2015	15:43	07/06/2015	22:37	1	413	413	Weather	Overhead Primary	Repair	Patrol/Test/Inspect	V
5066437	H10843	07/06/2015	15:48	07/06/2015	17:22	1	94	94	Weather	Meter	Patrol/Test/Inspect		V
5066629	307003	07/06/2015	15:49	07/06/2015	23:16	6	2683	447	Overhead equipment	Fuse	Replace - Same Size		VI
5066631	307003	07/06/2015	15:49	07/06/2015	20:52	1	302	302	Tree related-tree broken	Overhead Transformer		Replace - New Size	VI
5066445	J07135	07/06/2015	16:02	07/06/2015	17:10	1	67	67	Tree related-tree contact	Overhead Transformer	Patrol/Test/Inspect	Switch/Reset	I
5066469	X91511	07/06/2015	16:07	07/06/2015	18:06	407	48636	119	Tree related-tree broken	Overhead Primary	Replace - Same Size	Replace - Same Size	IV
5066459	315106	07/06/2015	16:11	07/06/2015	16:43	11	350	31	Overhead equipment	Overhead Service	Repair		V
5066487	H10843	07/06/2015	16:23	07/06/2015	16:29	24	140	5	Unknown				V
5066497	M53308	07/06/2015	16:29	07/06/2015	19:00	1	150	150	Tree related-tree contact	Overhead Service	Repair		V
5066511	R73841	07/06/2015	16:34	07/06/2015	18:11	1	96	96	Weather	Overhead Transformer	Switch/Reset		V
5066531	K58210	07/06/2015	16:34	07/06/2015	17:04	733	21608	29	Overhead equipment				VI
5066519	S92557	07/06/2015	16:38	07/06/2015	18:38	1	119	119	Overhead equipment	Recloser	Switch/Reset		VI
5066549	A56013	07/06/2015	16:46	07/06/2015	18:15	1	88	88	Overhead equipment	Overhead Service	Replace - Same Size		I
5066553	C60001	07/06/2015	16:47	07/06/2015	18:34	1	106	106	Other	Overhead Service	Raise		III
5066587	U01514	07/06/2015	17:01	07/06/2015	18:30	8	712	89	Animal related	Transformer Fuse	Replace - Same Size	Replace - Same Size	II
5066589	307005	07/06/2015	17:01	07/06/2015	18:30	6	532	88	Tree related-tree broken	Tree	Remove		VI
5066615	P26283	07/06/2015	17:28	07/06/2015	18:38	1	69	69	Animal related	Fuse	Repair	Replace - Same Size	I
5066619	A85002	07/06/2015	17:35	07/06/2015	19:42	1	126	126	Overhead equipment	Fuse	Replace - Same Size		I
5066625	B00002	07/06/2015	17:36	07/06/2015	20:18	36	5827	161	Underground equipment	Vault	Patrol/Test/Inspect	Patrol/Test/Inspect	I
5066639	S22595	07/06/2015	17:50	07/06/2015	20:24	1	153	153	Overhead equipment	Meter	Patrol/Test/Inspect		VI
5066655	S92557	07/06/2015	18:13	07/06/2015	19:38	7	595	85	Unknown				VI
5066657	R73841	07/06/2015	18:15	07/06/2015	19:35	1	79	79	Unknown	Overhead Secondary	Repair		V
5066661	F03004	07/06/2015	18:24	07/07/2015	0:32	2	479	367	Underground equipment	Underground Primary	Repair	Repair	III
5066667	K69117	07/06/2015	18:34	07/06/2015	22:10	1	215	215	Underground equipment	Underground Service	Patrol/Test/Inspect	Repair	IV
5066669	B80002	07/06/2015	18:36	07/06/2015	19:36	3	179	59	Unknown	Fuse	Replace - Same Size		I
5066675	J13108	07/06/2015	18:45	07/06/2015	20:10	1	84	84	Tree related-tree broken	Overhead Service	Repair	Reconnect	I
5066681	R16511	07/06/2015	19:07	07/06/2015	19:45	4	151	37	Weather	Fuse	Repair	Repair	I
5066683	R16511	07/06/2015	19:07	07/06/2015	19:45	10	377	37	Weather	Fuse	Repair	Repair	I
5066687	J05138	07/06/2015	19:09	07/06/2015	21:34	8	1158	144	Weather	Fuse	Replace - Same Size		I
5066753	P62138	07/06/2015	19:17	07/06/2015	20:30	484	35661	73	Unknown				VI
5066743	P62138	07/06/2015	19:17	07/06/2015	19:51	390	13521	34	Unknown				VI
5066717	D96001	07/06/2015	19:19	07/06/2015	21:45	1	145	145	Overhead equipment	Overhead Service	Replace - Same Size		I
5066721	J05138	07/06/2015	19:20	07/06/2015	21:46	1	146	146	Weather	Fuse	Patrol/Test/Inspect	Replace - Same Size	I

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5066751	L99392	07/06/2015	19:34	07/06/2015	20:29	1	54	54	Animal related	Transformer Fuse	Replace - Same Size		V
5066755	L17101	07/06/2015	19:42	07/06/2015	21:35	1	112	112	Overhead equipment	Other			III
5066757	L17101	07/06/2015	19:42	07/06/2015	21:28	1	105	105	Overhead equipment	Other			III
5066769	L17101	07/06/2015	19:43	07/06/2015	20:24	80	3245	40	Overhead equipment	Pole	Cut in Clear		III
5066765	F03004	07/06/2015	19:46	07/07/2015	5:02	1	556	556	Underground equipment	Underground Primary	Repair	Repair	III
5066775	D72003	07/06/2015	19:51	07/06/2015	21:19	1	87	87	Underground equipment	Underground Service	Repair	Repair	I
5066791	L17101	07/06/2015	20:16	07/07/2015	5:04	7	3695	527	Overhead equipment	Pole			III
5066799	V61563	07/06/2015	20:27	07/06/2015	23:22	472	82378	174	Public	Substation Breaker			II
5066797	R60551	07/06/2015	20:29	07/06/2015	21:41	32	2303	72	Underground equipment	Underground Primary	Switch/Reset	Repair	IV
5066805	M41182	07/06/2015	20:29	07/06/2015	22:10	7	700	100	Overhead equipment	Transformer Fuse	Replace - Same Size	Patrol/Test/Inspect	I
5066867	Q32171	07/06/2015	21:00	07/07/2015	1:24	1	263	263	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Switch/Reset	I
5066901	B62003	07/06/2015	21:50	07/07/2015	4:30	1	400	400	Underground equipment	Underground Primary	Patrol/Test/Inspect	Reconnect	I
5066909	V42572	07/06/2015	22:39	07/07/2015	0:17	1	97	97	Tree related-tree broken	Overhead Service	Repair		II
5066911	B65004	07/06/2015	22:52	07/07/2015	0:46	1	113	113	Tree related-tree broken	Overhead Service	Cut in Clear		I
5066913	B45005	07/06/2015	23:17	07/07/2015	2:22	7	1293	184	Overhead equipment	Fuse	Replace - Same Size		I
5066917	B45005	07/06/2015	23:30	07/07/2015	1:20	1	109	109	Overhead equipment	Customer Equipment	Patrol/Test/Inspect		I
5066923	W03570	07/06/2015	23:44	07/07/2015	5:52	13	2406	367	Tree related-tree broken	Tree	Patrol/Test/Inspect	Patrol/Test/Inspect	II
5066927	V69546	07/07/2015	1:12	07/07/2015	3:47	194	29901	154	Overhead equipment	Recloser	Switch/Reset		II
5066945	B81003	07/07/2015	1:36	07/07/2015	6:42	39	11921	305	Overhead equipment	Overhead Primary	Patrol/Test/Inspect	Repair	I
5066947	V92540	07/07/2015	1:37	07/07/2015	4:15	4	631	157	Weather	Fuse	Replace - Same Size		II
5066977	M81405	07/07/2015	3:21	07/07/2015	7:50	54	14497	268	Overhead equipment	Jumper	Repair		V
5066975	Z06537	07/07/2015	3:32	07/07/2015	5:53	1	140	140	Animal related	Transformer Fuse	Replace - Same Size		IV
5066989	J12166	07/07/2015	3:46	07/07/2015	6:56	231	43767	189	Overhead equipment	Overhead Primary	Repair		III
5066995	Y45503	07/07/2015	4:34	07/07/2015	6:18	1	103	103	Tree related-tree contact	Overhead Service	Repair	Replace - Same Size	IV
5066997	J12166	07/07/2015	4:38	07/07/2015	7:00	1	141	141	Overhead equipment	Overhead Primary	Repair		III
5066999	V69546	07/07/2015	4:40	07/07/2015	7:20	1	159	159	Animal related	Transformer Fuse	Replace - Same Size		II
5067005	R60553	07/07/2015	5:08	07/07/2015	7:51	34	5524	162	Overhead equipment	Overhead Primary	Repair		IV
5067013	K76542	07/07/2015	5:31	07/07/2015	9:25	32	7462	233	Tree related-tree contact	Fuse	Patrol/Test/Inspect	Repair	IV
5067021	X66580	07/07/2015	6:29	07/07/2015	8:25	1	115	115	Animal related	Transformer Fuse			IV
5067025	A45001	07/07/2015	6:50	07/07/2015	8:07	1	76	76	Overhead equipment	Fuse	Replace - Same Size		I
5067027	A45001	07/07/2015	6:51	07/07/2015	8:05	1	73	73	Overhead equipment	Fuse	Replace - Same Size		I
5067029	Q24313	07/07/2015	7:03	07/07/2015	8:05	1	61	61	Animal related	Transformer Fuse	Replace - Same Size		VI
5067039	J47175	07/07/2015	7:36	07/07/2015	8:22	1	45	45	Animal related	Transformer Fuse	Repair	Repair	III
5067041	B61001	07/07/2015	7:36	07/07/2015	8:50	1	73	73	Overhead equipment	Transformer Fuse	Replace - Same Size		I
5067043	V69546	07/07/2015	7:42	07/07/2015	9:38	1	115	115	Animal related	Transformer Fuse	Replace - Same Size		II
5067053	A45001	07/07/2015	8:16	07/07/2015	10:15	3	354	118	Overhead equipment	Disconnect Switch	Replace - Same Size	Repair	I
5067057	B61001	07/07/2015	8:25	07/07/2015	8:50	13	324	24	Overhead equipment	Crossarm	Repair		I
5067083	N44215	07/07/2015	8:25	07/07/2015	9:59	284	26724	94	Unknown				III
5067133	N44215	07/07/2015	8:29	07/07/2015	9:59	259	23395	90	Overhead equipment				III
5067077	M40131	07/07/2015	8:34	07/07/2015	10:51	1	136	136	Overhead equipment	Overhead Service	Patrol/Test/Inspect	Replace - Same Size	I
5067103	B62004	07/07/2015	8:57	07/07/2015	10:20	1	82	82	Overhead equipment	Fuse	Replace - Same Size		I
5067105	B58002	07/07/2015	9:03	07/07/2015	10:28	1	84	84	Animal related				I
5067115	P62138	07/07/2015	9:11	07/07/2015	12:33	1	201	201	Overhead equipment	Overhead Transformer	Repair		VI
5067121	R48167	07/07/2015	9:16	07/07/2015	10:07	1	50	50	Animal related	Fuse			IV
5067125	P58154	07/07/2015	9:21	07/07/2015	13:58	11	3039	276	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	VI
5067129	A17022	07/07/2015	9:31	07/07/2015	10:57	1	85	85	Unknown	Fuse	Replace - Same Size		I
5067131	S42579	07/07/2015	9:32	07/07/2015	10:18	14	633	45	Overhead equipment	Fuse	Repair	Replace - Same Size	VI
5067137	D28124	07/07/2015	9:35	07/07/2015	11:12	1	96	96	Animal related	Fuse	Replace - Same Size		I
5067151	S49549	07/07/2015	9:46	07/07/2015	10:20	1	33	33	Overhead equipment				VI
5067153	S07536	07/07/2015	9:49	07/07/2015	10:25	1	35	35	Animal related	Overhead Primary	Repair	Repair	VI
5067171	P85141	07/07/2015	9:51	07/07/2015	10:22	54	1665	30	Overhead equipment				III
5067167	J80806	07/07/2015	9:55	07/07/2015	10:25	1	29	29	Tree related-tree contact	Overhead Secondary	Repair	Repair	V
5067173	Y11555	07/07/2015	9:58	07/07/2015	11:20	1	81	81	Animal related	Fuse	Replace - Same Size		IV
5067203	R71-UNIT-1	07/07/2015	9:58	07/07/2015	10:56	804	46511	57	Substation equipment	Lightning Arrestor	Replace - Same Size		VI
5067269	X57566	07/07/2015	10:22	07/07/2015	11:46	274	6589	83	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	IV
5067273	B93002	07/07/2015	10:31	07/07/2015	12:07	1	95	95	Animal related	Fuse	Replace - Same Size		I

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5067371	X02548	07/07/2015	10:36	07/07/2015	11:50	4	295	73	Weather	Fuse	Replace - Same Size		IV
5067281	J15303	07/07/2015	10:37	07/07/2015	12:41	65	7996	123	Unknown	Recloser	Switch/Reset		I
5067289	K28180	07/07/2015	10:47	07/07/2015	11:53	1	65	65	Overhead equipment	Transformer Fuse	Repair		III
5067323	329149	07/07/2015	10:48	07/07/2015	16:43	598	169150	355	Underground equipment				V
5067307	U42512	07/07/2015	10:51	07/07/2015	12:00	1	68	68	Overhead equipment	Transformer Fuse	Replace - Same Size	Replace - Same Size	II
5067321	J06168	07/07/2015	10:53	07/07/2015	12:28	1	94	94	Weather	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	I
5067341	HA5432	07/07/2015	11:09	07/07/2015	12:12	1	62	62	Tree related-tree broken	Overhead Service	Repair		V
5067343	K94224	07/07/2015	11:10	07/07/2015	13:05	1	114	114	Other				III
5067357	330125	07/07/2015	11:21	07/07/2015	16:28	4	1225	306	Overhead equipment	Overhead Service	Patrol/Test/Inspect		V
5067365	L59929	07/07/2015	11:28	07/07/2015	12:15	8	372	46	Animal related	Fuse	Repair		VI
5067379	Q32170	07/07/2015	11:59	07/07/2015	13:14	1	74	74	Unknown	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	I
5067381	S47589	07/07/2015	12:01	07/07/2015	13:24	26	2134	82	Tree related-tree broken	Tree		Remove	VI
5067387	306003	07/07/2015	12:11	07/07/2015	14:26	1	134	134	Public	Overhead Service	Repair		VI
5067393	K09864	07/07/2015	12:21	07/07/2015	16:42	1	260	260	Underground equipment	Underground Primary	Replace - Same Size	Repair	V
5067397	U57560	07/07/2015	12:42	07/07/2015	14:09	1	86	86	Weather	Disconnect Switch	Replace - Same Size		II
5067399	Q63835	07/07/2015	12:45	07/07/2015	13:40	1	55	55	Overhead equipment	Transformer Fuse	Replace - Same Size		V
5067421	N35852	07/07/2015	13:30	07/07/2015	14:17	1	46	46	Tree related-tree broken	Overhead Service	Repair		V
5155115	R65451	07/07/2015	14:09	07/07/2015	17:17	8	1506	188	Overhead equipment				IV
5067457	329149	07/07/2015	14:37	07/07/2015	16:50	1	132	132	Underground equipment				V
5067483	P49180	07/07/2015	14:58	07/08/2015	7:59	61	17923	1021	Overhead equipment	Capacitor	Disconnect	Disconnect	I
5067477	329149	07/07/2015	15:34	07/07/2015	16:38	1	63	63	Overhead equipment				V
5067481	K09864	07/07/2015	15:36	07/07/2015	16:41	1	64	64	Underground equipment				V
5067487	Q32170	07/07/2015	15:47	07/07/2015	16:58	1	70	70	Animal related	Fuse	Repair	Replace - Same Size	I
5067489	H14342	07/07/2015	15:57	07/07/2015	17:25	6	527	87	Overhead equipment				V
5155119	R65451	07/07/2015	16:00	07/07/2015	17:17	346	26832	77	Overhead equipment				IV
5067491	S60581	07/07/2015	16:09	07/07/2015	17:26	1	76	76	Animal related	Transformer Fuse	Replace - Same Size		VI
5067499	329149	07/07/2015	16:28	07/07/2015	16:51	15	337	22	Overhead equipment	Customer Equipment	Advise Customer		V
5067501	329149	07/07/2015	16:33	07/07/2015	16:52	1	19	19	Underground equipment				V
5067503	C37001	07/07/2015	16:36	07/07/2015	18:01	1	84	84	Jurisdictional	Overhead Service	Disconnect	Disconnect	III
5067507	N60181	07/07/2015	16:42	07/08/2015	1:13	13	6640	510	Overhead equipment	Overhead Primary	Repair	Replace - Same Size	I
5067509	N60181	07/07/2015	16:43	07/07/2015	20:04	6	1204	200	Overhead equipment	Fuse	Repair	Replace - Same Size	I
5067511	329149	07/07/2015	16:45	07/08/2015	4:14	1	688	688	Underground equipment	Underground Transformer	Patrol/Test/Inspect	Replace - Same Size	V
5067541	J85161	07/07/2015	16:52	07/07/2015	18:11	289	22764	78	Public				VI
5067519	S83533	07/07/2015	16:53	07/07/2015	18:29	1	95	95	Overhead equipment	Overhead Primary			VI
5067539	312112	07/07/2015	16:56	07/07/2015	17:43	1	46	46	Overhead equipment	Overhead Service	Repair		V
5067549	X42501	07/07/2015	17:00	07/07/2015	18:06	1	65	65	Overhead equipment	Overhead Transformer	Replace - Same Size		IV
5067591	P49188	07/07/2015	17:31	07/07/2015	19:00	1	88	88	Overhead equipment	Overhead Primary	Patrol/Test/Inspect	Patrol/Test/Inspect	I
5067593	K36151	07/07/2015	17:34	07/07/2015	18:58	1	83	83	Overhead equipment	Connector	Replace - Same Size		III
5067595	X88510	07/07/2015	17:41	07/07/2015	19:33	1	111	111	Overhead equipment	Overhead Secondary	Repair		IV
5067597	M40132	07/07/2015	17:42	07/07/2015	20:38	1	175	175	Overhead equipment	Overhead Service	Repair	Replace - Same Size	I
5067599	X42501	07/07/2015	17:47	07/07/2015	18:06	1	18	18	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
5067601	R39934	07/07/2015	17:50	07/07/2015	22:50	926	58601	300	Public	Pole		Repair	VI
5067603	S47575	07/07/2015	17:50	07/07/2015	19:12	1	81	81	Animal related	Transformer Fuse		Replace - New Size	VI
5067605	S43502	07/07/2015	17:53	07/07/2015	19:05	1	71	71	Overhead equipment				VI
5067613	A36001	07/07/2015	18:06	07/07/2015	18:08	3	6	2	Unknown				I
5067619	C37001	07/07/2015	18:11	07/07/2015	19:17	1	65	65	Other				III
5067621	K15205	07/07/2015	18:12	07/08/2015	1:18	31	13219	426	Public				VI
5067625	B00005	07/07/2015	18:19	07/07/2015	19:20	1	60	60	Overhead equipment	Overhead Service	Repair		I
5067671	S93504	07/07/2015	19:30	07/07/2015	20:38	1	67	67	Overhead equipment	Transformer Fuse	Replace - Same Size		VI
5067675	M73328	07/07/2015	19:46	07/07/2015	21:14	1	87	87	Tree related-tree broken	Overhead Service	Reconnect		V
5067681	Y50002	07/07/2015	20:30	07/07/2015	21:25	1	54	54	Tree related-tree broken	Overhead Secondary	Repair		IV
5067689	R20502	07/07/2015	21:19	07/08/2015	1:20	1	240	240	Underground equipment	Underground Connector		Repair	IV
5067723	L79159	07/07/2015	22:44	07/07/2015	23:57	4	288	72	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
5067737	K67924	07/07/2015	22:45	07/08/2015	0:56	77	10073	130	Overhead equipment	Recloser	Switch/Reset	Patrol/Test/Inspect	VI
5067785	X12526	07/07/2015	22:57	07/08/2015	2:25	9	1873	208	Underground equipment	Fuse	Patrol/Test/Inspect	Replace - Same Size	IV
5067795	D92001	07/07/2015	22:58	07/08/2015	5:58	1	419	419	Underground equipment	Underground Service	Patrol/Test/Inspect	Replace - Urgent	I

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5067821	T14576	07/08/2015	0:01	07/08/2015	1:45	4	412	103	Overhead equipment	Fuse	Patrol/Test/Inspect	Patrol/Test/Inspect	VI
5067831	V10551	07/08/2015	4:06	07/08/2015	15:24	1	677	677	Tree related-tree broken	Overhead Primary	Replace - Same Size		II
5067849	V10551	07/08/2015	4:10	07/08/2015	15:23	139	90709	672	Tree related-tree broken	Overhead Primary	Remove	Repair	II
5067841	M53310	07/08/2015	4:19	07/08/2015	10:00	1	340	340	Tree related-tree broken	Overhead Service	Patrol/Test/Inspect		V
5067843	V89527	07/08/2015	4:41	07/08/2015	7:50	1	188	188	Other	Recloser	Switch/Reset		II
5067855	351001	07/08/2015	5:08	07/08/2015	6:50	1	102	101	Overhead equipment	Fuse	Replace - Same Size		VI
5067869	K28183	07/08/2015	5:46	07/08/2015	9:21	2	429	214	Public	Overhead Service			III
5067873	C70004	07/08/2015	5:50	07/08/2015	7:13	74	6105	82	Tree related-tree broken	Fuse			III
5067909	C70004	07/08/2015	5:50	07/08/2015	10:35	7	1990	284	Tree related-tree broken	Overhead Primary	Replace - Same Size		III
5154835	K69116	07/08/2015	6:09	07/08/2015	7:05	33	1849	56	Unknown				IV
5067887	K69116	07/08/2015	6:22	07/08/2015	7:15	1	52	52	Unknown				IV
5067889	J71128	07/08/2015	6:38	07/08/2015	14:45	1	486	486	Underground equipment	Overhead Service		Repair	I
5067897	S86582	07/08/2015	6:49	07/08/2015	12:06	2	633	316	Unknown	Overhead Transformer	Replace - Same Size		VI
5067899	Y23521	07/08/2015	6:51	07/08/2015	12:11	10	2246	319	Underground equipment	Underground Primary	Repair	Replace - Same Size	IV
5067901	K32915	07/08/2015	7:04	07/08/2015	9:33	1	148	148	Overhead equipment	Overhead Secondary		Repair	VI
5067903	L93149	07/08/2015	7:05	07/08/2015	8:10	1	64	64	Underground equipment	Underground Secondary			VI
5067907	C70004	07/08/2015	7:14	07/08/2015	10:35	1	200	200	Tree related-tree broken	Overhead Primary	Replace - Same Size		III
5067911	C70004	07/08/2015	7:14	07/08/2015	10:35	5	1000	200	Tree related-tree broken	Overhead Primary	Replace - Same Size		III
5067913	J06168	07/08/2015	7:19	07/08/2015	8:42	1	82	82	Unknown	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	I
5067921	X83541	07/08/2015	7:47	07/08/2015	8:35	1	47	47	Animal related	Fuse	Replace - Same Size		IV
5067931	K67924	07/08/2015	8:22	07/08/2015	10:20	76	8922	117	Overhead equipment	Recloser	Switch/Reset	Patrol/Test/Inspect	VI
5067933	Q15844	07/08/2015	8:24	07/08/2015	9:01	1	36	36	Animal related	Transformer Fuse	Replace - Same Size		V
5067937	J06167	07/08/2015	8:36	07/08/2015	12:39	1	242	242	Overhead equipment	Overhead Service	Patrol/Test/Inspect	Repair	I
5067945	D55001	07/08/2015	8:37	07/08/2015	10:55	7	963	137	Overhead equipment	Fuse	Patrol/Test/Inspect	Repair	I
5067941	Q34366	07/08/2015	8:38	07/08/2015	9:53	2	149	74	Animal related	Fuse	Replace - Same Size	Replace - Same Size	I
5067943	Q11517	07/08/2015	8:44	07/08/2015	9:22	1	37	37	Animal related	Transformer Fuse	Replace - Same Size		I
5067947	Q24312	07/08/2015	9:12	07/08/2015	11:15	3	366	122	Public				VI
5067957	J13108	07/08/2015	9:41	07/08/2015	10:45	1	63	63	Unknown	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	I
5067967	J83137	07/08/2015	10:11	07/08/2015	11:41	37	3314	89	Overhead equipment	Fuse	Repair	Repair	VI
5067985	K79212	07/08/2015	10:34	07/08/2015	12:17	1	102	102	Tree related-tree broken	Overhead Service	Disconnect	Reconnect	IV
5067989	V49535	07/08/2015	10:50	07/09/2015	3:22	1	991	991	Underground equipment	Underground Primary		Repair	II
5067999	N86228	07/08/2015	11:10	07/08/2015	12:28	8	621	77	Animal related	Transformer Fuse	Replace - Same Size		VI
5068007	343008	07/08/2015	11:26	07/08/2015	19:25	1	478	478	Tree related-tree broken	Tree	Patrol/Test/Inspect	Trim	VI
5068013	H06135	07/08/2015	11:34	07/08/2015	13:28	9	1025	113	Tree related-tree contact	Tree			IV
5068019	302003	07/08/2015	11:50	07/08/2015	14:00	1	129	129	Tree related-tree broken	Overhead Primary		Repair	VI
5068021	V24583	07/08/2015	11:51	07/08/2015	16:37	1	285	285	Tree related-tree broken	Fuse	Patrol/Test/Inspect	Replace - Same Size	II
5068023	D39002	07/08/2015	11:54	07/08/2015	12:59	1	64	64	Overhead equipment	Lightning Arrestor	Repair	Replace - Same Size	I
5068025	S20554	07/08/2015	12:05	07/08/2015	13:09	1	63	63	Other	Other	Patrol/Test/Inspect		VI
5068029	K27122	07/08/2015	12:08	07/08/2015	12:45	1	36	36	Other	Other	Reconnect	Reconnect	VI
5068031	K32915	07/08/2015	12:11	07/08/2015	13:30	7	552	78	Animal related	Fuse	Replace - Same Size		VI
5068033	K57212	07/08/2015	12:25	07/08/2015	13:46	1	80	80	Overhead equipment	Connector	Repair		VI
5068039	K39153	07/08/2015	12:33	07/08/2015	14:15	1	101	101	Tree related-tree contact	Overhead Service	Replace - Same Size		III
5068043	H06135	07/08/2015	12:38	07/08/2015	13:20	1	41	41	Tree related-tree contact	Overhead Secondary			IV
5068045	P47120	07/08/2015	12:40	07/08/2015	14:50	8	1038	129	Overhead equipment	Fuse	Replace - Same Size	Patrol/Test/Inspect	I
5068071	P47120	07/08/2015	12:58	07/08/2015	14:30	5	457	91	Overhead equipment	Fuse	Replace - Same Size	Patrol/Test/Inspect	I
5068053	D93002	07/08/2015	13:00	07/08/2015	14:13	6	432	72	Tree related-tree broken	Transformer Fuse	Replace - Same Size		IV
5068055	307001	07/08/2015	13:02	07/08/2015	16:05	1	182	182	Overhead equipment	Overhead Service	Repair		VI
5068061	R66470	07/08/2015	13:08	07/08/2015	16:35	1	206	206	Underground equipment	Underground Service	Patrol/Test/Inspect	Repair	IV
5068107	B19002	07/08/2015	13:23	07/08/2015	15:20	1	116	116	Other	Overhead Service	Replace - Same Size		I
5068113	K46388	07/08/2015	13:24	07/08/2015	14:04	1	39	39	Animal related	Fuse	Replace - Same Size		V
5068117	H00162	07/08/2015	13:31	07/08/2015	15:42	1	130	130	Tree related-tree contact	Overhead Service			III
5068119	M20221	07/08/2015	13:31	07/08/2015	15:52	1	140	140	Animal related	Transformer Fuse	Replace - Same Size		VI
5068135	P17107	07/08/2015	14:06	07/08/2015	14:59	38	2028	53	Underground equipment	Underground Primary	Switch/Reset	Repair	IV
5068139	P39298	07/08/2015	14:08	07/08/2015	14:29	3	63	21	Public	Underground Primary	Patrol/Test/Inspect		VI
5068141	R41131	07/08/2015	14:09	07/08/2015	16:11	3	365	121	Unknown	Disconnect Switch	Patrol/Test/Inspect	Replace - New Size	VI
5068145	Q15844	07/08/2015	14:09	07/08/2015	14:42	1	32	32	Animal related	Transformer Fuse	Replace - Same Size		V

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5068157	P82290	07/08/2015	14:45	07/08/2015	15:22	8	293	36	Animal related	Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
5068161	Y97513	07/08/2015	15:02	07/08/2015	15:16	1	13	13	Overhead equipment				IV
5068169	G30001	07/08/2015	15:25	07/08/2015	16:30	1	64	64	Overhead equipment	Fuse	Replace - Same Size		III
5068171	R28870	07/08/2015	15:26	07/08/2015	16:38	8	573	71	Animal related	Transformer Fuse	Replace - Same Size		V
5068173	K80382	07/08/2015	15:35	07/08/2015	18:20	29	4782	164	Animal related	Fuse	Patrol/Test/Inspect	Patrol/Test/Inspect	IV
5068177	L50214	07/08/2015	15:38	07/08/2015	17:09	1	90	90	Overhead equipment	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
5068179	K71812	07/08/2015	15:40	07/08/2015	19:30	1	230	229	Tree related-tree contact	Tree	Patrol/Test/Inspect	Remove	IV
5068197	Z04520	07/08/2015	16:19	07/08/2015	17:40	4	322	80	Animal related	Transformer Fuse	Replace - Same Size		IV
5068201	P77237	07/08/2015	16:32	07/08/2015	18:35	1	122	122	Tree related-tree broken	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
5068203	N67315	07/08/2015	16:33	07/08/2015	17:27	1	53	53	Other	Other			I
5068231	D39001	07/08/2015	16:45	07/08/2015	18:15	532	47656	89	Overhead equipment	Fuse	Replace - Same Size		I
5068271	P77237	07/08/2015	17:02	07/08/2015	18:35	1	92	92	Tree related-tree broken	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
5068285	L00134	07/08/2015	17:06	07/08/2015	17:13	1	6	6	Underground equipment	Underground Service	Patrol/Test/Inspect	Repair	III
5068301	S86580	07/08/2015	17:41	07/09/2015	0:53	2	863	431	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	VI
5068305	343008	07/08/2015	17:48	07/08/2015	19:25	1	96	96	Tree related-tree broken	Overhead Secondary	Repair		VI
5068311	K39154	07/08/2015	18:02	07/08/2015	21:29	17	2779	206	Underground equipment	Underground Primary	Switch/Reset	Repair	III
5068321	Q32170	07/08/2015	18:24	07/08/2015	20:00	63	5996	95	Animal related	Fuse	Replace - Same Size		I
5068327	K57212	07/08/2015	18:48	07/08/2015	21:23	17	2643	155	Underground equipment	Underground Primary	Patrol/Test/Inspect	Replace - Same Size	VI
5068333	M40132	07/08/2015	18:59	07/08/2015	21:25	1	145	145	Overhead equipment	Jumper	Repair		I
5068335	Q91175	07/08/2015	19:00	07/08/2015	20:30	1	89	89	Animal related	Transformer Fuse	Replace - Same Size		I
5068343	D89001	07/08/2015	19:14	07/08/2015	20:12	1	57	57	Animal related	Fuse	Replace - Same Size		I
5068345	K91117	07/08/2015	19:38	07/08/2015	21:14	1	95	95	Tree related-tree contact	Overhead Service	Replace - Same Size		III
5068351	R60552	07/08/2015	20:33	07/08/2015	23:59	8	1425	206	Underground equipment	Underground Primary	Switch/Reset	Repair	IV
5068355	L43154	07/08/2015	20:58	07/08/2015	23:30	1	151	151	Overhead equipment	Overhead Service	Repair	Repair	I
5068357	309139	07/08/2015	21:09	07/09/2015	0:03	19	3298	173	Overhead equipment	Overhead Secondary	Cut in Clear		V
5068363	A17021	07/08/2015	21:17	07/08/2015	23:25	61	7762	127	Animal related	Fuse	Patrol/Test/Inspect		I
5068369	J15303	07/08/2015	21:23	07/08/2015	22:00	1	36	36	Other	Other			I
5068507	302004	07/08/2015	21:26	07/08/2015	22:04	398	15012	37	Unknown				VI
5068471	302001	07/08/2015	21:28	07/08/2015	22:04	114	4086	35	Weather				VI
5068393	342004	07/08/2015	21:30	07/08/2015	21:59	710	21065	29	Weather				VI
5068419	342003	07/08/2015	21:34	07/08/2015	21:59	584	14646	25	Unknown				VI
5068495	S83-XTR1	07/08/2015	21:35	07/08/2015	22:52	888	68242	76	Overhead equipment	Overhead Primary	Replace - Same Size	Replace - Same Size	VI
5068531	302002	07/08/2015	21:36	07/08/2015	22:04	82	2331	28	Weather				VI
5068583	S34-XTR1	07/08/2015	21:36	07/09/2015	9:46	462	330085	729	Tree related-tree broken				VI
5068697	S75-XTR1	07/08/2015	21:36	07/09/2015	8:50	197	132636	673	Tree related-tree broken				VI
5068487	302003	07/08/2015	21:37	07/08/2015	22:04	59	1630	27	Weather				VI
5068445	K39154	07/08/2015	21:37	07/08/2015	21:45	1	7	7	Underground equipment	Underground Primary	Switch/Reset	Repair	III
5068563	C40002	07/08/2015	21:45	07/09/2015	3:23	557	180840	338	Overhead equipment	Pole	Replace - Same Size	Repair	I
5068787	C10001	07/08/2015	21:58	07/09/2015	2:55	9	2671	296	Underground equipment	Underground Transformer	Replace - Same Size		III
5068747	342004	07/08/2015	22:08	07/08/2015	23:13	93	6005	64	Weather				VI
5068833	B62003	07/08/2015	22:35	07/09/2015	0:00	1	84	84	Tree related-tree broken				I
5068839	Y89541	07/08/2015	22:39	07/09/2015	0:11	6	551	91	Overhead equipment	Disconnect Switch	Repair	Replace - Same Size	IV
5068841	S95571	07/08/2015	22:42	07/09/2015	2:00	32	6322	197	Tree related-tree broken				VI
5068845	S95571	07/08/2015	22:47	07/09/2015	2:00	1	192	192	Tree related-tree broken				VI
5068855	S83503	07/08/2015	23:03	07/09/2015	8:15	3	1655	551	Tree related-tree broken	Overhead Secondary	Repair	Repair	VI
5068859	T05539	07/08/2015	23:07	07/09/2015	3:00	39	9058	232	Overhead equipment				VI
5068861	A85001	07/08/2015	23:08	07/09/2015	7:10	1	482	481	Underground equipment	Underground Primary	Patrol/Test/Inspect	Replace - Urgent	I
5068865	S83533	07/08/2015	23:09	07/09/2015	6:10	1	420	420	Tree related-tree broken				VI
5068871	L24122	07/08/2015	23:17	07/09/2015	1:32	37	4966	134	Underground equipment	Underground Primary		Repair	III
5068873	L24122	07/08/2015	23:19	07/09/2015	0:33	1	73	73	Underground equipment	Other			III
5068897	S78551	07/08/2015	23:29	07/09/2015	3:00	12	2526	210	Overhead equipment				VI
5068911	B65003	07/08/2015	23:34	07/09/2015	2:28	1240	215450	173	Overhead equipment	Overhead Primary	Replace - Same Size	Replace - Same Size	I
5069035	Z50544	07/08/2015	23:56	07/09/2015	7:43	1	466	466	Underground equipment	Underground Primary	Repair	Replace - Same Size	IV
5068915	P17108	07/08/2015	23:57	07/09/2015	3:59	2	483	241	Tree related-tree broken	Fuse			IV
5068917	T05539	07/09/2015	0:16	07/09/2015	5:58	1	341	341	Tree related-tree broken	Overhead Primary	Repair		VI
5068927	S55534	07/09/2015	1:07	07/09/2015	2:01	28	1507	53	Overhead equipment	Fuse	Patrol/Test/Inspect		VI

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5068925	S55534	07/09/2015	1:20	07/09/2015	2:17	1	56	56	Overhead equipment	Transformer Fuse	Replace - New Size		VI
5068929	S55534	07/09/2015	1:38	07/09/2015	2:29	1	50	50	Tree related-tree broken	Overhead Service	Repair	Repair	VI
5068931	D35002	07/09/2015	1:38	07/09/2015	5:20	1	221	221	Tree related-tree contact	Tree	Trim		I
5068933	S55534	07/09/2015	1:43	07/09/2015	2:31	1	47	47	Overhead equipment	Transformer Fuse	Replace - New Size		VI
5068913	Z50544	07/09/2015	1:47	07/09/2015	8:03	10	3431	376	Underground equipment	Fuse	Patrol/Test/Inspect		IV
5068937	A85001	07/09/2015	2:23	07/09/2015	7:08	4	1139	284	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
5068939	X60596	07/09/2015	2:37	07/09/2015	6:10	10	2122	212	Overhead equipment	Overhead Transformer	Replace - Same Size	Replace - Same Size	IV
5068941	X87578	07/09/2015	2:44	07/09/2015	3:50	2	131	65	Overhead equipment	Disconnect Switch	Repair		IV
5068943	K65221	07/09/2015	2:55	07/09/2015	4:26	1	90	90	Tree related-tree contact	Overhead Service	Repair	Repair	III
5068947	D28124	07/09/2015	3:04	07/09/2015	6:17	35	6745	192	Overhead equipment	Lightning Arrestor	Patrol/Test/Inspect	Replace - Same Size	I
5068949	M09143	07/09/2015	3:06	07/09/2015	5:16	3	388	129	Tree related-tree broken	Fuse	Replace - Same Size		VI
5068951	T05539	07/09/2015	3:28	07/09/2015	5:55	39	5722	146	Overhead equipment	Overhead Service		Repair	VI
5068975	D36002	07/09/2015	4:10	07/09/2015	6:18	1654	210669	127	Overhead equipment	Regulator		Repair	I
5068985	M09144	07/09/2015	4:29	07/09/2015	6:55	1	145	145	Tree related-tree broken	Overhead Secondary	Repair		VI
5068989	D36001	07/09/2015	4:33	07/09/2015	6:27	1	113	113	Overhead equipment	Regulator	Patrol/Test/Inspect	Patrol/Test/Inspect	I
5068991	S78551	07/09/2015	4:39	07/09/2015	9:37	1	297	297	Tree related-tree broken	Overhead Primary	Repair		VI
5068995	N86225	07/09/2015	5:35	07/09/2015	16:09	1	633	633	Public	Meter			VI
5069001	Q74149	07/09/2015	5:57	07/09/2015	8:00	1	122	122	Unknown	Transformer Fuse	Replace - Same Size		IV
5069003	R01153	07/09/2015	6:17	07/09/2015	7:51	1	93	93	Tree related-tree contact	Overhead Service	Repair	Repair	III
5069005	K69117	07/09/2015	6:33	07/09/2015	8:00	30	2595	86	Animal related	Fuse	Patrol/Test/Inspect	Replace - Same Size	IV
5069023	U16500	07/09/2015	7:02	07/09/2015	8:52	1	109	109	Tree related-tree broken	Overhead Service	Replace - Same Size		II
5069027	V24583	07/09/2015	7:16	07/09/2015	13:24	1	367	367	Underground equipment	Underground Secondary	Repair	Replace - Same Size	II
5069029	N23-UNIT-1	07/09/2015	7:18	07/09/2015	14:22	1	423	423	Animal related	Overhead Transformer	Patrol/Test/Inspect		VI
5069033	J67134	07/09/2015	7:28	07/09/2015	9:34	13	1632	125	Tree related-tree contact	Overhead Service	Repair	Repair	III
5069043	J61114	07/09/2015	8:03	07/09/2015	8:28	1	24	24	Other	Transformer Fuse			III
5069047	Z50544	07/09/2015	8:07	07/09/2015	19:21	5	3370	674	Underground equipment	Switchgear	Patrol/Test/Inspect	Repair	IV
5069059	V21500	07/09/2015	8:37	07/09/2015	9:22	4	178	44	Animal related	Disconnect Switch	Repair		II
5069073	K76547	07/09/2015	9:02	07/09/2015	10:30	1	87	87	Animal related	Fuse	Replace - Same Size		IV
5069077	U33586	07/09/2015	9:04	07/09/2015	11:55	3	510	170	Overhead equipment	Overhead Transformer	Repair		II
5069081	K71822	07/09/2015	9:04	07/09/2015	10:19	1	74	74	Unknown	Overhead Service			IV
5069087	K76547	07/09/2015	9:08	07/09/2015	10:30	1	81	81	Animal related	Fuse	Replace - Same Size		IV
5069103	310122	07/09/2015	9:24	07/09/2015	11:29	1	124	124	Underground equipment	Underground Secondary	Repair	Repair	V
5069145	Q32170	07/09/2015	9:57	07/09/2015	11:27	131	11767	89	Animal related	Fuse	Replace - Same Size		I
5069139	N60181	07/09/2015	10:04	07/09/2015	12:15	1	130	130	Overhead equipment	Connector	Replace - New Size	Patrol/Test/Inspect	I
5069141	K76547	07/09/2015	10:04	07/09/2015	10:30	181	4620	25	Animal related	Fuse	Replace - Same Size		IV
5069143	R04407	07/09/2015	10:10	07/09/2015	11:05	1	54	54	Animal related	Fuse	Replace - Same Size		V
5069147	N60181	07/09/2015	10:15	07/09/2015	13:30	1	194	194	Animal related	Fuse	Replace - Same Size	Patrol/Test/Inspect	I
5069185	R95520	07/09/2015	10:21	07/09/2015	12:53	31	4709	151	Overhead equipment	Recloser	Patrol/Test/Inspect	Repair	I
5069177	L50215	07/09/2015	10:25	07/09/2015	11:03	2	74	37	Overhead equipment	Overhead Service	Patrol/Test/Inspect	Repair	VI
5069181	A28001	07/09/2015	10:28	07/09/2015	11:15	1	46	46	Overhead equipment	Connector	Replace - Same Size		I
5069205	S83503	07/09/2015	10:58	07/09/2015	19:27	1	508	508	Tree related-tree broken	Overhead Service	Repair	Replace - Same Size	VI
5069213	R53391	07/09/2015	11:08	07/09/2015	12:03	23	1244	54	Animal related	Fuse	Replace - Same Size	Replace - Same Size	V
5069225	K32932	07/09/2015	11:19	07/09/2015	12:34	19	1415	74	Overhead equipment	Fuse			VI
5069235	B61001	07/09/2015	11:22	07/09/2015	14:38	12	2356	196	Underground equipment	Underground Primary	Repair	Replace - Same Size	I
5069289	A56014	07/09/2015	11:26	07/09/2015	13:01	569	53525	94	Other	Fuse	Replace - Same Size		I
5069251	D69004	07/09/2015	11:31	07/09/2015	15:30	1	238	238	Underground equipment	Overhead Service	Repair	Repair	I
5069259	N35820	07/09/2015	11:36	07/09/2015	13:00	1	83	83	Intentional	Meter	Patrol/Test/Inspect		V
5069273	C10002	07/09/2015	11:54	07/09/2015	12:36	1	41	41	Other	Other	Replace - Same Size	Patrol/Test/Inspect	III
5069279	K69117	07/09/2015	11:58	07/09/2015	14:02	1	123	123	Overhead equipment				IV
5069281	N72240	07/09/2015	11:59	07/09/2015	12:50	1	50	50	Overhead equipment	Fuse		Replace - Same Size	III
5069299	C36002	07/09/2015	12:21	07/09/2015	14:12	1	110	110	Underground equipment	Underground Service	Repair		III
5069303	N72240	07/09/2015	12:22	07/09/2015	13:10	5	238	47	Overhead equipment	Fuse		Replace - Same Size	III
5069307	Q32170	07/09/2015	12:30	07/09/2015	15:34	1	183	183	Overhead equipment	Overhead Service	Disconnect	Cut in Clear	I
5069311	L95110	07/09/2015	12:36	07/09/2015	13:26	1	49	49	Tree related-tree contact	Overhead Service			III
5069313	S15559	07/09/2015	12:37	07/09/2015	14:19	1	101	101	Overhead equipment	Connector	Tie/Tighten		VI
5069315	P09307	07/09/2015	12:44	07/09/2015	17:50	1	305	305	Overhead equipment	Overhead Transformer		Replace - Same Size	V