Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5095093	342004	07/28/2015	16:14	07/29/2015	1:45	1	570	570	Tree related-tree broken	Tree	Trim		VI
5095095	346002	07/28/2015	16:15	07/28/2015	23:20	1	424	424	Tree related-tree contact	Overhead Secondary	Patrol/Test/Inspect	Repair	VI
5095101	N93260	07/28/2015	16:16	07/28/2015	19:47	1	210	210	Overhead equipment	Fuse	Replace - Same Size		III
5095105	346003	07/28/2015	16:17	07/28/2015	22:34	5	1884	376	Overhead equipment				VI
5095103	303001	07/28/2015	16:17	07/29/2015	1:36	1	558	558	Tree related-tree broken	Overhead Service	Repair		VI
5095109	T08502	07/28/2015	16:18	07/28/2015	20:00	1	221	221	Underground equipment	Underground Service	Patrol/Test/Inspect	Repair	VI
5095133	303005	07/28/2015	16:22	07/28/2015	21:30	5	1540	308	Overhead equipment	Overhead Secondary	Patrol/Test/Inspect		VI
5095131	349001	07/28/2015	16:22	07/28/2015	22:10	6	2088	348	Weather				VI
5095161	303001	07/28/2015	16:22	07/29/2015	2:05	41	23881	582	Tree related-tree broken				VI
5095137	303004	07/28/2015	16:23	07/28/2015	20:45	39	10198	261	Overhead equipment				VI
5095139	Y98518	07/28/2015	16:23	07/28/2015	18:15	1	111	111	Public	Overhead Secondary	Replace - Same Size	Replace - Same Size	IV
5095151	J86118	07/28/2015	16:25	07/28/2015	18:42	1	136	136	Overhead equipment	Transformer Fuse	Replace - Same Size		VI
5095165	351001	07/28/2015	16:30	07/29/2015	1:06	1	515	515	Overhead equipment	Overhead Service	Repair		VI
5095171	G50002	07/28/2015	16:31	07/28/2015	19:15	1	163	163	Weather	Fuse	Replace - Same Size		IV
5095189	Q24312	07/28/2015	16:35	07/28/2015	19:18	1	162	162	Weather	Transformer Fuse	Replace - Same Size		VI
5095191	B84002	07/28/2015	16:35	07/29/2015	1:40	3	1634	544	Public				I
5095193	K15205	07/28/2015	16:35	07/28/2015	18:05	1	89	89	Tree related-tree broken	Transformer Fuse			VI
5095195	303005	07/28/2015	16:36	07/29/2015	2:05	1	568	568	Tree related-tree broken				VI
5095197	341001	07/28/2015	16:38	07/28/2015	19:10	4	605	151	Overhead equipment	Fuse	Replace - Same Size		VI
5095201	Q24313	07/28/2015	16:42	07/28/2015	23:54	2	863	431	Weather	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	VI
5095219	S36571	07/28/2015	16:47	07/28/2015	18:38	14	1550	110	Tree related-tree broken	Overhead Primary	Repair		VI
5095395	303004	07/28/2015	16:48	07/28/2015	20:30	48	10653	221	Weather				VI
5095217	346004	07/28/2015	16:57	07/28/2015	20:33	41	8853	215	Weather				VI
5095221	303007	07/28/2015	16:58	07/29/2015	2:19	1	560	560	Overhead equipment	Overhead Service		Reconnect	VI
5095227	P69173	07/28/2015	17:02	07/28/2015	17:48	1	45	45	Unknown	Transformer Fuse	Replace - Same Size		III
5095261	346003	07/28/2015	17:09	07/29/2015	0:30	25	11006	440	Tree related-tree broken	Overhead Primary	Repair		VI
5095239	C30-X1	07/28/2015	17:14	07/28/2015	17:16	622	1729	2	Overhead equipment	Recloser	Switch/Reset		III
5095253	J86118	07/28/2015	17:15	07/28/2015	18:18	1	62	62	Weather	Fuse	Replace - Same Size		VI
5095271	303001	07/28/2015	17:21	07/29/2015	2:05	1	523	523	Tree related-tree broken	Pole	Patrol/Test/Inspect	Replace - Same Size	VI
5095273	Q75145	07/28/2015	17:22	07/28/2015	18:54	1	91	91	Weather	Fuse	Replace - Same Size		VI
5095277	B54004	07/28/2015	17:22	07/28/2015	18:18	22	1214	55	Overhead equipment	Fuse	Patrol/Test/Inspect	Replace - Same Size	I
5095279	S02501	07/28/2015	17:23	07/28/2015	19:53	1	149	149	Animal related	Transformer Fuse	Replace - Same Size		VI
5095281	D70005	07/28/2015	17:27	07/29/2015	5:35	37	14932	728	Underground equipment	Underground Primary	Repair	Repair	I
5095283	Y08553	07/28/2015	17:27	07/28/2015	18:22	1	54	54	Underground equipment	Transformer Fuse	Replace - Same Size	Replace - Same Size	IV
5095285	M31203	07/28/2015	17:29	07/28/2015	19:01	1	91	91	Animal related	Transformer Fuse	Replace - Same Size	Replace - Same Size	I
5095297	M09144	07/28/2015	17:46	07/28/2015	18:30	1	43	43	Overhead equipment	Connector	Replace - Same Size		VI
5095299	N44216	07/28/2015	17:48	07/28/2015	18:26	1	37	37	Tree related-tree broken	Overhead Service			III
5095301	U16001	07/28/2015	17:49	07/28/2015	18:45	1	55	55	Overhead equipment	Transformer Fuse	Replace - Same Size	Repair	II
5095305	303001	07/28/2015	17:53	07/28/2015	23:08	1	314	314	Tree related-tree broken	Overhead Service	Patrol/Test/Inspect	Repair	VI
5095307	J86118	07/28/2015	17:55	07/28/2015	18:57	1	61	61	Overhead equipment	Fuse	Replace - Same Size		VI
5095309	U66524	07/28/2015	17:58	07/28/2015	20:25	1	146	146	Weather	Fuse	Replace - Same Size		II
5095321	M48814	07/28/2015	18:16	07/28/2015	18:50	8	270	33	Overhead equipment	Overhead Transformer			V
5095323	341001	07/28/2015	18:21	07/28/2015	20:11	1	109	109	Tree related-tree broken	Fuse	Replace - Same Size		VI
5095327	J67134	07/28/2015	18:37	07/29/2015	1:00	1	382	382	Tree related-tree broken	Overhead Primary			III
5095337	N44216	07/28/2015	18:55	07/28/2015	20:00	1	64	64	Tree related-tree broken	Overhead Service			III
5095339	341001	07/28/2015	19:05	07/28/2015	20:11	1	65	65	Tree related-tree broken	Fuse	Replace - Same Size		VI
5095341	L23146	07/28/2015	19:06	07/28/2015	19:57	1	50	50	Overhead equipment	Connector	Replace - Same Size		III
5095343	P58156	07/28/2015	19:16	07/28/2015	20:04	1	47	47	Animal related	Transformer Fuse	Replace - Same Size		VI
5095345	U66515	07/28/2015	19:18	07/28/2015	20:57	1	98	98	Animal related	Transformer Fuse			II
5095351	337002	07/28/2015	19:36	07/29/2015	3:20	1	463	463	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	VI
5095355	D48001	07/28/2015	19:43	07/28/2015	20:25	1	41	41	Animal related	Fuse	Patrol/Test/Inspect	Replace - Same Size	I
5095357	S15567	07/28/2015	19:43	07/28/2015	21:28	7	732	104	Weather	Fuse	Repair		VI
5095359	S15559	07/28/2015	19:47	07/28/2015	21:15	1	87	87	Weather	Fuse	Repair		VI
5095361	Y45503	07/28/2015	19:47	07/28/2015	22:40	1	172	172	Overhead equipment	Transformer Fuse	Repair	Replace - Same Size	IV
5095363	U44001	07/28/2015	19:48	07/28/2015	21:25	1	96	96	Unknown	Other			II
5095365	S15567	07/28/2015	19:52	07/28/2015	21:16	1	83	83	Weather	Fuse	Repair		VI

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5095379	Q04411	07/28/2015	20:26	07/28/2015	21:35	1	68	68	Tree related-tree broken	Overhead Service			III
5095385	Q04411	07/28/2015	20:32	07/28/2015	21:35	1	62	62	Tree related-tree broken	Overhead Service			III
5095407	J63172	07/28/2015	21:13	07/29/2015	1:00	1	226	226	Tree related-tree broken	Overhead Primary			III
5095409	342003	07/28/2015	21:16	07/28/2015	21:30	152	2161	14	Overhead equipment				VI
5095419	N67310	07/28/2015	21:34	07/28/2015	21:52	1	17	17	Other	Other			I
5095427	342003	07/28/2015	22:11	07/28/2015	22:23	309	3949	12	Overhead equipment				VI
5095429	C00002	07/28/2015	22:14	07/29/2015	3:45	1	330	330	Underground equipment	Underground Service		Repair	I
5095433	K67924	07/28/2015	22:21	07/29/2015	1:20	1	178	178	Tree related-tree broken	Overhead Service	Repair		VI
5095437	M54315	07/28/2015	22:38	07/29/2015	0:51	1	132	132	Overhead equipment	Overhead Service	Repair		V
5095443	J08205	07/28/2015	22:57	07/29/2015	3:05	1	247	247	Overhead equipment	Overhead Transformer			I
5095449	303004	07/28/2015	23:29	07/29/2015	0:30	5	303	60	Tree related-tree broken				VI
5095465	J08207	07/28/2015	23:55	07/29/2015	1:40	1	104	104	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	I
5095467	M36189	07/28/2015	23:55	07/29/2015	1:48	15	1691	112	Weather	Pole	Repair	Replace - New Size	I
5095469	B82002	07/28/2015	23:57	07/29/2015	4:48	1	290	290	Unknown	Fuse	Repair	Replace - Same Size	I
5095483	N05173	07/29/2015	0:06	07/29/2015	1:30	23	1929	83	Weather	Fuse	Repair	Repair	I
5095481	Q11516	07/29/2015	0:18	07/29/2015	3:00	1	161	161	Tree related-tree broken	Fuse	Repair	Repair	I
5095495	B35002	07/29/2015	0:30	07/29/2015	5:40	68	21080	310	Weather	Overhead Primary	Replace - Same Size	Repair	I
5095499	337002	07/29/2015	0:53	07/29/2015	1:40	8	373	46	Tree related-tree contact	Overhead Primary	Replace - Same Size	Replace - Same Size	VI
5095675	D70005	07/29/2015	1:12	07/29/2015	5:46	17	4275	273	Weather				I
5095505	B08003	07/29/2015	1:13	07/29/2015	4:30	16	3144	196	Weather	Fuse	Replace - Same Size		I
5095507	342003	07/29/2015	1:14	07/29/2015	2:25	1	70	70	Overhead equipment				VI
5095511	M19222	07/29/2015	1:20	07/29/2015	4:15	1	174	174	Public	Overhead Service	Disconnect	Replace - New Size	VI
5095513	B21001	07/29/2015	1:23	07/29/2015	2:33	1	69	69	Weather	Fuse	Replace - Same Size		I
5095517	D70006	07/29/2015	1:28	07/29/2015	6:06	52	14415	277	Weather	Fuse	Patrol/Test/Inspect	Repair	I
5095537	B27-X1	07/29/2015	1:36	07/29/2015	3:35	1403	167476	119	Weather	Substation Misc.	Repair	Replace - Same Size	I
5095565	A42-X5	07/29/2015	1:36	07/29/2015	3:23	466	49829	106	Weather				I
5095575	A42-X4	07/29/2015	1:36	07/29/2015	3:23	1	106	106	Weather	Substation Misc.	Repair	Replace - Same Size	I
5095571	D48001	07/29/2015	1:52	07/29/2015	3:17	62	5214	84	Weather	Fuse	Replace - Same Size		I
5095629	N18211	07/29/2015	2:00	07/29/2015	4:56	241	42259	175	Weather	Recloser	Switch/Reset		III
5095623	D88001	07/29/2015	2:05	07/29/2015	3:57	141	15817	112	Overhead equipment	Lightning Arrestor	Replace - Same Size		I
5095619	K30205	07/29/2015	2:15	07/29/2015	5:45	1	210	210	Weather	Fuse	Replace - Same Size		III
5095639	Q11516	07/29/2015	2:39	07/29/2015	4:04	2	170	85	Tree related-tree broken	Pole	Cut in Clear	Remove	I
5095645	P47169	07/29/2015	2:56	07/29/2015	9:46	1	409	409	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Disconnect	I
5095655	H07106	07/29/2015	3:44	07/29/2015	5:00	1	75	75	Weather	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	IV
5095663	K36151	07/29/2015	3:57	07/29/2015	5:46	1	108	108	Unknown	Fuse	Replace - Same Size		III
5095665	B82002	07/29/2015	4:29	07/29/2015	5:14	1	44	44	Unknown	Fuse	Repair	Replace - Same Size	I
5095669	R48165	07/29/2015	4:32	07/29/2015	6:33	1	120	120	Weather	Transformer Fuse	Replace - Same Size		IV
5095671	L63936	07/29/2015	4:37	07/29/2015	10:00	14	4528	323	Underground equipment	Underground Primary	Repair	Repair	VI
5095677	R16510	07/29/2015	4:57	07/29/2015	8:18	1	200	200	Weather	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	I
5095679	K30204	07/29/2015	5:05	07/29/2015	11:15	1	369	369	Weather	Fuse	Patrol/Test/Inspect	Replace - Same Size	III
5095681	313135	07/29/2015	5:06	07/29/2015	8:09	1	182	182	Overhead equipment	Overhead Service	Replace - Same Size	Replace - Same Size	V
5095683	N18211	07/29/2015	5:10	07/29/2015	10:10	1	299	299	Weather				III
5095957	L63936	07/29/2015	5:17	07/29/2015	18:24	5	3933	786	Underground equipment	Underground Primary	Repair	Repair	VI
5095689	A36001	07/29/2015	5:24	07/29/2015	11:43	34	4692	378	Underground equipment	Underground Primary	Repair		I
5095697	B35002	07/29/2015	5:29	07/29/2015	5:40	96	1096	11	Overhead equipment	Jumper	Repair		I
5095693	X42502	07/29/2015	5:29	07/29/2015	7:10	3	301	100	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
5095695	N44215	07/29/2015	5:30	07/29/2015	8:04	6	920	153	Weather				III
5095699	A45003	07/29/2015	5:34	07/29/2015	6:23	2	97	48	Weather	Fuse	Replace - Same Size		I
5095713	D70005	07/29/2015	5:47	07/29/2015	6:33	8	367	45	Weather	Overhead Transformer	Replace - Same Size	Repair	I
5095717	N18211	07/29/2015	5:54	07/29/2015	8:12	1	137	137	Weather	Fuse	Replace - Same Size		III
5095719	K30204	07/29/2015	5:56	07/29/2015	7:15	1	78	78	Weather	Fuse	Replace - Same Size		III
5095723	B82002	07/29/2015	6:07	07/29/2015	7:13	1	66	65	Overhead equipment	Pole	Patrol/Test/Inspect	Repair	I
5095725	P47169	07/29/2015	6:10	07/29/2015	9:47	5	1082	216	Overhead equipment				I
5095727	M61302	07/29/2015	6:14	07/29/2015	7:22	1	67	67	Overhead equipment	Fuse	Repair	Repair	V
5095729	B21001	07/29/2015	6:19	07/29/2015	8:03	1	103	103	Weather	Fuse	Replace - Same Size		I
5095733	A80001	07/29/2015	6:24	07/29/2015	7:17	1	52	52	Weather	Transformer Fuse	Replace - Same Size	Replace - Same Size	I

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5095735	D55002	07/29/2015	6:26	07/29/2015	12:14	2	696	348	Underground equipment	Underground Primary	Replace - Same Size	Replace - Same Size	I
5095739	L93135	07/29/2015	6:27	07/29/2015	7:55	27	2355	87	Overhead equipment	Fuse	Repair	Repair	VI
5095743	N18211	07/29/2015	6:35	07/29/2015	8:08	1	92	92	Weather	Fuse	Replace - Same Size		III
5095753	P83710	07/29/2015	6:35	07/29/2015	8:34	102	12068	118	Animal related	Fuse	Patrol/Test/Inspect		I
5095763	B21001	07/29/2015	6:38	07/29/2015	8:03	19	1599	84	Weather	Fuse	Replace - Same Size		I
5095767	D55003	07/29/2015	6:45	07/29/2015	8:04	6	473	78	Weather	Fuse	Replace - Same Size		I
5095761	J06167	07/29/2015	6:50	07/29/2015	8:20	1	89	89	Overhead equipment	Fuse	Repair	Replace - Same Size	I
5095777	B46002	07/29/2015	7:22	07/29/2015	8:54	21	1921	91	Weather	Transformer Fuse	Replace - Same Size	Replace - Same Size	I
5095779	R68903	07/29/2015	7:30	07/29/2015	10:41	3	572	190	Tree related-tree broken	Overhead Primary	Replace - Same Size		I
5095781	338002	07/29/2015	7:37	07/29/2015	9:22	9	940	104	Public	Overhead Service	Repair		VI
5095791	HD0574	07/29/2015	7:46	07/29/2015	8:33	1	46	46	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	VI
5095795	N18211	07/29/2015	7:52	07/29/2015	10:10	1	137	137	Weather				III
5095797	L63936	07/29/2015	7:56	07/29/2015	10:00	1	123	123	Weather				VI
5095799	J47176	07/29/2015	7:59	07/29/2015	14:14	1	374	374	Weather	Overhead Transformer	Repair	Repair	III
5095801	D55003	07/29/2015	7:59	07/29/2015	14:50	1	410	410	Weather	Fuse	Patrol/Test/Inspect	Replace - Same Size	I
5095805	S62523	07/29/2015	8:02	07/29/2015	8:43	1	40	40	Overhead equipment	Fuse	Replace - New Size		VI
5095807	B80004	07/29/2015	8:03	07/29/2015	9:14	1	70	70	Animal related	Fuse	Replace - Same Size		I
5095811	D72001	07/29/2015	8:04	07/29/2015	9:30	1	85	85	Weather	Disconnect Switch	Replace - Same Size	Replace - Same Size	I
5095991	303004	07/29/2015	8:05	07/29/2015	11:13	8	1505	188	Tree related-tree contact	Tree	Trim		VI
5095815	D72001	07/29/2015	8:05	07/29/2015	9:32	1	86	86	Weather	Disconnect Switch	Replace - Same Size	Replace - Same Size	I
5095817	S62523	07/29/2015	8:07	07/29/2015	8:43	4	140	35	Overhead equipment	Fuse	Replace - New Size		VI
5095819	D72001	07/29/2015	8:10	07/29/2015	9:50	1	99	99	Weather	Disconnect Switch	Replace - Same Size	Replace - Same Size	I
5095829	M07235	07/29/2015	8:20	07/29/2015	8:36	1	15	15	Animal related				III
5095833	V74513	07/29/2015	8:33	07/29/2015	10:38	1	124	124	Public	Underground Service		Repair	II
5095841	P17107	07/29/2015	8:42	07/29/2015	10:40	9	1054	117	Overhead equipment	Transformer Fuse	Patrol/Test/Inspect	Replace - New Size	IV
5095847	J07173	07/29/2015	8:52	07/29/2015	10:05	1	72	72	Overhead equipment	Overhead Service	Repair	Replace - Same Size	I
5095849	X29548	07/29/2015	8:52	07/29/2015	9:45	19	1001	52	Animal related	Transformer Fuse	Repair	Replace - Same Size	IV
5095855	A26006	07/29/2015	8:55	07/29/2015	12:49	1	233	233	Overhead equipment	Fuse	Replace - Same Size		I
5095869	Q82907	07/29/2015	9:12	07/29/2015	16:46	6	2169	453	Overhead equipment	Overhead Primary	Repair	Repair	VI
5095879	M42105	07/29/2015	9:20	07/29/2015	13:12	1	231	231	Overhead equipment	Overhead Primary	Repair	Replace - Same Size	I
5095885	Q11517	07/29/2015	9:24	07/29/2015	10:00	1	35	35	Weather	Transformer Fuse	Replace - Same Size		I
5095891	N18211	07/29/2015	9:28	07/29/2015	10:16	1	47	47	Weather				III
5095895	L63936	07/29/2015	9:35	07/29/2015	10:28	3	157	52	Underground equipment	Underground Primary	Repair		VI
5095897	L63936	07/29/2015	9:35	07/29/2015	10:25	1	49	49	Underground equipment	Underground Primary	Repair		VI
5095903	R66472	07/29/2015	9:40	07/29/2015	11:10	1	89	89	Tree related-tree contact	Overhead Service	Repair		IV
5095911	H14343	07/29/2015	9:49	07/29/2015	12:48	1	178	178	Overhead equipment	Connector	Repair		V
5095921	341001	07/29/2015	9:54	07/29/2015	10:28	7	237	33	Tree related-tree broken	Overhead Secondary	Repair		VI
5095927	N94180	07/29/2015	10:09	07/29/2015	11:26	1	76	76	Weather	Transformer Fuse	Replace - Same Size		I
5095931	S61529	07/29/2015	10:10	07/29/2015	10:48	477	18235	38	Underground equipment	Underground Primary	Repair	Repair	VI
5095941	M31204	07/29/2015	10:22	07/29/2015	12:41	1	138	138	Public	Overhead Primary	Repair	Repair	I
5095947	Y51505	07/29/2015	10:27	07/29/2015	12:35	1	127	127	Underground equipment	Underground Service	Repair		IV
5095959	T15571	07/29/2015	10:35	07/29/2015	11:45	1	69	69	Public	Overhead Primary	Repair	Repair	VI
5095965	X20001	07/29/2015	10:38	07/29/2015	17:33	23	6390	415	Public	Underground Transformer	Repair	Replace - Same Size	IV
5095983	S61529	07/29/2015	10:53	07/29/2015	12:00	10	669	66	Underground equipment				VI
5095987	R59421	07/29/2015	11:01	07/29/2015	11:52	1	50	50	Tree related-tree broken	Overhead Service	Raise		IV
5095997	303004	07/29/2015	11:13	07/29/2015	12:35	1	81	81	Tree related-tree broken	Fuse	Repair	Replace - New Size	VI
5096009	U04538	07/29/2015	11:31	07/29/2015	13:20	1	108	108	Overhead equipment	Connector	Replace - New Size	Repair	II
5096011	S61529	07/29/2015	11:36	07/29/2015	12:07	1	30	30	Underground equipment				VI
5096021	U19534	07/29/2015	11:40	07/29/2015	13:15	12	1135	94	Underground equipment	Underground Primary	Repair	Repair	II
5096023	303007	07/29/2015	11:45	07/29/2015	12:36	1	50	50	Tree related-tree broken	Fuse	Patrol/Test/Inspect	Replace - New Size	VI
5096065	346004	07/29/2015	12:00	07/29/2015	12:45	174	7816	44	Public	Underground Primary	Repair	Remove	VI
5096037	B45005	07/29/2015	12:01	07/29/2015	13:32	2	182	91	Animal related	Fuse	Replace - Same Size		I
5096055	P54828	07/29/2015	12:05	07/29/2015	13:30	1	84	84	Overhead equipment	Fuse	Replace - Same Size		V
5096069	K76541	07/29/2015	12:10	07/29/2015	12:18	65	507	7	Jurisdictional				IV
5096075	Y84534	07/29/2015	12:14	07/29/2015	14:00	1	105	105	Tree related-tree broken	Overhead Service	Repair	Repair	IV
5096097	R73841	07/29/2015	12:58	07/29/2015	13:47	1	48	48	Intentional				V

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5096103	Q11517	07/29/2015	13:09	07/29/2015	14:00	1	50	50	Weather	Fuse	Replace - Same Size		I
5096121	X54001	07/29/2015	13:49	07/29/2015	17:50	1	240	240	Underground equipment	Underground Service	Repair	Repair	IV
5096127	D32212	07/29/2015	13:54	07/29/2015	20:08	1	374	374	Underground equipment	Underground Primary		Repair	I
5096135	Z51551	07/29/2015	14:32	07/29/2015	15:45	1	72	72	Tree related-tree contact	Other			IV
5096139	342003	07/29/2015	14:33	07/29/2015	15:50	1	76	76	Overhead equipment	Overhead Transformer	Switch/Reset		VI
5096145	X95001	07/29/2015	14:36	07/29/2015	18:00	9	1829	203	Overhead equipment	Overhead Primary	Repair	Patrol/Test/Inspect	IV
5096147	U16500	07/29/2015	14:40	07/29/2015	19:00	1	259	259	Overhead equipment	Overhead Transformer	Replace - Same Size	Repair	II
5096149	326170	07/29/2015	14:48	07/29/2015	15:52	1	63	63	Overhead equipment	Fuse	Replace - Same Size		V
5096155	Y97-XTR2	07/29/2015	15:10	07/29/2015	15:13	2213	7369	3	Overhead equipment				IV
5096167	V40556	07/29/2015	15:21	07/29/2015	16:43	1	81	81	Overhead equipment	Connector	Repair		II
5096181	Y26520	07/29/2015	15:48	07/29/2015	17:30	1	101	101	Other	Meter	Patrol/Test/Inspect		IV
5096183	HC9327	07/29/2015	16:01	07/30/2015	0:20	6	2988	498	Tree related-tree broken	Pole		Repair	VI
5096189	HC9327	07/29/2015	16:05	07/29/2015	18:58	1	172	172	Tree related-tree broken				VI
5096191	V25504	07/29/2015	16:06	07/29/2015	18:40	1	153	153	Weather	Transformer Fuse	Replace - Same Size		II
5096195	J33803	07/29/2015	16:15	07/29/2015	17:00	1	44	44	Intentional	Customer Equipment			V
5096201	Q01282	07/29/2015	16:16	07/29/2015	17:26	131	9205	70	Overhead equipment				III
5096209	R41131	07/29/2015	16:20	07/29/2015	19:15	1	174	174	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	VI
5096211	B61001	07/29/2015	16:21	07/29/2015	16:49	2	56	28	Other	Other			I
5096223	V41527	07/29/2015	16:28	07/29/2015	17:07	12	458	38	Other	Transformer Fuse	Repair		II
5096225	X24536	07/29/2015	16:29	07/29/2015	18:15	1	105	105	Weather	Transformer Fuse	Replace - Same Size		IV
5096227	Y36559	07/29/2015	16:32	07/29/2015	18:54	16	2267	141	Tree related-tree broken	Tree	Remove	Remove	IV
5096239	R71285	07/29/2015	16:50	07/29/2015	18:50	1	119	119	Overhead equipment	Fuse	Replace - Same Size		VI
5096243	U14528	07/29/2015	17:00	07/29/2015	19:41	1	160	160	Tree related-tree broken	Overhead Service	Repair	Replace - Same Size	II
5096245	X96543	07/29/2015	17:04	07/29/2015	18:50	1	105	105	Weather	Transformer Fuse	Replace - Same Size		IV
5096249	307003	07/29/2015	17:23	07/29/2015	18:44	1	80	80	Overhead equipment	Fuse	Replace - Same Size		VI
5096251	N05172	07/29/2015	17:23	07/29/2015	17:37	1	13	13	Overhead equipment	Connector	Repair		I
5096253	Y89535	07/29/2015	17:26	07/29/2015	20:30	6	1103	183	Overhead equipment	Overhead Transformer	Repair	Replace - Same Size	IV
5096257	Y36559	07/29/2015	17:31	07/29/2015	19:07	1	95	95	Tree related-tree broken	Overhead Transformer	Patrol/Test/Inspect		IV
5096259	B45005	07/29/2015	17:39	07/29/2015	18:56	1	76	76	Weather	Lightning Arrestor	Replace - Same Size		I
5096263	N44215	07/29/2015	18:09	07/29/2015	22:25	1	255	255	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	III
5096271	Q74150	07/29/2015	18:41	07/30/2015	2:29	1	467	467	Unknown	Overhead Service		Replace - Same Size	IV
5096277	Y36559	07/29/2015	19:05	07/29/2015	21:18	16	2127	132	Tree related-tree broken	Fuse	Repair		IV
5096289	Q32170	07/29/2015	19:28	07/29/2015	20:41	1	72	72	Animal related	Transformer Fuse	Replace - Same Size	Patrol/Test/Inspect	I
5096291	Q32170	07/29/2015	19:33	07/29/2015	20:41	1	67	67	Animal related	Transformer Fuse	Replace - Same Size	Patrol/Test/Inspect	I
5096299	Y36559	07/29/2015	20:11	07/29/2015	21:18	2	132	66	Tree related-tree broken	Fuse	Repair		IV
5096301	P60170	07/29/2015	20:34	07/29/2015	21:10	1	35	35	Other				VI
5096315	K32915	07/29/2015	21:17	07/30/2015	1:29	1	251	251	Underground equipment				VI
5096317	K32915	07/29/2015	21:18	07/29/2015	23:56	29	4603	158	Underground equipment	Underground Primary		Repair	VI
5096323	R68903	07/29/2015	21:47	07/30/2015	0:05	1	137	137	Tree related-tree broken	Overhead Service	Repair	Repair	I
5096329	346003	07/29/2015	22:33	07/29/2015	23:56	1	82	82	Overhead equipment	Fuse	Replace - Same Size		VI
5096331	S62520	07/29/2015	23:15	07/30/2015	0:15	2	119	59	Animal related	Transformer Fuse	Repair	Repair	VI
5096333	N44215	07/29/2015	23:35	07/30/2015	2:50	6	1167	194	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	III
5096335	Y08553	07/29/2015	23:50	07/30/2015	3:00	7	1327	189	Underground equipment	Underground Transformer	Replace - Same Size		IV
5096339	D69006	07/30/2015	0:04	07/30/2015	8:58	57	7347	533	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
5096349	M26161	07/30/2015	0:17	07/30/2015	2:08	1	110	110	Overhead equipment	Fuse	Replace - Same Size		III
5096351	B77003	07/30/2015	0:28	07/30/2015	2:50	1	141	141	Tree related-tree broken	Overhead Service	Repair		I
5096357	D16004	07/30/2015	6:11	07/30/2015	10:56	121	34466	284	Underground equipment	Fuse	Replace - Same Size	Replace - Same Size	I
5096361	P52306	07/30/2015	6:51	07/30/2015	7:50	21	1239	59	Unknown	Fuse	Patrol/Test/Inspect	Replace - Same Size	IV
5096375	V33006	07/30/2015	7:48	07/30/2015	11:00	1	191	191	Tree related-tree broken	Overhead Service	Repair	Repair	II
5096379	J75271	07/30/2015	7:53	07/30/2015	11:24	1	210	210	Underground equipment	Underground Secondary	Patrol/Test/Inspect	Replace - Same Size	IV
5096385	B19001	07/30/2015	8:15	07/30/2015	13:17	1	301	301	Underground equipment	Underground Primary	Patrol/Test/Inspect	Patrol/Test/Inspect	I
5096393	U09557	07/30/2015	8:32	07/30/2015	9:37	1	64	64	Animal related	Transformer Fuse	Replace - Same Size		II
5096401	J01119	07/30/2015	8:47	07/30/2015	12:48	25	3425	241	Underground equipment	Underground Primary	Repair	Replace - Same Size	I
5096431	M47802	07/30/2015	9:30	07/30/2015	10:50	1	79	79	Animal related	Fuse	Repair	Repair	V
5096443	M51275	07/30/2015	9:50	07/30/2015	11:29	1	98	98	Overhead equipment	Connector		Repair	III
5096467	S28552	07/30/2015	10:17	07/30/2015	11:33	1	75	75	Overhead equipment	Transformer Fuse	Replace - New Size		VI

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5096465	J20931	07/30/2015	10:17	07/30/2015	11:22	1	64	64	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	VI
5096473	L35139	07/30/2015	10:25	07/30/2015	16:06	123	41909	340	Underground equipment	Underground Primary	Repair		III
5096493	C10002	07/30/2015	10:52	07/30/2015	11:42	1	49	49	Underground equipment	Underground Transformer	Replace - Same Size		III
5096503	302001	07/30/2015	11:04	07/30/2015	13:13	1	128	128	Tree related-tree contact	Overhead Service	Repair		VI
5096511	D87001	07/30/2015	11:14	07/30/2015	12:08	1	53	53	Unknown	Transformer Fuse	Replace - Same Size		I
5096525	N93260	07/30/2015	11:38	07/30/2015	13:04	1	85	85	Overhead equipment	Overhead Service		Repair	III
5096531	B82002	07/30/2015	11:47	07/30/2015	17:13	1	325	325	Underground equipment	Underground Transformer	Replace - Same Size	Repair	I
5096539	A49003	07/30/2015	11:53	07/30/2015	11:56	218	584	2	Unknown				I
5096535	A49003	07/30/2015	11:53	07/30/2015	11:56	558	1495	2	Unknown				I
5096537	A49003	07/30/2015	11:53	07/30/2015	11:56	215	576	2	Unknown				I
5096543	S78551	07/30/2015	11:58	07/30/2015	13:00	1	61	61	Overhead equipment	Overhead Transformer		Repair	VI
5096547	J01119	07/30/2015	12:06	07/30/2015	13:00	1	53	53	Underground equipment	Underground Primary	Repair	Replace - Same Size	I
5096549	B19002	07/30/2015	12:08	07/30/2015	13:14	1	65	65	Animal related	Transformer Fuse	Replace - Same Size		I
5096553	J01119	07/30/2015	12:09	07/30/2015	12:57	1	47	47	Underground equipment	Underground Primary	Repair	Replace - Same Size	I
5096555	J01119	07/30/2015	12:10	07/30/2015	12:54	1	43	43	Underground equipment	Underground Primary	Repair	Replace - Same Size	I
5096613	337001	07/30/2015	14:06	07/30/2015	15:35	1	88	88	Tree related-tree broken	Tree	Patrol/Test/Inspect		VI
5096623	337001	07/30/2015	14:14	07/30/2015	15:35	1	80	80	Tree related-tree broken	Overhead Service	Repair		VI
5096631	N70330	07/30/2015	14:32	07/30/2015	15:34	1	61	61	Other	Other			I
5096633	U26001	07/30/2015	14:33	07/30/2015	16:15	5	505	101	Public				II
5096657	C70004	07/30/2015	15:22	07/30/2015	19:27	1	244	244	Other				III
5096663	N22296	07/30/2015	15:40	07/30/2015	16:34	1	53	53	Weather	Transformer Fuse	Replace - Same Size		VI
5096679	Y69553	07/30/2015	15:51	07/30/2015	18:03	328	43256	131	Other				IV
5096689	Y04504	07/30/2015	16:03	07/30/2015	17:21	1	77	77	Animal related	Transformer Fuse	Replace - Same Size		IV
5096711	Y89004	07/30/2015	16:17	07/30/2015	17:55	1	98	98	Overhead equipment	Connector	Repair	Replace - New Size	IV
5096713	312112	07/30/2015	16:18	07/30/2015	20:25	1	246	246	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	V
5096715	K08909	07/30/2015	16:27	07/30/2015	17:30	1	62	62	Public	Overhead Primary		Patrol/Test/Inspect	VI
5096721	325007	07/30/2015	16:38	07/30/2015	18:16	1	97	97	Overhead equipment	Overhead Service	Repair		VI
5096737	B61001	07/30/2015	16:53	07/30/2015	18:21	1	87	87	Underground equipment	Underground Primary	Patrol/Test/Inspect		I
5096741	Z29579	07/30/2015	17:01	07/30/2015	18:38	53	5131	96	Overhead equipment	Fuse	Replace - Same Size		IV
5096745	A85002	07/30/2015	17:03	07/30/2015	18:42	1	98	98	Overhead equipment	Fuse	Patrol/Test/Inspect	Replace - Same Size	I
5096747	D89002	07/30/2015	17:05	07/30/2015	17:50	6	269	44	Overhead equipment	Fuse	Patrol/Test/Inspect	Replace - Same Size	I
5096751	K95201	07/30/2015	17:17	07/30/2015	18:00	1	42	42	Overhead equipment	Connector	Replace - Same Size		III
5096779	B61001	07/30/2015	17:18	07/30/2015	21:20	1	242	241	Underground equipment	Underground Primary		Repair	I
5096753	J06167	07/30/2015	17:24	07/30/2015	18:46	1	81	81	Unknown	Fuse	Replace - Same Size		I
5096757	K80388	07/30/2015	17:45	07/30/2015	20:21	5	780	156	Underground equipment				IV
5096763	T06540	07/30/2015	17:54	07/30/2015	20:31	1	156	156	Other				VI
5096927	A45001	07/30/2015	18:14	07/30/2015	22:37	85	22293	262	Underground equipment	Underground Primary	Patrol/Test/Inspect	Patrol/Test/Inspect	I
5096775	B61001	07/30/2015	18:19	07/30/2015	18:21	1	2	2	Unknown				I
5096777	P72320	07/30/2015	18:20	07/30/2015	22:46	1	265	265	Overhead equipment	Connector	Repair		V
5096781	N60181	07/30/2015	18:25	07/30/2015	20:50	23	3329	144	Underground equipment	Underground Primary	Switch/Reset	Repair	I
5096789	B62003	07/30/2015	18:27	07/31/2015	2:01	162	73431	453	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
5097061	D87002	07/30/2015	18:36	07/31/2015	2:01	1	444	444	Other				I
5096803	D87002	07/30/2015	18:36	07/31/2015	2:01	38	16883	444	Underground equipment	Underground Primary			I
5096809	T06538	07/30/2015	18:47	07/30/2015	20:34	1	106	106	Other				VI
5096921	M78325	07/30/2015	18:50	07/30/2015	20:35	635	67011	105	Substation equipment	Substation Breaker	Patrol/Test/Inspect	Repair	V
5096993	M78323	07/30/2015	18:50	07/31/2015	1:55	815	346415	425	Substation equipment	Substation Breaker	Replace - Same Size	Replace - Same Size	V
5096931	M78324	07/30/2015	18:50	07/30/2015	20:38	297	31927	107	Substation equipment				V
5096917	P07179	07/30/2015	19:11	07/30/2015	22:18	1	186	186	Unknown	Overhead Service	Repair		I
5096925	Y60593	07/30/2015	19:24	07/30/2015	20:17	1	52	52	Animal related	Transformer Fuse	Replace - Same Size		IV
5096937	Q83147	07/30/2015	20:16	07/30/2015	23:10	6	1041	173	Overhead equipment	Disconnect Switch	Disconnect	Replace - New Size	VI
5096943	312112	07/30/2015	20:41	07/30/2015	20:51	1	9	9	Overhead equipment				V
5096951	T06540	07/30/2015	21:10	07/31/2015	9:25	1	734	734	Other				VI
5096953	U31598	07/30/2015	21:22	07/30/2015	22:55	1	92	92	Overhead equipment	Overhead Service	Repair	Repair	II
5096959	A45001	07/30/2015	21:32	07/30/2015	22:37	97	6210	64	Underground equipment	Underground Primary			I
5096963	L71171	07/30/2015	21:51	07/30/2015	22:37	3	135	45	Animal related	Transformer Fuse	Replace - Same Size		IV
5096967	N78243	07/30/2015	22:03	07/31/2015	0:30	1	146	146	Overhead equipment	Overhead Service	Repair	Repair	I

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5096971	K17119	07/30/2015	22:25	07/31/2015	0:45	1	139	139	Overhead equipment	Fuse	Replace - Same Size		VI
5096977	P52305	07/30/2015	22:38	07/31/2015	3:56	308	85373	317	Overhead equipment	Overhead Primary	Repair		IV
5096997	H11337	07/30/2015	22:57	07/30/2015	23:53	1	55	55	Tree related-tree broken	Overhead Service	Cut in Clear		V
5097381	J47175	07/31/2015	0:13	08/01/2015	2:20	20	31332	1566	Overhead equipment	Overhead Transformer		Replace - Same Size	III
5097019	J84124	07/31/2015	1:35	07/31/2015	3:16	10	1006	100	Overhead equipment	Fuse	Replace - Same Size		VI
5097017	J84124	07/31/2015	1:39	07/31/2015	3:24	1	104	104	Overhead equipment	Fuse	Replace - Same Size		VI
5097023	B62003	07/31/2015	1:41	07/31/2015	1:57	88	1379	15	Other	Underground Primary			I
5097021	J84124	07/31/2015	1:44	07/31/2015	3:24	6	595	99	Overhead equipment	Fuse	Replace - Same Size		VI
5097027	B62003	07/31/2015	2:05	07/31/2015	5:33	4	831	207	Other	Underground Primary	Repair		I
5097029	B76003	07/31/2015	3:05	07/31/2015	8:00	27	7948	294	Underground equipment	Underground Primary	Patrol/Test/Inspect	Replace - Urgent	I
5097033	P52305	07/31/2015	3:14	07/31/2015	4:31	112	5141	76	Overhead equipment	Recloser	Switch/Reset		IV
5097073	B76003	07/31/2015	3:31	07/31/2015	12:24	1	532	532	Underground equipment	Underground Primary	Patrol/Test/Inspect	Replace - Urgent	I
5097059	328120	07/31/2015	3:53	07/31/2015	7:12	6	1191	198	Underground equipment	Underground Primary	Switch/Reset	Repair	V
5097039	S86581	07/31/2015	4:43	07/31/2015	6:42	1	118	118	Other	Other	Patrol/Test/Inspect	Advise Customer	VI
5097041	P52305	07/31/2015	4:49	07/31/2015	7:24	17	2625	154	Tree related-tree broken	Overhead Primary	Patrol/Test/Inspect	Repair	IV
5097043	Q34360	07/31/2015	4:57	07/31/2015	10:29	9	2988	331	Tree related-tree contact	Fuse	Patrol/Test/Inspect	Repair	I
5097049	328120	07/31/2015	5:32	07/31/2015	6:44	40	2841	71	Underground equipment	Underground Primary			V
5097047	D87002	07/31/2015	5:33	07/31/2015	5:44	4	43	10	Other				I
5097057	V44504	07/31/2015	6:01	07/31/2015	11:00	1	298	298	Underground equipment	Underground Service			II
5097071	Q16867	07/31/2015	7:48	07/31/2015	8:32	1	43	43	Animal related	Transformer Fuse	Replace - Same Size	Replace - Same Size	V
5097079	P05825	07/31/2015	8:05	07/31/2015	8:55	4	199	49	Animal related	Transformer Fuse	Replace - Same Size		V
5097081	P62138	07/31/2015	8:06	07/31/2015	9:17	1	70	70	Overhead equipment	Overhead Primary	Repair		VI
5097083	B80004	07/31/2015	8:06	07/31/2015	9:28	1	81	81	Animal related	Transformer Fuse	Replace - Same Size		I
5097091	Q75146	07/31/2015	8:37	07/31/2015	10:04	1	86	86	Animal related	Transformer Fuse	Replace - Same Size		VI
5097093	M05362	07/31/2015	8:39	07/31/2015	9:27	1	47	47	Animal related	Fuse	Replace - Same Size		V
5097099	R59415	07/31/2015	8:45	07/31/2015	9:48	1	62	62	Unknown	Overhead Service			IV
5097115	R01153	07/31/2015	9:10	07/31/2015	15:38	1	387	387	Underground equipment	Underground Service	Repair	Repair	III
5097119	T06538	07/31/2015	9:12	07/31/2015	9:59	1	46	46	Overhead equipment				VI
5097131	R58951	07/31/2015	9:27	07/31/2015	10:04	8	291	36	Animal related	Transformer Fuse	Replace - Same Size		IV
5097133	N15850	07/31/2015	9:29	07/31/2015	12:05	1	155	155	Underground equipment	Underground Primary	Repair		V
5097135	T06540	07/31/2015	9:29	07/31/2015	9:43	1	13	13	Other	Other			VI
5097137	P17109	07/31/2015	9:30	07/31/2015	11:15	1	104	104	Animal related	Transformer Fuse	Replace - Same Size	Replace - New Size	IV
5097143	Q16867	07/31/2015	9:45	07/31/2015	10:20	1	34	34	Intentional	Meter	Patrol/Test/Inspect	Replace - New Size	V
5097155	Q18245	07/31/2015	10:08	07/31/2015	11:05	1	56	56	Tree related-tree contact	Transformer Fuse	Replace - Same Size		VI
5097163	N93260	07/31/2015	10:16	07/31/2015	11:29	1	72	72	Overhead equipment	Transformer Fuse		Repair	III
5097183	D93001	07/31/2015	10:48	07/31/2015	11:42	1	53	53	Unknown	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	IV
5097211	B80003	07/31/2015	11:40	07/31/2015	13:34	4	455	113	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
5097215	N15850	07/31/2015	11:57	07/31/2015	16:28	9	2445	271	Underground equipment	Underground Primary	Repair		V
5097221	B65004	07/31/2015	12:09	07/31/2015	15:10	1	180	180	Public	Overhead Service	Repair		I
5097223	V20502	07/31/2015	12:17	07/31/2015	13:06	1	48	48	Unknown	Transformer Fuse	Replace - Same Size		II
5097229	K69112	07/31/2015	12:24	07/31/2015	12:56	1	31	31	Unknown	Overhead Service			IV
5097231	C52001	07/31/2015	12:33	07/31/2015	13:38	1	64	64	Other				III
5097247	D35002	07/31/2015	13:29	07/31/2015	13:55	1	25	25	Animal related	Transformer Fuse	Replace - Same Size	Replace - Same Size	I
5097257	Y45003	07/31/2015	13:49	07/31/2015	15:10	1	80	80	Overhead equipment	Regulator	Raise		IV
5097261	337002	07/31/2015	13:53	07/31/2015	14:52	7	409	58	Tree related-tree broken	Overhead Transformer	Patrol/Test/Inspect		VI
5097263	M48815	07/31/2015	13:58	07/31/2015	14:53	1	54	54	Intentional				V
5097269	L71171	07/31/2015	14:04	07/31/2015	14:43	3	116	38	Tree related-tree contact	Fuse			IV
5097273	S50544	07/31/2015	14:15	07/31/2015	16:50	1	154	154	Overhead equipment	Overhead Transformer	Repair	Repair	VI
5097279	L50215	07/31/2015	14:18	07/31/2015	15:00	1	41	41	Tree related-tree broken				VI
5097285	B61001	07/31/2015	14:24	07/31/2015	15:20	1	55	55	Overhead equipment	Disconnect Switch	Replace - Same Size		I
5097297	E10001	07/31/2015	14:39	07/31/2015	14:55	1	15	15	Weather	Pole		Replace - Same Size	III
5097309	D87001	07/31/2015	14:45	07/31/2015	15:15	1	29	29	Other	Fuse	Replace - Same Size		I
5097319	N13860	07/31/2015	15:03	07/31/2015	15:41	4	148	37	Tree related-tree contact	Tree	Trim	Trim	V
5097343	Y51506	07/31/2015	16:09	07/31/2015	16:50	1	40	40	Animal related	Transformer Fuse	Replace - Same Size		IV
5097359	Y57001	07/31/2015	17:04	07/31/2015	18:30	1	85	85	Tree related-tree contact	Overhead Service	Patrol/Test/Inspect	Repair	IV
5097361	M41111	07/31/2015	17:30	07/31/2015	19:00	6	539	89	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect		I

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5097367	P05826	07/31/2015	17:54	07/31/2015	22:20	6	1597	266	Public	Pole		Replace - Same Size	V
5097373	V28597	07/31/2015	18:26	07/31/2015	19:07	1	40	40	Overhead equipment	Connector	Repair		II
5097379	J47175	07/31/2015	19:05	07/31/2015	22:49	10	2232	223	Unknown				III
5097383	N54108	07/31/2015	19:18	07/31/2015	20:19	1	60	60	Overhead equipment	Fuse	Replace - Same Size		II
5097377	N70331	07/31/2015	19:33	07/31/2015	20:15	8	336	42	Overhead equipment				I
5097387	M45211	07/31/2015	20:41	07/31/2015	23:30	1	168	168	Overhead equipment	Connector	Replace - Same Size		IV
5097393	343004	07/31/2015	21:04	07/31/2015	23:00	1	115	115	Tree related-tree broken	Overhead Service	Repair		VI
5097399	329146	07/31/2015	22:12	08/01/2015	4:31	20	6099	378	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	V
5097403	Y31589	07/31/2015	22:26	07/31/2015	23:45	1	78	78	Overhead equipment	Meter	Patrol/Test/Inspect		IV
5097405	H07106	07/31/2015	22:55	08/01/2015	0:01	1	65	65	Animal related	Transformer Fuse	Replace - Same Size		IV
5097409	X42501	07/31/2015	23:01	08/01/2015	7:13	25	12313	492	Underground equipment	Underground Primary		Repair	IV
5097417	B38002	07/31/2015	23:29	08/01/2015	4:35	1	305	305	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Repair	I
5097431	Q15845	08/01/2015	3:33	08/01/2015	4:30	1	56	56	Public	Overhead Service	Cut in Clear		V
5097437	D89003	08/01/2015	5:05	08/01/2015	6:20	1	74	74	Tree related-tree broken	Overhead Service	Cut in Clear		I
5097439	X19561	08/01/2015	5:51	08/01/2015	7:34	4	412	103	Overhead equipment	Fuse	Replace - Same Size		IV
5097441	V23592	08/01/2015	6:02	08/01/2015	7:17	1	74	74	Animal related	Transformer Fuse	Repair	Replace - Same Size	II
5097457	X19561	08/01/2015	6:10	08/01/2015	11:11	3	902	300	Underground equipment	Underground Primary		Patrol/Test/Inspect	IV
5097443	P20913	08/01/2015	6:30	08/01/2015	8:07	4	385	96	Animal related	Fuse	Replace - Same Size	Patrol/Test/Inspect	VI
5097447	Y55555	08/01/2015	6:37	08/01/2015	7:59	9	730	81	Animal related	Transformer Fuse	Replace - Same Size		IV
5097445	B65004	08/01/2015	6:37	08/01/2015	7:40	1	62	62	Overhead equipment	Overhead Service	Repair		I
5097449	R61241	08/01/2015	6:44	08/01/2015	7:57	9	650	72	Animal related	Fuse	Repair		IV
5097455	K30205	08/01/2015	7:25	08/01/2015	9:12	1	106	106	Unknown	Fuse	Replace - Same Size		III
5097459	J89105	08/01/2015	7:33	08/01/2015	8:10	6	217	36	Animal related	Transformer Fuse	Replace - Same Size		VI
5097461	A85002	08/01/2015	7:39	08/01/2015	14:31	2	824	412	Underground equipment	Underground Primary	Patrol/Test/Inspect		I
5097463	P07179	08/01/2015	7:53	08/01/2015	9:36	1	102	102	Animal related	Transformer Fuse	Replace - Same Size	Patrol/Test/Inspect	I
5097465	Q01282	08/01/2015	7:53	08/01/2015	8:46	5	262	52	Animal related	Fuse		Replace - Same Size	III
5097467	B76003	08/01/2015	8:00	08/01/2015	10:00	1	119	119	Overhead equipment	Connector	Repair		I
5097469	Z16547	08/01/2015	8:03	08/01/2015	11:09	1	185	185	Animal related	Disconnect Switch	Replace - Same Size		IV
5097479	S19551	08/01/2015	8:39	08/01/2015	13:55	5	1568	315	Underground equipment	Underground Primary			VI
5097487	302002	08/01/2015	9:00	08/01/2015	10:15	1	74	74	Overhead equipment	Overhead Secondary	Patrol/Test/Inspect		VI
5097505	P58155	08/01/2015	9:04	08/01/2015	10:40	121	11591	95	Overhead equipment	Fuse	Repair		VI
5097499	J86108	08/01/2015	9:07	08/01/2015	12:06	1	178	178	Overhead equipment	Overhead Service	Patrol/Test/Inspect	Repair	VI
5097509	P18103	08/01/2015	9:20	08/01/2015	11:15	1	114	114	Other	Overhead Transformer			IV
5097529	S16597	08/01/2015	10:05	08/01/2015	13:57	1	232	232	Underground equipment	Underground Primary	Repair	Repair	VI
5097533	D16001	08/01/2015	10:17	08/01/2015	11:42	12	1014	84	Underground equipment	Fuse	Patrol/Test/Inspect	Replace - Same Size	I
5097535	R02120	08/01/2015	10:28	08/01/2015	11:30	1	61	61	Overhead equipment	Fuse	Repair	Replace - Same Size	VI
5097547	U84566	08/01/2015	10:50	08/01/2015	15:27	7	1938	276	Public	Transformer Fuse	Replace - Same Size		II
5097549	R02120	08/01/2015	10:53	08/01/2015	11:30	1	36	36	Overhead equipment	Fuse	Repair	Replace - Same Size	VI
5097551	J06167	08/01/2015	11:00	08/01/2015	12:57	1	116	116	Overhead equipment	Fuse	Replace - Same Size		I
5097555	R20501	08/01/2015	11:07	08/01/2015	16:30	1	322	322	Underground equipment	Underground Service		Repair	IV
5097791	X19-XTR1	08/01/2015	12:43	08/01/2015	14:41	856	100434	117	Tree related-tree broken				IV
5097817	X83-XTR1	08/01/2015	12:43	08/01/2015	14:41	1127	132230	117	Tree related-tree broken				IV
5097645	Y68-XTR1	08/01/2015	12:43	08/01/2015	14:41	759	89053	117	Tree related-tree broken				IV
5097593	Z29-XTR1	08/01/2015	12:43	08/01/2015	14:41	735	86237	117	Tree related-tree broken				IV
5097933	M40132	08/01/2015	14:06	08/01/2015	16:49	1	162	162	Tree related-tree broken	Overhead Service	Repair		I
5097937	V20512	08/01/2015	14:18	08/01/2015	15:40	1	81	81	Tree related-tree broken	Overhead Service	Repair		II
5097939	Y91500	08/01/2015	14:30	08/01/2015	19:15	1	284	284	Overhead equipment	Overhead Transformer	Repair	Replace - Same Size	IV
5097961	332005	08/01/2015	16:18	08/01/2015	17:26	6	403	67	Other	Fuse	Replace - Same Size		VI
5097971	L95110	08/01/2015	16:58	08/01/2015	17:39	1	40	40	Underground equipment	Overhead Service	Repair		III
5098023	D90002	08/01/2015	17:19	08/02/2015	0:15	9	3743	415	Overhead equipment	Overhead Primary	Replace - Same Size		III
5097985	310124	08/01/2015	17:26	08/01/2015	18:34	1	67	67	Animal related	Fuse	Replace - Same Size		V
5097989	R41131	08/01/2015	17:29	08/01/2015	18:45	17	1285	75	Overhead equipment	Fuse	Repair	Replace - Same Size	VI
5097991	V34003	08/01/2015	17:34	08/01/2015	19:17	1	102	102	Overhead equipment	Overhead Secondary	Repair		II
5097995	K01236	08/01/2015	17:53	08/01/2015	19:20	1	86	86	Overhead equipment	Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
5097997	V23592	08/01/2015	17:56	08/01/2015	22:41	12	3418	284	Overhead equipment	Overhead Primary			II
5098013	310123	08/01/2015	19:42	08/01/2015	20:39	1	57	57	Animal related	Fuse	Replace - Same Size		V

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5098015	Y06544	08/01/2015	19:44	08/01/2015	20:48	1	63	63	Animal related	Transformer Fuse	Replace - Same Size		IV
5098017	D87001	08/01/2015	19:50	08/01/2015	23:10	1	199	199	Overhead equipment	Overhead Transformer	Replace - Same Size	Replace - Same Size	I
5098075	Q01282	08/01/2015	20:06	08/02/2015	2:17	33	12241	370	Overhead equipment	Underground Primary		Repair	III
5098021	Q01282	08/01/2015	20:16	08/01/2015	23:06	14	2384	170	Underground equipment	Underground Primary	Repair		III
5098029	Z05003	08/01/2015	20:37	08/01/2015	21:57	1	79	79	Overhead equipment	Overhead Service			IV
5098037	J58381	08/01/2015	20:47	08/01/2015	23:57	1	189	189	Overhead equipment	Other			III
5098039	M20221	08/01/2015	20:52	08/01/2015	23:50	1	177	177	Overhead equipment	Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
5098041	M05360	08/01/2015	20:57	08/02/2015	0:02	6	1105	184	Tree related-tree contact	Overhead Secondary	Patrol/Test/Inspect	Repair	V
5098045	J85160	08/01/2015	21:00	08/01/2015	22:54	33	3737	113	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	VI
5098049	D90002	08/01/2015	21:08	08/02/2015	0:45	6	1298	216	Overhead equipment	Fuse			III
5098051	D90002	08/01/2015	21:14	08/02/2015	0:54	1	219	219	Overhead equipment	Fuse			III
5098055	303001	08/01/2015	21:23	08/02/2015	6:30	25	8537	547	Tree related-tree broken	Tree	Patrol/Test/Inspect	Trim	VI
5098057	D90002	08/01/2015	21:35	08/02/2015	0:48	1	192	192	Overhead equipment	Fuse			III
5098063	D90002	08/01/2015	21:55	08/02/2015	0:53	1	177	177	Overhead equipment	Fuse			III
5098065	N05172	08/01/2015	22:07	08/01/2015	23:20	1	72	72	Animal related	Fuse	Repair	Replace - Same Size	I
5098069	R49275	08/01/2015	22:16	08/02/2015	0:42	1	145	145	Animal related	Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
5098077	D90002	08/01/2015	23:47	08/02/2015	0:53	1	65	65	Overhead equipment	Fuse			III
5098079	D90002	08/02/2015	0:13	08/02/2015	8:24	1	490	490	Overhead equipment	Overhead Primary			III
5098083	Q64919	08/02/2015	1:45	08/02/2015	7:51	3	1096	365	Tree related-tree broken	Overhead Primary		Repair	VI
5098085	A80001	08/02/2015	2:04	08/02/2015	6:53	3	864	288	Tree related-tree broken	Overhead Primary	Replace - Same Size	Repair	I
5098087	C15002	08/02/2015	2:09	08/02/2015	3:51	724	74340	102	Substation equipment	Substation Relay			III
5098095	A85001	08/02/2015	2:47	08/02/2015	8:00	26	8130	312	Overhead equipment	Overhead Primary	Patrol/Test/Inspect	Tie/Tighten	I
5098099	A73002	08/02/2015	3:39	08/02/2015	11:59	2	998	499	Underground equipment	Underground Primary	Replace - Same Size	Repair	I
5098101	C15002	08/02/2015	3:52	08/02/2015	9:56	7	2548	363	Underground equipment	Underground Primary	Repair		III
5098103	B81002	08/02/2015	4:12	08/02/2015	12:39	1	507	507	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
5098119	A49002	08/02/2015	4:23	08/02/2015	14:35	13	4969	612	Tree related-tree broken	Overhead Primary	Repair		I
5098107	P58159	08/02/2015	4:54	08/02/2015	6:02	6	404	67	Overhead equipment	Transformer Fuse	Repair		VI
5098109	S22592	08/02/2015	6:14	08/02/2015	6:42	1	27	27	Overhead equipment	Fuse			VI
5098117	S22592	08/02/2015	6:19	08/02/2015	6:44	120	2934	24	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	VI
5098123	Q80354	08/02/2015	7:17	08/02/2015	7:46	32	916	28	Animal related	Fuse	Replace - Same Size	Replace - Same Size	V
5098125	V10545	08/02/2015	7:19	08/02/2015	12:45	1	325	325	Animal related	Underground Primary	Repair	Replace - Same Size	II
5098141	N54214	08/02/2015	8:56	08/02/2015	11:22	7	1017	145	Tree related-tree contact	Fuse	Replace - Same Size		II
5098135	D31018	08/02/2015	9:25	08/02/2015	10:23	1	57	57	Animal related	Fuse			III
5098137	S21529	08/02/2015	9:29	08/02/2015	14:38	1	308	308	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	VI
5098139	X66580	08/02/2015	9:50	08/02/2015	11:13	1	82	82	Animal related	Transformer Fuse	Replace - Same Size		IV
5098147	N93260	08/02/2015	10:08	08/02/2015	11:11	5	314	62	Overhead equipment	Fuse		Replace - Same Size	III
5098151	P05825	08/02/2015	10:22	08/02/2015	11:44	1	81	81	Overhead equipment	Overhead Secondary	Repair		V
5098153	M36185	08/02/2015	10:25	08/02/2015	11:45	1	79	79	Animal related	Fuse	Replace - Same Size		I
5098155	M36185	08/02/2015	10:47	08/02/2015	11:45	1	57	57	Animal related	Fuse	Replace - Same Size		I
5098157	342003	08/02/2015	10:48	08/02/2015	12:05	11	836	76	Public	Overhead Service	Remove		VI
5098161	J87111	08/02/2015	10:51	08/02/2015	13:38	14	2146	167	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	VI
5098163	S01501	08/02/2015	11:00	08/02/2015	20:28	1	567	567	Underground equipment	Underground Primary	Repair	Replace - Same Size	VI
5098167	342003	08/02/2015	11:16	08/02/2015	11:40	1	23	23	Tree related-tree broken	Overhead Transformer	Patrol/Test/Inspect		VI
5098169	V92542	08/02/2015	11:17	08/02/2015	13:45	1	147	147	Overhead equipment	Overhead Service	Repair	Patrol/Test/Inspect	II
5098171	R53390	08/02/2015	11:18	08/02/2015	15:21	1	242	242	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	V
5098185	S22592	08/02/2015	11:30	08/02/2015	17:29	42	15108	359	Overhead equipment	Disconnect Switch	Patrol/Test/Inspect	Replace - New Size	VI
5098177	351002	08/02/2015	11:36	08/02/2015	13:02	1	85	85	Tree related-tree broken	Overhead Service	Disconnect		VI
5098179	V83505	08/02/2015	11:38	08/02/2015	13:40	5	607	121	Animal related	Transformer Fuse	Replace - Same Size	Repair	II
5098181	D70003	08/02/2015	11:40	08/02/2015	15:14	2	427	213	Underground equipment	Underground Primary	Replace - Same Size	Replace - Same Size	I
5098189	J87111	08/02/2015	11:59	08/02/2015	13:30	10	909	90	Underground equipment				VI
5098191	351002	08/02/2015	12:03	08/02/2015	13:02	6	348	58	Tree related-tree broken	Overhead Transformer	Patrol/Test/Inspect		VI
5098195	342003	08/02/2015	12:12	08/02/2015	14:12	1	119	119	Public				VI
5098199	J82117	08/02/2015	12:22	08/02/2015	14:03	1	100	100	Overhead equipment	Fuse			VI
5098271	D31016	08/02/2015	12:25	08/02/2015	14:45	979	127405	140	Weather	Overhead Primary			III
5098245	C66001	08/02/2015	12:26	08/02/2015	14:34	245	31127	127	Underground equipment	Vault	Disconnect		III
5098277	N73122	08/02/2015	12:54	08/02/2015	13:50	1	55	55	Overhead equipment	Transformer Fuse	Replace - Same Size		IV

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5098321	C66001	08/02/2015	13:14	08/02/2015	14:30	2	151	75	Underground equipment	Vault	Disconnect		III
5098291	R10943	08/02/2015	13:24	08/02/2015	17:32	2	494	247	Tree related-tree broken	Overhead Primary		Repair	VI
5098293	S16596	08/02/2015	13:25	08/02/2015	15:08	9	925	102	Overhead equipment	Overhead Service	Repair		VI
5098297	N54214	08/02/2015	13:44	08/02/2015	15:57	50	6621	132	Underground equipment	Underground Primary	Switch/Reset	Repair	II
5098301	A73002	08/02/2015	13:44	08/02/2015	18:42	2	376	297	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
5098305	S01501	08/02/2015	13:50	08/02/2015	20:13	1	382	382	Underground equipment				VI
5098319	D60001	08/02/2015	13:59	08/02/2015	16:22	85	12092	142	Underground equipment	Underground Primary	Switch/Reset	Repair	III
5098345	J82117	08/02/2015	14:31	08/02/2015	18:22	5	1152	230	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	VI
5098347	J80807	08/02/2015	14:37	08/02/2015	15:38	1	60	60	Animal related	Fuse	Replace - Same Size	Replace - Same Size	V
5098349	L16213	08/02/2015	14:39	08/02/2015	16:05	1	85	85	Tree related-tree broken	Overhead Service	Replace - Same Size		III
5098355	342004	08/02/2015	14:46	08/02/2015	16:45	1	118	118	Overhead equipment	Overhead Service	Repair		VI
5098365	F03003	08/02/2015	14:58	08/02/2015	16:23	476	40483	85	Overhead equipment	Disconnect Switch	Replace - Same Size		III
5098377	E05002	08/02/2015	15:23	08/02/2015	18:20	80	8337	176	Tree related-tree broken	Overhead Primary		Repair	IV
5098379	P77233	08/02/2015	15:32	08/02/2015	17:00	7	614	87	Tree related-tree broken	Overhead Secondary	Patrol/Test/Inspect		VI
5098381	U95001	08/02/2015	15:39	08/02/2015	17:30	1	110	110	Overhead equipment	Overhead Service	Repair	Repair	II
5098383	M73330	08/02/2015	15:47	08/02/2015	18:29	4	645	161	Overhead equipment	Overhead Transformer	Repair	Replace - Same Size	V
5098387	V49541	08/02/2015	16:10	08/02/2015	16:55	1	44	44	Overhead equipment	Fuse	Replace - Same Size		II
5098391	F03003	08/02/2015	16:23	08/02/2015	17:30	185	12354	66	Overhead equipment	Fuse	Replace - Same Size		III
5098401	J63172	08/02/2015	16:39	08/02/2015	17:40	128	7733	60	Overhead equipment	Fuse		Replace - Same Size	III
5098411	N35852	08/02/2015	16:45	08/02/2015	18:00	1	74	74	Overhead equipment	Connector	Repair		V
5098415	D28124	08/02/2015	16:57	08/02/2015	18:38	4	401	100	Overhead equipment	Overhead Transformer	Reconnect		I
5098419	B38001	08/02/2015	17:10	08/02/2015	21:32	1	261	261	Overhead equipment	Overhead Transformer		Repair	I
5098423	J99128	08/02/2015	17:12	08/02/2015	18:02	1	49	49	Overhead equipment	Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
5098445	F03003	08/02/2015	17:32	08/02/2015	17:48	128	2028	15	Other				III
5098437	F03003	08/02/2015	17:33	08/02/2015	17:48	264	4039	15	Other				III
5098505	K71821	08/02/2015	17:41	08/02/2015	19:44	26	3197	122	Underground equipment				IV
5098465	J63172	08/02/2015	17:45	08/02/2015	19:18	104	9628	92	Overhead equipment	Fuse		Replace - Same Size	III
5098469	K71821	08/02/2015	17:47	08/02/2015	18:57	1	69	69	Underground equipment	Underground Primary	Repair		IV
5098507	K71821	08/02/2015	18:05	08/02/2015	19:44	17	1676	98	Underground equipment				IV
5098541	A81004	08/02/2015	18:12	08/03/2015	1:46	11	4990	453	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
5098483	R49261	08/02/2015	18:13	08/02/2015	19:28	1	74	74	Animal related	Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
5098485	A81004	08/02/2015	18:13	08/02/2015	22:01	12	2736	228	Underground equipment	Underground Primary	Patrol/Test/Inspect	Reconnect	I
5098487	K89142	08/02/2015	18:16	08/02/2015	20:06	1	109	109	Tree related-tree broken	Overhead Service	Replace - Same Size		III
5098489	K89142	08/02/2015	18:17	08/02/2015	19:59	1	101	101	Tree related-tree broken	Overhead Service	Replace - Same Size		III
5098495	H11337	08/02/2015	18:19	08/02/2015	19:52	1	92	92	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	V
5098499	H11337	08/02/2015	18:25	08/02/2015	18:56	3	90	30	Overhead equipment	Overhead Transformer	Switch/Reset	Switch/Reset	V
5098501	J08205	08/02/2015	18:39	08/02/2015	21:41	1	181	181	Overhead equipment	Overhead Service	Repair		I
5098503	G50002	08/02/2015	18:43	08/02/2015	20:00	1	76	76	Animal related	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	IV
5098511	H11337	08/02/2015	19:57	08/02/2015	22:04	3	381	127	Overhead equipment	Overhead Transformer	Repair	Replace - Same Size	V
5098513	Q93522	08/02/2015	20:08	08/02/2015	21:50	1	101	101	Tree related-tree contact	Overhead Service	Repair	Replace - Same Size	I
5098517	D69008	08/02/2015	20:16	08/02/2015	21:52	9	859	95	Tree related-tree broken	Overhead Primary	Replace - Same Size		I
5098537	D69008	08/02/2015	20:21	08/03/2015	2:52	1	390	390	Tree related-tree broken	Overhead Primary	Raise	Repair	I
5098527	J83137	08/02/2015	21:07	08/03/2015	0:01	1	173	173	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	VI
5098539	H11337	08/02/2015	21:33	08/02/2015	22:04	1	30	30	Overhead equipment	Overhead Transformer	Repair	Replace - Same Size	V
5098549	341002	08/02/2015	22:50	08/03/2015	0:37	1	106	106	Overhead equipment	Overhead Service	Remove		VI
5098553	D35003	08/03/2015	1:20	08/03/2015	2:56	1	95	95	Animal related	Fuse	Replace - Same Size		I
5098557	S86580	08/03/2015	1:51	08/03/2015	4:21	1	149	149	Overhead equipment	Disconnect Switch			VI
5098565	N03299	08/03/2015	2:27	08/03/2015	8:30	17	6156	362	Tree related-tree broken	Overhead Primary	Repair	Repair	V
5098571	J07135	08/03/2015	4:10	08/03/2015	6:20	1	129	129	Animal related	Transformer Fuse	Replace - Same Size		I
5098573	L16213	08/03/2015	4:17	08/03/2015	6:15	5	587	117	Tree related-tree contact	Fuse	Replace - Same Size		III
5099073	N44-UNIT-2	08/03/2015	5:59	08/03/2015	7:03	1330	85878	64	Animal related	Substation Misc.	Repair		III
5099029	P93-UNIT-1	08/03/2015	5:59	08/03/2015	7:03	1	64	64	Animal related	Substation Misc.	Repair		III
5098997	P85-X1	08/03/2015	5:59	08/03/2015	7:03	997	64356	64	Animal related	Substation Misc.	Repair		III
5099077	J41-UNIT-1	08/03/2015	5:59	08/03/2015	7:03	1	64	64	Animal related				III
5098651	N44216	08/03/2015	5:59	08/03/2015	7:03	549	34823	63	Animal related				III
5098803	P85-X2	08/03/2015	5:59	08/03/2015	7:03	1778	112938	63	Animal related				III

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5098669	J68401	08/03/2015	6:01	08/03/2015	7:20	617	48249	78	Animal related				III
5098749	Q04-X1	08/03/2015	6:02	08/03/2015	7:03	2225	137060	61	Animal related	Substation Misc.	Repair		III
5099125	Z50544	08/03/2015	6:26	08/03/2015	9:57	1	211	211	Underground equipment	Underground Primary	Repair	Repair	IV
5099043	J68402	08/03/2015	6:42	08/03/2015	7:03	1	20	20	Substation equipment	Substation Breaker	Replace - Same Size		III
5099079	M61302	08/03/2015	6:44	08/03/2015	10:19	1	214	214	Overhead equipment	Fuse	Repair	Repair	V
5099097	M21134	08/03/2015	6:57	08/03/2015	7:30	2	64	32	Animal related	Transformer Fuse	Repair	Repair	VI
5099099	L16213	08/03/2015	6:59	08/03/2015	11:06	1	246	246	Tree related-tree contact	Tree	Remove	Remove	III
5099129	B84001	08/03/2015	7:05	08/03/2015	10:51	2	452	226	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
5099119	325008	08/03/2015	7:16	08/03/2015	8:45	7	616	88	Overhead equipment	Fuse	Patrol/Test/Inspect		VI
5099121	S02502	08/03/2015	7:17	08/03/2015	9:42	1	144	144	Animal related	Animal Guard			VI
5099127	S95571	08/03/2015	7:31	08/03/2015	17:02	1	570	570	Underground equipment	Underground Primary	Repair		VI
5099133	Q24313	08/03/2015	7:46	08/03/2015	9:20	1	93	93	Overhead equipment	Transformer Fuse	Replace - Same Size		VI
5099139	J18268	08/03/2015	7:52	08/03/2015	9:47	1	115	115	Overhead equipment	Overhead Primary	Patrol/Test/Inspect	Repair	VI
5099143	D48002	08/03/2015	8:03	08/03/2015	13:40	1	336	336	Underground equipment	Underground Service	Patrol/Test/Inspect	Repair	I
5099151	J18268	08/03/2015	8:13	08/03/2015	9:48	1	95	95	Overhead equipment	Overhead Primary	Patrol/Test/Inspect	Repair	VI
5099163	A85002	08/03/2015	8:25	08/03/2015	11:50	1	204	204	Overhead equipment	Fuse	Replace - Same Size		I
5099169	K94601	08/03/2015	8:34	08/03/2015	9:28	1	53	53	Overhead equipment				III
5099173	Q71846	08/03/2015	8:39	08/03/2015	9:47	1	67	67	Intentional	Meter	Replace - Same Size	Replace - Same Size	V
5099191	Z21564	08/03/2015	8:58	08/03/2015	10:45	1	106	106	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
5099193	Q01281	08/03/2015	9:04	08/03/2015	10:00	9	498	55	Animal related	Transformer Fuse	Replace - Same Size		III
5099209	J18268	08/03/2015	9:22	08/03/2015	9:47	4	101	25	Overhead equipment				VI
5099211	Y96564	08/03/2015	9:22	08/03/2015	12:30	6	1123	187	Overhead equipment	Overhead Transformer	Replace - New Size	Replace - New Size	IV
5099229	U86500	08/03/2015	9:46	08/03/2015	11:00	1	73	73	Overhead equipment	Connector	Repair		II
5099241	N58144	08/03/2015	10:04	08/03/2015	10:58	1	53	53	Unknown	Transformer Fuse	Replace - Same Size		I
5099465	Q25802	08/03/2015	10:07	08/03/2015	16:44	17	6734	396	Underground equipment	Underground Primary	Repair		I
5099253	R07382	08/03/2015	10:13	08/03/2015	15:13	10	2993	299	Overhead equipment	Pole	Replace - Same Size		I
5099255	R07382	08/03/2015	10:14	08/03/2015	15:13	3	896	298	Overhead equipment	Pole	Replace - Same Size		I
5099259	V59001	08/03/2015	10:15	08/03/2015	13:50	1	214	214	Overhead equipment	Meter	Repair		II
5099307	R07382	08/03/2015	10:18	08/03/2015	10:39	2033	41473	20	Jurisdictional	Jumper			I
5099309	S14510	08/03/2015	10:22	08/03/2015	10:50	1	27	27	Unknown	Customer Equipment	Replace - Same Size		VI
5099303	J75271	08/03/2015	10:22	08/03/2015	11:04	86	3569	41	Unknown				IV
5099301	J75271	08/03/2015	10:22	08/03/2015	11:04	97	4025	41	Unknown				IV
5099299	J75271	08/03/2015	10:22	08/03/2015	11:04	63	2614	41	Unknown	Recloser	Patrol/Test/Inspect	Switch/Reset	IV
5099257	Q25802	08/03/2015	10:24	08/03/2015	12:03	6	592	98	Underground equipment	Underground Primary	Repair		I
5099341	B28006	08/03/2015	10:27	08/03/2015	10:30	1	2	2	Unknown				I
5099389	Q06142	08/03/2015	10:44	08/03/2015	11:20	1	35	35	Unknown	Overhead Service			IV
5099409	M81403	08/03/2015	11:04	08/03/2015	19:58	4	2135	533	Underground equipment	Underground Secondary	Repair		V
5099429	T02534	08/03/2015	11:21	08/03/2015	12:14	1	52	52	Public	Transformer Fuse	Repair	Repair	VI
5099433	N54108	08/03/2015	11:23	08/03/2015	16:40	1	316	316	Overhead equipment	Overhead Transformer	Replace - Same Size		II
5099469	K91117	08/03/2015	12:04	08/03/2015	13:50	1	105	105	Tree related-tree contact	Overhead Service	Repair		III
5099487	H10843	08/03/2015	12:18	08/03/2015	13:07	2	98	49	Overhead equipment	Fuse	Replace - Same Size		V
5099503	P60170	08/03/2015	12:37	08/03/2015	13:52	1	74	74	Overhead equipment	Overhead Service	Repair		VI
5099525	V39002	08/03/2015	13:10	08/03/2015	15:59	6	1011	168	Public	Overhead Secondary	Patrol/Test/Inspect	Repair	II
5099529	V59561	08/03/2015	13:18	08/03/2015	16:45	2	413	206	Public	Underground Primary	Replace - Same Size		II
5099543	X09557	08/03/2015	13:33	08/03/2015	15:10	1	96	96	Tree related-tree contact	Tree	Patrol/Test/Inspect	Trim	IV
5099559	302001	08/03/2015	13:49	08/03/2015	14:50	1	60	60	Tree related-tree broken	Overhead Service	Repair		VI
5099571	A45002	08/03/2015	14:15	08/03/2015	15:10	1	54	54	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	I
5099573	A45002	08/03/2015	14:20	08/03/2015	15:00	1	39	39	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	I
5099585	P57108	08/03/2015	14:23	08/03/2015	15:18	55	3005	54	Public	Overhead Primary			VI
5099583	M41111	08/03/2015	14:24	08/03/2015	14:56	1	31	31	Overhead equipment	Overhead Service			I
5099665	N15850	08/03/2015	14:59	08/03/2015	17:26	160	23643	147	Overhead equipment	Overhead Primary	Repair	Repair	V
5099621	A45002	08/03/2015	15:05	08/03/2015	15:10	7	31	4	Animal related	Fuse	Replace - Same Size		I
5099673	N15850	08/03/2015	15:05	08/03/2015	16:35	4	361	90	Overhead equipment				V
5099625	N15850	08/03/2015	15:06	08/03/2015	18:43	4	867	216	Overhead equipment				V
5099631	A49003	08/03/2015	15:09	08/03/2015	17:43	8	1230	153	Underground equipment	Fuse	Replace - Same Size	Replace - Same Size	I
5099633	L23148	08/03/2015	15:10	08/03/2015	18:15	1	185	184	Tree related-tree contact	Overhead Service	Repair		III

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5099637	P57108	08/03/2015	15:15	08/03/2015	19:01	1	225	225	Public	Pole			VI
5099659	N50331	08/03/2015	15:47	08/03/2015	18:15	1	147	147	Tree related-tree contact	Overhead Service	Replace - New Size		II
5099677	309143	08/03/2015	16:20	08/03/2015	17:38	1	77	77	Public	Overhead Service	Patrol/Test/Inspect	Repair	V
5099679	U31598	08/03/2015	16:22	08/03/2015	16:45	1	22	22	Overhead equipment	Transformer Fuse	Repair		II
5099681	D66004	08/03/2015	16:41	08/03/2015	18:47	1	125	125	Overhead equipment	Fuse	Replace - Same Size		IV
5099691	D66004	08/03/2015	16:51	08/03/2015	18:47	1	115	115	Overhead equipment	Fuse	Replace - Same Size		IV
5099693	D66004	08/03/2015	16:57	08/03/2015	18:47	1	109	109	Overhead equipment	Fuse	Replace - Same Size		IV
5099697	A49003	08/03/2015	17:10	08/03/2015	17:45	1	35	34	Overhead equipment				I
5099705	N15850	08/03/2015	17:18	08/03/2015	19:06	1	107	107	Overhead equipment				V
5099707	N15850	08/03/2015	17:29	08/03/2015	17:35	159	950	5	Overhead equipment				V
5099715	N15850	08/03/2015	17:37	08/03/2015	19:54	159	21811	137	Overhead equipment	Overhead Primary	Replace - Same Size	Replace - Same Size	V
5099735	S83533	08/03/2015	18:41	08/03/2015	20:00	1	78	78	Animal related	Transformer Fuse	Replace - Same Size		VI
5099741	S22592	08/03/2015	18:50	08/04/2015	0:11	1	320	320	Overhead equipment	Pole			VI
5099743	N15850	08/03/2015	18:52	08/03/2015	19:08	1	15	15	Overhead equipment				V
5099751	P58154	08/03/2015	19:10	08/03/2015	19:38	1	27	27	Other	Transformer Fuse	Replace - Same Size		VI
5099753	N15850	08/03/2015	19:11	08/03/2015	20:23	4	288	72	Overhead equipment	Overhead Primary	Patrol/Test/Inspect		V
5099755	A85001	08/03/2015	19:14	08/03/2015	20:09	4	218	54	Overhead equipment	Jumper	Patrol/Test/Inspect	Replace - Same Size	I
5099763	Q21292	08/03/2015	19:41	08/03/2015	20:59	27	2079	77	Public	Pole			VI
5099775	Y59520	08/03/2015	20:40	08/03/2015	22:15	1	94	94	Overhead equipment	Fuse	Replace - Same Size		IV
5099781	S62522	08/03/2015	20:50	08/04/2015	5:08	1	498	498	Underground equipment	Underground Primary	Repair	Repair	VI
5099791	K46388	08/03/2015	21:15	08/03/2015	23:45	21	3157	150	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	V
5099793	J84146	08/03/2015	21:22	08/03/2015	23:22	5	599	119	Overhead equipment	Overhead Secondary	Repair		VI
5099799	N50331	08/03/2015	21:42	08/03/2015	22:48	1	65	65	Animal related	Fuse	Replace - Same Size		II
5099837	B38001	08/03/2015	22:11	08/04/2015	1:12	5	902	180	Overhead equipment	Overhead Primary	Repair	Repair	I
5099813	B38001	08/03/2015	22:12	08/04/2015	0:11	14	1669	119	Overhead equipment	Overhead Primary	Replace - Same Size		I
5099817	L42158	08/03/2015	22:20	08/03/2015	23:18	1	57	57	Overhead equipment	Transformer Fuse	Replace - Same Size		III
5099819	M26161	08/03/2015	22:32	08/04/2015	0:15	1	102	102	Overhead equipment	Fuse	Replace - Same Size		III
5099821	R60551	08/03/2015	22:44	08/04/2015	7:30	6	3154	525	Tree related-tree contact	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	IV
5099823	R48167	08/03/2015	22:58	08/04/2015	3:13	26	6616	254	Underground equipment	Underground Primary		Repair	IV
5099851	D70006	08/03/2015	23:51	08/04/2015	4:41	52	15060	289	Underground equipment	Fuse	Replace - Same Size	Replace - Same Size	I
5099831	B28006	08/03/2015	23:51	08/04/2015	5:30	9	1603	339	Underground equipment	Underground Primary	Switch/Reset	Repair	I
5099841	R60551	08/03/2015	23:58	08/04/2015	7:28	7	3147	449	Tree related-tree contact	Fuse	Replace - Same Size		IV
5099849	U52516	08/04/2015	0:18	08/04/2015	3:04	25	4152	166	Underground equipment	Underground Primary	Repair	Repair	II
5099855	L24123	08/04/2015	1:54	08/04/2015	3:02	5	339	67	Animal related	Fuse	Replace - Same Size		III
5099859	U31598	08/04/2015	2:04	08/04/2015	7:30	35	11399	325	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	II
5099873	U31598	08/04/2015	2:26	08/04/2015	5:27	10	1807	180	Underground equipment				II
5099867	R58951	08/04/2015	3:57	08/04/2015	5:21	8	667	83	Animal related	Overhead Transformer	Replace - Same Size		IV
5099871	Y93005	08/04/2015	5:09	08/04/2015	6:45	1	95	95	Overhead equipment	Overhead Service	Repair	Replace - Same Size	IV
5099877	B45005	08/04/2015	5:55	08/04/2015	7:18	1	82	82	Animal related	Fuse	Replace - Same Size		I
5099879	R73838	08/04/2015	5:58	08/04/2015	8:13	19	2572	135	Public	Overhead Secondary	Replace - Same Size		V
5099887	X75573	08/04/2015	6:22	08/04/2015	7:32	8	559	69	Animal related	Transformer Fuse	Replace - Same Size	Repair	IV
5099883	V18541	08/04/2015	6:27	08/04/2015	8:23	1	115	115	Animal related	Fuse	Replace - Same Size		II
5099895	X02547	08/04/2015	6:38	08/04/2015	11:07	7	1882	268	Weather	Pole	Replace - Same Size	Repair	IV
5099893	UE2001	08/04/2015	6:38	08/05/2015	8:51	9	14158	1573	Substation equipment	Substation Transformer	Patrol/Test/Inspect	Repair	V
5154873	K76543	08/04/2015	7:32	08/04/2015	8:45	239	17262	72	Unknown				IV
5099919	S61531	08/04/2015	8:02	08/04/2015	9:00	1	57	57	Overhead equipment	Fuse	Replace - Same Size		VI
5099921	S61531	08/04/2015	8:02	08/04/2015	9:00	1	57	57	Overhead equipment	Fuse	Replace - Same Size		VI
5099923	K01240	08/04/2015	8:03	08/04/2015	8:59	1	55	55	Overhead equipment	Transformer Fuse	Repair	Repair	VI
5099941	N05173	08/04/2015	8:29	08/04/2015	9:19	1	49	49	Animal related	Jumper	Repair		I
5099947	J07135	08/04/2015	8:37	08/04/2015	9:54	1	76	76	Overhead equipment	Fuse	Repair	Replace - Same Size	I
5099969	U84587	08/04/2015	8:47	08/04/2015	10:06	1	78	78	Overhead equipment	Fuse	Replace - Same Size		II
5099983	K09863	08/04/2015	9:08	08/04/2015	10:22	1	73	73	Animal related	Transformer Fuse	Replace - Same Size	Repair	V
5099999	N58144	08/04/2015	9:23	08/04/2015	11:55	1	151	151	Overhead equipment	Fuse	Patrol/Test/Inspect	Replace - Same Size	I
5100001	N58144	08/04/2015	9:25	08/04/2015	13:50	1	264	264	Overhead equipment	Fuse	Patrol/Test/Inspect	Replace - Same Size	I
5100007	T08501	08/04/2015	9:39	08/04/2015	10:12	1	32	32	Animal related	Fuse	Replace - Same Size		VI
5100083	P17107	08/04/2015	9:50	08/04/2015	10:36	97	4423	45	Overhead equipment	Recloser	Switch/Reset	Replace - Same Size	IV

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5100043	S83533	08/04/2015	10:07	08/04/2015	11:08	1	60	60	Overhead equipment	Transformer Fuse	Repair	Replace - Same Size	VI
5100061	Q32170	08/04/2015	10:14	08/04/2015	11:49	123	11657	94	Public	Overhead Primary	Replace - Same Size		I
5100079	X39530	08/04/2015	10:21	08/04/2015	14:40	3	775	258	Underground equipment	Fuse	Replace - Same Size	Repair	IV
5100093	T06504	08/04/2015	10:29	08/04/2015	12:00	35	3170	90	Tree related-tree broken	Jumper	Repair		VI
5100097	Q85162	08/04/2015	10:31	08/04/2015	11:20	1	48	48	Animal related	Transformer Fuse	Repair	Repair	VI
5100105	Q75146	08/04/2015	10:35	08/04/2015	11:45	1	69	69	Animal related	Fuse	Replace - Same Size		VI
5100125	J15303	08/04/2015	10:35	08/04/2015	11:22	121	5662	46	Public	Recloser	Switch/Reset		I
5100169	D28123	08/04/2015	11:57	08/04/2015	12:49	1	51	51	Animal related	Transformer Fuse	Replace - Same Size		I
5100173	R73841	08/04/2015	12:17	08/04/2015	13:40	1	82	82	Animal related	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	V
5100175	D41003	08/04/2015	12:19	08/04/2015	13:10	1	51	51	Underground equipment	Underground Transformer	Repair	Replace - Same Size	I
5100177	330126	08/04/2015	12:23	08/04/2015	14:25	1	121	121	Animal related	Overhead Service	Repair		V
5100181	D41003	08/04/2015	12:39	08/04/2015	13:09	50	1522	30	Underground equipment	Underground Transformer	Repair	Replace - Same Size	I
5100185	J89125	08/04/2015	12:42	08/04/2015	14:49	53	6578	126	Underground equipment	Underground Primary			VI
5100199	M26161	08/04/2015	12:52	08/04/2015	14:09	1	76	76	Overhead equipment	Overhead Transformer	Repair		III
5100205	K73366	08/04/2015	12:58	08/04/2015	14:00	17	1051	61	Animal related	Underground Transformer	Replace - Same Size		IV
5100207	T11508	08/04/2015	12:59	08/04/2015	14:01	1	61	61	Animal related	Transformer Fuse			VI
5100229	X02547	08/04/2015	13:28	08/04/2015	15:13	1	104	104	Weather	Fuse	Replace - Same Size		IV
5100233	X29548	08/04/2015	13:39	08/04/2015	13:52	14	190	13	Tree related-tree contact	Overhead Secondary	Replace - Same Size		IV
5100235	326168	08/04/2015	13:40	08/04/2015	14:40	1	59	59	Overhead equipment	Overhead Secondary	Repair		V
5100237	J87111	08/04/2015	13:43	08/04/2015	14:30	1	46	46	Animal related	Transformer Fuse	Replace - Same Size		VI
5100253	Z30584	08/04/2015	14:03	08/04/2015	15:12	2	137	68	Overhead equipment	Fuse	Repair		IV
5100259	P60161	08/04/2015	14:08	08/04/2015	15:26	1	77	77	Other	Overhead Service	Repair		VI
5100265	L59929	08/04/2015	14:12	08/04/2015	18:12	8	1918	239	Underground equipment	Underground Primary		Patrol/Test/Inspect	VI
5100269	N13860	08/04/2015	14:21	08/04/2015	16:57	1	155	155	Tree related-tree contact	Overhead Service	Replace - New Size		V
5100277	Z30584	08/04/2015	14:41	08/04/2015	15:12	1	30	30	Overhead equipment	Fuse	Repair		IV
5100283	A48005	08/04/2015	14:47	08/04/2015	16:45	1	117	117	Overhead equipment	Overhead Service	Repair		I
5100287	L59933	08/04/2015	14:49	08/04/2015	19:20	20	5413	270	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	VI
5100289	L59933	08/04/2015	14:54	08/04/2015	19:33	1	278	278	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	VI
5100297	J89125	08/04/2015	14:58	08/04/2015	16:19	12	963	80	Underground equipment	Underground Secondary	Replace - Same Size		VI
5100299	S03-XTR1	08/04/2015	15:15	08/04/2015	15:46	1582	47855	30	Tree related-tree broken	Overhead Primary			VI
5100333	S07-XTR1	08/04/2015	15:16	08/04/2015	15:46	1165	34227	29	Tree related-tree broken	Overhead Primary			VI
5100311	S04-XTR1	08/04/2015	15:17	08/04/2015	15:46	662	19198	29	Tree related-tree broken	Overhead Primary			VI
5100335	S04-XTR2	08/04/2015	15:17	08/04/2015	15:46	487	13991	28	Tree related-tree broken	Overhead Primary			VI
5100439	D31018	08/04/2015	15:31	08/04/2015	16:47	4	301	75	Overhead equipment	Disconnect Switch	Replace - Same Size		III
5100401	Q68836	08/04/2015	15:36	08/04/2015	21:01	1	324	324	Public	Underground Transformer	Replace - Same Size	Replace - Same Size	V
5100407	L59933	08/04/2015	15:43	08/04/2015	20:03	5	1299	259	Weather	Fuse	Replace - Same Size		VI
5100409	K67924	08/04/2015	15:44	08/04/2015	22:50	1	425	425	Weather	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	VI
5100415	Q64939	08/04/2015	15:47	08/04/2015	19:41	1	233	233	Weather				VI
5100419	Q64939	08/04/2015	15:49	08/04/2015	19:35	1	225	225	Weather	Overhead Primary			VI
5100423	Q64939	08/04/2015	15:50	08/04/2015	20:05	1	254	254	Weather	Fuse	Replace - Same Size		VI
5100463	R39934	08/04/2015	15:50	08/04/2015	19:17	273	56306	206	Weather	Recloser		Patrol/Test/Inspect	VI
5100441	T02543	08/04/2015	15:57	08/04/2015	17:13	1	75	75	Overhead equipment	Transformer Fuse	Repair	Repair	VI
5100557	R34921	08/04/2015	16:00	08/04/2015	22:08	4	1469	367	Overhead equipment	Overhead Primary		Repair	VI
5100471	R39934	08/04/2015	16:08	08/04/2015	20:26	1	257	257	Weather	Fuse		Patrol/Test/Inspect	VI
5100475	S04513	08/04/2015	16:08	08/04/2015	17:27	4	313	78	Tree related-tree broken	Overhead Primary	Repair	Repair	VI
5100483	S04512	08/04/2015	16:13	08/04/2015	17:00	71	3324	46	Tree related-tree broken	Overhead Primary	Patrol/Test/Inspect	Repair	VI
5100503	T09558	08/04/2015	16:22	08/04/2015	18:32	1	129	129	Other	Meter			VI
5100613	R39934	08/04/2015	16:23	08/04/2015	20:59	1	275	275	Weather				VI
5100507	S03531	08/04/2015	16:24	08/04/2015	17:43	1	78	78	Overhead equipment	Overhead Service	Patrol/Test/Inspect	Repair	VI
5100517	T22508	08/04/2015	16:25	08/04/2015	18:37	63	8266	131	Overhead equipment	Overhead Primary	Patrol/Test/Inspect	Repair	VI
5100523	351002	08/04/2015	16:29	08/04/2015	18:22	1	112	112	Tree related-tree broken	Overhead Service	Repair		VI
5100533	K28183	08/04/2015	16:32	08/04/2015	16:40	99	785	7	Tree related-tree contact	Tree	Trim	Trim	III
5100549	L59933	08/04/2015	16:41	08/04/2015	19:42	1	180	180	Weather	Fuse	Replace - Same Size		VI
5100551	M48815	08/04/2015	16:42	08/04/2015	17:20	1	37	37	Tree related-tree broken	Fuse	Repair	Repair	V
5100559	Q64919	08/04/2015	16:53	08/04/2015	19:25	1	151	151	Weather	Fuse	Patrol/Test/Inspect	Repair	VI
5100561	R39934	08/04/2015	16:58	08/04/2015	20:03	3	552	184	Weather	Fuse	Replace - Same Size	Patrol/Test/Inspect	VI

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5100563	R34920	08/04/2015	17:05	08/04/2015	21:11	1	245	245	Weather	Transformer Fuse		Replace - Same Size	VI
5100567	K67924	08/04/2015	17:20	08/04/2015	18:24	2	126	63	Tree related-tree contact	Overhead Primary	Repair		VI
5100581	R39934	08/04/2015	17:39	08/04/2015	20:57	1	197	197	Weather				VI
5100583	R39934	08/04/2015	17:42	08/04/2015	20:21	1	158	158	Weather				VI
5100587	R39934	08/04/2015	17:49	08/04/2015	20:19	1	149	149	Weather				VI
5100589	Q93522	08/04/2015	17:52	08/04/2015	19:52	24	2866	119	Animal related	Fuse	Repair		I
5100593	L59933	08/04/2015	18:05	08/04/2015	20:54	1	168	168	Weather	Fuse			VI
5100597	D70005	08/04/2015	18:15	08/06/2015	10:59	1	2444	2444	Public	Underground Transformer	Repair	Repair	I
5100601	P57108	08/04/2015	18:18	08/04/2015	19:21	1	62	62	Tree related-tree contact				VI
5100607	R39934	08/04/2015	18:37	08/04/2015	20:23	1	105	105	Weather				VI
5100609	T12527	08/04/2015	18:37	08/04/2015	21:00	1	142	142	Overhead equipment	Overhead Primary	Repair	Repair	VI
5100615	R39934	08/04/2015	18:56	08/04/2015	21:01	1	124	124	Weather				VI
5100625	R39934	08/04/2015	19:26	08/04/2015	20:31	1	64	64	Weather				VI
5100627	R39934	08/04/2015	19:29	08/04/2015	20:31	1	61	61	Weather				VI
5100629	X02548	08/04/2015	19:37	08/05/2015	0:03	1	265	265	Overhead equipment	Jumper	Repair	Repair	IV
5100631	Y55002	08/04/2015	19:41	08/04/2015	21:41	1	119	119	Tree related-tree contact	Overhead Service	Repair		IV
5100633	L59933	08/04/2015	19:46	08/05/2015	1:18	1	331	331	Overhead equipment	Overhead Transformer	Replace - Same Size	Replace - Same Size	VI
5100637	J86118	08/04/2015	20:01	08/04/2015	21:28	8	690	86	Tree related-tree broken	Transformer Fuse	Replace - Same Size		VI
5100651	K27150	08/04/2015	21:19	08/04/2015	23:30	1	130	130	Overhead equipment	Overhead Service	Replace - New Size		VI
5100655	V45526	08/04/2015	21:57	08/04/2015	23:57	1	119	119	Overhead equipment	Overhead Service	Replace - Same Size		II
5100657	315106	08/04/2015	22:10	08/04/2015	22:32	6	126	21	Overhead equipment	Transformer Fuse	Replace - Same Size		V
5100661	308002	08/04/2015	23:00	08/05/2015	0:35	1	94	94	Overhead equipment	Fuse	Replace - Same Size		VI
5100671	K89141	08/05/2015	0:15	08/05/2015	1:32	4	308	76	Underground equipment	Underground Primary		Repair	III
5100675	Q18244	08/05/2015	0:38	08/05/2015	3:24	11	1819	165	Underground equipment	Underground Primary		Repair	VI
5100677	Q06144	08/05/2015	0:48	08/05/2015	2:02	1	73	73	Animal related	Fuse	Replace - Same Size		IV
5100681	P69174	08/05/2015	1:32	08/05/2015	3:10	1	97	97	Unknown	Fuse	Replace - Same Size		III
5100683	U73583	08/05/2015	1:38	08/05/2015	4:21	1	162	162	Overhead equipment	Disconnect Switch	Replace - Same Size	Replace - Same Size	II
5100695	M40116	08/05/2015	1:55	08/05/2015	7:04	392	121175	309	Underground equipment	Underground Primary	Repair	Replace - Same Size	I
5100701	V25504	08/05/2015	2:14	08/05/2015	5:00	1	165	165	Animal related	Fuse	Replace - Same Size		II
5100709	M40117	08/05/2015	3:59	08/05/2015	4:58	1	58	58	Public				I
5100745	J89125	08/05/2015	5:55	08/05/2015	10:07	17	4280	251	Overhead equipment	Overhead Primary	Repair	Repair	VI
5100723	M19222	08/05/2015	6:06	08/05/2015	7:03	1	56	56	Weather	Transformer Fuse			VI
5100731	M19222	08/05/2015	6:09	08/05/2015	7:41	42	3839	91	Weather	Fuse			VI
5100735	307001	08/05/2015	6:14	08/05/2015	12:46	31	12144	391	Overhead equipment	Other	Advise Customer		VI
5100739	S25551	08/05/2015	6:16	08/05/2015	7:33	1	76	76	Animal related	Transformer Fuse	Replace - Same Size		VI
5100743	Q69926	08/05/2015	6:18	08/05/2015	9:21	1	182	182	Weather	Fuse		Replace - Same Size	VI
5100751	M19222	08/05/2015	6:26	08/05/2015	8:26	1	119	119	Weather				VI
5100755	M19222	08/05/2015	6:38	08/05/2015	11:57	3	954	318	Weather	Overhead Transformer			VI
5100767	L93133	08/05/2015	6:39	08/05/2015	7:26	1148	54667	47	Tree related-tree broken	Substation Breaker	Switch/Reset		VI
5100759	D87001	08/05/2015	6:39	08/05/2015	7:39	1	59	59	Animal related	Fuse	Replace - Same Size		I
5100845	M40116	08/05/2015	7:05	08/05/2015	9:21	106	14400	135	Overhead equipment	Connector	Repair	Replace - Same Size	I
5100851	D89001	08/05/2015	7:11	08/05/2015	8:11	1	59	59	Animal related	Fuse	Replace - Same Size		I
5100855	351001	08/05/2015	7:26	08/05/2015	8:40	1	73	73	Overhead equipment	Overhead Service	Repair		VI
5100857	M19222	08/05/2015	7:28	08/05/2015	10:53	4	818	204	Weather	Overhead Transformer		Repair	VI
5100869	Q82907	08/05/2015	7:39	08/05/2015	11:27	5	1136	227	Weather	Fuse		Repair	VI
5100875	C10002	08/05/2015	7:49	08/05/2015	13:53	1	363	363	Underground equipment	Underground Transformer	Patrol/Test/Inspect	Replace - Same Size	III
5100877	U16500	08/05/2015	7:55	08/05/2015	9:15	1	79	79	Animal related	Transformer Fuse	Replace - Same Size	Repair	II
5100921	M19222	08/05/2015	7:55	08/05/2015	9:26	8	722	90	Weather	Fuse			VI
5100927	M40116	08/05/2015	7:56	08/05/2015	9:21	86	7310	84	Overhead equipment	Overhead Primary	Replace - Same Size	Replace - Same Size	I
5100881	M36185	08/05/2015	7:56	08/05/2015	11:18	473	48612	201	Overhead equipment	Overhead Primary	Repair	Replace - Same Size	I
5100885	M36185	08/05/2015	7:56	08/05/2015	11:18	361	46049	201	Overhead equipment	Overhead Primary	Replace - Same Size		I
5100883	M36185	08/05/2015	7:56	08/05/2015	11:18	357	45407	201	Overhead equipment	Overhead Primary	Replace - Same Size		I
5100935	HB6281	08/05/2015	7:59	08/05/2015	9:24	3	252	84	Overhead equipment	Fuse	Replace - Same Size		VI
5100929	S01501	08/05/2015	8:08	08/05/2015	11:28	1	200	200	Underground equipment	Underground Primary	Repair		VI
5100907	Q06142	08/05/2015	8:20	08/05/2015	9:09	1	48	48	Animal related	Fuse	Replace - Same Size		IV
5100913	N18211	08/05/2015	8:36	08/05/2015	9:40	18	1147	63	Unknown	Fuse	Replace - Same Size		III

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5100933	M18131	08/05/2015	8:58	08/05/2015	10:00	1	61	61	Animal related	Transformer Fuse	Replace - Same Size		III
5100939	J87119	08/05/2015	9:03	08/05/2015	10:18	1	74	74	Overhead equipment	Overhead Service	Repair	Repair	VI
5100959	J14142	08/05/2015	9:55	08/05/2015	13:21	1	205	205	Overhead equipment	Overhead Transformer	Repair	Repair	VI
5100969	R08910	08/05/2015	10:13	08/05/2015	12:08	1	114	114	Overhead equipment	Fuse	Replace - Same Size		VI
5100973	B82002	08/05/2015	10:21	08/05/2015	11:39	1	77	77	Underground equipment	Underground Primary	Repair	Replace - Same Size	I
5100981	P57101	08/05/2015	10:33	08/05/2015	11:09	1	35	35	Overhead equipment	Fuse	Repair	Repair	VI
5100985	A26006	08/05/2015	10:41	08/05/2015	12:04	1	82	82	Overhead equipment	Connector	Tie/Tighten		I
5100987	H22346	08/05/2015	10:44	08/05/2015	12:25	10	1001	100	Overhead equipment	Fuse	Patrol/Test/Inspect	Repair	V
5100989	H22348	08/05/2015	10:44	08/05/2015	11:56	1	71	71	Animal related	Animal Guard	Replace - New Size	Repair	V
5101001	D89001	08/05/2015	11:06	08/05/2015	13:12	1	125	125	Unknown	Transformer Fuse	Replace - Same Size		I
5101035	L36214	08/05/2015	12:15	08/05/2015	15:50	17	3649	214	Public	Pole	Repair	Replace - Same Size	III
5101021	Q23258	08/05/2015	12:31	08/05/2015	13:12	5	203	40	Animal related	Transformer Fuse	Replace - Same Size		VI
5101029	D48001	08/05/2015	12:31	08/05/2015	13:45	62	4530	73	Unknown	Fuse	Patrol/Test/Inspect	Replace - Same Size	I
5101037	J74125	08/05/2015	12:42	08/05/2015	13:40	1	57	57	Overhead equipment	Overhead Transformer	Repair		VI
5101053	Y06546	08/05/2015	12:45	08/05/2015	15:31	32	4607	165	Underground equipment	Underground Primary		Repair	IV
5101087	P77233	08/05/2015	12:49	08/05/2015	17:02	2	505	252	Weather	Overhead Transformer			VI
5101051	D67001	08/05/2015	12:54	08/05/2015	14:18	19	1592	83	Underground equipment	Underground Primary		Repair	IV
5101055	L00133	08/05/2015	12:57	08/05/2015	13:54	1	56	56	Tree related-tree contact	Overhead Service	Repair		III
5101065	Y06546	08/05/2015	13:18	08/05/2015	14:30	1	71	71	Overhead equipment	Fuse	Replace - Same Size		IV
5101075	T41540	08/05/2015	13:39	08/05/2015	14:29	6	296	49	Underground equipment	Underground Primary	Repair		IV
5101077	S78551	08/05/2015	13:41	08/05/2015	14:45	1	63	63	Unknown	Transformer Fuse			VI
5101093	C30002	08/05/2015	14:02	08/05/2015	18:15	1	252	252	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Patrol/Test/Inspect	III
5101099	X57004	08/05/2015	14:06	08/05/2015	15:20	1	73	73	Overhead equipment	Transformer Fuse	Replace - Same Size	Replace - Same Size	IV
5101113	M07235	08/05/2015	14:28	08/05/2015	15:25	1	56	56	Animal related	Transformer Fuse	Replace - Same Size		III
5101115	S78551	08/05/2015	14:34	08/05/2015	14:47	1	12	12	Unknown	Transformer Fuse			VI
5101117	N35852	08/05/2015	14:42	08/05/2015	15:43	1	60	60	Overhead equipment	Overhead Service	Repair		V
5101121	S22594	08/05/2015	14:45	08/05/2015	15:18	1	32	32	Overhead equipment	Fuse		Replace - Same Size	VI
5101125	S22594	08/05/2015	14:51	08/05/2015	15:20	1	28	28	Overhead equipment				VI
5101127	S22592	08/05/2015	14:52	08/05/2015	15:23	1	30	30	Overhead equipment	Fuse		Replace - Same Size	VI
5101129	S22594	08/05/2015	14:52	08/05/2015	15:20	1	27	27	Overhead equipment	Fuse		Replace - Same Size	VI
5101169	T46003	08/05/2015	15:18	08/05/2015	18:21	7	1277	182	Overhead equipment	Jumper	Patrol/Test/Inspect	Repair	VI
5101145	S22595	08/05/2015	15:28	08/06/2015	1:23	25	11113	594	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	VI
5101147	Y06546	08/05/2015	15:29	08/05/2015	15:31	13	28	2	Unknown				IV
5101155	A68001	08/05/2015	15:37	08/05/2015	16:46	5	340	68	Overhead equipment	Disconnect Switch	Replace - Same Size		I
5101161	329145	08/05/2015	15:40	08/05/2015	16:05	1	25	24	Overhead equipment	Fuse	Replace - Same Size		V
5101163	D31015	08/05/2015	15:42	08/05/2015	17:12	1	89	89	Tree related-tree contact	Overhead Secondary	Replace - Same Size	Patrol/Test/Inspect	III
5101165	L95110	08/05/2015	15:54	08/05/2015	17:15	1	80	80	Tree related-tree contact	Overhead Service	Repair		III
5101185	Y07003	08/05/2015	16:49	08/05/2015	17:25	3	107	35	Overhead equipment	Overhead Transformer	Repair		IV
5101197	L59933	08/05/2015	17:11	08/05/2015	20:01	2	338	169	Tree related-tree broken	Overhead Primary		Repair	VI
5101199	P62138	08/05/2015	17:26	08/05/2015	19:25	1	118	118	Overhead equipment	Disconnect Switch	Replace - Same Size	Replace - Same Size	VI
5101201	R04409	08/05/2015	17:26	08/05/2015	20:35	10	1880	188	Tree related-tree broken	Overhead Primary	Repair		V
5101207	303002	08/05/2015	17:36	08/05/2015	19:35	1	118	118	Tree related-tree broken	Overhead Service	Repair		VI
5101211	R41131	08/05/2015	17:41	08/05/2015	18:50	1	68	68	Animal related	Transformer Fuse	Replace - Same Size		VI
5101215	S78551	08/05/2015	18:12	08/05/2015	19:05	1	52	52	Unknown	Transformer Fuse			VI
5101223	U84587	08/05/2015	18:37	08/05/2015	20:33	5	577	115	Overhead equipment	Disconnect Switch	Repair		II
5101231	J58380	08/05/2015	19:16	08/05/2015	21:53	132	20737	157	Underground equipment	Underground Primary	Repair		III
5101257	J58380	08/05/2015	19:20	08/05/2015	22:22	38	6942	182	Underground equipment	Underground Primary	Repair		III
5101241	J58380	08/05/2015	19:20	08/05/2015	21:53	46	7019	152	Underground equipment	Underground Primary	Repair		III
5101239	J58380	08/05/2015	19:20	08/05/2015	21:53	9	1373	152	Underground equipment	Underground Primary	Repair		III
5101243	S20555	08/05/2015	19:21	08/05/2015	19:59	1	37	37	Overhead equipment	Transformer Fuse	Replace - Same Size		VI
5101245	J58381	08/05/2015	19:21	08/06/2015	3:03	1	461	461	Underground equipment	Underground Primary			III
5101253	J58380	08/05/2015	19:29	08/05/2015	22:55	1	205	205	Underground equipment	Underground Service	Repair		III
5101263	S43512	08/05/2015	19:38	08/05/2015	22:00	5	707	141	Overhead equipment	Transformer Fuse	Replace - Same Size		VI
5101271	J58380	08/05/2015	19:55	08/05/2015	22:55	1	179	179	Underground equipment	Underground Primary	Repair		III
5101273	J58380	08/05/2015	19:59	08/05/2015	22:55	1	175	175	Underground equipment	Underground Primary	Repair		III
5101275	U84587	08/05/2015	20:08	08/05/2015	20:33	1	24	24	Overhead equipment	Overhead Primary			II

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5101277	Q95249	08/05/2015	20:14	08/06/2015	0:24	4	998	249	Tree related-tree contact	Tree		Remove	VI
5101281	J58380	08/05/2015	20:18	08/05/2015	22:55	1	156	156	Underground equipment	Underground Primary	Repair		III
5101325	M96-UNIT-1	08/05/2015	20:32	08/06/2015	6:26	1	594	594	Overhead equipment				V
5101323	M86-UNIT-1	08/05/2015	20:32	08/06/2015	7:03	1	630	630	Overhead equipment				V
5101329	M66-UNIT-1	08/05/2015	20:32	08/06/2015	6:25	1	593	593	Overhead equipment				V
5101331	M82-UNIT-1	08/05/2015	20:32	08/06/2015	6:25	4	2372	593	Overhead equipment				V
5101327	M62-UNIT-1	08/05/2015	20:32	08/06/2015	6:26	2	1186	593	Overhead equipment				V
5101295	Q10702	08/05/2015	20:52	08/06/2015	1:55	2	605	302	Overhead equipment				V
5101299	332001	08/05/2015	21:00	08/06/2015	3:40	16	6394	399	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	VI
5101301	351002	08/05/2015	21:06	08/06/2015	6:54	36	5719	587	Tree related-tree contact	Tree	Patrol/Test/Inspect	Trim	VI
5101341	351002	08/05/2015	21:07	08/05/2015	22:36	6	534	89	Tree related-tree broken				VI
5101305	A16001	08/05/2015	21:08	08/06/2015	0:22	1	193	193	Overhead equipment	Disconnect Switch	Disconnect	Repair	I
5101309	M54314	08/05/2015	21:14	08/06/2015	1:53	1	278	278	Overhead equipment				V
5101315	B93003	08/05/2015	21:28	08/06/2015	5:04	1	455	455	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
5101335	V25513	08/05/2015	21:55	08/05/2015	23:30	1	94	94	Overhead equipment	Fuse	Replace - Same Size		II
5101397	MIS-72	08/05/2015	22:05	08/06/2015	5:24	2	876	438	Overhead equipment	Crossarm		Replace - Same Size	V
5101347	L79159	08/05/2015	22:24	08/06/2015	0:35	7	915	130	Animal related	Transformer Fuse	Replace - Same Size		IV
5101351	J86118	08/05/2015	22:40	08/06/2015	12:23	2	1645	822	Tree related-tree broken	Tree	Patrol/Test/Inspect	Remove	VI
5101353	312113	08/05/2015	22:41	08/06/2015	1:19	1	157	157	Tree related-tree broken	Fuse	Replace - Same Size		V
5101355	J58380	08/05/2015	22:48	08/05/2015	22:55	53	355	6	Underground equipment				III
5101359	J58380	08/05/2015	22:51	08/05/2015	22:55	23	85	3	Underground equipment	Underground Primary	Repair		III
5101363	J58380	08/05/2015	22:52	08/05/2015	22:55	1	2	2	Underground equipment	Underground Primary	Repair		III
5101367	J58380	08/05/2015	22:52	08/05/2015	22:55	46	104	2	Unknown				III
5101365	J58380	08/05/2015	22:52	08/05/2015	22:55	9	20	2	Unknown				III
5101373	X49569	08/05/2015	22:58	08/06/2015	1:21	1	142	142	Weather	Lightning Arrestor	Replace - Same Size		IV
5101375	341001	08/05/2015	23:03	08/06/2015	14:15	1	911	911	Tree related-tree broken	Overhead Secondary	Replace - New Size	Replace - Same Size	VI
5101381	V40556	08/05/2015	23:22	08/06/2015	6:05	72	28958	402	Tree related-tree broken	Overhead Secondary	Repair	Repair	II
5101389	J58380	08/05/2015	23:34	08/06/2015	2:30	52	9166	176	Underground equipment	Underground Primary			III
5101391	V40556	08/05/2015	23:35	08/06/2015	6:11	1	395	395	Tree related-tree broken	Overhead Secondary			II
5101393	T17581	08/06/2015	0:11	08/06/2015	2:20	1	128	128	Tree related-tree broken	Overhead Service	Repair		VI
5101399	V40556	08/06/2015	0:55	08/06/2015	6:11	1	315	315	Tree related-tree broken	Overhead Secondary			II
5101401	X57001	08/06/2015	0:56	08/06/2015	2:00	1	63	63	Tree related-tree broken	Overhead Service	Repair		IV
5101403	307004	08/06/2015	1:02	08/06/2015	2:10	1	67	67	Tree related-tree broken				VI
5101405	Q16867	08/06/2015	1:08	08/06/2015	5:41	21	5729	272	Tree related-tree broken	Fuse	Patrol/Test/Inspect	Repair	V
5101411	A56017	08/06/2015	1:33	08/06/2015	2:50	1	76	76	Underground equipment	Underground Primary		Repair	I
5101413	J58380	08/06/2015	1:33	08/06/2015	1:39	13	69	5	Underground equipment				III
5101415	J58380	08/06/2015	1:33	08/06/2015	1:39	1	5	5	Underground equipment				III
5101419	R73839	08/06/2015	2:19	08/06/2015	4:15	1	115	115	Overhead equipment	Overhead Service	Patrol/Test/Inspect	Repair	V
5101423	N35851	08/06/2015	2:20	08/06/2015	4:02	32	3236	101	Overhead equipment	Overhead Primary	Tie/Tighten	Tie/Tighten	V
5101425	P60170	08/06/2015	2:39	08/06/2015	4:30	1	110	110	Tree related-tree broken	Overhead Service	Repair	Repair	VI
5101429	A28002	08/06/2015	2:52	08/06/2015	4:34	1	101	101	Tree related-tree broken	Overhead Service	Patrol/Test/Inspect	Repair	I
5101431	R04409	08/06/2015	2:52	08/06/2015	9:05	1	372	372	Underground equipment	Overhead Secondary		Repair	V
5101433	A50001	08/06/2015	3:37	08/06/2015	5:28	10	1107	110	Unknown	Fuse	Replace - Same Size		I
5101435	R73839	08/06/2015	3:50	08/06/2015	4:15	6	148	24	Overhead equipment	Overhead Secondary		Replace - Same Size	V
5101451	N54213	08/06/2015	3:50	08/06/2015	5:23	17	1569	92	Unknown	Recloser	Patrol/Test/Inspect		II
5101511	K15205	08/06/2015	4:12	08/06/2015	6:35	3	426	142	Overhead equipment	Transformer Fuse	Repair	Repair	VI
5101529	K28180	08/06/2015	4:33	08/06/2015	6:18	1	104	104	Tree related-tree contact	Overhead Service		Repair	III
5101531	S55535	08/06/2015	4:37	08/06/2015	11:28	13	5332	410	Overhead equipment	Pole	Repair		VI
5101537	S47589	08/06/2015	5:11	08/06/2015	6:32	20	1601	80	Overhead equipment	Fuse		Replace - Same Size	VI
5101535	M54314	08/06/2015	5:12	08/06/2015	9:27	1	254	254	Tree related-tree contact	Tree	Remove	Remove	V
5101543	L93135	08/06/2015	5:30	08/06/2015	10:04	21	5751	273	Underground equipment	Underground Primary			VI
5101549	L23146	08/06/2015	6:16	08/06/2015	7:25	1	68	68	Tree related-tree contact	Fuse	Replace - Same Size		III
5101551	D66004	08/06/2015	6:20	08/06/2015	18:50	4	2999	749	Underground equipment	Underground Primary			IV
5101555	L68111	08/06/2015	6:37	08/06/2015	9:47	3	570	190	Overhead equipment	Lightning Arrestor			IV
5101587	Q47833	08/06/2015	6:42	08/06/2015	10:34	108	25047	231	Overhead equipment	Pole	Patrol/Test/Inspect	Replace - New Size	V
5101567	Q21321	08/06/2015	7:02	08/06/2015	9:04	1	121	121	Tree related-tree broken	Fuse	Replace - Same Size		VI

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5101583	S47576	08/06/2015	7:18	08/06/2015	8:30	12	858	71	Overhead equipment	Fuse		Replace - Same Size	VI
5101589	U84001	08/06/2015	7:28	08/06/2015	8:05	11	402	36	Overhead equipment	Pole	Repair		II
5101591	Q82907	08/06/2015	7:40	08/06/2015	8:07	1	26	26	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	VI
5101593	N05170	08/06/2015	7:41	08/06/2015	8:45	1	63	63	Animal related	Transformer Fuse	Replace - Same Size		I
5101595	Q47833	08/06/2015	7:42	08/06/2015	11:24	1	221	221	Overhead equipment				V
5101597	D66004	08/06/2015	7:45	08/06/2015	8:51	331	21829	65	Overhead equipment	Overhead Primary	Repair		IV
5101607	K46389	08/06/2015	7:55	08/06/2015	9:01	1	65	65	Weather	Lightning Arrestor	Replace - Same Size		V
5101737	D70004	08/06/2015	7:56	08/06/2015	10:33	19	2983	156	Underground equipment	Underground Primary	Repair		I
5101613	D36002	08/06/2015	8:03	08/06/2015	10:55	1	171	171	Overhead equipment	Overhead Primary	Replace - Same Size	Repair	I
5101615	P62113	08/06/2015	8:07	08/06/2015	8:53	1	45	45	Other	Meter	Replace - Same Size		VI
5101687	D70004	08/06/2015	8:12	08/06/2015	10:33	3	422	140	Underground equipment	Underground Primary	Repair		I
5101621	Q06132	08/06/2015	8:16	08/06/2015	8:50	6	203	33	Animal related	Fuse	Replace - Same Size		IV
5101623	P47122	08/06/2015	8:17	08/06/2015	12:20	1	242	242	Overhead equipment	Connector	Replace - Same Size	Reconnect	I
5101631	S13548	08/06/2015	8:35	08/06/2015	9:55	1	79	79	Overhead equipment	Overhead Service	Repair		VI
5101611	D70004	08/06/2015	8:48	08/06/2015	10:33	8	839	104	Underground equipment	Underground Primary	Repair	Repair	I
5101665	Q47833	08/06/2015	9:33	08/06/2015	12:07	1	153	153	Overhead equipment	Transformer Fuse	Replace - Same Size		V
5101675	Q47833	08/06/2015	9:37	08/06/2015	10:35	229	13407	58	Overhead equipment	Overhead Primary	Replace - Same Size		V
5101681	H14342	08/06/2015	9:45	08/06/2015	10:48	8	502	62	Public	Transformer Fuse	Replace - Same Size		V
5101685	307004	08/06/2015	9:47	08/06/2015	11:00	1	72	72	Tree related-tree broken	Overhead Service	Repair		VI
5101721	Y86595	08/06/2015	10:16	08/06/2015	13:30	268	20066	193	Overhead equipment	Disconnect Switch	Remove		IV
5101747	S47576	08/06/2015	10:40	08/06/2015	11:39	1	58	58	Tree related-tree broken	Overhead Primary	Patrol/Test/Inspect	Repair	VI
5101749	L17102	08/06/2015	10:40	08/06/2015	11:53	1	72	72	Tree related-tree contact	Overhead Service	Repair		III
5101805	J75271	08/06/2015	11:08	08/06/2015	12:25	45	3432	76	Unknown				IV
5101785	K71810	08/06/2015	11:19	08/06/2015	11:40	44	893	20	Underground equipment	Underground Primary			IV
5101787	Y34596	08/06/2015	11:22	08/06/2015	12:45	1	82	82	Overhead equipment				IV
5101793	D36002	08/06/2015	11:29	08/06/2015	18:09	13	5188	399	Tree related-tree contact	Overhead Secondary	Trim	Trim	I
5101795	U80003	08/06/2015	11:33	08/06/2015	12:42	5	340	68	Overhead equipment	Transformer Fuse			II
5101797	S30518	08/06/2015	11:35	08/06/2015	12:20	1	44	44	Animal related	Fuse	Replace - Same Size		VI
5101799	Y31589	08/06/2015	11:37	08/06/2015	13:20	1	102	102	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
5101811	B35002	08/06/2015	11:45	08/06/2015	13:11	672	57939	86	Public	Overhead Primary	Replace - Same Size		I
5101883	B35002	08/06/2015	11:49	08/06/2015	20:26	1	516	516	Public	Pole	Replace - Same Size	Repair	I
5101863	335002	08/06/2015	11:52	08/06/2015	15:15	1	202	202	Public	Overhead Service	Patrol/Test/Inspect	Replace - Same Size	VI
5101887	V92543	08/06/2015	12:29	08/06/2015	13:35	5	325	65	Unknown	Transformer Fuse	Replace - Same Size	Replace - Same Size	II
5101895	Y34596	08/06/2015	12:37	08/06/2015	13:32	1	54	54	Overhead equipment				IV
5101899	Y86595	08/06/2015	12:42	08/06/2015	12:45	1	2	2	Unknown				IV
5101911	Y54591	08/06/2015	13:00	08/06/2015	17:56	6	1771	295	Overhead equipment	Pole	Replace - Same Size		IV
5101921	P54828	08/06/2015	13:11	08/06/2015	15:08	1	116	116	Overhead equipment	Transformer Fuse	Replace - Same Size		V
5101923	D36001	08/06/2015	13:15	08/06/2015	20:20	1	424	424	Underground equipment	Underground Service	Replace - Same Size	Repair	I
5101935	D96002	08/06/2015	13:29	08/06/2015	15:07	1	97	97	Overhead equipment	Transformer Fuse	Replace - Same Size		I
5101937	S09520	08/06/2015	13:30	08/06/2015	14:44	1	73	73	Overhead equipment	Overhead Service		Repair	VI
5101963	C70001	08/06/2015	14:22	08/06/2015	20:15	1	352	352	Underground equipment	Underground Service	Switch/Reset	Repair	III
5101981	B21001	08/06/2015	14:33	08/06/2015	16:10	48	4609	96	Underground equipment	Underground Primary	Repair	Repair	I
5101977	H10843	08/06/2015	14:34	08/06/2015	15:10	1	35	35	Animal related	Transformer Fuse	Replace - Same Size		V
5101983	S04545	08/06/2015	14:40	08/06/2015	15:36	1	55	55	Tree related-tree broken	Overhead Service	Repair	Repair	VI
5101995	341003	08/06/2015	14:53	08/06/2015	17:20	1	146	146	Tree related-tree broken	Tree	Remove		VI
5102005	K31120	08/06/2015	15:31	08/06/2015	16:48	1	76	76	Unknown	Transformer Fuse	Replace - Same Size		I
5102007	S34527	08/06/2015	15:34	08/06/2015	23:41	1	486	486	Underground equipment	Underground Primary		Repair	VI
5102013	HD0574	08/06/2015	16:00	08/06/2015	17:30	1	89	89	Tree related-tree broken	Overhead Service	Repair		VI
5102019	Q83147	08/06/2015	16:15	08/06/2015	17:56	1	100	100	Overhead equipment	Overhead Service	Repair		VI
5102055	V82551	08/06/2015	17:17	08/06/2015	18:49	71	6500	91	Public	Pole	Replace - New Size	Replace - New Size	II
5102053	L79157	08/06/2015	17:51	08/07/2015	2:20	1	508	508	Underground equipment	Underground Service		Repair	IV
5102059	P49188	08/06/2015	17:58	08/06/2015	21:12	1	193	193	Overhead equipment				I
5102061	P49188	08/06/2015	17:59	08/06/2015	21:10	1	190	190	Overhead equipment				I
5102071	M36189	08/06/2015	18:14	08/06/2015	22:47	9	2455	272	Underground equipment	Underground Primary	Patrol/Test/Inspect		I
5102069	K11376	08/06/2015	18:15	08/06/2015	23:13	1	297	297	Animal related	Transformer Fuse		Replace - Same Size	V
5102075	D36002	08/06/2015	18:42	08/07/2015	1:24	1	401	401	Tree related-tree broken	Overhead Secondary	Patrol/Test/Inspect	Repair	I

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5102081	J33803	08/06/2015	19:15	08/06/2015	22:00	7	1149	164	Overhead equipment	Overhead Transformer	Repair	Repair	V
5102087	T59925	08/06/2015	20:17	08/07/2015	3:15	13	5429	417	Underground equipment	Overhead Secondary	Repair	Repair	VI
5102089	307004	08/06/2015	20:17	08/06/2015	21:51	5	465	93	Animal related	Fuse	Replace - Same Size		VI
5102091	M19222	08/06/2015	20:41	08/06/2015	22:06	1	84	84	Overhead equipment	Transformer Fuse	Replace - Same Size		VI
5102095	P49188	08/06/2015	20:45	08/06/2015	22:02	28	2143	76	Overhead equipment	Crossarm	Raise	Repair	I
5102099	P05825	08/06/2015	21:09	08/07/2015	3:48	1	398	398	Underground equipment	Underground Service	Repair	Repair	V
5102107	Q32171	08/06/2015	22:02	08/06/2015	22:52	1	49	49	Animal related	Transformer Fuse	Replace - Same Size	Patrol/Test/Inspect	I
5102111	A91003	08/06/2015	22:43	08/06/2015	23:46	18	1131	62	Underground equipment	Underground Transformer	Repair		I
5102119	D36002	08/07/2015	0:22	08/07/2015	1:14	13	675	51	Tree related-tree broken	Overhead Primary	Replace - Same Size		I
5102121	348116	08/07/2015	0:31	08/07/2015	1:59	1	87	87	Public	Meter	Disconnect		V
5102125	D28124	08/07/2015	2:01	08/07/2015	3:34	1	92	92	Unknown	Fuse	Replace - Same Size		I
5102127	D89002	08/07/2015	3:37	08/07/2015	4:15	1	37	37	Public	Other		Repair	I
5102129	U92593	08/07/2015	4:18	08/07/2015	5:39	1	80	80	Animal related	Transformer Fuse	Replace - Same Size	Replace - Same Size	II
5102131	D87002	08/07/2015	6:17	08/07/2015	12:25	1	368	368	Underground equipment	Underground Primary	Patrol/Test/Inspect	Replace - Urgent	I
5102137	N70332	08/07/2015	6:58	08/07/2015	8:38	1	99	99	Overhead equipment	Fuse	Replace - Same Size		I
5102149	M22812	08/07/2015	7:10	08/07/2015	10:04	20	3488	174	Overhead equipment	Overhead Primary	Replace - Same Size	Replace - Same Size	V
5102141	K74168	08/07/2015	7:14	08/07/2015	8:44	59	5299	89	Animal related	Fuse	Replace - Same Size		IV
5102159	310123	08/07/2015	7:52	08/07/2015	9:01	1	68	68	Animal related	Fuse	Replace - Same Size		V
5102167	N70332	08/07/2015	8:04	08/07/2015	8:44	1	39	39	Overhead equipment	Fuse	Replace - Same Size		I
5102189	J15303	08/07/2015	8:09	08/07/2015	9:25	37	2844	76	Unknown	Recloser	Switch/Reset		I
5102175	X35500	08/07/2015	8:13	08/07/2015	11:22	29	5483	189	Underground equipment	Underground Primary		Repair	IV
5102183	K89142	08/07/2015	8:27	08/07/2015	9:06	27	1033	38	Animal related	Fuse	Replace - Same Size		III
5102195	N50334	08/07/2015	8:44	08/07/2015	10:00	38	2865	75	Unknown	Fuse	Replace - Same Size		II
5102213	X35500	08/07/2015	9:01	08/07/2015	11:21	1	139	139	Underground equipment	Underground Primary			IV
5102215	V04552	08/07/2015	9:02	08/07/2015	14:47	1	344	344	Overhead equipment	Overhead Transformer	Replace - Same Size	Repair	II
5102233	N44216	08/07/2015	9:26	08/07/2015	11:34	11	1403	127	Animal related	Fuse	Repair	Repair	III
5102235	N44216	08/07/2015	9:27	08/07/2015	12:35	1	187	187	Animal related	Fuse	Repair	Repair	III
5102237	M22812	08/07/2015	9:28	08/07/2015	10:04	15	536	35	Overhead equipment	Overhead Primary	Repair		V
5102239	V65549	08/07/2015	9:30	08/07/2015	14:00	1	269	269	Other				II
5102241	303007	08/07/2015	9:30	08/07/2015	10:33	1	62	62	Overhead equipment	Overhead Service	Repair		VI
5102337	R60552	08/07/2015	9:41	08/07/2015	11:47	1	125	125	Underground equipment	Underground Primary	Switch/Reset	Repair	IV
5102273	S78551	08/07/2015	10:18	08/07/2015	14:30	1	251	251	Underground equipment	Underground Secondary	Repair	Repair	VI
5102297	V61563	08/07/2015	10:47	08/07/2015	12:35	1	107	107	Tree related-tree broken	Tree	Remove		II
5102299	B45005	08/07/2015	10:49	08/07/2015	14:29	15	3289	219	Underground equipment	Underground Primary		Repair	I
5102317	M54292	08/07/2015	11:09	08/07/2015	12:17	1	67	67	Animal related	Transformer Fuse	Replace - Same Size		V
5102323	K31124	08/07/2015	11:25	08/07/2015	12:22	1	57	57	Animal related	Fuse	Replace - Same Size		I
5102325	B93001	08/07/2015	11:29	08/07/2015	13:00	1	90	90	Unknown	Fuse	Repair		I
5102347	X02547	08/07/2015	12:05	08/07/2015	13:46	1	100	100	Overhead equipment	Lightning Arrestor	Replace - Same Size		IV
5102353	B71002	08/07/2015	12:22	08/07/2015	15:40	1	197	197	Overhead equipment	Overhead Service	Repair		I
5102357	K01240	08/07/2015	12:35	08/07/2015	12:37	7	16	2	Overhead equipment				VI
5102363	D92002	08/07/2015	12:41	08/07/2015	15:45	1	183	183	Tree related-tree broken				I
5102375	Q27185	08/07/2015	13:08	08/07/2015	21:31	1	502	502	Overhead equipment	Overhead Primary		Replace - Same Size	VI
5102429	D48001	08/07/2015	15:06	08/07/2015	17:28	63	8937	141	Unknown	Other			I
5102439	B45005	08/07/2015	15:12	08/07/2015	15:14	10	26	2	Unknown				I
5102451	M40131	08/07/2015	15:18	08/07/2015	17:27	132	17156	129	Overhead equipment	Recloser	Replace - Same Size	Replace - Same Size	I
5102529	J80-UNIT-1	08/07/2015	15:32	08/07/2015	16:12	1940	76824	39	Overhead equipment	Crossarm	Replace - Same Size	Replace - Same Size	V
5102593	J76-UNIT-1	08/07/2015	15:33	08/07/2015	16:57	1529	128634	84	Overhead equipment	Crossarm	Replace - Same Size	Replace - Same Size	V
5102607	A81004	08/07/2015	15:46	08/07/2015	16:54	1	67	67	Animal related	Fuse	Patrol/Test/Inspect	Replace - Same Size	I
5102609	J14142	08/07/2015	15:52	08/07/2015	17:21	1	88	88	Overhead equipment	Fuse	Repair	Replace - Same Size	VI
5102667	J14140	08/07/2015	15:53	08/07/2015	21:09	1	315	315	Overhead equipment	Overhead Transformer		Replace - Same Size	VI
5102631	V10545	08/07/2015	16:31	08/07/2015	17:52	10	647	80	Underground equipment	Underground Primary	Switch/Reset	Repair	II
5102639	Y60593	08/07/2015	16:39	08/07/2015	17:51	1	71	71	Animal related	Transformer Fuse	Replace - Same Size		IV
5102645	U99515	08/07/2015	16:51	08/07/2015	20:10	6	1188	198	Animal related	Transformer Fuse	Replace - Same Size		II
5102649	B21002	08/07/2015	16:53	08/07/2015	17:56	1	62	62	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
5102659	U06551	08/07/2015	17:24	08/07/2015	21:28	1	243	243	Animal related	Transformer Fuse	Replace - Same Size		II
5102661	J80806	08/07/2015	17:36	08/07/2015	18:58	73	6004	82	Overhead equipment	Overhead Primary		Replace - Same Size	V

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5102663	L24122	08/07/2015	17:39	08/07/2015	18:28	1	48	48	Animal related	Fuse	Replace - Same Size		III
5102669	B21002	08/07/2015	18:10	08/07/2015	23:12	1	302	302	Underground equipment	Underground Primary	Repair	Repair	I
5102671	310123	08/07/2015	18:21	08/07/2015	19:53	1	91	91	Jurisdictional	Overhead Service	Repair		V
5102683	D69003	08/07/2015	18:49	08/07/2015	23:22	87	23748	272	Underground equipment	Underground Primary	Patrol/Test/Inspect	Switch/Reset	I
5102689	R53391	08/07/2015	19:19	08/07/2015	22:43	16	1825	203	Underground equipment	Underground Primary	Disconnect	Repair	V
5102715	L68113	08/07/2015	21:16	08/07/2015	21:56	1	39	39	Public				IV
5102721	J34356	08/07/2015	21:58	08/07/2015	23:35	1	96	96	Overhead equipment				V
5102727	Y07558	08/07/2015	22:10	08/07/2015	23:48	1	97	97	Tree related-tree contact	Overhead Service	Repair		IV
5102731	C37001	08/08/2015	2:54	08/08/2015	7:45	3	873	291	Underground equipment	Underground Primary			III
5102735	S69516	08/08/2015	4:18	08/08/2015	7:24	11	2041	185	Underground equipment	Recloser	Patrol/Test/Inspect		VI
5102739	B81003	08/08/2015	4:45	08/08/2015	6:11	5	429	85	Animal related	Overhead Transformer	Replace - Same Size		I
5102741	B76003	08/08/2015	5:07	08/08/2015	8:50	27	5719	223	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
5102747	R66472	08/08/2015	6:01	08/08/2015	8:45	39	6363	163	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	IV
5102749	U91584	08/08/2015	6:19	08/08/2015	8:05	1	105	105	Animal related	Transformer Fuse	Replace - Same Size		II
5102753	C70004	08/08/2015	6:31	08/08/2015	10:21	34	7798	229	Underground equipment	Underground Primary	Repair		III
5102757	R10903	08/08/2015	7:28	08/08/2015	7:54	6	153	25	Animal related	Fuse	Replace - Same Size		VI
5102801	P20930	08/08/2015	7:40	08/08/2015	12:29	52	15039	289	Overhead equipment	Pole		Replace - Same Size	VI
5102781	Q34367	08/08/2015	7:44	08/08/2015	9:24	165	16491	99	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	I
5102921	P20930	08/08/2015	7:44	08/08/2015	11:04	1	199	199	Public				VI
5102785	Q34367	08/08/2015	7:47	08/08/2015	9:24	1	96	96	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	I
5102795	D69003	08/08/2015	7:51	08/08/2015	9:30	2	197	98	Overhead equipment	Pole	Repair		I
5102805	P26284	08/08/2015	7:57	08/08/2015	10:29	1	151	151	Animal related	Fuse	Replace - Same Size	Replace - Same Size	I
5102807	HB5890	08/08/2015	8:00	08/08/2015	9:22	33	2685	81	Animal related	Recloser	Switch/Reset		I
5102817	B76003	08/08/2015	8:09	08/08/2015	8:13	48	195	4	Underground equipment	Fuse	Replace - Same Size		I
5102905	P20930	08/08/2015	8:16	08/08/2015	10:49	293	44849	153	Overhead equipment				VI
5102833	HB5890	08/08/2015	8:30	08/08/2015	9:25	1	54	54	Animal related	Recloser	Switch/Reset		I
5102837	P73158	08/08/2015	8:36	08/08/2015	10:28	1	111	111	Tree related-tree contact	Overhead Service	Repair		VI
5102843	J39391	08/08/2015	8:41	08/08/2015	9:25	1	43	43	Overhead equipment	Transformer Fuse		Replace - Same Size	III
5102845	N60181	08/08/2015	8:48	08/08/2015	10:45	1	116	116	Animal related	Transformer Fuse	Replace - Same Size		I
5102853	S04545	08/08/2015	9:01	08/08/2015	10:55	1	113	113	Animal related	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
5102949	Q83168	08/08/2015	9:18	08/08/2015	12:45	8	1662	207	Underground equipment				VI
5102951	Q83168	08/08/2015	9:18	08/08/2015	12:46	20	4162	208	Underground equipment	Underground Primary	Replace - Same Size	Replace - Same Size	VI
5102865	X96524	08/08/2015	9:18	08/08/2015	15:15	1	356	356	Underground equipment	Underground Service	Repair	Replace - New Size	IV
5102867	Q32170	08/08/2015	9:23	08/08/2015	10:45	9	735	81	Animal related	Fuse	Replace - Same Size	Patrol/Test/Inspect	I
5102871	M78324	08/08/2015	9:38	08/08/2015	10:29	1	50	50	Overhead equipment	Overhead Service	Repair		V
5102873	S69516	08/08/2015	9:45	08/08/2015	16:12	2	773	386	Underground equipment	Underground Primary	Repair	Replace - Same Size	VI
5102887	K80381	08/08/2015	10:02	08/08/2015	15:10	38	11737	308	Underground equipment	Underground Primary			IV
5102893	R33126	08/08/2015	10:28	08/08/2015	12:29	1	120	120	Animal related	Transformer Fuse	Replace - Same Size	Patrol/Test/Inspect	I
5102897	C40001	08/08/2015	10:33	08/08/2015	12:43	1	129	129	Unknown	Disconnect Switch	Replace - Same Size	Replace - Same Size	I
5102907	R24832	08/08/2015	10:38	08/08/2015	12:26	10	1076	107	Overhead equipment	Fuse			V
5102935	S09520	08/08/2015	11:19	08/08/2015	12:30	1	70	70	Overhead equipment	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
5102937	N60181	08/08/2015	11:23	08/08/2015	14:00	21	2798	156	Underground equipment	Underground Primary	Switch/Reset		I
5102941	Q14392	08/08/2015	11:34	08/08/2015	14:22	1	167	167	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	I
5102953	B62004	08/08/2015	12:04	08/08/2015	13:00	75	4168	55	Overhead equipment	Fuse	Patrol/Test/Inspect	Repair	I
5102971	Q83168	08/08/2015	12:46	08/08/2015	13:23	16	302	36	Underground equipment	Underground Primary	Replace - Same Size	Replace - Same Size	VI
5102973	V01002	08/08/2015	12:48	08/08/2015	13:50	1	61	61	Unknown	Transformer Fuse	Replace - Same Size		II
5102985	S34527	08/08/2015	13:18	08/08/2015	23:06	1	587	587	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	VI
5102989	S34527	08/08/2015	13:20	08/08/2015	15:20	1	119	119	Overhead equipment				VI
5102995	L35139	08/08/2015	13:46	08/08/2015	15:15	12	1059	88	Unknown	Transformer Fuse	Replace - Same Size		III
5102997	S22593	08/08/2015	14:00	08/08/2015	18:00	1	239	239	Overhead equipment	Fuse	Replace - Same Size		VI
5102999	Q83168	08/08/2015	14:20	08/08/2015	14:52	8	255	31	Underground equipment				VI
5103001	R73838	08/08/2015	14:34	08/08/2015	17:18	1	163	163	Tree related-tree broken	Overhead Service	Patrol/Test/Inspect	Replace - New Size	V
5103009	P19395	08/08/2015	14:44	08/08/2015	20:05	129	41492	321	Public	Overhead Service	Repair	Repair	V
5103007	M73331	08/08/2015	14:46	08/09/2015	6:14	6	5562	927	Underground equipment	Underground Secondary		Patrol/Test/Inspect	V
5103029	S20554	08/08/2015	15:11	08/08/2015	16:52	1	100	100	Jurisdictional	Overhead Service	Repair	Repair	VI
5103031	A73002	08/08/2015	15:15	08/08/2015	17:33	65	8964	137	Tree related-tree broken	Overhead Primary	Repair	Repair	I

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5103043	U06524	08/08/2015	15:54	08/08/2015	20:18	20	5278	263	Underground equipment	Underground Transformer			II
5103045	K28180	08/08/2015	15:55	08/08/2015	17:25	4	356	89	Unknown	Fuse	Replace - Same Size		III
5103129	U06524	08/08/2015	16:05	08/08/2015	22:54	5	2044	408	Underground equipment	Underground Transformer	Replace - Same Size	Repair	II
5103051	K76541	08/08/2015	16:33	08/08/2015	19:23	9	1527	169	Overhead equipment	Pole	Repair	Replace - Same Size	IV
5103059	K74164	08/08/2015	16:54	08/08/2015	20:52	10	2375	237	Overhead equipment	Overhead Secondary	Replace - Same Size		IV
5103061	K52400	08/08/2015	16:56	08/09/2015	6:02	1	785	785	Tree related-tree contact	Tree	Trim		V
5103063	U33509	08/08/2015	17:25	08/08/2015	18:11	1	45	45	Overhead equipment	Transformer Fuse	Repair	Repair	II
5103127	P19395	08/08/2015	17:42	08/08/2015	21:45	3	730	243	Public	Pole	Repair	Replace - Same Size	V
5103087	Z17522	08/08/2015	17:46	08/08/2015	19:35	7	756	108	Underground equipment	Underground Primary	Switch/Reset	Repair	IV
5103083	L24122	08/08/2015	18:15	08/08/2015	22:25	1	249	249	Overhead equipment	Overhead Transformer	Replace - Same Size		III
5103085	P49188	08/08/2015	18:16	08/08/2015	20:17	1	120	120	Animal related	Transformer Fuse	Replace - Same Size		I
5103089	K67924	08/08/2015	18:20	08/08/2015	19:47	1	86	86	Animal related	Fuse	Replace - Same Size		VI
5103103	Z16547	08/08/2015	19:22	08/08/2015	20:35	1	72	72	Animal related	Fuse	Replace - New Size		IV
5103107	D90003	08/08/2015	19:25	08/08/2015	22:18	1	172	172	Tree related-tree broken	Overhead Service	Repair		III
5103109	X30505	08/08/2015	19:26	08/08/2015	23:25	1	238	238	Underground equipment	Underground Service	Patrol/Test/Inspect	Patrol/Test/Inspect	IV
5103113	S47585	08/08/2015	19:27	08/08/2015	20:30	1	62	62	Overhead equipment	Fuse		Replace - Same Size	VI
5103115	K71822	08/08/2015	19:30	08/08/2015	21:06	17	1635	96	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	IV
5103307	K76541	08/08/2015	19:38	08/09/2015	5:34	9	5369	596	Overhead equipment	Pole	Replace - Same Size	Replace - Same Size	IV
5103123	U06524	08/08/2015	19:42	08/08/2015	20:18	17	617	36	Underground equipment	Underground Primary	Switch/Reset	Repair	II
5103139	N18211	08/08/2015	20:31	08/08/2015	22:14	19	1956	102	Overhead equipment				III
5103143	K27153	08/08/2015	21:00	08/08/2015	22:22	1	81	81	Tree related-tree broken	Overhead Service	Repair	Repair	VI
5103289	U51539	08/08/2015	21:22	08/09/2015	1:55	57	15545	272	Substation equipment	Substation Transformer			II
5103151	U51539	08/08/2015	21:29	08/08/2015	22:35	1	65	65	Overhead equipment				II
5103153	D93001	08/08/2015	21:29	08/09/2015	0:55	1	205	205	Animal related	Fuse	Replace - Same Size		IV
5103297	N22-UNIT-1	08/08/2015	21:33	08/09/2015	0:00	287	42389	147	Animal related	Substation Transformer	Repair	Replace - Same Size	VI
5103217	N22295	08/08/2015	21:33	08/09/2015	0:00	474	69858	147	Animal related				VI
5103305	S01560	08/08/2015	23:02	08/09/2015	2:21	7	1392	198	Overhead equipment	Transformer Fuse	Repair		VI
5103309	K76541	08/08/2015	23:52	08/09/2015	4:09	8	2051	256	Overhead equipment	Pole	Replace - Same Size	Replace - Same Size	IV
5103313	D88001	08/08/2015	23:53	08/09/2015	3:00	63	11770	186	Unknown	Fuse	Replace - Same Size		I
5103315	Y82587	08/08/2015	23:58	08/09/2015	1:31	1	92	92	Animal related	Transformer Fuse	Replace - Same Size		IV
5103317	N22296	08/09/2015	0:02	08/09/2015	0:59	287	16511	57	Animal related				VI
5103367	V65-XTR1	08/09/2015	2:27	08/09/2015	7:16	687	198797	289	Unknown	Substation Breaker	Switch/Reset		II
5103377	M31204	08/09/2015	2:36	08/09/2015	4:24	79	8607	108	Weather	Recloser	Switch/Reset		I
5103357	U33509	08/09/2015	2:37	08/09/2015	4:31	1	113	113	Weather	Transformer Fuse	Replace - Same Size		II
5103581	V66-XBK1	08/09/2015	2:40	08/09/2015	7:16	1	276	275	Weather	Substation Breaker	Switch/Reset		II
5103395	L74193	08/09/2015	2:59	08/09/2015	6:00	1	180	180	Animal related	Transformer Fuse		Install	IV
5103469	A85001	08/09/2015	3:06	08/09/2015	5:42	195	30390	155	Overhead equipment	Recloser	Switch/Reset	Replace - Same Size	I
5103411	S28552	08/09/2015	3:06	08/09/2015	15:09	386	278993	722	Tree related-tree broken	Overhead Primary		Repair	VI
5103497	D66004	08/09/2015	5:02	08/09/2015	10:28	1	325	325	Underground equipment	Underground Primary	Repair		IV
5103499	E10001	08/09/2015	5:17	08/09/2015	9:10	17	3955	232	Overhead equipment				III
5103503	N67309	08/09/2015	5:56	08/09/2015	7:15	1	78	78	Weather	Fuse	Replace - Same Size		I
5103653	A85002	08/09/2015	5:58	08/10/2015	2:04	4	4821	1205	Underground equipment	Underground Primary		Repair	I
5103507	D48001	08/09/2015	6:05	08/09/2015	7:40	1	94	94	Tree related-tree contact				I
5103511	D36002	08/09/2015	6:06	08/09/2015	10:28	52	13670	262	Underground equipment	Other		Repair	I
5103515	K31124	08/09/2015	6:15	08/09/2015	8:33	1	137	137	Overhead equipment	Transformer Fuse	Replace - Same Size		I
5103517	U37579	08/09/2015	6:21	08/09/2015	8:03	31	3152	101	Weather	Fuse	Replace - Same Size	Replace - Same Size	II
5103541	J71128	08/09/2015	6:22	08/09/2015	9:49	497	102953	207	Weather	Crossarm	Patrol/Test/Inspect	Replace - New Size	I
5103523	X75571	08/09/2015	6:23	08/09/2015	9:16	1	172	172	Tree related-tree broken	Overhead Service	Repair		IV
5103533	U13551	08/09/2015	6:30	08/09/2015	9:10	1	159	159	Weather	Fuse	Replace - Same Size	Replace - Same Size	II
5103535	Q32170	08/09/2015	6:31	08/09/2015	11:12	5	1404	280	Tree related-tree broken	Overhead Primary	Replace - Same Size		I
5103583	U10525	08/09/2015	6:46	08/09/2015	14:15	384	17035	449	Tree related-tree broken	Tree	Remove		II
5103553	U13551	08/09/2015	6:49	08/09/2015	9:10	1	140	140	Weather	Fuse	Replace - Same Size	Replace - Same Size	II
5103557	U10002	08/09/2015	6:50	08/09/2015	10:05	1	194	194	Weather	Overhead Transformer	Replace - Same Size	Replace - Same Size	II
5103571	B62003	08/09/2015	7:13	08/09/2015	9:23	12	1557	129	Animal related	Fuse	Replace - Same Size		I
5103573	M41111	08/09/2015	7:16	08/09/2015	12:55	1	338	338	Tree related-tree broken	Transformer Fuse	Replace - Same Size		I
5103577	B62003	08/09/2015	7:17	08/09/2015	9:23	4	503	125	Animal related	Fuse	Replace - Same Size		I

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5103585	K57211	08/09/2015	7:25	08/09/2015	8:42	3	229	76	Animal related	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
5103587	Q85162	08/09/2015	7:25	08/09/2015	8:48	1	82	82	Overhead equipment	Fuse	Repair	Replace - Same Size	VI
5103601	F03004	08/09/2015	7:57	08/09/2015	9:20	1	82	82	Overhead equipment	Disconnect Switch	Replace - Same Size		III
5103603	R33126	08/09/2015	8:00	08/09/2015	10:35	1	154	154	Weather	Pole	Cut in Clear	Repair	I
5103605	Q32171	08/09/2015	8:07	08/09/2015	14:55	3	1221	407	Weather	Overhead Service	Replace - Same Size	Patrol/Test/Inspect	I
5103619	L12128	08/09/2015	8:12	08/09/2015	14:19	23	8433	366	Underground equipment	Underground Primary	Patrol/Test/Inspect		III
5103609	L99392	08/09/2015	8:14	08/09/2015	9:22	6	407	67	Weather	Transformer Fuse	Replace - Same Size	Replace - Same Size	V
5103611	V61563	08/09/2015	8:15	08/09/2015	12:47	1	271	271	Weather	Pole	Replace - Same Size	Repair	II
5103613	U10001	08/09/2015	8:15	08/09/2015	14:00	1	344	344	Overhead equipment	Overhead Transformer	Replace - Same Size		II
5103627	V13510	08/09/2015	8:18	08/09/2015	11:36	30	5931	197	Tree related-tree broken				II
5103623	U13551	08/09/2015	8:25	08/09/2015	9:10	3	134	44	Weather	Fuse	Replace - Same Size	Replace - Same Size	II
5103663	V13510	08/09/2015	8:25	08/09/2015	11:36	28	5340	190	Tree related-tree broken				II
5103633	K69117	08/09/2015	8:41	08/09/2015	11:05	50	7170	143	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	IV
5103649	D48001	08/09/2015	8:47	08/09/2015	10:35	63	6752	107	Overhead equipment	Fuse	Replace - Same Size		I
5103707	K62102	08/09/2015	8:50	08/09/2015	10:48	29	3417	117	Tree related-tree contact	Fuse	Replace - Same Size		II
5103657	S41565	08/09/2015	9:04	08/09/2015	10:48	1	103	103	Overhead equipment	Connector	Tie/Tighten		VI
5103659	U51539	08/09/2015	9:09	08/09/2015	11:35	1	145	145	Other	Lightning Arrestor	Repair	Replace - Same Size	II
5103673	C66001	08/09/2015	9:12	08/09/2015	10:51	150	14809	98	Overhead equipment	Fuse	Replace - Same Size		III
5103681	V14579	08/09/2015	9:24	08/09/2015	15:25	27	8071	361	Weather	Underground Primary	Repair	Repair	II
5103685	U06524	08/09/2015	9:30	08/09/2015	12:46	3	588	195	Overhead equipment	Overhead Transformer	Replace - New Size		II
5103697	U09557	08/09/2015	9:35	08/09/2015	12:30	17	2963	174	Tree related-tree broken	Fuse	Replace - Same Size		II
5103691	K74164	08/09/2015	9:40	08/09/2015	12:25	1	164	164	Overhead equipment	Overhead Secondary	Replace - Same Size		IV
5103695	J05139	08/09/2015	9:47	08/09/2015	16:05	1	377	377	Animal related	Fuse	Replace - Same Size		I
5103705	Q32171	08/09/2015	10:10	08/09/2015	15:07	1	296	296	Weather	Transformer Fuse	Replace - Same Size	Patrol/Test/Inspect	I
5103709	Y32001	08/09/2015	10:18	08/09/2015	11:45	1	86	86	Overhead equipment	Transformer Fuse	Repair	Replace - Same Size	IV
5103711	J34357	08/09/2015	10:26	08/09/2015	10:57	6	182	30	Animal related	Transformer Fuse	Replace - Same Size	Replace - Same Size	V
5103721	L24123	08/09/2015	10:31	08/09/2015	13:20	1	168	168	Weather	Substation Transformer	Repair		III
5103723	L24123	08/09/2015	10:31	08/09/2015	13:20	1	168	168	Weather	Substation Transformer	Repair		III
5103725	L24123	08/09/2015	10:31	08/09/2015	13:20	1	168	168	Weather	Substation Transformer	Repair		III
5103719	L24123	08/09/2015	10:31	08/09/2015	13:20	1	168	168	Weather	Substation Transformer	Repair		III
5103739	L24-UNIT-1	08/09/2015	10:31	08/09/2015	13:29	337	59851	177	Weather	Substation Breaker	Replace - Same Size		III
5103735	P69175	08/09/2015	10:31	08/09/2015	13:20	1	168	168	Weather	Substation Transformer	Repair		III
5103763	U91599	08/09/2015	10:42	08/09/2015	13:01	1	138	138	Weather	Fuse	Replace - Same Size		II
5103767	HE3303	08/09/2015	10:48	08/09/2015	11:57	227	15583	68	Animal related				VI
5103765	HE3303	08/09/2015	10:48	08/09/2015	11:57	225	15446	68	Animal related				VI
5103839	A68001	08/09/2015	11:49	08/09/2015	18:22	30	11773	392	Overhead equipment	Pole	Replace - Same Size		I
5103797	Y73504	08/09/2015	12:09	08/09/2015	14:11	1	121	121	Substation equipment				IV
5103799	307003	08/09/2015	12:09	08/09/2015	13:20	1	70	70	Public	Overhead Service	Repair		VI
5103843	A68001	08/09/2015	12:13	08/09/2015	18:48	1	394	394	Overhead equipment	Pole	Replace - Same Size		I
5103807	N42856	08/09/2015	12:17	08/09/2015	21:03	11	5784	525	Underground equipment	Underground Primary	Repair	Repair	V
5103809	C70001	08/09/2015	12:31	08/09/2015	16:28	1	236	236	Weather	Fuse	Replace - Same Size		III
5103851	N54214	08/09/2015	12:58	08/09/2015	15:50	54	9288	171	Underground equipment	Underground Primary			II
5103817	P69175	08/09/2015	13:08	08/09/2015	13:20	1	11	11	Weather	Substation Transformer	Repair		III
5103825	D70006	08/09/2015	13:14	08/09/2015	16:09	52	9074	174	Unknown	Other		Repair	I
5103835	Z51551	08/09/2015	13:33	08/09/2015	14:15	1	41	41	Animal related	Fuse	Replace - Same Size		IV
5103837	X19561	08/09/2015	13:40	08/09/2015	14:55	9	674	74	Overhead equipment	Overhead Primary	Patrol/Test/Inspect		IV
5103845	D16003	08/09/2015	13:43	08/09/2015	15:30	1	106	106	Tree related-tree broken	Overhead Service	Tie/Tighten	Tie/Tighten	I
5103847	R16513	08/09/2015	13:50	08/09/2015	15:00	13	903	69	Animal related	Transformer Fuse	Replace - Same Size		I
5103855	U39541	08/09/2015	14:16	08/09/2015	16:12	1	115	115	Overhead equipment	Substation Misc.			II
5103857	J79304	08/09/2015	14:27	08/09/2015	16:25	1	117	117	Overhead equipment	Fuse	Replace - Same Size		I
5103859	S60581	08/09/2015	14:28	08/09/2015	17:24	1	175	175	Overhead equipment	Disconnect Switch	Patrol/Test/Inspect	Replace - Same Size	VI
5103861	U39541	08/09/2015	14:32	08/09/2015	16:35	1	122	122	Overhead equipment	Transformer Fuse	Replace - Same Size		II
5103867	X19561	08/09/2015	14:36	08/09/2015	19:06	10	2707	270	Underground equipment	Underground Primary	Repair	Repair	IV
5103871	M36189	08/09/2015	15:02	08/09/2015	17:05	1	122	122	Overhead equipment	Overhead Service	Patrol/Test/Inspect	Replace - Same Size	I
5103875	Q64919	08/09/2015	15:19	08/09/2015	16:55	1	95	95	Animal related	Fuse	Replace - Same Size		VI
5103877	U13551	08/09/2015	15:32	08/09/2015	17:08	1	95	95	Weather	Transformer Fuse	Replace - Same Size		II

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5103881	Y32002	08/09/2015	15:38	08/09/2015	17:58	1	139	139	Overhead equipment	Transformer Fuse	Repair	Replace - Same Size	IV
5103885	307003	08/09/2015	15:40	08/09/2015	17:57	33	4516	136	Public	Pole	Repair	Replace - Same Size	VI
5103893	Q34380	08/09/2015	16:20	08/09/2015	20:09	84	19185	228	Overhead equipment	Overhead Primary	Replace - Same Size	Repair	I
5103907	K27150	08/09/2015	16:55	08/09/2015	18:43	64	6854	107	Underground equipment	Underground Primary	Patrol/Test/Inspect		VI
5103913	P69174	08/09/2015	17:22	08/09/2015	22:26	1	303	303	Overhead equipment	Overhead Transformer	Replace - Same Size		III
5103925	Z04002	08/09/2015	17:56	08/09/2015	21:00	8	1465	183	Overhead equipment	Overhead Transformer	Replace - Same Size	Replace - Same Size	IV
5103931	K27153	08/09/2015	18:06	08/09/2015	19:13	1	66	66	Overhead equipment	Overhead Service	Repair	Repair	VI
5103937	N42856	08/09/2015	18:40	08/09/2015	21:03	2	285	142	Underground equipment				V
5103939	J79304	08/09/2015	18:43	08/09/2015	20:36	1	112	112	Overhead equipment	Overhead Secondary	Reconnect		I
5103941	U06524	08/09/2015	18:51	08/09/2015	20:28	33	3204	97	Other	Fuse	Replace - Same Size		II
5103953	L50214	08/09/2015	19:40	08/10/2015	6:55	16	10786	674	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	VI
5103955	301053	08/09/2015	19:46	08/09/2015	21:20	1	93	93	Overhead equipment	Transformer Fuse	Replace - Same Size		VI
5103977	M81402	08/09/2015	20:14	08/09/2015	22:45	80	12100	151	Overhead equipment	Fuse		Replace - Same Size	V
5103969	L50215	08/09/2015	20:15	08/10/2015	13:14	1	1018	1018	Weather	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	VI
5103971	K15207	08/09/2015	20:17	08/10/2015	12:34	14	13670	976	Tree related-tree broken				VI
5103985	J85161	08/09/2015	20:19	08/10/2015	3:25	98	41677	425	Weather	Fuse	Patrol/Test/Inspect		VI
5103981	306003	08/09/2015	20:21	08/09/2015	22:11	5	549	109	Overhead equipment	Overhead Primary	Repair		VI
5103989	332003	08/09/2015	20:24	08/10/2015	5:30	39	21261	545	Tree related-tree broken	Pole	Patrol/Test/Inspect	Replace - Same Size	VI
5103997	337002	08/09/2015	20:29	08/10/2015	6:00	1	570	570	Overhead equipment	Overhead Secondary	Tie/Tighten		VI
5104001	Q21423	08/09/2015	20:31	08/10/2015	9:25	6	4639	773	Transmission outage	Fuse	Replace - Same Size	Replace - Same Size	VI
5104003	311001	08/09/2015	20:32	08/10/2015	2:30	39	13940	357	Weather	Fuse	Replace - Same Size		VI
5104665	J85161	08/09/2015	20:33	08/10/2015	10:48	5	4273	854	Tree related-tree broken	Overhead Secondary	Patrol/Test/Inspect	Repair	VI
5104009	M30301	08/09/2015	20:37	08/10/2015	3:36	1	418	418	Overhead equipment				VI
5104011	K32915	08/09/2015	20:38	08/09/2015	22:06	40	3513	87	Weather	Fuse			VI
5104013	Y57001	08/09/2015	20:38	08/09/2015	22:33	1	114	114	Tree related-tree contact	Overhead Service	Repair		IV
5104017	K32915	08/09/2015	20:39	08/09/2015	21:40	9	546	60	Overhead equipment	Fuse	Replace - Same Size		VI
5104071	Q23256	08/09/2015	20:42	08/10/2015	0:20	1164	115536	218	Overhead equipment				VI
5104043	M19222	08/09/2015	20:44	08/10/2015	4:42	4	1908	477	Overhead equipment	Fuse	Repair	Repair	VI
5104045	K55398	08/09/2015	20:45	08/09/2015	23:18	1	152	152	Weather	Transformer Fuse	Replace - Same Size		V
5104049	L99392	08/09/2015	20:46	08/10/2015	1:20	7	1917	273	Weather	Fuse	Replace - Same Size		V
5104063	J20931	08/09/2015	20:48	08/10/2015	0:27	1	218	218	Weather	Fuse	Replace - Same Size		VI
5104067	325010	08/09/2015	20:49	08/10/2015	1:07	38	9800	257	Overhead equipment	Overhead Primary	Trim		VI
5104073	L50215	08/09/2015	20:50	08/10/2015	6:03	5	2761	552	Weather	Fuse	Patrol/Test/Inspect		VI
5104151	L99392	08/09/2015	20:51	08/10/2015	2:29	13	4385	337	Weather	Fuse	Replace - Same Size		V
5104093	L99392	08/09/2015	20:53	08/10/2015	2:53	157	56499	359	Weather				V
5104099	328120	08/09/2015	20:53	08/09/2015	22:05	30	2147	71	Tree related-tree broken	Fuse	Replace - Same Size		V
5104643	L99392	08/09/2015	20:53	08/10/2015	3:08	37	13774	374	Weather	Fuse	Replace - Same Size		V
5104087	R53390	08/09/2015	20:53	08/10/2015	7:20	4	2505	626	Weather	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	V
5104103	Q27185	08/09/2015	20:56	08/10/2015	1:49	14	4094	292	Overhead equipment	Jumper	Replace - Same Size		VI
5104101	K11372	08/09/2015	20:57	08/10/2015	9:30	1	752	752	Weather	Overhead Transformer	Patrol/Test/Inspect	Replace - New Size	V
5104165	P72319	08/09/2015	20:58	08/10/2015	3:34	587	232158	395	Weather	Overhead Primary		Repair	V
5104109	325010	08/09/2015	20:58	08/10/2015	4:10	20	8461	432	Underground equipment	Underground Transformer	Replace - Same Size		VI
5104193	J18268	08/09/2015	21:01	08/10/2015	2:30	15	4926	328	Weather	Fuse	Replace - Same Size		VI
5104129	334004	08/09/2015	21:03	08/10/2015	7:10	1	606	606	Overhead equipment	Connector	Patrol/Test/Inspect	Repair	VI
5104135	P82291	08/09/2015	21:03	08/10/2015	5:58	4	2137	534	Weather	Fuse	Replace - Same Size		VI
5104149	K55398	08/09/2015	21:07	08/10/2015	3:58	1	410	410	Weather	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	V
5104211	J18268	08/09/2015	21:09	08/10/2015	0:42	101	21437	212	Weather	Fuse	Replace - Same Size		VI
5104171	J18268	08/09/2015	21:13	08/10/2015	0:31	29	5729	197	Weather	Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
5104183	HD0573	08/09/2015	21:16	08/09/2015	21:50	1	33	33	Underground equipment				VI
5104195	329149	08/09/2015	21:19	08/09/2015	23:45	587	85220	145	Weather				V
5104199	H22346	08/09/2015	21:21	08/10/2015	6:24	27	14664	543	Weather	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	V
5104201	M81402	08/09/2015	21:22	08/10/2015	5:15	6	2837	472	Overhead equipment	Overhead Transformer		Replace - Same Size	V
5104259	N50331	08/09/2015	21:29	08/10/2015	1:36	1331	281942	246	Overhead equipment				II
5104227	HC9327	08/09/2015	21:30	08/10/2015	4:00	1	390	389	Overhead equipment	Fuse	Replace - Same Size		VI
5104507	329149	08/09/2015	21:31	08/10/2015	0:04	10	1525	152	Tree related-tree broken	Other	Patrol/Test/Inspect		V
5104253	R39934	08/09/2015	21:32	08/10/2015	1:20	1	227	227	Weather	Transformer Fuse	Replace - Same Size	Replace - Same Size	VI

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5104477	N50331	08/09/2015	21:34	08/09/2015	23:06	451	41410	91	Overhead equipment				II
5104293	N50333	08/09/2015	21:34	08/10/2015	4:22	14	5703	407	Unknown	Other	Patrol/Test/Inspect		II
5104303	P20930	08/09/2015	21:35	08/10/2015	3:25	1	349	349	Weather	Overhead Transformer		Replace - Same Size	VI
5104337	M53310	08/09/2015	21:39	08/10/2015	3:40	1	360	360	Weather				V
5104365	P73182	08/09/2015	21:39	08/10/2015	4:54	25	10886	435	Other	Overhead Primary		Replace - Same Size	VI
5104353	J18268	08/09/2015	21:43	08/10/2015	1:39	1	235	235	Weather	Disconnect Switch	Replace - Same Size		VI
5104371	L99392	08/09/2015	21:46	08/10/2015	3:27	1	340	340	Weather	Fuse	Replace - Same Size		V
5104379	330125	08/09/2015	21:48	08/10/2015	0:04	4	541	135	Tree related-tree broken	Other	Patrol/Test/Inspect		V
5104417	M78322	08/09/2015	21:55	08/10/2015	0:18	524	75036	143	Tree related-tree broken				V
5104415	R02120	08/09/2015	21:59	08/09/2015	23:45	1	105	105	Tree related-tree broken	Overhead Service	Disconnect	Advise Customer	VI
5104429	R02121	08/09/2015	22:01	08/10/2015	0:01	1	119	119	Overhead equipment	Fuse	Repair	Replace - Same Size	VI
5104433	J18268	08/09/2015	22:03	08/10/2015	0:52	1	168	168	Weather				VI
5104437	R06212	08/09/2015	22:04	08/10/2015	3:12	1	307	307	Unknown	Fuse	Replace - Same Size		II
5104447	J20931	08/09/2015	22:08	08/10/2015	1:38	2	419	209	Weather	Overhead Transformer		Replace - Same Size	VI
5104453	P42229	08/09/2015	22:09	08/10/2015	4:50	1	400	400	Overhead equipment	Fuse	Replace - Same Size		VI
5104457	L99392	08/09/2015	22:11	08/10/2015	6:30	1	498	498	Weather	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	V
5104471	P62113	08/09/2015	22:14	08/09/2015	23:27	22	1609	73	Overhead equipment	Fuse	Repair		VI
5104465	R04414	08/09/2015	22:16	08/10/2015	5:16	35	14712	420	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	V
5104467	303007	08/09/2015	22:17	08/10/2015	4:30	22	8192	372	Overhead equipment	Disconnect Switch	Patrol/Test/Inspect	Replace - Same Size	VI
5104655	311001	08/09/2015	22:27	08/10/2015	13:02	40	34983	874	Overhead equipment	Pole	Repair		VI
5104641	R53390	08/09/2015	22:32	08/10/2015	12:51	32	23459	858	Underground equipment	Underground Primary	Patrol/Test/Inspect	Patrol/Test/Inspect	V
5104489	K46389	08/09/2015	22:32	08/10/2015	4:30	1	357	357	Weather	Fuse	Replace - Same Size	Replace - Urgent	V
5104495	J74125	08/09/2015	22:38	08/10/2015	1:07	1	148	148	Overhead equipment	Fuse	Repair	Repair	VI
5104497	J74125	08/09/2015	22:41	08/10/2015	5:25	13	5259	404	Tree related-tree broken	Overhead Primary	Replace - Same Size		VI
5104529	N50331	08/09/2015	23:06	08/10/2015	1:40	319	48976	153	Overhead equipment				II
5104533	K22173	08/09/2015	23:22	08/10/2015	0:40	1	77	77	Unknown	Overhead Service	Replace - Same Size		VI
5104539	Q23256	08/09/2015	23:45	08/10/2015	14:26	3	2641	880	Overhead equipment	Overhead Primary	Replace - Same Size		VI
5104549	R02121	08/10/2015	0:21	08/10/2015	4:33	1	251	251	Overhead equipment	Overhead Transformer	Repair	Replace - Same Size	VI
5104561	Q51931	08/10/2015	0:35	08/10/2015	5:15	1	279	279	Weather	Substation Misc.	Patrol/Test/Inspect	Replace - Same Size	V
5104567	Q85162	08/10/2015	0:42	08/10/2015	5:48	2	610	305	Weather	Overhead Transformer	Repair	Repair	VI
5104571	J87111	08/10/2015	0:45	08/10/2015	10:26	36	15103	580	Tree related-tree broken	Tree			VI
5104573	M01912	08/10/2015	1:00	08/10/2015	1:23	1	22	22	Weather				V
5104577	329149	08/10/2015	1:07	08/10/2015	6:12	10	3053	305	Tree related-tree broken	Overhead Primary	Cut in Clear	Repair	V
5104581	K55398	08/10/2015	1:26	08/10/2015	3:58	1	151	151	Weather	Overhead Transformer	Repair	Replace - Urgent	V
5104585	X12526	08/10/2015	1:31	08/10/2015	5:30	1	238	238	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
5104615	K94223	08/10/2015	1:45	08/10/2015	4:19	331	50914	153	Overhead equipment	Pole			III
5104645	B84002	08/10/2015	2:55	08/10/2015	7:14	35	9069	259	Underground equipment	Underground Primary	Switch/Reset	Repair	I
5104649	R71285	08/10/2015	3:00	08/10/2015	12:25	1	564	564	Overhead equipment	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
5104657	S49549	08/10/2015	3:29	08/10/2015	8:59	1	329	329	Overhead equipment	Overhead Service	Patrol/Test/Inspect		VI
5104685	K94223	08/10/2015	3:48	08/10/2015	5:23	10	942	94	Public				III
5104667	L50214	08/10/2015	4:14	08/10/2015	7:44	4	836	209	Weather	Fuse	Replace - Same Size		VI
5104675	X69554	08/10/2015	4:29	08/10/2015	11:24	27	11222	415	Tree related-tree broken	Pole	Replace - Same Size	Replace - Same Size	IV
5104677	R41131	08/10/2015	4:54	08/10/2015	5:40	1	45	45	Tree related-tree broken	Fuse	Repair	Repair	VI
5104679	N50331	08/10/2015	4:55	08/10/2015	4:58	1	2	2	Unknown				II
5104683	N50331	08/10/2015	5:07	08/10/2015	6:03	1	55	55	Overhead equipment	Other	Patrol/Test/Inspect		II
5104699	R04414	08/10/2015	5:29	08/10/2015	9:20	23	5326	231	Weather	Overhead Transformer	Replace - Urgent		V
5104695	HB6281	08/10/2015	5:48	08/10/2015	10:20	1	271	271	Overhead equipment	Transformer Fuse	Repair	Repair	VI
5104703	R60552	08/10/2015	6:24	08/10/2015	10:03	1	218	218	Overhead equipment	Overhead Primary	Patrol/Test/Inspect	Repair	IV
5104707	P82291	08/10/2015	6:27	08/10/2015	10:30	1	242	242	Weather	Overhead Transformer		Replace - Same Size	VI
5104711	Q24313	08/10/2015	6:36	08/10/2015	9:16	1	159	159	Weather	Transformer Fuse	Replace - Same Size		VI
5104713	J80806	08/10/2015	6:36	08/10/2015	8:13	4	385	96	Animal related	Overhead Transformer	Replace - Same Size	Replace - Same Size	V
5104715	Y89535	08/10/2015	6:44	08/10/2015	9:00	1	135	135	Overhead equipment	Fuse	Repair	Replace - Same Size	IV
5104727	374056	08/10/2015	7:11	08/10/2015	11:01	2	459	229	Public	Disconnect Switch	Patrol/Test/Inspect		VI
5104729	H32370	08/10/2015	7:19	08/10/2015	8:32	1	72	72	Overhead equipment	Fuse	Replace - Same Size		V
5104731	Z05548	08/10/2015	7:20	08/10/2015	13:23	1	362	362	Underground equipment	Underground Primary			IV
5104735	J20931	08/10/2015	7:30	08/10/2015	8:30	1	59	59	Weather	Fuse	Repair		VI

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5104737	R02121	08/10/2015	7:34	08/10/2015	9:42	1	127	127	Overhead equipment	Overhead Transformer	Repair	Replace - Same Size	VI
5104739	L93135	08/10/2015	7:35	08/10/2015	10:22	1	166	166	Weather	Transformer Fuse			VI
5104741	L81141	08/10/2015	7:36	08/10/2015	9:08	1	91	91	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
5104743	K01241	08/10/2015	7:39	08/10/2015	9:51	1	131	131	Animal related	Transformer Fuse	Replace - Same Size		VI
5104745	J76804	08/10/2015	7:44	08/10/2015	13:00	1	315	315	Underground equipment	Underground Service	Repair	Repair	V
5104751	HC9327	08/10/2015	7:49	08/10/2015	12:15	1	265	265	Tree related-tree broken	Tree	Remove		VI
5104753	P52305	08/10/2015	7:52	08/10/2015	9:28	1	95	95	Weather	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	IV
5104755	332003	08/10/2015	7:52	08/10/2015	9:09	1	76	76	Tree related-tree broken	Other	Advise Customer		VI
5104759	D53001	08/10/2015	7:54	08/10/2015	9:03	1	68	68	Overhead equipment				I
5104761	U42512	08/10/2015	7:54	08/10/2015	10:05	1	130	130	Weather	Transformer Fuse	Replace - Same Size	Replace - Same Size	II
5104763	Q24312	08/10/2015	7:55	08/10/2015	10:45	1	169	169	Weather	Fuse	Replace - Same Size		VI
5104765	B21001	08/10/2015	7:55	08/10/2015	9:26	1	90	90	Other	Other			I
5104767	L50214	08/10/2015	7:56	08/10/2015	14:37	1	400	400	Weather	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	VI
5104771	B25002	08/10/2015	8:03	08/10/2015	8:48	1	44	44	Animal related	Transformer Fuse	Replace - Same Size		I
5104773	332005	08/10/2015	8:07	08/10/2015	8:24	1	16	16	Weather	Overhead Transformer	Disconnect		VI
5104775	U13551	08/10/2015	8:08	08/10/2015	9:26	1	77	77	Weather	Transformer Fuse	Replace - Same Size		II
5104779	L50214	08/10/2015	8:11	08/10/2015	14:03	12	4227	352	Weather	Underground Transformer	Patrol/Test/Inspect	Replace - Same Size	VI
5104785	R60552	08/10/2015	8:24	08/10/2015	10:06	130	13169	101	Overhead equipment	Overhead Primary	Replace - Same Size	Replace - Same Size	IV
5104787	R25906	08/10/2015	8:26	08/10/2015	16:02	1	455	455	Tree related-tree broken	Overhead Primary	Raise		I
5104791	K46422	08/10/2015	8:33	08/10/2015	9:54	83	6720	80	Tree related-tree broken	Tree		Trim	V
5104795	M25144	08/10/2015	8:36	08/10/2015	9:31	1	54	54	Animal related	Transformer Fuse	Replace - Same Size	Replace - Same Size	IV
5104861	B82001	08/10/2015	8:37	08/10/2015	11:17	57	9081	159	Overhead equipment	Lightning Arrestor	Repair		I
5104803	P17107	08/10/2015	8:45	08/10/2015	10:42	1	116	116	Overhead equipment	Overhead Service	Replace - New Size		IV
5104821	J87150	08/10/2015	9:03	08/10/2015	10:17	32	2366	73	Tree related-tree broken	Tree			VI
5104847	D41003	08/10/2015	9:37	08/10/2015	15:02	1	324	324	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
5104849	U41545	08/10/2015	9:38	08/10/2015	10:57	4	313	78	Unknown	Transformer Fuse	Replace - Same Size		II
5104865	Z06538	08/10/2015	10:03	08/10/2015	11:00	1	56	56	Overhead equipment	Connector	Replace - New Size		IV
5104889	K32932	08/10/2015	10:04	08/10/2015	11:14	7	492	70	Overhead equipment				VI
5104873	K32916	08/10/2015	10:05	08/10/2015	10:10	1	4	4	Overhead equipment				VI
5104875	J74125	08/10/2015	10:06	08/10/2015	10:48	1	41	41	Animal related	Transformer Fuse	Replace - Same Size		VI
5104877	L99392	08/10/2015	10:07	08/10/2015	11:35	1	87	87	Weather	Fuse	Replace - Same Size	Replace - Same Size	V
5104887	D53002	08/10/2015	10:14	08/10/2015	15:26	6	1873	312	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
5104891	U66515	08/10/2015	10:18	08/10/2015	12:25	1	126	126	Overhead equipment	Fuse	Replace - Same Size		II
5104907	P73182	08/10/2015	10:31	08/10/2015	13:44	4	772	193	Weather	Pole	Repair		VI
5104909	U73583	08/10/2015	10:34	08/10/2015	13:40	1	185	185	Animal related	Transformer Fuse	Replace - Same Size		II
5104921	P17108	08/10/2015	10:41	08/10/2015	11:59	1	77	77	Animal related	Transformer Fuse	Replace - Same Size		IV
5104923	B82001	08/10/2015	10:41	08/10/2015	10:45	249	1088	4	Overhead equipment	Recloser	Replace - Same Size	Replace - Same Size	I
5104987	B93001	08/10/2015	10:50	08/10/2015	14:45	1	235	235	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
5104951	B82001	08/10/2015	10:54	08/10/2015	11:38	1	43	43	Overhead equipment	Lightning Arrestor	Repair		I
5104957	B82001	08/10/2015	11:05	08/10/2015	11:37	1	31	31	Overhead equipment	Lightning Arrestor	Repair		I
5104963	C70002	08/10/2015	11:11	08/10/2015	12:35	1	83	83	Overhead equipment	Fuse	Replace - Same Size		III
5104969	A80001	08/10/2015	11:20	08/10/2015	12:42	1	81	81	Overhead equipment	Fuse	Repair	Replace - New Size	I
5104973	M17374	08/10/2015	11:23	08/10/2015	12:31	1	67	67	Weather	Fuse	Replace - Same Size		V
5104975	K30204	08/10/2015	11:23	08/10/2015	11:57	1	33	33	Animal related	Transformer Fuse	Replace - Same Size		III
5104979	S62522	08/10/2015	11:28	08/10/2015	12:52	1	83	83	Animal related	Transformer Fuse	Replace - New Size		VI
5104983	X72535	08/10/2015	11:34	08/10/2015	12:29	1	54	54	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
5104993	Q27185	08/10/2015	11:50	08/10/2015	13:55	1	124	124	Animal related	Transformer Fuse	Replace - Same Size		VI
5104997	K57211	08/10/2015	12:04	08/10/2015	13:44	1	99	99	Weather	Fuse	Repair	Replace - Same Size	VI
5105007	H14343	08/10/2015	12:22	08/10/2015	13:16	1	54	53	Overhead equipment	Fuse	Replace - Same Size		V
5105009	H11339	08/10/2015	12:24	08/10/2015	16:25	1	241	240	Underground equipment	Underground Service	Patrol/Test/Inspect	Repair	V
5105015	C21001	08/10/2015	12:34	08/10/2015	13:33	1	58	58	Overhead equipment	Fuse	Replace - Same Size		III
5105017	C21001	08/10/2015	12:35	08/10/2015	13:44	1	68	68	Overhead equipment	Fuse	Replace - Same Size		III
5105021	J13108	08/10/2015	12:45	08/10/2015	14:12	1	86	86	Animal related	Transformer Fuse	Replace - Same Size		I
5105051	S61531	08/10/2015	13:15	08/10/2015	13:52	1	36	36	Other	Pole	Replace - New Size		VI
5105053	Q37370	08/10/2015	13:18	08/10/2015	13:55	1	36	36	Animal related	Transformer Fuse	Replace - Same Size	Repair	I
5105055	D41003	08/10/2015	13:24	08/10/2015	15:09	2	208	104	Underground equipment	Underground Secondary	Repair	Replace - Same Size	I

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5105063	S61531	08/10/2015	13:39	08/10/2015	13:52	1	12	12	Other	Pole	Replace - New Size		VI
5105065	S03529	08/10/2015	13:40	08/10/2015	14:15	5	173	34	Tree related-tree broken	Overhead Primary	Repair	Repair	VI
5105069	X30505	08/10/2015	13:50	08/10/2015	14:40	1	49	49	Tree related-tree contact	Overhead Service			IV
5105085	L23145	08/10/2015	14:10	08/10/2015	14:43	1	32	32	Animal related	Transformer Fuse	Replace - Same Size		III
5105087	L68112	08/10/2015	14:15	08/10/2015	14:47	25	808	32	Overhead equipment	Overhead Transformer			IV
5105101	L68112	08/10/2015	14:47	08/10/2015	15:41	10	532	53	Overhead equipment	Overhead Transformer			IV
5105109	Q91175	08/10/2015	15:00	08/10/2015	15:20	1	19	19	Weather	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	I
5105113	H65272	08/10/2015	15:09	08/10/2015	17:50	1	160	160	Tree related-tree broken	Overhead Service	Repair		VI
5105121	308003	08/10/2015	15:21	08/10/2015	17:00	13	1277	98	Overhead equipment	Jumper	Repair		VI
5105123	J01118	08/10/2015	15:22	08/10/2015	18:19	1	176	176	Overhead equipment	Overhead Service	Tie/Tighten		I
5105135	M18131	08/10/2015	15:41	08/10/2015	16:08	4	108	27	Jurisdictional				III
5105143	Y06546	08/10/2015	16:09	08/10/2015	16:16	13	80	6	Underground equipment				IV
5105157	T15570	08/10/2015	16:49	08/10/2015	18:40	1	110	110	Intentional				VI
5105181	T06505	08/10/2015	16:51	08/10/2015	18:10	560	43820	78	Overhead equipment	Overhead Primary	Repair	Repair	VI
5105245	S53542	08/10/2015	17:14	08/10/2015	18:18	1	63	63	Overhead equipment				VI
5105253	Y61004	08/10/2015	17:50	08/10/2015	19:08	1	77	77	Overhead equipment	Overhead Service			IV
5105261	Y35005	08/10/2015	18:10	08/10/2015	19:15	1	64	64	Other	Meter			IV
5105263	L93149	08/10/2015	18:17	08/11/2015	1:01	8	3230	403	Underground equipment	Underground Secondary	Disconnect	Repair	VI
5105269	N50331	08/10/2015	18:29	08/10/2015	19:45	1	75	75	Overhead equipment	Transformer Fuse	Replace - Same Size		II
5105271	M09143	08/10/2015	18:34	08/10/2015	19:11	1	36	36	Overhead equipment	Overhead Primary	Replace - Same Size		VI
5105275	B93003	08/10/2015	18:36	08/10/2015	20:09	1	92	92	Overhead equipment	Fuse	Replace - Same Size		I
5105297	X02547	08/10/2015	20:18	08/10/2015	22:30	1	131	131	Overhead equipment	Fuse	Repair	Replace - Same Size	IV
5105301	H06135	08/10/2015	20:20	08/10/2015	22:05	1	104	104	Overhead equipment	Connector	Replace - Same Size		IV
5105307	M18131	08/10/2015	20:57	08/10/2015	21:50	1	52	52	Overhead equipment	Connector	Replace - Same Size		III
5105311	IP9009	08/10/2015	21:21	08/10/2015	22:47	1	85	85	Overhead equipment	Connector	Patrol/Test/Inspect	Repair	VI
5105317	L70127	08/10/2015	22:35	08/11/2015	1:23	41	6917	168	Underground equipment	Underground Primary	Repair		IV
5105325	V69532	08/11/2015	2:40	08/11/2015	3:27	1	46	46	Animal related	Transformer Fuse	Repair		II
5105327	X39530	08/11/2015	2:54	08/11/2015	8:56	7	1969	362	Underground equipment	Underground Primary	Repair	Repair	IV
5105385	B80004	08/11/2015	3:29	08/11/2015	14:29	933	243836	660	Overhead equipment	Overhead Primary	Replace - Same Size	Replace - Same Size	I
5105389	Q82907	08/11/2015	4:18	08/11/2015	5:56	1	97	97	Overhead equipment	Fuse	Replace - Same Size		VI
5105393	V23522	08/11/2015	5:27	08/11/2015	6:40	1	72	72	Animal related	Fuse	Patrol/Test/Inspect	Replace - Same Size	II
5105733	B80004	08/11/2015	5:55	08/11/2015	20:21	6	5192	865	Tree related-tree contact				I
5105397	U35511	08/11/2015	5:59	08/11/2015	7:28	1	88	88	Weather	Transformer Fuse	Replace - Same Size		II
5105399	K48378	08/11/2015	6:03	08/11/2015	11:25	1	321	321	Overhead equipment	Fuse	Patrol/Test/Inspect	Patrol/Test/Inspect	V
5105401	U44529	08/11/2015	6:16	08/11/2015	12:22	1	366	366	Underground equipment				II
5105403	V23522	08/11/2015	6:17	08/11/2015	6:40	1	22	22	Animal related	Fuse	Patrol/Test/Inspect	Replace - Same Size	II
5105497	D53002	08/11/2015	6:22	08/11/2015	14:27	3	1455	485	Tree related-tree broken	Tree			I
5105439	D53002	08/11/2015	6:31	08/11/2015	9:38	4	748	187	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
5105419	K32915	08/11/2015	7:02	08/11/2015	8:25	1	82	82	Tree related-tree contact	Overhead Service	Repair		VI
5105421	U41596	08/11/2015	7:04	08/11/2015	9:33	1	148	148	Unknown	Transformer Fuse	Replace - Same Size		II
5105425	U97528	08/11/2015	7:09	08/11/2015	9:35	1	145	145	Underground equipment	Underground Primary			II
5105435	Q32170	08/11/2015	7:26	08/11/2015	8:55	1	88	88	Animal related	Transformer Fuse	Repair	Patrol/Test/Inspect	I
5105445	Q16867	08/11/2015	7:51	08/11/2015	9:39	1	107	107	Overhead equipment	Transformer Fuse	Replace - Same Size		V
5105453	X75512	08/11/2015	8:07	08/11/2015	10:06	1	118	118	Animal related	Transformer Fuse	Replace - Same Size	Replace - Same Size	IV
5105455	P49180	08/11/2015	8:09	08/11/2015	9:28	1	78	78	Animal related	Fuse	Repair	Replace - Same Size	I
5105457	U93507	08/11/2015	8:09	08/11/2015	9:45	1	95	95	Overhead equipment	Overhead Service	Repair	Repair	II
5105461	B80004	08/11/2015	8:16	08/11/2015	9:07	1	50	50	Overhead equipment	Fuse	Replace - Same Size		I
5105471	V92540	08/11/2015	8:54	08/11/2015	10:34	27	2710	100	Public	Overhead Primary	Replace - Same Size		II
5105495	Q64919	08/11/2015	9:39	08/11/2015	10:13	1	33	33	Animal related	Transformer Fuse	Replace - Same Size		VI
5105527	K31120	08/11/2015	10:09	08/11/2015	11:46	87	8432	96	Unknown	Recloser	Switch/Reset		I
5105515	K31120	08/11/2015	10:15	08/11/2015	11:53	1	97	97	Unknown	Recloser	Switch/Reset		I
5105543	D93002	08/11/2015	10:33	08/11/2015	17:02	31	12046	388	Tree related-tree broken	Pole	Patrol/Test/Inspect	Repair	IV
5105551	K08909	08/11/2015	10:38	08/11/2015	11:18	1	39	39	Overhead equipment	Connector	Replace - New Size		VI
5105557	HC9325	08/11/2015	10:42	08/11/2015	12:32	1	109	109	Weather	Fuse	Repair		VI
5105563	D53001	08/11/2015	10:47	08/11/2015	13:09	16	2266	141	Overhead equipment	Other		Repair	I
5105585	U37001	08/11/2015	11:12	08/11/2015	11:35	7	155	22	Overhead equipment	Overhead Service	Replace - Same Size		II

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5154877	K31120	08/11/2015	11:39	08/11/2015	11:51	2	23	11	Unknown				I
5105617	A91003	08/11/2015	11:45	08/11/2015	15:36	1	230	230	Unknown	Underground Transformer	Patrol/Test/Inspect	Repair	I
5105623	U60559	08/11/2015	12:05	08/11/2015	13:00	1	54	54	Animal related	Fuse	Replace - Same Size		II
5105633	D48001	08/11/2015	12:15	08/11/2015	13:29	63	4628	73	Overhead equipment	Lightning Arrestor	Replace - Same Size		I
5105637	B71002	08/11/2015	12:31	08/11/2015	14:20	1	108	108	Overhead equipment	Connector	Replace - Same Size		I
5105643	HA5432	08/11/2015	12:45	08/11/2015	13:12	1	26	26	Overhead equipment	Lightning Arrestor	Disconnect		V
5105661	M30301	08/11/2015	12:56	08/11/2015	13:42	60	2748	45	Overhead equipment	Overhead Primary			VI
5105667	342003	08/11/2015	13:16	08/11/2015	16:48	1	211	211	Overhead equipment	Overhead Service	Patrol/Test/Inspect	Replace - New Size	VI
5105697	M22812	08/11/2015	13:26	08/11/2015	15:21	14	1606	114	Public	Fuse	Replace - Same Size	Repair	V
5105689	303006	08/11/2015	13:30	08/11/2015	16:22	1	171	171	Tree related-tree broken	Overhead Service	Repair		VI
5105699	D31016	08/11/2015	13:43	08/11/2015	14:25	1	41	41	Tree related-tree contact	Overhead Service	Repair		III
5105703	J07173	08/11/2015	13:47	08/11/2015	15:36	1	108	108	Tree related-tree broken	Overhead Service	Repair	Replace - Same Size	I
5105719	B10002	08/11/2015	14:09	08/11/2015	15:15	1	65	65	Overhead equipment	Disconnect Switch	Replace - Same Size		I
5105735	D70005	08/11/2015	14:30	08/11/2015	16:34	2	248	124	Underground equipment	Other	Repair	Repair	I
5105741	V99562	08/11/2015	14:32	08/11/2015	19:00	2	534	267	Overhead equipment	Pole	Replace - New Size	Patrol/Test/Inspect	II
5105753	H01192	08/11/2015	14:49	08/11/2015	15:35	1	45	45	Unknown	Transformer Fuse	Replace - Same Size		III
5105761	Y10011	08/11/2015	15:00	08/11/2015	16:05	1	64	64	Overhead equipment	Overhead Service	Repair		IV
5105765	C40002	08/11/2015	15:04	08/11/2015	21:43	1	398	398	Other	Meter	Reconnect		I
5105779	B38001	08/11/2015	15:58	08/12/2015	1:38	1	580	580	Underground equipment	Underground Primary	Repair	Repair	I
5105785	B45003	08/11/2015	16:05	08/11/2015	22:09	3	911	363	Underground equipment	Underground Primary	Repair	Repair	I
5105789	J85161	08/11/2015	16:17	08/11/2015	17:27	1	69	69	Overhead equipment	Fuse	Replace - Same Size		VI
5105791	B27009	08/11/2015	16:18	08/11/2015	20:07	1	228	228	Unknown	Overhead Service	Cut in Clear	Repair	I
5105813	R84148	08/11/2015	17:15	08/11/2015	18:05	7	348	49	Unknown	Fuse	Patrol/Test/Inspect	Replace - Same Size	I
5105815	S36571	08/11/2015	17:20	08/12/2015	1:25	3	1452	484	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Patrol/Test/Inspect	VI
5105823	J12166	08/11/2015	17:47	08/11/2015	18:34	7	322	46	Animal related	Transformer Fuse	Replace - Same Size		III
5105825	T46001	08/11/2015	17:53	08/11/2015	18:35	20	834	41	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect		VI
5105833	B82002	08/11/2015	18:46	08/11/2015	20:38	1	111	111	Overhead equipment	Transformer Fuse	Replace - Same Size		I
5105841	M45212	08/11/2015	19:57	08/11/2015	21:38	1	100	100	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
5105843	Q01281	08/11/2015	20:02	08/11/2015	22:00	1	117	117	Overhead equipment	Overhead Service			III
5105845	J30201	08/11/2015	20:03	08/12/2015	0:37	4	1094	273	Overhead equipment	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
5105853	N67309	08/11/2015	20:36	08/11/2015	21:10	1	33	33	Overhead equipment	Transformer Fuse	Replace - Same Size	Replace - Same Size	I
5105857	K28180	08/11/2015	20:41	08/11/2015	21:40	1	58	58	Overhead equipment	Lightning Arrestor	Replace - Same Size		III
5105863	U60518	08/11/2015	22:09	08/11/2015	23:20	1	70	70	Animal related	Transformer Fuse	Replace - Same Size		II
5105865	K31120	08/11/2015	22:41	08/12/2015	0:15	1	93	93	Overhead equipment	Overhead Transformer	Switch/Reset	Switch/Reset	I
5105867	A29001	08/11/2015	23:02	08/12/2015	0:25	1	82	82	Overhead equipment	Overhead Service	Patrol/Test/Inspect	Repair	I
5105871	A91001	08/11/2015	23:16	08/12/2015	4:22	64	19552	305	Underground equipment	Underground Secondary		Repair	I
5105877	C70002	08/12/2015	1:26	08/12/2015	9:57	1	510	510	Underground equipment	Underground Primary			III
5105879	K89143	08/12/2015	2:59	08/12/2015	6:31	19	3716	212	Underground equipment	Underground Primary		Repair	III
5105885	K89143	08/12/2015	3:42	08/12/2015	6:32	1	169	169	Underground equipment	Underground Primary	Repair		III
5105887	P20913	08/12/2015	3:52	08/12/2015	5:41	1	108	108	Overhead equipment	Overhead Transformer	Switch/Reset		VI
5105889	D70006	08/12/2015	4:08	08/12/2015	6:53	23	3799	165	Underground equipment	Other	Patrol/Test/Inspect	Patrol/Test/Inspect	I
5105895	V18541	08/12/2015	5:08	08/12/2015	8:44	25	5382	215	Underground equipment	Underground Primary	Repair	Repair	II
5105899	K89143	08/12/2015	6:36	08/12/2015	7:20	5	222	44	Underground equipment	Underground Primary	Repair	Replace - Same Size	III
5105905	L86175	08/12/2015	6:42	08/12/2015	9:58	38	7443	195	Underground equipment	Underground Primary			IV
5105903	K89143	08/12/2015	6:43	08/12/2015	6:56	14	179	12	Underground equipment	Underground Primary			III
5105907	HD0573	08/12/2015	6:58	08/12/2015	12:00	1	301	301	Underground equipment	Underground Secondary		Repair	VI
5105915	L86175	08/12/2015	7:23	08/12/2015	10:00	1	156	156	Underground equipment	Underground Primary			IV
5105917	L23146	08/12/2015	7:26	08/12/2015	8:37	1	70	70	Overhead equipment	Overhead Service	Cut in Clear		III
5105921	N54213	08/12/2015	8:02	08/12/2015	9:18	1	75	75	Animal related	Fuse	Replace - Same Size		II
5105923	U44001	08/12/2015	8:03	08/12/2015	8:46	1	42	42	Overhead equipment	Other			II
5105925	Y39001	08/12/2015	8:09	08/12/2015	11:06	1	176	176	Overhead equipment	Overhead Transformer	Replace - Same Size		IV
5105939	C00001	08/12/2015	8:29	08/12/2015	10:00	1	90	90	Animal related	Fuse	Replace - Same Size		I
5105957	Q18244	08/12/2015	9:04	08/12/2015	9:07	35	91	2	Overhead equipment				VI
5105959	Q18244	08/12/2015	9:05	08/12/2015	9:08	60	159	2	Overhead equipment				VI
5105969	Q23255	08/12/2015	9:21	08/12/2015	12:15	3	519	173	Tree related-tree contact	Tree			VI
5105973	L86175	08/12/2015	9:27	08/12/2015	10:00	1	32	32	Underground equipment	Underground Primary			IV

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5105975	L86175	08/12/2015	9:28	08/12/2015	10:09	1	41	41	Underground equipment	Underground Primary			IV
5106035	B71002	08/12/2015	10:44	08/12/2015	12:09	1	84	84	Tree related-tree broken	Overhead Service			I
5106057	D16003	08/12/2015	11:06	08/12/2015	14:44	74	16081	217	Overhead equipment	Disconnect Switch	Replace - Same Size	Replace - Same Size	I
5106073	U45585	08/12/2015	11:32	08/12/2015	14:18	1	165	165	Other	Other			II
5106083	M78322	08/12/2015	11:55	08/12/2015	12:30	1	34	34	Tree related-tree contact	Overhead Service	Repair		V
5106089	C52001	08/12/2015	12:17	08/12/2015	13:45	33	2878	87	Overhead equipment	Overhead Primary	Repair		III
5106117	L24123	08/12/2015	13:11	08/12/2015	14:52	1	100	100	Unknown	Transformer Fuse	Replace - Same Size		III
5106125	K74162	08/12/2015	13:17	08/12/2015	13:48	43	1304	30	Other				IV
5106131	V80002	08/12/2015	13:29	08/12/2015	15:15	17	1790	105	Overhead equipment	Fuse	Replace - Same Size		II
5106133	N50333	08/12/2015	13:30	08/12/2015	13:55	1	24	24	Animal related	Fuse	Replace - Same Size		II
5106137	J34377	08/12/2015	13:37	08/12/2015	15:20	1	102	102	Public	Overhead Service	Repair		V
5106143	R04413	08/12/2015	13:44	08/12/2015	14:58	23	1699	73	Public	Underground Primary	Disconnect		V
5106177	L35138	08/12/2015	14:10	08/12/2015	14:59	9	448	49	Overhead equipment	Connector	Repair		III
5106185	B38001	08/12/2015	14:28	08/12/2015	14:32	1	4	4	Overhead equipment	Overhead Primary	Replace - Same Size		I
5106215	Y20522	08/12/2015	15:46	08/12/2015	20:50	5	1166	304	Underground equipment	Underground Primary		Advise Customer	IV
5106223	309143	08/12/2015	16:24	08/12/2015	17:13	1	48	48	Overhead equipment	Overhead Service	Repair		V
5106225	S01501	08/12/2015	16:24	08/12/2015	17:26	1	61	61	Underground equipment	Underground Primary	Repair	Replace - Same Size	VI
5106233	J18268	08/12/2015	17:10	08/12/2015	21:00	4	917	229	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	VI
5106237	S61529	08/12/2015	17:16	08/12/2015	18:00	1	43	43	Overhead equipment				VI
5106239	M61302	08/12/2015	17:55	08/12/2015	20:27	1	151	151	Overhead equipment	Overhead Service	Repair		V
5106243	Q51931	08/12/2015	18:20	08/12/2015	23:48	1	327	327	Overhead equipment				V
5106249	B21001	08/12/2015	18:50	08/12/2015	22:09	73	14516	198	Underground equipment	Other	Repair	Repair	I
5106255	K01240	08/12/2015	18:54	08/13/2015	1:00	1	365	365	Underground equipment	Underground Secondary		Repair	VI
5106259	R59417	08/12/2015	19:13	08/12/2015	19:37	63	1477	23	Animal related	Transformer Fuse	Replace - Same Size		IV
5106261	T17581	08/12/2015	19:16	08/12/2015	22:35	1	198	198	Other	Other			VI
5106263	Y54002	08/12/2015	19:26	08/12/2015	20:20	24	1300	54	Tree related-tree broken	Overhead Primary	Repair		IV
5106269	U41517	08/12/2015	19:33	08/12/2015	21:56	8	1149	143	Overhead equipment	Overhead Primary	Repair		II
5106307	X36001	08/12/2015	23:41	08/13/2015	1:00	1	78	78	Public	Overhead Service	Cut in Clear	Remove	IV
5106309	U31565	08/12/2015	23:42	08/13/2015	2:08	103	14873	145	Underground equipment	Underground Primary	Repair		II
5106317	K76542	08/13/2015	3:50	08/13/2015	7:00	29	5196	190	Underground equipment	Underground Primary	Switch/Reset	Switch/Reset	IV
5106321	R58931	08/13/2015	5:21	08/13/2015	7:39	1	138	138	Overhead equipment	Fuse	Replace - Same Size		IV
5106327	U68581	08/13/2015	6:28	08/13/2015	8:22	4	454	113	Animal related	Transformer Fuse	Replace - Same Size		II
5106329	D37003	08/13/2015	7:28	08/13/2015	8:30	1	61	61	Overhead equipment	Connector	Replace - Same Size		I
5106335	P17109	08/13/2015	7:30	08/13/2015	9:39	14	1807	129	Underground equipment	Underground Primary	Switch/Reset	Repair	IV
5106333	B82001	08/13/2015	7:32	08/13/2015	14:55	1	442	442	Underground equipment	Underground Primary	Replace - Same Size	Repair	I
5106337	P57104	08/13/2015	7:42	08/13/2015	10:16	1	153	153	Overhead equipment	Overhead Transformer	Repair	Replace - Same Size	VI
5106341	Y45003	08/13/2015	8:07	08/13/2015	10:08	207	25015	120	Public	Overhead Primary	Repair	Replace - Same Size	IV
5106455	R94-UNIT-1	08/13/2015	8:11	08/13/2015	12:44	539	146512	272	Animal related	Recloser	Patrol/Test/Inspect	Replace - Same Size	VI
5106347	N15850	08/13/2015	8:12	08/13/2015	9:10	1	57	57	Overhead equipment	Fuse			V
5106363	X49568	08/13/2015	8:14	08/13/2015	9:05	1	50	50	Overhead equipment	Fuse	Repair		IV
5106479	P52305	08/13/2015	9:35	08/13/2015	11:54	1	138	138	Weather	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	IV
5106499	Z21564	08/13/2015	9:57	08/13/2015	12:00	1	122	122	Public	Underground Service	Repair	Replace - Same Size	IV
5106563	X57566	08/13/2015	10:15	08/13/2015	14:56	2	561	280	Animal related	Underground Primary	Repair	Repair	IV
5106527	M42105	08/13/2015	10:35	08/13/2015	12:08	1	92	92	Overhead equipment	Overhead Service	Repair	Replace - Same Size	I
5106541	F03003	08/13/2015	10:59	08/13/2015	13:06	2	253	126	Public				III
5106547	F03003	08/13/2015	11:18	08/13/2015	13:26	1	127	127	Public	Underground Transformer		Repair	III
5106557	B80004	08/13/2015	11:45	08/13/2015	18:38	1	413	413	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
5106567	U99593	08/13/2015	11:54	08/13/2015	16:55	16	1639	301	Overhead equipment	Pole	Replace - Same Size		II
5106571	U99593	08/13/2015	11:54	08/13/2015	12:10	34	514	15	Overhead equipment	Fuse	Replace - Same Size		II
5106593	S41565	08/13/2015	12:52	08/13/2015	14:53	10	1202	120	Overhead equipment	Overhead Transformer	Repair	Replace - Same Size	VI
5106619	S62520	08/13/2015	13:29	08/13/2015	14:00	1	30	30	Overhead equipment	Fuse		Replace - Same Size	VI
5106621	X78002	08/13/2015	13:30	08/13/2015	16:17	1	166	166	Tree related-tree contact	Tree	Trim		IV
5106635	Z17554	08/13/2015	13:47	08/13/2015	16:16	1	149	149	Underground equipment	Underground Primary	Repair	Repair	IV
5106639	D66001	08/13/2015	13:55	08/13/2015	16:08	10	1329	132	Tree related-tree contact	Tree		Trim	IV
5106655	J87120	08/13/2015	14:08	08/13/2015	16:01	22	2499	113	Public	Underground Primary	Switch/Reset		VI
5106653	T59942	08/13/2015	14:08	08/13/2015	14:56	1	47	47	Overhead equipment	Connector	Repair		VI

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5106665	V92543	08/13/2015	14:31	08/13/2015	19:39	2	615	307	Underground equipment	Underground Primary	Repair	Patrol/Test/Inspect	II
5106671	V01002	08/13/2015	15:04	08/14/2015	13:42	1	1357	1357	Tree related-tree broken				II
5106677	L71170	08/13/2015	15:20	08/13/2015	17:49	1	148	148	Animal related				IV
5106679	P19395	08/13/2015	15:22	08/13/2015	17:14	1	111	111	Overhead equipment	Transformer Fuse	Replace - Same Size		V
5106681	C66002	08/13/2015	15:23	08/13/2015	17:25	1	121	121	Tree related-tree broken	Overhead Service		Repair	III
5106697	Q34367	08/13/2015	15:47	08/13/2015	16:51	165	10452	63	Overhead equipment	Fuse	Replace - Same Size		I
5106705	X78002	08/13/2015	16:01	08/13/2015	16:17	1	15	15	Tree related-tree contact	Tree	Trim		IV
5106709	G10002	08/13/2015	16:21	08/14/2015	0:14	1	473	473	Underground equipment	Underground Primary	Disconnect	Repair	I
5106723	L90359	08/13/2015	16:57	08/13/2015	19:30	22	3357	152	Weather	Lightning Arrestor	Disconnect		V
5106729	N72240	08/13/2015	17:03	08/13/2015	19:06	1	122	122	Public	Overhead Secondary		Patrol/Test/Inspect	III
5106737	J20931	08/13/2015	17:57	08/13/2015	18:53	1	55	55	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	VI
5106739	B76003	08/13/2015	18:10	08/14/2015	4:30	1	619	619	Underground equipment	Underground Service	Patrol/Test/Inspect	Replace - Same Size	I
5106753	V21548	08/13/2015	18:44	08/14/2015	2:28	383	127578	463	Underground equipment	Underground Primary		Replace - Same Size	II
5106809	S95571	08/13/2015	20:03	08/13/2015	20:36	1	32	32	Animal related	Transformer Fuse	Replace - Same Size		VI
5106819	K62102	08/13/2015	21:00	08/14/2015	1:39	13	3628	279	Underground equipment	Underground Primary	Switch/Reset	Repair	II
5106823	L81141	08/13/2015	21:07	08/13/2015	22:02	1	54	54	Animal related	Transformer Fuse	Replace - Same Size		IV
5106825	Q01281	08/13/2015	21:10	08/14/2015	1:02	1	231	231	Underground equipment	Underground Service			III
5106843	R10943	08/13/2015	22:12	08/13/2015	23:22	16	1122	70	Underground equipment	Underground Primary	Switch/Reset	Repair	VI
5106841	K62102	08/13/2015	22:14	08/13/2015	23:26	1	71	71	Animal related	Transformer Fuse	Replace - Same Size		II
5106845	S62521	08/13/2015	22:56	08/13/2015	23:31	1	34	34	Overhead equipment				VI
5106849	R10943	08/13/2015	23:26	08/13/2015	23:39	33	428	12	Underground equipment	Underground Primary	Switch/Reset		VI
5106853	S88503	08/13/2015	23:44	08/14/2015	1:28	1	103	103	Overhead equipment	Fuse	Repair		VI
5106857	R10943	08/13/2015	23:57	08/14/2015	0:11	13	185	14	Underground equipment				VI
5106859	R10943	08/14/2015	0:11	08/14/2015	0:58	16	752	47	Underground equipment				VI
5106865	332001	08/14/2015	1:01	08/14/2015	8:00	18	7533	418	Tree related-tree broken	Overhead Primary	Patrol/Test/Inspect	Repair	VI
5106867	332001	08/14/2015	1:06	08/14/2015	8:00	1	413	413	Tree related-tree broken	Tree	Remove		VI
5106875	C40002	08/14/2015	2:39	08/14/2015	6:08	5	1041	208	Underground equipment	Disconnect Switch	Patrol/Test/Inspect	Replace - Same Size	I
5106877	M40132	08/14/2015	3:41	08/14/2015	11:11	32	9153	450	Underground equipment	Underground Primary		Repair	I
5106879	S27599	08/14/2015	3:43	08/14/2015	6:10	1	146	146	Overhead equipment	Transformer Fuse	Repair	Replace - Same Size	VI
5106883	P73157	08/14/2015	4:23	08/14/2015	7:49	2	411	205	Underground equipment	Underground Primary		Replace - Same Size	VI
5106885	L79158	08/14/2015	4:55	08/14/2015	6:21	13	1114	85	Animal related	Transformer Fuse	Replace - Same Size		IV
5106895	M22812	08/14/2015	7:14	08/14/2015	8:45	1	90	90	Tree related-tree contact	Tree	Trim		V
5106899	R68900	08/14/2015	7:58	08/14/2015	9:55	1	116	116	Animal related	Fuse	Replace - Same Size		I
5106901	M21134	08/14/2015	8:01	08/14/2015	9:23	1	81	81	Animal related	Transformer Fuse	Replace - Same Size		VI
5106905	U19534	08/14/2015	8:01	08/14/2015	10:05	18	2219	123	Underground equipment	Underground Primary	Switch/Reset	Repair	II
5106909	D28123	08/14/2015	8:08	08/14/2015	15:12	7	2968	424	Underground equipment	Underground Primary	Repair		I
5106911	X39530	08/14/2015	8:11	08/14/2015	9:42	1	90	90	Animal related	Transformer Fuse	Replace - Same Size		IV
5106913	U19534	08/14/2015	8:14	08/14/2015	10:15	1	120	120	Underground equipment				II
5106917	301052	08/14/2015	8:17	08/14/2015	10:00	1	102	102	Overhead equipment	Fuse	Replace - Same Size		VI
5106921	M40132	08/14/2015	8:28	08/14/2015	9:20	1	51	51	Overhead equipment	Overhead Service			I
5106925	X81555	08/14/2015	8:39	08/14/2015	11:20	1	160	160	Overhead equipment	Overhead Transformer	Replace - Same Size	Replace - Same Size	IV
5106953	R39934	08/14/2015	9:01	08/14/2015	11:50	1	168	168	Overhead equipment	Disconnect Switch	Repair	Repair	VI
5106965	J85161	08/14/2015	9:20	08/14/2015	10:10	1	49	49	Animal related	Transformer Fuse			VI
5106969	Q18244	08/14/2015	9:30	08/14/2015	10:10	6	239	39	Underground equipment				VI
5106987	P47124	08/14/2015	10:32	08/14/2015	12:33	1	120	120	Overhead equipment	Other			I
5107013	K36151	08/14/2015	11:29	08/14/2015	12:03	1	33	33	Overhead equipment	Other			III
5107023	K65220	08/14/2015	11:41	08/14/2015	11:43	1	2	2	Unknown				III
5107077	K76546	08/14/2015	13:48	08/14/2015	14:57	1	68	68	Underground equipment	Underground Primary	Repair	Repair	IV
5107103	P09305	08/14/2015	14:32	08/14/2015	17:58	1	205	205	Overhead equipment	Overhead Secondary	Patrol/Test/Inspect	Replace - Same Size	V
5107147	K30205	08/14/2015	15:02	08/14/2015	15:56	37	1986	53	Overhead equipment	Overhead Primary	Replace - Same Size		III
5107149	K30205	08/14/2015	15:02	08/14/2015	15:56	22	1181	53	Overhead equipment	Overhead Primary	Replace - Same Size		III
5107143	K30205	08/14/2015	15:02	08/14/2015	15:35	163	5423	33	Overhead equipment	Overhead Primary	Replace - Same Size		III
5107127	K76546	08/14/2015	15:07	08/17/2015	12:15	1	4148	4148	Underground equipment				IV
5107151	311002	08/14/2015	15:38	08/14/2015	17:03	1	84	84	Tree related-tree broken	Overhead Service	Repair		VI
5107153	L86175	08/14/2015	15:39	08/14/2015	18:30	1	170	170	Overhead equipment	Overhead Transformer	Replace - Same Size		IV
5107233	X19561	08/14/2015	17:02	08/14/2015	19:31	276	40936	148	Overhead equipment	Disconnect Switch	Repair		IV

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5107303	X19561	08/14/2015	17:02	08/14/2015	19:44	1	161	161	Overhead equipment				IV
5107307	X19561	08/14/2015	17:04	08/14/2015	19:44	1	159	159	Overhead equipment				IV
5107309	X19561	08/14/2015	17:12	08/14/2015	19:44	7	1062	151	Overhead equipment				IV
5107313	X19561	08/14/2015	17:15	08/14/2015	19:41	1	145	145	Overhead equipment				IV
5107305	X19561	08/14/2015	17:16	08/14/2015	19:44	2	294	147	Overhead equipment				IV
5107311	X19561	08/14/2015	17:28	08/14/2015	20:05	3	468	156	Overhead equipment				IV
5107301	X19561	08/14/2015	17:44	08/14/2015	19:30	1	105	105	Overhead equipment				IV
5107227	B44001	08/14/2015	17:45	08/14/2015	20:23	1	157	157	Overhead equipment	Meter			I
5107283	S36570	08/14/2015	18:00	08/14/2015	19:38	161	15681	97	Tree related-tree broken	Overhead Primary	Patrol/Test/Inspect	Repair	VI
5107251	B46002	08/14/2015	18:15	08/14/2015	19:13	15	867	57	Overhead equipment	Fuse	Replace - Same Size		I
5107257	B46002	08/14/2015	18:16	08/14/2015	19:14	21	1216	57	Overhead equipment	Fuse	Replace - Same Size		I
5107273	V92542	08/14/2015	18:34	08/14/2015	20:40	5	627	125	Overhead equipment	Overhead Primary	Repair	Patrol/Test/Inspect	II
5107275	L82187	08/14/2015	18:35	08/14/2015	19:44	1	68	68	Animal related	Transformer Fuse	Replace - Same Size		IV
5107279	HB5890	08/14/2015	18:44	08/14/2015	21:20	13	2016	155	Tree related-tree broken	Overhead Transformer	Repair	Replace - Same Size	I
5107333	HB5890	08/14/2015	18:49	08/15/2015	0:40	5	1753	350	Overhead equipment	Overhead Transformer	Repair	Replace - Same Size	I
5107291	302003	08/14/2015	19:10	08/14/2015	20:28	1	77	77	Public	Meter	Replace - Same Size		VI
5107293	Q74150	08/14/2015	19:15	08/14/2015	20:13	1	57	57	Public				IV
5107295	S36570	08/14/2015	19:29	08/14/2015	23:02	1	213	213	Overhead equipment				VI
5107323	A45002	08/14/2015	20:26	08/14/2015	21:24	1	57	57	Overhead equipment	Disconnect Switch	Replace - Same Size		I
5107325	P77237	08/14/2015	20:42	08/14/2015	22:10	1	88	87	Overhead equipment	Fuse	Replace - Same Size		VI
5107335	M09175	08/14/2015	21:43	08/14/2015	23:11	7	615	87	Animal related	Fuse	Replace - Same Size		VI
5107339	Q91175	08/14/2015	23:14	08/15/2015	3:10	1	235	235	Overhead equipment	Overhead Transformer	Replace - Same Size	Reconnect	I
5107341	U06524	08/14/2015	23:21	08/15/2015	9:33	35	21410	611	Overhead equipment	Fuse	Replace - Same Size		II
5107345	Y98532	08/15/2015	0:52	08/15/2015	8:25	1	452	452	Underground equipment	Fuse	Patrol/Test/Inspect	Replace - Same Size	IV
5107347	D96002	08/15/2015	1:25	08/15/2015	7:24	1	358	358	Underground equipment	Fuse	Replace - Same Size	Replace - Same Size	I
5107349	P83710	08/15/2015	1:50	08/15/2015	3:44	1	113	113	Weather	Fuse	Repair	Repair	I
5107357	A91004	08/15/2015	2:22	08/15/2015	4:22	40	4792	119	Animal related	Fuse	Repair	Replace - Same Size	I
5107361	U19534	08/15/2015	4:47	08/15/2015	10:13	17	3871	325	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	II
5107367	R07382	08/15/2015	6:04	08/15/2015	7:12	1	67	67	Public				I
5107371	Q83168	08/15/2015	6:50	08/15/2015	8:00	1	69	69	Overhead equipment	Fuse	Repair	Replace - Same Size	VI
5107421	K52400	08/15/2015	6:50	08/15/2015	15:23	810	122638	512	Overhead equipment	Overhead Primary			V
5107375	R09226	08/15/2015	6:51	08/15/2015	8:32	16	1601	100	Underground equipment	Underground Primary		Repair	III
5107423	K52421	08/15/2015	6:58	08/15/2015	8:27	2	176	88	Overhead equipment	Bracket	Repair		V
5107429	Y63527	08/15/2015	7:10	08/15/2015	8:17	7	464	66	Animal related	Transformer Fuse	Replace - Same Size		IV
5107433	K52421	08/15/2015	7:25	08/15/2015	8:28	1	62	62	Overhead equipment				V
5107435	P42230	08/15/2015	7:33	08/15/2015	14:10	27	10719	397	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	VI
5107439	R09226	08/15/2015	7:40	08/15/2015	8:31	11	552	50	Other	Other			III
5107455	J47178	08/15/2015	8:31	08/15/2015	10:00	5	448	89	Overhead equipment	Overhead Transformer			III
5107457	T12528	08/15/2015	8:55	08/15/2015	13:00	1	244	244	Public	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	VI
5107461	301053	08/15/2015	9:03	08/15/2015	14:46	1	342	342	Overhead equipment	Fuse	Replace - Same Size		VI
5107465	R24832	08/15/2015	9:14	08/15/2015	12:45	10	2103	210	Animal related	Fuse	Replace - Same Size	Replace - Same Size	V
5107467	X57003	08/15/2015	9:27	08/15/2015	11:10	2	204	102	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
5107477	P52306	08/15/2015	9:40	08/15/2015	10:45	1	64	64	Tree related-tree broken	Overhead Service	Cut in Clear		IV
5107531	J74-UNIT-1	08/15/2015	9:51	08/15/2015	13:38	488	110912	227	Overhead equipment	Recloser	Replace - Same Size		VI
5107495	Q01282	08/15/2015	9:56	08/15/2015	13:02	33	6110	185	Underground equipment	Underground Primary			III
5107545	B80003	08/15/2015	10:50	08/15/2015	16:25	1	334	334	Underground equipment	Underground Primary	Repair		I
5107543	B81001	08/15/2015	10:50	08/15/2015	12:17	1	86	86	Animal related	Transformer Fuse	Replace - Same Size		I
5107559	A91002	08/15/2015	11:08	08/15/2015	15:31	862	104320	262	Public	Pole	Replace - Same Size	Repair	I
5107569	D28124	08/15/2015	11:31	08/15/2015	14:26	1	174	174	Unknown	Lightning Arrestor	Replace - Same Size		I
5107579	S20554	08/15/2015	11:34	08/15/2015	17:38	19	6915	363	Underground equipment	Underground Primary	Patrol/Test/Inspect		VI
5107577	V20502	08/15/2015	11:44	08/15/2015	15:17	1	212	212	Animal related	Transformer Fuse	Replace - Same Size		II
5107583	329144	08/15/2015	11:51	08/15/2015	12:27	6	214	35	Overhead equipment	Fuse	Replace - Same Size		V
5107587	329144	08/15/2015	12:07	08/15/2015	12:29	1	21	21	Overhead equipment	Fuse	Replace - Same Size		V
5107593	327154	08/15/2015	12:18	08/15/2015	13:04	1	45	45	Tree related-tree contact	Customer Equipment	Advise Customer		V
5107627	U09517	08/15/2015	14:24	08/15/2015	19:13	1	288	288	Animal related	Fuse	Replace - Same Size		II
5107629	J06168	08/15/2015	14:30	08/15/2015	18:00	1	209	209	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	I

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5107631	B84002	08/15/2015	14:40	08/15/2015	15:54	1	73	73	Tree related-tree broken	Overhead Secondary	Repair		I
5107639	N22295	08/15/2015	14:58	08/15/2015	17:05	1	126	126	Weather	Transformer Fuse			VI
5107641	D55002	08/15/2015	15:13	08/15/2015	16:23	1	69	69	Overhead equipment	Connector	Replace - Same Size	Replace - Same Size	I
5107645	D69002	08/15/2015	15:44	08/15/2015	17:06	453	37123	81	Underground equipment	Underground Primary		Repair	I
5107651	N74230	08/15/2015	16:14	08/15/2015	17:08	6	318	53	Overhead equipment	Transformer Fuse	Replace - Same Size		I
5107653	HD0573	08/15/2015	16:15	08/15/2015	22:01	18	6212	345	Underground equipment	Underground Primary	Repair	Repair	VI
5107655	N74230	08/15/2015	16:18	08/15/2015	17:00	13	544	41	Overhead equipment	Transformer Fuse	Replace - Same Size		I
5107663	D48002	08/15/2015	16:32	08/15/2015	17:02	1	30	30	Underground equipment	Underground Primary			I
5107665	Q06142	08/15/2015	16:34	08/15/2015	17:45	1	70	70	Underground equipment	Underground Service	Repair		IV
5107669	V44504	08/15/2015	17:01	08/15/2015	19:22	424	4934	141	Public				II
5107671	V44504	08/15/2015	17:01	08/15/2015	19:22	325	24515	141	Public	Pole	Repair	Replace - Same Size	II
5107677	V44504	08/15/2015	17:10	08/15/2015	19:22	353	19796	132	Public	Pole	Repair	Replace - Same Size	II
5107687	V44504	08/15/2015	17:15	08/15/2015	17:49	8	267	33	Overhead equipment	Pole	Repair	Replace - Same Size	II
5107689	X86543	08/15/2015	17:19	08/15/2015	18:40	1	80	80	Weather	Fuse		Replace - Same Size	IV
5107693	V44504	08/15/2015	17:36	08/15/2015	19:22	85	9031	106	Overhead equipment	Pole	Repair	Replace - Same Size	II
5107695	V44504	08/15/2015	17:40	08/15/2015	17:52	454	5348	11	Public	Pole	Repair		II
5107697	V44504	08/15/2015	17:52	08/15/2015	17:55	1	2	2	Overhead equipment	Pole	Switch/Reset		II
5107699	V44504	08/15/2015	17:53	08/15/2015	18:00	1	6	6	Overhead equipment	Pole	Switch/Reset		II
5107701	B57002	08/15/2015	17:53	08/15/2015	19:08	1	74	74	Other				I
5107703	U84534	08/15/2015	17:56	08/15/2015	20:00	1	123	123	Animal related	Transformer Fuse	Replace - Same Size		II
5107705	R60551	08/15/2015	17:57	08/15/2015	19:45	1	107	107	Overhead equipment	Transformer Fuse	Repair		IV
5107711	U44001	08/15/2015	18:03	08/15/2015	20:55	8	1376	172	Overhead equipment	Transformer Fuse	Replace - New Size	Replace - New Size	II
5107713	J33803	08/15/2015	18:04	08/15/2015	19:00	58	3191	55	Overhead equipment	Overhead Primary			V
5107721	J33803	08/15/2015	18:08	08/15/2015	19:25	1	76	76	Overhead equipment				V
5107723	X66581	08/15/2015	18:12	08/15/2015	19:29	8	622	77	Animal related	Fuse	Replace - Same Size		IV
5107725	X86543	08/15/2015	18:13	08/15/2015	18:51	1	37	37	Weather	Transformer Fuse		Replace - Same Size	IV
5107729	P77237	08/15/2015	18:14	08/15/2015	19:52	1	97	97	Overhead equipment	Fuse	Replace - Same Size		VI
5107747	S27599	08/15/2015	18:51	08/15/2015	22:14	42	8518	202	Unknown				VI
5107743	S27599	08/15/2015	19:00	08/15/2015	22:14	1	193	193	Unknown				VI
5107751	V44504	08/15/2015	19:22	08/15/2015	19:40	233	4105	17	Overhead equipment	Pole	Repair		II
5107753	J08205	08/15/2015	19:32	08/15/2015	20:45	1	72	72	Animal related	Transformer Fuse	Replace - Same Size		I
5107757	V44504	08/15/2015	19:40	08/15/2015	20:25	233	10526	45	Overhead equipment	Pole	Repair	Replace - Same Size	II
5107759	U42001	08/15/2015	19:42	08/15/2015	22:04	1	141	141	Overhead equipment	Transformer Fuse	Repair		II
5107765	S13548	08/15/2015	19:59	08/15/2015	21:00	1	60	60	Public	Meter	Disconnect		VI
5107755	M37192	08/15/2015	20:10	08/15/2015	20:59	5	248	49	Overhead equipment	Overhead Secondary	Replace - Same Size		I
5107769	Q06142	08/15/2015	20:13	08/15/2015	21:21	1	67	67	Animal related	Transformer Fuse	Replace - Same Size		IV
5107783	D69004	08/15/2015	22:23	08/16/2015	5:25	96	40562	422	Underground equipment	Underground Primary	Patrol/Test/Inspect		I
5107785	N86228	08/16/2015	1:15	08/16/2015	4:50	1	214	214	Unknown	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	VI
5107789	S64501	08/16/2015	5:50	08/16/2015	6:43	1	52	52	Overhead equipment	Fuse		Replace - Same Size	VI
5107791	U68002	08/16/2015	6:06	08/16/2015	8:24	1	137	137	Unknown	Overhead Service	Repair		II
5107793	B62004	08/16/2015	6:56	08/16/2015	9:56	1	179	179	Animal related	Fuse	Replace - Same Size		I
5107795	M45212	08/16/2015	7:00	08/16/2015	8:47	6	641	106	Underground equipment	Underground Primary			IV
5107799	Q24312	08/16/2015	7:05	08/16/2015	12:59	57	20199	354	Overhead equipment	Fuse	Replace - Same Size		VI
5107801	Q24312	08/16/2015	7:25	08/16/2015	11:51	1	265	265	Animal related	Fuse	Replace - Same Size		VI
5107803	Q85162	08/16/2015	7:30	08/16/2015	10:00	2	300	150	Underground equipment				VI
5107805	310124	08/16/2015	8:39	08/16/2015	10:02	1	82	82	Animal related	Fuse	Replace - Same Size		V
5107809	S75505	08/16/2015	8:53	08/16/2015	11:52	1	178	178	Animal related	Transformer Fuse	Repair	Replace - Same Size	VI
5107811	M21134	08/16/2015	9:06	08/16/2015	9:52	1	45	45	Overhead equipment	Fuse	Repair	Replace - Same Size	VI
5107819	V69532	08/16/2015	9:55	08/16/2015	10:44	1	48	48	Animal related	Transformer Fuse	Replace - Same Size		II
5107821	V69532	08/16/2015	9:55	08/16/2015	10:45	9	444	49	Animal related	Transformer Fuse	Replace - Same Size		II
5107823	Q85162	08/16/2015	10:02	08/16/2015	13:42	2	439	219	Underground equipment	Underground Secondary	Repair		VI
5107827	J58380	08/16/2015	10:41	08/16/2015	14:33	2	464	232	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	III
5107829	Q10702	08/16/2015	10:44	08/16/2015	11:38	1	53	53	Tree related-tree contact	Fuse	Replace - Same Size	Replace - Same Size	V
5107831	Y35515	08/16/2015	11:14	08/16/2015	12:03	7	340	48	Tree related-tree contact	Fuse	Repair	Replace - Same Size	IV
5107835	U31598	08/16/2015	11:52	08/16/2015	12:31	1	38	38	Overhead equipment	Transformer Fuse	Repair	Repair	II
5107837	U90566	08/16/2015	12:15	08/16/2015	15:37	1	201	201	Overhead equipment	Overhead Transformer	Repair	Repair	II

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5107839	P83710	08/16/2015	12:24	08/16/2015	14:00	1	95	95	Animal related	Fuse	Replace - Same Size		I
5107843	Y96564	08/16/2015	13:06	08/16/2015	14:34	1	87	87	Tree related-tree broken	Overhead Service	Remove		IV
5107845	S36570	08/16/2015	13:22	08/16/2015	15:01	1	98	98	Overhead equipment	Fuse	Repair		VI
5107849	L71171	08/16/2015	13:48	08/16/2015	16:08	1	139	139	Tree related-tree broken	Overhead Secondary			IV
5107853	M05360	08/16/2015	15:07	08/16/2015	19:00	1	232	232	Overhead equipment	Overhead Transformer	Replace - Same Size	Advise Customer	V
5107855	P77237	08/16/2015	15:41	08/16/2015	18:00	1	138	138	Overhead equipment	Transformer Fuse	Replace - Same Size		VI
5107869	L81141	08/16/2015	16:21	08/16/2015	19:13	1821	242997	172	Public	Pole	Replace - Same Size	Replace - Same Size	IV
5107941	M07235	08/16/2015	16:44	08/16/2015	18:50	1	125	125	Overhead equipment	Overhead Transformer	Repair	Replace - Same Size	III
5107973	P47123	08/16/2015	16:45	08/16/2015	18:42	1	116	116	Animal related	Underground Primary	Patrol/Test/Inspect		I
5107945	V22555	08/16/2015	16:58	08/16/2015	18:21	1	82	82	Overhead equipment	Overhead Service			II
5107963	L81141	08/16/2015	17:32	08/16/2015	17:35	1	2	2	Unknown				IV
5107967	P83710	08/16/2015	18:04	08/16/2015	20:00	1	115	115	Overhead equipment	Connector	Replace - Same Size		I
5107971	B46002	08/16/2015	18:13	08/16/2015	19:11	66	3824	57	Unknown	Fuse	Repair		I
5107979	B46002	08/16/2015	18:31	08/16/2015	19:15	1	43	43	Overhead equipment	Fuse	Repair		I
5107987	B46002	08/16/2015	19:20	08/16/2015	19:54	66	2228	33	Overhead equipment	Fuse	Repair		I
5107993	B46002	08/16/2015	19:29	08/16/2015	19:50	1	20	20	Overhead equipment	Fuse	Repair		I
5107995	U84587	08/16/2015	19:33	08/16/2015	20:29	4	221	55	Overhead equipment	Fuse	Replace - Same Size		II
5108001	N50331	08/16/2015	20:22	08/16/2015	22:00	1	97	97	Animal related	Transformer Fuse	Replace - Same Size		II
5108005	J63171	08/16/2015	21:16	08/17/2015	2:10	7	2056	293	Underground equipment	Underground Secondary	Repair		III
5108009	J84123	08/16/2015	21:30	08/16/2015	23:30	1	119	119	Tree related-tree contact	Transformer Fuse	Replace - Same Size		VI
5108013	B57001	08/16/2015	21:56	08/16/2015	22:07	1	10	10	Overhead equipment	Overhead Transformer	Reconnect		I
5108017	D72001	08/16/2015	22:36	08/16/2015	23:50	1	73	73	Overhead equipment	Overhead Service	Repair		I
5108023	L81142	08/17/2015	1:10	08/17/2015	3:53	80	12981	162	Overhead equipment	Overhead Primary	Repair		IV
5108033	A45001	08/17/2015	2:27	08/17/2015	3:41	19	1409	74	Other	Fuse	Replace - Same Size		I
5108045	B38001	08/17/2015	5:50	08/17/2015	6:50	3	177	59	Unknown	Fuse	Replace - Same Size		I
5108047	B58002	08/17/2015	5:55	08/17/2015	7:00	1	64	64	Animal related	Fuse	Replace - Same Size		I
5108051	335002	08/17/2015	7:02	08/17/2015	8:33	5	450	90	Overhead equipment	Fuse	Replace - Same Size		VI
5108055	335002	08/17/2015	7:07	08/17/2015	8:33	9	772	85	Overhead equipment	Fuse	Replace - Same Size		VI
5108061	K08909	08/17/2015	7:41	08/17/2015	8:05	1	23	23	Animal related	Transformer Fuse	Replace - Same Size		VI
5108071	N93260	08/17/2015	8:07	08/17/2015	9:26	5	392	78	Animal related	Fuse			III
5108077	V39003	08/17/2015	8:19	08/17/2015	9:28	1	68	68	Tree related-tree broken	Overhead Service	Repair		II
5108081	D96002	08/17/2015	8:21	08/17/2015	11:23	1	182	182	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
5108085	N44216	08/17/2015	8:24	08/17/2015	8:35	1	10	10	Unknown	Fuse			III
5108087	U84534	08/17/2015	8:25	08/17/2015	9:12	1	46	46	Animal related	Transformer Fuse			II
5108095	D16003	08/17/2015	8:39	08/17/2015	10:29	31	3396	109	Overhead equipment	Crossarm	Patrol/Test/Inspect	Repair	I
5108165	D16003	08/17/2015	8:42	08/17/2015	11:03	18	2533	140	Overhead equipment	Overhead Primary	Repair	Repair	I
5108115	S21529	08/17/2015	9:16	08/17/2015	10:14	1	57	57	Overhead equipment	Transformer Fuse	Replace - Same Size		VI
5108121	U64521	08/17/2015	9:32	08/17/2015	12:00	1	147	147	Tree related-tree broken	Overhead Service			II
5108125	J18267	08/17/2015	9:41	08/17/2015	12:14	1	152	152	Public	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
5108133	335003	08/17/2015	9:58	08/17/2015	11:00	2	122	61	Animal related	Fuse	Replace - Same Size		VI
5108141	B73002	08/17/2015	10:04	08/17/2015	12:08	1	123	123	Unknown	Transformer Fuse	Replace - Same Size		I
5108143	P49188	08/17/2015	10:15	08/17/2015	12:35	1	139	139	Underground equipment	Underground Primary			I
5108147	332004	08/17/2015	10:16	08/17/2015	11:40	9	749	83	Overhead equipment	Fuse	Replace - Same Size		VI
5108169	A73002	08/17/2015	10:34	08/17/2015	12:18	1	103	103	Unknown	Fuse	Replace - Same Size		I
5108177	E10002	08/17/2015	10:40	08/17/2015	11:59	1	78	78	Other	Other	Patrol/Test/Inspect	Patrol/Test/Inspect	III
5108183	Y35003	08/17/2015	10:52	08/17/2015	12:02	1	69	69	Overhead equipment	Overhead Service			IV
5108185	Y35001	08/17/2015	10:54	08/17/2015	13:00	1	125	125	Tree related-tree broken	Overhead Service	Repair	Replace - Same Size	IV
5108219	V01002	08/17/2015	12:27	08/17/2015	13:27	1	59	59	Animal related	Transformer Fuse	Replace - Same Size		II
5108249	K30204	08/17/2015	13:05	08/17/2015	14:39	1	93	93	Weather	Fuse	Replace - Same Size		III
5108263	K30204	08/17/2015	13:13	08/17/2015	14:39	1	86	86	Weather	Fuse	Replace - Same Size		III
5108277	S78551	08/17/2015	13:33	08/17/2015	15:23	2	219	109	Animal related	Transformer Fuse			VI
5108401	R39934	08/17/2015	13:44	08/17/2015	16:00	1	135	135	Animal related	Fuse	Replace - Same Size		VI
5108287	V23003	08/17/2015	13:46	08/17/2015	14:53	1	66	66	Other				II
5108291	D28124	08/17/2015	13:50	08/17/2015	15:08	1	77	77	Tree related-tree contact	Overhead Service	Repair		I
5108407	H01190	08/17/2015	14:05	08/17/2015	15:29	1	83	83	Tree related-tree contact	Fuse	Replace - Same Size		III
5108411	H01190	08/17/2015	14:14	08/17/2015	15:30	17	1280	75	Tree related-tree broken	Overhead Primary			III

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5108333	L16213	08/17/2015	14:19	08/17/2015	17:15	7	1225	175	Public	Overhead Service	Repair		III
5108351	L24121	08/17/2015	14:37	08/17/2015	15:54	275	20990	76	Tree related-tree broken	Tree			III
5108365	L11242	08/17/2015	14:43	08/17/2015	16:39	4	463	115	Tree related-tree contact	Overhead Service	Raise		III
5108369	R16511	08/17/2015	14:45	08/17/2015	18:25	1	219	219	Overhead equipment	Overhead Primary	Replace - Same Size		I
5108449	R16511	08/17/2015	14:53	08/17/2015	18:25	9	1216	211	Overhead equipment	Overhead Primary	Replace - Same Size		I
5108379	334003	08/17/2015	14:58	08/17/2015	16:38	1	99	99	Overhead equipment	Overhead Transformer	Switch/Reset		VI
5108381	J12166	08/17/2015	15:00	08/17/2015	17:00	7	835	119	Tree related-tree contact	Overhead Secondary	Remove		III
5108389	R07382	08/17/2015	15:02	08/17/2015	16:30	62	5454	87	Tree related-tree broken	Overhead Primary	Repair	Repair	I
5108403	S79510	08/17/2015	15:26	08/17/2015	17:38	1	131	131	Overhead equipment	Transformer Fuse	Repair	Replace - Same Size	VI
5108405	R95520	08/17/2015	15:28	08/17/2015	18:55	20	4133	206	Tree related-tree contact	Fuse	Patrol/Test/Inspect		I
5108417	X36001	08/17/2015	15:39	08/17/2015	16:33	1	53	53	Overhead equipment	Overhead Service	Repair	Advise Customer	IV
5108423	P83705	08/17/2015	15:46	08/17/2015	21:40	1	353	353	Weather	Overhead Transformer	Patrol/Test/Inspect	Repair	I
5108439	J71128	08/17/2015	16:23	08/17/2015	17:08	1	44	44	Overhead equipment	Fuse	Repair		I
5108447	L00133	08/17/2015	16:34	08/17/2015	17:48	1	73	73	Animal related	Fuse	Replace - Same Size		III
5108453	K94224	08/17/2015	16:40	08/17/2015	18:00	1	79	79	Tree related-tree broken	Overhead Service	Repair		III
5108461	J71128	08/17/2015	16:46	08/17/2015	17:08	1	21	21	Overhead equipment	Fuse	Repair		I
5108469	G30001	08/17/2015	17:01	08/17/2015	22:08	2	613	306	Underground equipment	Underground Primary	Replace - Same Size		III
5108471	P52301	08/17/2015	17:03	08/17/2015	22:14	3	933	311	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	IV
5108475	A91002	08/17/2015	17:52	08/17/2015	20:02	1	129	129	Overhead equipment	Overhead Service	Repair		I
5108479	J05138	08/17/2015	17:56	08/17/2015	22:50	6	1758	293	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - New Size	I
5108481	D96002	08/17/2015	18:03	08/17/2015	23:22	1	318	318	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
5108487	Y20002	08/17/2015	18:16	08/17/2015	21:00	1	163	163	Tree related-tree broken	Overhead Secondary	Repair		IV
5108491	R01153	08/17/2015	18:18	08/17/2015	18:29	4	43	10	Overhead equipment	Lightning Arrestor	Replace - Same Size		III
5108517	R84148	08/17/2015	18:22	08/17/2015	19:13	118	6012	50	Weather	Recloser	Switch/Reset		I
5108503	V92542	08/17/2015	18:28	08/17/2015	20:10	20	2025	101	Tree related-tree broken	Fuse	Replace - Same Size	Replace - Same Size	II
5108515	R84148	08/17/2015	18:39	08/17/2015	19:16	1	36	36	Weather				I
5108529	J06168	08/17/2015	18:43	08/17/2015	23:46	1	302	302	Weather	Transformer Fuse	Replace - Same Size		I
5108535	J01118	08/17/2015	18:51	08/17/2015	22:08	15	2949	196	Tree related-tree contact	Fuse	Replace - Same Size	Replace - Same Size	I
5108537	J07173	08/17/2015	19:00	08/18/2015	0:02	1	301	301	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect		I
5108541	J06168	08/17/2015	19:02	08/18/2015	3:13	1	490	490	Weather	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	I
5108545	J07135	08/17/2015	19:06	08/18/2015	3:30	1	503	503	Weather				I
5108567	X86543	08/17/2015	19:19	08/17/2015	23:17	1	237	237	Weather	Overhead Transformer		Replace - Same Size	IV
5108569	K31120	08/17/2015	19:20	08/17/2015	20:20	1	59	59	Weather	Fuse	Repair	Repair	I
5108605	M45212	08/17/2015	19:26	08/17/2015	23:00	1	213	213	Overhead equipment	Overhead Transformer	Replace - Same Size		IV
5108577	B21004	08/17/2015	19:27	08/17/2015	22:40	108	20802	192	Weather	Fuse	Replace - Same Size		I
5108579	B21004	08/17/2015	19:36	08/17/2015	22:46	1	189	189	Underground equipment	Underground Primary	Switch/Reset		I
5108589	G50002	08/17/2015	19:53	08/17/2015	21:38	1	104	104	Overhead equipment	Overhead Service	Repair		IV
5108595	N60181	08/17/2015	20:13	08/17/2015	22:16	6	736	122	Weather	Fuse	Replace - Same Size		I
5108603	N60181	08/17/2015	20:15	08/17/2015	22:11	51	5904	115	Weather	Fuse	Replace - Same Size		I
5108599	K30204	08/17/2015	20:20	08/17/2015	22:58	13	2048	157	Weather	Fuse	Replace - Same Size		III
5108611	HB6251	08/17/2015	20:46	08/17/2015	22:01	1	74	74	Overhead equipment	Transformer Fuse	Replace - Same Size		VI
5108613	B61001	08/17/2015	20:48	08/17/2015	22:02	1	73	73	Weather	Fuse	Replace - Same Size		I
5108625	D69004	08/17/2015	21:07	08/18/2015	8:09	71	25645	662	Underground equipment	Underground Primary		Repair	I
5108645	D28124	08/17/2015	21:16	08/17/2015	22:30	1	73	73	Weather	Fuse	Replace - Same Size		I
5108637	P26283	08/17/2015	21:23	08/18/2015	3:35	1	371	371	Weather	Pole	Patrol/Test/Inspect	Repair	I
5108639	N93260	08/17/2015	21:28	08/17/2015	22:03	1	34	34	Overhead equipment	Fuse			III
5108647	D28124	08/17/2015	21:43	08/18/2015	2:34	1	290	290	Weather	Underground Transformer	Patrol/Test/Inspect	Repair	I
5108641	N60181	08/17/2015	21:50	08/17/2015	22:15	1	25	25	Weather				I
5108643	C21001	08/17/2015	22:07	08/18/2015	5:24	1	436	436	Overhead equipment	Disconnect Switch	Replace - Same Size		III
5108651	C65001	08/17/2015	22:19	08/18/2015	3:12	31	6611	292	Weather	Underground Primary	Switch/Reset	Repair	III
5108657	B21004	08/17/2015	22:46	08/18/2015	3:45	33	9874	299	Underground equipment	Underground Primary	Repair	Repair	I
5108659	R33126	08/17/2015	23:23	08/18/2015	2:52	15	3123	208	Weather	Fuse	Replace - Same Size		I
5108673	B21001	08/17/2015	23:42	08/18/2015	4:19	5	1381	276	Overhead equipment	Disconnect Switch	Replace - Same Size	Replace - Same Size	I
5108663	Q32170	08/17/2015	23:57	08/18/2015	3:30	1	212	212	Weather				I
5108667	A97006	08/18/2015	0:13	08/18/2015	3:37	1	203	203	Weather	Fuse	Replace - Same Size	Repair	I
5108669	K43386	08/18/2015	0:45	08/18/2015	2:16	1	90	90	Overhead equipment	Connector	Repair		V

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5108671	Q93522	08/18/2015	0:51	08/18/2015	5:05	1	253	253	Weather	Fuse	Patrol/Test/Inspect		I
5108677	Q11516	08/18/2015	1:53	08/18/2015	4:15	1	141	141	Tree related-tree broken	Overhead Service	Repair	Repair	I
5108681	N18211	08/18/2015	2:39	08/18/2015	5:31	1	171	171	Weather	Fuse	Replace - Same Size		III
5108683	N18211	08/18/2015	2:42	08/18/2015	4:53	9	1172	130	Weather	Fuse	Replace - Same Size		III
5108685	B19002	08/18/2015	2:50	08/18/2015	4:34	1	103	103	Overhead equipment	Fuse		Replace - Same Size	I
5108693	B68004	08/18/2015	3:41	08/18/2015	4:35	1	53	53	Animal related	Transformer Fuse	Replace - Same Size		III
5108695	N18211	08/18/2015	3:45	08/18/2015	5:20	1	94	94	Weather	Fuse	Replace - Same Size		III
5108699	R49275	08/18/2015	4:25	08/19/2015	20:16	10	23909	2391	Public	Pole	Patrol/Test/Inspect	Replace - Same Size	VI
5108703	D89002	08/18/2015	4:25	08/18/2015	6:09	22	1831	104	Underground equipment	Underground Primary	Switch/Reset	Repair	I
5108705	N44216	08/18/2015	4:52	08/18/2015	6:11	1	78	78	Overhead equipment	Fuse	Repair	Repair	III
5108711	N44216	08/18/2015	5:20	08/18/2015	6:12	1	51	51	Overhead equipment	Fuse	Repair	Repair	III
5108715	R50910	08/18/2015	5:51	08/18/2015	7:26	41	3914	95	Overhead equipment	Pole		Replace - Same Size	I
5108717	S34528	08/18/2015	6:23	08/19/2015	13:57	20	7387	1894	Public	Pole	Repair		VI
5108719	R33127	08/18/2015	6:25	08/18/2015	12:00	1	334	334	Weather	Overhead Transformer	Replace - Same Size	Patrol/Test/Inspect	I
5108725	D69004	08/18/2015	6:51	08/18/2015	7:10	1	18	18	Underground equipment	Underground Primary	Repair		I
5108729	A91002	08/18/2015	6:57	08/18/2015	7:57	1	59	59	Weather	Fuse	Replace - Same Size		I
5108731	Q01282	08/18/2015	7:01	08/18/2015	8:19	50	3877	77	Animal related	Fuse	Repair	Repair	III
5108735	P18103	08/18/2015	7:12	08/18/2015	8:13	1	60	60	Weather	Transformer Fuse		Replace - Same Size	IV
5108737	R50910	08/18/2015	7:15	08/18/2015	10:34	1	199	199	Overhead equipment	Pole	Repair		I
5108745	R50910	08/18/2015	7:27	08/18/2015	7:59	41	1306	31	Tree related-tree contact	Pole	Repair		I
5108747	X72536	08/18/2015	7:27	08/18/2015	7:46	1	18	18	Weather	Fuse	Replace - Same Size		IV
5108751	P77233	08/18/2015	7:52	08/18/2015	9:18	1	85	85	Animal related	Fuse	Replace - Same Size		VI
5108753	Z04520	08/18/2015	7:55	08/18/2015	11:45	1	229	229	Animal related	Overhead Transformer	Replace - Same Size	Replace - Same Size	IV
5108757	V40549	08/18/2015	8:00	08/18/2015	10:05	1	124	124	Tree related-tree broken	Overhead Service	Repair		II
5108763	S47576	08/18/2015	8:04	08/18/2015	9:50	1	105	105	Overhead equipment	Overhead Service	Replace - Same Size		VI
5108767	S09520	08/18/2015	8:08	08/18/2015	10:00	1	111	111	Animal related	Transformer Fuse			VI
5108771	J01118	08/18/2015	8:12	08/18/2015	9:03	7	356	50	Animal related	Fuse	Replace - Same Size	Replace - Same Size	I
5108779	C65001	08/18/2015	8:29	08/18/2015	8:38	1	8	8	Underground equipment				III
5108805	L68112	08/18/2015	9:08	08/18/2015	10:21	1	72	72	Tree related-tree broken				IV
5108809	K58213	08/18/2015	9:13	08/18/2015	11:07	1	113	113	Overhead equipment	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
5108811	R66470	08/18/2015	9:14	08/18/2015	10:22	1	67	67	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
5108815	N58144	08/18/2015	9:25	08/18/2015	11:11	1	105	105	Animal related	Transformer Fuse	Replace - Same Size		I
5108817	E10002	08/18/2015	9:26	08/18/2015	10:23	1	56	56	Other	Other	Patrol/Test/Inspect	Patrol/Test/Inspect	III
5108867	X16511	08/18/2015	9:58	08/18/2015	13:11	86	16548	192	Public	Overhead Primary	Repair		IV
5108851	D35003	08/18/2015	10:09	08/18/2015	11:30	1	80	80	Unknown	Fuse	Repair		I
5108855	S47585	08/18/2015	10:15	08/18/2015	11:08	1	52	52	Overhead equipment	Transformer Fuse	Patrol/Test/Inspect	Replace - New Size	VI
5108879	M22812	08/18/2015	10:35	08/18/2015	13:09	1	153	153	Public	Overhead Service	Repair		V
5108883	D67001	08/18/2015	10:38	08/18/2015	13:07	10	1487	148	Tree related-tree broken	Overhead Primary		Repair	IV
5108891	M78324	08/18/2015	10:45	08/18/2015	14:08	4	811	202	Overhead equipment	Overhead Secondary	Repair	Repair	V
5108899	P49188	08/18/2015	10:53	08/18/2015	16:21	1	327	327	Underground equipment	Underground Service	Patrol/Test/Inspect	Repair	I
5108905	Q83171	08/18/2015	11:04	08/18/2015	15:19	10	2548	254	Underground equipment	Underground Secondary	Repair		VI
5108913	X66582	08/18/2015	11:25	08/18/2015	14:57	1	212	212	Public	Underground Primary	Repair	Repair	IV
5108919	L12125	08/18/2015	11:28	08/18/2015	12:08	1	39	39	Overhead equipment	Transformer Fuse	Repair		III
5108921	R66470	08/18/2015	11:35	08/18/2015	12:53	22	1700	77	Tree related-tree contact	Fuse	Replace - Same Size		IV
5108929	K76542	08/18/2015	12:02	08/18/2015	14:09	13	1650	126	Tree related-tree contact				IV
5108931	L74191	08/18/2015	12:06	08/18/2015	13:29	1	82	82	Tree related-tree contact	Overhead Service	Repair		IV
5108937	Y57001	08/18/2015	12:12	08/18/2015	13:45	4	371	92	Tree related-tree broken	Overhead Service	Replace - Same Size		IV
5108941	L68114	08/18/2015	12:23	08/18/2015	14:10	1	106	106	Tree related-tree contact	Overhead Service	Repair		IV
5108945	305133	08/18/2015	12:24	08/18/2015	16:04	1	219	219	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	V
5108947	N35851	08/18/2015	12:26	08/18/2015	13:12	1	45	45	Animal related	Transformer Fuse	Replace - Same Size		V
5108969	S47584	08/18/2015	13:05	08/18/2015	14:57	4	446	111	Public				VI
5108993	U04550	08/18/2015	13:35	08/18/2015	14:36	1	60	60	Overhead equipment	Transformer Fuse	Replace - New Size	Repair	II
5109007	T13581	08/18/2015	14:08	08/18/2015	15:40	1	91	91	Public	Fuse	Replace - Same Size		VI
5109017	U10547	08/18/2015	14:38	08/18/2015	15:35	1	56	56	Jurisdictional	Overhead Service	Repair	Patrol/Test/Inspect	II
5109139	Q32170	08/18/2015	14:40	08/18/2015	18:17	2	434	217	Tree related-tree broken	Overhead Primary	Replace - Same Size		I
5109023	K94224	08/18/2015	14:40	08/18/2015	15:52	1	71	71	Tree related-tree broken	Overhead Service	Repair		III

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5109095	A36001	08/18/2015	14:44	08/18/2015	16:15	6	545	90	Weather	Fuse	Repair	Repair	I
5109027	A36001	08/18/2015	14:45	08/18/2015	15:33	14	665	47	Weather	Fuse	Repair		I
5109021	Q32170	08/18/2015	14:46	08/18/2015	16:45	7	830	118	Tree related-tree broken	Overhead Primary	Replace - Same Size		I
5109035	V44511	08/18/2015	14:47	08/18/2015	18:55	1	247	247	Underground equipment	Underground Service			II
5109039	B25001	08/18/2015	14:49	08/18/2015	16:42	58	6594	113	Tree related-tree broken	Recloser	Switch/Reset		I
5109025	A36001	08/18/2015	14:49	08/18/2015	15:49	15	889	59	Weather	Fuse	Repair	Repair	I
5109055	B25001	08/18/2015	14:53	08/18/2015	17:18	1	144	144	Tree related-tree broken	Overhead Primary	Repair		I
5109059	M31201	08/18/2015	14:55	08/18/2015	16:34	1	98	98	Overhead equipment	Overhead Service	Replace - Same Size	Replace - Same Size	I
5109075	P60161	08/18/2015	15:04	08/18/2015	17:38	58	8952	154	Underground equipment	Underground Primary		Repair	VI
5109069	J76805	08/18/2015	15:07	08/18/2015	15:44	1	36	36	Overhead equipment	Overhead Transformer	Repair	Repair	V
5109073	H11340	08/18/2015	15:13	08/18/2015	19:36	7	1837	262	Weather	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	V
5109081	B77001	08/18/2015	15:25	08/18/2015	22:15	1	409	409	Tree related-tree broken	Tree			I
5109085	J80807	08/18/2015	15:28	08/18/2015	16:00	1	31	31	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	V
5109105	Y37593	08/18/2015	15:52	08/18/2015	17:00	25	1698	67	Tree related-tree contact	Fuse	Replace - Same Size		IV
5109109	V25504	08/18/2015	15:53	08/18/2015	19:11	3	591	197	Unknown	Fuse			II
5109113	V25504	08/18/2015	15:55	08/18/2015	19:00	1	184	184	Weather	Fuse			II
5109117	V44504	08/18/2015	16:01	08/18/2015	16:23	1	21	21	Weather	Transformer Fuse	Replace - Same Size		II
5109119	B25001	08/18/2015	16:01	08/18/2015	17:22	3	240	80	Tree related-tree broken	Overhead Primary	Repair		I
5109125	339159	08/18/2015	16:09	08/18/2015	17:41	1	91	91	Tree related-tree broken	Overhead Service	Repair	Repair	V
5109127	J76805	08/18/2015	16:09	08/18/2015	19:00	1	170	170	Overhead equipment	Overhead Transformer	Replace - Same Size	Replace - Same Size	V
5109129	L43154	08/18/2015	16:10	08/18/2015	18:00	1	109	109	Overhead equipment	Overhead Service	Repair	Replace - Same Size	I
5109131	312112	08/18/2015	16:12	08/18/2015	20:15	1	242	242	Overhead equipment	Transformer Fuse	Replace - Same Size		V
5109133	V25504	08/18/2015	16:13	08/18/2015	19:11	1	177	177	Unknown	Fuse			II
5109135	J80807	08/18/2015	16:13	08/18/2015	16:25	1	11	11	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	V
5109137	339159	08/18/2015	16:19	08/18/2015	17:05	9	407	45	Tree related-tree broken	Overhead Transformer	Repair		V
5109447	374052	08/18/2015	16:23	08/18/2015	17:59	24	2322	96	Weather	Substation Misc.	Repair	Replace - Same Size	VI
5109289	303002	08/18/2015	16:25	08/18/2015	17:11	186	8652	46	Weather	Overhead Primary	Replace - Same Size	Replace - Same Size	VI
5109147	V24583	08/18/2015	16:26	08/18/2015	17:42	7	531	75	Weather	Fuse	Repair	Replace - Same Size	II
5109369	308001	08/18/2015	16:27	08/18/2015	17:42	145	10860	74	Weather				VI
5109153	308003	08/18/2015	16:28	08/18/2015	23:30	1	421	421	Tree related-tree broken	Overhead Service	Advise Customer	Repair	VI
5109159	346003	08/18/2015	16:30	08/18/2015	22:30	4	1438	359	Overhead equipment	Overhead Transformer	Repair	Repair	VI
5110099	P09307	08/18/2015	16:30	08/19/2015	1:49	100	55828	558	Overhead equipment	Overhead Primary		Repair	V
5109165	341002	08/18/2015	16:32	08/18/2015	23:22	1	409	409	Tree related-tree contact	Overhead Secondary	Patrol/Test/Inspect	Repair	VI
5109167	J76804	08/18/2015	16:32	08/18/2015	20:38	1	245	245	Overhead equipment	Overhead Service	Repair	Repair	V
5109173	A81004	08/18/2015	16:34	08/18/2015	17:30	1	55	55	Overhead equipment	Fuse	Patrol/Test/Inspect	Repair	I
5109181	303006	08/18/2015	16:36	08/18/2015	22:00	4	1295	323	Overhead equipment	Overhead Transformer	Switch/Reset		VI
5109183	342001	08/18/2015	16:38	08/18/2015	21:39	11	3304	300	Tree related-tree broken	Overhead Secondary	Trim		VI
5109185	338007	08/18/2015	16:38	08/18/2015	20:10	5	1056	211	Overhead equipment	Fuse	Replace - Same Size		VI
5109189	308003	08/18/2015	16:40	08/18/2015	23:30	1	409	409	Tree related-tree broken	Overhead Service	Advise Customer	Cut in Clear	VI
5109193	349001	08/18/2015	16:40	08/19/2015	0:30	6	2817	469	Overhead equipment	Tree	Advise Customer	Remove	VI
5109223	R07381	08/18/2015	16:41	08/18/2015	20:51	21	3560	249	Tree related-tree broken	Overhead Primary		Replace - Same Size	I
5109201	351002	08/18/2015	16:42	08/18/2015	21:52	13	4030	310	Tree related-tree broken	Tree	Trim		VI
5109203	Q32171	08/18/2015	16:43	08/18/2015	19:20	1	156	156	Weather	Transformer Fuse	Replace - Same Size	Repair	I
5109207	308003	08/18/2015	16:44	08/18/2015	18:00	1	75	75	Overhead equipment				VI
5109211	308003	08/18/2015	16:45	08/18/2015	23:53	1	427	427	Overhead equipment				VI
5109213	341002	08/18/2015	16:46	08/18/2015	21:35	9	2599	288	Overhead equipment	Overhead Transformer	Switch/Reset		VI
5109215	J01118	08/18/2015	16:46	08/18/2015	18:23	2	193	96	Weather	Fuse	Replace - Same Size		I
5109219	B46002	08/18/2015	16:47	08/18/2015	20:45	50	11883	237	Overhead equipment	Fuse	Replace - Same Size		I
5109221	334001	08/18/2015	16:49	08/18/2015	22:52	1	362	362	Tree related-tree broken	Overhead Service			VI
5109225	U30006	08/18/2015	16:52	08/18/2015	18:10	2	154	77	Overhead equipment	Lightning Arrestor	Repair		II
5109227	M47802	08/18/2015	16:53	08/18/2015	19:39	4	661	165	Weather	Fuse	Repair	Repair	V
5109231	308002	08/18/2015	16:56	08/18/2015	18:15	1	78	78	Overhead equipment				VI
5109241	V04552	08/18/2015	16:57	08/18/2015	19:26	1	148	148	Overhead equipment	Disconnect Switch	Replace - Same Size		II
5109245	351002	08/18/2015	16:59	08/18/2015	22:25	13	4229	325	Tree related-tree broken	Overhead Primary	Repair	Repair	VI
5109255	J80807	08/18/2015	17:02	08/18/2015	23:44	1	401	401	Overhead equipment				V
5109259	341002	08/18/2015	17:03	08/18/2015	21:35	1	271	271	Tree related-tree broken	Overhead Service	Disconnect		VI

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5109277	K30204	08/18/2015	17:03	08/18/2015	18:56	13	1460	112	Weather	Fuse	Replace - Same Size		III
5109279	U68581	08/18/2015	17:09	08/18/2015	21:00	9	2075	230	Tree related-tree broken	Overhead Primary	Raise		II
5109281	J80806	08/18/2015	17:09	08/18/2015	21:23	1	253	253	Underground equipment	Lightning Arrestor		Replace - Same Size	V
5109285	V36001	08/18/2015	17:09	08/18/2015	21:43	54	14729	273	Underground equipment	Underground Primary			II
5109287	B38001	08/18/2015	17:10	08/18/2015	18:15	1	64	64	Overhead equipment	Transformer Fuse	Replace - Same Size		I
5109297	U33586	08/18/2015	17:13	08/18/2015	19:53	1	159	159	Overhead equipment	Lightning Arrestor	Repair		II
5109323	M19222	08/18/2015	17:15	08/18/2015	18:12	109	4381	56	Overhead equipment	Fuse	Replace - Same Size		VI
5109303	U05595	08/18/2015	17:16	08/18/2015	18:25	1	68	68	Tree related-tree broken	Fuse	Replace - Same Size		II
5109371	J50185	08/18/2015	17:17	08/18/2015	17:58	9	363	40	Animal related	Fuse			III
5109311	D88001	08/18/2015	17:18	08/19/2015	4:35	1	676	676	Weather	Other			I
5109315	B38001	08/18/2015	17:18	08/19/2015	1:24	1	485	485	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect		I
5109325	341001	08/18/2015	17:21	08/19/2015	6:14	3	2316	772	Overhead equipment	Overhead Primary	Advise Customer	Repair	VI
5109327	U68581	08/18/2015	17:24	08/18/2015	21:09	1	224	224	Tree related-tree broken	Overhead Service	Raise		II
5109329	C52002	08/18/2015	17:26	08/18/2015	19:33	1	126	126	Tree related-tree broken	Overhead Service	Repair		III
5109331	308003	08/18/2015	17:27	08/18/2015	20:46	3	595	198	Overhead equipment				VI
5109333	U11531	08/18/2015	17:28	08/18/2015	20:42	1	193	193	Tree related-tree broken	Crossarm			II
5109335	P19395	08/18/2015	17:30	08/18/2015	20:56	1	205	205	Weather	Transformer Fuse	Replace - Same Size		V
5109341	D41002	08/18/2015	17:30	08/18/2015	19:15	369	38719	104	Overhead equipment	Ground Wire	Replace - Same Size		I
5109337	D41002	08/18/2015	17:30	08/18/2015	19:15	459	48162	104	Overhead equipment	Guy Wire	Replace - Same Size		I
5109339	D41002	08/18/2015	17:30	08/18/2015	19:15	382	40083	104	Overhead equipment				I
5109343	C52002	08/18/2015	17:31	08/18/2015	20:29	1	177	177	Tree related-tree broken	Overhead Service	Repair		III
5109347	B65004	08/18/2015	17:34	08/19/2015	1:38	36	17408	483	Weather	Overhead Transformer	Patrol/Test/Inspect		I
5109349	J79306	08/18/2015	17:35	08/18/2015	19:14	1	98	98	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	I
5109389	B45003	08/18/2015	17:39	08/18/2015	19:46	548	69689	127	Overhead equipment	Overhead Primary	Replace - Same Size		I
5109361	P60161	08/18/2015	17:40	08/18/2015	21:06	9	1850	205	Underground equipment	Underground Primary	Repair		VI
5109365	D32211	08/18/2015	17:41	08/18/2015	22:45	1	303	303	Overhead equipment	Overhead Primary	Replace - Same Size	Replace - Same Size	I
5109367	J80807	08/18/2015	17:41	08/18/2015	19:10	1	88	88	Weather	Fuse			V
5109383	351002	08/18/2015	17:45	08/18/2015	22:40	1	294	294	Tree related-tree broken	Overhead Primary	Repair	Repair	VI
5109737	D32211	08/18/2015	17:45	08/18/2015	22:45	14	4186	299	Tree related-tree broken	Overhead Primary	Repair		I
5109387	A17025	08/18/2015	17:46	08/18/2015	21:48	13	3143	241	Overhead equipment	Transformer Fuse	Replace - Same Size		I
5109393	U11531	08/18/2015	17:47	08/18/2015	21:25	6	1306	217	Overhead equipment	Fuse	Replace - Same Size		II
5109661	303002	08/18/2015	17:47	08/18/2015	20:15	110	16252	147	Overhead equipment	Jumper	Repair		VI
5109419	D92002	08/18/2015	17:53	08/18/2015	22:54	127	38131	300	Overhead equipment				I
5109425	D48002	08/18/2015	17:54	08/18/2015	20:04	18	2333	129	Overhead equipment	Fuse	Patrol/Test/Inspect	Repair	I
5109435	H10843	08/18/2015	17:56	08/18/2015	19:50	1	113	113	Weather	Transformer Fuse	Replace - Same Size		V
5109437	B93002	08/18/2015	17:56	08/18/2015	19:29	322	29936	92	Overhead equipment	Overhead Primary	Replace - Same Size		I
5109445	D32211	08/18/2015	17:58	08/18/2015	22:45	1	286	286	Overhead equipment	Overhead Primary	Replace - Same Size	Replace - Same Size	I
5109449	B93002	08/18/2015	17:59	08/18/2015	19:29	356	32075	90	Tree related-tree broken				I
5109457	D36003	08/18/2015	18:02	08/18/2015	20:49	2	333	166	Weather	Transformer Fuse	Replace - Same Size	Replace - Same Size	I
5109461	A50001	08/18/2015	18:03	08/19/2015	1:19	8	3486	435	Weather	Fuse	Patrol/Test/Inspect	Repair	I
5109473	A85001	08/18/2015	18:05	08/18/2015	23:58	1	352	352	Other	Fuse	Patrol/Test/Inspect	Replace - Same Size	I
5109471	D36001	08/18/2015	18:05	08/18/2015	21:34	1	208	208	Tree related-tree broken	Overhead Service	Repair		I
5109939	B93002	08/18/2015	18:08	08/18/2015	20:14	316	39910	126	Tree related-tree broken				I
5109515	N93260	08/18/2015	18:08	08/18/2015	19:39	450	40626	90	Unknown	Pole		Replace - Same Size	III
5109645	N93260	08/18/2015	18:09	08/18/2015	20:13	15	1860	124	Overhead equipment	Fuse			III
5109499	D53001	08/18/2015	18:12	08/18/2015	21:33	1	200	200	Tree related-tree broken				I
5109507	N54213	08/18/2015	18:13	08/18/2015	19:30	1	76	76	Weather	Fuse	Replace - Same Size		II
5109511	D31016	08/18/2015	18:14	08/18/2015	19:06	1	51	51	Weather	Fuse	Replace - Same Size		III
5109523	U31565	08/18/2015	18:15	08/18/2015	18:56	1	40	40	Overhead equipment	Fuse	Replace - Same Size		II
5109527	N54213	08/18/2015	18:15	08/18/2015	21:45	17	3558	209	Overhead equipment	Overhead Primary	Repair		II
5109949	B93002	08/18/2015	18:16	08/18/2015	20:28	307	40668	132	Tree related-tree broken				I
5109535	P09307	08/18/2015	18:16	08/18/2015	20:39	1	142	142	Weather				V
5109537	R10943	08/18/2015	18:16	08/18/2015	23:03	2	572	286	Overhead equipment				VI
5109951	N93260	08/18/2015	18:18	08/19/2015	1:15	3	1250	416	Tree related-tree broken				III
5109567	K95203	08/18/2015	18:20	08/18/2015	19:07	2	92	46	Weather	Overhead Transformer	Switch/Reset		III
5109605	Y45503	08/18/2015	18:22	08/18/2015	19:04	73	3046	41	Overhead equipment	Disconnect Switch	Repair	Replace - Same Size	IV

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5109581	D36003	08/18/2015	18:24	08/18/2015	21:05	1	160	160	Weather	Transformer Fuse	Replace - Same Size	Replace - Same Size	I
5109589	P09307	08/18/2015	18:25	08/18/2015	20:41	1	135	135	Weather				V
5109585	A85001	08/18/2015	18:25	08/19/2015	12:38	1	1092	1092	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
5109599	D48001	08/18/2015	18:26	08/19/2015	4:39	1	612	612	Overhead equipment	Overhead Transformer	Disconnect	Repair	I
5109627	G10002	08/18/2015	18:26	08/18/2015	22:26	53	12668	239	Overhead equipment	Fuse	Patrol/Test/Inspect	Replace - Same Size	I
5109603	N93260	08/18/2015	18:28	08/19/2015	0:36	1	367	367	Overhead equipment	Other			III
5109607	M51275	08/18/2015	18:29	08/18/2015	20:30	2	241	120	Tree related-tree contact	Fuse	Repair		III
5109625	N93260	08/18/2015	18:32	08/18/2015	21:18	21	3472	165	Overhead equipment	Fuse			III
5109619	N05172	08/18/2015	18:33	08/18/2015	20:03	1	89	89	Overhead equipment	Transformer Fuse	Repair	Replace - Same Size	I
5109617	B58002	08/18/2015	18:33	08/19/2015	0:40	9	3300	366	Overhead equipment	Fuse	Patrol/Test/Inspect	Repair	I
5109623	V25504	08/18/2015	18:34	08/18/2015	19:10	3	105	35	Overhead equipment				II
5109629	D48001	08/18/2015	18:35	08/18/2015	23:20	1	284	284	Weather	Transformer Fuse	Replace - Same Size		I
5109631	R78301	08/18/2015	18:36	08/18/2015	20:44	24	3051	127	Weather				V
5109641	D28123	08/18/2015	18:39	08/19/2015	5:11	1	631	631	Overhead equipment	Other		Repair	I
5109647	N93260	08/18/2015	18:41	08/18/2015	21:38	1	176	176	Overhead equipment	Other			III
5109649	A36002	08/18/2015	18:42	08/19/2015	3:38	3	1607	535	Overhead equipment	Fuse	Patrol/Test/Inspect	Replace - Urgent	I
5109915	R78301	08/18/2015	18:45	08/18/2015	21:46	47	8515	181	Tree related-tree broken	Tree	Trim	Trim	V
5109655	N93260	08/18/2015	18:47	08/19/2015	0:20	1	332	332	Tree related-tree contact	Overhead Service			III
5109659	N93260	08/18/2015	18:48	08/19/2015	2:14	3	1335	445	Overhead equipment	Overhead Transformer			III
5109711	R07382	08/18/2015	18:48	08/18/2015	23:59	758	130063	310	Tree related-tree broken	Overhead Primary	Switch/Reset	Switch/Reset	I
5109665	B93002	08/18/2015	18:49	08/18/2015	19:29	355	14441	40	Overhead equipment				I
5109673	M37191	08/18/2015	18:50	08/18/2015	19:57	1	66	66	Overhead equipment	Overhead Service	Repair		I
5109683	R07382	08/18/2015	18:50	08/18/2015	23:59	1288	221619	308	Tree related-tree broken	Overhead Primary	Switch/Reset	Switch/Reset	I
5109689	Q34360	08/18/2015	18:52	08/18/2015	22:26	29	6203	213	Weather	Fuse	Repair	Repair	I
5109847	P42229	08/18/2015	18:54	08/18/2015	20:20	32	2722	85	Tree related-tree broken	Fuse	Replace - Same Size		VI
5109719	K30205	08/18/2015	18:55	08/18/2015	19:36	2	81	40	Weather	Fuse	Replace - Same Size		III
5109725	B73003	08/18/2015	18:56	08/18/2015	23:24	1	267	267	Overhead equipment	Fuse	Replace - Same Size		I
5109733	B73002	08/18/2015	18:57	08/18/2015	21:37	1	159	159	Tree related-tree broken	Overhead Service	Cut in Clear		I
5109863	J20-UNIT-1	08/18/2015	19:00	08/18/2015	21:37	565	88829	157	Unknown				VI
5109755	D28123	08/18/2015	19:01	08/19/2015	5:11	1	609	609	Overhead equipment				I
5109765	HB6281	08/18/2015	19:01	08/18/2015	22:10	1	188	188	Weather	Fuse	Replace - Same Size		VI
5109783	P26284	08/18/2015	19:02	08/19/2015	2:50	1	467	467	Weather	Disconnect Switch	Repair	Repair	I
5109867	HB6283	08/18/2015	19:05	08/18/2015	20:29	172	14374	83	Tree related-tree broken	Fuse			VI
5109845	V18582	08/18/2015	19:09	08/18/2015	20:41	1	91	91	Tree related-tree broken	Overhead Service	Repair		II
5109873	M48815	08/18/2015	19:13	08/18/2015	22:05	1	171	171	Weather	Overhead Transformer	Repair	Repair	V
5109879	N93260	08/18/2015	19:13	08/18/2015	21:39	1	145	145	Overhead equipment	Other			III
5109887	Q95247	08/18/2015	19:17	08/19/2015	0:10	1	292	292	Weather	Fuse	Replace - Same Size		VI
5109891	P52301	08/18/2015	19:18	08/18/2015	23:28	3	751	250	Overhead equipment	Fuse	Patrol/Test/Inspect	Replace - Same Size	IV
5109895	Q37370	08/18/2015	19:19	08/19/2015	1:14	6	2127	354	Weather	Overhead Transformer	Repair	Repair	I
5109905	Q93522	08/18/2015	19:21	08/18/2015	23:21	28	6706	239	Overhead equipment	Recloser		Replace - Same Size	I
5109907	Y13041	08/18/2015	19:24	08/18/2015	22:46	1	201	201	Overhead equipment	Overhead Service	Repair		IV
5110145	R16511	08/18/2015	19:25	08/19/2015	1:01	9	3021	335	Overhead equipment	Fuse	Repair	Replace - Same Size	I
5109911	Q34367	08/18/2015	19:25	08/19/2015	1:30	9	3277	364	Weather	Overhead Transformer	Repair	Repair	I
5109919	B93002	08/18/2015	19:30	08/19/2015	3:04	65	29517	454	Tree related-tree broken	Overhead Primary	Switch/Reset	Repair	I
5109921	HB6283	08/18/2015	19:31	08/18/2015	19:59	8	221	27	Tree related-tree contact				VI
5109923	Q23255	08/18/2015	19:32	08/19/2015	1:10	1	338	338	Tree related-tree broken	Overhead Primary			VI
5109925	M22812	08/18/2015	19:32	08/18/2015	20:59	1	86	86	Public				V
5109935	M19222	08/18/2015	19:36	08/18/2015	21:55	1	138	138	Weather	Fuse	Replace - Same Size		VI
5109763	R07382	08/18/2015	19:40	08/19/2015	10:40	1	899	899	Tree related-tree broken	Overhead Primary	Repair	Repair	I
5109937	P83705	08/18/2015	19:41	08/19/2015	1:45	1	363	363	Overhead equipment	Overhead Transformer		Replace - Same Size	I
5109947	R49263	08/18/2015	19:45	08/18/2015	21:30	11	1144	104	Weather	Fuse	Replace - Same Size		VI
5109953	D32211	08/18/2015	19:58	08/18/2015	22:45	1	166	166	Overhead equipment	Overhead Primary	Replace - Same Size	Replace - Same Size	I
5109955	G10002	08/18/2015	19:59	08/18/2015	22:27	1	147	147	Overhead equipment	Fuse	Patrol/Test/Inspect	Replace - Same Size	I
5109957	N15850	08/18/2015	20:01	08/19/2015	4:22	43	21520	500	Tree related-tree broken	Fuse			V
5110379	B93001	08/18/2015	20:06	08/19/2015	6:10	29	17533	604	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
5109969	N86226	08/18/2015	20:11	08/19/2015	6:15	1	603	603	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	VI

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5109973	B93001	08/18/2015	20:14	08/19/2015	1:37	7	2255	322	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
5109975	303002	08/18/2015	20:15	08/18/2015	22:40	16	2320	145	Overhead equipment				VI
5109977	303002	08/18/2015	20:15	08/18/2015	20:49	14	465	33	Overhead equipment				VI
5109981	N15850	08/18/2015	20:18	08/18/2015	22:40	6	852	142	Weather	Fuse	Replace - Same Size		V
5109999	N86226	08/18/2015	20:31	08/18/2015	23:50	5	993	198	Overhead equipment				VI
5110095	D32211	08/18/2015	20:33	08/18/2015	22:45	27	3540	131	Overhead equipment	Overhead Primary	Replace - Same Size		I
5110011	B93002	08/18/2015	20:41	08/19/2015	7:33	1	651	651	Weather	Other			I
5110013	U52516	08/18/2015	20:41	08/18/2015	21:30	6	288	48	Weather	Transformer Fuse	Replace - Same Size		II
5110021	P73182	08/18/2015	20:47	08/18/2015	21:59	1	71	71	Weather	Fuse	Replace - Same Size		VI
5110025	J80807	08/18/2015	20:48	08/18/2015	23:17	1	148	148	Overhead equipment	Overhead Transformer	Repair	Repair	V
5110053	303002	08/18/2015	20:58	08/18/2015	22:41	186	19325	103	Overhead equipment				VI
5110043	P73182	08/18/2015	20:59	08/18/2015	22:00	1	60	60	Weather	Fuse	Replace - Same Size		VI
5110045	N73121	08/18/2015	21:00	08/18/2015	22:01	1	60	60	Tree related-tree broken	Overhead Service	Repair		IV
5110051	A97006	08/18/2015	21:10	08/18/2015	21:59	260	12719	48	Overhead equipment	Other		Repair	I
5110059	N54213	08/18/2015	21:11	08/18/2015	22:14	1	62	62	Tree related-tree broken	Overhead Service	Cut in Clear		II
5110057	R78301	08/18/2015	21:11	08/19/2015	7:06	2	1188	594	Tree related-tree contact	Pole	Replace - Same Size	Repair	V
5110065	P83705	08/18/2015	21:17	08/18/2015	23:50	1	152	152	Overhead equipment	Recloser		Replace - Same Size	I
5110069	Z20587	08/18/2015	21:23	08/19/2015	1:18	1	234	234	Overhead equipment	Fuse	Replace - Same Size		IV
5110081	R07382	08/18/2015	21:45	08/19/2015	1:30	1	224	224	Weather	Overhead Primary	Repair	Repair	I
5110085	341002	08/18/2015	21:46	08/18/2015	22:30	1	43	43	Tree related-tree broken	Overhead Service	Advise Customer	Advise Customer	VI
5110091	Q23255	08/18/2015	21:50	08/18/2015	22:20	7	204	29	Tree related-tree contact	Overhead Primary	Repair	Repair	VI
5110101	R07382	08/18/2015	22:12	08/19/2015	2:30	1	257	257	Overhead equipment	Disconnect Switch	Replace - Same Size		I
5110109	HE3304	08/18/2015	22:21	08/18/2015	23:43	18	1487	82	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	VI
5110111	D66004	08/18/2015	22:23	08/19/2015	3:42	3	954	318	Weather	Pole	Replace - New Size		IV
5110117	J99121	08/18/2015	22:45	08/18/2015	23:44	12	699	58	Weather	Transformer Fuse	Replace - Same Size		VI
5110121	V03562	08/18/2015	23:14	08/19/2015	1:45	29	4365	150	Weather	Fuse	Replace - Same Size		II
5110131	Q93522	08/18/2015	23:42	08/19/2015	3:28	1	225	225	Overhead equipment	Overhead Primary	Repair		I
5110135	R07382	08/18/2015	23:59	08/19/2015	10:42	87	55964	643	Tree related-tree broken	Overhead Primary	Repair	Repair	I
5110137	J27361	08/19/2015	0:05	08/19/2015	6:09	1	363	363	Overhead equipment				VI
5110139	J24-UNIT-1	08/19/2015	0:06	08/19/2015	6:09	1	362	362	Overhead equipment				VI
5110141	M19222	08/19/2015	0:14	08/19/2015	2:40	1	145	145	Weather	Fuse	Replace - Same Size		VI
5110147	R16511	08/19/2015	0:32	08/19/2015	4:48	1	255	255	Overhead equipment	Connector	Repair		I
5110151	U84566	08/19/2015	0:48	08/19/2015	1:40	6	307	51	Weather				II
5110207	J80-UNIT-1	08/19/2015	1:06	08/19/2015	1:41	1942	66125	34	Weather				V
5110241	J76-UNIT-1	08/19/2015	1:07	08/19/2015	1:41	1529	50609	33	Weather				V
5110193	N72240	08/19/2015	1:09	08/19/2015	1:20	5	51	10	Overhead equipment	Connector	Repair		III
5110233	N95824	08/19/2015	1:11	08/19/2015	3:49	17	2682	157	Overhead equipment	Lightning Arrestor	Replace - Same Size		V
5110399	U84534	08/19/2015	1:19	08/19/2015	2:36	46	3501	76	Weather	Fuse	Replace - Same Size		II
5110341	K80381	08/19/2015	1:25	08/19/2015	3:08	22	2258	102	Underground equipment	Underground Primary	Switch/Reset		IV
5110347	N72240	08/19/2015	1:29	08/19/2015	1:47	9	157	17	Overhead equipment	Connector	Repair		III
5110415	H32370	08/19/2015	1:33	08/19/2015	3:42	7	903	129	Overhead equipment	Fuse	Replace - Same Size		V
5110373	328119	08/19/2015	1:35	08/19/2015	4:10	1	154	154	Overhead equipment	Substation Breaker	Switch/Reset		V
5110405	350104	08/19/2015	1:36	08/19/2015	4:00	539	77411	143	Tree related-tree broken				V
5110387	329147	08/19/2015	1:38	08/19/2015	9:05	1	446	446	Overhead equipment	Other			V
5110401	329147	08/19/2015	1:42	08/19/2015	9:05	15	6631	442	Overhead equipment	Overhead Primary	Patrol/Test/Inspect	Repair	V
5110407	J80807	08/19/2015	1:45	08/19/2015	1:58	1	12	12	Overhead equipment	Overhead Service			V
5110411	310124	08/19/2015	1:46	08/19/2015	5:15	7	1462	208	Overhead equipment	Fuse	Replace - Same Size		V
5110413	307004	08/19/2015	1:46	08/19/2015	7:25	29	9827	338	Tree related-tree broken	Overhead Primary	Patrol/Test/Inspect	Repair	VI
5110417	328119	08/19/2015	1:48	08/19/2015	4:05	27	3672	136	Overhead equipment	Substation Breaker	Switch/Reset		V
5110425	D69004	08/19/2015	1:50	08/19/2015	6:05	172	43796	254	Underground equipment	Other	Patrol/Test/Inspect	Patrol/Test/Inspect	I
5110431	J33803	08/19/2015	2:03	08/19/2015	3:37	1	93	93	Weather				V
5110433	337002	08/19/2015	2:04	08/19/2015	7:30	4	1303	325	Tree related-tree broken				VI
5110439	312112	08/19/2015	2:13	08/19/2015	6:47	1	273	273	Tree related-tree contact	Overhead Service	Disconnect		V
5110441	Q63835	08/19/2015	2:16	08/19/2015	3:31	1	74	74	Weather	Transformer Fuse	Replace - Same Size		V
5110459	312111	08/19/2015	2:20	08/19/2015	6:12	18	4174	231	Tree related-tree broken	Overhead Primary	Repair	Repair	V
5110461	J88166	08/19/2015	2:43	08/19/2015	4:45	418	46336	121	Tree related-tree broken	Recloser			VI

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5110469	Q95247	08/19/2015	2:55	08/19/2015	4:20	10	850	85	Tree related-tree broken	Tree	Remove	Remove	VI
5110481	J88166	08/19/2015	3:06	08/19/2015	4:44	43	4241	98	Tree related-tree broken				VI
5110483	P73182	08/19/2015	3:07	08/19/2015	7:58	1	290	290	Overhead equipment	Overhead Transformer	Replace - Same Size	Replace - Same Size	VI
5110489	P73182	08/19/2015	3:12	08/19/2015	5:37	1	144	144	Weather	Fuse	Replace - Same Size		VI
5110491	J87111	08/19/2015	3:12	08/19/2015	8:47	65	14539	334	Tree related-tree broken	Overhead Primary		Repair	VI
5110495	J18268	08/19/2015	3:17	08/19/2015	8:30	1	312	312	Weather	Transformer Fuse	Replace - Same Size		VI
5110501	328119	08/19/2015	3:36	08/19/2015	4:16	1	39	39	Overhead equipment	Substation Breaker	Switch/Reset		V
5110505	J33803	08/19/2015	3:40	08/19/2015	4:20	1	39	39	Intentional				V
5110585	J20931	08/19/2015	3:42	08/19/2015	6:56	25	4835	193	Overhead equipment				VI
5110611	R10943	08/19/2015	3:56	08/19/2015	7:37	8	1764	220	Weather	Fuse	Replace - Same Size		VI
5110515	J76804	08/19/2015	4:16	08/19/2015	6:56	2	318	159	Overhead equipment	Overhead Primary	Repair	Repair	V
5110521	R49275	08/19/2015	4:23	08/19/2015	7:47	7	1425	203	Overhead equipment	Fuse	Repair	Repair	VI
5110525	S47575	08/19/2015	4:41	08/19/2015	6:55	1	133	133	Overhead equipment	Fuse			VI
5110535	Q04410	08/19/2015	4:41	08/19/2015	8:15	74	15769	213	Underground equipment	Underground Primary	Repair	Repair	III
5110529	K07322	08/19/2015	4:42	08/19/2015	6:04	1	81	81	Animal related	Fuse	Replace - Same Size		I
5110547	T09558	08/19/2015	4:45	08/19/2015	6:30	20	2087	104	Weather	Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
5110537	S86582	08/19/2015	4:47	08/19/2015	6:30	1	102	102	Overhead equipment	Disconnect Switch	Replace - Same Size		VI
5110551	N15849	08/19/2015	4:50	08/19/2015	6:32	278	28336	101	Overhead equipment				V
5110555	V22555	08/19/2015	4:58	08/19/2015	7:50	1	171	171	Tree related-tree broken	Overhead Service	Repair		II
5110557	308003	08/19/2015	4:58	08/19/2015	20:33	1	934	934	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	VI
5110571	R07382	08/19/2015	5:05	08/19/2015	6:30	1	84	84	Overhead equipment	Overhead Service	Repair	Repair	I
5110573	Y50002	08/19/2015	5:09	08/19/2015	7:30	1	140	140	Tree related-tree broken	Overhead Service	Repair		IV
5110577	312115	08/19/2015	5:11	08/19/2015	7:47	1	155	155	Tree related-tree broken	Overhead Service	Repair		V
5110579	P73182	08/19/2015	5:12	08/19/2015	5:38	1	25	25	Weather	Fuse	Replace - Same Size		VI
5110583	341002	08/19/2015	5:15	08/19/2015	6:58	1	102	102	Overhead equipment	Overhead Secondary	Patrol/Test/Inspect		VI
5110587	K09864	08/19/2015	5:17	08/19/2015	6:56	1	98	98	Weather	Fuse	Replace - Same Size	Repair	V
5110589	B93003	08/19/2015	5:17	08/19/2015	8:18	11	1984	180	Weather	Fuse	Replace - Same Size		I
5110593	J76804	08/19/2015	5:18	08/19/2015	6:57	1	98	98	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	V
5110601	S42579	08/19/2015	5:27	08/19/2015	6:51	5	417	83	Overhead equipment	Disconnect Switch	Repair	Replace - Same Size	VI
5110607	T06504	08/19/2015	5:34	08/19/2015	7:30	18	2075	115	Tree related-tree broken	Overhead Primary	Patrol/Test/Inspect	Repair	VI
5110615	B19002	08/19/2015	5:36	08/19/2015	13:48	8	3934	491	Underground equipment	Fuse	Replace - Same Size	Replace - Same Size	I
5110609	Q95247	08/19/2015	5:38	08/19/2015	7:50	1	131	131	Overhead equipment				VI
5110617	K27150	08/19/2015	5:48	08/19/2015	6:40	1	51	51	Weather	Transformer Fuse	Repair	Repair	VI
5110623	N15850	08/19/2015	6:07	08/19/2015	7:00	1	52	52	Weather	Fuse	Replace - Same Size		V
5110625	S47575	08/19/2015	6:12	08/19/2015	6:59	1	46	46	Overhead equipment	Disconnect Switch			VI
5110627	N15849	08/19/2015	6:15	08/19/2015	6:33	2	36	18	Overhead equipment	Overhead Transformer	Repair		V
5110639	M78322	08/19/2015	6:23	08/19/2015	11:35	29	9031	311	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	V
5110635	H10843	08/19/2015	6:25	08/19/2015	8:18	1	112	112	Weather	Transformer Fuse	Replace - Same Size		V
5110637	K62102	08/19/2015	6:28	08/19/2015	7:20	1	51	51	Tree related-tree contact	Fuse	Replace - Same Size		II
5110641	M19222	08/19/2015	6:36	08/19/2015	10:37	1	240	240	Overhead equipment	Transformer Fuse	Replace - Same Size		VI
5110643	D39001	08/19/2015	6:37	08/19/2015	12:03	7	2282	326	Overhead equipment	Overhead Primary	Patrol/Test/Inspect	Repair	I
5110645	D32212	08/19/2015	6:39	08/19/2015	10:33	1	233	233	Unknown	Fuse			I
5110647	U60559	08/19/2015	6:44	08/19/2015	8:23	1	98	98	Weather	Fuse			II
5110651	308003	08/19/2015	7:04	08/19/2015	8:35	1	90	90	Overhead equipment	Fuse	Patrol/Test/Inspect	Repair	VI
5110653	338007	08/19/2015	7:06	08/19/2015	9:14	1	127	127	Weather	Fuse	Repair		VI
5110655	L23145	08/19/2015	7:08	08/19/2015	9:11	1	122	122	Tree related-tree broken	Overhead Service	Repair		III
5110657	B77003	08/19/2015	7:11	08/19/2015	10:00	5	844	168	Tree related-tree broken	Overhead Primary	Repair	Repair	I
5110659	L23146	08/19/2015	7:16	08/19/2015	10:36	1	199	199	Overhead equipment	Overhead Service	Repair		III
5110661	L82187	08/19/2015	7:28	08/19/2015	8:48	1	79	79	Tree related-tree broken	Tree			IV
5110663	R16510	08/19/2015	7:30	08/19/2015	9:15	1	104	104	Tree related-tree contact	Overhead Service	Repair	Repair	I
5110665	Q69926	08/19/2015	7:31	08/19/2015	11:34	1	242	242	Overhead equipment	Tree	Trim	Trim	VI
5110915	B08003	08/19/2015	7:34	08/19/2015	14:17	4	1608	402	Underground equipment	Underground Primary		Repair	I
5110671	341002	08/19/2015	7:40	08/19/2015	10:19	1	158	158	Overhead equipment	Overhead Service	Repair		VI
5110675	S86582	08/19/2015	7:45	08/19/2015	11:05	1	199	199	Overhead equipment	Lightning Arrestor		Replace - Same Size	VI
5110677	V44504	08/19/2015	7:50	08/19/2015	9:20	2	178	89	Animal related	Transformer Fuse	Replace - Same Size		II
5110679	R07382	08/19/2015	8:03	08/19/2015	11:26	1	202	202	Underground equipment	Underground Service	Repair		I

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5110689	J13108	08/19/2015	8:23	08/19/2015	10:58	1	154	154	Overhead equipment	Overhead Primary	Tie/Tighten	Repair	I
5110691	S09520	08/19/2015	8:23	08/19/2015	10:18	2	228	114	Overhead equipment	Fuse		Replace - Same Size	VI
5110699	P05826	08/19/2015	8:39	08/19/2015	9:23	1	43	43	Weather	Transformer Fuse	Replace - Same Size		V
5110711	V42572	08/19/2015	9:01	08/19/2015	9:53	7	363	51	Animal related	Transformer Fuse	Replace - Same Size		II
5110715	S15559	08/19/2015	9:06	08/19/2015	10:48	1	101	101	Overhead equipment	Disconnect Switch	Replace - Same Size		VI
5110721	X02548	08/19/2015	9:09	08/19/2015	10:11	394	24644	62	Substation equipment				IV
5110797	X02549	08/19/2015	9:09	08/19/2015	10:11	701	43167	61	Substation equipment				IV
5110759	N97886	08/19/2015	9:12	08/19/2015	10:23	1	70	70	Overhead equipment	Fuse	Replace - Same Size		V
5110765	S15559	08/19/2015	9:12	08/19/2015	10:51	8	786	98	Overhead equipment				VI
5110835	Z10501	08/19/2015	9:12	08/19/2015	10:25	525	38262	72	Substation equipment				IV
5110779	S15559	08/19/2015	9:13	08/19/2015	10:52	1	98	98	Overhead equipment	Disconnect Switch	Replace - Same Size		VI
5110855	S15559	08/19/2015	9:17	08/19/2015	10:55	1	97	97	Overhead equipment	Fuse	Replace - Same Size		VI
5110885	V03562	08/19/2015	9:26	08/19/2015	10:54	1	87	87	Tree related-tree broken	Overhead Service	Repair		II
5110891	P49180	08/19/2015	9:38	08/19/2015	12:52	1	193	193	Animal related	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	I
5110893	N97886	08/19/2015	9:40	08/19/2015	10:35	1	54	54	Weather	Fuse	Replace - Same Size		V
5110907	K28183	08/19/2015	9:53	08/19/2015	10:34	1	40	40	Animal related	Fuse	Replace - Same Size		III
5110921	U90566	08/19/2015	10:01	08/19/2015	11:50	7	760	108	Overhead equipment	Disconnect Switch	Repair	Repair	II
5110933	338007	08/19/2015	10:08	08/19/2015	16:55	1	406	406	Tree related-tree broken	Overhead Service	Repair		VI
5110937	U15001	08/19/2015	10:10	08/19/2015	12:29	18	2491	138	Public	Underground Primary	Repair	Repair	II
5110939	P07179	08/19/2015	10:13	08/19/2015	11:00	1	46	46	Unknown	Transformer Fuse	Replace - Same Size		I
5110941	N93260	08/19/2015	10:14	08/19/2015	13:50	1	215	215	Overhead equipment	Overhead Transformer			III
5110943	L93135	08/19/2015	10:19	08/19/2015	12:20	1	120	120	Overhead equipment	Overhead Service	Repair	Repair	VI
5110945	X02546	08/19/2015	10:22	08/19/2015	10:25	1	2	2	Weather				IV
5110947	D28124	08/19/2015	10:24	08/19/2015	11:56	6	548	91	Unknown	Fuse	Replace - Same Size		I
5110951	N60181	08/19/2015	10:33	08/19/2015	11:36	12	744	62	Animal related	Fuse	Repair	Replace - Same Size	I
5110955	T06504	08/19/2015	10:40	08/19/2015	12:12	18	1652	91	Tree related-tree broken	Overhead Primary	Repair	Repair	VI
5110959	B19002	08/19/2015	10:43	08/19/2015	11:38	25	1381	55	Underground equipment	Underground Primary	Repair		I
5110967	J89105	08/19/2015	10:49	08/19/2015	11:42	1	52	52	Overhead equipment	Overhead Service	Repair		VI
5110977	D66001	08/19/2015	10:58	08/19/2015	11:57	1	58	58	Overhead equipment	Disconnect Switch	Replace - Same Size		IV
5110987	N95823	08/19/2015	11:18	08/19/2015	12:43	1	84	84	Other	Meter	Reconnect		V
5111021	R16510	08/19/2015	11:21	08/19/2015	13:36	81	10965	135	Overhead equipment	Overhead Primary	Replace - Same Size		I
5110991	D39001	08/19/2015	11:23	08/19/2015	12:03	3	117	39	Overhead equipment	Overhead Primary	Replace - Same Size		I
5110993	D39001	08/19/2015	11:24	08/19/2015	12:03	4	155	38	Overhead equipment	Overhead Primary	Replace - Same Size		I
5111001	P62138	08/19/2015	11:34	08/19/2015	13:22	1	107	107	Tree related-tree broken	Fuse	Replace - Same Size		VI
5111005	V21500	08/19/2015	11:38	08/19/2015	14:22	1	163	163	Public	Underground Service	Repair		II
5111007	P62138	08/19/2015	11:39	08/19/2015	13:28	1	108	108	Tree related-tree broken	Fuse	Repair		VI
5111009	P62138	08/19/2015	11:39	08/19/2015	13:26	1	106	106	Tree related-tree broken	Fuse	Repair		VI
5111017	Q54908	08/19/2015	11:48	08/19/2015	12:32	14	623	44	Overhead equipment	Fuse		Patrol/Test/Inspect	VI
5111025	J80807	08/19/2015	11:57	08/19/2015	14:41	1	163	163	Weather	Overhead Transformer		Replace - Same Size	V
5111027	J13108	08/19/2015	12:00	08/19/2015	15:30	1	209	209	Weather	Meter	Patrol/Test/Inspect	Patrol/Test/Inspect	I
5111029	D32212	08/19/2015	12:06	08/19/2015	19:47	1	460	460	Underground equipment	Underground Primary	Repair	Repair	I
5111031	HA5432	08/19/2015	12:07	08/19/2015	12:52	1	44	44	Weather	Fuse	Replace - Same Size		V
5111033	J80807	08/19/2015	12:09	08/19/2015	13:41	1	91	91	Weather				V
5111037	K76546	08/19/2015	12:14	08/19/2015	13:08	1	53	53	Unknown	Fuse			IV
5111043	R84148	08/19/2015	12:21	08/19/2015	14:05	1	104	104	Overhead equipment	Fuse	Patrol/Test/Inspect	Replace - Same Size	I
5111047	V22555	08/19/2015	12:32	08/19/2015	18:50	1	377	377	Tree related-tree broken	Pole	Repair		II
5111049	E10002	08/19/2015	12:39	08/19/2015	13:50	1	70	70	Overhead equipment	Other	Repair	Patrol/Test/Inspect	III
5111055	L24124	08/19/2015	12:49	08/19/2015	14:25	4	382	95	Animal related	Fuse	Replace - Same Size		III
5111065	M45212	08/19/2015	12:55	08/19/2015	15:44	2	338	169	Underground equipment	Underground Primary		Replace - Urgent	IV
5111067	R49275	08/19/2015	13:01	08/19/2015	14:08	1	66	66	Overhead equipment	Transformer Fuse	Replace - Same Size		VI
5111069	334001	08/19/2015	13:02	08/19/2015	13:09	1	6	6	Overhead equipment	Other	Patrol/Test/Inspect		VI
5111075	J20931	08/19/2015	13:08	08/19/2015	14:47	1	98	98	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	VI
5111085	Q32170	08/19/2015	13:19	08/19/2015	18:11	9	2627	291	Underground equipment	Underground Primary	Repair	Repair	I
5111101	S21529	08/19/2015	13:53	08/19/2015	19:21	7	1672	327	Underground equipment	Underground Primary	Repair		VI
5111119	L82187	08/19/2015	14:23	08/19/2015	16:49	1	145	145	Animal related	Transformer Fuse	Replace - Same Size		IV
5111159	S03531	08/19/2015	14:56	08/19/2015	20:40	521	92626	344	Public	Pole	Repair		VI

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5111167	M49424	08/19/2015	15:04	08/19/2015	15:10	27	137	5	Underground equipment	Fuse	Replace - Same Size	Replace - Same Size	V
5111201	S04512	08/19/2015	15:28	08/19/2015	20:42	1	313	313	Public	Pole	Repair		VI
5111205	L24124	08/19/2015	15:31	08/19/2015	16:11	1	39	39	Animal related	Fuse	Replace - Same Size		III
5111207	Q32171	08/19/2015	15:36	08/19/2015	16:55	1	78	78	Weather	Transformer Fuse	Replace - Same Size	Patrol/Test/Inspect	I
5111209	D36001	08/19/2015	15:43	08/20/2015	1:33	1	589	589	Underground equipment	Underground Service	Patrol/Test/Inspect	Repair	I
5111213	M45212	08/19/2015	15:45	08/19/2015	15:49	1	4	4	Underground equipment				IV
5111219	Q71846	08/19/2015	15:59	08/19/2015	17:47	1	107	107	Overhead equipment	Overhead Service	Repair	Repair	V
5111315	L93132	08/19/2015	16:06	08/20/2015	0:07	33	15852	480	Underground equipment	Underground Primary	Repair	Repair	VI
5111227	J34357	08/19/2015	16:12	08/19/2015	19:34	1	201	201	Underground equipment	Underground Service	Patrol/Test/Inspect	Repair	V
5111229	CW1016	08/19/2015	16:14	08/19/2015	17:40	1	85	85	Other	Other			III
5111233	K09864	08/19/2015	16:18	08/19/2015	17:06	1	47	47	Animal related	Transformer Fuse	Replace - Same Size	Repair	V
5111235	T15571	08/19/2015	16:37	08/19/2015	17:30	6	319	53	Underground equipment	Underground Transformer	Repair		VI
5111237	303001	08/19/2015	16:40	08/19/2015	18:12	1	91	91	Overhead equipment	Overhead Service	Repair		VI
5111239	X64503	08/19/2015	16:49	08/19/2015	17:45	1	55	55	Animal related	Transformer Fuse	Replace - Same Size		IV
5111241	J63172	08/19/2015	16:55	08/19/2015	20:05	1	189	189	Underground equipment	Underground Service			III
5111243	J20931	08/19/2015	16:56	08/19/2015	17:52	1	55	55	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	VI
5111249	J34377	08/19/2015	17:14	08/19/2015	17:37	8	182	22	Underground equipment	Underground Primary	Repair	Replace - Same Size	V
5111253	U73583	08/19/2015	17:27	08/19/2015	18:44	1	76	76	Overhead equipment				II
5111257	J34377	08/19/2015	17:45	08/19/2015	22:19	5	1371	274	Underground equipment	Underground Primary	Switch/Reset	Replace - Same Size	V
5111259	U60518	08/19/2015	17:50	08/19/2015	19:40	1	109	109	Tree related-tree broken	Overhead Service	Repair		II
5111261	J13108	08/19/2015	17:51	08/20/2015	6:07	1	735	735	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
5111271	D93002	08/19/2015	18:02	08/19/2015	22:04	9	1156	242	Overhead equipment	Fuse	Replace - Same Size		IV
5111267	A85001	08/19/2015	18:06	08/19/2015	19:40	1	93	93	Animal related	Fuse	Patrol/Test/Inspect	Repair	I
5111273	X96523	08/19/2015	18:14	08/19/2015	19:21	11	730	66	Weather	Transformer Fuse		Replace - Same Size	IV
5111277	J80807	08/19/2015	18:25	08/19/2015	19:17	1	51	51	Overhead equipment	Overhead Transformer	Repair	Repair	V
5111283	U84587	08/19/2015	18:49	08/19/2015	23:20	1	270	270	Weather	Overhead Transformer			II
5111285	C52001	08/19/2015	18:51	08/19/2015	18:53	10	21	2	Unknown				III
5111289	M09143	08/19/2015	18:57	08/19/2015	20:00	1	62	62	Overhead equipment	Connector	Replace - Same Size		VI
5111303	P05825	08/19/2015	19:34	08/19/2015	20:30	1	55	55	Weather	Transformer Fuse	Replace - Same Size		V
5111313	S47589	08/19/2015	20:37	08/19/2015	21:33	3	166	55	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	VI
5111317	M09144	08/19/2015	20:53	08/19/2015	21:37	1	43	43	Overhead equipment	Fuse	Replace - Same Size		VI
5111319	M09144	08/19/2015	20:54	08/19/2015	21:31	1	36	36	Overhead equipment	Fuse	Replace - Same Size		VI
5111321	J71128	08/19/2015	20:59	08/20/2015	10:08	1	789	789	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
5111325	S07536	08/19/2015	21:19	08/19/2015	21:47	22	630	28	Public	Pole	Repair		VI
5111335	N15850	08/19/2015	22:16	08/20/2015	2:20	11	2673	243	Overhead equipment	Overhead Primary	Patrol/Test/Inspect	Repair	V
5111345	C10001	08/19/2015	22:33	08/20/2015	6:06	25	11306	452	Overhead equipment	Pole	Patrol/Test/Inspect	Repair	III
5111351	D36002	08/19/2015	23:10	08/20/2015	11:07	1	716	716	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	I
5111353	D32212	08/19/2015	23:26	08/20/2015	0:41	1	74	74	Overhead equipment	Fuse	Replace - Same Size		I
5111355	M05360	08/19/2015	23:27	08/20/2015	0:21	1	53	53	Animal related	Transformer Fuse	Replace - Same Size		V
5111359	D36001	08/19/2015	23:31	08/20/2015	0:37	4	260	65	Underground equipment	Underground Service	Repair		I
5111367	J87101	08/20/2015	0:10	08/20/2015	5:04	236	69353	293	Underground equipment				VI
5111391	P77237	08/20/2015	0:22	08/20/2015	2:38	1	135	135	Animal related	Transformer Fuse	Replace - Same Size		VI
5111393	P58155	08/20/2015	0:22	08/20/2015	2:23	60	7227	120	Tree related-tree contact	Tree	Remove		VI
5111397	K15205	08/20/2015	2:41	08/20/2015	6:40	1	238	238	Overhead equipment				VI
5111399	X77543	08/20/2015	2:49	08/20/2015	4:04	1	74	74	Animal related	Transformer Fuse	Replace - Same Size		IV
5111401	K19114	08/20/2015	3:12	08/20/2015	5:25	1	132	132	Tree related-tree broken	Overhead Service	Repair	Repair	VI
5111403	J82116	08/20/2015	3:38	08/20/2015	3:46	236	1852	7	Overhead equipment				VI
5111425	C10001	08/20/2015	4:07	08/20/2015	6:06	25	2973	119	Overhead equipment	Crossarm	Repair	Replace - Same Size	III
5111427	A36001	08/20/2015	6:01	08/20/2015	7:18	1	76	76	Animal related	Fuse	Replace - Same Size		I
5111465	B93002	08/20/2015	6:17	08/20/2015	18:01	7	4496	703	Underground equipment	Underground Primary	Patrol/Test/Inspect	Replace - Urgent	I
5111437	B93001	08/20/2015	7:14	08/20/2015	8:20	61	3989	65	Animal related	Fuse	Replace - Same Size		I
5111439	R48165	08/20/2015	7:14	08/20/2015	11:32	1	257	257	Tree related-tree broken	Tree			IV
5111447	J88166	08/20/2015	7:22	08/20/2015	9:28	39	4913	125	Underground equipment	Underground Primary	Switch/Reset	Repair	VI
5111445	B77001	08/20/2015	7:23	08/20/2015	8:00	6	216	36	Animal related	Fuse	Replace - Same Size		I
5111453	L79159	08/20/2015	7:47	08/20/2015	10:41	1	173	173	Underground equipment	Underground Service	Repair		IV
5111473	Q21292	08/20/2015	8:01	08/20/2015	11:20	5	994	198	Overhead equipment	Transformer Fuse	Repair	Repair	VI

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5111477	P83710	08/20/2015	8:03	08/20/2015	10:35	1	151	151	Animal related	Transformer Fuse	Repair		I
5111493	L23145	08/20/2015	8:14	08/20/2015	12:00	1	225	225	Tree related-tree contact	Overhead Service	Repair		III
5111505	S16596	08/20/2015	8:25	08/20/2015	9:25	8	478	59	Animal related	Transformer Fuse	Replace - Same Size		VI
5111507	J15303	08/20/2015	8:31	08/20/2015	10:00	1	88	88	Unknown	Transformer Fuse	Replace - Same Size		I
5111555	U92593	08/20/2015	8:50	08/20/2015	9:44	1	53	53	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	II
5111581	S07536	08/20/2015	9:04	08/20/2015	10:15	1	70	70	Tree related-tree broken	Overhead Service	Repair	Repair	VI
5111585	B93003	08/20/2015	9:08	08/20/2015	12:02	1	173	173	Animal related	Transformer Fuse	Replace - Same Size		I
5111607	J61115	08/20/2015	9:39	08/20/2015	11:32	1	112	112	Intentional				III
5111615	A24001	08/20/2015	9:42	08/20/2015	10:55	4	288	72	Overhead equipment	Customer Equipment	Patrol/Test/Inspect		I
5111629	M22812	08/20/2015	10:05	08/20/2015	11:07	1	61	61	Weather	Transformer Fuse	Replace - Same Size		V
5111675	E10001	08/20/2015	11:07	08/20/2015	12:13	1	65	65	Other	Other	Patrol/Test/Inspect	Patrol/Test/Inspect	III
5111687	P52306	08/20/2015	11:19	08/20/2015	12:56	18	1736	96	Underground equipment	Underground Primary	Switch/Reset	Replace - Same Size	IV
5111695	D66001	08/20/2015	11:40	08/20/2015	12:01	262	5441	20	Unknown				IV
5111721	S13546	08/20/2015	12:10	08/20/2015	12:14	1	3	3	Other				VI
5111755	G50001	08/20/2015	12:58	08/20/2015	14:45	1	106	106	Tree related-tree contact	Overhead Service	Repair	Repair	IV
5111769	R16511	08/20/2015	13:22	08/20/2015	16:20	1	177	177	Weather	Overhead Transformer	Replace - Same Size		I
5111787	S86582	08/20/2015	13:46	08/20/2015	17:50	4	971	243	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	VI
5111805	Y98561	08/20/2015	14:35	08/20/2015	16:28	1	113	113	Overhead equipment	Overhead Service	Repair		IV
5111831	D89001	08/20/2015	14:54	08/20/2015	16:16	38	3097	81	Overhead equipment	Fuse	Patrol/Test/Inspect	Repair	I
5111835	B28006	08/20/2015	15:11	08/20/2015	18:03	1	171	171	Overhead equipment				I
5111837	H01190	08/20/2015	15:12	08/20/2015	16:07	23	1247	54	Animal related	Fuse	Replace - Same Size		III
5111847	Y39001	08/20/2015	15:20	08/20/2015	19:30	4	998	249	Tree related-tree broken	Pole	Replace - New Size		IV
5111851	T06505	08/20/2015	15:26	08/20/2015	19:00	1	213	213	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	VI
5111879	K69117	08/20/2015	16:22	08/20/2015	19:20	1	177	177	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	IV
5111885	P26284	08/20/2015	16:26	08/20/2015	18:00	1	93	93	Animal related	Fuse	Replace - Same Size		I
5111887	T06503	08/20/2015	16:29	08/20/2015	17:25	1	55	55	Animal related	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
5111895	T06503	08/20/2015	16:46	08/20/2015	17:29	1	42	42	Animal related	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
5111897	L24121	08/20/2015	17:00	08/20/2015	17:38	19	712	37	Overhead equipment	Fuse			III
5111901	K28180	08/20/2015	17:14	08/20/2015	18:50	1	95	95	Public	Overhead Transformer		Replace - Same Size	III
5111903	J63172	08/20/2015	17:23	08/20/2015	18:23	92	5508	59	Public	Fuse			III
5111905	B93001	08/20/2015	17:24	08/21/2015	5:30	1	725	725	Underground equipment	Underground Primary	Replace - Same Size		I
5111907	S31532	08/20/2015	17:25	08/20/2015	21:08	2	446	223	Underground equipment	Underground Primary	Repair		VI
5111909	J63172	08/20/2015	17:25	08/20/2015	18:10	7	310	44	Public	Fuse			III
5111913	K71811	08/20/2015	17:26	08/20/2015	18:36	1	69	69	Overhead equipment	Connector	Repair		IV
5111915	J63172	08/20/2015	17:27	08/20/2015	18:11	37	1593	43	Public	Fuse			III
5111921	Y37593	08/20/2015	17:31	08/20/2015	22:15	41	5774	283	Public	Pole	Repair	Replace - Same Size	IV
5111925	L24124	08/20/2015	17:32	08/20/2015	20:00	1	147	147	Underground equipment	Underground Service		Repair	III
5111929	L24121	08/20/2015	17:38	08/20/2015	17:45	1	6	6	Overhead equipment	Fuse	Repair		III
5111933	V14579	08/20/2015	17:45	08/20/2015	19:05	1	79	79	Animal related	Fuse	Replace - Same Size		II
5111935	J99141	08/20/2015	17:46	08/20/2015	22:20	1	273	273	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	VI
5111945	P47123	08/20/2015	18:17	08/21/2015	0:55	1	397	397	Overhead equipment	Overhead Transformer			I
5111953	C50001	08/20/2015	18:57	08/20/2015	21:35	1	157	157	Other	Other	Replace - Same Size	Patrol/Test/Inspect	III
5111957	A45003	08/20/2015	19:12	08/20/2015	21:08	1	115	115	Overhead equipment	Jumper	Repair		I
5111959	K30204	08/20/2015	19:24	08/20/2015	20:40	1	75	75	Unknown	Transformer Fuse	Replace - Same Size		III
5111983	B57002	08/20/2015	23:02	08/21/2015	0:34	302	26427	91	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
5111993	HE3304	08/20/2015	23:58	08/21/2015	1:35	29	2801	96	Animal related	Fuse	Replace - Same Size		VI
5111997	M42614	08/21/2015	1:56	08/21/2015	7:00	1	303	303	Overhead equipment				I
5112001	B57002	08/21/2015	3:55	08/21/2015	6:05	22	2854	129	Underground equipment	Underground Primary	Patrol/Test/Inspect	Replace - Urgent	I
5112023	Y39515	08/21/2015	7:20	08/21/2015	8:00	1	39	39	Animal related	Transformer Fuse	Replace - Same Size		IV
5112027	338007	08/21/2015	7:29	08/21/2015	8:40	1	70	70	Overhead equipment	Fuse	Repair		VI
5112029	U35554	08/21/2015	7:30	08/21/2015	8:28	1	57	57	Animal related	Transformer Fuse	Replace - Same Size		II
5112035	R53390	08/21/2015	7:46	08/21/2015	8:45	1	58	58	Animal related	Fuse	Replace - Same Size	Replace - Same Size	V
5112039	H14343	08/21/2015	7:58	08/21/2015	11:30	3	633	211	Public	Overhead Primary	Switch/Reset	Repair	V
5112043	P47120	08/21/2015	8:05	08/21/2015	10:19	7	932	133	Overhead equipment	Fuse	Repair	Replace - Same Size	I
5112045	L12128	08/21/2015	8:13	08/21/2015	10:01	18	1931	107	Underground equipment	Underground Primary		Repair	III
5112047	Y36559	08/21/2015	8:22	08/21/2015	9:26	1	63	63	Overhead equipment	Transformer Fuse			IV

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5112049	J89125	08/21/2015	8:25	08/21/2015	8:34	3	26	8	Overhead equipment	Overhead Transformer	Repair		VI
5112051	P47120	08/21/2015	8:28	08/21/2015	10:20	1	111	111	Overhead equipment	Fuse	Repair	Replace - Same Size	I
5112055	L82187	08/21/2015	8:33	08/21/2015	9:23	1	49	49	Weather	Transformer Fuse	Replace - Same Size		IV
5112067	T06505	08/21/2015	8:46	08/21/2015	14:49	1	362	362	Public	Underground Service	Repair		VI
5112081	B93003	08/21/2015	8:55	08/21/2015	11:01	1	125	125	Unknown	Transformer Fuse	Replace - Same Size		I
5112087	Q11517	08/21/2015	8:58	08/21/2015	10:33	10	942	94	Animal related	Fuse	Replace - Same Size		I
5112091	344003	08/21/2015	9:05	08/21/2015	10:15	1	69	69	Overhead equipment	Overhead Primary	Repair		VI
5112099	R65452	08/21/2015	9:10	08/21/2015	12:52	18	1412	221	Animal related	Fuse	Replace - Same Size		IV
5112131	L93149	08/21/2015	9:19	08/21/2015	10:38	670	52995	79	Overhead equipment	Recloser	Replace - Same Size		VI
5112159	L93132	08/21/2015	9:28	08/21/2015	11:21	1	112	112	Overhead equipment				VI
5112161	303005	08/21/2015	9:29	08/21/2015	11:50	5	700	140	Public	Overhead Secondary	Patrol/Test/Inspect		VI
5112163	K69112	08/21/2015	9:41	08/21/2015	16:30	1	408	408	Underground equipment	Underground Service	Patrol/Test/Inspect	Repair	IV
5112165	L93149	08/21/2015	9:41	08/21/2015	10:22	1	40	40	Overhead equipment				VI
5112209	J47178	08/21/2015	9:50	08/21/2015	12:03	41	5419	132	Underground equipment	Underground Primary	Repair	Repair	III
5112177	N72240	08/21/2015	9:55	08/21/2015	13:34	1	218	218	Tree related-tree broken	Overhead Service			III
5112203	S55535	08/21/2015	10:03	08/21/2015	15:43	11	3234	339	Underground equipment	Underground Primary	Repair	Repair	VI
5112191	K25166	08/21/2015	10:04	08/21/2015	11:34	1	89	89	Overhead equipment	Overhead Service	Repair	Repair	VI
5112227	A29001	08/21/2015	11:01	08/21/2015	12:05	1	63	63	Other	Meter	Reconnect		I
5112231	Q32170	08/21/2015	11:04	08/21/2015	12:42	1	97	97	Weather	Transformer Fuse	Replace - Same Size	Patrol/Test/Inspect	I
5112237	R48165	08/21/2015	11:10	08/21/2015	12:18	1	67	67	Overhead equipment	Overhead Service			IV
5112239	D36002	08/21/2015	11:12	08/21/2015	11:14	57	114	2	Unknown				I
5112241	D36002	08/21/2015	11:12	08/21/2015	11:41	33	954	28	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	I
5112251	D36002	08/21/2015	11:13	08/21/2015	11:31	60	1069	17	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	I
5112247	D36002	08/21/2015	11:15	08/21/2015	11:31	23	366	15	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	I
5112249	M41112	08/21/2015	11:15	08/21/2015	12:37	1	81	81	Overhead equipment	Overhead Service	Repair	Replace - Same Size	I
5112255	V23530	08/21/2015	11:16	08/21/2015	12:51	1	94	94	Tree related-tree broken	Overhead Secondary	Repair	Replace - Same Size	II
5112253	D36002	08/21/2015	11:16	08/21/2015	11:30	1	13	13	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	I
5112261	D36001	08/21/2015	11:18	08/21/2015	12:04	19	877	46	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	I
5112273	D36002	08/21/2015	11:31	08/21/2015	11:40	1	9	8	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	I
5112279	Z08509	08/21/2015	11:39	08/21/2015	13:00	1	80	80	Overhead equipment	Fuse	Repair	Replace - Same Size	IV
5112289	P05826	08/21/2015	11:45	08/21/2015	12:04	1	18	18	Overhead equipment	Overhead Primary			V
5112283	P05826	08/21/2015	11:46	08/21/2015	11:50	141	578	4	Unknown				V
5112291	P05826	08/21/2015	11:48	08/21/2015	12:01	1	12	12	Overhead equipment	Overhead Primary			V
5112293	D36001	08/21/2015	11:52	08/21/2015	11:58	8	55	6	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	I
5112299	P05826	08/21/2015	11:58	08/21/2015	12:08	1	9	9	Overhead equipment	Overhead Primary			V
5112301	D96001	08/21/2015	11:58	08/21/2015	15:01	8	1460	182	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Repair	I
5112303	P05826	08/21/2015	12:01	08/21/2015	12:19	1	17	17	Overhead equipment	Overhead Primary			V
5112331	J14140	08/21/2015	13:23	08/21/2015	14:14	1	50	50	Animal related	Fuse	Replace - Same Size		VI
5112353	B45004	08/21/2015	14:19	08/21/2015	15:22	1	62	62	Weather	Fuse	Replace - Same Size		I
5112373	S27599	08/21/2015	14:50	08/21/2015	15:30	95	3839	40	Jurisdictional	Overhead Primary	Replace - Same Size		VI
5112389	K80386	08/21/2015	15:03	08/21/2015	16:59	30	3463	115	Underground equipment	Underground Primary	Switch/Reset	Repair	IV
5112391	P53341	08/21/2015	15:55	08/21/2015	18:48	9	1560	173	Underground equipment	Underground Primary	Switch/Reset	Switch/Reset	IV
5112393	L14232	08/21/2015	16:09	08/21/2015	16:27	1	17	17	Overhead equipment	Overhead Service	Repair		III
5112399	L50217	08/21/2015	16:21	08/21/2015	20:51	1	269	269	Underground equipment	Underground Service	Disconnect	Repair	VI
5112405	P44324	08/21/2015	16:41	08/21/2015	18:34	1	112	112	Other	Other			I
5112411	J12166	08/21/2015	16:53	08/21/2015	17:31	1	37	37	Animal related	Fuse	Replace - Same Size		III
5112413	V18582	08/21/2015	17:02	08/21/2015	23:20	15	5671	378	Underground equipment	Underground Primary		Repair	II
5112417	K15207	08/21/2015	17:05	08/21/2015	19:07	1	121	121	Overhead equipment	Fuse	Replace - Same Size		VI
5112427	F10001	08/21/2015	17:42	08/21/2015	18:54	1	71	71	Overhead equipment	Connector	Replace - Same Size		III
5112429	X23505	08/21/2015	17:52	08/21/2015	19:00	1	67	67	Overhead equipment	Transformer Fuse			IV
5112431	Y13043	08/21/2015	18:04	08/21/2015	19:50	1	105	105	Overhead equipment	Overhead Service	Repair		IV
5112437	N54214	08/21/2015	18:24	08/21/2015	20:07	41	4201	102	Overhead equipment	Fuse	Replace - Same Size		II
5112469	N54214	08/21/2015	18:26	08/21/2015	21:30	13	2385	183	Animal related				II
5112445	B81003	08/21/2015	18:37	08/21/2015	18:39	28	58	2	Unknown				I
5112455	D37001	08/21/2015	18:55	08/21/2015	19:56	41	2492	60	Overhead equipment				I
5112461	X42502	08/21/2015	19:04	08/21/2015	20:26	1	81	81	Animal related	Transformer Fuse	Replace - Same Size	Replace - Same Size	IV

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5112463	CW1016	08/21/2015	19:09	08/21/2015	21:42	1	152	152	Underground equipment	Underground Primary			III
5112465	B65003	08/21/2015	19:11	08/21/2015	23:09	1	237	237	Overhead equipment	Overhead Service			I
5112495	D96001	08/21/2015	20:06	08/22/2015	5:11	2	1090	545	Overhead equipment	Underground Primary	Patrol/Test/Inspect	Patrol/Test/Inspect	I
5112499	U73599	08/21/2015	23:23	08/22/2015	1:18	6	688	114	Tree related-tree broken	Overhead Primary	Repair	Repair	II
5112503	L12126	08/22/2015	0:52	08/22/2015	3:10	28	3847	137	Underground equipment	Underground Primary		Repair	III
5112507	D37001	08/22/2015	0:57	08/22/2015	1:12	5	73	14	Overhead equipment	Crossarm	Repair	Replace - Same Size	I
5112509	L12126	08/22/2015	1:11	08/22/2015	2:34	1	82	82	Underground equipment	Underground Primary	Replace - Same Size		III
5112513	N70330	08/22/2015	2:40	08/22/2015	7:15	1	274	274	Overhead equipment	Overhead Transformer	Replace - Same Size	Replace - Same Size	I
5112515	Q82907	08/22/2015	2:54	08/22/2015	4:31	1	96	96	Animal related	Transformer Fuse	Replace - Same Size		VI
5112517	K22173	08/22/2015	4:14	08/22/2015	5:50	21	1995	95	Animal related	Transformer Fuse	Repair	Repair	VI
5112519	F03003	08/22/2015	4:42	08/22/2015	9:05	1	262	262	Underground equipment	Underground Primary	Repair		III
5112523	Z10501	08/22/2015	6:15	08/22/2015	7:18	1	62	62	Tree related-tree contact	Transformer Fuse			IV
5112525	N70330	08/22/2015	6:32	08/22/2015	7:16	1	43	43	Overhead equipment	Overhead Transformer	Replace - Same Size	Replace - Same Size	I
5112527	V40556	08/22/2015	6:47	08/22/2015	10:48	4	965	241	Underground equipment	Underground Primary	Repair		II
5112529	V38003	08/22/2015	6:47	08/22/2015	7:54	1	66	66	Overhead equipment	Overhead Service	Replace - Same Size		II
5112531	B27009	08/22/2015	6:59	08/22/2015	8:05	93	6103	65	Animal related	Fuse	Replace - Same Size		I
5112539	N22295	08/22/2015	7:01	08/22/2015	8:27	1	85	85	Animal related	Fuse	Replace - Same Size		VI
5112543	P82290	08/22/2015	7:13	08/22/2015	8:37	9	755	83	Overhead equipment	Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
5112547	M20221	08/22/2015	7:17	08/22/2015	8:33	1	75	75	Overhead equipment	Fuse	Replace - Same Size	Remove	VI
5112549	L00134	08/22/2015	7:31	08/22/2015	8:18	1	46	46	Unknown	Fuse	Replace - Same Size		III
5112551	Q47833	08/22/2015	7:40	08/22/2015	8:21	1	40	40	Overhead equipment	Transformer Fuse	Repair	Repair	V
5112557	J34356	08/22/2015	7:45	08/22/2015	9:18	556	51430	92	Unknown	Recloser			V
5112721	J34356	08/22/2015	7:46	08/22/2015	9:21	323	30685	94	Unknown				V
5112659	J34356	08/22/2015	7:46	08/22/2015	9:21	336	31792	94	Overhead equipment	Recloser			V
5112647	R33127	08/22/2015	8:42	08/22/2015	11:00	1	137	137	Overhead equipment	Fuse	Replace - Same Size		I
5112673	V40556	08/22/2015	9:39	08/22/2015	11:05	5	427	85	Animal related	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	II
5112677	J01118	08/22/2015	9:52	08/22/2015	12:08	1	135	135	Overhead equipment	Fuse	Replace - Same Size		I
5112681	B10002	08/22/2015	10:08	08/22/2015	15:10	1	301	301	Underground equipment	Underground Service	Patrol/Test/Inspect	Repair	I
5112685	V03562	08/22/2015	10:16	08/22/2015	12:00	51	5282	103	Weather	Fuse	Replace - Same Size	Replace - Same Size	II
5112687	V03562	08/22/2015	10:17	08/22/2015	12:00	3	308	102	Weather	Fuse	Replace - Same Size	Replace - Same Size	II
5112691	K27150	08/22/2015	10:28	08/22/2015	11:10	1	41	41	Animal related	Transformer Fuse	Repair	Repair	VI
5112703	Q85162	08/22/2015	10:45	08/22/2015	11:14	6	168	28	Public	Pole	Repair	Replace - Same Size	VI
5112705	R10903	08/22/2015	10:57	08/22/2015	11:40	4	170	42	Animal related	Transformer Fuse	Replace - Same Size		VI
5112707	J34356	08/22/2015	11:30	08/22/2015	13:58	13	1915	147	Underground equipment	Underground Primary	Switch/Reset	Repair	V
5112719	310122	08/22/2015	12:02	08/22/2015	12:39	1	36	36	Overhead equipment	Fuse	Replace - Same Size		V
5112723	M36185	08/22/2015	12:40	08/22/2015	15:55	4	777	194	Overhead equipment	Overhead Transformer		Replace - Same Size	I
5112741	X02548	08/22/2015	14:08	08/22/2015	15:35	1	86	86	Overhead equipment	Fuse			IV
5112743	A80001	08/22/2015	14:10	08/22/2015	15:08	1	57	57	Overhead equipment				I
5112745	HD5254	08/22/2015	14:15	08/22/2015	15:12	1	56	56	Animal related	Transformer Fuse	Replace - Same Size		VI
5112749	Q82907	08/22/2015	14:25	08/22/2015	15:42	1	76	76	Animal related	Transformer Fuse	Replace - Same Size		VI
5112751	Y28597	08/22/2015	14:59	08/22/2015	16:30	1	90	90	Overhead equipment	Fuse	Replace - Same Size		IV
5112757	Z17503	08/22/2015	15:36	08/22/2015	17:40	1	123	123	Animal related	Disconnect Switch	Replace - Same Size	Replace - Same Size	IV
5112759	V80506	08/22/2015	15:42	08/22/2015	17:38	3	350	116	Overhead equipment	Fuse	Replace - Same Size		II
5112761	P49187	08/22/2015	15:57	08/22/2015	19:09	1	191	191	Overhead equipment	Overhead Transformer		Replace - Same Size	I
5112765	M18131	08/22/2015	16:23	08/22/2015	17:03	23	898	39	Animal related	Fuse	Repair		III
5112769	Q69926	08/22/2015	16:26	08/22/2015	19:50	6	1223	203	Tree related-tree broken	Overhead Secondary		Repair	VI
5112777	Y79500	08/22/2015	16:32	08/22/2015	19:36	19	3057	184	Underground equipment	Underground Primary	Disconnect		IV
5112773	Q82907	08/22/2015	16:32	08/22/2015	18:40	1	127	127	Weather	Transformer Fuse	Replace - Same Size		VI
5112775	Q82907	08/22/2015	16:39	08/22/2015	19:25	1	165	165	Weather	Fuse	Replace - Same Size		VI
5112779	Q82907	08/22/2015	16:49	08/22/2015	18:06	1	76	76	Weather	Transformer Fuse	Replace - Same Size		VI
5112829	S36571	08/22/2015	17:24	08/22/2015	20:00	336	44808	156	Weather				VI
5112809	S86582	08/22/2015	17:45	08/22/2015	19:20	5	471	94	Weather	Overhead Primary	Repair		VI
5112825	K07320	08/22/2015	17:54	08/22/2015	19:22	1	87	87	Underground equipment	Underground Service	Repair		I
5112857	R33127	08/22/2015	18:47	08/22/2015	21:28	4	640	160	Underground equipment	Underground Primary		Repair	I
5112869	P47120	08/22/2015	18:57	08/22/2015	22:51	28	5872	233	Overhead equipment	Jumper	Repair		I
5112867	K27150	08/22/2015	18:59	08/22/2015	23:52	60	17572	293	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	VI

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5112871	K15207	08/22/2015	19:06	08/22/2015	20:54	1	107	107	Weather	Fuse	Replace - Same Size		VI
5112885	Y98561	08/22/2015	20:26	08/22/2015	22:22	37	4277	115	Overhead equipment	Overhead Primary	Repair	Repair	IV
5112889	S28552	08/22/2015	20:31	08/22/2015	21:27	1	55	55	Weather	Transformer Fuse		Repair	VI
5112891	S34528	08/22/2015	20:56	08/22/2015	23:00	1	123	123	Weather				VI
5112927	M12151	08/22/2015	21:08	08/22/2015	22:17	417	28793	69	Public				VI
5112961	U35511	08/22/2015	21:59	08/23/2015	7:53	21	12483	594	Underground equipment	Underground Primary	Repair		II
5112963	P49187	08/22/2015	22:37	08/23/2015	0:43	1	125	125	Overhead equipment	Overhead Service	Repair		I
5112969	K48379	08/22/2015	23:24	08/23/2015	4:54	25	8236	329	Tree related-tree broken	Overhead Primary	Patrol/Test/Inspect	Repair	V
5112979	J46180	08/23/2015	0:33	08/23/2015	1:45	1	71	71	Overhead equipment	Fuse			III
5112981	J46180	08/23/2015	0:40	08/23/2015	1:45	11	714	64	Overhead equipment	Fuse			III
5112999	P52306	08/23/2015	3:17	08/23/2015	4:21	21	1325	63	Animal related	Fuse	Patrol/Test/Inspect	Replace - Same Size	IV
5113003	K15205	08/23/2015	3:40	08/23/2015	5:30	4	437	109	Tree related-tree broken	Transformer Fuse	Replace - Same Size		VI
5113013	R09226	08/23/2015	4:02	08/23/2015	6:09	13	1658	127	Underground equipment	Underground Primary	Switch/Reset	Repair	III
5113007	344002	08/23/2015	4:40	08/23/2015	6:12	1	91	91	Tree related-tree broken	Overhead Service	Disconnect		VI
5113009	A56013	08/23/2015	4:43	08/23/2015	5:35	1	51	51	Overhead equipment	Overhead Service	Replace - Same Size		I
5113019	P62112	08/23/2015	6:41	08/23/2015	7:34	1	52	52	Animal related	Transformer Fuse	Replace - Same Size		VI
5113021	P57108	08/23/2015	6:49	08/23/2015	7:35	1	45	45	Animal related	Transformer Fuse	Replace - Same Size		VI
5113023	T12527	08/23/2015	6:50	08/23/2015	8:20	77	6866	89	Animal related	Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
5113031	B27009	08/23/2015	7:00	08/23/2015	8:10	1	69	69	Overhead equipment	Overhead Service	Replace - Same Size		I
5113035	K89143	08/23/2015	7:23	08/23/2015	8:49	47	4065	86	Unknown	Fuse	Replace - Same Size		III
5113041	M18216	08/23/2015	7:30	08/23/2015	9:51	1	140	140	Unknown	Transformer Fuse	Repair		III
5113043	H14343	08/23/2015	8:01	08/23/2015	12:58	1	296	296	Overhead equipment	Underground Primary	Disconnect	Repair	V
5113047	S36571	08/23/2015	8:25	08/23/2015	9:44	1	78	78	Animal related	Transformer Fuse	Replace - Same Size		VI
5113049	K69112	08/23/2015	8:35	08/23/2015	10:30	1	114	114	Underground equipment	Underground Transformer	Replace - Same Size	Replace - Same Size	IV
5113055	P47123	08/23/2015	8:57	08/23/2015	11:08	1	130	130	Animal related	Fuse	Replace - Same Size	Replace - Same Size	I
5113059	R23334	08/23/2015	9:41	08/23/2015	17:19	2	916	458	Underground equipment	Underground Primary	Patrol/Test/Inspect	Replace - Urgent	V
5113063	W03570	08/23/2015	10:45	08/23/2015	10:55	9	85	9	Tree related-tree contact	Tree	Trim		II
5113067	A81004	08/23/2015	11:11	08/23/2015	12:40	1	88	88	Animal related	Transformer Fuse	Replace - Same Size		I
5113069	N50331	08/23/2015	11:17	08/23/2015	14:23	1	185	185	Underground equipment	Underground Secondary		Repair	II
5113071	V42572	08/23/2015	11:19	08/23/2015	13:50	1	150	150	Tree related-tree broken	Overhead Service	Repair	Raise	II
5113073	Z08509	08/23/2015	11:22	08/23/2015	12:28	1	65	65	Overhead equipment	Transformer Fuse	Repair	Replace - Same Size	IV
5113085	F10003	08/23/2015	12:21	08/23/2015	13:45	1	83	83	Animal related	Transformer Fuse	Replace - Same Size		III
5113087	D32212	08/23/2015	12:29	08/23/2015	13:01	1	31	31	Overhead equipment	Transformer Fuse	Replace - Same Size	Replace - Same Size	I
5113089	K71822	08/23/2015	12:48	08/23/2015	16:06	17	3354	197	Underground equipment	Overhead Primary			IV
5113093	R60552	08/23/2015	13:01	08/23/2015	17:33	7	1900	271	Unknown	Overhead Primary			IV
5113105	348117	08/23/2015	13:52	08/23/2015	14:26	12	403	33	Public	Overhead Secondary	Repair		V
5113107	K95208	08/23/2015	13:55	08/23/2015	15:50	1	114	114	Tree related-tree broken	Tree	Remove		III
5113111	A56017	08/23/2015	14:08	08/23/2015	18:21	72	18185	252	Underground equipment	Underground Primary	Replace - Same Size	Replace - Same Size	I
5113119	P47120	08/23/2015	14:27	08/23/2015	15:54	1	86	86	Animal related	Transformer Fuse	Replace - Same Size	Replace - Same Size	I
5113123	B21003	08/23/2015	14:33	08/23/2015	20:46	1	372	372	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
5113125	M45212	08/23/2015	14:34	08/23/2015	15:49	1	74	74	Unknown	Transformer Fuse	Replace - Same Size		IV
5113127	D60001	08/23/2015	14:44	08/23/2015	15:17	1	32	32	Overhead equipment	Fuse	Replace - Same Size		III
5113131	H07106	08/23/2015	15:01	08/23/2015	18:50	5	1141	228	Unknown				IV
5113133	K71822	08/23/2015	15:16	08/23/2015	16:03	17	791	46	Underground equipment				IV
5113137	A56017	08/23/2015	15:24	08/23/2015	18:32	1	187	187	Underground equipment	Underground Primary	Repair	Replace - Same Size	I
5113139	M36185	08/23/2015	15:26	08/23/2015	17:35	141	11482	129	Public	Pole	Repair		I
5113141	M36185	08/23/2015	15:34	08/23/2015	15:47	1	12	12	Public	Pole	Repair	Replace - Same Size	I
5113143	M36185	08/23/2015	15:38	08/23/2015	15:47	7	57	8	Public	Pole	Repair	Replace - Same Size	I
5113145	M20221	08/23/2015	15:43	08/23/2015	17:15	2	183	91	Overhead equipment	Fuse	Replace - Same Size		VI
5113151	S47575	08/23/2015	16:06	08/23/2015	17:05	1	58	58	Animal related	Transformer Fuse			VI
5113183	N67-X1	08/23/2015	16:19	08/24/2015	1:17	1706	917793	537	Substation equipment	Substation Misc.	Repair		I
5113167	N67-X2	08/23/2015	16:19	08/24/2015	1:17	665	357417	537	Substation equipment	Substation Misc.	Repair		I
5113227	L12127	08/23/2015	16:29	08/23/2015	19:51	33	5840	201	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	III
5113231	R60554	08/23/2015	16:30	08/23/2015	19:22	1	171	171	Unknown				IV
5113241	R33126	08/23/2015	16:54	08/23/2015	20:50	1	235	235	Overhead equipment	Fuse	Replace - Same Size		I
5113245	V45526	08/23/2015	16:57	08/23/2015	18:00	26	1626	62	Unknown	Fuse	Replace - Same Size		II

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5113259	A56017	08/23/2015	17:42	08/23/2015	18:18	1	35	35	Underground equipment	Underground Primary	Repair		I
5113261	L23145	08/23/2015	17:56	08/23/2015	19:24	1	87	87	Overhead equipment	Fuse	Replace - Same Size		III
5113265	A45003	08/23/2015	18:12	08/24/2015	4:34	1	622	622	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
5113275	R73838	08/23/2015	18:40	08/23/2015	20:16	1	95	95	Overhead equipment	Overhead Service	Repair	Repair	V
5113279	R09225	08/23/2015	19:01	08/23/2015	20:13	1	71	71	Overhead equipment	Fuse			III
5113283	A45003	08/23/2015	19:36	08/24/2015	4:36	3	1619	539	Underground equipment	Underground Primary	Repair	Repair	I
5113285	D70006	08/23/2015	19:38	08/23/2015	23:39	98	23590	240	Underground equipment	Underground Primary	Patrol/Test/Inspect	Patrol/Test/Inspect	I
5113289	D70006	08/23/2015	19:40	08/23/2015	23:39	6	1433	238	Underground equipment	Underground Connector	Repair	Repair	I
5113291	D32212	08/23/2015	19:42	08/24/2015	4:54	2	1102	551	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
5113293	N15850	08/23/2015	20:06	08/23/2015	20:58	1	51	51	Overhead equipment	Transformer Fuse	Replace - Same Size		V
5113295	B21002	08/23/2015	20:08	08/23/2015	21:42	1	93	93	Overhead equipment	Overhead Service	Reconnect		I
5113305	Y07003	08/23/2015	20:33	08/24/2015	0:01	1	207	207	Overhead equipment	Tree	Trim	Trim	IV
5113307	V01002	08/23/2015	20:35	08/23/2015	23:33	46	8181	178	Underground equipment	Underground Primary		Replace - Same Size	II
5113313	R09226	08/23/2015	21:25	08/24/2015	0:37	11	2066	192	Underground equipment	Underground Primary			III
5113315	D55003	08/23/2015	21:25	08/23/2015	22:43	1	77	77	Overhead equipment	Overhead Service	Repair		I
5113321	V01002	08/23/2015	23:36	08/23/2015	23:45	1	8	8	Underground equipment				II
5113379	J88165	08/23/2015	23:37	08/24/2015	1:17	8	798	99	Underground equipment	Underground Primary	Repair	Replace - Same Size	VI
5113375	J88165	08/23/2015	23:38	08/24/2015	1:13	24	2260	94	Underground equipment	Overhead Primary	Replace - Same Size		VI
5113329	303001	08/23/2015	23:55	08/24/2015	2:00	59	7349	124	Public	Overhead Primary	Repair		VI
5113335	A91001	08/24/2015	0:16	08/24/2015	1:37	1	80	80	Unknown				I
5113607	A91001	08/24/2015	0:42	08/24/2015	15:17	5	4372	874	Underground equipment	Underground Primary	Repair	Repair	I
5113449	B93001	08/24/2015	0:48	08/24/2015	6:14	175	57058	326	Overhead equipment	Jumper	Patrol/Test/Inspect	Repair	I
5113371	H07106	08/24/2015	1:12	08/24/2015	3:25	1	132	132	Unknown	Transformer Fuse	Replace - Same Size	Replace - Same Size	IV
5113385	A26005	08/24/2015	1:20	08/24/2015	7:34	6	2245	374	Underground equipment	Other	Patrol/Test/Inspect	Patrol/Test/Inspect	I
5113389	A91001	08/24/2015	1:54	08/24/2015	2:56	17	1050	61	Underground equipment	Fuse		Replace - Same Size	I
5113431	R93351	08/24/2015	2:26	08/24/2015	6:13	644	146574	227	Animal related	Substation Breaker	Switch/Reset		V
5113447	R93350	08/24/2015	2:27	08/24/2015	4:51	101	14607	144	Animal related				V
5113457	A91001	08/24/2015	2:56	08/24/2015	6:54	12	2849	237	Underground equipment	Underground Primary	Repair	Repair	I
5113463	K46388	08/24/2015	3:03	08/24/2015	5:25	1	141	141	Public				V
5113465	B25002	08/24/2015	3:12	08/24/2015	4:39	1	86	86	Unknown	Fuse	Replace - Same Size		I
5113489	H11339	08/24/2015	4:53	08/24/2015	5:45	35	1819	51	Animal related				V
5113487	H11339	08/24/2015	4:53	08/24/2015	5:45	18	935	51	Animal related				V
5113485	H11339	08/24/2015	4:53	08/24/2015	5:45	48	2495	51	Animal related				V
5113665	A26005	08/24/2015	4:55	08/24/2015	12:24	1	448	448	Underground equipment	Underground Primary	Repair	Repair	I
5113497	U41517	08/24/2015	6:18	08/24/2015	7:49	1	90	90	Overhead equipment	Transformer Fuse	Repair		II
5113911	Q80354	08/24/2015	6:28	08/24/2015	14:59	396	202506	511	Overhead equipment	Pole	Repair	Replace - Same Size	V
5113501	Q80352	08/24/2015	6:28	08/24/2015	7:20	1	51	51	Overhead equipment				V
5113503	Q80352	08/24/2015	6:28	08/24/2015	7:20	1	51	51	Overhead equipment				V
5113639	J34377	08/24/2015	6:29	08/24/2015	7:20	70	3501	50	Overhead equipment	Pole	Repair	Replace - Same Size	V
5113691	J34377	08/24/2015	6:30	08/24/2015	9:07	1	156	156	Overhead equipment				V
5113689	J34377	08/24/2015	6:31	08/24/2015	7:20	54	2616	48	Overhead equipment				V
5113611	R59415	08/24/2015	6:34	08/24/2015	7:40	226	14807	65	Overhead equipment	Fuse	Replace - Same Size		IV
5113687	J34377	08/24/2015	6:36	08/24/2015	7:20	5	218	43	Overhead equipment	Pole	Repair	Replace - Same Size	V
5113583	Q04411	08/24/2015	6:41	08/24/2015	8:51	1	129	129	Overhead equipment	Transformer Fuse	Repair	Repair	III
5113593	H07106	08/24/2015	6:48	08/24/2015	8:10	1	81	81	Overhead equipment	Overhead Primary	Patrol/Test/Inspect	Repair	IV
5113655	R59415	08/24/2015	6:48	08/24/2015	7:39	9	457	50	Unknown				IV
5113693	J34377	08/24/2015	6:48	08/24/2015	7:20	1	31	31	Overhead equipment	Pole	Repair	Replace - Same Size	V
5113629	J34377	08/24/2015	6:51	08/24/2015	9:53	9	1637	181	Overhead equipment	Pole	Repair	Replace - Same Size	V
5113619	M09143	08/24/2015	7:10	08/24/2015	8:37	11	953	86	Animal related	Fuse	Replace - Same Size		VI
5113657	Q80352	08/24/2015	7:26	08/24/2015	9:07	1	100	100	Overhead equipment				V
5113659	H11340	08/24/2015	7:28	08/24/2015	9:51	5	712	142	Animal related	Fuse	Replace - Same Size		V
5113669	V78513	08/24/2015	7:38	08/24/2015	12:57	1	318	318	Underground equipment	Underground Primary	Repair	Repair	II
5113679	S84535	08/24/2015	8:05	08/24/2015	8:30	1	24	24	Overhead equipment	Fuse	Replace - Same Size		VI
5155129	R04413	08/24/2015	8:27	08/25/2015	11:58	36	59429	1650	Public				V
5113697	J15303	08/24/2015	8:30	08/24/2015	16:02	1	451	451	Underground equipment	Underground Primary	Repair		I
5113701	D35003	08/24/2015	8:39	08/24/2015	11:08	1	148	148	Unknown	Fuse			I

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5113711	HD5254	08/24/2015	8:48	08/24/2015	10:42	19	2150	113	Overhead equipment	Fuse	Repair	Repair	VI
5113723	HD5254	08/24/2015	8:49	08/24/2015	10:36	71	7646	107	Animal related	Fuse	Replace - Same Size		VI
5113729	L08225	08/24/2015	9:02	08/24/2015	10:15	1	72	72	Tree related-tree broken	Overhead Service	Repair		III
5113733	J34356	08/24/2015	9:08	08/24/2015	13:08	1	239	239	Animal related	Transformer Fuse	Replace - Same Size	Replace - Same Size	V
5113751	P20913	08/24/2015	9:13	08/24/2015	10:49	14	1341	95	Animal related	Fuse	Replace - Same Size		VI
5113745	J05139	08/24/2015	9:16	08/24/2015	9:58	1	41	41	Animal related	Transformer Fuse	Replace - Same Size		I
5113757	Q82907	08/24/2015	9:32	08/24/2015	12:05	1	152	152	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	VI
5113771	B65004	08/24/2015	9:35	08/24/2015	14:47	9	2807	311	Underground equipment				I
5113783	Q82907	08/24/2015	9:40	08/24/2015	10:27	1	46	46	Overhead equipment	Overhead Transformer	Replace - Same Size	Replace - Same Size	VI
5113789	K39156	08/24/2015	9:47	08/24/2015	10:36	1	48	48	Other	Other			III
5113793	Z08509	08/24/2015	9:53	08/24/2015	10:40	1	46	46	Animal related	Transformer Fuse	Repair	Replace - Same Size	IV
5113795	D88001	08/24/2015	10:01	08/24/2015	11:17	6	450	75	Overhead equipment	Fuse	Replace - Same Size		I
5113799	Q23255	08/24/2015	10:10	08/24/2015	12:02	1	111	111	Overhead equipment	Transformer Fuse	Repair	Repair	VI
5113805	D72001	08/24/2015	10:15	08/24/2015	10:47	1	31	31	Overhead equipment				I
5113815	HD5254	08/24/2015	10:22	08/24/2015	10:41	1	18	18	Animal related				VI
5113817	T04514	08/24/2015	10:24	08/24/2015	10:34	1	9	9	Other	Other			VI
5113827	U52516	08/24/2015	10:34	08/24/2015	14:22	1	228	228	Underground equipment	Underground Primary	Repair	Repair	II
5113829	U52516	08/24/2015	10:34	08/24/2015	11:15	31	1272	41	Underground equipment	Fuse	Replace - Same Size		II
5113837	HD5254	08/24/2015	10:45	08/24/2015	10:54	1	8	8	Animal related				VI
5113907	D55002	08/24/2015	11:14	08/24/2015	17:18	4	1455	363	Underground equipment	Underground Primary	Repair	Repair	I
5113857	J14140	08/24/2015	11:15	08/24/2015	13:05	1	109	109	Weather	Fuse	Replace - Same Size		VI
5113861	Y66557	08/24/2015	11:30	08/24/2015	12:07	4	147	36	Tree related-tree contact	Overhead Secondary			IV
5113873	Q16867	08/24/2015	12:09	08/24/2015	13:00	1	50	50	Animal related	Transformer Fuse	Replace - Same Size	Replace - Same Size	V
5113877	R34920	08/24/2015	12:10	08/24/2015	14:24	2	266	133	Public	Transformer Fuse	Replace - Same Size		VI
5113903	B76001	08/24/2015	12:47	08/24/2015	13:42	43	2331	54	Overhead equipment	Jumper	Repair		I
5113905	K08909	08/24/2015	12:56	08/24/2015	14:43	1	106	106	Overhead equipment	Connector			VI
5113925	Y98002	08/24/2015	13:27	08/24/2015	14:15	1	47	47	Overhead equipment	Overhead Service	Repair		IV
5113929	Q06144	08/24/2015	13:30	08/24/2015	14:50	1	79	79	Animal related	Fuse	Replace - Same Size		IV
5113939	X88507	08/24/2015	13:39	08/24/2015	16:11	1	151	151	Tree related-tree contact	Overhead Service	Repair		IV
5114011	D39002	08/24/2015	13:49	08/24/2015	15:44	69	7894	114	Unknown	Fuse			I
5113965	Q54908	08/24/2015	13:58	08/24/2015	16:34	1	155	155	Overhead equipment	Connector	Replace - New Size		VI
5113975	S13549	08/24/2015	14:03	08/24/2015	14:16	1	12	12	Other				VI
5113989	C70004	08/24/2015	14:14	08/24/2015	15:12	1	57	57	Overhead equipment	Connector	Replace - Same Size		III
5113997	J01118	08/24/2015	14:20	08/24/2015	15:37	1	76	76	Tree related-tree broken	Overhead Secondary	Repair	Replace - Same Size	I
5114017	S16597	08/24/2015	14:36	08/24/2015	14:50	1	13	13	Other				VI
5113765	Q80354	08/24/2015	14:58	08/24/2015	15:08	1	9	9	Overhead equipment	Pole	Repair	Replace - Same Size	V
5114039	P69174	08/24/2015	15:03	08/24/2015	15:45	1	41	41	Animal related	Transformer Fuse	Replace - Same Size		III
5114053	B19002	08/24/2015	15:34	08/24/2015	17:13	1	98	98	Overhead equipment	Fuse	Replace - Same Size		I
5114055	Q32170	08/24/2015	15:35	08/24/2015	17:11	9	864	96	Public	Pole	Repair	Replace - Same Size	I
5114063	M20221	08/24/2015	16:18	08/24/2015	17:48	1	89	89	Overhead equipment	Transformer Fuse	Replace - Same Size		VI
5114065	B28006	08/24/2015	16:21	08/24/2015	18:17	1	115	115	Overhead equipment				I
5114067	C52002	08/24/2015	16:31	08/24/2015	19:10	6	948	158	Overhead equipment	Overhead Primary		Repair	III
5114069	H22349	08/24/2015	16:39	08/24/2015	23:15	1	395	395	Underground equipment	Underground Service	Patrol/Test/Inspect	Repair	V
5114087	F03003	08/24/2015	17:20	08/24/2015	18:55	1	94	94	Overhead equipment	Connector	Replace - Same Size		III
5114093	U10525	08/24/2015	17:50	08/24/2015	19:30	1	99	99	Jurisdictional	Fuse	Replace - Same Size		II
5114099	U13551	08/24/2015	18:05	08/24/2015	19:36	1	90	90	Overhead equipment	Overhead Service	Repair		II
5114101	Q82906	08/24/2015	18:05	08/24/2015	23:36	1	330	330	Tree related-tree broken	Fuse			VI
5114105	J12166	08/24/2015	18:16	08/24/2015	20:29	1	132	132	Overhead equipment	Overhead Transformer		Replace - Same Size	III
5114109	L23145	08/24/2015	19:08	08/24/2015	20:06	1	57	57	Unknown	Transformer Fuse	Replace - Same Size		III
5114111	U86500	08/24/2015	19:58	08/24/2015	20:50	1	51	51	Overhead equipment	Overhead Service	Repair	Repair	II
5114115	M81405	08/24/2015	20:20	08/25/2015	0:52	1	271	271	Underground equipment	Overhead Service	Patrol/Test/Inspect	Repair	V
5114127	L70128	08/24/2015	20:35	08/24/2015	21:44	122	8446	69	Public				IV
5114125	L70128	08/24/2015	20:41	08/24/2015	21:40	1	58	58	Public	Pole	Replace - Same Size	Replace - Same Size	IV
5114145	L70128	08/24/2015	20:50	08/24/2015	21:40	1	49	49	Overhead equipment	Pole	Replace - Same Size	Replace - Same Size	IV
5114149	P47120	08/24/2015	21:03	08/25/2015	1:46	10	2825	282	Public	Overhead Secondary	Repair	Repair	I
5114169	L70128	08/24/2015	21:45	08/25/2015	4:05	1	379	379	Overhead equipment	Pole		Replace - Same Size	IV

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5114183	X60596	08/24/2015	23:10	08/25/2015	1:55	27	4442	164	Underground equipment	Underground Primary	Switch/Reset	Switch/Reset	IV
5114179	V40556	08/24/2015	23:14	08/25/2015	0:45	1	90	90	Animal related	Transformer Fuse	Replace - Same Size		II
5114185	V40556	08/24/2015	23:35	08/25/2015	0:44	1	68	68	Animal related	Transformer Fuse	Replace - Same Size		II
5114191	R61242	08/24/2015	23:45	08/25/2015	1:50	16	1996	124	Underground equipment	Underground Primary	Switch/Reset	Repair	IV
5114189	A49001	08/24/2015	23:53	08/25/2015	0:57	20	1284	64	Other	Pole	Repair	Replace - Same Size	I
5114193	M07235	08/25/2015	0:56	08/25/2015	6:00	1	303	303	Animal related	Transformer Fuse	Replace - Same Size		III
5114197	335002	08/25/2015	1:02	08/25/2015	5:45	1	282	282	Public	Overhead Secondary	Patrol/Test/Inspect	Replace - Same Size	VI
5114199	X34530	08/25/2015	1:21	08/25/2015	3:00	3	294	98	Animal related	Transformer Fuse	Replace - Same Size		IV
5114201	K80381	08/25/2015	1:22	08/25/2015	6:27	37	11282	304	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	IV
5114207	U06524	08/25/2015	5:30	08/25/2015	11:15	8	2757	344	Underground equipment	Underground Primary	Repair	Repair	II
5114209	V46552	08/25/2015	5:57	08/25/2015	9:59	1	242	242	Underground equipment				II
5114211	335003	08/25/2015	6:14	08/25/2015	7:13	2	117	58	Overhead equipment	Fuse	Replace - Same Size		VI
5114215	U86500	08/25/2015	7:33	08/25/2015	9:04	1	90	90	Overhead equipment	Transformer Fuse	Repair	Repair	II
5114217	B45005	08/25/2015	7:37	08/25/2015	8:17	1	39	39	Unknown	Fuse	Replace - Same Size		I
5114221	Q64919	08/25/2015	7:50	08/25/2015	9:20	1	89	89	Underground equipment	Underground Primary	Repair		VI
5114247	P77233	08/25/2015	8:58	08/25/2015	10:02	1	63	63	Animal related	Fuse	Patrol/Test/Inspect		VI
5114267	Q23258	08/25/2015	9:24	08/25/2015	10:54	1	89	89	Animal related	Fuse	Replace - Same Size		VI
5114269	B82001	08/25/2015	9:29	08/25/2015	13:53	1	263	263	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
5114301	T59942	08/25/2015	9:35	08/25/2015	10:34	65	3779	58	Animal related	Recloser	Replace - Same Size		VI
5114299	N54214	08/25/2015	9:47	08/25/2015	13:00	43	7029	192	Underground equipment	Underground Primary	Switch/Reset	Repair	II
5114317	B19002	08/25/2015	10:09	08/25/2015	12:40	1	150	150	Animal related	Transformer Fuse	Replace - Same Size		I
5114349	P62138	08/25/2015	11:12	08/25/2015	12:04	1	51	51	Overhead equipment	Fuse	Replace - Same Size		VI
5114351	D28123	08/25/2015	11:14	08/25/2015	12:43	1	88	88	Overhead equipment	Lightning Arrestor	Replace - Same Size		I
5114369	R99180	08/25/2015	11:47	08/25/2015	12:52	8	513	64	Underground equipment	Underground Primary	Switch/Reset	Repair	IV
5114377	J99121	08/25/2015	12:09	08/25/2015	18:26	16	6024	376	Underground equipment	Underground Primary		Repair	VI
5114381	B82001	08/25/2015	12:28	08/25/2015	13:53	1	85	85	Underground equipment	Underground Primary	Repair		I
5114393	J47175	08/25/2015	13:01	08/25/2015	14:59	11	1293	117	Overhead equipment	Overhead Transformer			III
5114403	C66002	08/25/2015	13:34	08/25/2015	19:30	1	355	355	Underground equipment	Underground Transformer	Repair	Replace - Same Size	III
5114413	G10001	08/25/2015	13:46	08/25/2015	14:24	1	37	37	Other	Other			I
5114425	V84509	08/25/2015	14:06	08/25/2015	16:04	5	585	117	Animal related	Transformer Fuse	Replace - Same Size		II
5114431	332005	08/25/2015	14:20	08/25/2015	15:58	1	97	97	Overhead equipment	Overhead Service	Repair		VI
5114435	L93132	08/25/2015	14:28	08/25/2015	15:30	54	3330	61	Jurisdictional	Underground Primary	Switch/Reset		VI
5114481	P60170	08/25/2015	15:58	08/25/2015	17:42	1	103	103	Public	Overhead Service	Disconnect		VI
5114495	Q69926	08/25/2015	17:01	08/25/2015	17:11	1	9	9	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	VI
5114507	G50001	08/25/2015	17:42	08/25/2015	23:15	1	332	332	Underground equipment	Overhead Secondary	Patrol/Test/Inspect	Repair	IV
5114513	R24832	08/25/2015	17:53	08/25/2015	18:58	12	780	65	Animal related	Fuse	Replace - Same Size	Repair	V
5114521	B45005	08/25/2015	18:56	08/25/2015	22:46	1	229	229	Overhead equipment	Connector	Repair		I
5114525	S49549	08/25/2015	19:11	08/25/2015	20:45	1	93	93	Overhead equipment	Disconnect Switch	Repair	Repair	VI
5114533	C66002	08/25/2015	19:37	08/25/2015	22:31	1	173	173	Overhead equipment				III
5114535	N50334	08/25/2015	19:38	08/25/2015	20:30	1	51	51	Overhead equipment	Connector	Replace - Same Size		II
5114537	J01118	08/25/2015	19:42	08/25/2015	22:19	1	156	156	Unknown	Transformer Fuse	Replace - Same Size		I
5114539	N95824	08/25/2015	19:44	08/25/2015	20:56	1	71	71	Overhead equipment	Transformer Fuse	Replace - Same Size		V
5114541	Q69926	08/25/2015	19:45	08/25/2015	19:48	105	286	2	Overhead equipment				VI
5114551	C66002	08/25/2015	20:01	08/25/2015	22:30	1	148	148	Underground equipment	Underground Primary			III
5114571	N54214	08/25/2015	22:47	08/26/2015	2:55	89	22062	248	Underground equipment	Underground Primary	Switch/Reset	Repair	II
5114577	U02597	08/26/2015	0:51	08/26/2015	2:30	1	98	98	Overhead equipment	Transformer Fuse	Replace - Same Size	Patrol/Test/Inspect	II
5114587	Y84-XTR1	08/26/2015	2:56	08/26/2015	3:10	365	5102	13	Jurisdictional				IV
5114593	Y85-XTR1	08/26/2015	2:56	08/26/2015	3:10	1	13	13	Jurisdictional				IV
5114597	Y88-XTR1	08/26/2015	2:56	08/26/2015	3:10	1	13	13	Jurisdictional				IV
5114595	X80-XTR1	08/26/2015	2:56	08/26/2015	3:10	1	13	13	Jurisdictional				IV
5114599	307004	08/26/2015	5:55	08/26/2015	6:58	1	62	62	Overhead equipment	Fuse	Replace - Same Size		VI
5114605	Q54908	08/26/2015	7:08	08/26/2015	8:11	1	62	62	Overhead equipment	Transformer Fuse	Replace - Same Size		VI
5114607	G50002	08/26/2015	7:25	08/26/2015	9:04	1	98	98	Public	Pole	Patrol/Test/Inspect	Repair	IV
5114613	R49261	08/26/2015	8:02	08/26/2015	8:45	1	42	42	Animal related	Fuse	Replace - Same Size		VI
5114635	A49001	08/26/2015	8:05	08/26/2015	10:49	7	1144	163	Overhead equipment	Fuse	Replace - Same Size		I
5114623	R49261	08/26/2015	8:39	08/26/2015	8:46	1	6	6	Animal related	Fuse	Replace - Same Size		VI

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5114637	343008	08/26/2015	8:57	08/26/2015	11:00	1	122	122	Tree related-tree broken	Tree	Remove		VI
5114643	H10843	08/26/2015	9:13	08/26/2015	11:16	1	122	122	Animal related	Transformer Fuse	Replace - Same Size		V
5114645	U02597	08/26/2015	9:23	08/26/2015	10:30	1	66	66	Animal related	Transformer Fuse	Replace - Same Size		II
5114647	R53390	08/26/2015	9:25	08/26/2015	10:05	1	39	39	Animal related	Fuse	Replace - Same Size	Replace - Same Size	V
5114649	B93002	08/26/2015	9:29	08/26/2015	10:28	1	58	58	Unknown	Fuse	Replace - Same Size		I
5114679	X72536	08/26/2015	10:30	08/26/2015	11:12	1	41	41	Animal related	Transformer Fuse	Replace - Same Size		IV
5114681	P12290	08/26/2015	10:36	08/26/2015	12:42	1	125	125	Intentional	Meter	Replace - Same Size	Replace - Same Size	V
5114683	P52305	08/26/2015	10:42	08/26/2015	14:34	1	232	232	Underground equipment	Underground Primary	Repair		IV
5114685	338004	08/26/2015	10:44	08/26/2015	10:47	2	5	2	Unknown				VI
5114693	A49003	08/26/2015	10:51	08/26/2015	16:35	1	343	343	Underground equipment	Underground Service	Patrol/Test/Inspect	Reconnect	I
5114695	S31561	08/26/2015	10:52	08/26/2015	12:40	1	107	107	Animal related	Transformer Fuse	Replace - Same Size		VI
5114707	B93002	08/26/2015	11:19	08/26/2015	14:11	1	171	171	Animal related	Fuse	Replace - Same Size		I
5114709	S31527	08/26/2015	11:22	08/26/2015	13:00	1	97	97	Unknown	Customer Equipment	Replace - Same Size		VI
5114715	Q15845	08/26/2015	11:27	08/26/2015	12:10	1	42	42	Intentional				V
5114719	X92508	08/26/2015	11:51	08/26/2015	13:10	9	710	78	Overhead equipment	Fuse	Repair	Replace - Same Size	IV
5114721	D69004	08/26/2015	11:56	08/26/2015	17:33	1	336	336	Underground equipment	Underground Transformer	Patrol/Test/Inspect	Patrol/Test/Inspect	I
5114725	X92508	08/26/2015	12:06	08/26/2015	13:05	2	117	58	Overhead equipment	Fuse	Repair	Replace - Same Size	IV
5114727	Y89535	08/26/2015	12:12	08/26/2015	13:14	1	61	61	Overhead equipment	Jumper	Repair	Replace - Same Size	IV
5114731	B84001	08/26/2015	12:28	08/26/2015	20:33	2	969	484	Underground equipment	Underground Primary	Patrol/Test/Inspect	Reconnect	I
5114761	B62002	08/26/2015	13:21	08/26/2015	14:25	1	63	63	Animal related	Transformer Fuse	Replace - Same Size		I
5114777	L70127	08/26/2015	13:46	08/26/2015	14:22	1	35	35	Animal related	Fuse	Replace - Same Size		IV
5114781	A80001	08/26/2015	14:06	08/26/2015	15:00	1	53	53	Unknown	Fuse	Repair	Replace - Same Size	I
5114797	K89142	08/26/2015	14:32	08/26/2015	15:13	692	28565	41	Unknown	Recloser	Switch/Reset		III
5114799	K46388	08/26/2015	14:34	08/26/2015	20:30	1	355	355	Underground equipment	Underground Service		Repair	V
5114801	X88510	08/26/2015	14:36	08/26/2015	14:57	1	20	20	Animal related	Transformer Fuse	Replace - Same Size		IV
5114803	P26284	08/26/2015	14:40	08/26/2015	15:40	1	59	59	Animal related	Fuse	Replace - Same Size	Replace - Same Size	I
5114813	P20930	08/26/2015	14:46	08/26/2015	16:31	1	104	104	Animal related	Fuse		Patrol/Test/Inspect	VI
5114817	P77237	08/26/2015	14:48	08/26/2015	21:09	1	380	380	Underground equipment	Underground Service	Disconnect	Repair	VI
5114833	346002	08/26/2015	15:05	08/26/2015	16:38	1	92	92	Overhead equipment	Overhead Service	Repair		VI
5114837	P26284	08/26/2015	15:09	08/26/2015	15:40	1	30	30	Animal related	Fuse	Replace - Same Size	Replace - Same Size	I
5114843	341002	08/26/2015	15:12	08/26/2015	18:34	1	201	201	Public	Overhead Secondary	Patrol/Test/Inspect	Repair	VI
5114845	P47123	08/26/2015	15:13	08/26/2015	16:51	1	97	97	Animal related	Transformer Fuse	Replace - Same Size	Patrol/Test/Inspect	I
5114865	N60172	08/26/2015	15:42	08/26/2015	18:30	1	167	167	Overhead equipment	Overhead Transformer	Replace - Same Size	Replace - Same Size	I
5114867	H88101	08/26/2015	15:51	08/26/2015	19:35	2	446	223	Overhead equipment	Transformer Fuse	Replace - Same Size		II
5114873	K30204	08/26/2015	16:02	08/26/2015	17:45	1	103	103	Public	Fuse	Replace - Same Size		III
5114879	N93260	08/26/2015	16:13	08/26/2015	18:46	13	1978	152	Overhead equipment	Fuse			III
5114885	B62003	08/26/2015	16:25	08/27/2015	0:48	1	502	502	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
5114887	Q69926	08/26/2015	16:26	08/26/2015	20:43	1	256	256	Overhead equipment	Fuse		Patrol/Test/Inspect	VI
5114913	K30204	08/26/2015	16:53	08/26/2015	21:03	3	750	250	Public	Fuse	Replace - Same Size		III
5114893	S34528	08/26/2015	16:55	08/26/2015	18:00	1	64	64	Overhead equipment	Disconnect Switch			VI
5114907	U04538	08/26/2015	17:23	08/26/2015	19:49	2	290	145	Public	Overhead Primary	Replace - Same Size	Repair	II
5114909	J47175	08/26/2015	17:26	08/26/2015	19:50	9	1288	143	Overhead equipment	Overhead Transformer			III
5114915	K30204	08/26/2015	17:36	08/26/2015	17:54	1	17	17	Public	Fuse	Replace - Same Size		III
5114921	N93260	08/26/2015	18:20	08/26/2015	18:47	1	26	26	Overhead equipment	Fuse			III
5114923	J88163	08/26/2015	18:34	08/26/2015	19:11	1	36	36	Animal related	Fuse	Replace - Same Size		VI
5114927	B62003	08/26/2015	19:11	08/27/2015	0:47	4	1343	335	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
5114945	N73121	08/26/2015	19:52	08/26/2015	20:49	7	403	57	Overhead equipment				IV
5114959	N18211	08/26/2015	21:17	08/26/2015	22:42	295	25024	84	Animal related	Overhead Primary	Replace - Same Size		III
5115049	K08909	08/26/2015	22:00	08/27/2015	4:00	8	2219	360	Tree related-tree broken	Fuse		Patrol/Test/Inspect	VI
5115095	C40002	08/27/2015	0:17	08/27/2015	2:00	1239	127369	102	Underground equipment	Underground Primary	Repair	Replace - Same Size	I
5115137	J99128	08/27/2015	1:22	08/27/2015	2:52	1	89	89	Animal related	Transformer Fuse	Replace - Same Size		VI
5115143	HA5430	08/27/2015	1:46	08/27/2015	5:48	44	10646	241	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	V
5115149	C66001	08/27/2015	5:09	08/27/2015	6:44	34	3201	94	Animal related	Fuse	Replace - Same Size		III
5115155	C66001	08/27/2015	5:45	08/27/2015	6:48	1	62	62	Animal related	Fuse	Replace - Same Size		III
5115157	L50215	08/27/2015	6:01	08/27/2015	7:21	1	79	79	Animal related	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
5115159	C66001	08/27/2015	6:28	08/27/2015	6:53	1	24	24	Animal related	Fuse	Replace - Same Size		III

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5115213	B73002	08/27/2015	6:33	08/27/2015	8:23	810	88881	109	Animal related	Overhead Primary	Repair	Repair	I
5115183	D89002	08/27/2015	6:44	08/27/2015	7:46	1	61	61	Animal related	Fuse	Replace - Same Size		I
5115189	K95205	08/27/2015	7:15	08/27/2015	8:19	1	63	63	Public				III
5115353	M18130	08/27/2015	7:59	08/27/2015	10:25	8	1165	145	Tree related-tree contact	Overhead Secondary	Repair		III
5115217	B73002	08/27/2015	7:59	08/27/2015	10:54	127	22208	174	Animal related	Overhead Primary	Repair		I
5115209	K28180	08/27/2015	8:17	08/27/2015	8:58	1	40	40	Other	Other			III
5115211	G50002	08/27/2015	8:21	08/27/2015	9:44	61	5083	83	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	IV
5115221	B19002	08/27/2015	8:25	08/27/2015	10:54	1	148	148	Animal related	Overhead Primary	Repair		I
5115223	Q80352	08/27/2015	8:27	08/27/2015	14:11	13	4476	344	Tree related-tree contact	Tree		Trim	V
5115225	B19002	08/27/2015	8:28	08/27/2015	10:54	1	145	145	Animal related	Overhead Primary	Repair		I
5115227	D31018	08/27/2015	8:28	08/27/2015	14:52	3	1152	384	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	III
5115241	B21004	08/27/2015	8:38	08/27/2015	10:02	1	83	83	Animal related	Transformer Fuse	Replace - Same Size		I
5115259	B19002	08/27/2015	8:48	08/27/2015	10:54	1	125	125	Animal related	Overhead Primary	Repair		I
5115269	B19002	08/27/2015	9:03	08/27/2015	10:54	1	110	110	Animal related	Overhead Primary	Repair		I
5115271	C65001	08/27/2015	9:03	08/27/2015	10:05	4	244	61	Animal related	Fuse	Replace - Same Size		III
5115273	Y89541	08/27/2015	9:08	08/27/2015	10:00	1	51	51	Overhead equipment	Transformer Fuse	Repair	Replace - Same Size	IV
5115279	C65001	08/27/2015	9:10	08/27/2015	10:07	1	56	56	Animal related	Fuse	Replace - Same Size		III
5115281	C65001	08/27/2015	9:13	08/27/2015	10:09	7	389	55	Animal related	Fuse	Replace - Same Size		III
5115283	S31532	08/27/2015	9:19	08/27/2015	11:16	4	467	116	Animal related	Fuse	Replace - Same Size		VI
5115299	343006	08/27/2015	9:35	08/27/2015	9:43	2	16	8	Overhead equipment				VI
5115309	C65001	08/27/2015	9:42	08/27/2015	10:10	1	27	27	Animal related	Fuse	Replace - Same Size		III
5115311	X75571	08/27/2015	9:43	08/27/2015	13:45	8	1929	241	Underground equipment	Underground Primary	Repair	Repair	IV
5115319	B19002	08/27/2015	9:52	08/27/2015	10:54	1	61	61	Animal related	Overhead Primary	Repair		I
5115329	N35851	08/27/2015	10:00	08/27/2015	12:17	1	136	136	Other	Meter	Patrol/Test/Inspect		V
5115365	Y79500	08/27/2015	10:36	08/27/2015	11:59	4	331	82	Underground equipment	Underground Service	Repair	Replace - Same Size	IV
5115385	D69004	08/27/2015	11:09	08/27/2015	12:05	1	55	55	Underground equipment	Other	Repair	Repair	I
5115387	X49570	08/27/2015	11:13	08/27/2015	12:36	1	82	82	Animal related	Transformer Fuse	Replace - Same Size		IV
5115391	P10-UNIT-1	08/27/2015	11:20	08/27/2015	11:23	1	2	2	Unknown				V
5115399	A17021	08/27/2015	11:32	08/27/2015	13:09	1	96	96	Overhead equipment	Tree	Trim		I
5115403	308003	08/27/2015	11:36	08/27/2015	15:12	1	215	215	Weather	Disconnect Switch	Patrol/Test/Inspect	Replace - New Size	VI
5115409	S21529	08/27/2015	11:47	08/27/2015	15:55	1	247	247	Underground equipment	Underground Transformer	Repair	Replace - Same Size	VI
5115427	N54214	08/27/2015	12:09	08/27/2015	14:30	26	3678	141	Underground equipment	Underground Primary	Switch/Reset	Repair	II
5115421	N15850	08/27/2015	12:23	08/27/2015	14:28	1	125	125	Underground equipment	Underground Transformer	Repair	Replace - Same Size	V
5115425	Q64919	08/27/2015	12:24	08/27/2015	18:58	1	393	393	Overhead equipment	Overhead Transformer	Replace - Same Size	Replace - Same Size	VI
5115429	Y39515	08/27/2015	12:29	08/27/2015	13:20	1	50	50	Overhead equipment	Fuse	Replace - Same Size		IV
5115453	S83532	08/27/2015	13:14	08/27/2015	14:30	7	531	75	Animal related	Fuse	Replace - Same Size		VI
5115495	X34530	08/27/2015	14:04	08/27/2015	14:46	1	41	41	Unknown	Transformer Fuse	Replace - Same Size		IV
5115497	V40549	08/27/2015	14:16	08/27/2015	15:02	1	45	45	Tree related-tree broken	Overhead Primary			II
5115505	V40549	08/27/2015	14:17	08/27/2015	15:13	21	1163	55	Tree related-tree broken	Overhead Primary			II
5115535	D89002	08/27/2015	15:05	08/27/2015	22:42	40	4836	456	Underground equipment	Underground Primary			I
5115547	V34001	08/27/2015	15:48	08/27/2015	18:04	6	815	135	Public	Overhead Secondary	Replace - Same Size		II
5115601	B62002	08/27/2015	17:01	08/28/2015	2:01	3	1620	540	Underground equipment	Underground Primary	Repair		I
5115571	B62002	08/27/2015	17:05	08/27/2015	20:02	2	354	177	Underground equipment	Underground Primary			I
5115583	341001	08/27/2015	17:51	08/27/2015	20:21	6	896	149	Public	Overhead Transformer	Switch/Reset		VI
5115585	J99121	08/27/2015	18:02	08/27/2015	18:40	4	149	37	Overhead equipment	Overhead Primary	Replace - Same Size	Replace - Same Size	VI
5115589	Q06142	08/27/2015	18:59	08/27/2015	21:26	1	146	146	Overhead equipment	Connector	Repair		IV
5115597	D28124	08/27/2015	19:38	08/28/2015	3:36	1	477	477	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect		I
5115603	Q82906	08/27/2015	19:57	08/27/2015	23:25	1	207	207	Overhead equipment	Overhead Transformer	Replace - New Size	Repair	VI
5115611	A36002	08/27/2015	20:11	08/27/2015	21:50	14	1378	98	Unknown	Fuse	Replace - Same Size		I
5115613	P98191	08/27/2015	20:48	08/28/2015	0:45	1	236	236	Underground equipment	Underground Service			III
5115615	U41545	08/27/2015	20:50	08/27/2015	22:03	1	72	72	Overhead equipment	Overhead Service	Repair		II
5115619	L16213	08/27/2015	21:06	08/27/2015	23:05	10	1180	118	Overhead equipment	Overhead Secondary			III
5115621	K22173	08/27/2015	22:05	08/28/2015	0:54	1	168	168	Tree related-tree broken	Overhead Service	Repair		VI
5115631	A81004	08/27/2015	23:38	08/28/2015	2:33	23	4011	174	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
5115641	U11531	08/28/2015	4:50	08/28/2015	8:45	1	234	234	Underground equipment	Underground Service	Repair	Replace - Same Size	II
5115645	R58931	08/28/2015	4:55	08/28/2015	6:30	1	94	94	Overhead equipment	Fuse	Replace - New Size		IV

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5115647	U10547	08/28/2015	5:19	08/28/2015	7:40	1	140	140	Animal related	Transformer Fuse	Replace - Same Size	Replace - Same Size	II
5115651	J15302	08/28/2015	5:56	08/28/2015	7:10	1	73	73	Overhead equipment	Connector	Repair		I
5115653	T06504	08/28/2015	6:28	08/28/2015	8:30	35	4235	121	Overhead equipment				VI
5115657	HB6283	08/28/2015	6:43	08/28/2015	7:11	12	324	27	Animal related	Fuse			VI
5115669	R08910	08/28/2015	8:01	08/28/2015	10:25	1	143	143	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	VI
5115671	V23522	08/28/2015	8:06	08/28/2015	11:29	1	202	202	Underground equipment	Underground Service	Patrol/Test/Inspect	Repair	II
5115673	Q85162	08/28/2015	8:13	08/28/2015	9:03	1	49	49	Overhead equipment	Transformer Fuse	Repair	Repair	VI
5115677	Z30584	08/28/2015	8:17	08/28/2015	10:33	1	135	135	Overhead equipment	Connector	Replace - Same Size		IV
5115689	L42158	08/28/2015	8:44	08/28/2015	9:41	1	56	56	Animal related	Transformer Fuse	Repair		III
5115701	U80001	08/28/2015	8:54	08/28/2015	11:40	1	165	165	Overhead equipment	Overhead Transformer	Replace - Same Size		II
5115703	J79304	08/28/2015	8:55	08/28/2015	10:08	1	72	72	Tree related-tree broken	Overhead Service	Repair		I
5115719	L99392	08/28/2015	9:11	08/28/2015	10:00	1	48	48	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	V
5115731	N35851	08/28/2015	9:33	08/28/2015	10:00	5	132	26	Overhead equipment	Transformer Fuse	Replace - Same Size		V
5115735	N60181	08/28/2015	9:40	08/28/2015	11:55	1	134	134	Animal related	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	I
5115745	U90572	08/28/2015	10:00	08/28/2015	11:08	1	67	67	Animal related	Transformer Fuse	Repair		II
5115757	M30301	08/28/2015	10:14	08/28/2015	12:35	1	140	140	Public	Overhead Primary		Repair	VI
5115767	K58213	08/28/2015	10:23	08/28/2015	12:26	1	122	122	Overhead equipment	Connector	Repair		VI
5115769	S42579	08/28/2015	10:30	08/28/2015	11:10	1	39	39	Overhead equipment	Transformer Fuse	Replace - Same Size		VI
5115777	M18131	08/28/2015	10:37	08/28/2015	12:15	6	583	97	Overhead equipment	Overhead Secondary	Repair		III
5115801	U31598	08/28/2015	11:09	08/28/2015	13:53	1	163	163	Overhead equipment	Transformer Fuse	Replace - Same Size		II
5115803	P47120	08/28/2015	11:12	08/28/2015	11:58	1	45	45	Unknown	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	I
5115809	R53391	08/28/2015	11:13	08/28/2015	12:00	36	1690	46	Animal related	Fuse	Replace - Same Size	Replace - Same Size	V
5115877	P69174	08/28/2015	11:29	08/28/2015	13:14	13	1359	104	Underground equipment	Underground Primary		Repair	III
5115829	324002	08/28/2015	11:38	08/28/2015	13:30	1	111	111	Weather	Fuse	Replace - Same Size		VI
5115871	P69174	08/28/2015	11:38	08/28/2015	13:17	1	98	98	Underground equipment	Underground Primary		Replace - Same Size	III
5115847	P69174	08/28/2015	12:13	08/28/2015	12:28	1	14	14	Other	Other			III
5115853	V20502	08/28/2015	12:37	08/28/2015	14:34	1	117	117	Public	Underground Secondary	Repair		II
5115857	B76003	08/28/2015	12:46	08/28/2015	19:00	1	373	373	Underground equipment	Underground Service	Patrol/Test/Inspect	Repair	I
5115861	A85001	08/28/2015	12:49	08/29/2015	11:10	1	1340	1340	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
5115911	P57101	08/28/2015	13:32	08/28/2015	14:14	438	18448	42	Overhead equipment	Overhead Primary	Repair	Repair	VI
5115939	K39153	08/28/2015	13:43	08/28/2015	15:15	1	91	91	Overhead equipment	Other			III
5115971	J01118	08/28/2015	14:30	08/28/2015	15:58	1	87	87	Overhead equipment	Overhead Service	Repair	Replace - Same Size	I
5115975	P57101	08/28/2015	14:32	08/28/2015	15:08	1	35	35	Other	Other			VI
5115989	S01501	08/28/2015	15:17	08/28/2015	15:45	1	27	27	Overhead equipment	Fuse	Replace - Same Size		VI
5116005	R33126	08/28/2015	15:57	08/28/2015	18:12	1	134	134	Weather	Transformer Fuse	Replace - Same Size	Patrol/Test/Inspect	I
5116023	K71812	08/28/2015	16:28	08/28/2015	17:04	1	35	35	Animal related	Transformer Fuse	Replace - Same Size		IV
5116011	C40002	08/28/2015	17:17	08/28/2015	19:10	81	9166	113	Underground equipment	Underground Primary	Repair	Repair	I
5116033	P47123	08/28/2015	17:23	08/28/2015	18:46	1	82	82	Public	Overhead Service	Repair		I
5116045	P17109	08/28/2015	18:15	08/28/2015	19:22	1	66	66	Weather	Fuse			IV
5116053	S09520	08/28/2015	18:28	08/28/2015	20:00	18	1646	91	Overhead equipment	Lightning Arrestor	Repair	Repair	VI
5116051	A17025	08/28/2015	18:33	08/28/2015	20:46	1	132	132	Overhead equipment	Connector	Replace - Same Size		I
5116055	Z61565	08/28/2015	18:42	08/28/2015	20:15	1	92	92	Animal related	Transformer Fuse	Replace - Same Size		IV
5116059	C36002	08/28/2015	18:56	08/28/2015	20:21	1	84	84	Animal related	Fuse	Replace - Same Size		III
5116063	Z20566	08/28/2015	20:01	08/28/2015	21:13	1	71	71	Overhead equipment	Fuse	Replace - Same Size		IV
5116067	P58155	08/28/2015	20:29	08/28/2015	21:28	1	58	58	Other				VI
5116069	B82001	08/28/2015	20:30	08/28/2015	22:21	1	110	110	Overhead equipment	Transformer Fuse	Replace - Same Size		I
5116075	C40002	08/28/2015	20:39	08/28/2015	20:53	43	623	14	Underground equipment	Underground Secondary	Repair	Replace - Same Size	I
5116079	C40002	08/28/2015	20:50	08/28/2015	20:56	81	481	5	Underground equipment				I
5116081	C40002	08/28/2015	20:59	08/28/2015	21:25	81	2077	25	Underground equipment	Underground Secondary	Repair		I
5116093	S14511	08/28/2015	22:39	08/29/2015	7:50	4	2201	550	Underground equipment	Underground Primary	Repair	Repair	VI
5116095	S14511	08/28/2015	22:42	08/29/2015	7:50	8	4378	547	Underground equipment	Underground Primary	Repair	Repair	VI
5116097	HD0573	08/28/2015	23:51	08/29/2015	0:42	1	50	50	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	VI
5116107	D70006	08/29/2015	0:06	08/29/2015	11:41	52	19675	695	Underground equipment	Other	Patrol/Test/Inspect	Patrol/Test/Inspect	I
5116109	D70006	08/29/2015	0:34	08/29/2015	5:30	1	296	296	Underground equipment	Underground Secondary	Repair		I
5116111	C40002	08/29/2015	1:07	08/29/2015	7:02	5	1669	354	Underground equipment	Other	Patrol/Test/Inspect	Patrol/Test/Inspect	I
5116117	S22595	08/29/2015	3:38	08/29/2015	4:40	1	61	61	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	VI

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5116123	S14511	08/29/2015	3:55	08/29/2015	4:20	1	24	24	Overhead equipment				VI
5116129	B80001	08/29/2015	4:09	08/29/2015	8:33	46	12167	264	Animal related	Disconnect Switch	Replace - Same Size		I
5116135	K52400	08/29/2015	5:52	08/29/2015	17:25	1	692	692	Underground equipment	Underground Transformer	Patrol/Test/Inspect	Replace - Same Size	V
5116137	309139	08/29/2015	6:02	08/29/2015	7:52	15	1646	109	Overhead equipment				V
5116139	J13108	08/29/2015	6:08	08/29/2015	8:29	1	140	140	Tree related-tree broken	Overhead Service	Replace - New Size	Reconnect	I
5116141	309139	08/29/2015	6:09	08/29/2015	9:35	1	205	205	Overhead equipment				V
5116143	309139	08/29/2015	6:17	08/29/2015	9:35	8	1579	197	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect		V
5116145	U66515	08/29/2015	6:20	08/29/2015	10:31	1	250	250	Overhead equipment	Transformer Fuse	Replace - Same Size		II
5116147	K31124	08/29/2015	6:22	08/29/2015	7:51	1	88	88	Weather	Fuse	Replace - Same Size		I
5116151	Y51506	08/29/2015	6:37	08/29/2015	7:31	6	323	53	Animal related	Transformer Fuse	Replace - Same Size		IV
5116153	M45212	08/29/2015	6:59	08/29/2015	8:27	1	87	87	Animal related	Fuse			IV
5116155	V20502	08/29/2015	7:00	08/29/2015	8:09	1	68	68	Animal related	Fuse			II
5116157	M09143	08/29/2015	7:18	08/29/2015	7:58	17	676	39	Animal related	Fuse	Replace - Same Size		VI
5116175	309139	08/29/2015	8:02	08/29/2015	9:35	15	1391	92	Overhead equipment				V
5116177	J99121	08/29/2015	8:03	08/29/2015	9:00	1	56	56	Overhead equipment	Overhead Service	Patrol/Test/Inspect	Repair	VI
5116195	E10001	08/29/2015	8:50	08/29/2015	10:26	1	95	95	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	III
5116205	D70006	08/29/2015	9:23	08/29/2015	11:30	1	126	126	Underground equipment	Underground Primary	Repair	Repair	I
5116217	M42107	08/29/2015	9:54	08/29/2015	10:46	1	51	51	Overhead equipment	Overhead Service	Repair		I
5116229	U73583	08/29/2015	10:08	08/29/2015	12:51	1	162	162	Unknown	Fuse	Repair	Repair	II
5116235	D72003	08/29/2015	10:15	08/29/2015	11:05	21	1040	49	Animal related				I
5116233	346004	08/29/2015	10:16	08/29/2015	13:26	19	3599	189	Other	Overhead Transformer	Patrol/Test/Inspect	Replace - New Size	VI
5116241	J76804	08/29/2015	10:24	08/29/2015	11:09	94	4220	44	Overhead equipment	Overhead Transformer	Repair	Repair	V
5116257	L16213	08/29/2015	10:43	08/29/2015	11:26	1	42	42	Overhead equipment	Overhead Service	Raise		III
5116259	X96524	08/29/2015	10:44	08/29/2015	12:00	1	75	75	Animal related	Transformer Fuse	Repair	Patrol/Test/Inspect	IV
5116265	J76804	08/29/2015	11:17	08/29/2015	12:07	1	49	49	Overhead equipment	Overhead Secondary	Repair	Repair	V
5116269	Q80353	08/29/2015	11:42	08/29/2015	12:58	1	75	75	Animal related	Transformer Fuse	Replace - Same Size		V
5116289	A81003	08/29/2015	11:58	08/29/2015	13:56	23	2715	118	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
5116279	L50217	08/29/2015	12:30	08/29/2015	14:13	1	102	102	Overhead equipment	Transformer Fuse	Replace - Same Size		VI
5116291	U80001	08/29/2015	13:09	08/29/2015	14:17	1	67	67	Tree related-tree broken				II
5116293	J39392	08/29/2015	13:39	08/29/2015	14:24	1	44	44	Overhead equipment	Jumper	Repair	Repair	III
5116295	J86118	08/29/2015	13:53	08/29/2015	14:45	1	51	51	Tree related-tree broken	Tree			VI
5116303	J01118	08/29/2015	13:58	08/29/2015	15:00	8	496	62	Animal related	Fuse	Replace - Same Size		I
5116305	K22173	08/29/2015	14:11	08/29/2015	15:00	1	48	48	Other	Other	Reconnect	Reconnect	VI
5116307	P07179	08/29/2015	14:21	08/29/2015	17:40	9	1786	198	Tree related-tree broken	Overhead Secondary	Repair	Patrol/Test/Inspect	I
5116327	P26283	08/29/2015	14:43	08/29/2015	16:32	98	10637	108	Animal related	Fuse	Repair	Replace - Same Size	I
5116335	T08501	08/29/2015	16:13	08/29/2015	17:30	1	76	76	Animal related	Transformer Fuse	Replace - Same Size	Patrol/Test/Inspect	VI
5116309	A81003	08/29/2015	16:23	08/29/2015	17:12	1	48	48	Underground equipment	Underground Primary	Repair	Replace - Same Size	I
5116339	C30002	08/29/2015	16:41	08/30/2015	0:34	1	472	472	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	III
5116341	C66001	08/29/2015	17:32	08/29/2015	19:32	104	12396	119	Overhead equipment	Fuse	Replace - Same Size		III
5116355	L71171	08/29/2015	18:37	08/29/2015	19:58	1	80	80	Animal related	Fuse			IV
5116361	N44217	08/29/2015	20:05	08/29/2015	22:25	1	139	139	Animal related				III
5116371	315106	08/29/2015	20:35	08/29/2015	21:52	540	41337	76	Public	Pole			V
5116375	329149	08/29/2015	20:40	08/29/2015	21:52	1	71	71	Public	Pole			V
5116385	N58144	08/29/2015	21:05	08/29/2015	23:30	1	144	144	Overhead equipment	Fuse	Replace - Same Size		I
5116389	315107	08/29/2015	21:12	08/29/2015	21:52	1	39	39	Public	Pole			V
5116391	J76804	08/29/2015	22:00	08/30/2015	0:05	1	124	124	Overhead equipment	Overhead Secondary			V
5116401	X57001	08/29/2015	23:06	08/30/2015	0:15	1	68	68	Public	Transformer Fuse	Replace - Same Size		IV
5116403	B45005	08/30/2015	0:45	08/30/2015	1:41	10	555	55	Animal related	Fuse	Replace - Same Size		I
5116415	B73002	08/30/2015	2:09	08/30/2015	5:15	12	2229	185	Tree related-tree contact	Fuse	Replace - Same Size		I
5116417	R49263	08/30/2015	2:28	08/30/2015	4:05	1	96	96	Overhead equipment	Fuse	Replace - Same Size		VI
5116419	L90359	08/30/2015	2:29	08/30/2015	4:15	55	5798	105	Overhead equipment	Lightning Arrestor	Disconnect		V
5116423	L90359	08/30/2015	2:34	08/30/2015	4:24	1	109	109	Overhead equipment	Lightning Arrestor	Replace - Same Size	Replace - Same Size	V
5116425	L90359	08/30/2015	2:38	08/30/2015	4:22	8	825	103	Overhead equipment				V
5116473	313134	08/30/2015	3:02	08/30/2015	14:42	6	4197	699	Underground equipment				V
5116429	B93003	08/30/2015	3:31	08/30/2015	6:06	6	926	154	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	I
5116433	L46811	08/30/2015	4:05	08/30/2015	5:55	1	109	109	Overhead equipment	Transformer Fuse	Replace - Same Size		V

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5116445	J34357	08/30/2015	7:13	08/30/2015	8:13	15	895	59	Animal related	Fuse	Replace - Same Size	Replace - Same Size	V
5116449	P49180	08/30/2015	7:13	08/30/2015	13:40	4	1544	386	Public	Pole	Cut in Clear	Replace - Same Size	I
5116453	M78325	08/30/2015	7:15	08/30/2015	8:38	26	2145	82	Animal related	Fuse	Replace - Same Size		V
5116455	J34357	08/30/2015	7:16	08/30/2015	8:14	14	805	57	Animal related	Fuse	Replace - Same Size	Replace - Same Size	V
5116459	L62928	08/30/2015	7:16	08/30/2015	12:00	4	1133	283	Overhead equipment	Overhead Transformer		Repair	VI
5116461	J98104	08/30/2015	7:25	08/30/2015	8:50	1	84	84	Overhead equipment	Overhead Service	Repair		VI
5116463	S47576	08/30/2015	7:26	08/30/2015	8:20	1	53	53	Animal related	Transformer Fuse	Replace - Same Size	Replace - Same Size	VI
5116483	N58144	08/30/2015	7:52	08/30/2015	10:01	9	1160	128	Animal related	Fuse	Replace - Same Size		I
5116479	Y36559	08/30/2015	8:15	08/30/2015	9:17	2	122	61	Overhead equipment	Fuse			IV
5116485	N58144	08/30/2015	8:27	08/30/2015	10:06	1	98	98	Animal related	Fuse	Replace - Same Size		I
5116489	N58144	08/30/2015	8:40	08/30/2015	10:08	1	87	87	Animal related	Fuse	Replace - Same Size		I
5116491	B21004	08/30/2015	8:42	08/30/2015	9:35	1	52	52	Animal related	Fuse	Replace - Same Size		I
5116493	K01236	08/30/2015	8:45	08/30/2015	9:35	3	148	49	Animal related	Fuse			VI
5116495	Q34360	08/30/2015	8:50	08/30/2015	10:17	2	173	86	Animal related	Fuse	Patrol/Test/Inspect	Repair	I
5116499	S78551	08/30/2015	9:01	08/30/2015	10:01	1	59	59	Animal related	Transformer Fuse			VI
5116501	P77237	08/30/2015	9:04	08/30/2015	10:30	1	85	85	Overhead equipment	Fuse	Replace - Same Size		VI
5116505	K27153	08/30/2015	9:35	08/30/2015	11:15	1	99	99	Overhead equipment	Disconnect Switch	Repair	Repair	VI
5116517	Y60548	08/30/2015	10:53	08/30/2015	18:50	9	4293	477	Underground equipment	Underground Primary		Repair	IV
5116523	N44217	08/30/2015	11:21	08/30/2015	13:00	1	98	98	Overhead equipment	Fuse			III
5116529	L74191	08/30/2015	11:52	08/30/2015	12:55	1	62	62	Tree related-tree contact	Overhead Service			IV
5116531	D88001	08/30/2015	12:06	08/30/2015	13:23	1	76	76	Overhead equipment	Connector	Repair		I
5116533	S09520	08/30/2015	12:33	08/30/2015	15:14	1	160	160	Tree related-tree broken	Overhead Service	Repair	Patrol/Test/Inspect	VI
5116539	A68001	08/30/2015	13:47	08/30/2015	15:49	30	3660	122	Unknown				I
5116635	U99593	08/30/2015	14:25	08/30/2015	17:34	538	101332	188	Overhead equipment	Substation Breaker	Replace - Same Size		II
5116549	B19002	08/30/2015	14:27	08/30/2015	15:18	1	50	50	Overhead equipment	Disconnect Switch	Replace - Same Size	Replace - Same Size	I
5116591	U06551	08/30/2015	14:32	08/30/2015	17:34	1	181	181	Overhead equipment	Lightning Arrestor	Replace - Same Size	Replace - Same Size	II
5116611	X77586	08/30/2015	14:34	08/30/2015	15:40	1	65	65	Animal related	Fuse	Replace - Same Size		IV
5116629	V21500	08/30/2015	14:40	08/30/2015	17:34	1	173	173	Overhead equipment				II
5116633	U62521	08/30/2015	14:41	08/30/2015	17:34	1	172	172	Overhead equipment	Lightning Arrestor	Replace - Same Size	Replace - Same Size	II
5116651	X60596	08/30/2015	15:07	08/30/2015	16:07	11	661	60	Underground equipment	Underground Primary	Patrol/Test/Inspect		IV
5116659	X60596	08/30/2015	15:27	08/30/2015	17:04	15	1333	97	Underground equipment	Underground Primary	Replace - Same Size	Replace - Same Size	IV
5116657	N14880	08/30/2015	15:51	08/30/2015	22:30	1	398	398	Underground equipment	Overhead Secondary	Patrol/Test/Inspect	Repair	V
5116665	C40002	08/30/2015	16:12	08/30/2015	20:32	44	9157	260	Underground equipment	Underground Primary	Patrol/Test/Inspect	Patrol/Test/Inspect	I
5116671	D96001	08/30/2015	16:18	08/30/2015	23:06	1	407	407	Underground equipment	Underground Primary	Patrol/Test/Inspect	Patrol/Test/Inspect	I
5116675	U99578	08/30/2015	16:41	08/30/2015	17:34	1	52	52	Overhead equipment	Lightning Arrestor	Replace - Same Size	Replace - Same Size	II
5116697	U99515	08/30/2015	17:24	08/30/2015	17:34	425	4029	9	Other				II
5116759	U99593	08/30/2015	17:47	08/30/2015	19:31	1	103	103	Overhead equipment	Fuse	Replace - Same Size		II
5116735	D96001	08/30/2015	18:31	08/30/2015	23:03	2	543	271	Underground equipment	Underground Primary	Repair		I
5116739	313135	08/30/2015	18:51	08/30/2015	19:32	9	360	40	Overhead equipment	Fuse	Replace - Same Size		V
5116737	313135	08/30/2015	18:51	08/30/2015	19:31	9	351	39	Overhead equipment	Fuse	Replace - Same Size		V
5116755	U99515	08/30/2015	18:55	08/30/2015	19:22	12	331	27	Overhead equipment	Fuse	Replace - Same Size		II
5116743	S41565	08/30/2015	19:02	08/30/2015	20:45	41	4191	102	Overhead equipment	Guy Wire	Raise		VI
5116751	B93002	08/30/2015	19:11	08/30/2015	22:24	1	192	192	Animal related	Fuse	Replace - Same Size		I
5116753	B93002	08/30/2015	19:12	08/30/2015	22:16	8	1465	183	Overhead equipment	Fuse	Replace - Same Size		I
5116767	J07173	08/30/2015	19:31	08/30/2015	21:15	34	3534	103	Overhead equipment	Jumper	Repair		I
5116765	J07135	08/30/2015	19:31	08/30/2015	21:10	1	98	98	Overhead equipment				I
5116775	C40002	08/30/2015	19:57	08/30/2015	20:10	11	142	12	Underground equipment	Underground Connector	Repair		I
5116779	G10002	08/30/2015	20:40	08/30/2015	23:33	7	1206	172	Other	Overhead Secondary	Repair		I
5116781	D01001	08/30/2015	21:28	08/31/2015	5:09	1	461	461	Underground equipment	Underground Primary	Patrol/Test/Inspect	Patrol/Test/Inspect	I
5116783	N15849	08/30/2015	21:40	08/30/2015	22:53	1	72	72	Overhead equipment	Overhead Service	Repair		V
5116785	U37002	08/30/2015	22:03	08/30/2015	22:30	1	26	26	Public				II
5116793	L35138	08/31/2015	2:02	08/31/2015	3:40	5	490	98	Underground equipment	Underground Primary		Repair	III
5116795	337001	08/31/2015	4:51	08/31/2015	5:36	1	44	44	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect		VI
5116797	V69546	08/31/2015	5:10	08/31/2015	7:12	1	121	121	Animal related	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	II
5116805	J99141	08/31/2015	6:35	08/31/2015	7:39	188	11906	63	Animal related	Fuse			VI
5116821	Z17503	08/31/2015	6:39	08/31/2015	9:06	4	586	146	Animal related	Fuse	Replace - Same Size		IV

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5116829	A17026	08/31/2015	6:50	08/31/2015	12:00	1	309	309	Underground equipment	Fuse	Replace - Same Size	Replace - Same Size	I
5116837	F10001	08/31/2015	7:10	08/31/2015	8:17	1	66	66	Other	Other	Replace - Same Size	Patrol/Test/Inspect	III
5116845	T17581	08/31/2015	8:07	08/31/2015	9:12	1	64	64	Tree related-tree broken	Tree	Trim		VI
5116859	U64518	08/31/2015	8:48	08/31/2015	9:56	1	67	67	Public	Overhead Primary	Repair	Replace - Same Size	II
5116863	V10002	08/31/2015	8:56	08/31/2015	9:41	1	44	44	Other	Other			II
5116877	N96-UNIT-1	08/31/2015	9:44	08/31/2015	11:04	1	80	79	Overhead equipment				V
5116879	D69007	08/31/2015	9:44	08/31/2015	16:13	18	6655	388	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
5116897	E10001	08/31/2015	10:06	08/31/2015	11:23	1	77	77	Other	Other	Replace - Same Size	Patrol/Test/Inspect	III
5116899	D36002	08/31/2015	10:08	08/31/2015	11:13	1	64	64	Unknown	Fuse	Repair		I
5116915	Y89535	08/31/2015	10:39	08/31/2015	11:10	24	737	30	Overhead equipment	Transformer Fuse	Repair	Replace - Same Size	IV
5116917	Q54908	08/31/2015	10:41	08/31/2015	13:55	1	193	193	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - New Size	VI
5116933	P18103	08/31/2015	11:01	08/31/2015	13:13	46	6053	131	Tree related-tree broken	Overhead Primary		Trim	IV
5116939	K71821	08/31/2015	11:12	08/31/2015	12:18	1	65	65	Overhead equipment				IV
5116941	U86500	08/31/2015	11:15	08/31/2015	12:17	1	61	61	Overhead equipment	Transformer Fuse	Repair	Repair	II
5116945	V84531	08/31/2015	11:23	08/31/2015	12:30	1	66	66	Overhead equipment	Fuse	Replace - Same Size		II
5116951	L62928	08/31/2015	11:31	08/31/2015	12:20	1	48	48	Overhead equipment	Overhead Service	Cut in Clear	Cut in Clear	VI
5116957	324002	08/31/2015	12:02	08/31/2015	15:16	1	193	193	Overhead equipment	Fuse	Replace - Same Size		VI
5116965	V25504	08/31/2015	12:24	08/31/2015	12:30	62	370	5	Overhead equipment	Pole			II
5116971	J86118	08/31/2015	12:43	08/31/2015	19:30	1	406	406	Underground equipment	Underground Service		Repair	VI
5116979	A36002	08/31/2015	13:03	08/31/2015	15:39	1	155	155	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
5116985	B28002	08/31/2015	13:05	08/31/2015	15:49	1	163	163	Overhead equipment				I
5116987	X88510	08/31/2015	13:07	09/01/2015	9:59	1	1251	1251	Weather	Transformer Fuse	Replace - Same Size		IV
5116997	324002	08/31/2015	13:12	08/31/2015	15:10	1	117	117	Overhead equipment	Fuse	Replace - Same Size		VI
5117001	303001	08/31/2015	13:17	08/31/2015	14:20	2	124	62	Overhead equipment	Overhead Secondary	Patrol/Test/Inspect	Repair	VI
5117005	H07106	08/31/2015	13:27	08/31/2015	14:05	4	151	37	Underground equipment	Underground Primary	Patrol/Test/Inspect	Switch/Reset	IV
5117011	S36571	08/31/2015	13:33	08/31/2015	15:27	1	113	113	Overhead equipment	Overhead Service	Patrol/Test/Inspect	Repair	VI
5117035	R33126	08/31/2015	14:40	08/31/2015	15:39	1	58	58	Overhead equipment	Connector	Replace - Same Size	Repair	I
5117067	P53341	08/31/2015	15:21	08/31/2015	16:22	406	24859	61	Overhead equipment	Jumper	Patrol/Test/Inspect	Repair	IV
5117085	U06551	08/31/2015	15:33	08/31/2015	17:53	3	419	139	Overhead equipment	Fuse	Replace - Same Size		II
5117099	R60552	08/31/2015	15:43	08/31/2015	17:25	1	101	101	Overhead equipment	Jumper	Repair		IV
5117103	R33126	08/31/2015	15:47	08/31/2015	16:00	1	12	12	Overhead equipment	Connector	Replace - Same Size	Repair	I
5117107	S61575	08/31/2015	15:53	08/31/2015	17:00	1	66	66	Overhead equipment	Meter			VI
5117127	Y37592	08/31/2015	16:30	08/31/2015	17:00	1	29	29	Overhead equipment	Overhead Service			IV
5117131	L12127	08/31/2015	16:46	08/31/2015	19:04	65	8279	137	Unknown	Underground Primary			III
5117137	X72535	08/31/2015	17:02	08/31/2015	20:25	1	202	202	Tree related-tree contact	Overhead Service	Repair	Repair	IV
5117139	S62522	08/31/2015	17:02	08/31/2015	18:33	1	90	90	Public	Overhead Service	Patrol/Test/Inspect	Repair	VI
5117143	R73841	08/31/2015	17:12	08/31/2015	18:46	1	93	93	Overhead equipment	Overhead Service	Repair	Repair	V
5117149	Q83172	08/31/2015	17:16	08/31/2015	18:12	9	499	55	Animal related	Transformer Fuse	Replace - Same Size		VI
5117147	J01118	08/31/2015	17:16	08/31/2015	18:49	1	92	92	Unknown	Transformer Fuse	Replace - Same Size		I
5117153	U06524	08/31/2015	17:20	08/31/2015	18:26	5	328	65	Overhead equipment	Fuse	Replace - Same Size		II
5117155	T23528	08/31/2015	17:21	08/31/2015	23:33	7	2219	372	Underground equipment	Underground Primary		Repair	VI
5117161	303005	08/31/2015	17:21	08/31/2015	22:50	22	7229	328	Tree related-tree broken	Overhead Primary	Patrol/Test/Inspect	Repair	VI
5117169	U06524	08/31/2015	17:29	08/31/2015	18:25	5	276	55	Overhead equipment	Fuse	Replace - Same Size		II
5117171	342001	08/31/2015	17:42	08/31/2015	19:18	1	95	95	Tree related-tree broken	Overhead Service	Repair		VI
5117179	A36002	08/31/2015	18:04	08/31/2015	19:02	1	57	57	Underground equipment	Underground Primary	Repair		I
5117187	B71002	08/31/2015	18:07	09/01/2015	4:35	232	57540	627	Underground equipment	Switchgear		Repair	I
5117197	P73158	08/31/2015	18:13	08/31/2015	18:34	1	20	20	Overhead equipment	Fuse	Replace - Same Size		VI
5117199	303005	08/31/2015	18:14	08/31/2015	18:30	1	15	15	Tree related-tree broken	Other	Patrol/Test/Inspect		VI
5117207	L16213	08/31/2015	18:21	08/31/2015	19:26	1	64	64	Overhead equipment	Connector	Replace - Same Size		III
5117215	K52400	08/31/2015	18:33	08/31/2015	19:13	1	39	39	Jurisdictional				V
5117217	N05172	08/31/2015	18:37	08/31/2015	19:30	1	52	52	Overhead equipment	Fuse	Repair	Repair	I
5117219	303005	08/31/2015	18:43	08/31/2015	22:50	1	246	246	Tree related-tree broken	Customer Equipment	Patrol/Test/Inspect	Repair	VI
5117227	L12127	08/31/2015	19:06	08/31/2015	22:01	65	6326	174	Underground equipment	Underground Transformer	Replace - Same Size		III
5117237	L79159	08/31/2015	20:25	08/31/2015	23:20	9	1573	174	Overhead equipment	Overhead Transformer			IV
5117253	M09143	08/31/2015	22:11	08/31/2015	23:02	2	101	50	Animal related	Fuse	Replace - Same Size		VI
5117265	E10001	08/31/2015	23:35	09/01/2015	0:48	17	1231	72	Overhead equipment	Fuse	Replace - Same Size		III

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5117273	B81002	09/01/2015	2:39	09/01/2015	7:04	1	264	264	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
5117275	342003	09/01/2015	3:29	09/01/2015	5:15	4	421	105	Overhead equipment	Fuse	Replace - Same Size		VI
5117277	C50001	09/01/2015	4:10	09/01/2015	10:01	38	13338	351	Underground equipment	Underground Primary			III
5117295	L86175	09/01/2015	4:47	09/01/2015	11:14	185	41061	386	Underground equipment	Underground Primary	Disconnect	Repair	IV
5117291	S22595	09/01/2015	5:07	09/01/2015	7:24	1	136	136	Animal related	Transformer Fuse	Patrol/Test/Inspect	Replace - New Size	VI
5117293	Y97514	09/01/2015	5:22	09/01/2015	7:10	1	107	107	Weather	Disconnect Switch	Replace - Same Size		IV
5117299	M21133	09/01/2015	6:04	09/01/2015	6:50	1	45	45	Overhead equipment	Guy Wire	Repair	Repair	VI
5117301	P17108	09/01/2015	6:07	09/01/2015	7:50	7	718	102	Weather	Fuse	Replace - Same Size		IV
5117303	M21133	09/01/2015	6:10	09/01/2015	6:50	1	39	39	Overhead equipment	Fuse	Repair	Repair	VI
5117305	X77586	09/01/2015	6:11	09/01/2015	7:30	1	78	78	Weather	Transformer Fuse	Replace - Same Size		IV
5117307	R06212	09/01/2015	6:12	09/01/2015	9:30	65	12332	198	Underground equipment	Underground Primary	Switch/Reset	Repair	II
5117361	R59417	09/01/2015	6:22	09/01/2015	8:10	750	81165	108	Weather	Fuse	Replace - Same Size	Replace - Same Size	IV
5117769	C50001	09/01/2015	6:22	09/01/2015	11:52	5	1646	329	Underground equipment	Underground Primary			III
5117327	Q71846	09/01/2015	6:49	09/01/2015	8:37	1	107	107	Animal related	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	V
5117333	K74166	09/01/2015	7:04	09/01/2015	8:26	1	81	81	Tree related-tree contact	Overhead Service	Repair		IV
5117339	X87578	09/01/2015	7:15	09/01/2015	14:30	1	434	434	Weather	Overhead Transformer	Replace - New Size	Replace - Same Size	IV
5117351	Y04504	09/01/2015	7:18	09/01/2015	8:22	25	1588	63	Weather	Fuse	Replace - Same Size		IV
5117567	V42-XTR1	09/01/2015	7:24	09/01/2015	9:42	1073	147558	137	Jurisdictional				II
5117353	X09557	09/01/2015	7:34	09/01/2015	8:34	1	59	59	Weather	Fuse	Replace - Same Size		IV
5117677	B08003	09/01/2015	7:44	09/01/2015	10:40	10	1627	176	Underground equipment	Underground Primary	Switch/Reset	Repair	I
5117403	X78536	09/01/2015	8:12	09/01/2015	9:37	1	84	84	Animal related	Transformer Fuse	Replace - Same Size		IV
5117407	R59417	09/01/2015	8:18	09/01/2015	9:25	22	1460	66	Overhead equipment	Fuse	Repair		IV
5117409	L23145	09/01/2015	8:19	09/01/2015	8:58	1	38	38	Unknown	Transformer Fuse	Replace - Same Size		III
5117413	M04365	09/01/2015	8:25	09/01/2015	11:46	1	200	200	Underground equipment	Underground Service	Disconnect	Repair	V
5117419	Z04520	09/01/2015	8:43	09/01/2015	12:50	1	246	246	Underground equipment	Underground Transformer	Replace - Same Size	Replace - Same Size	IV
5117423	C66001	09/01/2015	8:45	09/01/2015	14:23	1	337	337	Underground equipment	Underground Primary			III
5117425	M06623	09/01/2015	8:48	09/01/2015	10:09	31	2490	80	Overhead equipment	Substation Relay	Patrol/Test/Inspect	Replace - Same Size	V
5117649	V45-XTR1	09/01/2015	8:49	09/01/2015	10:06	1200	93396	77	Jurisdictional	Substation Breaker			II
5117561	V41-XTR1	09/01/2015	8:49	09/01/2015	9:17	2210	60885	27	Jurisdictional	Substation Breaker			II
5117477	V51-XTR1	09/01/2015	8:50	09/01/2015	9:22	240	7615	31	Jurisdictional	Substation Breaker			II
5117687	Y63527	09/01/2015	8:59	09/01/2015	10:55	39	4495	115	Tree related-tree broken	Overhead Primary	Repair		IV
5117689	374052	09/01/2015	9:02	09/01/2015	14:15	1	312	312	Overhead equipment	Overhead Primary	Patrol/Test/Inspect	Repair	VI
5117691	L12126	09/01/2015	9:02	09/01/2015	10:58	1	115	115	Underground equipment	Underground Service	Patrol/Test/Inspect	Repair	III
5117697	V39003	09/01/2015	9:04	09/01/2015	10:38	1	94	94	Other				II
5117699	Y61007	09/01/2015	9:06	09/01/2015	10:55	1	108	108	Tree related-tree broken	Overhead Primary	Repair	Repair	IV
152445207		09/01/2015	9:07	09/01/2015	9:51	1	44	43	Other				II
5117707	Y86595	09/01/2015	9:11	09/01/2015	9:49	2	76	38	Overhead equipment	Connector	Repair	Replace - Same Size	IV
5117709	V46-XTR1	09/01/2015	9:13	09/01/2015	10:03	1021	51070	50	Jurisdictional	Substation Breaker			II
5117787	Z29579	09/01/2015	9:14	09/01/2015	10:39	46	3891	84	Overhead equipment	Fuse	Replace - Same Size		IV
5117715	M25144	09/01/2015	9:14	09/01/2015	10:33	1	78	78	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
5117721	N60181	09/01/2015	9:21	09/01/2015	12:14	21	3603	172	Underground equipment	Underground Primary	Repair	Replace - Same Size	I
5117745	S09520	09/01/2015	9:40	09/01/2015	11:19	3	295	98	Animal related	Transformer Fuse	Repair		VI
5117747	M25143	09/01/2015	9:40	09/01/2015	11:02	1	81	81	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
5117771	Y82590	09/01/2015	10:00	09/01/2015	10:40	1	39	39	Weather	Fuse	Replace - Same Size	Repair	IV
5117773	A49002	09/01/2015	10:03	09/01/2015	11:58	1	114	114	Overhead equipment	Fuse	Replace - Same Size		I
5117791	D66003	09/01/2015	10:16	09/01/2015	11:58	1	101	101	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
5117797	V45574	09/01/2015	10:25	09/01/2015	10:29	1	3	3	Other				II
5117801	V42593	09/01/2015	10:29	09/01/2015	13:26	1	176	176	Other	Underground Transformer	Patrol/Test/Inspect		II
5117809	A91004	09/01/2015	10:41	09/01/2015	15:06	1	264	264	Overhead equipment	Overhead Transformer		Repair	I
5117811	X82576	09/01/2015	10:42	09/01/2015	16:27	1	344	344	Overhead equipment	Pole	Replace - New Size		IV
5117813	Q74149	09/01/2015	10:47	09/01/2015	11:56	1	68	68	Weather	Transformer Fuse	Replace - Same Size		IV
5117825	K25166	09/01/2015	10:55	09/01/2015	11:40	1	44	44	Animal related	Fuse	Replace - Same Size	Replace - Same Size	VI
5117855	A81001	09/01/2015	11:29	09/01/2015	12:55	1	85	85	Overhead equipment	Connector	Replace - Same Size		I
5117857	K01241	09/01/2015	11:29	09/01/2015	17:04	1	334	334	Underground equipment	Underground Secondary			VI
5117863	Z29579	09/01/2015	11:41	09/01/2015	21:21	1	579	579	Weather	Overhead Transformer	Replace - Same Size	Repair	IV
5117867	J47176	09/01/2015	11:46	09/01/2015	12:00	35	474	13	Overhead equipment	Pole			III

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5117871	N67309	09/01/2015	11:52	09/01/2015	14:08	1	135	135	Overhead equipment	Overhead Transformer	Replace - Same Size		I
5117879	325006	09/01/2015	12:08	09/01/2015	20:29	12	2835	501	Overhead equipment	Pole	Repair	Replace - Same Size	VI
5117885	Y07577	09/01/2015	12:38	09/01/2015	13:20	1	41	41	Overhead equipment	Jumper	Replace - Same Size		IV
5117889	308003	09/01/2015	12:43	09/01/2015	16:12	1	208	208	Overhead equipment	Overhead Service	Repair		VI
5117893	Y07577	09/01/2015	12:50	09/01/2015	13:20	1	29	29	Overhead equipment	Jumper	Replace - Same Size		IV
5117897	Y97514	09/01/2015	12:54	09/01/2015	17:00	1	125	245	Weather	Overhead Transformer	Replace - Same Size	Replace - Same Size	IV
5117899	Q83149	09/01/2015	12:56	09/01/2015	13:26	8	237	29	Overhead equipment	Connector	Replace - Same Size	Replace - Same Size	VI
5117913	Y28597	09/01/2015	13:09	09/01/2015	16:00	1	170	170	Weather	Overhead Transformer	Replace - Same Size	Repair	IV
5117921	Z04520	09/01/2015	13:11	09/01/2015	17:43	3	813	271	Underground equipment	Underground Secondary	Repair	Replace - Same Size	IV
5117939	L81141	09/01/2015	13:30	09/01/2015	14:15	1	44	44	Animal related	Fuse			IV
5117943	M40132	09/01/2015	13:33	09/01/2015	14:03	57	1696	29	Animal related	Fuse	Repair	Replace - Same Size	I
5118025	U99593	09/01/2015	14:25	09/01/2015	14:39	1	13	13	Tree related-tree broken				II
5118033	P58156	09/01/2015	14:36	09/01/2015	15:55	1	78	78	Overhead equipment	Overhead Service	Repair		VI
5118037	M05360	09/01/2015	14:40	09/01/2015	18:35	1	234	234	Animal related	Fuse	Repair		V
5118047	H00161	09/01/2015	14:47	09/01/2015	18:00	6	1157	192	Public	Pole	Repair	Replace - Same Size	III
5118063	J86118	09/01/2015	15:29	09/01/2015	16:23	1	53	53	Overhead equipment	Transformer Fuse	Replace - Same Size		VI
5118065	Q06141	09/01/2015	15:42	09/01/2015	17:04	28	2148	81	Underground equipment	Underground Primary	Switch/Reset	Repair	IV
5118071	D31015	09/01/2015	15:58	09/01/2015	17:04	1	65	65	Overhead equipment	Overhead Service	Repair		III
5118079	N22295	09/01/2015	16:05	09/01/2015	17:29	1	83	83	Overhead equipment	Overhead Transformer		Replace - New Size	VI
5118089	L23148	09/01/2015	16:24	09/01/2015	17:44	1	80	79	Unknown	Transformer Fuse	Replace - Same Size		III
5118093	L23148	09/01/2015	16:25	09/01/2015	17:44	1	78	78	Unknown	Transformer Fuse	Replace - Same Size		III
5118097	D53001	09/01/2015	16:28	09/01/2015	19:08	6	954	159	Overhead equipment				I
5118103	Q95249	09/01/2015	16:32	09/01/2015	17:18	1	45	45	Animal related	Fuse	Replace - Same Size		VI
5118105	T15570	09/01/2015	16:33	09/01/2015	18:34	1	120	120	Overhead equipment	Overhead Service	Patrol/Test/Inspect	Repair	VI
5118109	B84002	09/01/2015	16:35	09/01/2015	19:07	25	3797	151	Underground equipment	Underground Primary	Switch/Reset	Repair	I
5118113	Z29579	09/01/2015	16:44	09/01/2015	18:15	1	90	90	Overhead equipment	Animal Guard		Install	IV
5118129	F03003	09/01/2015	17:19	09/01/2015	22:13	10	2013	294	Overhead equipment	Overhead Primary		Repair	III
5118139	V58507	09/01/2015	17:48	09/01/2015	20:15	1	146	146	Overhead equipment	Overhead Service	Repair	Repair	II
5118141	L71171	09/01/2015	18:05	09/01/2015	20:41	1	155	155	Overhead equipment	Overhead Transformer			IV
5118143	T46001	09/01/2015	18:06	09/01/2015	19:15	20	1375	68	Underground equipment	Underground Transformer	Switch/Reset		VI
5118153	E10001	09/01/2015	19:16	09/01/2015	20:34	4	310	77	Overhead equipment	Fuse	Replace - Same Size		III
5118167	R66470	09/01/2015	19:37	09/02/2015	0:31	407	119914	294	Tree related-tree broken				IV
5118169	R66470	09/01/2015	19:37	09/02/2015	0:31	243	59822	294	Tree related-tree broken				IV
5118165	R66470	09/01/2015	19:37	09/02/2015	0:31	173	50970	294	Tree related-tree broken				IV
5118177	D89002	09/01/2015	19:43	09/01/2015	22:50	41	7630	186	Underground equipment	Underground Primary	Patrol/Test/Inspect	Switch/Reset	I
5118181	T46001	09/01/2015	20:14	09/01/2015	21:00	20	902	45	Underground equipment	Underground Transformer		Replace - New Size	VI
5118187	Y79500	09/01/2015	20:39	09/02/2015	0:05	8	1640	205	Overhead equipment	Transformer Fuse	Repair	Replace - Same Size	IV
5118191	R65451	09/01/2015	21:26	09/01/2015	22:45	1	78	78	Tree related-tree contact	Overhead Service	Patrol/Test/Inspect	Repair	IV
5118195	K46388	09/01/2015	21:28	09/02/2015	0:42	1	193	193	Underground equipment	Underground Service	Patrol/Test/Inspect	Repair	V
5118199	D89002	09/01/2015	22:07	09/02/2015	6:23	3	1486	495	Underground equipment	Underground Primary	Replace - Same Size		I
5118209	HA5430	09/01/2015	23:16	09/02/2015	1:31	4	538	134	Animal related	Transformer Fuse	Replace - Same Size		V
5118211	T23528	09/01/2015	23:22	09/02/2015	5:25	5	1814	362	Underground equipment	Underground Primary	Repair	Repair	VI
5118213	B80004	09/01/2015	23:40	09/02/2015	4:52	90	28156	312	Underground equipment	Underground Primary		Repair	I
5118217	B80004	09/02/2015	0:33	09/02/2015	4:56	5	1312	262	Underground equipment	Underground Primary	Repair		I
5118221	B62003	09/02/2015	1:01	09/02/2015	2:47	415	43998	106	Underground equipment	Underground Primary	Repair		I
5118223	B62003	09/02/2015	1:01	09/02/2015	2:48	133	14188	106	Underground equipment	Underground Primary	Repair		I
5118219	B62003	09/02/2015	1:01	09/02/2015	2:48	204	21507	106	Underground equipment	Underground Primary	Repair	Repair	I
5118231	Y45003	09/02/2015	3:04	09/02/2015	4:04	1	59	59	Public	Overhead Service	Remove	Remove	IV
5118237	S28552	09/02/2015	4:06	09/02/2015	6:27	1	140	140	Animal related	Transformer Fuse	Replace - Same Size		VI
5118239	V22555	09/02/2015	4:47	09/02/2015	6:45	1	117	117	Animal related	Fuse	Replace - Same Size		II
5118251	N05172	09/02/2015	6:56	09/02/2015	8:13	1	76	76	Animal related	Transformer Fuse	Replace - Same Size		I
5118253	D39001	09/02/2015	6:57	09/02/2015	14:11	1	433	433	Underground equipment	Underground Primary	Repair	Repair	I
5118255	B00005	09/02/2015	7:07	09/02/2015	8:55	10	1077	107	Animal related	Fuse	Replace - Same Size		I
5118257	M49424	09/02/2015	7:19	09/02/2015	8:35	1	75	75	Animal related	Fuse	Replace - Same Size	Replace - Same Size	V
5118259	HA5430	09/02/2015	7:21	09/02/2015	7:57	1	35	35	Animal related	Fuse	Replace - Same Size		V
5118261	M47816	09/02/2015	7:23	09/02/2015	7:50	1	26	26	Animal related	Fuse	Repair	Repair	V

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5118263	B68004	09/02/2015	7:42	09/02/2015	8:12	1	29	29	Overhead equipment	Connector	Replace - Same Size		III
5118267	HC9327	09/02/2015	8:13	09/02/2015	9:47	1	93	93	Overhead equipment	Pedestal	Repair	Repair	VI
5118287	E10001	09/02/2015	9:06	09/02/2015	10:38	1	92	92	Underground equipment	Underground Primary			III
5118323	D89003	09/02/2015	9:12	09/02/2015	10:03	263	13223	50	Overhead equipment	Recloser	Switch/Reset		I
5118407	Q36412	09/02/2015	9:28	09/02/2015	10:54	5	426	85	Overhead equipment	Fuse	Replace - Same Size	Repair	I
5118391	R50910	09/02/2015	10:02	09/02/2015	11:00	1	57	57	Animal related	Transformer Fuse	Replace - Same Size		I
5118443	R05114	09/02/2015	11:26	09/02/2015	12:48	1	81	81	Tree related-tree broken	Overhead Secondary	Repair	Replace - Same Size	I
5118447	R28870	09/02/2015	11:27	09/02/2015	13:01	1	93	93	Underground equipment	Underground Service			V
5118449	J13108	09/02/2015	11:27	09/02/2015	12:46	1	78	78	Animal related	Transformer Fuse	Replace - Same Size		I
5118461	P69174	09/02/2015	12:06	09/02/2015	14:30	1	143	143	Public	Underground Service		Repair	III
5118465	Q74150	09/02/2015	12:11	09/02/2015	13:11	1	59	59	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
5118467	Q74150	09/02/2015	12:22	09/02/2015	13:22	1	59	59	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
5118473	B38002	09/02/2015	12:41	09/02/2015	14:42	35	4207	120	Overhead equipment	Recloser	Switch/Reset		I
5118491	A45003	09/02/2015	13:06	09/02/2015	14:53	38	4032	106	Jurisdictional	Underground Primary	Switch/Reset	Switch/Reset	I
5118645	A45003	09/02/2015	13:21	09/02/2015	15:34	33	4370	133	Jurisdictional	Underground Primary	Switch/Reset		I
5118597	A45003	09/02/2015	13:25	09/02/2015	19:26	1	360	360	Jurisdictional				I
5118505	B81002	09/02/2015	13:29	09/03/2015	6:49	1	1039	1039	Underground equipment	Underground Primary	Patrol/Test/Inspect	Reconnect	I
5118519	K94223	09/02/2015	13:49	09/02/2015	14:48	1	58	58	Overhead equipment	Overhead Service	Repair		III
5118525	J14142	09/02/2015	13:57	09/02/2015	15:31	1	93	93	Overhead equipment	Pole	Patrol/Test/Inspect	Repair	VI
5118651	R58961	09/02/2015	14:30	09/02/2015	17:37	140	26173	186	Overhead equipment	Jumper	Repair	Replace - Same Size	IV
5118555	R58961	09/02/2015	14:39	09/02/2015	17:37	4	711	177	Overhead equipment	Jumper	Patrol/Test/Inspect	Repair	IV
5118747	A29002	09/02/2015	14:44	09/02/2015	18:09	18	3688	204	Overhead equipment	Overhead Transformer	Replace - Same Size		I
5118581	K32935	09/02/2015	14:51	09/02/2015	17:18	1	146	146	Overhead equipment	Fuse			VI
5118587	K15205	09/02/2015	14:54	09/02/2015	16:28	1	93	93	Overhead equipment	Overhead Service	Repair		VI
5118589	R58961	09/02/2015	14:54	09/02/2015	17:37	1	162	162	Overhead equipment	Jumper	Patrol/Test/Inspect	Repair	IV
5118601	334003	09/02/2015	15:07	09/02/2015	17:35	1	147	147	Tree related-tree broken	Overhead Secondary	Advise Customer	Repair	VI
5118615	Q32170	09/02/2015	15:13	09/02/2015	17:05	198	22021	111	Overhead equipment	Recloser			I
5118641	Q24310	09/02/2015	15:23	09/02/2015	18:10	6	996	166	Underground equipment	Underground Primary	Switch/Reset		VI
5118647	Q83171	09/02/2015	15:29	09/02/2015	16:45	1	75	75	Other	Meter	Reconnect		VI
5118653	Q24310	09/02/2015	15:33	09/02/2015	18:10	1	156	156	Underground equipment	Underground Primary	Switch/Reset		VI
5118655	Q34363	09/02/2015	15:37	09/02/2015	17:21	20	2074	103	Overhead equipment	Lightning Arrestor	Replace - Same Size	Repair	I
5118657	D16003	09/02/2015	15:37	09/02/2015	19:35	1	237	237	Overhead equipment	Crossarm	Replace - Same Size	Repair	I
5118665	Q34361	09/02/2015	15:48	09/02/2015	17:23	1	94	94	Overhead equipment	Lightning Arrestor	Replace - Same Size	Repair	I
5118869	X72-XTR1	09/02/2015	15:51	09/02/2015	18:59	53	9986	188	Overhead equipment				IV
5118675	X72535	09/02/2015	15:52	09/03/2015	6:02	635	149753	850	Substation equipment	Substation Transformer	Repair	Replace - Same Size	IV
5118681	D28123	09/02/2015	15:55	09/02/2015	22:45	2	819	409	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	I
5118695	N18211	09/02/2015	15:56	09/02/2015	17:40	1	103	103	Unknown	Fuse	Replace - Same Size		III
5118715	N58144	09/02/2015	15:59	09/02/2015	17:07	1	67	67	Unknown	Transformer Fuse	Replace - Same Size		I
5118851	N18211	09/02/2015	16:03	09/02/2015	17:44	9	904	100	Unknown	Fuse			III
5118781	B76003	09/02/2015	16:09	09/03/2015	3:10	1	660	660	Underground equipment	Underground Service	Disconnect	Repair	I
5118825	Q32170	09/02/2015	16:52	09/02/2015	17:20	1	27	27	Overhead equipment	Recloser			I
5118853	Q32170	09/02/2015	17:08	09/02/2015	17:35	1	26	26	Overhead equipment	Recloser			I
5118857	Q32170	09/02/2015	17:22	09/02/2015	17:45	1	22	22	Overhead equipment	Recloser			I
5118861	H01190	09/02/2015	17:31	09/02/2015	18:20	1	48	48	Unknown	Transformer Fuse	Replace - Same Size		III
5118867	A27011	09/02/2015	18:12	09/02/2015	21:41	125	26122	208	Underground equipment	Underground Primary	Repair	Repair	I
5118877	P98190	09/02/2015	18:36	09/02/2015	20:06	1	89	89	Tree related-tree contact	Other			III
5118879	P98190	09/02/2015	18:42	09/03/2015	0:24	9	3073	341	Tree related-tree broken	Tree			III
5118905	K01240	09/02/2015	19:24	09/02/2015	21:24	10	1197	119	Overhead equipment	Fuse	Replace - Same Size		VI
5118903	X72535	09/02/2015	19:30	09/02/2015	20:38	1	67	67	Overhead equipment	Substation Transformer		Patrol/Test/Inspect	IV
5118917	X72535	09/02/2015	20:21	09/02/2015	20:48	1	26	26	Overhead equipment	Substation Transformer		Patrol/Test/Inspect	IV
5118921	D36002	09/02/2015	20:45	09/03/2015	0:49	1	243	243	Tree related-tree broken	Overhead Service		Repair	I
5118925	X72535	09/02/2015	21:10	09/02/2015	22:18	1	67	67	Overhead equipment	Substation Transformer			IV
5118933	B84004	09/02/2015	21:45	09/03/2015	0:55	9	1702	189	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	I
5118953	H11340	09/02/2015	23:42	09/03/2015	2:00	162	22229	137	Other	Fuse	Replace - Same Size		V
5118963	R71286	09/03/2015	0:53	09/03/2015	2:37	1	103	103	Animal related	Fuse	Replace - Same Size		VI
5118965	C70001	09/03/2015	1:00	09/03/2015	7:37	1	396	396	Underground equipment	Underground Primary	Repair	Repair	III

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5118981	S16502	09/03/2015	2:43	09/03/2015	7:19	16	4412	275	Overhead equipment	Overhead Primary	Replace - Same Size		VI
5118977	Z06537	09/03/2015	3:31	09/03/2015	5:55	1	143	143	Animal related	Underground Primary	Repair		IV
5119083	C36-X2	09/03/2015	5:39	09/03/2015	6:44	629	40683	64	Jurisdictional				III
5118985	X34530	09/03/2015	6:12	09/03/2015	8:36	1	143	143	Overhead equipment	Overhead Service	Replace - New Size		IV
5118987	K67924	09/03/2015	6:13	09/03/2015	7:30	1	76	76	Animal related	Fuse	Replace - Same Size		VI
5119005	C36-X1	09/03/2015	6:33	09/03/2015	6:44	624	6938	11	Jurisdictional				III
5119075	C15-X1	09/03/2015	6:34	09/03/2015	6:45	725	7743	10	Jurisdictional				III
5119153	C15002	09/03/2015	6:46	09/03/2015	8:07	1	80	80	Overhead equipment				III
5119157	C36002	09/03/2015	6:53	09/03/2015	8:10	1	76	76	Overhead equipment	Substation Misc.			III
5119161	K27153	09/03/2015	6:58	09/03/2015	8:40	1	101	101	Tree related-tree broken	Overhead Service	Replace - Same Size	Replace - Same Size	VI
5119163	C15002	09/03/2015	7:03	09/03/2015	8:13	1	69	69	Overhead equipment	Substation Misc.			III
5119165	C36002	09/03/2015	7:05	09/03/2015	8:12	1	66	66	Overhead equipment	Substation Misc.			III
5119167	C36002	09/03/2015	7:06	09/03/2015	8:14	1	67	67	Overhead equipment	Substation Misc.			III
5119185	N93260	09/03/2015	7:56	09/03/2015	10:16	14	1964	140	Overhead equipment	Overhead Primary			III
5119187	Y55594	09/03/2015	8:00	09/03/2015	9:15	1	74	74	Animal related	Transformer Fuse	Replace - Same Size	Replace - Same Size	IV
5119189	B73001	09/03/2015	8:02	09/03/2015	11:48	1	225	225	Public	Underground Primary	Repair	Repair	I
5119191	R60552	09/03/2015	8:11	09/03/2015	8:59	1	47	47	Animal related	Transformer Fuse	Replace - Same Size		IV
5119205	U35511	09/03/2015	9:07	09/03/2015	10:02	1	54	54	Animal related	Fuse	Replace - Same Size		II
5119231	U60518	09/03/2015	9:36	09/03/2015	9:50	1	13	13	Animal related	Transformer Fuse			II
5119233	D31016	09/03/2015	9:37	09/03/2015	10:40	1	62	62	Animal related	Transformer Fuse	Replace - Same Size		III
5119255	U98002	09/03/2015	10:07	09/03/2015	11:54	1	106	106	Overhead equipment	Disconnect Switch	Replace - Same Size	Replace - New Size	II
5119273	U60518	09/03/2015	10:37	09/03/2015	10:57	1	19	19	Animal related	Overhead Service			II
5119275	K01240	09/03/2015	10:37	09/03/2015	12:05	1	87	87	Weather	Transformer Fuse			VI
5119325	N67309	09/03/2015	11:54	09/03/2015	13:42	82	8820	107	Overhead equipment	Recloser	Replace - Same Size	Replace - Same Size	I
5119307	N05172	09/03/2015	11:58	09/03/2015	12:25	1	26	26	Overhead equipment	Disconnect Switch	Replace - Same Size		I
5119317	S01501	09/03/2015	11:58	09/03/2015	12:33	54	1861	34	Overhead equipment	Fuse	Repair		VI
5119333	N67309	09/03/2015	12:33	09/03/2015	13:50	1	76	76	Overhead equipment	Recloser	Replace - Same Size		I
5119337	R33127	09/03/2015	12:47	09/03/2015	13:49	1	61	61	Overhead equipment	Overhead Transformer	Replace - Same Size	Patrol/Test/Inspect	I
5119359	A49001	09/03/2015	13:07	09/03/2015	17:46	1	278	278	Underground equipment	Underground Primary	Repair	Repair	I
5119367	H07106	09/03/2015	13:17	09/03/2015	14:23	1	65	65	Weather	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	IV
5119369	L17104	09/03/2015	13:18	09/03/2015	17:30	1	251	251	Underground equipment	Underground Primary		Repair	III
5119375	E10001	09/03/2015	13:21	09/03/2015	14:32	17	1204	70	Overhead equipment	Other	Replace - Same Size	Patrol/Test/Inspect	III
5119379	A26006	09/03/2015	13:27	09/03/2015	13:53	1	25	25	Overhead equipment				I
5119387	308002	09/03/2015	13:42	09/04/2015	6:53	1	1030	1030	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	VI
5119395	L82187	09/03/2015	14:05	09/03/2015	14:47	1	41	41	Overhead equipment	Fuse	Replace - Same Size		IV
5119399	J80807	09/03/2015	14:08	09/03/2015	15:20	1	71	71	Jurisdictional				V
5119401	K69112	09/03/2015	14:09	09/03/2015	18:48	1	279	279	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	IV
5119427	T46002	09/03/2015	15:19	09/03/2015	17:20	1	120	120	Public	Overhead Transformer	Disconnect		VI
5119429	X75558	09/03/2015	15:20	09/04/2015	11:30	1	1209	1209	Weather	Overhead Primary	Replace - Same Size	Replace - Same Size	IV
5119453	P58156	09/03/2015	16:26	09/03/2015	17:00	1	33	33	Other				VI
5119469	L12125	09/03/2015	17:05	09/03/2015	18:07	35	2174	62	Underground equipment	Underground Primary	Switch/Reset	Repair	III
5119473	S04512	09/03/2015	17:09	09/03/2015	22:15	1	305	305	Overhead equipment	Overhead Transformer	Replace - Same Size	Replace - Same Size	VI
5119479	D87001	09/03/2015	17:35	09/03/2015	22:00	12	1374	264	Tree related-tree broken	Tree	Patrol/Test/Inspect	Trim	I
5119489	D66004	09/03/2015	17:46	09/03/2015	18:21	178	6247	35	Overhead equipment	Fuse	Replace - Same Size		IV
5119501	K07320	09/03/2015	18:22	09/03/2015	20:25	1	122	122	Tree related-tree broken	Overhead Service	Replace - Same Size	Replace - Same Size	I
5119503	R08910	09/03/2015	18:27	09/03/2015	18:36	4	35	8	Overhead equipment	Pole	Replace - Same Size	Replace - Same Size	VI
5119515	L79158	09/03/2015	19:19	09/03/2015	22:19	1	179	179	Overhead equipment	Overhead Transformer			IV
5119517	S47584	09/03/2015	19:22	09/03/2015	23:56	1	273	273	Overhead equipment	Overhead Primary			VI
5119519	S47584	09/03/2015	19:24	09/03/2015	23:47	1	262	262	Overhead equipment	Disconnect Switch		Repair	VI
5119521	K27150	09/03/2015	19:29	09/03/2015	23:33	4	973	243	Tree related-tree broken	Overhead Primary	Cut in Clear	Repair	VI
5119525	S66579	09/03/2015	19:37	09/03/2015	21:04	1	86	86	Overhead equipment				VI
5119535	329146	09/03/2015	20:19	09/03/2015	20:54	10	349	34	Overhead equipment	Transformer Fuse	Replace - Same Size		V
5119537	U57561	09/03/2015	20:24	09/03/2015	22:10	1	105	105	Overhead equipment	Overhead Secondary	Repair		II
5119539	K27150	09/03/2015	20:25	09/03/2015	23:33	1	187	187	Overhead equipment	Overhead Primary	Replace - Same Size	Replace - Same Size	VI
5119545	B84006	09/03/2015	20:31	09/04/2015	1:09	59	13231	278	Underground equipment	Underground Primary	Switch/Reset	Repair	I
5119553	J33803	09/03/2015	20:35	09/03/2015	22:30	58	6613	114	Overhead equipment				V

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5119555	J33803	09/03/2015	20:39	09/03/2015	22:30	1	110	110	Overhead equipment				V
5119605	X36550	09/03/2015	20:42	09/04/2015	7:32	5	3254	650	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	IV
5119609	X36550	09/03/2015	20:54	09/04/2015	7:34	1	639	639	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	IV
5119565	U37579	09/03/2015	21:03	09/03/2015	22:20	1	76	76	Tree related-tree contact	Tree	Remove		II
5119567	307005	09/03/2015	21:08	09/03/2015	22:23	1	74	74	Tree related-tree broken	Overhead Service	Repair		VI
5119569	329146	09/03/2015	21:12	09/03/2015	21:53	10	403	40	Overhead equipment	Overhead Secondary	Repair	Replace - New Size	V
5119571	L90359	09/03/2015	21:21	09/03/2015	22:08	1	46	46	Overhead equipment				V
5119573	H22349	09/03/2015	21:26	09/03/2015	22:07	1	40	40	Overhead equipment				V
5119575	B62003	09/03/2015	21:27	09/04/2015	4:40	10	4331	433	Underground equipment	Other		Repair	I
5119579	B62003	09/03/2015	21:35	09/04/2015	3:50	13	4883	375	Underground equipment	Underground Transformer	Repair	Replace - Same Size	I
5119583	HC9325	09/03/2015	21:44	09/04/2015	0:13	13	1936	148	Underground equipment	Underground Primary		Repair	VI
5119595	Q18245	09/03/2015	22:46	09/04/2015	1:14	31	4587	147	Underground equipment	Underground Primary	Switch/Reset	Repair	VI
5119601	B73002	09/03/2015	23:38	09/04/2015	1:00	1	81	81	Unknown	Fuse	Replace - Same Size		I
5119617	K67911	09/04/2015	1:05	09/04/2015	2:13	4	270	67	Overhead equipment	Fuse	Replace - Same Size	Patrol/Test/Inspect	VI
5119623	M54292	09/04/2015	1:19	09/04/2015	3:00	1	100	100	Overhead equipment	Transformer Fuse	Replace - Same Size		V
5119627	R65451	09/04/2015	1:49	09/04/2015	5:41	24	5566	231	Underground equipment	Underground Primary	Switch/Reset	Switch/Reset	IV
5119629	M26161	09/04/2015	2:04	09/04/2015	7:38	1	333	333	Unknown	Recloser			III
5119631	M26161	09/04/2015	2:14	09/04/2015	7:38	1	323	323	Unknown	Recloser			III
5119633	M26161	09/04/2015	2:17	09/04/2015	7:38	1	320	320	Unknown	Recloser			III
5119635	M26161	09/04/2015	2:24	09/04/2015	7:38	1	313	313	Unknown	Recloser			III
5119637	M26161	09/04/2015	2:36	09/04/2015	7:38	1	301	301	Unknown	Recloser			III
5119641	U93563	09/04/2015	2:59	09/04/2015	4:33	1	93	93	Overhead equipment	Transformer Fuse	Replace - Same Size		II
5119651	M26161	09/04/2015	5:35	09/04/2015	7:38	36	4429	123	Unknown	Recloser	Replace - Same Size		III
5119655	HB0391	09/04/2015	6:38	09/04/2015	6:40	4	8	2	Unknown				IV
5119663	K71810	09/04/2015	6:45	09/04/2015	8:00	17	1274	74	Unknown	Fuse	Repair		IV
5119671	U11531	09/04/2015	6:51	09/04/2015	10:46	1	234	234	Underground equipment	Underground Transformer	Repair	Repair	II
5119673	D60001	09/04/2015	6:57	09/04/2015	9:13	1	135	135	Overhead equipment	Fuse	Replace - Same Size		III
5119843	D60001	09/04/2015	7:07	09/04/2015	9:01	1	113	113	Underground equipment	Underground Primary			III
5119675	Y36559	09/04/2015	7:09	09/04/2015	7:24	5	73	14	Animal related	Fuse	Repair	Replace - Same Size	IV
5119681	D60001	09/04/2015	7:36	09/04/2015	9:12	1	95	95	Overhead equipment	Fuse	Replace - Same Size		III
5119683	V23522	09/04/2015	7:47	09/04/2015	8:56	1	68	68	Overhead equipment	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	II
5119687	A48004	09/04/2015	7:47	09/04/2015	10:02	77	10354	134	Overhead equipment				I
5119691	M41111	09/04/2015	7:51	09/04/2015	8:36	1	44	44	Overhead equipment	Overhead Secondary	Repair	Replace - Same Size	I
5119695	U52516	09/04/2015	8:04	09/04/2015	10:50	4	660	165	Animal related	Fuse	Replace - Same Size		II
5119697	Y13043	09/04/2015	8:08	09/04/2015	9:20	45	3206	71	Overhead equipment	Fuse	Replace - Same Size		IV
5119701	V92543	09/04/2015	8:16	09/04/2015	9:25	5	341	68	Animal related	Transformer Fuse	Replace - Same Size	Replace - Same Size	II
5119707	N58144	09/04/2015	8:20	09/04/2015	10:45	19	2769	145	Public	Pole	Repair	Replace - Same Size	I
5119845	D60001	09/04/2015	8:20	09/04/2015	9:01	4	160	40	Underground equipment	Underground Primary			III
5119713	V99562	09/04/2015	8:31	09/04/2015	10:10	1	98	98	Animal related	Transformer Fuse	Replace - Same Size	Replace - Same Size	II
5119721	U73599	09/04/2015	8:39	09/04/2015	10:44	1	124	124	Animal related	Fuse	Replace - Same Size		II
5119727	S49550	09/04/2015	8:52	09/04/2015	9:26	1	33	33	Overhead equipment	Fuse		Replace - Same Size	VI
5119743	Q11517	09/04/2015	9:10	09/04/2015	10:22	10	719	71	Animal related	Fuse	Replace - Same Size		I
5119751	X77543	09/04/2015	9:29	09/04/2015	10:00	2	61	30	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
5119773	R84148	09/04/2015	10:06	09/04/2015	12:40	1	153	153	Overhead equipment	Fuse	Replace - Same Size		I
5119805	N58144	09/04/2015	10:40	09/04/2015	13:30	1	169	169	Public	Fuse	Replace - Same Size		I
5119809	P72320	09/04/2015	10:42	09/04/2015	11:48	1	65	65	Overhead equipment	Overhead Service	Repair		V
5119811	T23528	09/04/2015	10:44	09/04/2015	12:08	5	422	84	Public	Underground Primary	Repair		VI
5119819	HE3303	09/04/2015	11:11	09/04/2015	13:10	9	1063	118	Overhead equipment	Overhead Transformer	Replace - Same Size	Replace - New Size	VI
5119825	M05361	09/04/2015	11:41	09/04/2015	14:10	1	148	148	Underground equipment	Underground Service	Disconnect	Repair	V
5119833	A36001	09/04/2015	11:59	09/04/2015	12:53	1	53	53	Tree related-tree broken				I
5119873	R60551	09/04/2015	13:26	09/04/2015	18:00	1	273	273	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	IV
5119891	Q82906	09/04/2015	14:04	09/04/2015	14:36	1	31	31	Animal related	Fuse	Replace - Same Size		VI
5119907	P26283	09/04/2015	14:46	09/04/2015	16:24	3	293	97	Overhead equipment	Overhead Transformer	Replace - Same Size		I
5119913	R20502	09/04/2015	14:59	09/04/2015	18:37	1	217	217	Underground equipment	Underground Service		Repair	IV
5119929	S68512	09/04/2015	15:11	09/04/2015	20:52	5	1690	341	Public				VI
5119943	B38002	09/04/2015	15:26	09/04/2015	17:27	6	724	120	Overhead equipment	Jumper	Repair		I

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5119939	P57108	09/04/2015	15:30	09/04/2015	15:59	1	29	29	Other				VI
5119945	B71001	09/04/2015	15:42	09/04/2015	17:02	9	712	79	Overhead equipment	Overhead Transformer	Replace - Same Size		I
5119957	L14231	09/04/2015	16:03	09/04/2015	20:10	345	21454	246	Overhead equipment	Pole			III
5119969	K91115	09/04/2015	16:08	09/04/2015	17:45	1	96	96	Overhead equipment	Pole	Patrol/Test/Inspect		III
5119971	L08226	09/04/2015	16:17	09/04/2015	17:37	1	79	79	Overhead equipment	Pole	Patrol/Test/Inspect		III
5119973	M18131	09/04/2015	16:20	09/04/2015	17:43	1	82	82	Overhead equipment	Pole	Patrol/Test/Inspect		III
5119977	L08226	09/04/2015	16:26	09/04/2015	17:48	1	81	81	Overhead equipment	Pole	Remove		III
5119987	R41131	09/04/2015	16:27	09/04/2015	19:35	79	14840	187	Overhead equipment				VI
5119995	R41131	09/04/2015	16:35	09/04/2015	19:35	1	179	179	Overhead equipment	Overhead Primary	Repair	Repair	VI
5154969	B46002	09/04/2015	16:36	09/04/2015	17:37	114	6891	60	Overhead equipment				I
5120005	J67133	09/04/2015	16:47	09/04/2015	17:46	1	58	58	Overhead equipment	Overhead Service			III
5120045	S55566	09/04/2015	17:55	09/04/2015	19:34	1	98	98	Animal related	Transformer Fuse	Replace - Same Size		VI
5120049	S43512	09/04/2015	17:58	09/04/2015	20:20	6	848	141	Overhead equipment				VI
5120283	S43512	09/04/2015	18:03	09/05/2015	0:15	5	1857	371	Overhead equipment	Overhead Transformer	Repair	Replace - Same Size	VI
5120057	B79005	09/04/2015	18:28	09/04/2015	19:17	1	48	48	Overhead equipment				I
5120073	X19561	09/04/2015	18:58	09/05/2015	0:34	27	4618	336	Overhead equipment	Fuse	Replace - Same Size		IV
5120063	X77586	09/04/2015	18:59	09/04/2015	20:00	1	60	60	Tree related-tree broken				IV
5120065	X19561	09/04/2015	19:00	09/04/2015	22:07	1	186	186	Overhead equipment	Fuse	Replace - Same Size		IV
5120075	R09226	09/04/2015	19:14	09/04/2015	20:26	10	718	71	Overhead equipment	Fuse			III
5120077	L82187	09/04/2015	19:18	09/04/2015	19:59	1	40	40	Overhead equipment	Fuse	Replace - Same Size		IV
5120079	R48167	09/04/2015	19:22	09/04/2015	22:42	4	796	199	Weather	Transformer Fuse	Replace - Same Size		IV
5120089	L74193	09/04/2015	19:27	09/04/2015	21:35	80	10204	127	Tree related-tree broken	Fuse	Replace - Same Size		IV
5120083	L68114	09/04/2015	19:29	09/04/2015	22:02	7	1073	153	Weather				IV
5120087	B00005	09/04/2015	19:34	09/05/2015	3:30	8	3803	475	Overhead equipment	Other		Repair	I
5120091	R48166	09/04/2015	19:36	09/05/2015	8:49	6	4757	792	Weather				IV
5120101	L74193	09/04/2015	19:38	09/04/2015	21:04	18	1541	85	Tree related-tree broken	Fuse	Replace - Same Size		IV
5120117	L74191	09/04/2015	19:39	09/05/2015	0:42	8	2426	303	Tree related-tree broken	Tree	Remove	Remove	IV
5120105	R09225	09/04/2015	19:41	09/04/2015	21:25	25	2578	103	Overhead equipment				III
5120107	R48165	09/04/2015	19:46	09/05/2015	9:53	1	846	846	Tree related-tree broken	Overhead Service	Repair		IV
5120113	L68114	09/04/2015	19:48	09/05/2015	3:38	7	3284	469	Tree related-tree broken	Tree	Remove	Remove	IV
5120307	R48166	09/04/2015	19:49	09/04/2015	23:20	15	3164	210	Overhead equipment	Fuse	Replace - Same Size		IV
5120125	R48167	09/04/2015	19:50	09/05/2015	3:37	60	27991	466	Tree related-tree broken	Overhead Primary			IV
5120131	R09226	09/04/2015	19:51	09/04/2015	21:48	1	116	116	Overhead equipment				III
5120413	M45211	09/04/2015	19:53	09/05/2015	0:03	44	11011	250	Substation equipment				IV
5120351	L68114	09/04/2015	19:55	09/05/2015	7:33	7	4884	697	Overhead equipment				IV
5120415	M45211	09/04/2015	19:55	09/04/2015	23:45	850	195389	229	Substation equipment	Substation Transformer	Repair	Replace - Same Size	IV
5120409	M45211	09/04/2015	19:58	09/05/2015	0:11	73	18512	253	Substation equipment				IV
5120165	R09226	09/04/2015	19:59	09/04/2015	21:49	1	109	109	Overhead equipment				III
5120163	L82187	09/04/2015	19:59	09/05/2015	6:20	1	620	620	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	IV
5120229	M45211	09/04/2015	20:00	09/04/2015	23:04	157	28963	184	Overhead equipment				IV
5120187	R09225	09/04/2015	20:02	09/04/2015	21:49	1	106	106	Overhead equipment				III
5120207	R09226	09/04/2015	20:05	09/04/2015	21:50	1	104	104	Overhead equipment				III
5120209	R09226	09/04/2015	20:05	09/04/2015	22:27	3	423	141	Overhead equipment				III
5120215	P83710	09/04/2015	20:06	09/05/2015	2:00	1	353	353	Overhead equipment	Overhead Transformer	Repair	Repair	I
5120219	L68114	09/04/2015	20:06	09/05/2015	2:05	14	5019	358	Tree related-tree broken				IV
5120231	R60552	09/04/2015	20:09	09/04/2015	23:41	6	1273	212	Weather	Overhead Primary	Patrol/Test/Inspect	Repair	IV
5120263	J61115	09/04/2015	20:10	09/04/2015	22:04	877	100258	114	Overhead equipment	Regulator			III
5120417	L80221	09/04/2015	20:11	09/04/2015	23:00	20	3367	168	Overhead equipment	Recloser	Replace - Same Size		IV
5120253	L74193	09/04/2015	20:12	09/05/2015	8:32	8	5916	739	Weather	Tree	Remove		IV
5120279	K76545	09/04/2015	20:18	09/04/2015	22:46	16	2358	147	Weather	Fuse	Replace - Same Size		IV
5120281	R09226	09/04/2015	20:18	09/04/2015	22:27	1	128	128	Overhead equipment				III
5120291	K71822	09/04/2015	20:21	09/04/2015	21:39	42	3238	77	Weather	Fuse	Replace - Same Size		IV
5120325	D69004	09/04/2015	20:28	09/05/2015	0:38	97	24283	250	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
5120449	D69004	09/04/2015	20:29	09/05/2015	1:33	14	4248	303	Underground equipment	Underground Primary			I
5120411	M45211	09/04/2015	20:31	09/05/2015	0:19	35	7981	228	Substation equipment	Substation Transformer	Repair	Replace - Same Size	IV
5120301	B93003	09/04/2015	20:33	09/04/2015	22:15	1	101	101	Unknown	Transformer Fuse	Replace - Same Size		I

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5120303	K74166	09/04/2015	20:33	09/05/2015	4:45	7	3442	491	Tree related-tree contact	Overhead Secondary			IV
5120433	K74164	09/04/2015	20:51	09/05/2015	1:45	4	1172	293	Tree related-tree broken	Overhead Secondary	Patrol/Test/Inspect	Repair	IV
5120319	Q15844	09/04/2015	20:57	09/04/2015	21:30	1	32	32	Overhead equipment				V
5120329	K71812	09/04/2015	20:58	09/04/2015	22:17	43	3409	79	Weather				IV
5120323	Q15844	09/04/2015	20:58	09/04/2015	21:30	1	31	31	Overhead equipment				V
5120337	Q15844	09/04/2015	21:10	09/04/2015	21:30	1	19	19	Overhead equipment				V
5120339	R60552	09/04/2015	21:20	09/04/2015	23:41	1	140	140	Weather	Fuse	Patrol/Test/Inspect	Repair	IV
5120343	Z04520	09/04/2015	21:24	09/04/2015	22:15	1	50	50	Weather	Transformer Fuse	Replace - Same Size		IV
5120349	H07106	09/04/2015	21:28	09/05/2015	1:58	1	269	269	Unknown	Recloser			IV
5120355	X81555	09/04/2015	21:49	09/04/2015	23:15	1	85	85	Weather	Transformer Fuse	Replace - Same Size		IV
5120357	R48166	09/04/2015	21:51	09/05/2015	7:03	1	551	551	Weather	Fuse	Replace - Same Size		IV
5120375	R09225	09/04/2015	21:56	09/04/2015	22:03	1	6	6	Overhead equipment				III
5120385	L74193	09/04/2015	22:03	09/05/2015	12:08	1	844	844	Tree related-tree broken	Tree	Remove		IV
5120391	K76545	09/04/2015	22:12	09/04/2015	22:46	40	1323	33	Weather	Fuse	Replace - Same Size		IV
5120393	R09226	09/04/2015	22:15	09/04/2015	22:28	1	12	12	Overhead equipment				III
5120401	Q74149	09/04/2015	22:29	09/05/2015	7:40	1	550	550	Overhead equipment	Overhead Transformer			IV
5120421	L74193	09/04/2015	22:49	09/05/2015	3:45	38	11213	295	Weather	Fuse	Replace - Same Size		IV
5120425	L74193	09/04/2015	22:55	09/05/2015	3:45	1	289	289	Weather	Fuse	Replace - Same Size		IV
5120447	U06524	09/05/2015	1:11	09/05/2015	4:50	1	218	218	Tree related-tree broken	Tree	Remove		II
5120469	M45211	09/05/2015	3:21	09/05/2015	3:38	1160	19546	16	Other				IV
5120489	H00163	09/05/2015	3:55	09/05/2015	8:39	52	14804	284	Underground equipment	Underground Primary		Repair	III
5120493	R65452	09/05/2015	4:01	09/05/2015	7:00	32	5718	178	Underground equipment	Underground Primary	Switch/Reset	Switch/Reset	IV
5120499	Q32171	09/05/2015	4:25	09/05/2015	9:10	49	10077	285	Tree related-tree broken	Fuse	Replace - Same Size	Patrol/Test/Inspect	I
5120505	U06524	09/05/2015	4:59	09/05/2015	5:55	1	55	55	Overhead equipment	Overhead Service	Repair		II
5120509	T23527	09/05/2015	5:23	09/05/2015	7:52	7	1042	148	Animal related	Disconnect Switch	Patrol/Test/Inspect	Replace - New Size	VI
5120511	M45211	09/05/2015	5:52	09/05/2015	7:22	2	178	89	Overhead equipment				IV
5120513	V77543	09/05/2015	5:55	09/05/2015	7:13	5	388	77	Overhead equipment	Overhead Secondary	Replace - Same Size		II
5120515	R48166	09/05/2015	5:58	09/05/2015	7:01	1	62	62	Weather	Fuse	Replace - Same Size		IV
5120523	L71171	09/05/2015	6:27	09/05/2015	11:56	10	3289	328	Tree related-tree contact	Tree			IV
5120529	P26283	09/05/2015	7:12	09/05/2015	13:05	1	352	352	Weather	Transformer Fuse	Replace - Same Size	Repair	I
5120539	P26281	09/05/2015	7:19	09/05/2015	9:05	5	525	105	Animal related	Transformer Fuse	Repair		I
5120553	U64518	09/05/2015	7:36	09/05/2015	9:12	1	95	95	Overhead equipment	Overhead Service	Repair		II
5120607	Q06144	09/05/2015	7:40	09/05/2015	16:23	1	522	522	Overhead equipment	Overhead Transformer	Repair		IV
5120559	V41527	09/05/2015	7:51	09/05/2015	8:54	10	626	62	Animal related	Transformer Fuse	Replace - Same Size		II
5120775	X83533	09/05/2015	8:00	09/05/2015	14:31	8	3126	390	Overhead equipment	Overhead Transformer	Replace - Same Size	Repair	IV
5120563	B77002	09/05/2015	8:04	09/05/2015	8:48	70	3014	43	Unknown	Disconnect Switch	Replace - Same Size	Replace - Same Size	I
5120565	Q32171	09/05/2015	8:07	09/05/2015	8:37	1	29	29	Tree related-tree broken	Fuse			I
5120767	X83533	09/05/2015	8:15	09/05/2015	10:39	15	2151	143	Tree related-tree contact	Tree	Trim		IV
5120571	J50185	09/05/2015	8:16	09/05/2015	11:45	1	208	208	Underground equipment	Underground Service		Repair	III
5120573	C37002	09/05/2015	8:17	09/05/2015	13:15	4	1188	297	Underground equipment	Underground Primary	Repair	Repair	III
5120575	Z29579	09/05/2015	8:28	09/05/2015	12:34	4	982	245	Weather	Fuse	Replace - Same Size		IV
5120579	X82576	09/05/2015	8:32	09/05/2015	11:00	25	3681	147	Weather	Disconnect Switch	Replace - Same Size	Replace - Same Size	IV
5120581	T15570	09/05/2015	8:32	09/05/2015	10:01	1	88	88	Animal related	Transformer Fuse	Replace - Same Size		VI
5120583	R48166	09/05/2015	8:39	09/05/2015	11:31	1	171	171	Tree related-tree broken	Overhead Service			IV
5120589	L12125	09/05/2015	8:43	09/05/2015	12:41	3	712	237	Overhead equipment	Overhead Transformer		Replace - Same Size	III
5120615	Q74149	09/05/2015	8:49	09/05/2015	10:52	3	367	122	Tree related-tree broken	Overhead Primary			IV
5120599	M81402	09/05/2015	8:57	09/05/2015	9:33	2	70	35	Animal related	Fuse	Replace - Same Size		V
5120601	Y23521	09/05/2015	8:58	09/05/2015	10:28	10	891	89	Overhead equipment	Transformer Fuse	Repair	Replace - Same Size	IV
5120611	R48167	09/05/2015	9:24	09/05/2015	12:07	4	651	162	Overhead equipment	Overhead Transformer			IV
5120753	L12125	09/05/2015	9:52	09/05/2015	11:28	11	1052	95	Public	Other			III
5120741	M31201	09/05/2015	9:55	09/05/2015	11:49	1	113	113	Overhead equipment	Overhead Secondary	Repair		I
5120745	X83533	09/05/2015	10:01	09/05/2015	11:45	3	311	103	Weather	Transformer Fuse	Replace - Same Size	Replace - Same Size	IV
5120747	Q11516	09/05/2015	10:05	09/05/2015	11:30	66	5578	84	Weather	Fuse	Replace - Same Size		I
5120757	M26164	09/05/2015	10:07	09/05/2015	11:59	1	111	111	Public	Overhead Service	Raise		III
5120759	L73185	09/05/2015	10:11	09/05/2015	12:48	1	156	156	Weather	Transformer Fuse	Replace - Same Size		IV
5120773	Q11516	09/05/2015	11:01	09/05/2015	12:10	16	1103	68	Tree related-tree contact	Fuse	Replace - Same Size		I

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5120777	S09520	09/05/2015	11:12	09/05/2015	13:15	1	122	122	Underground equipment	Overhead Service	Repair		VI
5120781	X82004	09/05/2015	11:17	09/05/2015	13:20	1	122	122	Overhead equipment	Overhead Transformer	Replace - Same Size	Repair	IV
5120787	V69546	09/05/2015	11:45	09/05/2015	14:44	1	179	179	Underground equipment	Underground Primary			II
5120789	Z19547	09/05/2015	12:01	09/05/2015	13:15	1	73	73	Animal related	Transformer Fuse	Replace - Same Size		IV
5120797	V76526	09/05/2015	12:16	09/05/2015	13:39	1	82	82	Overhead equipment	Fuse	Replace - Same Size		II
5120805	N73121	09/05/2015	12:32	09/05/2015	14:00	1	87	87	Tree related-tree broken	Overhead Service	Repair		IV
5120809	D96001	09/05/2015	12:54	09/05/2015	14:12	1	77	77	Unknown	Transformer Fuse	Replace - Same Size	Replace - Same Size	I
5120813	M07236	09/05/2015	12:57	09/05/2015	15:00	10	1227	122	Overhead equipment	Transformer Fuse	Replace - Same Size		III
5120815	F22001	09/05/2015	13:00	09/05/2015	17:00	5	1196	239	Overhead equipment	Overhead Transformer		Repair	IV
5120817	Y63541	09/05/2015	13:06	09/05/2015	14:00	1	53	53	Overhead equipment	Fuse	Replace - Same Size		IV
5120827	N73121	09/05/2015	13:19	09/05/2015	14:00	1	40	40	Tree related-tree broken	Overhead Service	Repair		IV
5120829	Z11506	09/05/2015	13:34	09/05/2015	14:50	1	75	75	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
5120833	B19002	09/05/2015	13:53	09/05/2015	16:55	2	363	181	Underground equipment	Underground Primary	Repair	Repair	I
5120835	Q06131	09/05/2015	13:55	09/05/2015	14:40	1	44	44	Overhead equipment	Fuse	Repair		IV
5120839	G10001	09/05/2015	14:01	09/05/2015	15:30	1	88	88	Overhead equipment	Overhead Secondary	Repair		I
5120841	K15205	09/05/2015	14:15	09/06/2015	4:45	23	20005	869	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	VI
5120843	L70125	09/05/2015	14:20	09/05/2015	14:59	1	38	38	Tree related-tree broken				IV
5120859	D96001	09/05/2015	15:49	09/05/2015	20:59	1	309	309	Underground equipment	Underground Primary	Replace - Same Size	Repair	I
5120863	P47120	09/05/2015	16:14	09/05/2015	18:35	3	376	140	Overhead equipment	Insulator	Replace - Same Size		I
5120973	T46-UNIT-1	09/05/2015	16:17	09/05/2015	18:32	1138	152913	134	Public				VI
5120883	343008	09/05/2015	16:18	09/05/2015	18:35	21	2877	137	Public				VI
5120885	P26283	09/05/2015	16:18	09/05/2015	17:41	4	329	82	Animal related	Transformer Fuse	Repair		I
5120923	325010	09/05/2015	16:21	09/05/2015	18:36	19	2578	135	Public				VI
5120979	343007	09/05/2015	16:33	09/05/2015	18:38	1	124	124	Public	Pole		Replace - Same Size	VI
5120983	N35851	09/05/2015	16:36	09/05/2015	21:00	5	1318	263	Overhead equipment	Overhead Transformer	Replace - Same Size	Replace - Same Size	V
5120989	S64501	09/05/2015	17:03	09/06/2015	2:09	1	545	545	Other	Underground Primary	Disconnect	Repair	VI
5120995	J63172	09/05/2015	17:06	09/05/2015	19:00	1	113	113	Overhead equipment	Overhead Service		Repair	III
5121009	Q28141	09/05/2015	17:39	09/05/2015	23:00	7	2240	320	Overhead equipment	Overhead Transformer		Repair	VI
5121011	N86228	09/05/2015	17:43	09/05/2015	18:53	8	557	69	Overhead equipment	Overhead Service	Repair		VI
5121013	R28870	09/05/2015	18:04	09/05/2015	20:10	1	125	125	Overhead equipment	Connector	Replace - New Size		V
5121021	341002	09/05/2015	18:44	09/05/2015	19:23	1	38	38	Public				VI
5121023	T46001	09/05/2015	19:05	09/05/2015	19:20	1	14	14	Public				VI
5121031	Y32001	09/05/2015	19:15	09/05/2015	21:43	8	1181	147	Other				IV
5121033	T46001	09/05/2015	19:15	09/05/2015	19:28	1	12	12	Public	Pole		Replace - Same Size	VI
5121037	325008	09/05/2015	19:22	09/05/2015	19:37	1	14	14	Public	Pole		Replace - Same Size	VI
5121041	B62003	09/05/2015	19:43	09/05/2015	22:14	2	302	151	Underground equipment	Underground Primary	Disconnect	Repair	I
5121045	R23332	09/05/2015	19:46	09/05/2015	21:10	1	83	83	Tree related-tree broken	Fuse	Replace - Same Size		V
5121085	B62003	09/05/2015	20:04	09/06/2015	2:56	3	1236	412	Underground equipment	Underground Primary	Disconnect	Repair	I
5121055	343008	09/05/2015	20:14	09/05/2015	22:00	1	105	105	Overhead equipment	Disconnect Switch	Repair		VI
5121061	341002	09/05/2015	20:30	09/06/2015	3:30	10	4196	419	Public	Pole	Repair		VI
5121067	P57102	09/05/2015	20:42	09/05/2015	22:05	8	656	82	Overhead equipment	Overhead Service	Repair	Replace - Same Size	VI
5121091	T06504	09/05/2015	22:51	09/06/2015	3:19	60	13159	268	Tree related-tree broken	Tree	Trim		VI
5121099	Q06131	09/05/2015	23:51	09/06/2015	3:48	1	236	236	Overhead equipment	Overhead Secondary	Repair		IV
5121101	R39934	09/06/2015	0:47	09/06/2015	3:08	1	140	140	Overhead equipment	Fuse	Replace - Same Size	Patrol/Test/Inspect	VI
5121107	M78323	09/06/2015	4:03	09/06/2015	6:00	26	3036	116	Overhead equipment	Fuse	Replace - Same Size		V
5121109	L73154	09/06/2015	4:39	09/06/2015	5:29	1	50	50	Public	Overhead Service	Disconnect	Cut in Clear	IV
5121111	341002	09/06/2015	5:23	09/06/2015	7:35	1	131	131	Overhead equipment	Fuse	Replace - Same Size		VI
5121115	J58380	09/06/2015	6:27	09/06/2015	9:55	16	3314	207	Underground equipment	Underground Primary		Repair	III
5121119	U73583	09/06/2015	7:09	09/06/2015	15:00	14	6584	470	Underground equipment	Underground Primary	Repair	Repair	II
5121121	R48166	09/06/2015	7:10	09/06/2015	9:08	1	117	117	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
5121125	K28180	09/06/2015	7:11	09/06/2015	8:57	83	8788	105	Overhead equipment	Fuse	Replace - Same Size		III
5121127	341002	09/06/2015	7:11	09/06/2015	7:41	1	29	29	Overhead equipment	Fuse	Replace - Same Size		VI
5121131	X88510	09/06/2015	7:16	09/06/2015	8:30	3	220	73	Animal related	Overhead Transformer		Install	IV
5121133	K28180	09/06/2015	7:18	09/06/2015	8:57	4	393	98	Overhead equipment	Fuse	Replace - Same Size		III
5121135	E10002	09/06/2015	7:26	09/06/2015	10:40	1	193	193	Overhead equipment	Overhead Transformer	Replace - Same Size		III
5121139	K28180	09/06/2015	7:42	09/06/2015	8:57	1	74	74	Overhead equipment	Fuse	Replace - Same Size		III

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5121143	J84124	09/06/2015	7:52	09/06/2015	10:21	1	148	148	Tree related-tree broken	Overhead Service	Replace - New Size		VI
5121145	P44324	09/06/2015	8:14	09/06/2015	9:50	1	95	95	Unknown	Fuse	Replace - Same Size		I
5121155	Y20522	09/06/2015	8:32	09/06/2015	14:13	21	4871	341	Underground equipment	Underground Primary	Repair	Repair	IV
5121151	D66004	09/06/2015	9:00	09/06/2015	9:34	1	33	33	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
5121157	D92002	09/06/2015	9:21	09/06/2015	12:55	2	427	213	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	I
5121159	K08909	09/06/2015	9:25	09/06/2015	10:47	1	81	81	Animal related	Fuse	Repair		VI
5121167	D41003	09/06/2015	9:43	09/06/2015	10:38	1	54	54	Unknown	Disconnect Switch	Replace - Same Size	Replace - Same Size	I
5121171	V25513	09/06/2015	10:11	09/06/2015	11:31	1	79	79	Overhead equipment	Overhead Service	Replace - Same Size		II
5121173	S04513	09/06/2015	10:21	09/06/2015	15:12	5	1454	290	Tree related-tree broken	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	VI
5121175	U16500	09/06/2015	10:33	09/06/2015	11:46	1	72	72	Animal related	Transformer Fuse	Replace - Same Size		II
5121179	X83533	09/06/2015	11:23	09/06/2015	12:16	1	52	52	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
5121181	J08207	09/06/2015	11:48	09/06/2015	14:07	1	138	138	Public	Overhead Secondary	Repair		I
5121185	Q32171	09/06/2015	12:51	09/06/2015	14:35	1	103	103	Overhead equipment	Fuse	Replace - Same Size		I
5121193	L42158	09/06/2015	13:32	09/06/2015	14:31	1	58	58	Tree related-tree broken	Overhead Service	Reconnect		III
5121199	V59577	09/06/2015	13:42	09/06/2015	16:09	1	146	146	Overhead equipment	Transformer Fuse	Replace - Same Size		II
5121211	M19222	09/06/2015	14:40	09/06/2015	18:55	1	254	254	Overhead equipment	Disconnect Switch		Replace - Same Size	VI
5121215	A85002	09/06/2015	15:35	09/06/2015	21:30	2	708	354	Underground equipment	Underground Primary	Patrol/Test/Inspect		I
5121217	P09307	09/06/2015	15:45	09/06/2015	17:05	8	636	79	Overhead equipment	Transformer Fuse	Replace - New Size	Replace - New Size	V
5121221	K95204	09/06/2015	16:01	09/06/2015	17:04	1	62	62	Tree related-tree broken	Overhead Service	Reconnect		III
5121223	K95204	09/06/2015	16:04	09/06/2015	17:07	1	62	62	Tree related-tree broken	Overhead Service	Reconnect		III
5121225	B57002	09/06/2015	16:07	09/06/2015	18:58	1	170	170	Overhead equipment	Overhead Service	Reconnect		I
5121343	C50001	09/06/2015	17:08	09/06/2015	21:04	483	113978	235	Overhead equipment	Overhead Primary	Replace - Same Size		III
5121243	P72320	09/06/2015	17:11	09/06/2015	18:26	76	5668	74	Other	Fuse	Replace - Same Size	Replace - Same Size	V
5121323	B73003	09/06/2015	17:39	09/06/2015	21:31	5	1156	231	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Repair	I
5121325	M37191	09/06/2015	17:43	09/06/2015	20:30	11	1827	166	Overhead equipment	Overhead Transformer	Switch/Reset	Replace - New Size	I
5121329	P61110	09/06/2015	17:45	09/06/2015	19:10	1	84	84	Overhead equipment	Transformer Fuse	Repair	Replace - Same Size	VI
5121339	K65221	09/06/2015	18:06	09/06/2015	19:36	1	89	89	Overhead equipment	Transformer Fuse		Replace - Same Size	III
5121341	K65221	09/06/2015	18:07	09/06/2015	19:51	1	103	103	Overhead equipment	Transformer Fuse		Replace - Same Size	III
5121345	V23522	09/06/2015	18:17	09/06/2015	22:20	4	969	242	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	II
5121367	A85002	09/06/2015	20:05	09/06/2015	23:36	5	1054	210	Underground equipment	Underground Primary	Patrol/Test/Inspect	Reconnect	I
5121369	R95520	09/06/2015	20:08	09/06/2015	22:15	1	126	126	Unknown	Transformer Fuse	Repair		I
5121383	Y36559	09/06/2015	20:41	09/06/2015	22:25	53	5494	103	Underground equipment	Fuse		Repair	IV
5121385	331152	09/06/2015	21:14	09/06/2015	22:20	1	65	65	Tree related-tree broken	Overhead Service	Repair	Repair	V
5121391	R49275	09/06/2015	21:57	09/07/2015	0:56	12	2049	179	Tree related-tree contact	Overhead Primary	Cut in Clear		VI
5121399	J58381	09/06/2015	23:30	09/07/2015	3:54	65	15872	264	Underground equipment	Underground Primary		Repair	III
5121407	V92543	09/07/2015	0:09	09/07/2015	2:10	30	3602	120	Unknown	Fuse	Replace - Same Size	Patrol/Test/Inspect	II
5121409	R49275	09/07/2015	0:52	09/07/2015	0:56	10	37	3	Overhead equipment				VI
5121413	R49275	09/07/2015	0:57	09/07/2015	2:51	12	1367	113	Tree related-tree contact	Overhead Primary	Cut in Clear		VI
5121415	D28124	09/07/2015	0:59	09/07/2015	2:49	1	109	109	Animal related	Fuse	Replace - Same Size		I
5121417	338006	09/07/2015	1:03	09/07/2015	1:35	1	31	31	Public	Overhead Service	Disconnect		VI
5121423	D31017	09/07/2015	1:10	09/07/2015	4:23	21	4044	192	Animal related	Fuse	Replace - Same Size		III
5121427	S09521	09/07/2015	2:55	09/07/2015	8:53	47	16807	357	Underground equipment	Underground Primary		Patrol/Test/Inspect	VI
5121429	S09521	09/07/2015	5:20	09/07/2015	8:53	9	1909	212	Underground equipment	Underground Primary	Repair	Repair	VI
5121439	A42005	09/07/2015	7:01	09/07/2015	10:10	7	1318	188	Animal related	Fuse		Replace - Same Size	I
5121445	A42005	09/07/2015	7:10	09/07/2015	9:50	53	8456	159	Animal related	Fuse		Replace - Same Size	I
5121443	A81001	09/07/2015	7:16	09/07/2015	10:54	30	6530	218	Underground equipment	Underground Primary	Switch/Reset		I
5121465	Q80354	09/07/2015	7:25	09/07/2015	8:35	395	27440	69	Animal related	Overhead Transformer			V
5121495	Y97512	09/07/2015	7:37	09/07/2015	9:28	1	110	110	Animal related	Fuse	Replace - Same Size		IV
5121557	Q64919	09/07/2015	7:47	09/07/2015	10:15	14	2066	147	Public	Pole	Repair	Replace - Same Size	VI
5121505	A80001	09/07/2015	7:56	09/07/2015	9:18	23	1868	81	Animal related	Fuse	Replace - Same Size		I
5121507	A36001	09/07/2015	7:57	09/07/2015	11:33	1	215	215	Animal related				I
5121511	T29561	09/07/2015	8:08	09/07/2015	9:18	54	3743	69	Animal related	Fuse	Replace - Same Size		VI
5121519	A26005	09/07/2015	8:12	09/07/2015	9:26	97	7116	73	Unknown	Disconnect Switch	Replace - Same Size	Replace - Same Size	I
5121525	K36151	09/07/2015	8:23	09/07/2015	10:42	1	138	138	Unknown	Fuse	Replace - Same Size		III
5121527	Y31589	09/07/2015	8:31	09/07/2015	9:20	1	48	48	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
5121539	V76526	09/07/2015	9:11	09/07/2015	11:11	1	120	120	Overhead equipment	Fuse	Replace - Same Size		II

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5121543	P17107	09/07/2015	9:34	09/07/2015	11:33	38	4444	119	Underground equipment	Underground Primary	Switch/Reset	Switch/Reset	IV
5121561	U60518	09/07/2015	10:00	09/07/2015	11:10	1	69	69	Animal related	Transformer Fuse	Replace - Same Size		II
5121565	K32916	09/07/2015	10:30	09/07/2015	12:05	1	94	94	Overhead equipment	Fuse	Replace - Same Size		VI
5121577	D37001	09/07/2015	11:00	09/07/2015	17:18	108	33520	377	Underground equipment	Underground Primary	Switch/Reset	Repair	I
5121589	A68001	09/07/2015	11:16	09/07/2015	13:54	30	4712	157	Overhead equipment	Recloser		Replace - Urgent	I
5121593	K17119	09/07/2015	11:34	09/07/2015	15:42	1	247	247	Tree related-tree broken	Overhead Transformer	Repair	Repair	VI
5121595	P26280	09/07/2015	11:35	09/07/2015	12:38	30	1875	62	Unknown	Fuse	Replace - Same Size		I
5121625	M18131	09/07/2015	12:02	09/07/2015	13:54	83	9289	111	Tree related-tree broken	Overhead Primary	Repair		III
5121643	M18131	09/07/2015	13:13	09/07/2015	17:50	1	277	277	Tree related-tree broken	Overhead Primary	Replace - Same Size		III
5121659	J20931	09/07/2015	14:34	09/07/2015	15:59	80	6837	85	Overhead equipment				VI
5121675	Y89004	09/07/2015	15:27	09/07/2015	17:30	42	5139	122	Overhead equipment	Overhead Primary	Repair	Replace - Same Size	IV
5121681	A24002	09/07/2015	15:58	09/07/2015	17:46	1	107	107	Tree related-tree broken	Tree	Remove		I
5121683	S25552	09/07/2015	16:08	09/07/2015	18:20	1	131	131	Unknown	Transformer Fuse	Replace - Same Size	Replace - Same Size	VI
5121685	D48002	09/07/2015	16:11	09/07/2015	17:21	18	1256	69	Overhead equipment	Fuse	Patrol/Test/Inspect	Replace - Same Size	I
5121697	S04512	09/07/2015	16:40	09/07/2015	19:21	1	160	160	Overhead equipment	Overhead Service	Patrol/Test/Inspect	Repair	VI
5121711	R41131	09/07/2015	17:13	09/07/2015	19:15	47	5724	121	Tree related-tree broken	Overhead Primary	Trim		VI
5121713	M45212	09/07/2015	17:31	09/08/2015	2:15	1	523	523	Underground equipment	Underground Service		Repair	IV
5121715	L93132	09/07/2015	17:38	09/07/2015	18:32	1	53	53	Underground equipment	Underground Service		Repair	VI
5121717	K91117	09/07/2015	17:52	09/07/2015	20:20	8	1184	148	Overhead equipment	Overhead Transformer		Replace - Same Size	III
5121721	K91117	09/07/2015	17:52	09/07/2015	20:20	5	737	147	Overhead equipment	Other			III
5121737	K58213	09/07/2015	18:17	09/07/2015	22:07	47	10802	229	Tree related-tree broken	Disconnect Switch		Replace - New Size	VI
5121751	U99515	09/07/2015	19:15	09/07/2015	21:14	1	118	118	Overhead equipment	Jumper	Repair		II
5121755	K39156	09/07/2015	19:30	09/07/2015	19:45	13	182	14	Overhead equipment	Transformer Fuse	Replace - Same Size		III
5121757	D28123	09/07/2015	19:55	09/07/2015	23:28	1	212	212	Overhead equipment				I
5121759	X96543	09/07/2015	20:04	09/07/2015	21:01	5	283	56	Overhead equipment	Connector	Repair		IV
5121761	Q16867	09/07/2015	20:30	09/07/2015	22:14	86	8935	103	Tree related-tree broken	Fuse	Patrol/Test/Inspect	Replace - Same Size	V
5121763	T22508	09/07/2015	20:32	09/07/2015	23:54	1	201	201	Overhead equipment	Disconnect Switch	Patrol/Test/Inspect	Replace - Same Size	VI
5121767	Q93522	09/07/2015	21:08	09/07/2015	22:40	1	91	91	Overhead equipment	Fuse	Repair	Repair	I
5121771	M45212	09/07/2015	21:11	09/07/2015	22:05	1	53	53	Animal related	Transformer Fuse	Replace - Same Size		IV
5121783	V16501	09/07/2015	22:33	09/08/2015	4:57	1	383	383	Animal related	Overhead Primary			II
5121785	P18-UNIT-1	09/07/2015	23:51	09/08/2015	0:11	1592	30805	19	Public	Overhead Primary	Replace - Same Size	Replace - Same Size	IV
5121795	T06503	09/08/2015	2:59	09/08/2015	6:00	1	180	180	Overhead equipment	Overhead Primary	Repair	Repair	VI
5121797	T06505	09/08/2015	3:49	09/08/2015	5:05	1	75	75	Overhead equipment	Fuse		Replace - Same Size	VI
5121799	N50334	09/08/2015	4:46	09/08/2015	8:45	3	715	238	Underground equipment	Underground Primary	Repair	Repair	II
5121801	T15570	09/08/2015	5:09	09/08/2015	6:48	1	98	98	Animal related	Fuse	Patrol/Test/Inspect	Repair	VI
5121805	K67924	09/08/2015	6:03	09/08/2015	7:24	1	80	80	Overhead equipment	Fuse	Replace - Same Size		VI
5121807	N54213	09/08/2015	6:11	09/08/2015	10:39	25	6497	267	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	II
5121809	S22595	09/08/2015	6:12	09/08/2015	7:45	1	92	92	Overhead equipment				VI
5121817	N54214	09/08/2015	6:49	09/08/2015	10:49	84	20105	239	Underground equipment	Underground Primary	Patrol/Test/Inspect	Switch/Reset	II
5121819	X81555	09/08/2015	6:58	09/08/2015	13:00	1	362	362	Underground equipment	Underground Primary	Repair	Repair	IV
5121821	M26164	09/08/2015	7:00	09/08/2015	9:09	1	128	128	Overhead equipment	Transformer Fuse	Repair		III
5121823	R06209	09/08/2015	7:03	09/08/2015	8:07	54	3456	63	Animal related	Fuse	Replace - Same Size		II
5121825	V10551	09/08/2015	7:03	09/08/2015	9:26	1	142	142	Animal related	Transformer Fuse	Replace - Same Size		II
5121841	Y63541	09/08/2015	7:25	09/08/2015	8:11	1	45	45	Animal related	Transformer Fuse	Replace - Same Size		IV
5121843	Q82906	09/08/2015	7:36	09/08/2015	8:17	1	40	40	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	VI
5121845	X96524	09/08/2015	7:39	09/08/2015	8:55	16	1215	75	Animal related	Fuse	Replace - Same Size		IV
5121849	X42502	09/08/2015	7:45	09/08/2015	10:10	1	144	144	Tree related-tree broken	Overhead Service	Repair		IV
5121853	Q82906	09/08/2015	7:53	09/08/2015	8:23	1	29	29	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	VI
5121863	U52516	09/08/2015	8:33	09/08/2015	10:10	1	96	96	Overhead equipment				II
5121871	K11376	09/08/2015	8:41	09/08/2015	10:40	1	118	118	Overhead equipment	Overhead Secondary	Raise	Raise	V
5121873	X96543	09/08/2015	8:44	09/08/2015	9:21	1	36	36	Animal related	Fuse	Replace - Same Size		IV
5121875	M36189	09/08/2015	8:45	09/08/2015	9:46	1	60	60	Overhead equipment	Underground Primary	Patrol/Test/Inspect	Replace - Same Size	I
5121877	X92507	09/08/2015	8:47	09/08/2015	9:50	1	62	62	Overhead equipment	Overhead Primary	Repair	Replace - Same Size	IV
5121881	Y39515	09/08/2015	8:53	09/08/2015	9:50	1	56	56	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
5121901	Z04520	09/08/2015	9:17	09/08/2015	14:49	1	332	332	Underground equipment	Underground Primary	Repair	Repair	IV
5121907	Q47833	09/08/2015	9:22	09/08/2015	10:42	1	79	79	Overhead equipment	Transformer Fuse	Repair	Repair	V

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5121921	325010	09/08/2015	9:36	09/08/2015	16:57	1	440	440	Underground equipment	Underground Service	Patrol/Test/Inspect	Repair	VI
5121927	Q70161	09/08/2015	9:37	09/08/2015	10:32	1	54	54	Unknown	Transformer Fuse	Replace - Same Size		I
5121931	J07173	09/08/2015	9:38	09/08/2015	10:21	1	42	42	Overhead equipment	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	I
5121935	A81001	09/08/2015	9:48	09/08/2015	21:40	1	711	711	Underground equipment	Underground Service	Patrol/Test/Inspect	Repair	I
5122035	Y07-XTR1	09/08/2015	9:49	09/08/2015	10:05	1079	16638	15	Substation equipment				IV
5122161	X34-XTR1	09/08/2015	9:49	09/08/2015	10:05	2124	32645	15	Overhead equipment				IV
5122351	Y07-XBK3	09/08/2015	9:49	09/08/2015	10:05	1579	23795	15	Substation equipment				IV
5122407	Y08-XTR1	09/08/2015	9:50	09/08/2015	11:00	579	40518	69	Substation equipment				IV
5121945	X30506	09/08/2015	9:50	09/08/2015	10:30	247	9842	39	Overhead equipment	High Line Switch			IV
5122153	X29-XTR2	09/08/2015	9:50	09/08/2015	10:05	1276	18821	14	Overhead equipment				IV
5121951	X30506	09/08/2015	9:50	09/08/2015	10:30	67	2655	39	Overhead equipment				IV
5121975	X29547	09/08/2015	9:50	09/08/2015	10:05	158	2279	14	Overhead equipment				IV
5122065	Y10-XTR1	09/08/2015	9:50	09/08/2015	10:05	1212	17186	14	Substation equipment				IV
5121983	X29547	09/08/2015	9:50	09/08/2015	10:05	254	3652	14	Overhead equipment				IV
5121985	X29547	09/08/2015	9:50	09/08/2015	10:05	187	2689	14	Overhead equipment				IV
5121995	X29547	09/08/2015	9:50	09/08/2015	10:05	102	1438	14	Overhead equipment				IV
5121993	X29547	09/08/2015	9:50	09/08/2015	10:05	180	2538	14	Overhead equipment				IV
5121997	X29547	09/08/2015	9:50	09/08/2015	10:05	190	2679	14	Overhead equipment				IV
5122325	X29548	09/08/2015	9:50	09/08/2015	10:10	227	4324	19	Overhead equipment				IV
5122227	Y07-XBK2	09/08/2015	9:50	09/08/2015	10:05	929	13024	14	Substation equipment				IV
5122303	X30505	09/08/2015	9:52	09/08/2015	10:10	301	5348	17	Overhead equipment				IV
5122055	X30527	09/08/2015	9:52	09/08/2015	10:30	5	185	37	Overhead equipment	High Line Switch			IV
5122129	Y11555	09/08/2015	9:54	09/08/2015	10:30	1	35	35	Overhead equipment				IV
5122135	X30506	09/08/2015	9:54	09/08/2015	10:30	1	35	35	Overhead equipment				IV
5122183	X30506	09/08/2015	9:54	09/08/2015	10:30	1	35	35	Overhead equipment				IV
5122239	Y11555	09/08/2015	9:54	09/08/2015	11:00	1	65	65	Overhead equipment				IV
5122379	X35501	09/08/2015	9:59	09/08/2015	10:30	1	30	30	Overhead equipment	Other			IV
5122401	Z30584	09/08/2015	10:00	09/08/2015	11:00	1	59	59	Overhead equipment				IV
5122419	X29547	09/08/2015	10:04	09/08/2015	10:30	1058	26481	25	Overhead equipment				IV
5122473	X34532	09/08/2015	10:14	09/08/2015	10:30	1	15	15	Overhead equipment	Other			IV
5122475	X34531	09/08/2015	10:14	09/08/2015	10:30	1	15	15	Overhead equipment	Other			IV
5122507	Y10-XTR1	09/08/2015	10:16	09/08/2015	11:00	1212	52515	43	Substation equipment				IV
5122481	X34531	09/08/2015	10:16	09/08/2015	11:00	1	43	43	Overhead equipment	Other			IV
5122521	Y07577	09/08/2015	10:17	09/08/2015	10:30	516	6279	12	Substation equipment				IV
5155145		09/08/2015	10:19	09/08/2015	11:00	1540	63140	41	Overhead equipment				IV
5155127		09/08/2015	10:19	09/08/2015	11:00	410	16740	40	Overhead equipment				IV
5122503		09/08/2015	10:19	09/08/2015	10:30	1039	10597	10	Overhead equipment				IV
5122631	L99392	09/08/2015	10:31	09/08/2015	13:25	1	173	173	Overhead equipment	Fuse		Replace - Same Size	V
5122675	K43382	09/08/2015	10:35	09/08/2015	14:22	8	1810	226	Underground equipment	Underground Service	Patrol/Test/Inspect	Repair	V
5122689	K27153	09/08/2015	10:37	09/08/2015	12:20	1	102	102	Unknown	Transformer Fuse	Replace - Same Size	Replace - Same Size	VI
5122705	X34532	09/08/2015	10:40	09/08/2015	11:00	1	19	19	Overhead equipment	Other			IV
5122715	A91001	09/08/2015	10:45	09/08/2015	15:21	30	7470	275	Underground equipment	Underground Transformer	Replace - Same Size		I
5122725	Y89535	09/08/2015	10:47	09/08/2015	12:10	1	82	82	Underground equipment	Underground Service	Repair	Replace - Same Size	IV
5122729	Y13042	09/08/2015	10:48	09/08/2015	11:00	1	11	11	Overhead equipment				IV
5122737	X29003	09/08/2015	10:51	09/08/2015	11:00	1	8	8	Overhead equipment	Other			IV
5122767	J68402	09/08/2015	10:53	09/08/2015	11:36	15	630	42	Overhead equipment	Fuse		Replace - Same Size	III
5122777	L23145	09/08/2015	11:02	09/08/2015	12:10	1	67	67	Overhead equipment	Transformer Fuse	Repair		III
5122785	C50001	09/08/2015	11:08	09/08/2015	15:20	1	251	251	Weather	Underground Primary		Repair	III
5122791	J08205	09/08/2015	11:16	09/08/2015	13:26	1	129	129	Weather	Fuse	Replace - Same Size		I
5123095	B21001	09/08/2015	11:17	09/08/2015	14:28	259	49266	190	Public	Pole	Patrol/Test/Inspect	Replace - Same Size	I
5122801	B82002	09/08/2015	11:20	09/08/2015	12:49	1	88	88	Overhead equipment	Fuse	Repair		I
5122803	V41527	09/08/2015	11:22	09/08/2015	11:58	5	179	35	Weather	Transformer Fuse	Replace - Same Size		II
5122809	V44504	09/08/2015	11:23	09/08/2015	12:26	7	436	62	Weather	Transformer Fuse	Replace - Same Size		II
5122879	Z17503	09/08/2015	11:33	09/08/2015	12:26	102	5436	53	Overhead equipment	Recloser	Replace - Same Size	Replace - Same Size	IV
5122843	B82002	09/08/2015	11:37	09/08/2015	12:49	1	71	71	Unknown	Fuse	Repair	Replace - Same Size	I
5122857	U92593	09/08/2015	11:45	09/08/2015	13:43	20	2365	118	Underground equipment	Underground Primary		Repair	II

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5122861	Z17503	09/08/2015	11:49	09/08/2015	12:25	1	35	35	Overhead equipment	Fuse	Replace - Same Size		IV
5122867	P52305	09/08/2015	11:52	09/08/2015	12:33	4	160	40	Overhead equipment	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	IV
5122873	R58961	09/08/2015	11:59	09/08/2015	14:27	1	147	147	Underground equipment	Underground Service	Patrol/Test/Inspect	Repair	IV
5122875	B25001	09/08/2015	12:00	09/08/2015	14:16	1	135	135	Overhead equipment	Connector	Tie/Tighten	Repair	I
5122893	K69116	09/08/2015	12:13	09/08/2015	14:16	1	122	122	Underground equipment	Underground Primary		Repair	IV
5122903	J71128	09/08/2015	12:28	09/08/2015	13:15	1	46	46	Unknown	Transformer Fuse	Replace - Same Size		I
5122905	Z17503	09/08/2015	12:35	09/08/2015	17:02	23	1392	267	Underground equipment				IV
5122909	U42512	09/08/2015	12:46	09/08/2015	15:35	1	168	168	Animal related	Transformer Fuse	Replace - Same Size	Replace - Same Size	II
5122913	X83541	09/08/2015	12:51	09/08/2015	14:57	1	125	125	Tree related-tree contact	Overhead Service	Repair		IV
5122917	B93002	09/08/2015	12:54	09/08/2015	16:15	4	804	201	Weather	Fuse	Replace - Same Size		I
5123159	D48002	09/08/2015	12:58	09/08/2015	17:48	15	4362	290	Weather	Riser			I
5122933	M18130	09/08/2015	13:11	09/08/2015	14:03	1	51	51	Unknown	Fuse	Replace - Same Size		III
5123071	U04-XTR1	09/08/2015	13:15	09/08/2015	14:15	1575	94610	60	Overhead equipment	Crossarm	Repair	Repair	II
5122939	E10003	09/08/2015	13:15	09/08/2015	20:44	4	1522	448	Weather				III
5122937	N70331	09/08/2015	13:15	09/08/2015	15:00	1	104	104	Overhead equipment	Transformer Fuse	Replace - Same Size	Replace - Same Size	I
5122949	Z17503	09/08/2015	13:18	09/08/2015	17:02	9	2017	224	Underground equipment	Underground Transformer	Repair	Replace - Same Size	IV
5122957	K95208	09/08/2015	13:19	09/08/2015	13:54	1	34	34	Public	Overhead Service			III
5122959	Z17503	09/08/2015	13:19	09/08/2015	17:02	12	2677	223	Underground equipment				IV
5122977	E10002	09/08/2015	13:22	09/08/2015	14:35	1	72	72	Overhead equipment	Overhead Secondary	Raise		III
5123007	Z17503	09/08/2015	13:25	09/08/2015	13:36	1	10	10	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	IV
5123049	B45005	09/08/2015	13:30	09/08/2015	15:58	9	1326	147	Tree related-tree broken	Overhead Secondary	Replace - Same Size	Replace - Same Size	I
5123059	A91001	09/08/2015	13:34	09/08/2015	15:21	7	749	107	Underground equipment	Underground Transformer	Repair	Replace - Same Size	I
5123069	K74166	09/08/2015	13:36	09/08/2015	17:31	1	234	234	Underground equipment	Underground Primary	Repair		IV
5123087	M07235	09/08/2015	13:39	09/08/2015	15:10	5	451	90	Weather	Fuse	Replace - Same Size		III
5123093	374052	09/08/2015	13:41	09/08/2015	20:05	24	4349	383	Weather	Overhead Primary	Patrol/Test/Inspect	Repair	VI
5123097	R93351	09/08/2015	13:46	09/08/2015	15:13	1	86	86	Tree related-tree broken	Fuse	Replace - Same Size		V
5122929	D48002	09/08/2015	13:50	09/08/2015	15:11	3	245	81	Weather	Riser			I
5123105	M37192	09/08/2015	14:10	09/08/2015	14:48	1	37	37	Overhead equipment	Overhead Transformer	Repair	Replace - Same Size	I
5123177	B68003	09/08/2015	14:14	09/08/2015	17:43	149	28096	209	Unknown				III
5123109	B93002	09/08/2015	14:14	09/08/2015	16:28	3	399	133	Animal related	Transformer Fuse	Replace - Same Size		I
5123115	J56341	09/08/2015	14:17	09/08/2015	15:11	5	269	53	Tree related-tree contact	Tree			III
5123119	R16511	09/08/2015	14:20	09/08/2015	15:20	1	59	59	Overhead equipment	Fuse	Repair	Repair	I
5123127	M49411	09/08/2015	14:32	09/08/2015	18:37	1	244	244	Overhead equipment	Overhead Service	Cut in Clear	Replace - Same Size	V
5123129	HD5254	09/08/2015	14:33	09/08/2015	15:53	1	79	79	Weather	Transformer Fuse	Replace - Same Size		VI
5123225	B68003	09/08/2015	14:33	09/08/2015	17:26	1	172	172	Overhead equipment	Fuse	Replace - Same Size		III
5123137	P17109	09/08/2015	14:46	09/08/2015	18:03	31	6081	196	Tree related-tree contact	Overhead Primary		Trim	IV
5123143	Y07558	09/08/2015	14:50	09/08/2015	15:18	1	27	27	Tree related-tree broken	Transformer Fuse	Replace - Same Size		IV
5123151	X30505	09/08/2015	14:59	09/08/2015	15:35	1	35	35	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
5123171	X64501	09/08/2015	15:29	09/08/2015	19:52	1	262	262	Weather	Crossarm	Repair	Repair	IV
5123173	Z06537	09/08/2015	15:29	09/08/2015	17:02	1	92	92	Tree related-tree contact	Overhead Service	Repair		IV
5123179	K46389	09/08/2015	15:34	09/08/2015	20:30	1	295	295	Underground equipment	Underground Service	Patrol/Test/Inspect	Repair	V
5123185	L24122	09/08/2015	15:39	09/08/2015	16:37	1	57	57	Overhead equipment	Transformer Fuse	Replace - Same Size		III
5123231	N18211	09/08/2015	15:39	09/08/2015	23:51	639	144902	491	Unknown	Pole	Patrol/Test/Inspect	Replace - Same Size	III
5123191	Y86593	09/08/2015	15:41	09/08/2015	16:05	1	23	23	Underground equipment	Underground Transformer	Patrol/Test/Inspect		IV
5123193	X60596	09/08/2015	15:41	09/08/2015	21:59	32	10766	377	Underground equipment	Underground Primary	Switch/Reset	Replace - Same Size	IV
5123195	B00002	09/08/2015	15:42	09/08/2015	17:24	1	101	101	Tree related-tree broken	Overhead Service		Repair	I
5123209	S19552	09/08/2015	15:47	09/08/2015	16:14	1	26	26	Jurisdictional	Underground Service	Patrol/Test/Inspect		VI
5123239	K89144	09/08/2015	15:59	09/08/2015	16:28	1	28	28	Unknown	Underground Primary	Patrol/Test/Inspect		III
5123257	Y13042	09/08/2015	16:07	09/08/2015	17:55	1	107	107	Unknown	Overhead Service	Patrol/Test/Inspect		IV
5123285	N95824	09/08/2015	16:22	09/08/2015	18:25	1	122	122	Animal related	Transformer Fuse	Replace - Same Size		V
5154971	P73182	09/08/2015	16:39	09/08/2015	18:57	19	2604	137	Unknown				VI
5123301	B61001	09/08/2015	16:50	09/08/2015	18:34	1	103	103	Overhead equipment	Disconnect Switch	Replace - Same Size		I
5123303	N15850	09/08/2015	16:50	09/08/2015	20:32	1	221	221	Weather	Overhead Transformer	Replace - Same Size	Replace - Same Size	V
5123323	J86118	09/08/2015	17:36	09/08/2015	18:37	5	300	60	Animal related	Transformer Fuse	Replace - Same Size		VI
5123327	M45211	09/08/2015	17:40	09/08/2015	19:15	1	94	94	Tree related-tree broken	Overhead Service	Repair		IV
5123331	344003	09/08/2015	17:54	09/08/2015	19:15	1	80	80	Overhead equipment	Overhead Service	Advise Customer	Repair	VI

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5123333	T05539	09/08/2015	17:58	09/08/2015	19:00	7	429	61	Overhead equipment	Transformer Fuse			VI
5123335	Y84534	09/08/2015	18:12	09/08/2015	20:37	1	144	144	Tree related-tree contact	Overhead Service	Repair		IV
5123345	V65-XTR1	09/08/2015	18:21	09/08/2015	18:30	687	6341	9	Overhead equipment				II
5123401	Y40534	09/08/2015	18:26	09/08/2015	21:00	1	153	153	Overhead equipment	Overhead Transformer	Repair	Replace - Same Size	IV
5123417	L68115	09/08/2015	18:46	09/08/2015	23:50	1	303	303	Tree related-tree broken	Tree	Trim		IV
5123421	X66581	09/08/2015	19:00	09/08/2015	21:30	1	149	149	Tree related-tree broken	Tree			IV
5123443	K30204	09/08/2015	19:08	09/08/2015	20:26	303	23461	77	Overhead equipment				III
5123427	K25166	09/08/2015	19:09	09/08/2015	21:08	1	118	118	Tree related-tree broken	Overhead Service	Repair		VI
5123437	T08502	09/08/2015	19:20	09/08/2015	20:15	1	54	54	Animal related	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
5123453	Y06546	09/08/2015	19:31	09/08/2015	20:00	17	492	28	Tree related-tree broken	Fuse	Repair	Replace - Same Size	IV
5123469	K30204	09/08/2015	20:22	09/08/2015	20:25	1	2	2	Overhead equipment	Fuse	Replace - Same Size		III
5123471	M26164	09/08/2015	20:26	09/08/2015	21:27	40	2445	61	Underground equipment	Underground Primary	Switch/Reset	Repair	III
5123473	307003	09/08/2015	20:28	09/08/2015	22:33	6	745	124	Overhead equipment	Fuse	Replace - Same Size		VI
5123475	M26164	09/08/2015	20:31	09/08/2015	21:24	1	52	52	Underground equipment	Underground Primary	Switch/Reset		III
5123485	S92559	09/08/2015	20:51	09/08/2015	21:58	1	66	66	Overhead equipment	Transformer Fuse	Replace - Same Size		VI
5154973	P73182	09/08/2015	21:23	09/08/2015	23:37	19	2527	133	Unknown				VI
5123497	M26164	09/08/2015	21:32	09/08/2015	21:50	1	17	17	Underground equipment	Underground Primary	Switch/Reset		III
5123501	G30001	09/08/2015	21:54	09/09/2015	0:10	1	135	135	Weather				III
5123505	J83137	09/09/2015	0:10	09/09/2015	5:40	11	3639	330	Weather	Crossarm		Replace - Same Size	VI
5123511	D69008	09/09/2015	0:51	09/09/2015	4:48	49	11593	236	Underground equipment	Fuse	Replace - Same Size	Replace - Same Size	I
5123515	Z06537	09/09/2015	1:12	09/09/2015	2:57	1	104	104	Overhead equipment	Fuse	Repair	Replace - Same Size	IV
5123517	337001	09/09/2015	2:11	09/09/2015	6:35	1	263	263	Tree related-tree broken	Overhead Primary	Patrol/Test/Inspect	Repair	VI
5123523	S47537	09/09/2015	2:20	09/09/2015	4:40	67	9324	139	Other	Disconnect Switch	Replace - Same Size		VI
5123525	HB6283	09/09/2015	2:47	09/09/2015	5:13	23	3354	145	Underground equipment	Underground Primary			VI
5123527	V34002	09/09/2015	2:57	09/09/2015	4:27	1	89	89	Tree related-tree broken	Transformer Fuse	Repair		II
5123531	D37003	09/09/2015	3:35	09/09/2015	5:27	58	6523	112	Overhead equipment	Crossarm	Patrol/Test/Inspect	Replace - Same Size	I
5123535	D92001	09/09/2015	3:39	09/09/2015	10:11	1	391	391	Underground equipment	Underground Secondary	Patrol/Test/Inspect	Repair	I
5123537	V21500	09/09/2015	3:58	09/09/2015	6:08	1	129	129	Animal related	Transformer Fuse	Replace - Same Size		II
5123551	M45212	09/09/2015	4:56	09/09/2015	10:55	65	23375	359	Public	Pole		Replace - Same Size	IV
5123565	S95-XTR1	09/09/2015	5:17	09/09/2015	6:46	171	15301	89	Unknown				VI
5123579	S93-XTR1	09/09/2015	5:18	09/09/2015	5:49	938	29012	30	Overhead equipment	Overhead Primary	Replace - Same Size		VI
5123657	C70001	09/09/2015	5:30	09/09/2015	11:01	11	3633	330	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	III
5123583	D37003	09/09/2015	5:31	09/09/2015	7:30	6	713	118	Overhead equipment	Crossarm	Patrol/Test/Inspect	Repair	I
5123597	C70001	09/09/2015	5:38	09/09/2015	7:45	3	379	126	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	III
5123609	Q82906	09/09/2015	5:49	09/09/2015	11:48	1	358	358	Tree related-tree broken	Fuse	Replace - Same Size	Replace - Same Size	VI
5123617	325003	09/09/2015	6:21	09/09/2015	7:58	65	5330	96	Underground equipment	Underground Primary	Replace - Same Size	Replace - Same Size	VI
5123619	D90004	09/09/2015	6:29	09/09/2015	12:41	1	371	371	Underground equipment	Underground Secondary	Patrol/Test/Inspect	Patrol/Test/Inspect	III
5123623	R42914	09/09/2015	6:40	09/09/2015	8:58	1	137	137	Tree related-tree broken	Tree	Advise Customer		VI
5123625	R42914	09/09/2015	6:43	09/09/2015	8:59	1	135	135	Tree related-tree broken	Overhead Service	Advise Customer	Replace - New Size	VI
5123627	S07536	09/09/2015	6:53	09/09/2015	8:20	4	345	86	Tree related-tree broken	Overhead Secondary	Repair	Repair	VI
5123629	U99515	09/09/2015	6:54	09/09/2015	8:40	1	106	105	Weather	Lightning Arrestor	Replace - Same Size		II
5123639	U80564	09/09/2015	7:22	09/09/2015	9:10	1	107	107	Tree related-tree contact	Overhead Service	Repair		II
5123641	L95209	09/09/2015	7:23	09/09/2015	12:05	1	281	281	Tree related-tree contact	Tree		Remove	III
5123645	M26161	09/09/2015	7:38	09/09/2015	10:05	1	146	146	Overhead equipment	Overhead Transformer	Replace - New Size		III
5123647	Y79500	09/09/2015	7:49	09/09/2015	10:25	10	1559	155	Overhead equipment	Overhead Transformer	Replace - Same Size	Replace - Same Size	IV
5123655	K27122	09/09/2015	7:58	09/09/2015	10:55	1	177	177	Underground equipment	Underground Primary	Replace - Same Size	Replace - Same Size	VI
5123661	Q93522	09/09/2015	8:06	09/09/2015	12:44	1	277	277	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Repair	I
5123679	P77237	09/09/2015	8:25	09/09/2015	14:43	1	377	377	Overhead equipment	Pole		Repair	VI
5123683	K43386	09/09/2015	8:38	09/09/2015	9:11	1	32	32	Animal related	Fuse	Replace - Same Size		V
5123687	D88001	09/09/2015	8:48	09/09/2015	10:29	16	1601	100	Overhead equipment	Fuse	Replace - Same Size		I
5123693	M31204	09/09/2015	8:50	09/09/2015	9:30	42	1672	39	Public	Overhead Primary			I
5123691	P98192	09/09/2015	8:55	09/09/2015	9:52	1	56	56	Animal related	Transformer Fuse	Repair	Repair	III
5123719	K31120	09/09/2015	8:56	09/09/2015	11:12	8	1086	135	Overhead equipment	Overhead Primary	Replace - Same Size		I
5123705	P98192	09/09/2015	9:08	09/09/2015	9:50	1	41	41	Animal related	Transformer Fuse	Repair	Repair	III
5123707	303005	09/09/2015	9:13	09/09/2015	12:55	1	221	221	Tree related-tree contact	Overhead Service	Patrol/Test/Inspect	Replace - New Size	VI
5123715	S08548	09/09/2015	9:36	09/09/2015	16:15	1	398	398	Underground equipment	Underground Primary	Repair	Repair	VI