Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5123725	B93003	09/09/2015	9:48	09/09/2015	10:51	1	62	62	Unknown	Underground Primary	Patrol/Test/Inspect		I
5123729	R84148	09/09/2015	9:52	09/09/2015	11:05	1	72	72	Unknown	Transformer Fuse	Replace - Same Size		I
5123737	P98191	09/09/2015	10:01	09/09/2015	10:34	1	32	32	Animal related	Fuse	Repair	Repair	III
5123739	K27153	09/09/2015	10:05	09/09/2015	14:41	66	8486	276	Underground equipment	Underground Primary	Repair	Repair	VI
5123743	S04545	09/09/2015	10:18	09/09/2015	11:30	1	71	71	Overhead equipment	Transformer Fuse	Replace - Same Size	Replace - Same Size	VI
5123761	D88001	09/09/2015	10:36	09/09/2015	11:28	1	51	51	Overhead equipment	Fuse	Replace - Same Size		I
5123763	Y66556	09/09/2015	10:44	09/09/2015	11:25	28	1139	40	Animal related	Fuse	Replace - Same Size		IV
5123765	308004	09/09/2015	10:44	09/09/2015	12:34	7	764	109	Tree related-tree broken	Tree	Patrol/Test/Inspect		VI
5123767	P07179	09/09/2015	10:47	09/09/2015	11:25	1	37	37	Unknown	Transformer Fuse	Replace - Same Size		I
5123773	M47802	09/09/2015	10:52	09/09/2015	12:09	1	76	76	Tree related-tree broken	Overhead Service	Repair		V
5123777	Q34360	09/09/2015	10:58	09/09/2015	11:53	20	1098	54	Overhead equipment	Connector	Replace - Same Size	Repair	I
5123783	P77237	09/09/2015	11:09	09/09/2015	14:38	5	1043	208	Weather				VI
5123785	Q34360	09/09/2015	11:12	09/09/2015	11:53	8	324	40	Overhead equipment	Connector	Replace - Same Size	Repair	I
5123791	J99128	09/09/2015	11:18	09/09/2015	12:12	1	53	53	Animal related	Transformer Fuse	Replace - Same Size		VI
5123795	X39530	09/09/2015	11:22	09/09/2015	12:56	12	1125	93	Animal related	Transformer Fuse	Replace - Same Size		IV
5123799	J01118	09/09/2015	11:30	09/09/2015	13:42	1	131	131	Tree related-tree broken	Overhead Service	Patrol/Test/Inspect	Repair	I
5123801	Q54908	09/09/2015	11:32	09/09/2015	13:50	1	137	137	Animal related	Disconnect Switch	Repair	Repair	VI
5123809	Y63541	09/09/2015	11:45	09/09/2015	13:05	5	396	79	Tree related-tree broken	Overhead Secondary	Repair		IV
5123837	S36570	09/09/2015	11:56	09/09/2015	14:53	162	28763	177	Substation equipment	Substation Breaker	Replace - Same Size	Replace - Same Size	VI
5123859	A32001	09/09/2015	12:32	09/09/2015	15:21	1	168	168	Overhead equipment	Lightning Arrestor	Patrol/Test/Inspect		I
5123861	Y93544	09/09/2015	12:33	09/09/2015	12:55	1	21	21	Overhead equipment	Transformer Fuse	Repair	Replace - Same Size	IV
5123871	P77237	09/09/2015	12:44	09/09/2015	17:17	1	272	272	Animal related	Fuse	Replace - Same Size		VI
5123875	A36001	09/09/2015	12:49	09/09/2015	13:49	21	1258	59	Animal related	Transformer Fuse	Replace - Same Size		I
5123881	Y35001	09/09/2015	12:54	09/09/2015	14:20	14	1200	85	Tree related-tree broken	Overhead Service	Repair		IV
5123889	R10941	09/09/2015	12:56	09/09/2015	13:11	91	1355	14	Jurisdictional	Substation Misc.	Repair	Replace - Same Size	VI
5123917	R10903	09/09/2015	12:57	09/09/2015	13:08	602	6742	11	Jurisdictional				VI
5123933	Y35001	09/09/2015	13:01	09/09/2015	14:20	1	78	78	Tree related-tree broken	Overhead Service	Repair		IV
5123939	S14510	09/09/2015	13:01	09/09/2015	14:55	1	113	113	Tree related-tree broken	Overhead Service	Repair	Repair	VI
5123955	V59003	09/09/2015	13:33	09/09/2015	16:58	1	204	204	Underground equipment	Underground Service	Repair		II
5123957	X60598	09/09/2015	13:35	09/09/2015	15:45	1	129	129	Intentional	Meter	Replace - New Size		IV
5123961	S08548	09/09/2015	13:45	09/09/2015	14:35	7	344	49	Overhead equipment	Overhead Service			VI
5123985	S14509	09/09/2015	14:05	09/09/2015	15:39	520	48687	93	Substation equipment				VI
5123999	S14509	09/09/2015	14:14	09/09/2015	15:23	16	1091	68	Underground equipment				VI
5124005	M30301	09/09/2015	14:34	09/09/2015	17:53	5	993	198	Overhead equipment	Fuse	Replace - Same Size		VI
5124227	R39-X1	09/09/2015	14:40	09/09/2015	16:32	947	105495	111	Overhead equipment	Substation Breaker	Switch/Reset		VI
5124145	R89-UNIT-1	09/09/2015	14:42	09/09/2015	15:58	234	17779	75	Unknown				VI
5124039	R34-X1	09/09/2015	14:42	09/09/2015	16:32	735	80813	109	Overhead equipment	Substation Breaker	Switch/Reset		VI
5124225	P19395	09/09/2015	14:51	09/09/2015	16:02	1	70	70	Animal related	Overhead Primary			V
5124235	309142	09/09/2015	15:00	09/09/2015	16:35	1	94	94	Public	Overhead Secondary	Disconnect		V
5124247	J01119	09/09/2015	15:22	09/09/2015	16:25	49	3087	63	Public	Fuse	Replace - Same Size	Patrol/Test/Inspect	I
5124265	P98190	09/09/2015	15:45	09/09/2015	18:15	90	13479	149	Underground equipment	Underground Primary			III
5124273	309141	09/09/2015	15:55	09/09/2015	17:59	1	123	123	Overhead equipment	Overhead Secondary			V
5124277	U01523	09/09/2015	16:03	09/09/2015	18:16	1	132	132	Overhead equipment	Fuse	Replace - Same Size		II
5124283	L73155	09/09/2015	16:09	09/09/2015	18:18	7	900	128	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
5124289	P20930	09/09/2015	16:12	09/09/2015	16:37	8	199	24	Overhead equipment				VI
5124293	Z29579	09/09/2015	16:13	09/09/2015	17:15	1	61	61	Tree related-tree broken	Overhead Service			IV
5124295	P19395	09/09/2015	16:19	09/09/2015	23:44	1	444	444	Weather	Fuse	Replace - Same Size		V
5124297	S15560	09/09/2015	16:28	09/09/2015	17:40	1	71	71	Animal related	Transformer Fuse	Replace - Same Size		VI
5124307	N18211	09/09/2015	16:38	09/09/2015	17:36	1	57	57	Animal related	Transformer Fuse	Replace - Same Size		III
5124317		09/09/2015	16:46	09/09/2015	18:09	1	82	82	Animal related	Transformer Fuse	Replace - Same Size		VI
5124331	K52401	09/09/2015	16:58	09/09/2015	21:00	52	12626	242	Animal related	Fuse	Replace - Same Size		V
5124345	J89126	09/09/2015	17:43	09/09/2015	18:42	48	2791	58	Overhead equipment	Jumper	Repair		VI
5124347	312114	09/09/2015	17:45	09/09/2015	18:38	4	212	52	Overhead equipment	Fuse	Replace - Same Size		V
5124361	V41527	09/09/2015	18:21	09/09/2015	20:32	9	1176	130	Tree related-tree broken	Overhead Service	Repair		II
5124359	K80381	09/09/2015	18:23	09/09/2015	22:16	37	8613	232	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	IV
5124375	U42001	09/09/2015	19:13	09/09/2015	21:00	66	7027	106	Overhead equipment	Fuse	Patrol/Test/Inspect	Replace - Same Size	II

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5124431	U42001	09/09/2015	19:29	09/09/2015	21:09	1	99	99	Overhead equipment	Fuse	Patrol/Test/Inspect	Replace - Same Size	II
5124383	B38001	09/09/2015	19:38	09/09/2015	21:39	1	120	120	Public	Underground Transformer		Repair	I
5124387	B21004	09/09/2015	19:39	09/10/2015	6:59	107	45081	680	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
5124395	B21004	09/09/2015	19:45	09/10/2015	1:18	1	332	332	Underground equipment	Underground Primary			I
5124397	U92593	09/09/2015	19:58	09/09/2015	21:37	140	13815	98	Overhead equipment	Pole	Replace - New Size		II
5124405	K52401	09/09/2015	20:02	09/09/2015	21:23	1	80	80	Animal related	Transformer Fuse	Replace - Same Size		V
5124411	P20913	09/09/2015	20:12	09/09/2015	22:27	1	134	134	Tree related-tree contact	Overhead Service	Replace - New Size	Replace - New Size	VI
5124413	A24002	09/09/2015	20:16	09/09/2015	21:29	1	72	72	Overhead equipment	Connector	Replace - Same Size		I
5124417	J89126	09/09/2015	20:18	09/09/2015	21:04	1	45	45	Overhead equipment	Transformer Fuse	Replace - Same Size		VI
5124423	J87111	09/09/2015	20:29	09/09/2015	21:23	1	53	53	Animal related	Transformer Fuse	Replace - Same Size		VI
5124427	Y04504	09/09/2015	20:48	09/10/2015	0:48	1	239	239	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
5124435	R71286	09/09/2015	21:26	09/09/2015	23:40	1	133	133	Tree related-tree broken	Tree			VI
5124441	S61529	09/09/2015	21:35	09/10/2015	6:19	1	523	523	Underground equipment	Underground Primary	Repair	Replace - Same Size	VI
5124443	B38001	09/09/2015	21:38	09/09/2015	21:41	1	2	2	Unknown				I
5124451	L99392	09/09/2015	22:22	09/10/2015	0:20	1	117	117	Weather	Transformer Fuse	Replace - Same Size		V
5124457	S27599	09/09/2015	22:52	09/10/2015	0:42	1	109	109	Overhead equipment	Overhead Transformer	Repair		VI
5124459	X12001	09/09/2015	22:55	09/10/2015	2:52	3	711	237	Overhead equipment	Overhead Transformer	Replace - New Size	Repair	IV
5124463	R01153	09/09/2015	23:29	09/10/2015	0:19	1	49	49	Public	Other			III
5124469	B21004	09/10/2015	0:07	09/10/2015	1:20	1	72	72	Underground equipment	Underground Primary			I
5124471	B21004	09/10/2015	0:23	09/10/2015	1:20	1	56	56	Underground equipment	Underground Primary			I
5124473	M41113	09/10/2015	1:44	09/10/2015	2:41	1	56	56	Public	Overhead Service	Cut in Clear		I
5124481	T14576	09/10/2015	4:05	09/10/2015	6:12	5	632	126	Overhead equipment	Transformer Fuse	Replace - Same Size	Patrol/Test/Inspect	VI
5124495	B84002	09/10/2015	6:49	09/10/2015	7:58	6	408	68	Animal related	Fuse	Replace - Same Size		I
5124499	Z21564	09/10/2015	6:54	09/10/2015	8:45	1	110	110	Overhead equipment	Fuse	Repair	Replace - Same Size	IV
5124505	A91001	09/10/2015	6:56	09/10/2015	10:25	1	208	208	Underground equipment	Underground Primary	Repair	Repair	I
5124513	D36001	09/10/2015	7:22	09/10/2015	8:45	13	1077	82	Overhead equipment	Transformer Fuse	Replace - Same Size	Replace - Same Size	I
5124517	B21003	09/10/2015	7:32	09/10/2015	10:51	1	198	198	Overhead equipment	Connector	Repair		I
5124527	B68003	09/10/2015	7:41	09/10/2015	9:04	5	414	82	Overhead equipment	Recloser			III
5124533	U14528	09/10/2015	8:11	09/10/2015	9:07	1	55	55	Animal related	Transformer Fuse	Repair	Replace - Same Size	II
5124649	Y36559	09/10/2015	8:19	09/10/2015	9:09	20	992	49	Underground equipment	Underground Primary	Repair		IV
5124615	F22001	09/10/2015	8:32	09/10/2015	9:44	259	18422	71	Overhead equipment				IV
5124619	L12127	09/10/2015	8:51	09/10/2015	9:39	1	47	47	Overhead equipment	Overhead Service	Repair		III
5124629	B68003	09/10/2015	8:53	09/10/2015	9:05	1	11	11	Overhead equipment	Recloser			III
5124635	R48167	09/10/2015	8:56	09/10/2015	10:15	1	78	78	Overhead equipment	Transformer Fuse			IV
5124655	V44511	09/10/2015	9:07	09/10/2015	9:54	1	46	46	Unknown				II
5124659	V44511	09/10/2015	9:08	09/10/2015	9:48	17	667	39	Unknown	Fuse	Replace - Same Size		II
5124667	K27153	09/10/2015	9:15	09/10/2015	11:04	1	108	108	Public	Overhead Service	Replace - Same Size	Replace - Same Size	VI
5124679	J20931	09/10/2015	9:30	09/10/2015	10:00	1	29	29	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	VI
5124683	Y55505	09/10/2015	9:31	09/10/2015	10:52	7	563	80	Animal related	Disconnect Switch	Replace - Same Size		IV
5124691	S86582	09/10/2015	9:39	09/10/2015	10:58	1	78	78	Animal related	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
5124753	312112	09/10/2015	9:40	09/10/2015	12:12	43	6539	152	Animal related	Overhead Transformer	Disconnect	Replace - Same Size	V
5124715	V41533	09/10/2015	9:58	09/10/2015	10:49	26	1303	50	Unknown	Fuse	Replace - Same Size		II
5124735	A91001	09/10/2015	10:25	09/10/2015	11:39	2	147	73	Underground equipment	Underground Primary	Repair	Repair	I
5124737	N93260	09/10/2015	10:27	09/10/2015	11:57	1	89	89	Public	Pole			III
5124739	N93260	09/10/2015	10:28	09/10/2015	13:45	8	1572	196	Public	Fuse			III
5124745	L35139	09/10/2015	10:32	09/10/2015	12:14	1	101	101	Animal related	Fuse	Replace - Same Size		III
5124747	P69175	09/10/2015	10:39	09/10/2015	11:13	1	33	33	Animal related	Other			III
5124749	Q74148	09/10/2015	10:39	09/10/2015	12:14	1	94	94	Unknown	Transformer Fuse	Replace - Same Size		IV
5124767	J68401	09/10/2015	10:56	09/10/2015	13:15	1	138	138	Unknown	Transformer Fuse			III
5124769	D89001	09/10/2015	10:57	09/10/2015	12:02	1	64	64	Animal related	Transformer Fuse	Replace - Same Size		I
5124773	Q69926	09/10/2015	10:58	09/10/2015	12:16	1	77	77	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	VI
5124799	D60001	09/10/2015	11:36	09/10/2015	12:12	1	35	35	Underground equipment	Underground Primary			III
5124801	D60001	09/10/2015	11:38	09/10/2015	12:16	1	37	37	Underground equipment	Underground Primary			III
5124803	D60001	09/10/2015	11:38	09/10/2015	12:18	1	39	39	Underground equipment	Underground Primary			III
5124807	N93260	09/10/2015	11:39	09/10/2015	14:48	2	376	188	Public	Overhead Transformer			III
5124825	P69173	09/10/2015	11:51	09/10/2015	12:32	281	11402	40	Unknown	Other			III

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5124819	D69008	09/10/2015	11:53	09/10/2015	15:48	76	17850	234	Underground equipment	Underground Primary	Patrol/Test/Inspect		I
5124835	R50910	09/10/2015	11:57	09/10/2015	12:40	1	42	42	Animal related	Transformer Fuse	Replace - Same Size		I
5125221	D69008	09/10/2015	12:14	09/10/2015	18:35	13	4953	381	Underground equipment	Underground Primary	Repair	Repair	I
5124869	N67309	09/10/2015	12:33	09/10/2015	12:56	1	22	22	Overhead equipment	Other			I
5124919	P69173	09/10/2015	12:37	09/10/2015	13:25	752	35983	47	Overhead equipment	Recloser			III
5124905	B84003	09/10/2015	12:54	09/10/2015	16:11	30	5903	196	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
5124907	N93260	09/10/2015	12:56	09/10/2015	13:56	1	59	59	Public	Pole	Replace - Same Size	Replace - Same Size	III
5124917	D88001	09/10/2015	12:58	09/10/2015	14:47	25	2707	108	Underground equipment	Underground Primary	Repair	Repair	I
5124915	Q34360	09/10/2015	12:58	09/10/2015	13:39	132	5339	40	Overhead equipment	Pole	Repair		I
5124911	Q34360	09/10/2015	12:58	09/10/2015	13:39	152	6148	40	Overhead equipment	Pole	Repair		I
5124913	Q34360	09/10/2015	12:58	09/10/2015	13:39	142	5743	40	Overhead equipment	Pole	Repair		I
5124931	Q34360	09/10/2015	13:03	09/10/2015	17:50	338	96786	286	Overhead equipment	Pole	Repair		I
5124937	C70001	09/10/2015	13:13	09/10/2015	13:47	1	33	33	Animal related	Fuse	Replace - Same Size		III
5125009	D35002	09/10/2015	13:13	09/10/2015	18:53	22	7494	340	Overhead equipment	Overhead Primary	Replace - Same Size	Repair	I
5125055	D35002	09/10/2015	13:13	09/10/2015	18:53	4	1362	340	Overhead equipment	Overhead Primary	Replace - Same Size		I
5124945	D35002	09/10/2015	13:15	09/10/2015	14:14	60	3525	58	Overhead equipment	Overhead Primary	Replace - Same Size	Replace - Same Size	I
5124951	N95824	09/10/2015	13:19	09/10/2015	15:20	1	120	120	Animal related	Fuse	Replace - Same Size		V
5125001	B93003	09/10/2015	13:19	09/10/2015	19:12	44	8566	352	Tree related-tree broken	Tree	Patrol/Test/Inspect	Remove	I
5125503	D35001	09/10/2015	13:29	09/10/2015	22:10	37	19273	520	Tree related-tree broken	Overhead Primary	Repair	Repair	I
5125035	B93002	09/10/2015	13:34	09/10/2015	20:50	121	52255	435	Tree related-tree broken	Tree	Remove	Remove	I
5125065	Q34366	09/10/2015	13:46	09/10/2015	15:58	8	1052	131	Tree related-tree broken	Overhead Primary	Repair	Repair	I
5125045	B93002	09/10/2015	13:48	09/10/2015	20:50	24	10118	421	Tree related-tree broken	Overhead Primary			I
5125025	B93003	09/10/2015	13:56	09/10/2015	16:39	1	162	162	Unknown	Fuse	Replace - Same Size		I
5125027	J08205	09/10/2015	14:01	09/10/2015	15:28	1	87	87	Unknown	Transformer Fuse	Replace - Same Size		I
5125051	X87576	09/10/2015	14:12	09/10/2015	15:30	1	77	77	Animal related	Transformer Fuse	Replace - Same Size		IV
5125053	D36001	09/10/2015	14:13	09/10/2015	17:33	2	398	199	Animal related	Fuse	Replace - Same Size		I
5125057	N18211	09/10/2015	14:15	09/10/2015	20:52	1	396	396	Tree related-tree broken	Overhead Service	Patrol/Test/Inspect	Replace - Same Size	III
5125067	V14579	09/10/2015	14:21	09/10/2015	17:47	27	3212	206	Underground equipment	Underground Transformer	Repair	Repair	II
5125079	P98193	09/10/2015	14:32	09/10/2015	15:20	1	47	47	Intentional	Other			III
5125087	S14511	09/10/2015	14:41	09/10/2015	15:17	4	142	35	Animal related	Transformer Fuse	Replace - Same Size		VI
5125095	Y84526	09/10/2015	14:42	09/10/2015	15:08	77	2000	25	Weather				IV
5125105	B62004	09/10/2015	14:45	09/10/2015	16:36	102	11267	110	Overhead equipment	Fuse	Patrol/Test/Inspect	Replace - Same Size	I
5125115	X77543	09/10/2015	15:00	09/10/2015	15:39	613	23643	38	Tree related-tree broken	Tree	Remove		IV
5125117	X77002	09/10/2015	15:03	09/10/2015	16:01	282	16237	57	Tree related-tree broken	Tree	Remove		IV
5125175	P62112	09/10/2015	15:17	09/10/2015	16:36	1	78	78	Tree related-tree broken				VI
5125185	K30204	09/10/2015	15:24	09/10/2015	17:15	19	2090	110	Overhead equipment	Overhead Primary	Repair		III
5125191	H10843	09/10/2015	15:32	09/10/2015	19:56	1	263	263	Public	Pole	Replace - New Size	Patrol/Test/Inspect	V
5125195	X36001	09/10/2015	15:38	09/10/2015	17:39	1	120	120	Tree related-tree contact	Overhead Service	Repair	Advise Customer	IV
5125199	R33126	09/10/2015	15:39	09/10/2015	17:07	1	87	87	Weather	Transformer Fuse	Replace - Same Size	Patrol/Test/Inspect	I
5125207	Z29579	09/10/2015	15:48	09/10/2015	17:35	1	107	107	Tree related-tree broken	Overhead Service	Repair		IV
5125235		09/10/2015	15:51	09/10/2015	21:31	1642	557573	339	Overhead equipment	Other	Patrol/Test/Inspect	Patrol/Test/Inspect	III
5125401	R61241	09/10/2015	15:57	09/10/2015	18:26	32	4748	148	Overhead equipment	Pole			IV
5125281	L82187	09/10/2015	15:57	09/10/2015	21:37	5	1697	339	Tree related-tree broken	Pole		Replace - Same Size	IV
5125309	B93003	09/10/2015	16:01	09/10/2015	16:40	1	38	38	Unknown	Fuse	Replace - Same Size		I
5125283	R61241	09/10/2015	16:02	09/10/2015	18:23	35	4934	140	Tree related-tree broken	Pole			IV
5125313	N18210	09/10/2015	16:06	09/10/2015	18:26	4	558	139	Animal related	Fuse	Replace - Same Size		III
5125357	V61563	09/10/2015	16:38	09/10/2015	18:49	66	8601	130	Overhead equipment	Recloser	Switch/Reset		II
5125337	V63553	09/10/2015	16:43	09/10/2015	18:39	19	2194	115	Tree related-tree broken	Fuse	Replace - Same Size		II
5125343	S88503	09/10/2015	16:51	09/10/2015	19:18	1	146	146	Unknown	Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
5125347	V63553	09/10/2015	16:57	09/10/2015	22:15	1	317	317	Tree related-tree broken	Overhead Primary	Repair		II
5125363	K01239	09/10/2015	17:24	09/10/2015	18:11	21	982	46	Animal related	Fuse	Replace - Same Size		VI
5125365	R33126	09/10/2015	17:26	09/10/2015	18:49	1	82	82	Weather	Transformer Fuse	Replace - Same Size	Patrol/Test/Inspect	I
5125367	P49183	09/10/2015	17:26	09/10/2015	18:38	108	7702	71	Overhead equipment	Disconnect Switch	Replace - Same Size		I
5125369	L68111	09/10/2015	17:27	09/10/2015	21:37	1	249	249	Tree related-tree broken	Overhead Service	Repair		IV
5125371	Y79500	09/10/2015	17:30	09/10/2015	19:19	6	655	109	Overhead equipment	Overhead Secondary	Raise	Raise	IV
5125373	303006	09/10/2015	17:35	09/10/2015	18:58	10	826	82	Overhead equipment	Fuse	Replace - Same Size		VI

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5125375	303006	09/10/2015	17:43	09/10/2015	19:00	1	76	76	Overhead equipment	Fuse	Replace - Same Size		VI
5125379	J01118	09/10/2015	17:53	09/10/2015	20:41	1	167	167	Tree related-tree broken	Overhead Service	Replace - New Size		I
5125381	V61563	09/10/2015	17:53	09/10/2015	19:37	5	515	103	Tree related-tree broken	Overhead Primary	Cut in Clear		II
5125391	C70001	09/10/2015	17:57	09/10/2015	21:45	50	11391	227	Overhead equipment	Fuse	Replace - Same Size		III
5125399	V63553	09/10/2015	18:21	09/10/2015	21:10	3	506	168	Tree related-tree broken	Overhead Primary	Repair		II
5125403	U04571	09/10/2015	18:24	09/10/2015	21:40	3	586	195	Tree related-tree contact	Pole	Repair	Replace - Same Size	II
5125423	V63553	09/10/2015	18:27	09/10/2015	23:31	1	304	304	Tree related-tree broken	Overhead Primary	Repair		II
5125415	V63553	09/10/2015	18:27	09/10/2015	18:47	1	20	20	Overhead equipment				II
5125419	U04571	09/10/2015	18:31	09/10/2015	22:30	4	954	238	Overhead equipment	Overhead Transformer			II
5125431	M47802	09/10/2015	19:00	09/10/2015	20:50	50	5472	109	Tree related-tree broken	Tree	Trim		V
5125433	Q15844	09/10/2015	19:16	09/10/2015	22:28	7	1338	191	Weather	Transformer Fuse	Replace - Same Size		V
5125435	R28871	09/10/2015	19:17	09/10/2015	22:00	78	12692	162	Tree related-tree broken	Fuse	Replace - Same Size		V
5125439	N54213	09/10/2015	19:22	09/11/2015	1:38	6	2250	375	Underground equipment	Underground Service	Repair	Repair	II
5125441	N14880	09/10/2015	19:24	09/10/2015	20:40	1	75	75	Tree related-tree broken	Fuse	Replace - Same Size		V
5125673	R28871	09/10/2015	19:25	09/10/2015	23:14	18	4111	228	Tree related-tree broken	Overhead Primary	Replace - Same Size		V
5125445	Q15844	09/10/2015	19:25	09/10/2015	21:55	3	447	149	Tree related-tree broken	Tree	Trim		V
5125495	B93003	09/10/2015	19:40	09/11/2015	12:37	1	1016	1016	Other	Meter			I
5125499	P19395	09/10/2015	19:50	09/10/2015	20:54	1	63	63	Weather				V
5125515	N15850	09/10/2015	20:03	09/10/2015	21:10	6	402	67	Tree related-tree broken	Fuse	Replace - Same Size		V
5125513	V61563	09/10/2015	20:10	09/11/2015	1:04	47	13803	293	Tree related-tree broken	Overhead Primary			II
5125519	P05826	09/10/2015	20:25	09/10/2015	23:02	1	156	156	Weather	Transformer Fuse	Replace - Same Size		V
5125521	J18268	09/10/2015	20:26	09/11/2015	0:20	1	233	233	Weather	Transformer Fuse	Replace - Same Size		VI
5125693	D01001	09/10/2015	20:35	09/11/2015	5:02	1	506	506	Underground equipment	Underground Primary	Repair	Repair	I
5125527	J86118	09/10/2015	20:40	09/10/2015	21:41	1	60	60	Overhead equipment	Transformer Fuse	Replace - Same Size		VI
5125529	J18267	09/10/2015	20:41	09/10/2015	23:17	5	779	155	Tree related-tree broken	Transformer Fuse	Replace - Same Size		VI
5125573	J18267	09/10/2015	20:42	09/11/2015	1:45	41	6815	302	Tree related-tree broken	Overhead Primary		Repair	VI
5125539	Q27185	09/10/2015	20:43	09/11/2015	7:07	494	281470	624	Tree related-tree contact	Overhead Primary		Repair	VI
5125547	349002	09/10/2015	20:49	09/10/2015	22:15	6	511	85	Tree related-tree broken	Tree	Trim		VI
5125657	Q27186	09/10/2015	20:50	09/11/2015	1:08	147	37789	257	Overhead equipment				VI
5125555	Q68836	09/10/2015	20:52	09/11/2015	0:07	14	2723	194	Overhead equipment	Overhead Primary	Replace - Same Size		V
5125709	Q27185	09/10/2015	20:53	09/11/2015	7:14	43	26703	621	Weather				VI
5154981	P73182	09/10/2015	20:56	09/10/2015	23:30	19	2917	153	Overhead equipment				VI
5125615	Q18242	09/10/2015	21:09	09/11/2015	0:31	1	201	201	Tree related-tree broken	Overhead Service	Repair		VI
5125621	N15850	09/10/2015	21:12	09/10/2015	21:28	6	95	15	Tree related-tree broken	Fuse	Replace - Same Size		V
5125625	Q27185	09/10/2015	21:15	09/11/2015	7:42	23	14420	626	Tree related-tree broken	Fuse	Repair	Repair	VI
5125623	Q15844	09/10/2015	21:15	09/10/2015	22:29	1	73	73	Weather				V
5125627	Q27185	09/10/2015	21:15	09/11/2015	1:23	206	50888	247	Overhead equipment				VI
5125633	Q27185	09/10/2015	21:20	09/11/2015	3:37	1	376	376	Tree related-tree broken	Overhead Service		Replace - Same Size	VI
5125663	L23146	09/10/2015	21:49	09/10/2015	22:50	1	60	60	Animal related	Transformer Fuse	Replace - Same Size		III
5125675	D01001	09/10/2015	22:02	09/10/2015	23:00	2	115	57	Underground equipment	Underground Primary	Repair	Replace - Same Size	I
5125685	Q27185	09/10/2015	22:40	09/11/2015	11:50	1	789	789	Overhead equipment	Overhead Primary	Repair	Repair	VI
5125699	P58159	09/10/2015	23:59	09/11/2015	3:04	1	184	184	Underground equipment	Overhead Primary			VI
5125701	P58159	09/11/2015	0:06	09/11/2015	2:57	8	1367	170	Underground equipment	Underground Primary	Replace - Same Size	Replace - Same Size	VI
5125703	V22555	09/11/2015	0:10	09/11/2015	1:45	1	94	94	Animal related	Fuse	Replace - Same Size		II
5125705	P58159	09/11/2015	0:12	09/11/2015	2:56	8	1310	163	Underground equipment	Underground Primary	Replace - Same Size	Replace - Same Size	VI
5125715	V56002	09/11/2015	1:27	09/11/2015	3:14	1	106	106	Unknown	Recloser	Switch/Reset		II
5125717	Q27185	09/11/2015	1:34	09/11/2015	3:23	1	108	108	Other				VI
5125895	Q27186	09/11/2015	1:42	09/11/2015	19:15	109	47708	1053	Tree related-tree broken				VI
5125725	Q27186	09/11/2015	1:49	09/11/2015	5:12	1	202	202	Overhead equipment				VI
5125729	J18268	09/11/2015	1:51	09/11/2015	3:31	2	199	99	Overhead equipment	Overhead Transformer	Disconnect	Replace - Same Size	VI
5125911	Q27186	09/11/2015	1:57	09/11/2015	18:23	38	37465	985	Tree related-tree broken				VI
5125735	K27153	09/11/2015	2:06	09/11/2015	4:02	2	231	115	Animal related	Fuse	Replace - Same Size		VI
5125737	Q27185	09/11/2015	2:06	09/11/2015	2:36	6	179	29	Other	Other			VI
5125831	Q27186	09/11/2015	3:02	09/11/2015	7:24	105	27523	262	Overhead equipment	Overhead Primary		Replace - Same Size	VI
5125755	Q27185	09/11/2015	3:08	09/11/2015	4:13	1	64	64	Other				VI
5125761	Q27185	09/11/2015	3:30	09/11/2015	8:57	1	326	326	Tree related-tree broken	Overhead Service			VI

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5125765	D92001	09/11/2015	3:48	09/11/2015	11:31	84	24609	463	Underground equipment	Underground Transformer	Disconnect	Replace - Same Size	I
5125771	Q27185	09/11/2015	4:01	09/11/2015	8:57	1	295	295	Tree related-tree broken	Overhead Service			VI
5125773	Q27185	09/11/2015	4:10	09/11/2015	6:14	54	6685	123	Overhead equipment	Overhead Primary		Replace - Same Size	VI
5125775	Q27185	09/11/2015	4:18	09/11/2015	9:56	1	337	337	Overhead equipment				VI
5125783	Q27185	09/11/2015	4:32	09/11/2015	10:43	1	370	370	Tree related-tree broken				VI
5125789	Q27185	09/11/2015	4:44	09/11/2015	10:57	1	372	372	Tree related-tree broken				VI
5125799	P26280	09/11/2015	4:51	09/11/2015	9:57	19	5751	306	Tree related-tree contact	Recloser	Patrol/Test/Inspect		I
5125805	C70004	09/11/2015	4:53	09/11/2015	9:09	1	255	255	Underground equipment	Overhead Transformer	Disconnect	Replace - Same Size	III
5126165	A97003	09/11/2015	5:07	09/11/2015	14:02	24	12838	534	Underground equipment	Underground Primary	Repair	Repair	I
5125813	Q27185	09/11/2015	5:09	09/11/2015	11:14	1	364	364	Tree related-tree broken				VI
5125815	Q27186	09/11/2015	5:15	09/11/2015	6:31	1	75	75	Overhead equipment				VI
5125819	Q27185	09/11/2015	5:36	09/11/2015	11:33	1	356	356	Tree related-tree broken				VI
5125835	Q70161	09/11/2015	5:40	09/11/2015	13:07	18	8042	446	Public	Recloser			I
5125823	N74241	09/11/2015	5:41	09/11/2015	7:00	88	6871	78	Unknown				I
5125875	L46811	09/11/2015	6:07	09/11/2015	7:18	14	991	70	Tree related-tree broken	Fuse	Replace - Same Size		V
5125839	D87001	09/11/2015	6:14	09/11/2015	19:39	1	804	804	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
5125841	A50001	09/11/2015	6:18	09/11/2015	9:53	105	22606	215	Underground equipment	Underground Primary	Repair		I
5125851	307004	09/11/2015	6:32	09/11/2015	7:45	5	363	72	Animal related	Fuse	Replace - Same Size		VI
5125853	P26280	09/11/2015	6:38	09/11/2015	9:52	1	193	193	Tree related-tree broken	Tree	Remove		I
5125859	M22812	09/11/2015	6:53	09/11/2015	8:45	1	111	111	Overhead equipment	Overhead Service	Repair		V
5125867	Q27185	09/11/2015	6:57	09/11/2015	7:14	14	238	17	Overhead equipment	Overhead Primary		Replace - Same Size	VI
5125863		09/11/2015	6:57	09/11/2015	9:52	1	174	174	Tree related-tree broken	Tree	Remove		I
5125869	Q83172	09/11/2015	7:05	09/11/2015	9:11	1	125	125	Weather	Fuse	Replace - Same Size		VI
5125887	D92001	09/11/2015	7:16	09/11/2015	7:33	83	1355	16	Underground equipment	Underground Primary	Repair		I
5125889	L46811	09/11/2015	7:18	09/11/2015	9:26	1	127	127	Tree related-tree broken	Overhead Primary	Replace - Same Size	Replace - Same Size	V
5125891	Q27185	09/11/2015	7:22	09/11/2015	10:32	1	189	189	Tree related-tree broken	Overhead Service			VI
5125893	Q18243	09/11/2015	7:23	09/11/2015	8:32	1	68	68	Overhead equipment	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
5125897	L46811	09/11/2015	7:27	09/11/2015	7:34	13	99	7	Tree related-tree broken	Fuse	Replace - Same Size		V
5126103	D70003	09/11/2015	7:36	09/11/2015	12:57	2	641	320	Underground equipment	Fuse	Repair	Repair	I
5125909	Q24312	09/11/2015	7:48	09/11/2015	11:39	2	460	230	Tree related-tree broken	Overhead Primary	Patrol/Test/Inspect	Repair	VI
5125913	Q27185	09/11/2015	7:51	09/11/2015	11:00	1	188	188	Tree related-tree broken	Overhead Service			VI
5126101	R49275	09/11/2015	7:52	09/11/2015	13:41	10	3482	348	Overhead equipment	Overhead Primary	Repair	Repair	VI
5125919	P19395	09/11/2015	7:55	09/11/2015	9:33	1	97	97	Weather	Fuse	Replace - Same Size	Replace - Same Size	V
5125921	P19395	09/11/2015	8:00	09/11/2015	9:34	1	93	93	Weather				V
5125923	329147	09/11/2015	8:00	09/11/2015	11:50	1	229	229	Animal related	Overhead Service	Patrol/Test/Inspect	Replace - New Size	V
5126075	J99121	09/11/2015	8:20	09/11/2015	9:10	43	2111	49	Animal related	Fuse			VI
5126081	R01153	09/11/2015	8:31	09/11/2015	11:29	1	177	177	Tree related-tree broken	Overhead Service			III
5126095	P26280	09/11/2015	8:49	09/11/2015	9:57	17	1159	68	Tree related-tree broken	Tree	Remove		I
5126097	Q27185	09/11/2015	8:51	09/11/2015	11:12	1	140	140	Tree related-tree broken	Pole	Replace - Same Size	Replace - Same Size	VI
5126099	R71286	09/11/2015	8:53	09/11/2015	9:47	1	53	53	Animal related	Transformer Fuse	Repair	Replace - Same Size	VI
5126105	Q27185	09/11/2015	9:02	09/11/2015	11:15	6	798	133	Overhead equipment				VI
5126113	A97003	09/11/2015	9:19	09/11/2015	11:00	1	100	100	Overhead equipment	Connector	Replace - New Size		I
5126115	B21004	09/11/2015	9:22	09/11/2015	14:23	1	300	300	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Repair	I
5126117	P73160	09/11/2015	9:25	09/11/2015	9:51	2	51	25	Overhead equipment	Overhead Secondary	Repair		VI
5126121	S62520	09/11/2015	9:39	09/11/2015	11:37	1	117	117	Tree related-tree broken	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	VI
5126125	B58001	09/11/2015	9:48	09/11/2015	11:03	1	74	74	Overhead equipment	Fuse	Replace - Same Size		I
5126127	P82291	09/11/2015	9:52	09/11/2015	10:36	1	43	43	Animal related	Transformer Fuse	Repair	Replace - Same Size	VI
5126135	D88002	09/11/2015	9:56	09/11/2015	16:15	176	66476	378	Underground equipment	Underground Primary			I
5126141	Z21564	09/11/2015	9:59	09/11/2015	12:35	1	156	155	Tree related-tree contact	Overhead Service	Repair		IV
5126151	C52002	09/11/2015	10:05	09/11/2015	10:56	53	2678	50	Overhead equipment	Fuse	Replace - Same Size		III
5126171	B28004	09/11/2015	10:20	09/11/2015	12:30	1	129	129	Overhead equipment				I
5126175	D36001	09/11/2015	10:35	09/11/2015	12:01	1	85	85	Overhead equipment	Connector	Replace - Same Size	Replace - Same Size	I
5126183	D36003	09/11/2015	10:47	09/11/2015	13:16	13	1945	149	Underground equipment	Underground Primary	Repair		I
5126181	L23146	09/11/2015	10:49	09/11/2015	11:20	5	151	30	Underground equipment	Underground Primary			III
5126185	L23146	09/11/2015	10:50	09/11/2015	11:20	3	88	29	Underground equipment	Underground Primary			III
5126309	D36003	09/11/2015	10:52	09/11/2015	15:42	1	289	289	Underground equipment	Underground Primary	Repair	Repair	I

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5126189	D66004	09/11/2015	10:54	09/11/2015	13:55	1	180	180	Underground equipment				IV
5126191	Q27185	09/11/2015	10:55	09/11/2015	11:28	5	162	32	Overhead equipment	Overhead Secondary	Replace - Same Size	Replace - Same Size	VI
5126207	J08205	09/11/2015	11:08	09/11/2015	12:46	1	97	97	Overhead equipment	Overhead Primary	Repair		I
5126209	Q27185	09/11/2015	11:16	09/11/2015	12:37	1	81	81	Weather				VI
5126217	P73160	09/11/2015	11:36	09/11/2015	12:10	10	341	34	Overhead equipment	Overhead Secondary		Replace - Same Size	VI
5126221	P25152	09/11/2015	11:41	09/11/2015	12:53	1	71	71	Animal related	Fuse	Repair		III
5126227	Q85162	09/11/2015	11:47	09/11/2015	13:48	1	120	120	Animal related	Transformer Fuse	Replace - Same Size		VI
5126229	P25152	09/11/2015	11:49	09/11/2015	12:54	5	322	64	Animal related	Fuse	Repair		III
5126237	K67924	09/11/2015	12:00	09/11/2015	13:07	1	66	66	Overhead equipment	Fuse	Replace - Same Size	Repair	VI
5126241	S02502	09/11/2015	12:05	09/11/2015	13:06	1	60	60	Animal related	Transformer Fuse	Replace - Same Size		VI
5126249	L79157	09/11/2015	12:13	09/11/2015	13:28	9	672	74	Animal related	Transformer Fuse	Replace - Same Size		IV
5126253	B68004	09/11/2015	12:43	09/11/2015	13:44	1	61	60	Overhead equipment	Connector	Repair		III
5126261	M37192	09/11/2015	12:45	09/11/2015	13:30	1	44	44	Tree related-tree broken	Overhead Service	Repair	Replace - Same Size	I
5126273	J88165	09/11/2015	12:54	09/11/2015	15:00	32	4007	125	Underground equipment	Underground Primary			VI
5126283	D70003	09/11/2015	12:56	09/11/2015	15:05	2	257	128	Underground equipment	Underground Primary	Replace - Same Size	Replace - Same Size	I
5126287	D88002	09/11/2015	12:58	09/11/2015	19:56	1	417	417	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	I
5126313	L23146	09/11/2015	13:33	09/11/2015	15:06	6	555	92	Other	Overhead Primary			III
5126317	L23146	09/11/2015	13:41	09/11/2015	15:06	3	255	85	Overhead equipment	Overhead Primary			III
5126321	S14509	09/11/2015	13:45	09/11/2015	14:12	1	26	26	Unknown	Customer Equipment	Replace - Same Size		VI
5126323	J06167	09/11/2015	13:50	09/11/2015	14:35	1	44	44	Overhead equipment	Fuse	Repair	Replace - Same Size	I
5126325	N74241	09/11/2015	13:50	09/11/2015	14:25	88	3006	34	Overhead equipment	Disconnect Switch	Replace - Same Size	Replace - Same Size	I
5126343	V39001	09/11/2015	14:29	09/11/2015	15:50	1	80	80	Tree related-tree broken	Overhead Service	Raise		II
5126347	Y37593	09/11/2015	14:36	09/11/2015	16:50	1	133	133	Overhead equipment				IV
5126351	A85001	09/11/2015	14:41	09/11/2015	15:45	6	380	63	Overhead equipment				I
5126363	Q27185	09/11/2015	15:13	09/11/2015	16:12	1	58	58	Tree related-tree broken	Fuse	Replace - Same Size		VI
5126365	B77003	09/11/2015	15:20	09/11/2015	16:53	29	2674	92	Tree related-tree broken	Overhead Primary	Replace - Same Size		I
5126371	Y45504	09/11/2015	15:34	09/11/2015	15:55	1	20	20	Overhead equipment	Transformer Fuse	Repair	Replace - Same Size	IV
5126377	M18130	09/11/2015	15:46	09/11/2015	17:12	4	342	85	Overhead equipment	Overhead Service	Repair		III
5126387		09/11/2015	16:18	09/11/2015	17:10	4	205	51	Public	Customer Equipment			II
5126389	V61563	09/11/2015	16:27	09/11/2015	19:12	1	164	164	Tree related-tree broken	Tree	Trim		II
5126401	Y05001	09/11/2015	16:50	09/11/2015	18:39	1	108	108	Tree related-tree broken	Overhead Service	Repair		IV
5126409	S50541	09/11/2015	17:08	09/11/2015	19:27	3	416	138	Overhead equipment				VI
5126419	S61575	09/11/2015	17:34	09/11/2015	20:40	2	370	185	Tree related-tree contact	Transformer Fuse	Replace - Same Size		VI
5126421	L63936	09/11/2015	17:35	09/11/2015	23:45	19	5725	369	Underground equipment	Underground Primary		Repair	VI
5126435	N03297	09/11/2015	18:02	09/11/2015	19:11	1	68	68	Tree related-tree broken	Overhead Service	Repair		V
5126437	U80001	09/11/2015	18:07	09/11/2015	19:05	1	57	57	Overhead equipment	Connector	Repair		II
5126439	324002	09/11/2015	18:18	09/11/2015	20:06	1	107	107	Overhead equipment	Other	Patrol/Test/Inspect		VI
5126445	P54828	09/11/2015	18:34	09/11/2015	19:55	1	80	80	Animal related	Fuse	Replace - Same Size		V
5126451	P54828	09/11/2015	19:19	09/11/2015	19:59	1	39	39	Animal related	Fuse	Replace - Same Size		V
5126453	A91004	09/11/2015	19:19	09/12/2015	0:03	1	283	283	Underground equipment	Underground Primary	Repair	Repair	I
5126455	A91004	09/11/2015	19:35	09/11/2015	21:39	14	1733	123	Underground equipment	Underground Primary	Switch/Reset		I
5126459	S93504	09/11/2015	19:47	09/11/2015	21:49	1	121	121	Overhead equipment	Disconnect Switch	Replace - Same Size	Repair	VI
5126475	J30203	09/11/2015	19:50	09/12/2015	3:05	4	1739	434	Tree related-tree broken	Tree			VI
5126463	B00003	09/11/2015	19:53	09/11/2015	21:29	1	95	95	Overhead equipment	Connector	Replace - Same Size		I
5126465	K76545	09/11/2015	20:14	09/11/2015	21:29	1	74	74	Overhead equipment	Overhead Service	Repair		IV
5126471	C00001	09/11/2015	22:53	09/12/2015	2:20	11	2268	206	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
5126479	N67309	09/11/2015	23:16	09/12/2015	0:14	1	57	57	Overhead equipment	Other	Replace - Same Size	Replace - Same Size	I
5126481	P18103	09/11/2015	23:18	09/12/2015	1:15	1	116	116	Unknown	Transformer Fuse	Replace - Same Size		IV
5126483	Y37592	09/12/2015	0:01	09/12/2015	1:34	1	92	92	Overhead equipment	Disconnect Switch	Replace - Same Size		IV
5126487	S78551	09/12/2015	1:48	09/12/2015	2:39	1	50	50	Public				VI
5126531	V99562	09/12/2015	6:22	09/12/2015	9:20	852	151511	177	Substation equipment	Substation Misc.			II
5126547	P83710	09/12/2015	6:32	09/12/2015	8:34	1	121	121	Animal related	Transformer Fuse	Repair		I
5126555	R39934	09/12/2015	6:36	09/12/2015	9:29	1	172	172	Animal related	Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
5126699	J99141	09/12/2015	6:50	09/12/2015	11:58	2068	389533	307	Animal related	Pole	Patrol/Test/Inspect	Replace - Same Size	VI
5126743	N18211	09/12/2015	6:59	09/12/2015	8:35	1	95	95	Overhead equipment	Transformer Fuse	Replace - Same Size		III
5126745	P98190	09/12/2015	7:01	09/12/2015	7:44	1	43	43	Animal related	Fuse			III

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5126747	P98190	09/12/2015	7:01	09/12/2015	7:27	6	150	25	Animal related	Fuse			III
5126751	S09520	09/12/2015	7:08	09/12/2015	12:21	3	937	312	Underground equipment	Underground Primary	Repair		VI
5126755	U86500	09/12/2015	7:22	09/12/2015	8:43	1	80	80	Animal related	Transformer Fuse	Replace - Same Size		II
5126757	J99128	09/12/2015	7:23	09/12/2015	9:29	1	125	125	Animal related	Transformer Fuse	Replace - Same Size		VI
5126759	328119	09/12/2015	7:54	09/12/2015	8:46	15	771	51	Animal related	Fuse	Replace - Same Size		V
5126761	A45002	09/12/2015	8:01	09/12/2015	9:00	8	470	58	Unknown	Disconnect Switch	Replace - Same Size	Replace - Same Size	I
5126765	R04407	09/12/2015	8:09	09/12/2015	11:25	7	1367	195	Overhead equipment	Overhead Transformer	Replace - Same Size	Replace - Same Size	V
5126767	B73001	09/12/2015	8:10	09/12/2015	9:42	1	91	91	Animal related				I
5126777	L99392	09/12/2015	8:20	09/12/2015	9:06	1	45	45	Animal related	Fuse	Replace - Same Size		V
5126779	P98192	09/12/2015	8:26	09/12/2015	9:07	8	327	40	Animal related	Transformer Fuse			III
5126781	V14579	09/12/2015	8:39	09/12/2015	9:49	1	69	69	Overhead equipment	Overhead Service	Repair		II
5126795	N05172	09/12/2015	8:49	09/12/2015	9:40	1	50	50	Animal related	Transformer Fuse	Replace - Same Size		I
5126799	M09144	09/12/2015	9:03	09/12/2015	9:46	1	42	42	Animal related	Fuse	Replace - Same Size		VI
5126813	K27153	09/12/2015	9:04	09/12/2015	10:16	11	783	71	Unknown	Fuse	Replace - Same Size	Replace - Same Size	VI
5126805	M09144	09/12/2015	9:06	09/12/2015	9:45	1	38	38	Animal related	Fuse	Replace - Same Size		VI
5126811	R39934	09/12/2015	9:20	09/12/2015	9:33	2	26	13	Overhead equipment				VI
5126821	N97886	09/12/2015	9:38	09/12/2015	20:40	1	661	661	Underground equipment	Underground Primary		Replace - Same Size	V
5126823	N18211	09/12/2015	9:47	09/12/2015	11:50	1	122	122	Overhead equipment	Transformer Fuse	Replace - Same Size		III
5126829	K69112	09/12/2015	10:12	09/12/2015	12:59	17	2829	166	Animal related	Underground Primary	Patrol/Test/Inspect	Repair	IV
5126831	Z29579	09/12/2015	10:13	09/12/2015	11:18	1	64	64	Tree related-tree broken	Overhead Service	Repair		IV
5126841	Q85162	09/12/2015	10:33	09/12/2015	11:52	27	2106	78	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	VI
5126853	P60170	09/12/2015	11:16	09/12/2015	14:00	14	2295	163	Tree related-tree broken	Overhead Primary	Repair	Repair	VI
5126869	D37001	09/12/2015	11:35	09/12/2015	13:49	1	133	133	Overhead equipment	Connector	Replace - Same Size		I
5126871	X91510	09/12/2015	11:41	09/12/2015	15:06	1	204	204	Overhead equipment	Transformer Fuse	Repair	Replace - Same Size	IV
5126873	J83137	09/12/2015	11:42	09/12/2015	11:58	8	122	15	Overhead equipment				VI
5126875	J83137	09/12/2015	11:45	09/12/2015	11:58	203	2594	12	Overhead equipment				VI
5126879	N97886	09/12/2015	11:51	09/12/2015	20:44	2	1067	533	Underground equipment	Underground Primary	Replace - Same Size		V
5126881	D36001	09/12/2015	11:56	09/12/2015	12:40	1	43	43	Animal related				I
5126911	J14140	09/12/2015	12:26	09/12/2015	15:00	1	153	153	Animal related	Transformer Fuse	Replace - Same Size		VI
5126915	D89001	09/12/2015	12:35	09/12/2015	13:41	38	2473	65	Unknown				I
5126973		09/12/2015	12:35	09/12/2015	16:25	1236	149830	229	Animal related				IV
5126921	D92002	09/12/2015	12:36	09/12/2015	15:07	1	150	150	Tree related-tree contact	Overhead Service	Repair		I
5126965	C70004	09/12/2015	12:45	09/12/2015	16:20	1	214	214	Underground equipment	Underground Primary			III
5126999	L46811	09/12/2015	12:54	09/12/2015	13:40	1	45	45	Overhead equipment	Transformer Fuse	Replace - Same Size		V
5127021	Q93522	09/12/2015	13:14	09/12/2015	14:50	1	95	95	Overhead equipment	Transformer Fuse	Replace - Same Size		I
5127031	L35139	09/12/2015	13:18	09/12/2015	15:51	44	6702	152	Overhead equipment	Fuse	Replace - Same Size		III
5127033	B53001	09/12/2015	13:29	09/12/2015	23:53	1	624	624	Overhead equipment	Overhead Primary			III
5155247	K69116	09/12/2015	13:56	09/12/2015	15:13	281	21755	77	Animal related				IV
5127089	P42229	09/12/2015	13:57	09/12/2015	14:55	20	1156	57	Overhead equipment	Fuse			VI
5127135	K69115	09/12/2015	14:20	09/12/2015	14:57	1	37	37	Animal related				IV
5127141	V44511	09/12/2015	14:42	09/12/2015	18:15	36	7643	212	Underground equipment	Fuse		Repair	II
5127153	M41113	09/12/2015	15:09	09/12/2015	16:20	5	352	70	Overhead equipment	Fuse	Replace - Same Size		I
5127161	C52001	09/12/2015	15:50	09/12/2015	19:10	1	199	199	Overhead equipment	Overhead Transformer			III
5127163	K31124	09/12/2015	15:51	09/12/2015	18:15	1	143	143	Overhead equipment	Recloser	Switch/Reset		I
5127169	Q74149	09/12/2015	16:14	09/12/2015	18:16	1	121	121	Tree related-tree contact	Overhead Service	Repair		IV
5127173	B53001	09/12/2015	16:56	09/12/2015	23:53	5	2088	417	Overhead equipment	Pole	Repair	Replace - Same Size	III
5127179	L17101	09/12/2015	17:06	09/12/2015	19:05	28	3315	118	Animal related	Overhead Primary	Repair		III
5127193	Y37592	09/12/2015	17:32	09/12/2015	18:19	1	46	46	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
5127197	P17107	09/12/2015	17:37	09/12/2015	18:58	37	2987	80	Animal related	Fuse	Replace - Same Size		IV
5127199	D35003	09/12/2015	17:41	09/12/2015	18:42	1	60	60	Overhead equipment	Connector	Replace - Same Size	Replace - Same Size	I
5127205	K62102	09/12/2015	18:11	09/12/2015	20:13	1	121	121	Overhead equipment				II
5127211	U97520	09/12/2015	19:14	09/12/2015	20:39	4	337	84	Overhead equipment	Fuse	Replace - Same Size		II
5127215	L35137	09/12/2015	19:33	09/12/2015	21:36	1	122	122	Overhead equipment	Overhead Service			III
5127221	K15205	09/12/2015	19:55	09/12/2015	23:15	1	199	199	Tree related-tree contact	Transformer Fuse	Replace - Same Size		VI
5127229	N67309	09/12/2015	22:36	09/13/2015	1:05	1	148	148	Overhead equipment	Connector	Repair		I
5127237	M45212	09/13/2015	0:20	09/13/2015	3:50	20	4154	209	Underground equipment	Underground Primary		Repair	IV

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5127239	HA5432	09/13/2015	1:01	09/13/2015	2:54	1	112	112	Public	Pole	Patrol/Test/Inspect		V
5127245	K71821	09/13/2015	1:39	09/13/2015	3:18	38	3760	98	Unknown	Overhead Transformer	Replace - Same Size	Replace - Same Size	IV
5127257	Y31591	09/13/2015	3:07	09/13/2015	5:35	146	21619	148	Overhead equipment	Overhead Primary	Repair		IV
5127271	R05115	09/13/2015	3:27	09/13/2015	8:13	10	2857	285	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
5127287	N18211	09/13/2015	5:12	09/13/2015	7:15	24	2945	122	Overhead equipment	Overhead Primary	Tie/Tighten		III
5127277	K80381	09/13/2015	5:36	09/13/2015	9:57	22	5752	261	Underground equipment	Underground Primary	Repair		IV
5127289	U84566	09/13/2015	7:03	09/13/2015	7:50	10	461	46	Overhead equipment	Fuse	Replace - Same Size		II
5127293	D36002	09/13/2015	7:12	09/13/2015	9:20	1	127	127	Animal related	Fuse	Replace - Same Size		I
5127295	Y31589	09/13/2015	7:28	09/13/2015	8:27	1	58	58	Animal related	Transformer Fuse	Replace - Same Size		IV
5127297	D87001	09/13/2015	7:31	09/13/2015	8:50	1	78	78	Animal related	Fuse	Replace - Same Size		I
5127301	T23527	09/13/2015	7:42	09/13/2015	9:32	5	545	109	Animal related	Disconnect Switch	Replace - Same Size	Patrol/Test/Inspect	VI
5127321	Q80352	09/13/2015	8:21	09/13/2015	9:02	1	40	40	Animal related	Transformer Fuse	Replace - Same Size	Replace - Same Size	V
5127325	J88166	09/13/2015	8:30	09/13/2015	10:15	1	104	104	Animal related	Fuse	Replace - Same Size		VI
5127327	X02548	09/13/2015	8:33	09/13/2015	10:12	1	98	98	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
5127331	K32915	09/13/2015	8:35	09/13/2015	9:52	1	76	76	Animal related	Overhead Primary		Repair	VI
5127335	B73003	09/13/2015	8:40	09/13/2015	10:47	3	380	126	Animal related	Fuse	Replace - Same Size		I
5127339	J84145	09/13/2015	8:44	09/13/2015	11:40	1	175	175	Overhead equipment	Fuse	Replace - Same Size		VI
5127345	K80381	09/13/2015	9:13	09/13/2015	10:23	1	69	69	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	IV
5127351	C10002	09/13/2015	9:57	09/13/2015	14:56	1	298	298	Overhead equipment	Overhead Primary	Patrol/Test/Inspect	Patrol/Test/Inspect	III
5127359	335003	09/13/2015	11:00	09/13/2015	13:00	1	119	119	Animal related	Fuse	Replace - Same Size		VI
5127363	R39934	09/13/2015	11:28	09/13/2015	13:41	1	132	132	Animal related	Transformer Fuse	Replace - Same Size		VI
5127369	A45003	09/13/2015	11:47	09/13/2015	12:18	34	1048	30	Overhead equipment	Fuse	Patrol/Test/Inspect		I
5127375	A45003	09/13/2015	12:32	09/13/2015	14:22	1	109	109	Overhead equipment	Fuse			I
5127377	V59002	09/13/2015	12:32	09/13/2015	13:53	1	80	80	Underground equipment	Underground Service	Repair		II
5127379	A45003	09/13/2015	12:33	09/13/2015	14:04	1	90	90	Overhead equipment	Fuse			I
5127381	Z06537	09/13/2015	13:17	09/13/2015	14:02	1	44	44	Tree related-tree broken	Transformer Fuse	Repair	Replace - Same Size	IV
5127383	N05172	09/13/2015	13:23	09/13/2015	14:32	1	68	68	Overhead equipment	Fuse			I
5127385	Y28598	09/13/2015	13:45	09/13/2015	17:00	1	195	195	Overhead equipment	Overhead Transformer	Replace - Same Size	Replace - Same Size	IV
5127391	C52001	09/13/2015	14:06	09/13/2015	15:50	41	4244	103	Overhead equipment	Fuse	Replace - Same Size		III
5127397	A45003	09/13/2015	14:34	09/13/2015	17:38	31	5683	183	Underground equipment	Underground Primary	Patrol/Test/Inspect	Patrol/Test/Inspect	I
5127411	K89143	09/13/2015	15:04	09/13/2015	16:36	20	1840	91	Overhead equipment	Overhead Primary	Repair		III
5127409	R58951	09/13/2015	15:07	09/13/2015	16:26	8	627	78	Unknown	Transformer Fuse	Replace - Same Size	Replace - Same Size	IV
5127445	T06505	09/13/2015	16:05	09/13/2015	16:52	1	46	46	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	VI
5127523	C50002	09/13/2015	16:09	09/13/2015	22:21	105	39110	372	Animal related	Jumper	Repair	Replace - Same Size	III
5127451	S42579	09/13/2015	16:12	09/13/2015	17:15	3	188	62	Animal related	Fuse	Replace - Same Size		VI
5127489	A45003	09/13/2015	16:14	09/13/2015	20:37	3	788	262	Underground equipment	Underground Primary	Repair	Repair	I
5127471	P60170	09/13/2015	16:30	09/13/2015	19:40	14	2649	189	Tree related-tree broken	Overhead Primary		Repair	VI
5127477	N44217	09/13/2015	16:55	09/13/2015	17:54	1	58	58	Tree related-tree contact	Overhead Service	Repair		III
5127521	C50002	09/13/2015	17:17	09/13/2015	22:21	1	304	304	Animal related	Fuse	Replace - Same Size	Replace - Same Size	III
5127493	L23145	09/13/2015	17:50	09/13/2015	19:00	21	1450	69	Animal related	Fuse	Replace - Same Size		III
5127497	E10001	09/13/2015	18:11	09/13/2015	21:50	17	3711	218	Overhead equipment	Fuse	Replace - Same Size		III
5127503	Q32171	09/13/2015	18:16	09/13/2015	19:19	3	186	62	Animal related	Fuse	Replace - Same Size	Patrol/Test/Inspect	I
5127511	K30205	09/13/2015	18:19	09/13/2015	19:51	5	456	91	Animal related	Fuse			III
5127507	Q32171	09/13/2015	18:26	09/13/2015	19:32	1	65	65	Animal related	Fuse	Replace - Same Size	Patrol/Test/Inspect	I
5127509	Q32171	09/13/2015	18:32	09/13/2015	18:58	4	101	25	Animal related	Fuse	Replace - Same Size	Patrol/Test/Inspect	I
5127527	B21001	09/13/2015	20:42	09/13/2015	22:18	1	95	95	Underground equipment	Underground Primary	Patrol/Test/Inspect	Reconnect	I
5127529	J76804	09/13/2015	21:01	09/14/2015	0:07	1	185	185	Underground equipment	Underground Service	Repair	Repair	V
5127531	Q74150	09/13/2015	21:23	09/13/2015	23:10	1	106	106	Overhead equipment	Overhead Service	Repair		IV
5127539	D48002	09/13/2015	21:58	09/13/2015	23:32	1	93	93	Overhead equipment	Fuse	Replace - Same Size		I
5127541	C50002	09/13/2015	22:06	09/13/2015	22:21	140	2188	15	Animal related	Jumper	Repair	Replace - Same Size	III
5127547	B21001	09/13/2015	22:29	09/14/2015	2:37	1	247	247	Underground equipment	Underground Primary	Repair	Repair	I
5127557	D28123	09/14/2015	6:07	09/14/2015	11:59	4	1211	352	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
5127559	B61001	09/14/2015	6:56	09/14/2015	8:10	1	73	73	Overhead equipment	Connector	Repair		I
5127561	U64518	09/14/2015	7:14	09/14/2015	9:30	1	135	135	Animal related	Transformer Fuse	Replace - Same Size		II
5127563	T42525	09/14/2015	7:19	09/14/2015	12:10	1	290	290	Underground equipment	Underground Primary	Repair	Repair	IV
5127565	J07135	09/14/2015	7:31	09/14/2015	8:52	3	242	80	Animal related	Fuse	Repair	Replace - Same Size	I

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5127567	K62102	09/14/2015	7:32	09/14/2015	9:16	1	103	103	Overhead equipment	Transformer Fuse	Replace - Same Size		II
5127583	B84002	09/14/2015	8:20	09/14/2015	9:38	89	6930	77	Animal related	Fuse	Replace - Same Size		I
5127585	338007	09/14/2015	8:20	09/14/2015	9:57	1	96	96	Overhead equipment	Transformer Fuse	Replace - Same Size		VI
5127593	L17104	09/14/2015	8:23	09/14/2015	9:58	1	94	94	Overhead equipment	Fuse	Repair		III
5127599	F03003	09/14/2015	8:27	09/14/2015	9:47	7	555	79	Animal related	Fuse	Replace - Same Size		III
5127609	U39541	09/14/2015	8:31	09/14/2015	9:38	23	1531	66	Animal related	Fuse	Replace - Same Size		II
5127603	N67309	09/14/2015	8:31	09/14/2015	9:13	1	41	41	Animal related	Fuse	Replace - Same Size		I
5127605	C30002	09/14/2015	8:32	09/14/2015	9:28	1	55	55	Animal related	Transformer Fuse	Replace - Same Size		III
5127607	U09557	09/14/2015	8:32	09/14/2015	11:14	1	161	161	Animal related	Transformer Fuse	Replace - Same Size		II
5127617	J75271	09/14/2015	8:48	09/14/2015	10:18	1	89	89	Public	Fuse	Replace - Same Size		IV
5127647	P77233	09/14/2015	9:45	09/14/2015	13:47	1	241	241	Underground equipment	Underground Primary	Patrol/Test/Inspect		VI
5127653	H65-X1	09/14/2015	9:48	09/14/2015	10:40	1	51	51	Overhead equipment	Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
5127665	P62113	09/14/2015	9:55	09/14/2015	11:00	1	64	64	Overhead equipment	Transformer Fuse	Replace - Same Size		VI
5127667	L71171	09/14/2015	9:56	09/14/2015	11:12	1	75	75	Overhead equipment	Fuse	Replace - Same Size		IV
5127673	315106	09/14/2015	10:11	09/14/2015	13:45	1	213	213	Overhead equipment	Disconnect Switch	Patrol/Test/Inspect	Replace - Same Size	V
5127691	P17109	09/14/2015	10:29	09/14/2015	13:10	1	160	160	Public	Overhead Service		Replace - New Size	IV
5127857	U12-XTR2	09/14/2015	10:30	09/14/2015	10:38	529	4205	7	Jurisdictional				II
5127693	M47816	09/14/2015	10:30	09/14/2015	10:37	596	4070	6	Overhead equipment				V
5127759	V20512	09/14/2015	10:30	09/14/2015	10:38	419	3611	8	Jurisdictional	Capacitor	Repair	Replace - Same Size	II
5127721	U12-XTR2	09/14/2015	10:30	09/14/2015	10:38	529	4179	7	Jurisdictional	Capacitor	Repair	Replace - Same Size	II
5127755	U14-XBK1	09/14/2015	10:30	09/14/2015	10:38	184	1376	7	Jurisdictional	Capacitor	Repair	Replace - Same Size	II
5127851	U12-XTR1	09/14/2015	10:30	09/14/2015	10:38	367	3090	8	Jurisdictional				II
5127807	U64-XTR1	09/14/2015	10:30	09/14/2015	10:38	910	7070	7	Jurisdictional	Capacitor	Repair	Replace - Same Size	II
5127765	V20502	09/14/2015	10:30	09/14/2015	10:38	805	6142	7	Jurisdictional	Capacitor	Repair	Replace - Same Size	II
5127735	U12-XTR1	09/14/2015	10:33	09/14/2015	10:38	367	1479	4	Jurisdictional	Capacitor	Repair	Replace - Same Size	II
5127841	J18268	09/14/2015	10:44	09/14/2015	11:54	95	6581	69	Animal related				VI
5127829	M47816	09/14/2015	10:45	09/14/2015	11:35	1	49	49	Overhead equipment	Regulator			V
5127831	H00161	09/14/2015	10:45	09/14/2015	11:55	1	69	69	Overhead equipment	Overhead Transformer	Repair	Repair	III
5127847	J18268	09/14/2015	10:50	09/14/2015	11:54	35	2207	63	Animal related				VI
5127849	K28183	09/14/2015	10:53	09/14/2015	13:45	1	171	171	Overhead equipment	Other			III
5127891	U04550	09/14/2015	11:49	09/14/2015	14:45	1	175	175	Overhead equipment	Disconnect Switch	Replace - Same Size	Repair	II
5127901	J18268	09/14/2015	11:56	09/14/2015	12:20	2	47	23	Overhead equipment	Overhead Transformer	Repair	Repair	VI
5127903	S25551	09/14/2015	11:57	09/14/2015	13:13	1	75	75	Animal related	Fuse	Patrol/Test/Inspect	Repair	VI
5127905	D35003	09/14/2015	11:57	09/14/2015	20:08	2	982	490	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
5127913	U57561	09/14/2015	12:03	09/14/2015	12:24	6	122	20	Animal related	Transformer Fuse	Replace - Same Size		II
5127949	S88502	09/14/2015	12:19	09/14/2015	13:31	1	71	71	Overhead equipment	Disconnect Switch	Patrol/Test/Inspect	Replace - Same Size	VI
5127951	A81004	09/14/2015	12:34	09/14/2015	19:12	25	7930	397	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
5127961	A32003	09/14/2015	12:42	09/14/2015	16:46	3	729	243	Animal related	Fuse	Replace - Same Size		I
5127973	Y91500	09/14/2015	13:00	09/14/2015	13:44	13	561	43	Overhead equipment	Transformer Fuse	Repair	Replace - Same Size	IV
5127975	S19553	09/14/2015	13:01	09/14/2015	13:25	1	23	23	Unknown	Customer Equipment	Replace - Same Size		VI
5127977	L81141	09/14/2015	13:01	09/14/2015	13:11	1	9	9	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
5127999	R01153	09/14/2015	13:19	09/14/2015	15:26	1	126	126	Overhead equipment	Connector			III
5128005	C50001	09/14/2015	13:32	09/14/2015	13:40	1	7	7	Underground equipment				III
5128007	A97003	09/14/2015	13:34	09/14/2015	21:04	77	16646	449	Overhead equipment	Pole	Patrol/Test/Inspect	Reconnect	I
5128011	R66470	09/14/2015	13:37	09/14/2015	14:54	26	1979	76	Underground equipment	Underground Primary	Switch/Reset	Repair	IV
5128023	D92001	09/14/2015	13:47	09/14/2015	17:47	93	21931	240	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
5128073	R66470	09/14/2015	13:49	09/14/2015	14:54	26	1695	65	Underground equipment				IV
5128027	Q69926	09/14/2015	13:52	09/14/2015	16:37	1	164	164	Tree related-tree contact	Tree	Patrol/Test/Inspect	Trim	VI
5128043	T06538	09/14/2015	14:03	09/14/2015	15:05	36	2197	61	Tree related-tree broken	Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
5128047	U92593	09/14/2015	14:10	09/14/2015	15:15	1	64	64	Overhead equipment	Transformer Fuse	Replace - Same Size	Replace - Same Size	II
5128049	L70127	09/14/2015	14:15	09/14/2015	16:24	29	3732	128	Animal related				IV
5128051	T06538	09/14/2015	14:16	09/14/2015	15:19	1	62	62	Overhead equipment	Fuse	Patrol/Test/Inspect	Repair	VI
5128061	L71171	09/14/2015	14:30	09/14/2015	15:03	1	32	32	Animal related	Transformer Fuse	Replace - Same Size		IV
5128075	P26284	09/14/2015	14:56	09/14/2015	19:11	1	254	254	Animal related	Fuse	Replace - Same Size		I
5128077	D72002	09/14/2015	15:02	09/14/2015	16:57	13	1494	114	Animal related	Fuse	Replace - Same Size		I
5128081	J61110	09/14/2015	15:10	09/14/2015	16:16	1	65	65	Overhead equipment	Overhead Transformer			III

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5128145	Q14392	09/14/2015	15:18	09/14/2015	16:25	125	8287	66	Overhead equipment	Recloser			I
5128097	U39541	09/14/2015	15:20	09/14/2015	17:24	1	123	123	Other	Guy Wire	Replace - Same Size		II
5128101	HB5890	09/14/2015	15:27	09/14/2015	16:30	1	62	62	Unknown	Fuse	Repair	Repair	I
5128113	L70127	09/14/2015	15:39	09/14/2015	17:57	8	1097	137	Public	Transformer Fuse	Replace - Same Size		IV
5128121	J46183	09/14/2015	15:56	09/14/2015	16:46	1	49	49	Overhead equipment	Overhead Service			III
5128125	N91255	09/14/2015	16:01	09/14/2015	18:56	1	174	174	Tree related-tree contact	Tree			III
5128151	S88503	09/14/2015	16:34	09/14/2015	19:49	1	194	194	Overhead equipment	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
5128189	C30002	09/14/2015	17:31	09/15/2015	1:45	5	2472	494	Overhead equipment	Pole	Repair	Replace - Same Size	III
5128161	L12125	09/14/2015	17:41	09/14/2015	18:55	1	73	73	Tree related-tree broken	Overhead Service	Repair		III
5128163	A97003	09/14/2015	17:43	09/14/2015	18:00	1	16	16	Other				I
5128165	M09144	09/14/2015	17:51	09/14/2015	21:14	1	202	202	Overhead equipment	Overhead Transformer	Replace - Same Size	Repair	VI
5128171	R07382	09/14/2015	17:58	09/14/2015	19:11	1	72	72	Animal related	Fuse	Replace - Same Size		I
5128175	X02546	09/14/2015	18:04	09/14/2015	18:55	1	50	50	Jurisdictional	Meter	Reconnect		IV
5128179	V22555	09/14/2015	18:11	09/14/2015	19:14	1	62	62	Overhead equipment	Transformer Fuse	Replace - Same Size		II
5128187	R58961	09/14/2015	18:30	09/14/2015	20:40	10	1291	129	Tree related-tree broken	Overhead Primary	Patrol/Test/Inspect	Repair	IV
5128243	X16511	09/14/2015	19:03	09/14/2015	22:03	86	12729	179	Overhead equipment	Overhead Primary	Repair	Repair	IV
5128205	V39003	09/14/2015	19:06	09/14/2015	20:39	16	1483	92	Overhead equipment	Transformer Fuse	Replace - Same Size		II
5128241	R78301	09/14/2015	19:36	09/14/2015	20:14	1	37	37	Overhead equipment	Overhead Service	Repair		V
5128251	P26280	09/14/2015	20:10	09/14/2015	23:00	1	169	169	Tree related-tree contact	Overhead Service	Repair	Repair	I
5128257	U31565	09/14/2015	20:56	09/14/2015	22:25	1	88	88	Underground equipment	Underground Primary	Repair		II
5128261	U31565	09/14/2015	21:00	09/14/2015	22:25	58	4923	84	Underground equipment	Underground Primary	Repair		II
5128269	K30204	09/14/2015	21:48	09/15/2015	1:25	1	216	216	Overhead equipment	Fuse	Replace - Same Size		III
5128275	A91004	09/14/2015	21:49	09/14/2015	23:26	201	19470	96	Tree related-tree broken	Recloser	Replace - Same Size	Replace - Same Size	I
5128311	A91004	09/14/2015	21:50	09/14/2015	23:26	120	11522	96	Tree related-tree broken	Recloser	Replace - Same Size	Replace - Same Size	I
5128313	A91004	09/14/2015	21:50	09/14/2015	23:26	111	10598	95	Tree related-tree broken	Recloser	Replace - Same Size	Replace - Same Size	I
5128303	A91004	09/14/2015	21:53	09/14/2015	23:26	1	92	92	Tree related-tree broken	Recloser	Replace - Same Size	Replace - Same Size	I
5128309	K89142	09/14/2015	21:56	09/15/2015	0:59	5	912	182	Overhead equipment	Overhead Transformer	Replace - Same Size		III
5128321	B80004	09/14/2015	23:39	09/15/2015	2:00	48	6751	141	Tree related-tree broken	Tree	Remove		I
5128353	A45002	09/14/2015	23:51	09/15/2015	5:54	2	726	363	Underground equipment	Underground Secondary	Repair	Replace - Same Size	I
5128337	B80004	09/15/2015	2:01	09/15/2015	7:04	12	3630	302	Tree related-tree broken	Pole	Patrol/Test/Inspect	Replace - Same Size	I
5128339	A45002	09/15/2015	2:23	09/15/2015	5:07	1	164	164	Underground equipment	Fuse	Replace - Same Size	Replace - Same Size	I
5128349	L79158	09/15/2015	3:02	09/15/2015	4:53	23	2531	110	Underground equipment				IV
5128351	L79158	09/15/2015	3:05	09/15/2015	5:33	23	3397	147	Underground equipment	Underground Primary		Repair	IV
5128345	L79158	09/15/2015	3:10	09/15/2015	4:52	1	101	101	Underground equipment				IV
5128357	V74506	09/15/2015	5:23	09/15/2015	6:45	1	81	81	Overhead equipment				II
5128359	V74506	09/15/2015	6:24	09/15/2015	6:45	1	20	20	Overhead equipment	Fuse	Replace - Same Size		II
5128363	D70007	09/15/2015	6:32	09/15/2015	7:31	1	58	58	Overhead equipment	Fuse	Replace - Same Size		I
5128365	J58381	09/15/2015	6:38	09/15/2015	8:35	1	116	116	Overhead equipment	Jumper		Repair	III
5128387	D28123	09/15/2015	6:41	09/15/2015	13:09	16	1361	387	Overhead equipment	Fuse	Replace - Same Size		I
5128375	Y36559	09/15/2015	6:46	09/15/2015	7:20	2	67	33	Tree related-tree broken	Fuse	Repair	Replace - Same Size	IV
5128377	D67001	09/15/2015	6:47	09/15/2015	8:11	1	83	83	Animal related	Fuse	Repair		IV
5128385	K57211	09/15/2015	7:26	09/15/2015	8:47	1	80	80	Animal related	Transformer Fuse	Replace - Same Size		VI
5128389	Y96564	09/15/2015	7:32	09/15/2015	9:40	1	127	127	Animal related	Transformer Fuse	Replace - Same Size		IV
5128395	R48166	09/15/2015	7:52	09/15/2015	9:00	1	67	67	Unknown	Fuse			IV
5128397	P73182	09/15/2015	7:53	09/15/2015	17:48	1	594	594	Overhead equipment	Overhead Secondary	Replace - Same Size		VI
5128399	U64518	09/15/2015	7:57	09/15/2015	10:07	1	129	129	Tree related-tree broken	Lightning Arrestor	Replace - Same Size		II
5128401	K46388	09/15/2015	8:10	09/15/2015	8:50	1	39	39	Animal related	Fuse	Replace - Same Size		V
5128407	U09517	09/15/2015	8:33	09/15/2015	10:15	1	101	101	Overhead equipment	Overhead Service	Repair		II
5128409	J84124	09/15/2015	8:37	09/15/2015	9:48	3	213	71	Animal related	Transformer Fuse	Replace - Same Size		VI
5128419	Z19547	09/15/2015	9:00	09/15/2015	10:10	1	69	69	Animal related	Transformer Fuse	Replace - Same Size		IV
5128437	R93350	09/15/2015	9:19	09/15/2015	10:17	1	57	57	Overhead equipment	Fuse	Replace - Same Size		V
5128445	M07236	09/15/2015	9:40	09/15/2015	10:38	1	57	57	Unknown	Transformer Fuse			III
5128449	K32915	09/15/2015	9:45	09/15/2015	9:56	1	10	10	Animal related	Fuse			VI
5128451	H06135	09/15/2015	9:45	09/15/2015	11:54	24	3097	129	Underground equipment	Underground Primary		Repair	IV
5128481	R93351	09/15/2015	9:58	09/15/2015	12:46	2	336	168	Overhead equipment	Disconnect Switch	Patrol/Test/Inspect	Replace - Same Size	V
5128467	F10001	09/15/2015	10:12	09/15/2015	11:30	8	620	77	Animal related	Underground Primary	Replace - Same Size	Patrol/Test/Inspect	III

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5128483	H06135	09/15/2015	11:02	09/15/2015	11:11	14	125	8	Underground equipment				IV
5128497	X99538	09/15/2015	11:30	09/15/2015	13:06	1	95	95	Animal related	Transformer Fuse			IV
5128499	C10002	09/15/2015	11:34	09/15/2015	12:58	1	83	83	Animal related	Fuse	Replace - Same Size		III
5128511	S66595	09/15/2015	12:16	09/15/2015	12:49	1	32	32	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	VI
5128531	J06168	09/15/2015	13:09	09/15/2015	14:15	1	65	65	Overhead equipment				I
5128573	H07106	09/15/2015	13:38	09/15/2015	17:12	3	641	213	Overhead equipment	Recloser		Replace - Same Size	IV
5128565	C36002	09/15/2015	14:00	09/15/2015	14:51	1	50	50	Overhead equipment	Fuse	Replace - Same Size		III
5128567	C36002	09/15/2015	14:02	09/15/2015	14:48	1	45	45	Animal related	Fuse	Replace - Same Size		III
5128571	L11244	09/15/2015	14:09	09/15/2015	16:20	1	130	130	Tree related-tree contact	Overhead Service	Repair		III
5128581	Y86593	09/15/2015	14:14	09/15/2015	15:40	1	85	85	Overhead equipment	Fuse	Replace - Same Size		IV
5128593	P71830	09/15/2015	14:30	09/15/2015	17:15	1	164	164	Tree related-tree contact	Overhead Service	Repair		V
5128601	U93563	09/15/2015	15:01	09/15/2015	16:35	1	93	93	Overhead equipment	Transformer Fuse	Replace - Same Size	Replace - Same Size	II
5128633	315106	09/15/2015	15:27	09/15/2015	17:32	9	1118	124	Public	Overhead Primary	Replace - Same Size	Replace - Same Size	V
5128657	A56013	09/15/2015	16:30	09/15/2015	17:54	1	83	83	Overhead equipment	Meter			I
5128683	P69174	09/15/2015	17:40	09/15/2015	21:45	1	244	244	Overhead equipment	Overhead Transformer	Replace - Same Size		III
5128693	M49410	09/15/2015	18:42	09/15/2015	21:54	7	1344	192	Public	Underground Transformer	Disconnect	Replace - Same Size	V
5128707	M40117	09/15/2015	18:59	09/15/2015	20:36	469	45178	96	Underground equipment	Disconnect Switch	Switch/Reset		I
5128757	R04412	09/15/2015	19:28	09/15/2015	23:00	1	211	211	Overhead equipment	Overhead Service			V
5128771	HC9327	09/15/2015	21:59	09/15/2015	23:11	1	71	71	Animal related	Transformer Fuse	Replace - Same Size		VI
5128773	S61530	09/15/2015	22:01	09/16/2015	1:03	10	1818	181	Underground equipment	Fuse	Patrol/Test/Inspect		VI
5128787	Q28141	09/16/2015	2:29	09/16/2015	2:34	1	4	4	Overhead equipment				VI
5128793	B84003	09/16/2015	3:12	09/16/2015	9:20	14	4390	367	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
5128797	A17025	09/16/2015	5:39	09/17/2015	7:00	1	1520	1520	Public	Overhead Service	Disconnect	Reconnect	I
5128799	N60181	09/16/2015	6:40	09/16/2015	7:52	1	71	71	Animal related	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	I
5128805	J34357	09/16/2015	7:15	09/16/2015	9:06	56	6194	110	Overhead equipment	Fuse	Patrol/Test/Inspect	Replace - New Size	V
5128807	Y35513	09/16/2015	7:16	09/16/2015	7:35	1	18	18	Animal related	Fuse	Repair	Replace - Same Size	IV
5128809	S07536	09/16/2015	7:26	09/16/2015	8:50	3	249	83	Animal related	Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
5128883	D69006	09/16/2015	7:29	09/16/2015	11:57	2	536	268	Underground equipment	Underground Primary	Repair	Repair	I
5128813	L93135	09/16/2015	7:30	09/16/2015	8:05	1	34	34	Animal related	Transformer Fuse			VI
5128815	K80381	09/16/2015	7:33	09/16/2015	8:44	1	70	70	Animal related	Fuse	Repair		IV
5128821	HA5432	09/16/2015	7:43	09/16/2015	9:00	1	76	76	Animal related	Fuse	Replace - Same Size		V
5128831	M05360	09/16/2015	8:19	09/16/2015	9:20	1	60	60	Overhead equipment	Fuse	Replace - Same Size		V
5128811	D69006	09/16/2015	8:22	09/16/2015	9:39	1	76	76	Underground equipment	Fuse	Patrol/Test/Inspect	Replace - Same Size	I
5128839	N05172	09/16/2015	8:38	09/16/2015	9:05	1	26	26	Overhead equipment	Fuse	Replace - Same Size		I
5128909	M37191	09/16/2015	8:55	09/16/2015	11:17	10	1419	141	Overhead equipment				I
5128853	M37191	09/16/2015	8:55	09/16/2015	11:17	296	42008	141	Overhead equipment	Recloser			I
5128869	T22508	09/16/2015	9:20	09/16/2015	10:00	1	39	39	Overhead equipment	Transformer Fuse	Replace - Same Size		VI
5128891	M42107	09/16/2015	9:58	09/16/2015	12:06	47	5971	127	Animal related	Fuse	Repair	Replace - Same Size	I
5128893	M42107	09/16/2015	9:59	09/16/2015	12:06	10	1268	126	Animal related	Fuse	Repair	Replace - Same Size	I
5128911	A91001	09/16/2015	10:23	09/16/2015	13:48	1	204	204	Public	Underground Service	Patrol/Test/Inspect	Repair	I
5128917	K76545	09/16/2015	10:38	09/16/2015	11:54	4	303	75	Overhead equipment	Insulator	Replace - Same Size	Replace - Same Size	IV
5128921	L12128	09/16/2015	10:46	09/16/2015	12:11	1	84	84	Underground equipment	Underground Service	Repair		III
5128925	B00002	09/16/2015	10:50	09/16/2015	12:07	36	2770	76	Underground equipment	Underground Primary	Repair	Repair	I
5128939	S28551	09/16/2015	10:53	09/16/2015	12:40	1	106	106	Animal related	Overhead Transformer	Repair		VI
5128941	S28551	09/16/2015	10:56	09/16/2015	12:35	1	98	98	Animal related	Overhead Transformer	Repair		VI
5128943	M41113	09/16/2015	11:02	09/16/2015	11:27	1	24	24	Overhead equipment				I
5128953	D53002	09/16/2015	11:17	09/16/2015	13:15	1	117	117	Public	Underground Secondary	Repair		I
5128955	S16502	09/16/2015	11:25	09/16/2015	11:53	7	189	27	Overhead equipment	Overhead Primary	Replace - Same Size		VI
5128957	R58961	09/16/2015	11:42	09/16/2015	13:50	5	639	127	Animal related	Transformer Fuse	Replace - Same Size		IV
5128963	M41113	09/16/2015	11:51	09/16/2015	12:41	1	49	49	Overhead equipment	Overhead Service	Repair	Replace - Same Size	I
5128969	C65001	09/16/2015	12:10	09/16/2015	13:31	1	80	80	Overhead equipment	Connector	Replace - Same Size		III
5128977	Q32170	09/16/2015	12:19	09/16/2015	13:47	1	87	87	Overhead equipment	Connector	Replace - Same Size	Repair	I
5128983	X86543	09/16/2015	12:35	09/16/2015	13:45	1	69	69	Overhead equipment	Transformer Fuse			IV
5129017	P20930	09/16/2015	13:52	09/16/2015	15:40	1	107	107	Overhead equipment	Fuse		Patrol/Test/Inspect	VI
5129039	R20501	09/16/2015	14:41	09/16/2015	16:42	1	120	120	Animal related	Transformer Fuse	Replace - Same Size		IV
5129047	D36001	09/16/2015	14:54	09/16/2015	15:22	1	27	27	Unknown	Fuse	Repair	Replace - Same Size	I

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5129057	M04365	09/16/2015	15:28	09/16/2015	17:00	63	5734	91	Tree related-tree broken	Tree	Patrol/Test/Inspect		V
5129061	D88002	09/16/2015	15:29	09/16/2015	17:45	1	135	135	Overhead equipment	Disconnect Switch	Replace - Same Size		I
5129075	M04365	09/16/2015	16:35	09/16/2015	19:29	1	173	173	Tree related-tree broken	Tree	Trim	Trim	V
5129079	Q27186	09/16/2015	17:12	09/16/2015	17:47	3	104	34	Overhead equipment				VI
5129083	341002	09/16/2015	17:18	09/16/2015	19:05	1	106	106	Overhead equipment	Overhead Service	Repair		VI
5129095	V36001	09/16/2015	17:58	09/16/2015	21:54	58	13643	235	Underground equipment	Underground Primary	Repair		II
5129097	K89141	09/16/2015	17:59	09/16/2015	18:45	7	315	45	Overhead equipment	Overhead Transformer	Switch/Reset		III
5129101	M53312	09/16/2015	18:14	09/16/2015	20:07	50	5603	112	Overhead equipment	Fuse	Repair		V
5129107	R99180	09/16/2015	18:44	09/16/2015	19:57	1	72	72	Overhead equipment	Fuse	Repair		IV
5129109	N74-UNIT-5	09/16/2015	18:46	09/16/2015	21:20	943	145363	154	Overhead equipment				I
5129161	N74-UNIT-4	09/16/2015	18:46	09/16/2015	21:20	803	124063	154	Overhead equipment	Other			I
5129169	T02543	09/16/2015	19:29	09/16/2015	21:05	1	95	95	Other	Meter	Replace - Same Size	Replace - Same Size	VI
5129173	L23146	09/16/2015	19:51	09/16/2015	20:50	86	4989	58	Unknown	Fuse	Replace - Same Size		III
5129177	L23146	09/16/2015	19:57	09/16/2015	20:50	14	737	52	Unknown	Fuse	Replace - Same Size		III
5129181	Q32171	09/16/2015	20:42	09/17/2015	2:00	8	2538	317	Overhead equipment	Overhead Transformer	Replace - Same Size	Patrol/Test/Inspect	I
5129185	P20930	09/16/2015	20:47	09/17/2015	0:10	3	608	202	Overhead equipment	Overhead Transformer	Repair	Replace - Same Size	VI
5129191	Z17503	09/16/2015	21:00	09/16/2015	22:05	1	64	64	Animal related	Transformer Fuse	Replace - Same Size		IV
5129203	B19001	09/16/2015	22:42	09/17/2015	3:45	30	9084	302	Underground equipment	Underground Primary	Repair	Repair	I
5129205	V34002	09/16/2015	22:49	09/17/2015	2:23	1	213	213	Overhead equipment	Overhead Service	Repair		II
5129207	D96001	09/16/2015	22:51	09/16/2015	23:44	1	52	52	Animal related	Fuse	Replace - Same Size		I
5129225	X99538	09/17/2015	0:12	09/17/2015	6:45	30	11777	392	Public	Pole	Repair	Replace - Same Size	IV
5129227	V74001	09/17/2015	1:14	09/17/2015	2:04	1	49	49	Public				II
5129231	B84006	09/17/2015	3:08	09/17/2015	4:13	614	39910	65	Animal related	Disconnect Switch	Remove		I
5129305	B84002	09/17/2015	3:10	09/17/2015	4:08	2113	122511	57	Animal related	Disconnect Switch	Remove		I
5129307	B84001	09/17/2015	3:16	09/17/2015	4:23	1	66	66	Animal related	Disconnect Switch	Remove		I
5129311	B84006	09/17/2015	4:27	09/17/2015	5:57	1	89	89	Animal related	Disconnect Switch	Remove		I
5129313	N05173	09/17/2015	4:48	09/17/2015	6:23	9	852	94	Animal related	Fuse	Replace - Same Size		I
5129317	X99538	09/17/2015	5:24	09/17/2015	6:50	1	85	85	Overhead equipment	Meter	Patrol/Test/Inspect		IV
5129319	Z43549	09/17/2015	5:33	09/17/2015	7:15	1	101	101	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
5129321	Q74148	09/17/2015	5:37	09/17/2015	10:00	1	262	262	Overhead equipment	Overhead Transformer		Replace - Urgent	IV
5129327	R10943	09/17/2015	7:05	09/17/2015	8:32	1	86	86	Animal related	Fuse	Replace - Same Size	Repair	VI
5129329	R10943	09/17/2015	7:07	09/17/2015	8:33	1	85	85	Animal related	Fuse	Replace - Same Size	Repair	VI
5129331	R10943	09/17/2015	7:13	09/17/2015	8:32	1	78	78	Animal related	Fuse	Replace - Same Size	Repair	VI
5129333	N50331	09/17/2015	7:17	09/17/2015	8:22	14	905	64	Animal related	Fuse	Replace - Same Size		II
5129337	Q54908	09/17/2015	7:25	09/17/2015	9:28	1	122	122	Public	Overhead Primary	Repair		VI
5129339	V69558	09/17/2015	7:29	09/17/2015	9:13	1	103	103	Animal related	Fuse			II
5129345	Z11536	09/17/2015	7:51	09/17/2015	8:30	10	380	38	Animal related	Transformer Fuse	Repair		IV
5129347	M09143	09/17/2015	8:08	09/17/2015	9:24	32	2403	75	Animal related	Fuse	Replace - Same Size		VI
5129349	M09175	09/17/2015	8:10	09/17/2015	9:24	7	517	73	Animal related	Fuse	Replace - Same Size		VI
5129363	M61302	09/17/2015	8:11	09/17/2015	9:34	34	2800	82	Overhead equipment	Fuse	Replace - Same Size		V
5129355	K15205	09/17/2015	8:11	09/17/2015	9:06	1	54	54	Animal related	Transformer Fuse	Repair	Repair	VI
5129365	D89002	09/17/2015	8:18	09/17/2015	12:16	77	18366	238	Public	Underground Primary	Repair	Replace - Same Size	I
5129379	D89002	09/17/2015	8:35	09/17/2015	10:50	40	5285	134	Underground equipment	Underground Primary			I
5129387	R68900	09/17/2015	8:39	09/17/2015	9:44	1	64	64	Overhead equipment	Connector	Replace - Same Size		I
5129409	Q27185	09/17/2015	8:56	09/17/2015	10:03	1	66	66	Tree related-tree contact	Overhead Secondary	Replace - Same Size		VI
5129431	S36571	09/17/2015	9:22	09/17/2015	10:48	337	29049	86	Animal related	Substation Breaker			VI
5129445	M09175	09/17/2015	9:31	09/17/2015	10:08	7	252	36	Animal related	Fuse	Replace - Same Size		VI
5129527	S61529	09/17/2015	9:43	09/17/2015	10:09	1	25	25	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	VI
5129575	D32211	09/17/2015	9:56	09/17/2015	11:35	1	99	98	Underground equipment	Underground Primary		Repair	I
5129591	C70004	09/17/2015	10:14	09/17/2015	14:14	1	239	239	Overhead equipment	Overhead Primary	Switch/Reset	Repair	III
5129601	T05539	09/17/2015	10:25	09/17/2015	11:50	1	84	84	Overhead equipment	Transformer Fuse			VI
5129607	P52306	09/17/2015	10:28	09/17/2015	11:44	1	75	75	Overhead equipment	Overhead Service	Tie/Tighten		IV
5129609	V45526	09/17/2015	10:28	09/17/2015	12:43	10	1343	134	Overhead equipment	Overhead Secondary	Repair		II
5129719	S27599	09/17/2015	10:32	09/17/2015	16:56	9	2944	383	Underground equipment	Underground Primary	Repair	Replace - Same Size	VI
5129681	K69117	09/17/2015	10:50	09/17/2015	13:05	43	5799	134	Unknown	Fuse	Repair		IV
5129631	V21500	09/17/2015	10:51	09/17/2015	12:00	4	273	68	Animal related	Transformer Fuse	Replace - Same Size		II

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5129637	H22349	09/17/2015	10:56	09/17/2015	13:13	1	136	136	Overhead equipment				V
5129653	S47589	09/17/2015	11:07	09/17/2015	11:40	1	32	32	Animal related	Transformer Fuse	Replace - Same Size		VI
5129657	V23530	09/17/2015	11:15	09/17/2015	16:15	8	2396	299	Public	Pole	Replace - Same Size		II
5129659	B93001	09/17/2015	11:16	09/17/2015	12:30	29	2143	73	Animal related	Fuse	Replace - Same Size		I
5129667	V23530	09/17/2015	11:28	09/17/2015	12:44	1	75	75	Public	Fuse	Replace - Same Size		II
5129669	D32211	09/17/2015	11:34	09/17/2015	15:16	1	222	222	Underground equipment	Underground Primary	Repair	Repair	I
5129699	N50331	09/17/2015	12:12	09/17/2015	18:13	56	15299	361	Public	Pole	Repair	Replace - Same Size	II
5129691	B19002	09/17/2015	12:31	09/17/2015	20:13	4	1844	461	Underground equipment	Underground Primary		Repair	I
5129695	U42512	09/17/2015	12:38	09/17/2015	14:30	1	111	111	Overhead equipment	Transformer Fuse	Replace - Same Size	Replace - Same Size	II
5129705	J56341	09/17/2015	12:42	09/17/2015	14:18	41	3918	95	Tree related-tree broken	Overhead Primary	Repair	Repair	III
5129731	Y89535	09/17/2015	13:20	09/17/2015	13:52	11	348	31	Overhead equipment	Transformer Fuse	Repair	Replace - Same Size	IV
5129735	346004	09/17/2015	13:25	09/17/2015	15:22	1	116	116	Tree related-tree contact	Overhead Secondary	Repair		VI
5129741	HB5890	09/17/2015	13:26	09/17/2015	14:44	1	77	77	Animal related	Fuse	Replace - Same Size		I
5129747	K39154	09/17/2015	13:36	09/17/2015	14:51	1	74	74	Overhead equipment	Overhead Service	Disconnect		III
5129753	J88166	09/17/2015	13:41	09/17/2015	15:15	70	6610	94	Underground equipment	Underground Primary			VI
5129761	Y12559	09/17/2015	13:50	09/17/2015	14:45	1	54	54	Animal related	Transformer Fuse	Repair		IV
5129763	N54107	09/17/2015	13:54	09/17/2015	14:28	1	33	33	Overhead equipment	Fuse	Replace - Same Size		II
5129789	B68004	09/17/2015	14:39	09/17/2015	23:25	1	525	525	Overhead equipment	Overhead Service			III
5129793	N50331	09/17/2015	14:45	09/17/2015	16:30	1	104	104	Public	Pole	Replace - New Size		II
5129795	R33126	09/17/2015	14:46	09/17/2015	17:25	1	158	158	Overhead equipment				I
5129797	R33126	09/17/2015	14:48	09/17/2015	17:36	1	167	167	Overhead equipment				I
5129801	R33126	09/17/2015	14:49	09/17/2015	17:38	1	168	168	Overhead equipment				I
5129807	K39153	09/17/2015	14:57	09/17/2015	16:16	1	78	78	Overhead equipment	Transformer Fuse	Replace - Same Size		III
5129809	T28562	09/17/2015	14:59	09/17/2015	18:35	1	215	215	Overhead equipment	Overhead Secondary			VI
5129821	X78536	09/17/2015	15:23	09/17/2015	15:54	1	30	30	Animal related	Transformer Fuse	Replace - Same Size		IV
5129823	C10002	09/17/2015	15:31	09/18/2015	5:32	1	841	841	Underground equipment	Underground Primary	Repair		III
5129845	U31598	09/17/2015	15:35	09/17/2015	16:20	124	5464	44	Overhead equipment	Fuse	Replace - Same Size		II
5129853	R33126	09/17/2015	15:51	09/17/2015	17:25	1	93	93	Overhead equipment				I
5129855	V14579	09/17/2015	15:51	09/17/2015	22:31	1	399	399	Public	Pole		Replace - New Size	II
5129869	R33126	09/17/2015	16:22	09/17/2015	17:25	1	62	62	Overhead equipment				I
5129873	V23530	09/17/2015	16:23	09/17/2015	18:12	1	108	108	Underground equipment	Underground Primary		Repair	II
5129875	X88510	09/17/2015	16:28	09/17/2015	17:46	1	77	77	Animal related	Transformer Fuse	Replace - Same Size		IV
5129887	R33126	09/17/2015	16:59	09/17/2015	17:25	1	25	25	Overhead equipment				I
5129891	S31532	09/17/2015	16:59	09/17/2015	20:33	1	213	213	Unknown				VI
5129893	D90002	09/17/2015	17:05	09/17/2015	20:38	17	3624	213	Public	Pole	Repair	Replace - Same Size	III
5129899	U30003	09/17/2015	17:35	09/17/2015	20:10	4	616	154	Overhead equipment	Overhead Service	Repair		II
5129913	B45005	09/17/2015	18:32	09/17/2015	19:48	17	1282	75	Overhead equipment	Fuse	Replace - Same Size	Patrol/Test/Inspect	I
5129919	M49411	09/17/2015	19:27	09/17/2015	21:22	1	114	114	Underground equipment	Underground Primary	Disconnect		V
5129921	B93002	09/17/2015	19:30	09/17/2015	22:04	1	153	153	Unknown	Transformer Fuse	Replace - Same Size		I
5129923	M49411	09/17/2015	19:34	09/18/2015	0:56	11	3546	322	Underground equipment	Underground Primary		Repair	V
5129925	K01240	09/17/2015	19:37	09/17/2015	23:30	1	232	232	Underground equipment	Underground Service	Disconnect	Repair	VI
5129927	X13001	09/17/2015	19:43	09/17/2015	21:53	1	129	129	Overhead equipment	Fuse	Repair		IV
5129929	J76804	09/17/2015	20:03	09/17/2015	22:13	1	129	129	Animal related	Transformer Fuse	Repair		V
5129935	K89143	09/17/2015	20:49	09/18/2015	1:52	10	686	303	Overhead equipment	Pole		Replace - Same Size	III
5129939	D41002	09/17/2015	21:38	09/18/2015	1:41	2	485	242	Underground equipment	Underground Transformer	Patrol/Test/Inspect	Patrol/Test/Inspect	I
5129943	X13001	09/17/2015	22:48	09/18/2015	0:01	1	72	72	Overhead equipment	Fuse	Repair	Replace - New Size	IV
5129953	K80388	09/17/2015	23:56	09/18/2015	2:50	48	8359	174	Underground equipment	Underground Primary	Switch/Reset	Repair	IV
5129963	347003	09/18/2015	0:55	09/18/2015	2:15	1	79	79	Public	Meter		Replace - Same Size	VI
5129969	J15302	09/18/2015	2:32	09/18/2015	5:13	40	6443	161	Overhead equipment	Recloser			I
5129967	N94180	09/18/2015	2:36	09/18/2015	4:35	1	118	118	Weather	Fuse	Repair	Repair	I
5129973	J15302	09/18/2015	3:02	09/18/2015	5:13	1	130	130	Overhead equipment	Recloser			I
5129977	D39001	09/18/2015	3:15	09/18/2015	5:00	1	104	104	Weather	Fuse	Replace - Same Size		I
5129979	R16511	09/18/2015	3:33	09/18/2015	5:55	1	141	141	Weather	Transformer Fuse	Repair		I
5130013	D01001	09/18/2015	3:37	09/18/2015	7:02	23	4697	204	Weather	Fuse	Replace - Same Size		I
5130017	A17025	09/18/2015	3:59	09/18/2015	12:57	58	11380	538	Weather	Overhead Transformer	Replace - Same Size	Repair	I
5129995	A50001	09/18/2015	4:13	09/18/2015	6:00	175	18782	107	Underground equipment	Underground Primary	Replace - Same Size		I

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5130003	B93002	09/18/2015	4:19	09/18/2015	7:04	4	658	164	Overhead equipment	Fuse	Replace - Same Size		I
5130005	D32212	09/18/2015	4:31	09/18/2015	4:48	3	50	16	Underground equipment				I
5130011	U06551	09/18/2015	5:06	09/18/2015	6:25	1	78	78	Animal related	Transformer Fuse	Replace - Same Size		II
5130021	N58144	09/18/2015	5:50	09/18/2015	7:58	1	127	127	Tree related-tree broken	Overhead Service	Repair	Reconnect	I
5130037	B54004	09/18/2015	6:13	09/18/2015	7:27	24	1761	73	Unknown	Fuse	Replace - Same Size		I
5130039	M61302	09/18/2015	6:19	09/18/2015	8:42	1	142	142	Animal related	Fuse	Replace - Same Size		V
5130043	Y55555	09/18/2015	6:25	09/18/2015	7:45	1	79	79	Weather	Disconnect Switch	Replace - Same Size		IV
5130047	N05173	09/18/2015	6:34	09/18/2015	7:20	1	45	45	Weather	Transformer Fuse	Repair	Repair	I
5130049	Y89004	09/18/2015	6:35	09/18/2015	8:22	1	106	106	Public	Pole	Repair	Replace - Same Size	IV
5130051	R20501	09/18/2015	6:36	09/18/2015	9:25	1	168	168	Weather	Transformer Fuse	Replace - Same Size		IV
5130053	J11015	09/18/2015	6:38	09/18/2015	15:44	1	545	545	Weather				IV
5130055	N94180	09/18/2015	6:41	09/18/2015	7:41	1	59	59	Weather	Fuse	Replace - Same Size		I
5130057	F22001	09/18/2015	6:43	09/18/2015	8:41	1	117	117	Weather	Overhead Primary			IV
5130061	Y82587	09/18/2015	6:50	09/18/2015	7:56	1	65	65	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
5130063	K71821	09/18/2015	6:51	09/18/2015	8:53	43	5234	121	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	IV
5130129	R20501	09/18/2015	6:51	09/18/2015	10:00	1	188	188	Weather	Overhead Primary	Repair		IV
5130065	K71821	09/18/2015	6:57	09/18/2015	8:49	13	1451	111	Underground equipment	Underground Primary	Repair		IV
5130067	P52305	09/18/2015	7:01	09/18/2015	10:05	1	183	183	Weather	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	IV
5130131	R20501	09/18/2015	7:04	09/18/2015	8:37	1	92	92	Weather	Recloser	Switch/Reset		IV
5130071	U61572	09/18/2015	7:06	09/18/2015	8:25	1	78	78	Overhead equipment	Fuse	Replace - Same Size		II
5130073	M25143	09/18/2015	7:06	09/18/2015	10:45	46	10040	218	Overhead equipment	Overhead Primary	Repair		IV
5130077	R20501	09/18/2015	7:18	09/18/2015	8:18	1	59	59	Weather	Recloser	Switch/Reset		IV
5130081	U60518	09/18/2015	7:23	09/18/2015	10:40	1	196	196	Weather	Overhead Transformer	Replace - New Size		II
5130085	R06211	09/18/2015	7:38	09/18/2015	8:22	1	43	43	Overhead equipment	Fuse	Replace - Same Size		II
5130087	J11260	09/18/2015	7:39	09/18/2015	15:44	1	484	484	Weather	Overhead Primary			IV
5130315	D69005	09/18/2015	7:41	09/18/2015	12:07	53	14128	266	Underground equipment	Underground Secondary	Repair	Replace - Same Size	I
5130093	Z04520	09/18/2015	7:43	09/18/2015	13:17	1	333	333	Overhead equipment	Pole	Replace - Same Size	Repair	IV
5130101	J18267	09/18/2015	7:55	09/18/2015	9:16	1	80	80	Overhead equipment	Fuse	Replace - Same Size		VI
5130107	M45211	09/18/2015	8:02	09/18/2015	12:44	74	20850	281	Weather	Pole			IV
5130109	R71285	09/18/2015	8:08	09/18/2015	9:00	1	51	51	Animal related	Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
5130113	V49541	09/18/2015	8:11	09/18/2015	9:25	1	73	73	Unknown	Overhead Primary		Replace - Same Size	II
5130115	B25001	09/18/2015	8:11	09/18/2015	10:45	1	153	153	Overhead equipment	Recloser	Switch/Reset	Repair	I
5130119	M40132	09/18/2015	8:15	09/18/2015	9:19	1	63	63	Tree related-tree broken	Overhead Service	Repair	Replace - Same Size	I
5130123	K31124	09/18/2015	8:20	09/18/2015	10:27	1	126	126	Overhead equipment	Disconnect Switch	Repair		I
5130125	P12290	09/18/2015	8:21	09/18/2015	8:41	5	98	19	Animal related	Fuse	Replace - Same Size		V
5130127	N50332	09/18/2015	8:21	09/18/2015	10:40	4	552	138	Animal related	Transformer Fuse	Replace - Same Size		II
5130135	K52401	09/18/2015	8:23	09/18/2015	9:10	57	2637	46	Animal related	Fuse	Replace - Same Size	Replace - Same Size	V
5130141	L12127	09/18/2015	8:24	09/18/2015	9:43	23	1808	78	Underground equipment	Underground Primary		Repair	III
5130153	K91117	09/18/2015	8:42	09/18/2015	9:31	24	1170	48	Weather	Fuse	Replace - Same Size		III
5130151	R65451	09/18/2015	8:52	09/18/2015	10:27	1	94	94	Weather	Transformer Fuse	Replace - Same Size		IV
5130155	N50331	09/18/2015	9:07	09/18/2015	10:39	1	91	91	Animal related	Fuse	Replace - Same Size		II
5130159	Q83171	09/18/2015	9:12	09/18/2015	9:49	6	219	36	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	VI
5130161	313134	09/18/2015	9:13	09/18/2015	9:33	1	19	19	Overhead equipment	Customer Equipment	Advise Customer		V
5130163	313135	09/18/2015	9:13	09/18/2015	9:36	1	22	22	Overhead equipment	Other	Advise Customer		V
5130165	J80807	09/18/2015	9:17	09/18/2015	13:10	1	233	232	Overhead equipment	Overhead Transformer	Replace - Same Size	Replace - Same Size	V
5130167	N05172	09/18/2015	9:19	09/18/2015	10:20	1	60	60	Animal related	Fuse	Replace - Same Size		I
5130171	B25001	09/18/2015	9:24	09/18/2015	13:37	4	284	252	Overhead equipment	Recloser	Replace - Same Size	Repair	I
5130175	M04365	09/18/2015	9:32	09/18/2015	10:14	1	41	41	Animal related	Fuse	Replace - Same Size		V
5130183	D88002	09/18/2015	9:37	09/18/2015	12:23	1	165	165	Underground equipment	Underground Primary	Switch/Reset	Repair	I
5130191	315109	09/18/2015	9:38	09/18/2015	10:21	104	4440	42	Unknown				V
5130193	L74191	09/18/2015	9:38	09/18/2015	10:02	1	23	23	Overhead equipment	Fuse	Replace - Same Size		IV
5130195	313134	09/18/2015	9:38	09/18/2015	10:04	161	4068	25	Unknown				V
5130199	V41533	09/18/2015	9:39	09/18/2015	10:02	1	22	22	Overhead equipment	Lightning Arrestor	Replace - Same Size		II
5130201	K91117	09/18/2015	9:46	09/18/2015	10:18	9	287	31	Animal related	Fuse	Replace - Same Size	Repair	III
5130217	342001	09/18/2015	9:55	09/18/2015	11:21	1	85	85	Public	Overhead Service	Repair		VI
5130221	D69005	09/18/2015	10:02	09/18/2015	12:03	103	12476	121	Underground equipment	Underground Secondary			I

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5130321	D69005	09/18/2015	10:08	09/18/2015	11:43	13	1222	94	Underground equipment	Underground Primary	Repair	Replace - Same Size	I
5130237	IP9009	09/18/2015	10:12	09/18/2015	12:40	1	147	147	Public	Overhead Service	Replace - New Size		VI
5130243	P27-UNIT-1	09/18/2015	10:26	09/18/2015	11:25	1	58	58	Other	Transformer Fuse	Repair		I
5130319	D69005	09/18/2015	10:33	09/18/2015	11:43	25	1725	69	Underground equipment	Underground Primary	Repair	Replace - Same Size	I
5130317	D69005	09/18/2015	10:33	09/18/2015	11:43	1	69	69	Underground equipment	Underground Primary	Repair	Replace - Same Size	I
5130261	R02120	09/18/2015	10:41	09/18/2015	12:52	1	130	130	Overhead equipment	Customer Equipment	Repair	Repair	VI
5130311	D69005	09/18/2015	10:48	09/18/2015	11:43	1	54	54	Underground equipment	Underground Primary	Repair	Replace - Same Size	I
5130269	M47802	09/18/2015	10:50	09/18/2015	11:45	1	54	54	Animal related	Fuse	Repair	Repair	V
5130271	L11242	09/18/2015	10:51	09/18/2015	14:46	1	234	234	Tree related-tree broken	Overhead Service	Raise		III
5130273	P47123	09/18/2015	10:51	09/18/2015	12:39	9	969	107	Overhead equipment	Recloser	Switch/Reset		I
5130279	J80807	09/18/2015	10:59	09/18/2015	12:49	1	109	109	Overhead equipment	Overhead Transformer	Repair	Repair	V
5130281	D28124	09/18/2015	11:02	09/18/2015	12:37	1	95	94	Overhead equipment	Disconnect Switch	Replace - Same Size		I
5130287	U35554	09/18/2015	11:15	09/18/2015	11:45	1	29	29	Other				II
5130307	R41131	09/18/2015	11:56	09/18/2015	16:11	1	254	254	Underground equipment	Underground Service	Replace - Same Size	Replace - Same Size	VI
5130337	V10551	09/18/2015	12:25	09/18/2015	13:30	11	708	64	Unknown	Other			II
5130341	V24583	09/18/2015	12:39	09/18/2015	14:47	1	127	127	Animal related	Transformer Fuse	Repair	Replace - Same Size	II
5130347	V10551	09/18/2015	12:52	09/18/2015	13:30	1	37	37	Unknown	Other			II
5130363	Q32170	09/18/2015	13:02	09/18/2015	15:15	31	4092	132	Tree related-tree broken	Overhead Primary	Repair		I
5130359	V59561	09/18/2015	13:06	09/18/2015	13:45	1	38	38	Weather	Transformer Fuse	Replace - Same Size		II
5130373	D72001	09/18/2015	13:18	09/18/2015	14:20	1	61	61	Weather	Fuse	Replace - Same Size		I
5130377	V76526	09/18/2015	13:29	09/18/2015	16:35	6	1116	186	Tree related-tree contact	Fuse	Replace - Same Size	Replace - Same Size	II
5130379	V21500	09/18/2015	13:29	09/18/2015	15:00	7	632	90	Weather	Fuse	Replace - Same Size		II
5130393	Y68582	09/18/2015	13:42	09/18/2015	16:55	1	192	192	Overhead equipment	Overhead Service	Repair		IV
5130395	V10551	09/18/2015	13:45	09/18/2015	15:14	1	88	88	Other	Fuse	Replace - Same Size		II
5130397	V10551	09/18/2015	13:46	09/18/2015	14:38	11	564	51	Unknown	Fuse	Replace - Same Size		II
5130405	Q27185	09/18/2015	13:53	09/18/2015	17:14	1	200	200	Tree related-tree broken	Overhead Primary		Replace - Same Size	VI
5130407	P53341	09/18/2015	13:54	09/18/2015	14:24	1	29	29	Weather	Fuse	Patrol/Test/Inspect	Replace - Same Size	IV
5130411	L23146	09/18/2015	14:01	09/18/2015	19:51	1	349	349	Tree related-tree contact	Overhead Service	Repair		III
5130441	M45218	09/18/2015	14:38	09/18/2015	16:05	2	173	86	Overhead equipment				IV
5130443	B93002	09/18/2015	14:43	09/18/2015	15:29	1	45	45	Animal related	Fuse	Replace - Same Size		I
5130447	D36001	09/18/2015	14:46	09/18/2015	15:48	4	247	61	Animal related	Transformer Fuse	Replace - Same Size	Replace - Same Size	I
5130453	N35852	09/18/2015	14:57	09/18/2015	15:28	1	30	30	Overhead equipment	Overhead Service	Repair		V
5130459	R60552	09/18/2015	14:59	09/18/2015	16:08	1	68	68	Weather	Transformer Fuse	Replace - Same Size		IV
5130463	Q91175	09/18/2015	15:02	09/18/2015	19:20	1	257	257	Overhead equipment	Overhead Primary	Repair		I
5130465	G10001	09/18/2015	15:06	09/18/2015	16:23	14	1074	76	Overhead equipment				I
5130467	F10001	09/18/2015	15:09	09/18/2015	17:37	1	147	147	Weather	Other	Replace - Same Size	Patrol/Test/Inspect	III
5130471	R33127	09/18/2015	15:27	09/18/2015	16:45	1	77	77	Unknown	Fuse	Replace - Same Size		I
5130475	K82202	09/18/2015	15:32	09/19/2015	9:46	1	1093	1093	Overhead equipment	Overhead Transformer			III
5130489	H01194	09/18/2015	16:01	09/18/2015	17:10	1	68	68	Weather	Fuse	Replace - Same Size		III
5130499	B93002	09/18/2015	16:04	09/18/2015	23:45	4	1840	460	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
5130501	D48001	09/18/2015	16:05	09/18/2015	19:36	36	7590	210	Overhead equipment	Fuse	Patrol/Test/Inspect	Repair	I
5130515	A45003	09/18/2015	16:12	09/18/2015	19:20	1	187	187	Weather	Fuse	Replace - Same Size		I
5130521	D66002	09/18/2015	16:14	09/18/2015	19:19	1	184	184	Weather	Transformer Fuse	Replace - Same Size		IV
5130523	V24583	09/18/2015	16:14	09/18/2015	21:28	1	313	313	Underground equipment	Underground Secondary	Switch/Reset	Repair	II
5130527	R95520	09/18/2015	16:18	09/18/2015	18:30	4	525	131	Weather	Fuse	Replace - Same Size		I
5130541	J46184	09/18/2015	16:21	09/18/2015	17:17	69	2508	55	Overhead equipment	Overhead Transformer			III
5130535	D53001	09/18/2015	16:25	09/18/2015	17:14	1	48	48	Overhead equipment	Transformer Fuse	Replace - Same Size		I
5130539	B73001	09/18/2015	16:26	09/18/2015	18:09	1	102	102	Overhead equipment	Fuse	Replace - Same Size		I
5130663	B93001	09/18/2015	16:33	09/18/2015	21:05	14	3806	271	Unknown	Fuse	Replace - Same Size		I
5130549	Q11517	09/18/2015	16:38	09/18/2015	17:30	1	51	51	Weather	Fuse	Replace - Same Size		I
5130551	A45003	09/18/2015	16:41	09/18/2015	19:04	1	142	142	Overhead equipment	Fuse	Replace - Same Size		I
5130561	A97006	09/18/2015	16:43	09/18/2015	18:33	103	11247	109	Overhead equipment	Other	Patrol/Test/Inspect	Repair	I
5130567	P73182	09/18/2015	16:46	09/18/2015	18:14	1	87	87	Public	Overhead Service	Repair	Repair	VI
5130565	K65221	09/18/2015	16:46	09/19/2015	3:09	1	622	622	Weather	Overhead Transformer		Replace - Same Size	III
5130571	A45002	09/18/2015	16:47	09/18/2015	18:20	1	92	92	Public	Overhead Service	Repair		I
5130573	Q91175	09/18/2015	16:48	09/18/2015	20:46	2	475	237	Weather	Pole	Repair		I

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5130579	A97006	09/18/2015	16:57	09/18/2015	18:51	1	113	113	Overhead equipment				I
5130581	A97006	09/18/2015	16:58	09/18/2015	18:54	1	115	115	Overhead equipment				I
5130585	Q11517	09/18/2015	16:59	09/18/2015	17:30	1	30	30	Weather	Fuse	Replace - Same Size		I
5130587	Y05001	09/18/2015	17:01	09/18/2015	19:30	2	296	148	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
5130595	A85002	09/18/2015	17:14	09/18/2015	19:45	1	150	150	Overhead equipment	Transformer Fuse	Replace - Same Size		I
5130599	B38002	09/18/2015	17:14	09/18/2015	19:39	348	49869	145	Overhead equipment	Recloser	Replace - Same Size		I
5130601	P52306	09/18/2015	17:17	09/18/2015	18:27	7	488	69	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
5130633	J58380	09/18/2015	17:17	09/18/2015	20:40	45	9123	202	Overhead equipment	Pole		Replace - Same Size	III
5130605	J46184	09/18/2015	17:17	09/18/2015	18:15	2	114	57	Overhead equipment	Overhead Transformer			III
5130623	U32594	09/18/2015	17:22	09/18/2015	18:23	1	60	60	Overhead equipment	Transformer Fuse	Repair	Repair	II
5131039	J58380	09/18/2015	17:23	09/19/2015	6:07	8	6111	763	Overhead equipment	Pole	Repair		III
5130639	D48003	09/18/2015	17:27	09/18/2015	20:14	22	3652	166	Overhead equipment				I
5130697		09/18/2015	17:39	09/18/2015	18:58	17	1343	79	Overhead equipment				I
5130655	J97136	09/18/2015	17:40	09/18/2015	18:22	1	41	41	Overhead equipment	Overhead Service	Repair		VI
5131059	V65549	09/18/2015	17:41	09/18/2015	21:45	141	34340	243	Overhead equipment	Disconnect Switch	Repair		II
5131179	V65549	09/18/2015	17:43	09/18/2015	21:45	69	16664	241	Overhead equipment	Fuse	Replace - Same Size		II
5130671	B62002	09/18/2015	17:44	09/18/2015	20:31	14	2329	166	Overhead equipment	Disconnect Switch	Patrol/Test/Inspect	Replace - Same Size	I
5130685	D28123	09/18/2015	17:45	09/18/2015	19:27	123	12560	102	Overhead equipment	Fuse	Replace - Same Size		I
5130699	U10525	09/18/2015	17:47	09/18/2015	19:25	1	97	97	Overhead equipment	Transformer Fuse	Replace - Same Size	Patrol/Test/Inspect	II
5130703	D48001	09/18/2015	17:48	09/18/2015	22:38	6	1739	289	Weather	Fuse	Patrol/Test/Inspect	Repair	I
5130757	A97002	09/18/2015	18:01	09/18/2015	20:10	9	1161	129	Weather	Lightning Arrestor	Repair		I
5130731	K46388	09/18/2015	18:05	09/18/2015	21:28	21	3401	202	Underground equipment	Underground Primary		Repair	V
5130735	B84002	09/18/2015	18:07	09/18/2015	20:57	103	17548	170	Unknown	Fuse	Patrol/Test/Inspect	Repair	I
5130795	K91115	09/18/2015	18:22	09/19/2015	2:27	703	61432	485	Overhead equipment	Overhead Primary	Patrol/Test/Inspect	Repair	III
5130797	C36001	09/18/2015	18:35	09/19/2015	3:01	1	505	505	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	III
5130805	N93260	09/18/2015	18:38	09/18/2015	22:50	13	3276	252	Overhead equipment	Fuse			III
5130807	A97006	09/18/2015	18:43	09/19/2015	1:52	3	1286	428	Overhead equipment	Crossarm	Repair		I
5130823	D69002	09/18/2015	18:44	09/18/2015	21:09	460	66874	145	Underground equipment	Underground Primary			I
5130819	A97006	09/18/2015	18:47	09/18/2015	18:57	1	9	9	Overhead equipment				I
5130827	K30204	09/18/2015	18:50	09/18/2015	21:24	15	2301	153	Weather	Fuse	Replace - Same Size		III
5130829	K30204	09/18/2015	18:53	09/18/2015	21:05	22	2896	131	Weather	Fuse	Replace - Same Size		III
5130841	N72240	09/18/2015	19:07	09/19/2015	4:40	1	572	572	Weather	Overhead Transformer			III
5130861	K30205	09/18/2015	19:11	09/18/2015	21:45	49	7537	153	Weather	Recloser	Switch/Reset		III
5130851	X64501	09/18/2015	19:16	09/18/2015	22:20	57	10462	183	Overhead equipment	Overhead Primary	Repair		IV
5130857	X36550	09/18/2015	19:19	09/18/2015	20:31	14	1002	71	Weather	Fuse	Replace - Same Size		IV
5130859	J46183	09/18/2015	19:19	09/18/2015	23:18	1	238	238	Overhead equipment	Fuse			III
5130941	H01190	09/18/2015	19:26	09/18/2015	23:16	954	206002	229	Unknown	Substation Breaker	Switch/Reset		III
5131015	K65221	09/18/2015	19:47	09/18/2015	21:38	365	40525	111	Overhead equipment	Recloser	Replace - Same Size		III
5130999	Y39515	09/18/2015	19:51	09/18/2015	22:05	30	3994	133	Weather	Fuse	Patrol/Test/Inspect	Replace - Same Size	IV
5131005	V92540	09/18/2015	19:54	09/18/2015	21:10	1	76	75	Tree related-tree broken	Overhead Service	Repair	Patrol/Test/Inspect	II
5131009	M18131	09/18/2015	19:55	09/19/2015	0:01	1	245	245	Weather	Fuse	Replace - Same Size		III
5131017	M18217	09/18/2015	20:02	09/18/2015	23:21	1	198	198	Weather				III
5131019	N93260	09/18/2015	20:02	09/19/2015	8:18	1	735	735	Overhead equipment	Overhead Transformer			III
5131023	M21133	09/18/2015	20:05	09/18/2015	22:31	1	145	145	Overhead equipment	Fuse	Replace - Same Size		VI
5131025	M18131	09/18/2015	20:13	09/19/2015	0:02	1	228	228	Weather	Fuse	Replace - Same Size		III
5131027	E10001	09/18/2015	20:13	09/19/2015	9:39	1	805	805	Overhead equipment	Transformer Fuse	Replace - Same Size		III
5131031	C15002	09/18/2015	20:19	09/18/2015	22:00	1	100	100	Weather	Lightning Arrestor	Replace - Same Size		III
5131033	K91115	09/18/2015	20:21	09/18/2015	20:45	1	23	23	Overhead equipment				III
5131035	K31124	09/18/2015	20:22	09/18/2015	22:22	5	599	119	Tree related-tree contact	Transformer Fuse	Replace - Same Size		I
5131041	A80002	09/18/2015	20:40	09/19/2015	12:35	1	954	954	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
5131045	K39154	09/18/2015	20:45	09/19/2015	0:43	1	237	237	Weather	Fuse	Replace - Same Size		III
5131051	X68506	09/18/2015	20:55	09/18/2015	22:45	4	437	109	Weather	Transformer Fuse	Replace - Same Size		IV
5131055	Z29579	09/18/2015	21:02	09/18/2015	23:18	1	135	135	Weather	Fuse	Replace - Same Size		IV
5131057	X82576	09/18/2015	21:03	09/18/2015	22:28	1	84	84	Weather	Transformer Fuse	Replace - Same Size		IV
5131061	K91115	09/18/2015	21:05	09/18/2015	21:10	1	4	4	Overhead equipment				III
5131065	K39154	09/18/2015	21:06	09/19/2015	0:42	4	861	215	Unknown	Fuse	Replace - Same Size		III

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5131067	K39154	09/18/2015	21:08	09/19/2015	0:43	1	214	214	Weather	Fuse	Replace - Same Size		III
5131069	Q06132	09/18/2015	21:08	09/18/2015	22:38	9	806	89	Weather	Transformer Fuse	Replace - Same Size		IV
5131071	P52305	09/18/2015	21:09	09/18/2015	22:16	1	66	66	Weather	Fuse	Patrol/Test/Inspect	Replace - Same Size	IV
5131091	R58952	09/18/2015	21:11	09/18/2015	22:32	178	14546	81	Weather	Substation Misc.	Repair		IV
5131083	R60552	09/18/2015	21:21	09/18/2015	22:42	1	80	80	Overhead equipment				IV
5131087	R60552	09/18/2015	21:22	09/18/2015	22:42	4	317	79	Weather				IV
5131089	K91115	09/18/2015	21:22	09/18/2015	21:25	1	2	2	Unknown	Overhead Primary	Repair		III
5131095	N93260	09/18/2015	21:25	09/19/2015	8:53	1	687	687	Overhead equipment	Fuse			III
5131255	C10002	09/18/2015	21:29	09/19/2015	8:54	54	36964	684	Tree related-tree broken	Fuse	Replace - Same Size		III
5131105	K71811	09/18/2015	21:33	09/18/2015	23:41	75	9534	127	Weather	Fuse	Replace - Same Size		IV
5131103	J75271	09/18/2015	21:35	09/18/2015	23:04	1	89	88	Weather	Fuse	Patrol/Test/Inspect	Replace - Same Size	IV
5131111	B76003	09/18/2015	21:41	09/19/2015	2:41	1	299	299	Overhead equipment	Fuse	Replace - Same Size		I
5131115	J71129	09/18/2015	21:45	09/18/2015	23:30	1	104	104	Unknown	Transformer Fuse	Replace - Same Size		I
5131117	R60551	09/18/2015	21:48	09/19/2015	3:49	38	13730	361	Weather	Overhead Primary		Repair	IV
5131119	R60551	09/18/2015	21:48	09/19/2015	3:49	24	8663	360	Weather	Overhead Primary		Repair	IV
5131121	R60552	09/18/2015	21:49	09/18/2015	23:04	1	74	74	Overhead equipment				IV
5131127	K74166	09/18/2015	22:01	09/19/2015	0:30	1	148	148	Tree related-tree broken	Overhead Service	Repair		IV
5131137	L81141	09/18/2015	22:05	09/18/2015	23:58	90	10082	112	Weather	Fuse	Replace - Same Size		IV
5131141	L42158	09/18/2015	22:08	09/19/2015	1:15	1	186	186	Unknown	Fuse	Replace - Same Size		III
5131155	K91115	09/18/2015	22:15	09/18/2015	22:30	1	14	14	Overhead equipment				III
5131163	L82187	09/18/2015	22:25	09/19/2015	6:52	1	506	506	Weather	Overhead Transformer	Replace - Same Size		IV
5131167	B68004	09/18/2015	22:37	09/19/2015	9:15	9	5734	637	Overhead equipment	Disconnect Switch	Replace - Same Size		III
5131169	J56341	09/18/2015	22:40	09/19/2015	7:00	42	20982	499	Overhead equipment	Overhead Primary			III
5131177	H00161	09/18/2015	22:46	09/19/2015	1:10	1	143	143	Tree related-tree broken	Overhead Service	Repair		III
5131183	J75271	09/18/2015	22:54	09/18/2015	23:39	1	44	44	Weather	Fuse	Patrol/Test/Inspect	Replace - Same Size	IV
5131185	R58952	09/18/2015	22:54	09/18/2015	23:05	1	10	10	Overhead equipment				IV
5131187	K74162	09/18/2015	23:00	09/19/2015	11:11	1	730	730	Weather	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	IV
5131189	B68002	09/18/2015	23:02	09/19/2015	8:57	3	1784	594	Overhead equipment	Transformer Fuse	Replace - Same Size		III
5131191	X64501	09/18/2015	23:02	09/18/2015	23:49	1	46	46	Overhead equipment	Fuse	Replace - Same Size		IV
5131193	Y55505	09/18/2015	23:05	09/19/2015	1:21	1	135	135	Weather	Fuse	Replace - Same Size		IV
5131195	K69117	09/18/2015	23:06	09/19/2015	2:21	79	15394	194	Underground equipment	Underground Primary	Switch/Reset	Repair	IV
5131199	340102	09/18/2015	23:12	09/19/2015	2:50	8	1738	217	Tree related-tree broken	Overhead Secondary	Patrol/Test/Inspect	Repair	V
5131201	L81141	09/18/2015	23:22	09/19/2015	5:15	1	352	352	Weather	Overhead Transformer	Replace - Same Size	Replace - Same Size	IV
5131203	X64501	09/18/2015	23:23	09/18/2015	23:55	1	31	31	Overhead equipment	Fuse	Replace - Same Size		IV
5131207	R60552	09/18/2015	23:33	09/19/2015	4:07	4	1094	273	Overhead equipment	Transformer Fuse	Repair		IV
5131205	U62521	09/18/2015	23:33	09/19/2015	1:25	4	446	111	Overhead equipment	Fuse	Replace - Same Size		II
5131209	Q93522	09/18/2015	23:40	09/19/2015	6:46	3	1275	425	Tree related-tree broken	Overhead Secondary	Repair	Repair	I
5131211	R02121	09/18/2015	23:52	09/19/2015	1:08	1	75	75	Animal related	Transformer Fuse	Replace - Same Size		VI
5131215	H07106	09/18/2015	23:56	09/19/2015	6:36	9	3593	399	Weather	Overhead Primary	Patrol/Test/Inspect	Repair	IV
5131217	C50001	09/19/2015	0:00	09/19/2015	12:40	5	3801	760	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	III
5131219	C10002	09/19/2015	0:01	09/19/2015	10:15	1	613	613	Overhead equipment	Fuse	Replace - Same Size		III
5131223	X75512	09/19/2015	0:04	09/19/2015	1:30	1	85	85	Weather	Fuse	Replace - Same Size		IV
5131227	B93001	09/19/2015	0:09	09/19/2015	6:11	3	1085	361	Underground equipment	Underground Primary	Repair		I
5131299	Q93522	09/19/2015	0:10	09/19/2015	4:30	1	259	259	Weather	Overhead Transformer	Repair	Repair	I
5131233	U95003	09/19/2015	0:31	09/19/2015	2:15	1	103	103	Tree related-tree broken	Overhead Service	Repair	Repair	II
5131235	X75573	09/19/2015	0:32	09/19/2015	2:13	1	100	100	Weather	Fuse	Replace - Same Size		IV
5131237	R99180	09/19/2015	0:34	09/19/2015	9:16	1	521	521	Weather	Transformer Fuse			IV
5131239	L42158	09/19/2015	0:38	09/19/2015	2:08	31	2776	89	Unknown	Fuse	Replace - Same Size		III
5131243	J75271	09/19/2015	0:50	09/19/2015	1:41	1	50	50	Weather	Fuse	Patrol/Test/Inspect	Replace - Same Size	IV
5131245	U06551	09/19/2015	0:56	09/19/2015	2:06	5	345	69	Weather	Fuse	Replace - Same Size		II
5131251	X30505	09/19/2015	1:21	09/19/2015	4:57	1	215	215	Overhead equipment	Fuse	Replace - Same Size		IV
5131265	L70127	09/19/2015	2:15	09/19/2015	3:06	57	2897	50	Weather	Fuse	Replace - Same Size		IV
5131273	J75271	09/19/2015	2:15	09/19/2015	4:30	10	1348	134	Weather	Fuse	Patrol/Test/Inspect	Replace - Same Size	IV
5131285	Y54587	09/19/2015	2:15	09/19/2015	8:27	55	10238	372	Underground equipment	Underground Transformer	Replace - Same Size		IV
5131271	J75271	09/19/2015	2:17	09/19/2015	2:51	1	33	33	Weather	Fuse	Patrol/Test/Inspect	Replace - Same Size	IV
5131279	V76526	09/19/2015	2:22	09/19/2015	4:20	1	117	117	Weather	Fuse	Replace - Same Size	Replace - Same Size	II

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5131283	J61115	09/19/2015	2:29	09/19/2015	6:43	58	14675	253	Overhead equipment	Fuse			III
5131291	P18103	09/19/2015	2:42	09/19/2015	10:39	1	476	476	Weather	Overhead Transformer		Replace - Same Size	IV
5131293	Y54591	09/19/2015	2:43	09/19/2015	5:37	1	173	173	Tree related-tree broken	Overhead Service	Cut in Clear		IV
5131295	D88002	09/19/2015	2:49	09/19/2015	4:42	5	560	112	Public	Disconnect Switch	Replace - Same Size		I
5131305	Q23255	09/19/2015	3:10	09/19/2015	5:17	1	126	126	Weather	Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
5131307	Q24312	09/19/2015	3:11	09/19/2015	5:50	1	158	158	Weather	Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
5131311	R49263	09/19/2015	3:16	09/19/2015	8:30	1	313	313	Weather	Transformer Fuse	Replace - Same Size		VI
5131323	N70330	09/19/2015	3:18	09/19/2015	5:39	55	7760	141	Tree related-tree broken	Overhead Primary	Repair		I
5131321	J18268	09/19/2015	3:35	09/19/2015	6:04	1	148	148	Weather	Transformer Fuse	Replace - Same Size		VI
5131325	Y60593	09/19/2015	3:42	09/19/2015	5:28	7	738	105	Overhead equipment	Overhead Secondary	Repair		IV
5131327	R60551	09/19/2015	4:01	09/19/2015	7:42	1	220	220	Weather	Overhead Transformer			IV
5131329	Y05001	09/19/2015	4:02	09/19/2015	6:31	1	148	148	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
5131375	Q16868	09/19/2015	4:15	09/19/2015	7:34	7	1390	198	Weather	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	V
5131335	K15205	09/19/2015	4:20	09/19/2015	7:05	6	993	165	Overhead equipment	Overhead Secondary	Patrol/Test/Inspect	Tie/Tighten	VI
5131337	R48166	09/19/2015	4:34	09/19/2015	6:07	1	92	92	Weather	Fuse	Replace - Same Size		IV
5131341	M25144	09/19/2015	4:58	09/19/2015	11:00	1	361	361	Overhead equipment	Overhead Transformer	Replace - Same Size		IV
5131351	X19561	09/19/2015	5:20	09/19/2015	9:43	1	262	262	Weather	Overhead Transformer	Replace - Same Size	Replace - Same Size	IV
5131407	B77001	09/19/2015	5:21	09/19/2015	9:45	39	10260	263	Tree related-tree broken	Tree	Remove	Remove	I
5131367	B77001	09/19/2015	5:28	09/19/2015	7:19	9	996	110	Tree related-tree broken	Fuse			I
5131361	N70330	09/19/2015	5:38	09/19/2015	7:40	2	242	121	Tree related-tree broken	Overhead Primary	Cut in Clear	Repair	I
5131363	338005	09/19/2015	5:40	09/19/2015	8:08	1	147	147	Public	Fuse	Replace - Same Size		VI
5131365	D66002	09/19/2015	5:41	09/19/2015	8:04	7	1000	142	Overhead equipment	Overhead Transformer	Replace - Same Size		IV
5131409	R84148	09/19/2015	5:48	09/19/2015	7:38	6	659	109	Unknown	Fuse	Patrol/Test/Inspect	Replace - Same Size	I
5131381	R20501	09/19/2015	6:16	09/19/2015	8:03	1	106	106	Weather	Transformer Fuse	Replace - Same Size		IV
5131385	K77041	09/19/2015	6:18	09/19/2015	8:32	1	133	133	Weather	Overhead Primary			IV
5131383	R60552	09/19/2015	6:18	09/19/2015	15:33	4	2218	554	Weather	Overhead Transformer		Replace - Same Size	IV
5131387	V28597	09/19/2015	6:24	09/19/2015	8:26	1	121	121	Tree related-tree broken	Overhead Service	Repair		II
5131389	J68401	09/19/2015	6:28	09/19/2015	7:39	1	70	70	Weather	Fuse	Repair	Repair	III
5131391	C10002	09/19/2015	6:37	09/19/2015	10:40	1	242	242	Overhead equipment	Fuse	Replace - Same Size		III
5131393	Z21564	09/19/2015	6:45	09/19/2015	8:40	1	114	114	Overhead equipment	Connector	Repair	Replace - Same Size	IV
5131395	Y60548	09/19/2015	6:50	09/19/2015	8:27	1	96	96	Weather	Transformer Fuse	Replace - Same Size		IV
5131397	C70001	09/19/2015	6:52	09/19/2015	8:32	1	100	100	Animal related	Fuse	Replace - Same Size		III
5131411	R60552	09/19/2015	7:12	09/19/2015	9:57	1	164	164	Weather	Transformer Fuse	Patrol/Test/Inspect	Repair	IV
5131413	R60552	09/19/2015	7:16	09/19/2015	8:48	1	91	91	Weather	Transformer Fuse	Replace - Same Size		IV
5131429	K74166	09/19/2015	7:29	09/19/2015	10:22	138	21332	173	Overhead equipment				IV
5131443	Q11517	09/19/2015	7:40	09/19/2015	9:30	198	21734	109	Tree related-tree contact	Fuse	Replace - Same Size		I
5131451	M45212	09/19/2015	7:44	09/19/2015	9:21	1	96	96	Weather	Fuse	Replace - Same Size		IV
5131453	R60552	09/19/2015	7:51	09/19/2015	9:21	1	89	89	Weather	Transformer Fuse	Replace - Same Size		IV
5131459	R84148	09/19/2015	7:57	09/19/2015	11:20	1	202	202	Weather	Overhead Transformer	Replace - Same Size	Replace - Same Size	I
5131461	Z04520	09/19/2015	7:59	09/19/2015	8:40	11	448	40	Overhead equipment	Fuse	Replace - Same Size		IV
5131469	Z04520	09/19/2015	8:03	09/19/2015	9:30	45	3923	87	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	IV
5131471	L93135	09/19/2015	8:09	09/19/2015	9:06	5	280	56	Animal related	Transformer Fuse	Repair		VI
5131473	M07235	09/19/2015	8:12	09/19/2015	14:26	2	629	373	Public	Underground Primary	Patrol/Test/Inspect	Repair	III
5131475	U33586	09/19/2015	8:19	09/19/2015	9:35	1	75	75	Overhead equipment	Transformer Fuse	Repair	Repair	II
5131477	Z04520	09/19/2015	8:26	09/19/2015	10:03	2	192	96	Overhead equipment	Overhead Service			IV
5131481	D66002	09/19/2015	8:32	09/19/2015	12:15	1	222	222	Overhead equipment	Overhead Transformer	Replace - Same Size		IV
5131489	Q14392	09/19/2015	8:45	09/19/2015	9:48	1	62	62	Weather	Fuse	Replace - Same Size		I
5131491	J83140	09/19/2015	8:48	09/19/2015	10:45	175	20475	116	Overhead equipment	Recloser	Patrol/Test/Inspect		VI
5131513	X75512	09/19/2015	8:55	09/19/2015	10:46	1	110	110	Overhead equipment	Disconnect Switch	Replace - Same Size		IV
5131517	J83140	09/19/2015	8:56	09/19/2015	10:45	2	216	108	Overhead equipment				VI
5131521	S15559	09/19/2015	8:57	09/19/2015	17:57	8	4322	540	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	VI
5131525	Z04520	09/19/2015	8:59	09/19/2015	9:59	1	59	59	Overhead equipment	Overhead Service			IV
5131529	U68552	09/19/2015	9:09	09/19/2015	10:30	1	80	80	Overhead equipment	Fuse	Replace - Same Size		II
5131531	F10001	09/19/2015	9:10	09/19/2015	11:40	1	149	149	Overhead equipment	Fuse	Replace - Same Size		III
5131537	C10002	09/19/2015	9:11	09/19/2015	12:26	1	194	194	Weather	Overhead Transformer	Repair		III
5131539	X64501	09/19/2015	9:14	09/19/2015	10:19	1	64	64	Overhead equipment	Transformer Fuse	Replace - Same Size		IV

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5131541	J83140	09/19/2015	9:18	09/19/2015	10:48	1	89	89	Overhead equipment				VI
5131543	X66581	09/19/2015	9:20	09/19/2015	12:25	2	368	184	Weather	Lightning Arrestor	Replace - Same Size		IV
5131545	Z04520	09/19/2015	9:22	09/19/2015	14:10	1	287	287	Overhead equipment	Pole	Replace - New Size	Replace - New Size	IV
5131555	J15303	09/19/2015	9:43	09/19/2015	12:30	1	166	166	Weather	Fuse	Replace - Same Size		I
5131567	K15205	09/19/2015	9:57	09/19/2015	12:35	1	157	157	Overhead equipment	Overhead Service	Repair		VI
5131569	Q24312	09/19/2015	10:05	09/19/2015	11:30	1	84	84	Weather				VI
5131573	R60552	09/19/2015	10:11	09/19/2015	12:32	1	140	140	Weather	Overhead Transformer		Replace - Same Size	IV
5131583	K74166	09/19/2015	10:17	09/19/2015	11:16	91	3012	58	Unknown				IV
5131581	R34920	09/19/2015	10:18	09/19/2015	10:35	8	134	16	Overhead equipment				VI
5131585	K74166	09/19/2015	10:24	09/19/2015	10:58	47	1610	34	Overhead equipment	Fuse			IV
5131587	B73001	09/19/2015	10:30	09/19/2015	16:41	1	370	370	Public	Underground Service	Replace - Same Size	Repair	I
5131591	B93001	09/19/2015	10:39	09/19/2015	12:20	17	1707	100	Animal related	Fuse	Replace - Same Size		I
5131601	K74166	09/19/2015	10:40	09/19/2015	11:16	38	1363	35	Overhead equipment				IV
5131599	M40116	09/19/2015	10:43	09/19/2015	12:20	1	96	96	Tree related-tree broken	Overhead Service	Cut in Clear		I
5131605	S60581	09/19/2015	10:48	09/19/2015	11:58	1	69	69	Animal related	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
5131611	R60552	09/19/2015	10:51	09/19/2015	12:10	1	78	78	Weather	Fuse			IV
5131613	D32211	09/19/2015	10:52	09/19/2015	12:12	1	79	79	Animal related	Transformer Fuse	Replace - Same Size		I
5131625	K09864	09/19/2015	11:12	09/19/2015	13:03	1	110	110	Animal related	Transformer Fuse	Repair		V
5131633	HD5254	09/19/2015	11:32	09/19/2015	12:19	1	46	46	Animal related	Transformer Fuse	Replace - Same Size		VI
5131635	Q74150	09/19/2015	11:32	09/19/2015	11:44	6	66	11	Overhead equipment				IV
5131637	P52305	09/19/2015	11:34	09/19/2015	16:34	1	299	299	Underground equipment	Underground Service	Patrol/Test/Inspect	Repair	IV
5131641	Z05549	09/19/2015	11:40	09/19/2015	14:23	1	162	162	Animal related	Transformer Fuse	Replace - Same Size		IV
5131643	U42512	09/19/2015	11:50	09/19/2015	13:25	1	95	95	Overhead equipment	Transformer Fuse	Replace - Same Size	Replace - Same Size	II
5131647	B93001	09/19/2015	12:07	09/19/2015	12:23	1	15	15	Animal related				I
5131653	M25144	09/19/2015	12:13	09/19/2015	13:20	3	199	66	Weather	Overhead Transformer	Replace - Same Size		IV
5131655	X09594	09/19/2015	12:15	09/19/2015	13:56	1	100	100	Overhead equipment	Overhead Transformer			IV
5131657	S22595	09/19/2015	12:23	09/19/2015	14:15	1	111	111	Animal related	Transformer Fuse	Patrol/Test/Inspect	Replace - New Size	VI
5131661	K28180	09/19/2015	12:28	09/19/2015	13:34	1	65	65	Overhead equipment	Fuse	Replace - Same Size		III
5131667	B83001	09/19/2015	12:35	09/19/2015	13:15	1	39	39	Overhead equipment	Fuse	Replace - Same Size		III
5131673	C50001	09/19/2015	12:48	09/19/2015	14:03	5	371	74	Overhead equipment	Overhead Transformer	Replace - Same Size		III
5131675	HB6283	09/19/2015	12:56	09/19/2015	13:46	1	49	49	Animal related	Fuse	Repair		VI
5131677	HB6283	09/19/2015	12:58	09/19/2015	13:45	1	46	46	Animal related	Fuse	Repair		VI
5131687	P58155	09/19/2015	13:05	09/19/2015	13:38	27	888	32	Tree related-tree broken	Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
5131685	R33126	09/19/2015	13:13	09/19/2015	14:10	1	56	56	Tree related-tree broken	Overhead Service	Cut in Clear		I
5131691	HB6283	09/19/2015	13:26	09/19/2015	13:45	1	18	18	Animal related	Fuse	Repair		VI
5131693	K30204	09/19/2015	13:27	09/19/2015	19:30	1	362	362	Weather	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	III
5131701	310123	09/19/2015	13:45	09/19/2015	14:40	4	218	54	Overhead equipment	Fuse	Replace - Same Size		V
5131703	B45005	09/19/2015	13:51	09/19/2015	14:54	29	1820	62	Unknown	Disconnect Switch	Replace - Same Size	Replace - Same Size	I
5131709	K76542	09/19/2015	13:56	09/19/2015	15:38	15	1517	101	Public	Transformer Fuse	Repair		IV
5131715	J14140	09/19/2015	14:17	09/19/2015	15:07	1	49	49	Animal related	Fuse	Replace - Same Size		VI
5131723	Q64919	09/19/2015	14:21	09/19/2015	16:05	12	1245	103	Tree related-tree broken	Fuse	Replace - Same Size		VI
5131717	K30205	09/19/2015	14:21	09/19/2015	16:25	1	123	123	Weather	Overhead Primary	Repair		III
5131727	C30002	09/19/2015	14:43	09/19/2015	17:47	42	7709	183	Overhead equipment	Fuse	Replace - Same Size		III
5131739	J98131	09/19/2015	14:57	09/19/2015	18:10	4	770	192	Overhead equipment	Disconnect Switch	Replace - Same Size		VI
5131747	B28006	09/19/2015	15:01	09/19/2015	22:24	14	3097	443	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
5131751	R48166	09/19/2015	15:22	09/19/2015	17:42	1	139	139	Tree related-tree contact	Overhead Service	Repair		IV
5131753	L74191	09/19/2015	15:41	09/19/2015	16:56	5	373	74	Tree related-tree contact	Overhead Secondary	Repair		IV
5131755	P49180	09/19/2015	16:10	09/19/2015	17:06	1	55	55	Weather	Overhead Transformer	Switch/Reset		I
5131759	R73838	09/19/2015	16:22	09/19/2015	19:58	1	215	215	Overhead equipment	Overhead Service	Patrol/Test/Inspect	Repair	V
5131763	S09521	09/19/2015	16:28	09/19/2015	20:20	13	2411	231	Underground equipment	Underground Primary	Repair	Patrol/Test/Inspect	VI
5131769	M22812	09/19/2015	17:17	09/19/2015	19:16	1	118	118	Animal related	Transformer Fuse	Replace - Same Size		V
5131773	K58213	09/19/2015	17:29	09/19/2015	19:15	1	105	105	Tree related-tree broken	Transformer Fuse			VI
5131775	Y39515	09/19/2015	17:49	09/19/2015	19:07	1	77	77	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	IV
5131779	D31016	09/19/2015	18:08	09/19/2015	19:15	62	4138	66	Animal related	Fuse	Replace - Same Size		III
5131783	P58155	09/19/2015	18:10	09/19/2015	19:35	1	84	84	Animal related	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
5131793	D96002	09/19/2015	18:19	09/19/2015	20:13	13	1483	114	Overhead equipment	Overhead Primary	Replace - Same Size		I

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5131787	N74241	09/19/2015	18:20	09/19/2015	20:10	88	9673	109	Overhead equipment	Fuse	Repair		I
5131791	N74241	09/19/2015	18:22	09/19/2015	20:08	12	1268	105	Overhead equipment	Fuse	Repair		I
5131795	N74241	09/19/2015	18:29	09/19/2015	20:10	80	8060	100	Overhead equipment	Fuse	Repair		I
5131803	R16511	09/19/2015	18:43	09/19/2015	21:11	1	147	147	Overhead equipment	Overhead Service	Repair		I
5131805	Q80353	09/19/2015	18:49	09/19/2015	20:43	4	452	113	Animal related	Transformer Fuse	Replace - Same Size		V
5131809	C00002	09/19/2015	19:09	09/20/2015	2:53	1	463	463	Public	Underground Service	Patrol/Test/Inspect	Repair	I
5131811	Q75145	09/19/2015	19:12	09/19/2015	20:40	1	87	87	Animal related	Fuse	Replace - Same Size		VI
5131819	Q18245	09/19/2015	20:06	09/19/2015	23:39	27	5716	213	Underground equipment	Underground Primary	Switch/Reset	Repair	VI
5131831	R60551	09/19/2015	20:13	09/20/2015	2:21	125	46008	368	Public	Pole	Patrol/Test/Inspect	Repair	IV
5131835	P82291	09/19/2015	20:14	09/19/2015	23:03	1	168	168	Tree related-tree contact	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
5131841	K62102	09/19/2015	20:52	09/19/2015	22:25	1	92	92	Unknown	Fuse	Replace - Same Size		II
5131845	K62102	09/19/2015	20:56	09/19/2015	22:48	1	111	111	Unknown	Fuse	Replace - Same Size		II
5131851	V01002	09/19/2015	22:19	09/20/2015	5:40	46	20319	441	Underground equipment	Underground Primary	Repair	Repair	II
5131855	H06135	09/19/2015	22:23	09/20/2015	5:15	14	3344	411	Underground equipment	Underground Primary	Repair		IV
5131861	P17109	09/20/2015	1:17	09/20/2015	2:22	1	64	64	Public				IV
5131927	312-UNIT-1	09/20/2015	3:06	09/20/2015	4:40	1568	147266	93	Overhead equipment				V
5131911	330125	09/20/2015	3:17	09/20/2015	7:03	1	225	225	Overhead equipment				V
5131973	H06135	09/20/2015	3:40	09/20/2015	3:51	24	276	11	Underground equipment	Underground Primary	Repair	Replace - Same Size	IV
5131975	D32212	09/20/2015	4:24	09/20/2015	11:24	1	419	419	Underground equipment	Underground Primary	Repair	Repair	I
5131979	V42586	09/20/2015	4:41	09/20/2015	6:22	5	500	100	Overhead equipment	Transformer Fuse	Replace - Same Size	Repair	II
5131987	U06551	09/20/2015	6:04	09/20/2015	7:05	1	60	60	Animal related	Fuse	Replace - Same Size		II
5131989	315106	09/20/2015	6:10	09/20/2015	8:16	162	20493	126	Overhead equipment	Overhead Primary	Replace - Same Size		V
5131995	R49261	09/20/2015	6:47	09/20/2015	9:00	9	1192	132	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	VI
5131999	Q80354	09/20/2015	7:10	09/20/2015	7:38	32	892	27	Animal related	Fuse	Replace - Same Size	Replace - Same Size	V
5132003	P49187	09/20/2015	7:25	09/20/2015	9:09	6	620	103	Animal related	Fuse	Replace - Same Size		I
5132005	P49187	09/20/2015	7:33	09/20/2015	9:09	5	475	95	Animal related	Fuse	Replace - Same Size		I
5132011	B71002	09/20/2015	8:07	09/20/2015	8:48	28	1137	40	Animal related	Disconnect Switch	Replace - Same Size	Replace - Same Size	I
5132013	V69558	09/20/2015	8:17	09/20/2015	9:57	3	297	99	Animal related	Transformer Fuse	Replace - Same Size		II
5132015	S15559	09/20/2015	8:22	09/20/2015	10:33	11	1436	130	Animal related	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
5132021	T23527	09/20/2015	8:50	09/20/2015	10:14	1	83	83	Animal related	Transformer Fuse	Replace - Same Size		VI
5132029	D69006	09/20/2015	8:50	09/20/2015	9:33	58	2459	42	Unknown	Disconnect Switch	Replace - Same Size	Replace - Same Size	I
5132037	P47169	09/20/2015	9:00	09/20/2015	9:58	135	7800	57	Animal related	Fuse	Replace - Same Size		I
5132049	HC9325	09/20/2015	9:18	09/20/2015	11:25	1	126	126	Animal related	Transformer Fuse	Replace - Same Size		VI
5132059	J14142	09/20/2015	9:35	09/20/2015	11:20	1	105	104	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	VI
5132061	J84123	09/20/2015	9:37	09/20/2015	13:00	1	202	202	Overhead equipment	Overhead Service	Tie/Tighten		VI
5132063	K32932	09/20/2015	9:46	09/20/2015	10:42	1	55	55	Animal related	Fuse	Replace - Same Size		VI
5132065	K80381	09/20/2015	9:48	09/20/2015	12:14	22	3226	146	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	IV
5132073	X78536	09/20/2015	10:07	09/20/2015	11:28	1	80	80	Animal related	Fuse	Repair	Replace - Same Size	IV
5132075	Q82906	09/20/2015	10:09	09/20/2015	11:07	1	57	57	Overhead equipment	Transformer Fuse	Replace - Same Size		VI
5132081	M07236	09/20/2015	10:11	09/20/2015	12:22	40	5200	130	Unknown	Fuse			III
5132083	X75512	09/20/2015	10:17	09/20/2015	11:30	1	72	72	Overhead equipment	Disconnect Switch	Replace - Same Size	Replace - Same Size	IV
5132085	K67924	09/20/2015	10:18	09/20/2015	12:15	1	116	116	Animal related	Transformer Fuse	Replace - Same Size		VI
5132091	P54828	09/20/2015	10:22	09/20/2015	11:20	51	2950	57	Public				V
5132099	R04407	09/20/2015	10:46	09/20/2015	14:53	1	246	246	Overhead equipment	Overhead Service	Patrol/Test/Inspect	Replace - New Size	V
5132113	L24121	09/20/2015	11:34	09/20/2015	13:05	22	1989	90	Animal related	Fuse	Repair		III
5132123	Y31589	09/20/2015	12:37	09/20/2015	13:20	1	42	42	Tree related-tree broken	Fuse	Repair	Replace - Same Size	IV
5132127	N18210	09/20/2015	12:57	09/20/2015	14:02	1	64	64	Animal related	Fuse			III
5132131	S41563	09/20/2015	13:42	09/20/2015	15:09	1	86	86	Overhead equipment	Overhead Service	Repair	Replace - Same Size	VI
5132143	K32932	09/20/2015	13:59	09/20/2015	15:12	12	864	72	Animal related	Fuse	Replace - Same Size		VI
5132135	K32932	09/20/2015	14:03	09/20/2015	15:12	1	68	68	Animal related	Fuse	Replace - Same Size		VI
5132137	Y89002	09/20/2015	14:04	09/20/2015	15:06	1	61	61	Tree related-tree broken	Overhead Service	Raise	Repair	IV
5132141	R16511	09/20/2015	14:08	09/20/2015	15:10	1	61	61	Animal related	Transformer Fuse	Repair		I
5132145	M26161	09/20/2015	14:16	09/20/2015	15:50	1	93	93	Overhead equipment	Transformer Fuse	Repair		III
5132147	HD0574	09/20/2015	14:16	09/20/2015	15:35	1	78	78	Animal related	Transformer Fuse	Replace - Same Size		VI
5132149	J58380	09/20/2015	14:22	09/20/2015	18:49	9	2400	266	Overhead equipment	Overhead Transformer			III
5132151	301052	09/20/2015	14:22	09/20/2015	16:12	1	109	109	Overhead equipment	Fuse	Replace - Same Size		VI

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5132153	B83001	09/20/2015	14:32	09/20/2015	21:00	1	387	387	Underground equipment	Underground Service			III
5132157	V84509	09/20/2015	14:43	09/20/2015	17:09	4	582	145	Animal related	Transformer Fuse	Replace - Same Size		II
5132159	R99180	09/20/2015	14:45	09/20/2015	18:30	1	224	224	Overhead equipment	Overhead Transformer		Replace - Same Size	IV
5132165	J30201	09/20/2015	15:33	09/20/2015	18:50	48	8012	197	Overhead equipment	Fuse	Replace - Same Size	Repair	VI
5132169	L74193	09/20/2015	16:18	09/20/2015	18:57	1	158	158	Overhead equipment	Overhead Service	Repair		IV
5132171	N86225	09/20/2015	16:28	09/20/2015	17:01	18	591	32	Overhead equipment	Pole	Replace - Same Size		VI
5132203	P42230	09/20/2015	16:39	09/20/2015	20:45	25	5490	246	Underground equipment	Underground Primary	Switch/Reset	Repair	VI
5132179	C36001	09/20/2015	17:02	09/20/2015	20:30	2	415	207	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	III
5132205	D28124	09/20/2015	18:45	09/21/2015	0:05	1	319	319	Overhead equipment	Overhead Primary	Patrol/Test/Inspect	Reconnect	I
5132207	P98192	09/20/2015	19:00	09/20/2015	19:45	6	268	44	Overhead equipment	Fuse			III
5132209	J84124	09/20/2015	19:10	09/20/2015	20:18	5	337	67	Animal related	Transformer Fuse	Replace - Same Size		VI
5132225	R20501	09/20/2015	20:02	09/20/2015	22:31	123	18317	148	Overhead equipment	Recloser	Patrol/Test/Inspect	Replace - Same Size	IV
5132221	R20501	09/20/2015	20:05	09/20/2015	22:31	15	2176	145	Overhead equipment	Recloser	Replace - Same Size	Replace - Same Size	IV
5132231	R20501	09/20/2015	20:09	09/20/2015	22:31	1	141	141	Overhead equipment	Recloser	Replace - Same Size	Replace - Same Size	IV
5132241	D93001	09/20/2015	20:14	09/20/2015	21:45	1	90	90	Overhead equipment	Disconnect Switch	Replace - Same Size		IV
5132253	N35852	09/20/2015	20:52	09/21/2015	1:43	6	1746	291	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	V
5132283	P12290	09/20/2015	21:26	09/21/2015	4:42	1078	469770	435	Animal related	Substation Transformer	Repair	Replace - Same Size	V
5132301	P09304	09/20/2015	21:29	09/21/2015	0:26	1	176	176	Animal related				V
5132313	M53311	09/20/2015	21:40	09/21/2015	1:08	1	207	207	Animal related				V
5132317	M25144	09/20/2015	22:28	09/21/2015	0:05	5	480	96	Overhead equipment	Pole	Repair	Replace - Same Size	IV
5132321	Q95247	09/20/2015	23:05	09/21/2015	0:42	1	97	97	Overhead equipment	Transformer Fuse	Replace - Same Size		VI
5132323	U11531	09/20/2015	23:09	09/21/2015	8:15	29	15834	545	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	II
5132325	R20501	09/20/2015	23:34	09/21/2015	5:12	20	6759	337	Overhead equipment	Overhead Primary	Patrol/Test/Inspect	Repair	IV
5132333	D70006	09/21/2015	1:02	09/21/2015	5:01	19	4530	238	Underground equipment	Fuse	Replace - Same Size		I
5132335	N18211	09/21/2015	1:18	09/21/2015	3:59	1	160	160	Unknown	Fuse	Replace - Same Size		III
5132339	N35852	09/21/2015	1:44	09/21/2015	5:00	4	783	195	Underground equipment	Underground Primary	Repair	Repair	V
5132343	310124	09/21/2015	2:04	09/21/2015	11:23	88	49242	559	Public	Pole	Repair	Replace - Same Size	V
5132363	B84001	09/21/2015	5:18	09/21/2015	6:00	15	637	42	Overhead equipment	Fuse	Replace - Same Size		I
5132361	A91002	09/21/2015	5:26	09/21/2015	7:09	4	412	103	Underground equipment	Underground Primary	Repair	Repair	I
5132367	X72535	09/21/2015	7:08	09/21/2015	8:12	1	63	63	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
5132375	B77001	09/21/2015	7:22	09/21/2015	7:58	6	214	35	Animal related	Customer Equipment	Patrol/Test/Inspect		I
5132377	T23528	09/21/2015	7:27	09/21/2015	8:30	1	62	62	Animal related	Transformer Fuse	Replace - Same Size		VI
5132381	P47169	09/21/2015	7:30	09/21/2015	8:34	1	63	63	Overhead equipment	Connector	Reconnect	Patrol/Test/Inspect	I
5132383	J76804	09/21/2015	7:39	09/21/2015	8:48	1	68	68	Overhead equipment	Connector	Repair	Repair	V
5132389	R84148	09/21/2015	7:51	09/21/2015	9:20	1	88	88	Unknown	Fuse	Patrol/Test/Inspect	Replace - Same Size	I
5132391	Q06132	09/21/2015	7:54	09/21/2015	9:45	29	3206	110	Overhead equipment	Fuse	Repair		IV
5132403	X72535	09/21/2015	8:07	09/21/2015	8:12	1	4	4	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
5132419	N18210	09/21/2015	8:29	09/21/2015	9:40	48	3381	70	Animal related	Fuse	Replace - Same Size		III
5132413	R71285	09/21/2015	8:33	09/21/2015	9:59	1	85	85	Animal related	Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
5132421	A91002	09/21/2015	8:46	09/21/2015	10:52	2	252	126	Underground equipment	Underground Primary	Repair	Repair	I
5132427	C66001	09/21/2015	8:51	09/21/2015	9:38	1	46	46	Overhead equipment	Fuse	Repair	Replace - Same Size	III
5132433	D35002	09/21/2015	8:53	09/21/2015	10:02	1	68	68	Animal related	Fuse	Repair	Replace - Same Size	I
5132435	S88503	09/21/2015	8:54	09/21/2015	10:49	1	114	114	Overhead equipment	Overhead Secondary	Patrol/Test/Inspect	Repair	VI
5132437	D67001	09/21/2015	8:54	09/21/2015	9:57	1	62	62	Overhead equipment	Connector	Replace - Same Size		IV
5132439	B28006	09/21/2015	8:54	09/21/2015	21:07	6	4392	732	Underground equipment	Underground Service	Patrol/Test/Inspect	Repair	I
5132451	M78323	09/21/2015	8:55	09/21/2015	10:48	26	2932	112	Animal related	Fuse	Replace - Same Size		V
5132443	K08909	09/21/2015	8:55	09/21/2015	10:00	11	710	64	Animal related	Transformer Fuse		Patrol/Test/Inspect	VI
5132463	K28180	09/21/2015	9:08	09/21/2015	9:53	1	44	44	Unknown	Fuse	Replace - Same Size		III
5132465	H00163	09/21/2015	9:16	09/21/2015	14:35	1	318	318	Underground equipment	Underground Service	Repair	Repair	III
5132475	J87101	09/21/2015	9:20	09/21/2015	11:09	1	108	108	Tree related-tree broken	Overhead Service		Replace - Same Size	VI
5132489	U62510	09/21/2015	9:36	09/21/2015	10:00	3	70	23	Unknown	Fuse	Replace - Same Size		II
5132493	X42502	09/21/2015	9:48	09/21/2015	10:19	1	30	30	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	IV
5132631	Y79500	09/21/2015	9:56	09/21/2015	11:10	712	52723	74	Animal related				IV
5132633	Y79503	09/21/2015	9:56	09/21/2015	11:10	341	25210	73	Animal related				IV
5132565	M19222	09/21/2015	10:02	09/21/2015	14:09	1	246	246	Overhead equipment	Overhead Transformer	Replace - New Size	Replace - New Size	VI
5132597	N44217	09/21/2015	10:27	09/21/2015	11:25	1	57	57	Overhead equipment	Transformer Fuse		Replace - Same Size	III

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5132603	M41111	09/21/2015	10:32	09/21/2015	12:24	1	111	111	Animal related	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	I
5132613	R20501	09/21/2015	10:36	09/21/2015	13:00	1	143	143	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
5132611	R60552	09/21/2015	10:36	09/21/2015	12:09	1	92	92	Underground equipment	Underground Service	Patrol/Test/Inspect	Repair	IV
5132609	D92001	09/21/2015	10:36	09/21/2015	13:01	1	144	144	Underground equipment	Underground Service	Patrol/Test/Inspect	Repair	I
5132617	M41111	09/21/2015	10:40	09/21/2015	12:01	1	80	80	Weather	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	I
5132635	N54213	09/21/2015	10:55	09/21/2015	12:12	1	76	76	Overhead equipment	Overhead Service	Repair		II
5132639	M81405	09/21/2015	10:58	09/21/2015	11:45	1	46	46	Overhead equipment				V
5132641	L93148	09/21/2015	11:01	09/21/2015	13:24	4	569	142	Public	Underground Secondary			VI
5132665	X96543	09/21/2015	11:27	09/21/2015	12:22	6	328	54	Animal related	Transformer Fuse	Repair	Patrol/Test/Inspect	IV
5132669	N15849	09/21/2015	11:37	09/21/2015	12:33	1	55	55	Intentional				V
5132673	N44215	09/21/2015	11:41	09/21/2015	16:45	6	1818	303	Public	Underground Secondary		Repair	III
5132681	P83705	09/21/2015	11:51	09/21/2015	13:24	1	92	92	Animal related	Fuse	Repair		I
5132695	P83705	09/21/2015	12:37	09/21/2015	13:30	3	158	52	Animal related				I
5132701	J58380	09/21/2015	12:52	09/21/2015	15:52	16	2888	180	Underground equipment	Underground Primary		Repair	III
5132713	Y11555	09/21/2015	13:05	09/21/2015	13:40	1	34	34	Unknown	Fuse	Replace - Same Size		IV
5132711	A85001	09/21/2015	13:05	09/21/2015	14:53	1	107	107	Overhead equipment	Fuse	Replace - Same Size		I
5132721	N54108	09/21/2015	13:21	09/21/2015	14:18	1	56	56	Weather	Fuse	Replace - Same Size		II
5132723	A91001	09/21/2015	13:26	09/21/2015	13:59	1	32	32	Other	Other			I
5132727	S25551	09/21/2015	13:30	09/21/2015	14:11	1	40	40	Animal related	Transformer Fuse	Repair	Repair	VI
5132731	HC9325	09/21/2015	13:33	09/21/2015	15:20	1	106	106	Public	Underground Service			VI
5132741	S14509	09/21/2015	13:41	09/21/2015	14:22	1	40	40	Unknown	Customer Equipment	Replace - Same Size		VI
5132751	B44002	09/21/2015	14:17	09/21/2015	15:29	9	647	71	Animal related	Transformer Fuse	Replace - Same Size	Replace - Same Size	I
5132755	F03003	09/21/2015	14:25	09/21/2015	15:14	5	243	48	Overhead equipment	Fuse	Repair	Replace - Same Size	III
5132757	B38002	09/21/2015	14:34	09/21/2015	14:52	2	35	17	Overhead equipment	Fuse	Replace - Same Size		I
5132759	F03003	09/21/2015	14:34	09/21/2015	15:14	1	39	39	Overhead equipment	Fuse	Repair	Replace - Same Size	III
5132767	Q27185	09/21/2015	14:48	09/21/2015	15:33	1	44	44	Animal related	Fuse	Replace - Same Size		VI
5132779	J58380	09/21/2015	15:18	09/21/2015	15:42	1	23	23	Underground equipment	Underground Primary			III
5132793	Q32171	09/21/2015	15:34	09/21/2015	17:10	1	95	95	Animal related	Transformer Fuse	Replace - Same Size		I
5132799	Q24313	09/21/2015	15:46	09/21/2015	16:27	1	40	40	Overhead equipment	Transformer Fuse	Replace - Same Size		VI
5132817	P26280	09/21/2015	17:07	09/21/2015	18:38	15	1351	90	Animal related	Transformer Fuse	Repair		I
5132819	Q27185	09/21/2015	17:16	09/21/2015	18:12	1	55	55	Overhead equipment	Overhead Secondary	Replace - Same Size		VI
5132823	F03003	09/21/2015	17:24	09/21/2015	21:02	1	217	217	Overhead equipment	Lightning Arrestor	Disconnect		III
5132825	D93001	09/21/2015	17:39	09/21/2015	21:16	1	216	216	Overhead equipment	Overhead Transformer	Replace - Same Size	Replace - Same Size	IV
5132829	M47802	09/21/2015	17:53	09/21/2015	18:50	1	56	56	Overhead equipment	Fuse	Repair	Repair	V
5132843	A91001	09/21/2015	18:06	09/21/2015	19:14	1	67	67	Overhead equipment	Meter			I
5132847	D33142	09/21/2015	18:47	09/21/2015	20:30	1	102	102	Overhead equipment	Overhead Service			I
5132849	Y89004	09/21/2015	18:48	09/21/2015	20:03	22	1650	75	Overhead equipment	Fuse	Repair	Replace - Same Size	IV
5132851	S93504	09/21/2015	18:50	09/21/2015	19:54	1	63	63	Overhead equipment	Transformer Fuse	Replace - Same Size		VI
5132853	A97002	09/21/2015	18:50	09/21/2015	22:15	1	204	204	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
5132855	K74166	09/21/2015	18:52	09/22/2015	0:34	1	342	342	Underground equipment	Underground Primary	Disconnect	Repair	IV
5132857	Y89005	09/21/2015	18:58	09/21/2015	20:03	1	64	64	Overhead equipment	Fuse	Repair	Replace - Same Size	IV
5132859	U13551	09/21/2015	18:58	09/21/2015	22:29	1	210	210	Underground equipment	Underground Primary	Repair	Repair	II
5132863	V82551	09/21/2015	19:20	09/21/2015	20:03	1	42	42	Overhead equipment	Transformer Fuse	Replace - Same Size		II
5132879	349002	09/21/2015	21:44	09/21/2015	23:12	1	87	87	Animal related				VI
5132889	B58001	09/21/2015	22:01	09/21/2015	23:26	35	2950	84	Overhead equipment	Jumper	Disconnect	Repair	I
5132895	S03531	09/21/2015	22:02	09/21/2015	22:55	1	52	52	Other				VI
5132893	J76805	09/21/2015	22:02	09/22/2015	0:08	1	125	125	Animal related	Fuse			V
5132903	B58001	09/21/2015	22:05	09/22/2015	0:05	7	841	120	Overhead equipment	Connector	Repair	Replace - Same Size	I
5132897	C70001	09/21/2015	23:03	09/22/2015	6:09	1	426	426	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	III
5132905	Q47833	09/22/2015	0:33	09/22/2015	1:32	1	58	58	Animal related	Transformer Fuse	Replace - Same Size		V
5132955	S02502	09/22/2015	0:47	09/22/2015	4:21	328	70267	214	Underground equipment	Underground Primary	Repair	Repair	VI
5133039	N50332	09/22/2015	1:33	09/22/2015	5:35	10	2413	242	Underground equipment	Underground Primary	Switch/Reset	Repair	II
5132949	V16501	09/22/2015	1:39	09/22/2015	9:09	5	2247	449	Substation equipment	Regulator	Patrol/Test/Inspect	Replace - Same Size	II
5132957	K09864	09/22/2015	1:56	09/22/2015	5:20	1	203	203	Overhead equipment				V
5133013	K09864	09/22/2015	2:01	09/22/2015	5:05	278	51143	183	Other				V
5133023	U45585	09/22/2015	2:17	09/22/2015	3:34	1	76	76	Overhead equipment	Overhead Service	Repair		II

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5133055	K09864	09/22/2015	5:51	09/22/2015	9:24	56	11943	213	Overhead equipment	Jumper	Replace - New Size	Repair	V
5133051	S30518	09/22/2015	6:53	09/22/2015	12:15	1	321	321	Underground equipment	Underground Primary		Repair	VI
5133053	C70001	09/22/2015	6:59	09/22/2015	10:30	1	210	210	Underground equipment	Underground Primary		Repair	III
5133065	K71810	09/22/2015	7:42	09/22/2015	8:46	17	1078	63	Animal related	Transformer Fuse	Replace - Same Size		IV
5133069	B58001	09/22/2015	7:46	09/22/2015	10:36	13	2199	169	Animal related	Transformer Fuse	Replace - Same Size		I
5133071	V01002	09/22/2015	7:52	09/22/2015	9:44	1	111	111	Unknown	Transformer Fuse	Replace - Same Size	Replace - Same Size	II
5133075	P26283	09/22/2015	8:08	09/22/2015	10:35	1	146	146	Animal related	Transformer Fuse	Repair		I
5133079	R04409	09/22/2015	8:12	09/22/2015	8:31	146	2864	19	Animal related				V
5133091	R04409	09/22/2015	8:19	09/22/2015	8:32	1	12	12	Animal related				V
5133101	K71811	09/22/2015	8:32	09/22/2015	9:25	20	1052	52	Animal related	Fuse	Replace - Same Size		IV
5133105	K32915	09/22/2015	8:33	09/22/2015	9:14	1	40	40	Overhead equipment	Jumper			VI
5133113	Y04508	09/22/2015	8:48	09/22/2015	9:35	1	46	46	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
5133117	R53390	09/22/2015	8:51	09/22/2015	9:27	1	35	35	Animal related	Fuse	Replace - Same Size		V
5133127	K62102	09/22/2015	8:59	09/22/2015	10:15	1	75	75	Animal related	Transformer Fuse	Replace - Same Size		II
5133135	P73157	09/22/2015	9:10	09/22/2015	10:38	1	87	87	Animal related	Fuse	Replace - Same Size		VI
5133137	U90566	09/22/2015	9:13	09/22/2015	10:18	1	64	64	Tree related-tree broken	Overhead Service	Repair		II
5133153	B46001	09/22/2015	9:28	09/22/2015	9:31	6	17	2	Unknown				I
5133155	S25551	09/22/2015	9:28	09/22/2015	10:33	1	64	64	Other				VI
5133159	S25551	09/22/2015	9:30	09/22/2015	10:22	1	51	51	Animal related	Transformer Fuse	Replace - Same Size	Replace - Same Size	VI
5133163	K71811	09/22/2015	9:42	09/22/2015	9:53	1	10	10	Animal related	Transformer Fuse	Replace - Same Size		IV
5133167	S27599	09/22/2015	9:49	09/22/2015	9:51	6	14	2	Unknown				VI
5133175	S27599	09/22/2015	9:52	09/22/2015	9:54	6	13	2	Unknown				VI
5133181	M04365	09/22/2015	9:55	09/22/2015	11:02	33	2184	66	Animal related	Fuse	Replace - Same Size		V
5133183	M04365	09/22/2015	9:57	09/22/2015	10:53	1	55	55	Animal related	Fuse	Replace - Same Size		V
5133187	X65540	09/22/2015	10:00	09/22/2015	10:28	607	17008	28	Overhead equipment	Recloser			IV
5133205	J56341	09/22/2015	10:06	09/22/2015	10:44	15	568	37	Animal related	Fuse	Repair	Repair	III
5133253	M05360	09/22/2015	10:45	09/22/2015	16:32	2	694	347	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	V
5133303	P52305	09/22/2015	11:44	09/22/2015	13:00	102	7770	76	Overhead equipment				IV
5133281	Y96564	09/22/2015	11:54	09/22/2015	12:55	1	60	60	Animal related	Transformer Fuse	Replace - Same Size		IV
5133287	J58380	09/22/2015	12:20	09/22/2015	16:50	26	3463	270	Underground equipment	Underground Primary			III
5133293	M49411	09/22/2015	12:23	09/22/2015	13:25	1	61	61	Animal related	Fuse	Replace - Same Size		V
5133301	P52305	09/22/2015	12:31	09/22/2015	13:00	3	85	28	Overhead equipment	Lightning Arrestor	Replace - Same Size	Replace - Same Size	IV
5133309	D41003	09/22/2015	12:48	09/22/2015	14:33	2	210	105	Underground equipment	Underground Primary	Repair	Repair	I
5133311	P47123	09/22/2015	12:50	09/22/2015	18:29	1	338	338	Weather	Fuse	Patrol/Test/Inspect	Replace - Same Size	I
5133313	S57502	09/22/2015	12:52	09/22/2015	13:40	1	47	47	Overhead equipment	Transformer Fuse	Repair	Replace - Same Size	VI
5133323	S31527	09/22/2015	13:04	09/22/2015	14:38	6	561	93	Overhead equipment	Transformer Fuse	Repair	Replace - Same Size	VI
5133325	X78536	09/22/2015	13:05	09/22/2015	13:14	5	41	8	Overhead equipment	Overhead Transformer		Replace - Same Size	IV
5133331	K80381	09/22/2015	13:15	09/22/2015	14:26	1	70	70	Public				IV
5133337	A81001	09/22/2015	13:35	09/22/2015	15:29	52	5882	113	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
5133341	B21004	09/22/2015	13:38	09/22/2015	14:56	1	77	77	Unknown	Transformer Fuse	Replace - Same Size		I
5133361	338005	09/22/2015	14:07	09/22/2015	15:04	1	56	56	Overhead equipment	Overhead Service	Patrol/Test/Inspect		VI
5133367	Z10501	09/22/2015	14:14	09/22/2015	15:23	1	68	68	Overhead equipment	Overhead Service			IV
5133369	K71822	09/22/2015	14:21	09/22/2015	16:24	31	3787	122	Underground equipment	Underground Primary	Switch/Reset	Repair	IV
5133371	M31204	09/22/2015	14:27	09/22/2015	15:16	1	48	48	Animal related	Fuse	Replace - Same Size		I
5133405	R95-UNIT-1	09/22/2015	14:31	09/22/2015	15:32	1073	64433	60	Unknown				I
5133379	K80381	09/22/2015	14:35	09/22/2015	16:45	7	911	130	Public	Underground Transformer		Repair	IV
5133389	R04412	09/22/2015	15:08	09/22/2015	20:34	1	325	325	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	V
5133393	306003	09/22/2015	15:21	09/22/2015	16:59	1	97	97	Public	Overhead Service	Repair		VI
5133395	N54214	09/22/2015	15:24	09/22/2015	16:22	1	57	57	Unknown	Fuse	Repair		II
5133417	M37191	09/22/2015	16:06	09/22/2015	16:51	1	44	44	Overhead equipment	Disconnect Switch	Replace - Same Size		I
5133419	M37191	09/22/2015	16:08	09/22/2015	16:54	1	45	45	Overhead equipment	Disconnect Switch	Replace - Same Size		I
5133425	J87150	09/22/2015	16:30	09/22/2015	18:06	27	2519	95	Underground equipment	Underground Primary		Repair	VI
5133429	R01152	09/22/2015	16:51	09/22/2015	17:00	5	40	8	Tree related-tree contact	Tree			III
5133433	J14140	09/22/2015	16:59	09/22/2015	20:20	3	602	200	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	VI
5133435	J74125	09/22/2015	17:01	09/22/2015	19:02	1	120	120	Overhead equipment	Connector	Repair		VI
5133451	P20913	09/22/2015	18:33	09/22/2015	22:09	13	2811	216	Underground equipment	Underground Primary	Disconnect	Patrol/Test/Inspect	VI

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5133455	S61583	09/22/2015	18:38	09/22/2015	19:35	24	1345	56	Overhead equipment	Fuse	Repair		VI
5133457	R60551	09/22/2015	18:53	09/22/2015	19:56	3	187	62	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
5133467	R04412	09/22/2015	19:03	09/22/2015	20:39	1	95	95	Underground equipment				V
5133469	R04412	09/22/2015	19:03	09/22/2015	21:04	1	120	120	Underground equipment				V
5133471	R04412	09/22/2015	19:04	09/22/2015	21:05	1	120	120	Underground equipment				V
5133473	R04412	09/22/2015	19:15	09/22/2015	20:47	1	91	91	Underground equipment				V
5133481	A45003	09/22/2015	20:15	09/23/2015	9:37	1	801	801	Weather	Pole		Replace - Urgent	I
5133521	Q74148	09/22/2015	20:15	09/23/2015	5:45	712	158520	570	Overhead equipment	Substation Breaker	Switch/Reset		IV
5133577	P73157	09/22/2015	20:41	09/22/2015	21:42	11	673	61	Underground equipment	Underground Primary	Replace - Same Size	Replace - Same Size	VI
5133585	Y31591	09/22/2015	20:52	09/22/2015	22:15	1	82	82	Overhead equipment	Overhead Service			IV
5133589	D92002	09/22/2015	21:14	09/22/2015	23:01	1	106	106	Overhead equipment				I
5133593	Z29579	09/22/2015	21:55	09/22/2015	22:43	7	334	47	Animal related	Transformer Fuse	Replace - Same Size		IV
5133603	X65540	09/23/2015	2:38	09/23/2015	4:54	19	2590	136	Underground equipment				IV
5133611	X65540	09/23/2015	3:42	09/23/2015	7:54	3	755	251	Underground equipment	Underground Primary	Repair	Repair	IV
5133623	L24122	09/23/2015	4:03	09/23/2015	7:19	28	5496	196	Underground equipment	Other			III
5133627	L24122	09/23/2015	4:06	09/23/2015	7:25	11	2187	198	Underground equipment	Underground Primary		Repair	III
5133615	K80382	09/23/2015	5:25	09/23/2015	7:30	41	4643	124	Underground equipment	Underground Primary		Repair	IV
5133621	L24122	09/23/2015	6:27	09/23/2015	7:26	1	58	58	Underground equipment	Other			III
5133635	V83505	09/23/2015	7:39	09/23/2015	10:10	4	603	150	Overhead equipment	Fuse	Replace - Same Size		II
5133639	M41112	09/23/2015	7:41	09/23/2015	8:35	1	53	53	Animal related	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	I
5133641	D32211	09/23/2015	7:46	09/23/2015	12:18	13	3531	271	Animal related	Fuse	Replace - Same Size		I
5133645	K27150	09/23/2015	7:49	09/23/2015	9:30	1	100	100	Underground equipment	Underground Transformer	Replace - Same Size	Replace - Same Size	VI
5133647	S47537	09/23/2015	8:00	09/23/2015	9:28	1	87	87	Tree related-tree contact	Overhead Service	Repair	Repair	VI
5133685	L93135	09/23/2015	8:06	09/23/2015	11:00	1237	215633	174	Animal related	Overhead Primary		Repair	VI
5133665	S61529	09/23/2015	8:08	09/23/2015	13:45	1	336	336	Underground equipment	Underground Primary	Repair	Repair	VI
5133703	Q28141	09/23/2015	8:48	09/23/2015	9:43	1	54	54	Animal related	Fuse	Replace - Same Size		VI
5133711	U45536	09/23/2015	8:54	09/24/2015	13:00	1	1686	1686	Overhead equipment	Fuse	Replace - Same Size		II
5133729	B81003	09/23/2015	9:06	09/23/2015	10:29	153	12709	83	Animal related	Fuse	Replace - Same Size		I
5133727	N70330	09/23/2015	9:08	09/23/2015	10:27	1	78	78	Weather	Jumper	Replace - Same Size		I
5133737	H88101	09/23/2015	9:18	09/23/2015	10:34	1	75	75	Overhead equipment	Disconnect Switch	Replace - Same Size		II
5133755	B00002	09/23/2015	9:41	09/23/2015	11:20	36	3544	98	Animal related	Fuse	Replace - Same Size		I
5133771	V31002	09/23/2015	10:21	09/23/2015	12:15	1	113	113	Overhead equipment	Overhead Service	Repair		II
5133773	Y89540	09/23/2015	10:24	09/23/2015	10:52	1	27	27	Overhead equipment	Transformer Fuse	Repair	Replace - Same Size	IV
5133789	J34356	09/23/2015	10:25	09/23/2015	12:46	71	7943	140	Overhead equipment	Recloser	Disconnect	Repair	V
5133801	L86175	09/23/2015	10:38	09/23/2015	17:25	80	18429	407	Underground equipment	Underground Primary		Repair	IV
5133803	N70330	09/23/2015	10:44	09/23/2015	11:39	1	54	54	Weather	Jumper	Replace - Same Size		I
5133805	D70005	09/23/2015	10:56	09/23/2015	11:55	1	58	58	Other	Meter	Reconnect		I
5133817	M73329	09/23/2015	11:14	09/23/2015	12:33	1	78	78	Overhead equipment	Overhead Service	Replace - New Size		V
5133819	Q91175	09/23/2015	11:17	09/23/2015	12:55	1	97	97	Animal related	Fuse	Replace - Same Size	Patrol/Test/Inspect	I
5133821	Q91175	09/23/2015	11:18	09/23/2015	13:43	1	144	144	Weather	Transformer Fuse	Replace - Same Size	Patrol/Test/Inspect	I
5133827	J07173	09/23/2015	11:31	09/23/2015	19:36	1	485	484	Overhead equipment	Overhead Transformer	Repair	Replace - Same Size	I
5133841	J34356	09/23/2015	12:14	09/23/2015	13:24	1	69	69	Overhead equipment				V
5133855	M40131	09/23/2015	12:39	09/23/2015	13:44	135	8662	64	Overhead equipment	Recloser	Repair	Replace - Same Size	I
5133849	M40131	09/23/2015	12:41	09/23/2015	13:55	1	73	73	Animal related	Fuse	Repair	Replace - Same Size	I
5133875	D66002	09/23/2015	13:16	09/23/2015	18:00	1	283	283	Public	Fuse	Replace - Same Size		IV
5133883	D66002	09/23/2015	13:32	09/23/2015	17:58	33	8761	265	Public	Fuse	Replace - Same Size		IV
5133891	R33127	09/23/2015	13:50	09/23/2015	16:50	1	179	179	Overhead equipment	Overhead Transformer	Replace - Same Size	Patrol/Test/Inspect	I
5133899	S03530	09/23/2015	13:54	09/23/2015	14:26	1	31	31	Other				VI
5133911	R06209	09/23/2015	14:00	09/23/2015	14:17	21	355	16	Underground equipment	Underground Primary	Repair		II
5133915	H01190	09/23/2015	14:09	09/23/2015	18:00	1	231	231	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	III
5133925	C50001	09/23/2015	14:54	09/23/2015	16:22	6	529	88	Public	Other	Replace - Same Size	Patrol/Test/Inspect	III
5133937	Z06537	09/23/2015	15:05	09/23/2015	22:10	44	3918	424	Public	Pole	Replace - Same Size	Replace - Same Size	IV
5133935	K44-UNIT-1	09/23/2015	15:16	09/23/2015	17:28	1	131	131	Other				V
5133939	B68002	09/23/2015	15:36	09/23/2015	17:30	4	454	113	Overhead equipment	Overhead Primary	Raise		III
5133941	V29001	09/23/2015	15:37	09/23/2015	16:55	1	77	77	Overhead equipment	Overhead Service			II
5133947	R93351	09/23/2015	15:53	09/23/2015	16:14	1	20	20	Overhead equipment	Substation Breaker			V

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5133955	R93351	09/23/2015	15:57	09/23/2015	17:27	14	1262	90	Underground equipment	Underground Primary	Switch/Reset	Repair	V
5133957	U80564	09/23/2015	16:28	09/23/2015	17:45	1	76	76	Tree related-tree broken	Overhead Service	Repair		II
5133967	Q25802	09/23/2015	16:45	09/23/2015	17:30	1	44	44	Public	Overhead Service	Repair	Repair	I
5134001	D70003	09/23/2015	16:53	09/24/2015	5:37	3	2292	764	Underground equipment	Underground Primary	Patrol/Test/Inspect	Patrol/Test/Inspect	I
5133973	P82291	09/23/2015	16:59	09/23/2015	18:14	1	74	74	Animal related	Transformer Fuse	Replace - Same Size		VI
5133977	D69006	09/23/2015	17:07	09/23/2015	18:35	12	1050	87	Unknown	Fuse	Repair	Replace - Same Size	I
5133997	J20931	09/23/2015	17:28	09/23/2015	21:40	1	251	251	Overhead equipment	Overhead Transformer	Replace - Same Size	Replace - Same Size	VI
5134005	P42230	09/23/2015	17:30	09/23/2015	18:44	13	949	73	Underground equipment	Underground Primary		Repair	VI
5134009	J15302	09/23/2015	17:37	09/23/2015	21:23	1	225	225	Overhead equipment	Overhead Transformer	Replace - Same Size	Replace - Same Size	I
5134015	J18268	09/23/2015	17:51	09/23/2015	18:25	5	168	33	Animal related	Transformer Fuse	Replace - Same Size		VI
5134031	V25504	09/23/2015	18:58	09/23/2015	23:25	1	266	266	Underground equipment	Underground Primary	Repair		II
5134033	P07179	09/23/2015	19:16	09/23/2015	22:24	1	187	187	Overhead equipment	Transformer Fuse	Replace - Same Size		I
5134035	X88507	09/23/2015	19:31	09/23/2015	20:21	1	49	49	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
5134037	Z10501	09/23/2015	19:39	09/23/2015	20:28	1	48	48	Overhead equipment	Transformer Fuse			IV
5134041	V25504	09/23/2015	19:47	09/23/2015	23:25	1	217	217	Underground equipment				II
5134057	Y36559	09/23/2015	20:41	09/23/2015	23:42	86	15492	180	Underground equipment	Underground Primary		Repair	IV
5134177	Y36559	09/23/2015	20:42	09/24/2015	4:04	34	8445	441	Underground equipment				IV
5134053	Y36559	09/23/2015	20:45	09/24/2015	4:37	1	471	471	Underground equipment				IV
5134063	P25150	09/23/2015	21:08	09/23/2015	22:35	1	86	86	Overhead equipment	Overhead Service	Repair		III
5134069	Q83168	09/23/2015	22:32	09/24/2015	1:15	1	162	162	Overhead equipment				VI
5134071	Q83168	09/23/2015	22:33	09/24/2015	7:41	234	10974	547	Public				VI
5134073	Q83168	09/23/2015	22:33	09/24/2015	7:41	88	14924	547	Public				VI
5134109	Q83171	09/23/2015	22:35	09/24/2015	7:11	397	76147	515	Overhead equipment				VI
5134077	Q83168	09/23/2015	22:35	09/23/2015	22:50	169	2565	15	Public				VI
5134105	Q83171	09/23/2015	22:42	09/24/2015	7:11	653	116252	508	Public				VI
5134121	Q83168	09/23/2015	22:51	09/24/2015	1:15	1	143	143	Overhead equipment				VI
5134125	Q83168	09/23/2015	22:54	09/23/2015	22:57	169	442	2	Public				VI
5134127	M18131	09/23/2015	22:57	09/23/2015	23:27	1	29	29	Animal related	Transformer Fuse	Replace - Same Size		III
5134131	Q83168	09/23/2015	22:58	09/24/2015	1:15	1	136	136	Overhead equipment				VI
5134137	D69007	09/23/2015	23:01	09/24/2015	1:46	57	9454	165	Underground equipment	Underground Primary	Patrol/Test/Inspect	Patrol/Test/Inspect	I
5134139	Q83168	09/23/2015	23:02	09/23/2015	23:06	169	807	4	Public				VI
5134143	Q83168	09/23/2015	23:07	09/24/2015	1:15	1	127	127	Overhead equipment				VI
5134145	Q83168	09/23/2015	23:07	09/24/2015	1:15	1	127	127	Overhead equipment				VI
5134149	Q83168	09/23/2015	23:08	09/24/2015	1:15	1	126	126	Overhead equipment				VI
5134153	Q83168	09/23/2015	23:19	09/24/2015	1:15	1	115	115	Overhead equipment				VI
5134157	Q83168	09/23/2015	23:20	09/24/2015	1:14	59	6741	114	Public				VI
5134155	Q83168	09/23/2015	23:20	09/24/2015	1:14	169	699	114	Public				VI
5134161	Q83168	09/23/2015	23:26	09/23/2015	23:33	167	1227	7	Public				VI
5134179	Q83168	09/23/2015	23:41	09/24/2015	1:15	1	93	93	Overhead equipment				VI
5134225	Q83168	09/24/2015	0:07	09/24/2015	0:16	167	1419	8	Public				VI
5134227	Q83168	09/24/2015	0:16	09/24/2015	1:15	1	58	58	Overhead equipment				VI
5134237	Q83168	09/24/2015	0:27	09/24/2015	0:40	167	2201	13	Public				VI
5134241	V50001	09/24/2015	0:55	09/24/2015	9:50	1	534	534	Underground equipment	Underground Primary			II
5134247	Y36559	09/24/2015	1:24	09/24/2015	4:04	23	3688	160	Underground equipment				IV
5134261	V50001	09/24/2015	1:36	09/24/2015	9:51	3	1486	495	Underground equipment	Underground Primary			II
5134257	J84124	09/24/2015	4:11	09/24/2015	7:24	12	2316	193	Underground equipment				VI
5134259	F10001	09/24/2015	6:26	09/24/2015	8:22	1	115	115	Public	Overhead Secondary		Replace - Same Size	III
5134263	D35002	09/24/2015	6:31	09/24/2015	11:18	2	574	287	Underground equipment	Underground Primary	Repair	Repair	I
5134265	K32915	09/24/2015	6:32	09/24/2015	8:05	1	92	92	Overhead equipment	Fuse	Replace - Same Size		VI
5134269	D88001	09/24/2015	7:07	09/24/2015	9:22	1	134	134	Animal related	Fuse	Replace - Same Size		I
5134279	V22555	09/24/2015	7:21	09/24/2015	8:42	1	80	80	Overhead equipment	Transformer Fuse	Replace - Same Size		II
5134287	Q80354	09/24/2015	7:42	09/24/2015	9:38	1	115	115	Animal related	Fuse	Replace - Same Size		V
5134313	Q80354	09/24/2015	7:42	09/24/2015	9:34	178	19820	111	Animal related	Fuse	Replace - Same Size		V
5134293	A48002	09/24/2015	7:43	09/24/2015	9:08	22	1851	84	Animal related	Animal Guard	Remove		I
5134309	N35852	09/24/2015	7:49	09/24/2015	8:21	3	94	31	Animal related	Transformer Fuse	Replace - Same Size		V
5134311	P62138	09/24/2015	7:52	09/24/2015	9:38	1	105	105	Overhead equipment	Transformer Fuse	Replace - Same Size		VI

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5134325	T06505	09/24/2015	8:10	09/24/2015	9:02	1	51	51	Animal related	Fuse	Replace - Same Size	Patrol/Test/Inspect	VI
5134355	Q83168	09/24/2015	8:29	09/24/2015	8:32	153	417	2	Public				VI
5134385	L68112	09/24/2015	8:44	09/24/2015	10:45	1	120	120	Overhead equipment	Overhead Transformer		Replace - Same Size	IV
5134391	L23146	09/24/2015	8:53	09/24/2015	9:40	5	233	46	Unknown	Transformer Fuse	Replace - Same Size		III
5134393	P61111	09/24/2015	8:55	09/24/2015	9:40	1	44	44	Overhead equipment	Fuse	Replace - Same Size		VI
5134397	Q91175	09/24/2015	8:59	09/24/2015	11:20	1	140	140	Weather	Transformer Fuse	Replace - Same Size	Patrol/Test/Inspect	I
5134411	K09863	09/24/2015	9:14	09/24/2015	10:02	1	47	47	Animal related	Fuse	Replace - Same Size	Repair	V
5134413	L14232	09/24/2015	9:15	09/24/2015	10:35	1	79	79	Overhead equipment	Overhead Service			III
5134419	Y66556	09/24/2015	9:22	09/24/2015	10:01	1	38	38	Animal related	Transformer Fuse	Replace - Same Size		IV
5134429	Y89535	09/24/2015	9:32	09/24/2015	10:20	8	379	47	Overhead equipment	Transformer Fuse	Repair	Replace - Same Size	IV
5134435	Z57516	09/24/2015	9:46	09/24/2015	11:15	3	266	88	Animal related	Overhead Transformer	Replace - Same Size		IV
5134445	H11340	09/24/2015	10:00	09/24/2015	11:20	93	7382	79	Overhead equipment	Fuse	Replace - Same Size		V
5134449	S07536	09/24/2015	10:01	09/24/2015	11:15	1	73	73	Animal related	Transformer Fuse	Patrol/Test/Inspect	Replace - New Size	VI
5134451	306003	09/24/2015	10:04	09/24/2015	10:35	14	425	30	Tree related-tree broken	Overhead Primary	Patrol/Test/Inspect		VI
5134461	S95571	09/24/2015	10:25	09/24/2015	13:07	1	161	161	Animal related	Transformer Fuse	Replace - Same Size		VI
5134477	326170	09/24/2015	10:40	09/24/2015	12:36	1	115	115	Overhead equipment	Capacitor	Patrol/Test/Inspect		V
5134491	P77233	09/24/2015	10:52	09/24/2015	14:22	1	209	209	Tree related-tree broken	Overhead Primary		Repair	VI
5134511	R01153	09/24/2015	11:10	09/25/2015	6:29	1	1158	1158	Underground equipment	Underground Primary	Repair	Repair	III
5134519	L71171	09/24/2015	11:20	09/24/2015	12:22	1	61	61	Overhead equipment	Fuse	Replace - Same Size		IV
5134521	H11340	09/24/2015	11:20	09/24/2015	11:23	1	2	2	Unknown				V
5134535	R39934	09/24/2015	11:56	09/24/2015	12:56	1	59	59	Overhead equipment	Transformer Fuse	Replace - Same Size		VI
5134539	S88502	09/24/2015	12:01	09/24/2015	12:33	1	31	31	Public	Overhead Secondary	Patrol/Test/Inspect		VI
5134541	P77233	09/24/2015	12:09	09/24/2015	14:15	3	377	125	Tree related-tree broken	Insulator		Replace - Same Size	VI
5134543	N44216	09/24/2015	12:09	09/24/2015	13:13	3	191	63	Overhead equipment	Fuse		Replace - Same Size	III
5134553	J01118	09/24/2015	12:39	09/24/2015	13:30	1	50	50	Animal related	Fuse	Repair	Replace - Same Size	I
5134565	X82003	09/24/2015	13:01	09/24/2015	17:46	1	284	284	Underground equipment	Underground Service	Repair	Repair	IV
5134595	R16510	09/24/2015	13:41	09/24/2015	15:30	1	108	108	Overhead equipment	Transformer Fuse	Repair	Repair	I
5134597	S43502	09/24/2015	13:49	09/24/2015	15:23	2	187	93	Overhead equipment	Transformer Fuse	Replace - New Size		VI
5134605	S27598	09/24/2015	14:01	09/24/2015	14:29	1	27	27	Overhead equipment				VI
5134607	U92593	09/24/2015	14:04	09/24/2015	15:25	1	80	80	Animal related	Transformer Fuse	Replace - Same Size		II
5134609	D36002	09/24/2015	14:06	09/25/2015	9:26	1	1159	1159	Unknown	Overhead Transformer			I
5134613	K28180	09/24/2015	14:12	09/24/2015	16:05	5	564	112	Public	Pole	Repair	Replace - Same Size	III
5134621	R39934	09/24/2015	14:41	09/24/2015	16:42	3	360	120	Overhead equipment	Fuse	Replace - Same Size		VI
5134623	M19222	09/24/2015	14:47	09/24/2015	15:28	8	326	40	Overhead equipment	Fuse	Replace - Same Size		VI
5134639	B71002	09/24/2015	15:18	09/24/2015	21:14	1	355	355	Unknown	Overhead Service			I
5134643	D37003	09/24/2015	15:22	09/24/2015	19:14	26	6030	231	Tree related-tree broken	Overhead Primary	Patrol/Test/Inspect	Raise	I
5134657	L08225	09/24/2015	15:36	09/24/2015	20:23	42	12019	286	Public	Overhead Transformer	Replace - Same Size		III
5134659	D88002	09/24/2015	15:41	09/24/2015	17:05	3	250	83	Overhead equipment	Fuse	Patrol/Test/Inspect	Repair	I
5134661	L08225	09/24/2015	15:50	09/24/2015	18:27	12	1877	156	Public	Fuse	Replace - Same Size		III
5134671	P98192	09/24/2015	16:40	09/24/2015	17:49	1	68	68	Jurisdictional	Other			III
5134675	U44529	09/24/2015	17:01	09/24/2015	18:08	1	66	66	Overhead equipment	Transformer Fuse	Repair	Repair	II
5134679	S78551	09/24/2015	17:37	09/24/2015	18:30	1	52	52	Animal related	Transformer Fuse			VI
5134685	M21133	09/24/2015	18:21	09/24/2015	19:00	1	38	38	Overhead equipment	Fuse	Repair	Replace - Same Size	VI
5134687	Q75146	09/24/2015	18:25	09/24/2015	19:00	1	34	34	Animal related	Fuse	Replace - Same Size		VI
5134701	U31598	09/24/2015	20:18	09/24/2015	21:15	13	732	56	Overhead equipment	Lightning Arrestor	Repair		II
5134705	J58380	09/24/2015	20:33	09/24/2015	22:03	1	90	90	Unknown	Fuse			III
5134715	K46389	09/24/2015	22:39	09/25/2015	1:42	4	731	182	Tree related-tree contact	Transformer Fuse	Replace - Same Size		V
5134717	L08225	09/24/2015	22:57	09/25/2015	0:06	1	68	68	Public	Lightning Arrestor	Replace - Same Size		III
5134723	R48168	09/25/2015	0:38	09/25/2015	2:45	7	887	127	Underground equipment	Underground Primary	Repair		IV
5134725	K08909	09/25/2015	1:41	09/25/2015	3:16	4	381	95	Overhead equipment	Fuse		Patrol/Test/Inspect	VI
5134741	Q83152	09/25/2015	5:09	09/25/2015	6:02	132	6999	53	Public				VI
5134745	D35003	09/25/2015	6:20	09/25/2015	7:29	1	68	68	Animal related	Fuse	Replace - Same Size		I
5134747	D69006	09/25/2015	6:41	09/25/2015	13:14	1	393	393	Underground equipment	Underground Primary	Repair	Repair	I
5134751	Y36541	09/25/2015	7:09	09/25/2015	7:58	1	48	48	Overhead equipment	Transformer Fuse			IV
5134753	S93507	09/25/2015	7:36	09/25/2015	8:24	1	47	47	Animal related	Transformer Fuse	Replace - Same Size		VI
5134759	J18267	09/25/2015	7:51	09/25/2015	9:08	1	76	76	Animal related	Transformer Fuse	Replace - Same Size		VI

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5134763	U54516	09/25/2015	8:08	09/25/2015	10:10	1	121	121	Overhead equipment	Transformer Fuse	Replace - Same Size	Replace - Same Size	II
5134765	M78325	09/25/2015	8:12	09/25/2015	9:25	1	72	72	Overhead equipment	Fuse	Replace - Same Size		V
5134769	A49001	09/25/2015	8:20	09/25/2015	10:00	4	399	99	Animal related	Fuse	Replace - Same Size		I
5134775	K19114	09/25/2015	8:43	09/25/2015	9:28	12	536	44	Public	Overhead Primary	Replace - Same Size	Replace - Same Size	VI
5134777	Q80353	09/25/2015	8:44	09/25/2015	9:22	1	37	37	Animal related	Transformer Fuse	Replace - Same Size		V
5134803	K15205	09/25/2015	9:24	09/25/2015	10:23	9	530	58	Animal related	Transformer Fuse	Replace - Same Size		VI
5134807	L71171	09/25/2015	9:28	09/25/2015	10:11	1	42	42	Animal related	Transformer Fuse	Replace - Same Size		IV
5134809	K32916	09/25/2015	9:32	09/25/2015	10:24	1	51	51	Animal related	Fuse	Replace - Same Size		VI
5134845	J87150	09/25/2015	10:28	09/25/2015	16:29	410	21346	361	Overhead equipment	Overhead Primary	Reconnect	Repair	VI
5134869	B35002	09/25/2015	10:46	09/25/2015	11:20	1	33	33	Animal related	Transformer Fuse	Replace - Same Size		I
5134873	HC9327	09/25/2015	10:54	09/25/2015	11:55	1	60	60	Animal related				VI
5134885	HC9327	09/25/2015	11:11	09/25/2015	14:01	1	169	169	Overhead equipment	Fuse			VI
5134887	L93149	09/25/2015	11:11	09/25/2015	13:30	1	138	138	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	VI
5134889	HC9327	09/25/2015	11:13	09/25/2015	11:43	1	29	29	Animal related				VI
5134895	Q32170	09/25/2015	11:38	09/25/2015	13:01	1	82	82	Weather	Transformer Fuse	Replace - Same Size	Patrol/Test/Inspect	I
5134897	K31124	09/25/2015	11:40	09/25/2015	12:58	1	77	77	Overhead equipment	Transformer Fuse	Replace - Same Size		I
5134899	N95824	09/25/2015	11:41	09/25/2015	12:25	1	43	43	Animal related	Transformer Fuse	Replace - Same Size		V
5134907	B62003	09/25/2015	12:18	09/25/2015	14:06	17	1833	107	Animal related	Fuse	Replace - Same Size		I
5134909	K57211	09/25/2015	12:18	09/25/2015	13:51	1	92	92	Animal related	Transformer Fuse	Repair	Replace - Same Size	VI
5134917	R01152	09/25/2015	12:33	09/25/2015	13:10	1	36	36	Tree related-tree broken	Transformer Fuse	Repair	Repair	III
5134925	S93507	09/25/2015	12:45	09/25/2015	14:05	1	79	79	Other				VI
5134927	R58961	09/25/2015	12:47	09/25/2015	13:37	5	248	49	Animal related	Transformer Fuse	Replace - Same Size		IV
5134933	U94573	09/25/2015	13:21	09/25/2015	14:30	1	68	68	Overhead equipment	Transformer Fuse	Replace - Same Size	Replace - Same Size	II
5134937	N93260	09/25/2015	13:22	09/25/2015	15:42	70	9740	139	Overhead equipment	Overhead Primary			III
5134947	L68115	09/25/2015	13:38	09/25/2015	17:06	1	207	207	Overhead equipment	Overhead Service	Repair		IV
5134959	X02549	09/25/2015	14:31	09/25/2015	15:55	1	83	83	Animal related	Transformer Fuse	Replace - Same Size		IV
5134973	M40132	09/25/2015	14:50	09/25/2015	19:58	147	16552	307	Public	Pole	Switch/Reset	Replace - New Size	I
5134981	R49261	09/25/2015	15:11	09/25/2015	18:46	2	430	214	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	VI
5134985	L62927	09/25/2015	15:14	09/25/2015	16:18	61	3859	63	Overhead equipment	Fuse	Repair		VI
5134989	M18131	09/25/2015	15:22	09/25/2015	18:58	13	686	215	Overhead equipment	Pole		Replace - Same Size	III
5134995	C50001	09/25/2015	15:43	09/25/2015	17:30	1	106	106	Overhead equipment	Connector	Replace - Same Size		III
5134999	M81402	09/25/2015	16:00	09/25/2015	16:34	1	33	33	Animal related	Transformer Fuse	Repair		V
5135009	P07179	09/25/2015	16:24	09/25/2015	19:39	1	194	194	Overhead equipment	Transformer Fuse	Replace - Same Size		I
5135015	P17109	09/25/2015	16:45	09/25/2015	17:54	1	68	68	Animal related	Transformer Fuse	Replace - Same Size		IV
5135019	D89002	09/25/2015	17:03	09/26/2015	3:16	63	10734	613	Underground equipment	Underground Primary	Switch/Reset	Switch/Reset	I
5135023	Q27185	09/25/2015	17:28	09/25/2015	18:09	5	203	40	Overhead equipment	Overhead Secondary	Replace - Same Size		VI
5135045	Y04504	09/25/2015	18:16	09/25/2015	19:59	30	3083	102	Overhead equipment	Fuse	Replace - Same Size		IV
5135035	S52515	09/25/2015	18:17	09/25/2015	20:10	1	112	112	Tree related-tree broken	Overhead Service	Repair	Repair	VI
5135039	R94269	09/25/2015	18:49	09/25/2015	23:20	2	541	270	Public	Pole		Replace - Same Size	VI
5135043	A81004	09/25/2015	18:49	09/25/2015	22:06	139	13043	196	Overhead equipment	Overhead Primary	Patrol/Test/Inspect	Raise	I
5135055	K89144	09/25/2015	18:55	09/25/2015	20:47	27	1431	112	Tree related-tree broken	Tree	Remove	Remove	III
5135053	K46389	09/25/2015	18:58	09/25/2015	20:37	14	1395	99	Overhead equipment	Riser		Repair	V
5135057	K22173	09/25/2015	18:59	09/25/2015	20:05	1	65	65	Animal related	Transformer Fuse	Replace - Same Size		VI
5135065	L17102	09/25/2015	19:44	09/25/2015	20:29	7	311	44	Animal related	Transformer Fuse	Replace - Same Size		III
5135073	V40549	09/25/2015	20:27	09/25/2015	22:19	7	782	111	Overhead equipment	Transformer Fuse	Replace - Same Size		II
5135079	A81001	09/25/2015	21:51	09/26/2015	0:27	79	12298	155	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
5135081	P09304	09/25/2015	22:00	09/26/2015	0:40	1	159	159	Overhead equipment	Connector	Repair		V
5135087	R60551	09/25/2015	22:36	09/25/2015	23:46	1	70	69	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
5135089	B08003	09/26/2015	0:01	09/26/2015	6:10	16	5891	368	Overhead equipment	Fuse	Patrol/Test/Inspect	Replace - Same Size	I
5135301	Q91-UNIT-1	09/26/2015	0:31	09/26/2015	2:30	1602	190349	118	Public	Pole	Repair		I
5135349	Q32-UNIT-1	09/26/2015	0:31	09/26/2015	11:06	1973	1253130	635	Public	Pole	Patrol/Test/Inspect	Replace - New Size	I
5135369	Q31-UNIT-1	09/26/2015	0:31	09/26/2015	11:00	1	628	628	Public	Pole			I
5135417	R34-X1	09/26/2015	2:42	09/26/2015	4:45	734	90296	123	Unknown				VI
5135375	R39-X1	09/26/2015	2:44	09/26/2015	4:46	945	115006	121	Unknown				VI
5135411	R89-UNIT-1	09/26/2015	2:47	09/26/2015	4:41	232	26448	113	Unknown				VI
5135443	A97003	09/26/2015	4:04	09/26/2015	8:12	47	11639	247	Underground equipment	Underground Primary	Patrol/Test/Inspect	Patrol/Test/Inspect	I

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5135439	351001	09/26/2015	4:23	09/26/2015	4:55	1	31	31	Public	Meter	Disconnect		VI
5135445	A73002	09/26/2015	4:58	09/26/2015	11:51	10	4131	413	Underground equipment	Underground Primary		Repair	I
5135569	A73002	09/26/2015	5:29	09/26/2015	14:58	4	2275	568	Underground equipment	Underground Primary	Repair	Repair	I
5135463	D01001	09/26/2015	6:32	09/26/2015	10:45	27	6811	252	Unknown	Fuse	Patrol/Test/Inspect	Replace - Same Size	I
5135469	B08004	09/26/2015	7:42	09/26/2015	8:26	36	1550	43	Animal related				I
5135471	B80004	09/26/2015	7:51	09/26/2015	9:10	12	941	78	Animal related	Fuse	Replace - Same Size		I
5135491	P77235	09/26/2015	8:35	09/26/2015	10:14	1	99	98	Overhead equipment	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
5135497	L86175	09/26/2015	8:58	09/26/2015	9:59	58	3558	61	Overhead equipment	Fuse	Replace - Same Size		IV
5135503	L86175	09/26/2015	9:09	09/26/2015	11:55	1	165	165	Overhead equipment	Fuse	Replace - Same Size		IV
5135505	L86175	09/26/2015	9:21	09/26/2015	11:55	1	153	153	Overhead equipment	Fuse	Replace - Same Size		IV
5135509	313136	09/26/2015	9:28	09/26/2015	13:05	7	1516	216	Public	Underground Service	Disconnect	Repair	V
5135519	R04415	09/26/2015	9:29	09/26/2015	20:12	70	5920	642	Underground equipment	Underground Transformer	Disconnect	Replace - Same Size	V
5135515	K28180	09/26/2015	9:46	09/26/2015	11:15	1	88	88	Animal related	Fuse	Replace - Same Size		III
5135517	M83327	09/26/2015	9:48	09/26/2015	14:27	4	1115	278	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	V
5135523	L86175	09/26/2015	9:59	09/26/2015	11:58	5	590	118	Overhead equipment	Disconnect Switch	Replace - Same Size		IV
5135525	L86175	09/26/2015	10:00	09/26/2015	11:56	5	579	115	Overhead equipment	Disconnect Switch	Replace - Same Size		IV
5135529	T23527	09/26/2015	10:02	09/27/2015	2:39	19	7688	997	Underground equipment	Underground Primary	Repair		VI
5135531	X69554	09/26/2015	10:05	09/26/2015	10:51	1	45	45	Animal related	Transformer Fuse			IV
5135535	A49003	09/26/2015	10:21	09/26/2015	13:38	71	13995	197	Underground equipment	Other	Repair	Repair	I
5135539	V42586	09/26/2015	10:21	09/26/2015	11:25	1	63	63	Animal related	Transformer Fuse	Replace - Same Size		II
5135545	N93260	09/26/2015	10:44	09/26/2015	11:50	1	65	65	Unknown	Transformer Fuse			III
5135579	Q32170	09/26/2015	11:18	09/26/2015	13:44	33	4809	145	Overhead equipment	Recloser			I
5135557	P49183	09/26/2015	11:20	09/26/2015	12:31	7	497	71	Unknown	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	I
5135561	Q32170	09/26/2015	11:24	09/26/2015	11:42	1	18	18	Overhead equipment	Pole			I
5135563	A36001	09/26/2015	11:32	09/26/2015	14:00	4	588	147	Animal related	Fuse	Replace - Same Size		I
5135573	N44217	09/26/2015	11:57	09/26/2015	12:49	1	51	51	Overhead equipment	Connector			III
5135577	B73001	09/26/2015	12:00	09/26/2015	13:00	1	59	59	Weather	Transformer Fuse	Replace - Same Size	Replace - Same Size	I
5135581	Q32170	09/26/2015	12:05	09/26/2015	14:03	1	117	117	Overhead equipment	Overhead Transformer	Replace - Same Size	Patrol/Test/Inspect	I
5135583	Q24313	09/26/2015	12:09	09/26/2015	13:19	1	69	69	Animal related	Transformer Fuse	Replace - Same Size		VI
5135597	Q83172	09/26/2015	13:07	09/26/2015	14:50	1	102	102	Overhead equipment	Overhead Transformer	Repair	Replace - Same Size	VI
5135613	L93133	09/26/2015	14:12	09/26/2015	16:58	42	6967	165	Tree related-tree broken	Overhead Primary	Patrol/Test/Inspect	Replace - Same Size	VI
5135615	Q32170	09/26/2015	14:26	09/26/2015	18:26	1	239	239	Overhead equipment	Fuse	Replace - Same Size	Patrol/Test/Inspect	I
5135617	Q32170	09/26/2015	14:27	09/26/2015	14:50	1	22	22	Overhead equipment	Transformer Fuse	Replace - Same Size	Patrol/Test/Inspect	I
5135619	L81141	09/26/2015	14:42	09/26/2015	17:35	1	172	172	Overhead equipment				IV
5135623	Y35515	09/26/2015	14:45	09/26/2015	15:47	88	5379	61	Overhead equipment	Fuse			IV
5135629	R84148	09/26/2015	14:57	09/26/2015	16:00	1	62	62	Overhead equipment	Jumper	Repair		I
5135631	R08910	09/26/2015	15:23	09/26/2015	16:30	1	66	66	Animal related	Transformer Fuse	Replace - Same Size		VI
5135633	Q32170	09/26/2015	15:30	09/26/2015	17:10	1	99	99	Overhead equipment	Fuse	Replace - Same Size	Patrol/Test/Inspect	I
5135637	S15558	09/26/2015	15:45	09/26/2015	16:45	1	59	59	Animal related	Transformer Fuse	Replace - Same Size		VI
5135639	Q15844	09/26/2015	16:08	09/26/2015	18:03	32	3652	114	Overhead equipment				V
5135645	J99141	09/26/2015	16:30	09/26/2015	17:33	49	3083	62	Overhead equipment	Fuse	Replace - Same Size		VI
5135651	M47802	09/26/2015	17:07	09/26/2015	19:15	3	382	127	Animal related				V
5135655	U54503	09/26/2015	17:22	09/26/2015	23:54	1	391	391	Underground equipment	Underground Primary	Repair		II
5135657	K39154	09/26/2015	17:23	09/26/2015	19:00	7	681	97	Underground equipment	Underground Primary		Repair	III
5135659	M81403	09/26/2015	17:31	09/26/2015	18:06	12	418	34	Animal related	Transformer Fuse	Replace - Same Size		V
5135661	Q27185	09/26/2015	17:43	09/26/2015	18:31	1	47	47	Animal related	Fuse	Replace - Same Size		VI
5135663	Y11556	09/26/2015	18:06	09/26/2015	19:35	7	622	88	Animal related	Transformer Fuse	Replace - Same Size		IV
5135665	K69117	09/26/2015	18:17	09/26/2015	19:34	44	3383	76	Overhead equipment	Fuse	Replace - Same Size		IV
5135669	P52305	09/26/2015	18:23	09/26/2015	21:41	1	197	197	Overhead equipment	Overhead Service	Repair		IV
5135681	D90002	09/26/2015	19:44	09/26/2015	23:15	1	210	210	Other	Overhead Secondary	Replace - Same Size	Repair	III
5135683	U54503	09/26/2015	19:56	09/26/2015	23:54	1	238	238	Underground equipment	Underground Primary	Repair		II
5135685	T23527	09/26/2015	20:11	09/26/2015	21:30	37	2906	78	Underground equipment				VI
5135693	Q74149	09/26/2015	20:44	09/26/2015	22:28	1	103	103	Animal related	Transformer Fuse	Replace - Same Size		IV
5135697	J20931	09/26/2015	21:14	09/26/2015	22:54	27	2690	99	Animal related	Fuse	Replace - Same Size		VI
5135703	A97001	09/26/2015	21:32	09/27/2015	1:02	1	209	209	Other	Fuse	Replace - Same Size		I
5135707	B80003	09/26/2015	22:20	09/27/2015	6:44	1	503	503	Underground equipment	Underground Service	Patrol/Test/Inspect	Repair	I

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5135711	R01152	09/26/2015	22:27	09/26/2015	23:18	1	50	50	Animal related	Fuse	Replace - Same Size		III
5135719	T23527	09/27/2015	0:38	09/27/2015	2:27	8	870	108	Underground equipment	Underground Primary	Repair		VI
5135723	L36214	09/27/2015	2:00	09/27/2015	3:10	30	2094	69	Public				III
5135725	L24124	09/27/2015	2:11	09/27/2015	4:13	3	364	121	Overhead equipment	Fuse	Repair		III
5135727	L36214	09/27/2015	2:22	09/27/2015	3:14	1	51	51	Public				III
5135731	L36214	09/27/2015	2:38	09/27/2015	3:15	1	36	36	Public				III
5135735	L36214	09/27/2015	3:04	09/27/2015	3:17	1	12	12	Public				III
5135739	332005	09/27/2015	4:07	09/27/2015	10:35	8	3099	387	Public	Pole	Repair		VI
5135743	S62520	09/27/2015	6:57	09/27/2015	8:03	3	195	65	Animal related	Transformer Fuse	Replace - New Size		VI
5135745	D69006	09/27/2015	7:04	09/27/2015	11:05	9	2166	240	Underground equipment	Fuse	Patrol/Test/Inspect	Replace - Same Size	I
5135747	V65549	09/27/2015	7:11	09/27/2015	9:17	7	876	125	Animal related	Transformer Fuse	Replace - Same Size		II
5135749	D90002	09/27/2015	7:11	09/27/2015	8:32	1	80	80	Overhead equipment	Overhead Service	Repair		III
5135751	J15302	09/27/2015	7:20	09/27/2015	9:55	1	154	154	Animal related	Fuse	Replace - Same Size		I
5135787	Y68582	09/27/2015	7:43	09/27/2015	9:35	1	111	111	Animal related	Transformer Fuse	Replace - Same Size	Replace - Same Size	IV
5135803	B93002	09/27/2015	7:56	09/27/2015	13:23	7	2082	326	Underground equipment	Underground Primary	Patrol/Test/Inspect		I
5135807	T09530	09/27/2015	8:29	09/27/2015	9:50	4	323	80	Animal related	Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
5135829	T29561	09/27/2015	8:56	09/27/2015	16:00	9	3815	423	Underground equipment	Underground Primary	Replace - Same Size	Replace - Same Size	VI
5135835	R60552	09/27/2015	9:25	09/27/2015	10:44	5	391	78	Animal related	Fuse	Replace - Same Size		IV
5135839	P69174	09/27/2015	9:40	09/27/2015	10:55	30	2229	74	Unknown	Fuse	Replace - Same Size		III
5135841	V42572	09/27/2015	9:52	09/27/2015	11:40	21	2265	107	Unknown	Fuse	Replace - Same Size	Replace - Same Size	II
5135845	K28180	09/27/2015	10:03	09/27/2015	14:26	1	262	262	Animal related	Transformer Fuse	Replace - Same Size		III
5135847	P69174	09/27/2015	10:13	09/27/2015	11:00	1	46	46	Unknown	Fuse	Replace - Same Size		III
5135849	HD0573	09/27/2015	10:21	09/27/2015	12:05	186	954	103	Underground equipment	Underground Primary	Repair	Replace - Same Size	VI
5135851	HD0573	09/27/2015	10:21	09/27/2015	12:05	159	16507	103	Other				VI
5135855	V42572	09/27/2015	10:24	09/27/2015	11:43	1	78	78	Unknown	Fuse	Replace - Same Size	Replace - Same Size	II
5135861	T16527	09/27/2015	10:30	09/27/2015	13:07	1	157	156	Animal related	Transformer Fuse	Replace - New Size		VI
5135873	D69006	09/27/2015	11:03	09/27/2015	14:19	2	390	195	Underground equipment	Underground Primary	Repair		I
5135875	Y82587	09/27/2015	11:06	09/27/2015	15:17	1	250	250	Underground equipment	Underground Transformer	Patrol/Test/Inspect	Replace - Same Size	IV
5135885	Y86593	09/27/2015	12:13	09/27/2015	14:46	1	152	152	Animal related	Transformer Fuse	Repair	Patrol/Test/Inspect	IV
5135887	N67309	09/27/2015	12:23	09/27/2015	15:20	1	176	176	Overhead equipment	Overhead Transformer	Replace - Same Size		I
5135893	N54107	09/27/2015	12:49	09/27/2015	14:18	7	620	88	Animal related	Fuse	Replace - Same Size		II
5135895	M61302	09/27/2015	13:07	09/27/2015	14:10	1	62	62	Animal related	Fuse	Replace - Same Size	Replace - Same Size	V
5135897	D66001	09/27/2015	13:11	09/27/2015	18:37	45	14672	326	Underground equipment				IV
5135907	B25001	09/27/2015	13:18	09/27/2015	14:28	24	1671	69	Unknown	Disconnect Switch	Replace - Same Size	Replace - Same Size	I
5135909	P25150	09/27/2015	13:51	09/27/2015	15:32	42	4233	100	Animal related	Fuse	Replace - Same Size		III
5135911	R84148	09/27/2015	13:52	09/27/2015	15:20	1	87	87	Animal related	Transformer Fuse	Replace - Same Size		I
5135917	Y89535	09/27/2015	14:00	09/27/2015	16:06	1	125	125	Public	Underground Service	Repair	Replace - Same Size	IV
5135919	N19371	09/27/2015	14:14	09/27/2015	15:25	4	283	70	Animal related	Underground Primary	Patrol/Test/Inspect	Repair	V
5135933	Q80353	09/27/2015	15:08	09/27/2015	17:13	9	1121	124	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	V
5154985	P73182	09/27/2015	15:18	09/27/2015	16:38	19	1505	79	Animal related				VI
5135941	K36251	09/27/2015	15:30	09/27/2015	17:00	5	445	89	Unknown	Overhead Transformer	Switch/Reset		III
5135951	U28510	09/27/2015	16:42	09/27/2015	18:39	1	116	116	Tree related-tree contact	Overhead Service	Repair		II
5135953	L81141	09/27/2015	18:37	09/27/2015	19:15	3	111	37	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
5135957	J01118	09/27/2015	19:17	09/27/2015	21:39	11	1566	142	Underground equipment	Underground Primary	Switch/Reset	Repair	I
5135961	M78323	09/27/2015	19:55	09/27/2015	21:12	1	76	76	Animal related	Connector	Replace - Same Size	Replace - Same Size	V
5135963	X66582	09/27/2015	20:00	09/27/2015	21:20	4	319	79	Animal related	Transformer Fuse	Replace - Same Size	Replace - Same Size	IV
5135967	K43385	09/27/2015	20:32	09/27/2015	22:25	1	112	112	Animal related	Transformer Fuse	Replace - Same Size		V
5135971	T03582	09/27/2015	20:53	09/27/2015	22:06	1	72	72	Overhead equipment	Transformer Fuse	Replace - Same Size	Replace - Same Size	VI
5135975	J71128	09/27/2015	21:56	09/27/2015	22:55	1	58	58	Tree related-tree broken	Overhead Service	Repair		I
5135977	V88001	09/27/2015	22:56	09/28/2015	0:20	1	83	83	Overhead equipment	Overhead Service	Repair		II
5135985	Z17503	09/27/2015	23:33	09/28/2015	6:50	52	22272	437	Underground equipment	Underground Primary	Repair	Repair	IV
5135989	X19561	09/28/2015	0:54	09/28/2015	4:19	3	612	204	Tree related-tree broken	Overhead Secondary	Repair	Repair	IV
5135991	D69003	09/28/2015	4:10	09/28/2015	7:25	58	11283	194	Underground equipment	Fuse	Replace - Same Size	Replace - Same Size	I
5135997	N94180	09/28/2015	4:19	09/28/2015	6:05	1	105	105	Animal related	Transformer Fuse	Replace - Same Size		I
5135999	P83705	09/28/2015	4:40	09/28/2015	8:24	1	223	223	Overhead equipment	Transformer Fuse	Patrol/Test/Inspect		I
5136001	Q24313	09/28/2015	5:40	09/28/2015	7:04	1	83	83	Overhead equipment	Transformer Fuse			VI

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5136005	K27153	09/28/2015	6:48	09/28/2015	7:40	1	51	51	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	VI
5136007	S86582	09/28/2015	6:58	09/28/2015	7:40	35	1460	41	Animal related	Fuse	Replace - Same Size		VI
5136021	S78551	09/28/2015	7:13	09/28/2015	8:31	1	77	77	Animal related	Transformer Fuse			VI
5136023	V74506	09/28/2015	7:25	09/28/2015	8:20	1	54	54	Animal related	Fuse	Replace - Same Size		II
5136035	H94-UNIT-1	09/28/2015	7:39	09/28/2015	12:57	1	317	317	Substation equipment				I
5136025	D32212	09/28/2015	7:48	09/28/2015	8:30	1	41	41	Overhead equipment	Fuse	Repair		I
5136027	R48167	09/28/2015	7:58	09/28/2015	8:46	1	48	47	Overhead equipment	Fuse	Replace - Same Size		IV
5136045	K22173	09/28/2015	8:39	09/28/2015	9:40	1	60	60	Animal related	Transformer Fuse	Repair	Repair	VI
5136049	K46389	09/28/2015	8:49	09/28/2015	9:37	3	141	47	Tree related-tree contact				V
5136053	L59933	09/28/2015	8:56	09/28/2015	9:22	6	150	25	Animal related	Fuse	Replace - Same Size		VI
5136061	X64003	09/28/2015	9:17	09/28/2015	10:39	1	81	81	Public	Overhead Service	Disconnect		IV
5136063	B82002	09/28/2015	9:18	09/28/2015	10:13	1	54	54	Overhead equipment	Fuse	Repair		I
5136065	S31532	09/28/2015	9:21	09/28/2015	10:40	6	473	78	Overhead equipment	Transformer Fuse	Replace - Same Size		VI
5136067	S55534	09/28/2015	9:23	09/28/2015	16:22	1	419	419	Underground equipment	Underground Primary	Repair	Replace - Same Size	VI
5136073	R33126	09/28/2015	9:43	09/28/2015	11:02	1	78	78	Weather	Transformer Fuse	Replace - Same Size	Patrol/Test/Inspect	I
5136091	B35002	09/28/2015	9:43	09/28/2015	11:10	99	8551	86	Animal related	Recloser			I
5136099	D89002	09/28/2015	10:08	09/28/2015	17:44	1	456	456	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
5136139	C52001	09/28/2015	11:06	09/28/2015	12:29	37	3067	82	Overhead equipment	Fuse	Replace - Same Size		III
5136155	R60552	09/28/2015	11:20	09/28/2015	13:39	1	138	138	Overhead equipment	Jumper	Patrol/Test/Inspect	Repair	IV
5136173	R73841	09/28/2015	12:05	09/28/2015	13:12	17	1128	66	Jurisdictional	Underground Primary			V
5136175	B73001	09/28/2015	12:07	09/28/2015	13:15	1	67	67	Unknown	Fuse	Replace - Same Size		I
5136179	M61302	09/28/2015	12:13	09/28/2015	13:33	1	79	79	Public	Pole		Replace - Same Size	V
5136203	A48005	09/28/2015	13:23	09/28/2015	14:08	1	44	44	Overhead equipment	Connector	Replace - Same Size	Replace - Same Size	I
5136213	R33127	09/28/2015	13:51	09/28/2015	14:35	1	43	43	Unknown	Transformer Fuse	Replace - Same Size		I
5136215	V19002	09/28/2015	13:55	09/28/2015	15:13	12	929	77	Animal related	Fuse	Replace - Same Size		II
5136219	K74162	09/28/2015	14:04	09/28/2015	14:56	29	1487	51	Unknown	Fuse	Replace - Same Size		IV
5136239	Q18242	09/28/2015	14:39	09/28/2015	16:13	45	4206	93	Animal related	Fuse	Replace - Same Size		VI
5136249	S25551	09/28/2015	14:56	09/28/2015	18:00	1	183	183	Overhead equipment	Overhead Transformer	Repair	Repair	VI
5136255	M21133	09/28/2015	15:00	09/28/2015	19:55	1	294	294	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	VI
5136263	D39002	09/28/2015	15:12	09/28/2015	16:30	8	617	77	Overhead equipment	Overhead Primary	Repair		I
5136269	L11242	09/28/2015	15:33	09/28/2015	15:55	13	279	21	Animal related	Transformer Fuse	Replace - Same Size		III
5136271	L11242	09/28/2015	15:38	09/28/2015	15:55	1	16	16	Animal related	Transformer Fuse	Replace - Same Size		III
5136281	L00134	09/28/2015	16:02	09/28/2015	18:04	42	5108	121	Underground equipment	Underground Primary	Repair		III
5136283	L24124	09/28/2015	16:05	09/28/2015	18:04	1	118	118	Underground equipment	Underground Primary	Repair		III
5136285	A17024	09/28/2015	16:06	09/28/2015	23:38	1	451	451	Underground equipment	Disconnect Switch	Replace - Same Size	Replace - Same Size	I
5136287	L00134	09/28/2015	16:16	09/28/2015	18:04	1	107	107	Underground equipment	Underground Primary	Repair		III
5136291	Q75146	09/28/2015	16:31	09/28/2015	17:21	1	49	49	Overhead equipment	Overhead Primary		Replace - Same Size	VI
5136295	Y50003	09/28/2015	16:37	09/28/2015	17:50	1	72	72	Overhead equipment	Overhead Service	Repair		IV
5136299	E05002	09/28/2015	16:41	09/28/2015	17:55	51	3731	73	Underground equipment	Underground Primary		Repair	IV
5136303	Q95249	09/28/2015	16:54	09/28/2015	17:41	1	46	46	Animal related	Fuse	Replace - Same Size		VI
5136307	M40132	09/28/2015	17:06	09/28/2015	18:30	47	3948	83	Public	Underground Primary	Switch/Reset	Repair	I
5136309	K39154	09/28/2015	17:14	09/28/2015	18:56	1	101	101	Unknown	Transformer Fuse	Replace - Same Size		III
5136313	T23528	09/28/2015	17:37	09/28/2015	18:32	1	54	54	Overhead equipment	Fuse		Replace - Same Size	VI
5136681	J14140	09/28/2015	17:37	09/28/2015	19:57	1	139	139	Overhead equipment	Overhead Transformer	Replace - Same Size	Replace - Same Size	VI
5136647	R08-X1	09/28/2015	18:20	09/28/2015	19:20	369	22029	59	Overhead equipment				VI
5136371	J20-UNIT-1	09/28/2015	18:20	09/28/2015	19:21	565	34024	60	Overhead equipment	Overhead Primary	Replace - Same Size	Repair	VI
5136539	Q69-X1	09/28/2015	18:21	09/28/2015	22:04	630	140162	222	Overhead equipment				VI
5136485	Q82-X1	09/28/2015	18:22	09/28/2015	22:03	1412	311557	220	Overhead equipment				VI
5136735	Q54908	09/28/2015	18:57	09/28/2015	22:21	1	203	203	Overhead equipment	Overhead Primary	Replace - Same Size	Replace - Same Size	VI
5136737	L79157	09/28/2015	18:59	09/28/2015	20:34	4	379	94	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
5136739	X88507	09/28/2015	19:01	09/28/2015	23:33	1	271	271	Overhead equipment	Overhead Transformer	Replace - Same Size	Replace - Same Size	IV
5136741	R08910	09/28/2015	19:20	09/28/2015	22:16	1	175	175	Overhead equipment	Overhead Primary	Replace - Same Size	Replace - Same Size	VI
5136743	J20931	09/28/2015	19:21	09/28/2015	22:38	1	196	196	Overhead equipment	Overhead Primary	Replace - Same Size	Replace - Same Size	VI
5136751	J20931	09/28/2015	20:32	09/28/2015	22:23	1	110	110	Overhead equipment	Overhead Primary	Replace - Same Size	Replace - Same Size	VI
5136753	L59929	09/28/2015	21:05	09/28/2015	22:28	1	82	82	Overhead equipment	Overhead Primary	Replace - Same Size	Replace - Same Size	VI
5136755	J20931	09/28/2015	22:00	09/28/2015	22:27	1	26	26	Overhead equipment	Overhead Primary	Replace - Same Size	Replace - Same Size	VI

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5136759	L23146	09/28/2015	22:57	09/28/2015	23:50	1	52	52	Overhead equipment	Overhead Service	Repair		III
5136761	R60552	09/28/2015	23:05	09/29/2015	1:27	15	2124	141	Underground equipment	Underground Primary	Switch/Reset	Repair	IV
5136765	B82002	09/29/2015	1:16	09/29/2015	2:16	1	59	59	Overhead equipment	Fuse	Replace - Same Size		I
5136769	F10002	09/29/2015	5:47	09/29/2015	7:22	1	94	94	Overhead equipment	Fuse	Replace - Same Size		III
5136773	P73182	09/29/2015	5:58	09/29/2015	7:33	37	3491	94	Overhead equipment	Fuse	Replace - Same Size		VI
5136775	S04512	09/29/2015	6:42	09/29/2015	8:45	2	244	122	Tree related-tree broken	Overhead Primary	Patrol/Test/Inspect	Repair	VI
5136779	T05539	09/29/2015	7:06	09/29/2015	7:40	1	33	33	Overhead equipment	Disconnect Switch			VI
5136785	S52515	09/29/2015	7:22	09/29/2015	10:05	1	162	162	Animal related	Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
5136787	346004	09/29/2015	7:24	09/29/2015	8:55	1	90	90	Tree related-tree contact	Overhead Service	Repair		VI
5136793	Z20586	09/29/2015	8:08	09/29/2015	13:47	1	338	338	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	IV
5136799	A81004	09/29/2015	8:34	09/29/2015	9:26	1	52	52	Animal related	Fuse	Replace - Same Size		I
5136801	R48165	09/29/2015	8:34	09/29/2015	9:08	1	33	33	Animal related	Fuse			IV
5136805	M31203	09/29/2015	8:50	09/29/2015	9:59	1	68	68	Overhead equipment				I
5136841	D48002	09/29/2015	9:36	09/29/2015	10:12	704	25449	36	Unknown	Substation Breaker		Switch/Reset	I
5136857	D48001	09/29/2015	9:46	09/29/2015	10:22	1	35	35	Animal related				I
5136877	U92593	09/29/2015	10:48	09/29/2015	11:43	1	54	54	Animal related	Transformer Fuse	Replace - Same Size		II
5136893	U92593	09/29/2015	10:48	09/29/2015	11:43	6	326	54	Animal related	Transformer Fuse	Replace - Same Size		II
5136891	K67924	09/29/2015	11:23	09/29/2015	12:27	1	63	63	Public				VI
5136897	M18131	09/29/2015	11:35	09/29/2015	13:26	1	110	110	Other				III
5136899	D01001	09/29/2015	11:36	09/29/2015	12:20	1	43	43	Overhead equipment	Overhead Primary	Repair		I
5136901	Q85162	09/29/2015	11:37	09/29/2015	12:44	1	66	66	Animal related	Transformer Fuse	Repair	Repair	VI
5136903	Q74150	09/29/2015	11:52	09/29/2015	20:12	2	999	499	Overhead equipment	Connector	Repair	Replace - Same Size	IV
5136905	B82001	09/29/2015	11:53	09/29/2015	12:25	1	31	31	Tree related-tree broken	Overhead Transformer	Patrol/Test/Inspect		I
5136911	A56013	09/29/2015	12:07	09/29/2015	14:32	1	144	144	Other	Meter	Replace - Same Size		I
5136913	D31016	09/29/2015	12:15	09/29/2015	12:59	1	43	43	Overhead equipment	Disconnect Switch	Replace - Same Size		III
5136919	B25002	09/29/2015	12:26	09/29/2015	13:30	3	191	63	Animal related	Transformer Fuse	Replace - Same Size		I
5136923	J50185	09/29/2015	12:29	09/29/2015	17:47	24	4989	317	Underground equipment	Underground Primary		Repair	III
5136927	D33142	09/29/2015	12:38	09/29/2015	14:50	1	131	131	Overhead equipment	Overhead Service	Repair		I
5136941	B58001	09/29/2015	13:23	09/29/2015	13:48	2	50	25	Overhead equipment				I
5136945	Q95247	09/29/2015	13:31	09/29/2015	17:16	1	224	224	Underground equipment	Underground Service	Patrol/Test/Inspect		VI
5136947	N44216	09/29/2015	13:40	10/01/2015	19:54	14	603	3254	Public	Pole		Replace - Same Size	III
5136951	T06503	09/29/2015	13:42	09/29/2015	17:51	2	498	249	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	VI
5136955	X60598	09/29/2015	14:07	09/29/2015	14:48	1	41	41	Animal related	Transformer Fuse	Replace - Same Size		IV
5136957	V21500	09/29/2015	14:11	09/29/2015	15:48	1	96	96	Overhead equipment	Overhead Transformer	Replace - Same Size	Replace - Same Size	II
5136959	P52305	09/29/2015	14:20	09/29/2015	18:00	1	219	219	Weather	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	IV
5136965	X68506	09/29/2015	14:31	09/29/2015	15:22	4	200	50	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
5136973	Q74148	09/29/2015	14:47	09/29/2015	16:01	1	73	73	Animal related	Transformer Fuse	Replace - Same Size		IV
5136983	B80002	09/29/2015	14:55	09/29/2015	16:59	30	3711	123	Underground equipment	Underground Primary	Repair	Replace - Same Size	I
5136981	Y69553	09/29/2015	15:04	09/29/2015	18:10	1	185	185	Tree related-tree broken	Overhead Service	Repair		IV
5136995	K15205	09/29/2015	15:24	09/30/2015	5:06	38	31224	821	Tree related-tree broken	Tree	Patrol/Test/Inspect	Remove	VI
5136993	L81141	09/29/2015	15:29	09/29/2015	17:16	4	426	106	Overhead equipment	Fuse	Replace - Same Size		IV
5136997	T59925	09/29/2015	15:32	09/29/2015	16:35	1	62	62	Animal related	Transformer Fuse			VI
5136999	T59925	09/29/2015	15:35	09/29/2015	16:39	1	63	63	Animal related	Fuse			VI
5137001	F10002	09/29/2015	15:44	09/29/2015	16:36	1	51	51	Overhead equipment	Fuse	Replace - Same Size		III
5137009	R93350	09/29/2015	16:03	09/29/2015	17:00	1	56	56	Overhead equipment	Connector	Repair		V
5137023	P47124	09/29/2015	17:13	09/29/2015	18:15	1	61	61	Overhead equipment	Connector	Replace - Same Size	Reconnect	I
5137027	307005	09/29/2015	17:21	09/29/2015	18:13	25	1299	51	Tree related-tree broken	Overhead Primary	Repair		VI
5137031	S88502	09/29/2015	17:22	09/29/2015	19:10	1	107	107	Animal related	Disconnect Switch	Replace - Same Size		VI
5137039	K22173	09/29/2015	17:53	09/29/2015	19:31	1	97	97	Animal related	Transformer Fuse	Replace - Same Size		VI
5137041	R61241	09/29/2015	17:55	09/29/2015	18:37	23	953	41	Animal related	Fuse	Replace - Same Size		IV
5137073	L95210	09/29/2015	18:08	09/29/2015	18:57	82	4024	49	Tree related-tree broken	Overhead Primary	Repair		III
5137075	L95210	09/29/2015	18:10	09/29/2015	23:36	25	8145	325	Tree related-tree broken	Overhead Primary	Replace - Same Size	Replace - Same Size	III
5137071	Y59519	09/29/2015	18:13	09/30/2015	2:30	66	20455	496	Overhead equipment	Pole	Replace - New Size	Repair	IV
5137065	Y59519	09/29/2015	18:17	09/29/2015	19:55	1	97	97	Overhead equipment	Pole	Replace - New Size		IV
5137077	J07135	09/29/2015	18:29	09/29/2015	19:41	1	71	71	Overhead equipment	Overhead Service	Repair		I
5137079	J15302	09/29/2015	18:47	09/29/2015	19:57	6	417	69	Animal related	Fuse	Replace - Same Size	Replace - Same Size	I

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5137091	A85001	09/29/2015	19:45	09/30/2015	2:18	14	3652	392	Underground equipment	Underground Primary			I
5137117	B82001	09/29/2015	21:12	09/30/2015	4:25	1	432	432	Underground equipment	Underground Transformer	Replace - New Size	Repair	I
5137095	A68001	09/29/2015	21:53	09/30/2015	4:52	1	418	418	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
5137099	M18131	09/29/2015	22:25	09/30/2015	0:35	63	8145	129	Overhead equipment	Jumper			III
5137103	R49261	09/29/2015	23:13	09/30/2015	2:34	11	1807	201	Underground equipment	Underground Primary		Repair	VI
5137105	X02548	09/29/2015	23:21	09/30/2015	0:07	1	45	45	Animal related	Transformer Fuse	Replace - Same Size		IV
5137109	B80003	09/29/2015	23:42	09/30/2015	0:56	7	513	73	Animal related	Fuse	Patrol/Test/Inspect	Repair	I
5137111	S47576	09/29/2015	23:57	09/30/2015	1:35	1	97	97	Overhead equipment	Disconnect Switch		Replace - Same Size	VI
5137113	L23145	09/30/2015	0:00	09/30/2015	0:46	13	604	46	Tree related-tree contact	Recloser	Switch/Reset		III
5137119	K58213	09/30/2015	3:08	09/30/2015	5:00	6	670	111	Animal related	Fuse		Replace - Same Size	VI
5137121	N22295	09/30/2015	3:10	09/30/2015	5:47	7	1098	156	Overhead equipment	Overhead Secondary		Repair	VI
5137129	J84124	09/30/2015	7:23	09/30/2015	9:10	7	748	106	Animal related	Fuse	Replace - Same Size		VI
5137131	P58156	09/30/2015	7:41	09/30/2015	8:48	1	66	66	Tree related-tree broken	Overhead Service	Repair	Repair	VI
5137135	Q64919	09/30/2015	7:49	09/30/2015	8:57	1	67	67	Animal related	Transformer Fuse	Replace - Same Size		VI
5137137	T23527	09/30/2015	7:50	09/30/2015	9:40	6	657	109	Overhead equipment	Disconnect Switch	Replace - New Size		VI
5137151	X30506	09/30/2015	8:34	09/30/2015	10:00	1	85	85	Underground equipment	Overhead Service	Patrol/Test/Inspect	Repair	IV
5137161	Q74148	09/30/2015	8:43	09/30/2015	9:46	1	62	62	Unknown	Fuse	Replace - Same Size		IV
5137163	J14142	09/30/2015	8:51	09/30/2015	10:01	1	69	69	Animal related	Transformer Fuse	Repair	Repair	VI
5137187	B93002	09/30/2015	9:29	09/30/2015	11:10	74	7465	100	Public	Recloser	Patrol/Test/Inspect	Switch/Reset	I
5137185	Y55004	09/30/2015	9:34	09/30/2015	11:15	1	100	100	Tree related-tree contact	Overhead Service	Repair		IV
5137205	D60001	09/30/2015	9:56	09/30/2015	10:44	1	47	47	Animal related	Fuse	Replace - Same Size		III
5137217	B93002	09/30/2015	10:07	09/30/2015	11:10	1	62	62	Public	Recloser	Patrol/Test/Inspect	Switch/Reset	I
5137229	M07236	09/30/2015	10:33	09/30/2015	11:34	1	60	60	Public	Overhead Service	Remove		III
5137245	HA5432	09/30/2015	10:42	09/30/2015	12:18	26	2483	95	Animal related	Fuse	Repair		V
5137247	X42502	09/30/2015	11:01	09/30/2015	11:25	1	23	23	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
5137253	V18541	09/30/2015	11:13	09/30/2015	12:31	31	2425	78	Public	Pole	Repair	Repair	II
5137263	K27153	09/30/2015	11:17	09/30/2015	12:40	1	83	83	Overhead equipment				VI
5137277	C66001	09/30/2015	11:57	09/30/2015	13:39	1	101	101	Unknown	Fuse	Replace - Same Size		III
5137279	V18541	09/30/2015	11:59	09/30/2015	16:19	4	1042	260	Public	Pole	Repair	Repair	II
5137281	G30001	09/30/2015	12:01	09/30/2015	12:26	290	7299	25	Public	Other	Advise Customer		III
5137285	V44504	09/30/2015	12:18	09/30/2015	13:05	1	46	46	Animal related	Transformer Fuse	Replace - Same Size		II
5137287	Y23513	09/30/2015	12:21	09/30/2015	13:04	1	42	42	Animal related	Transformer Fuse	Replace - Same Size		IV
5137293	U44529	09/30/2015	12:34	09/30/2015	13:12	1	37	37	Overhead equipment	Transformer Fuse	Replace - Same Size		II
5137295	T06505	09/30/2015	12:35	09/30/2015	14:12	1	96	96	Tree related-tree broken	Disconnect Switch	Replace - Same Size	Patrol/Test/Inspect	VI
5137301	V28597	09/30/2015	12:41	09/30/2015	13:56	1	74	74	Overhead equipment	Overhead Service	Repair	Repair	II
5137303	U44529	09/30/2015	12:41	09/30/2015	13:13	1	31	31	Overhead equipment	Transformer Fuse	Replace - Same Size		II
5137309	A28001	09/30/2015	12:50	09/30/2015	15:03	1	132	132	Tree related-tree broken	Overhead Service	Reconnect		I
5137331	R41131	09/30/2015	13:29	09/30/2015	14:12	1	42	42	Overhead equipment				VI
5137333	S01560	09/30/2015	13:43	09/30/2015	15:00	1	76	76	Other	Overhead Secondary	Replace - Same Size		VI
5137343	P19395	09/30/2015	14:09	09/30/2015	17:43	1	213	213	Animal related	Transformer Fuse	Replace - Same Size		V
5137349	U73599	09/30/2015	14:25	09/30/2015	15:09	1	43	43	Overhead equipment	Jumper	Repair		II
5137351	V77543	09/30/2015	14:25	09/30/2015	15:27	1	61	61	Animal related	Transformer Fuse	Replace - Same Size		II
5137359	U10547	09/30/2015	15:00	09/30/2015	16:10	1	69	69	Animal related	Transformer Fuse	Replace - Same Size	Patrol/Test/Inspect	II
5137365	Y89540	09/30/2015	15:15	09/30/2015	16:00	1	44	44	Overhead equipment	Transformer Fuse	Repair	Replace - Same Size	IV
5137367	Q18244	09/30/2015	15:15	09/30/2015	21:00	1	344	344	Underground equipment	Underground Service	Patrol/Test/Inspect	Repair	VI
5137371	U44529	09/30/2015	15:33	09/30/2015	18:45	1	191	191	Underground equipment	Underground Primary	Repair		II
5137375	V21500	09/30/2015	15:36	09/30/2015	16:26	1	49	49	Animal related	Fuse	Replace - Same Size		II
5137377	P98192	09/30/2015	15:41	09/30/2015	17:34	1	112	112	Overhead equipment	Overhead Service			III
5137385	S22592	09/30/2015	16:07	09/30/2015	17:06	1	58	58	Other				VI
5137387	A36001	09/30/2015	16:08	09/30/2015	17:40	1	91	91	Animal related	Transformer Fuse	Replace - Same Size		I
5137389	K74162	09/30/2015	16:08	09/30/2015	17:28	29	2303	79	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	IV
5137401	R73841	09/30/2015	16:43	09/30/2015	18:20	1	96	96	Animal related	Transformer Fuse	Replace - Same Size		V
5137403	S01560	09/30/2015	16:48	09/30/2015	17:25	1	36	36	Overhead equipment	Overhead Service			VI
5137407	Z16518	09/30/2015	16:51	10/01/2015	2:07	1	555	555	Underground equipment	Underground Transformer	Replace - New Size		IV
5137409	S31532	09/30/2015	16:55	09/30/2015	17:48	1	52	52	Animal related	Transformer Fuse	Repair	Replace - Same Size	VI
5137419	L17105	09/30/2015	17:28	09/30/2015	20:12	1	163	163	Overhead equipment	Overhead Primary	Repair		III

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5137421	L17105	09/30/2015	17:28	09/30/2015	19:59	611	92215	150	Overhead equipment	Overhead Primary	Patrol/Test/Inspect	Repair	III
5137423	L17105	09/30/2015	17:28	09/30/2015	19:59	192	28976	150	Overhead equipment	Overhead Primary	Repair		III
5137425	L17105	09/30/2015	17:28	09/30/2015	19:59	191	28827	150	Overhead equipment	Overhead Primary	Replace - Same Size	Replace - Same Size	III
5137427	U13551	09/30/2015	17:29	09/30/2015	19:14	1	104	104	Other	Fuse			II
5137431	T06503	09/30/2015	17:34	09/30/2015	18:20	28	1260	45	Overhead equipment	Overhead Primary	Repair	Repair	VI
5137437	L17105	09/30/2015	17:46	09/30/2015	20:24	49	7710	157	Overhead equipment	Overhead Primary	Repair		III
5137441	R08910	09/30/2015	17:51	09/30/2015	19:44	1	112	112	Animal related	Fuse	Replace - Same Size		VI
5137447	J79306	09/30/2015	18:12	09/30/2015	19:12	1	59	59	Animal related	Transformer Fuse	Replace - Same Size	Replace - Same Size	I
5137451	A81004	09/30/2015	18:24	09/30/2015	19:33	139	9636	69	Overhead equipment				I
5137465	L35282	09/30/2015	19:16	09/30/2015	20:28	1	71	71	Overhead equipment	Overhead Primary	Repair		III
5137467	P09304	09/30/2015	19:17	09/30/2015	19:53	8	292	36	Tree related-tree contact	Overhead Transformer	Repair		V
5137471	A81004	09/30/2015	19:33	09/30/2015	20:57	20	1593	83	Overhead equipment	Overhead Primary	Raise		I
5137475	D39001	09/30/2015	19:57	10/01/2015	5:09	1	552	552	Underground equipment	Underground Primary		Repair	I
5137483	L79180	09/30/2015	20:21	09/30/2015	23:50	7	1458	208	Overhead equipment	Pole	Repair	Replace - Same Size	IV
5137485	J34377	09/30/2015	20:28	09/30/2015	21:12	40	1744	43	Overhead equipment	Fuse	Replace - Same Size		V
5137487	A81004	09/30/2015	21:30	09/30/2015	21:39	139	1260	9	Overhead equipment				I
5137493	D67001	09/30/2015	22:43	10/01/2015	3:14	5	1354	270	Underground equipment	Underground Primary	Repair	Replace - Same Size	IV
5137497	A97001	09/30/2015	23:18	10/01/2015	6:15	1	416	416	Overhead equipment	Overhead Transformer			I
5137505	S31561	10/01/2015	1:34	10/01/2015	3:36	1	122	121	Overhead equipment	Overhead Service	Repair		VI
5137507	N86228	10/01/2015	4:16	10/01/2015	8:47	13	3520	270	Overhead equipment	Pole		Replace - Same Size	VI
5137509	K27150	10/01/2015	5:50	10/01/2015	7:20	1	89	89	Overhead equipment	Overhead Service	Repair	Repair	VI
5137523	S19543	10/01/2015	6:03	10/01/2015	11:06	4	1213	303	Underground equipment	Underground Primary			VI
5137513	V45526	10/01/2015	6:54	10/01/2015	7:56	18	1112	61	Overhead equipment				II
5137515	D88001	10/01/2015	7:18	10/01/2015	9:28	25	3248	129	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
5137525	302001	10/01/2015	7:45	10/01/2015	10:00	1	134	134	Overhead equipment	Fuse	Replace - Same Size		VI
5137527	R02120	10/01/2015	7:58	10/01/2015	8:29	1	30	30	Animal related	Transformer Fuse	Repair	Repair	VI
5137529	U01514	10/01/2015	8:16	10/01/2015	9:20	1	63	63	Animal related	Transformer Fuse	Replace - Same Size	Replace - Same Size	II
5137531	P52305	10/01/2015	8:19	10/01/2015	10:50	2	300	150	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	IV
5137555	J79304	10/01/2015	8:41	10/01/2015	9:32	1	50	50	Unknown	Transformer Fuse	Replace - Same Size		I
5137543	S62521	10/01/2015	8:57	10/01/2015	9:27	1	29	29	Overhead equipment				VI
5137557	R68900	10/01/2015	9:15	10/01/2015	10:33	1	77	77	Animal related	Transformer Fuse	Replace - Same Size		I
5137563	R68900	10/01/2015	9:28	10/01/2015	10:00	1	31	31	Animal related	Transformer Fuse	Replace - Same Size		I
5137567	S64501	10/01/2015	9:34	10/01/2015	15:00	1	325	325	Public	Pole	Replace - Same Size	Replace - Same Size	VI
5137581	B58002	10/01/2015	9:51	10/01/2015	11:14	8	656	82	Overhead equipment				I
5137591	S61530	10/01/2015	10:14	10/01/2015	11:30	3	225	75	Animal related	Disconnect Switch	Replace - Same Size		VI
5137599	Q70161	10/01/2015	10:22	10/01/2015	11:29	7	468	66	Overhead equipment	Overhead Secondary			I
5137607	Q64919	10/01/2015	10:43	10/01/2015	11:12	1	28	28	Animal related	Transformer Fuse	Replace - Same Size		VI
5137611	R05186	10/01/2015	10:54	10/01/2015	18:00	1	425	425	Underground equipment	Underground Service	Repair	Replace - Same Size	I
5137617	P83710	10/01/2015	11:12	10/01/2015	11:28	1	15	15	Overhead equipment	Overhead Secondary			I
5137643	P44324	10/01/2015	11:19	10/01/2015	12:08	57	2837	49	Overhead equipment	Connector	Repair		I
5137637	N54213	10/01/2015	11:27	10/01/2015	13:12	1	104	104	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	II
5137671	V69546	10/01/2015	12:00	10/01/2015	19:21	6	2648	441	Overhead equipment	Pole	Replace - Same Size		II
5137655	D36001	10/01/2015	12:20	10/01/2015	14:14	1	113	113	Animal related	Disconnect Switch	Replace - Same Size	Replace - Same Size	I
5137661	D32212	10/01/2015	12:40	10/01/2015	13:35	1	54	54	Animal related	Transformer Fuse	Replace - Same Size	Replace - Same Size	I
5137683	V55524	10/01/2015	13:35	10/01/2015	15:15	1	99	99	Public	Overhead Service	Patrol/Test/Inspect	Repair	II
5137705	R05186	10/01/2015	14:28	10/01/2015	14:35	1	6	6	Underground equipment	Underground Service	Repair	Replace - Same Size	I
5137707	L59933	10/01/2015	14:29	10/01/2015	17:40	1	190	190	Tree related-tree broken	Overhead Secondary		Repair	VI
5137713	K82202	10/01/2015	14:53	10/01/2015	15:49	1	55	55	Tree related-tree contact	Overhead Transformer			III
5137717	R05186	10/01/2015	14:57	10/01/2015	18:00	1	182	182	Public				I
5137721	L35139	10/01/2015	15:09	10/01/2015	15:40	1	30	30	Animal related	Transformer Fuse	Replace - Same Size		III
5137733	K89142	10/01/2015	15:28	10/01/2015	16:25	600	33660	56	Animal related	Recloser	Switch/Reset		III
5137731	K82202	10/01/2015	15:29	10/01/2015	15:51	1	21	21	Tree related-tree contact	Overhead Transformer			III
5137745	K89142	10/01/2015	15:35	10/01/2015	16:25	1	49	49	Unknown	Recloser	Switch/Reset		III
5137769	K89142	10/01/2015	15:53	10/01/2015	16:25	1	31	31	Unknown	Recloser	Switch/Reset		III
5137775	M05362	10/01/2015	16:04	10/01/2015	19:05	13	2347	180	Overhead equipment	Overhead Primary	Switch/Reset	Repair	V
5137777	L71171	10/01/2015	16:12	10/01/2015	17:49	1	96	96	Animal related	Transformer Fuse	Replace - Same Size		IV

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5137779	K89142	10/01/2015	16:12	10/01/2015	16:25	1	12	12	Unknown	Recloser	Switch/Reset		III
5137783	HC9327	10/01/2015	16:14	10/01/2015	17:38	414	25138	83	Tree related-tree broken	Fuse	Replace - Same Size		VI
5137787	N42856	10/01/2015	16:22	10/01/2015	17:54	1	91	91	Intentional	Meter	Replace - Same Size		V
5137793	R06209	10/01/2015	16:29	10/01/2015	17:00	1	30	30	Overhead equipment	Fuse	Replace - Same Size		II
5137795	N35851	10/01/2015	16:57	10/01/2015	18:09	6	430	71	Overhead equipment	Overhead Secondary	Repair		V
5137797	HC9327	10/01/2015	17:02	10/01/2015	17:35	135	4398	32	Overhead equipment	Fuse	Replace - Same Size		VI
5137799	Y59519	10/01/2015	17:04	10/01/2015	18:33	1	88	88	Other	Underground Service	Advise Customer		IV
5137805	J01118	10/01/2015	17:16	10/01/2015	19:08	11	1120	111	Underground equipment	Underground Primary	Switch/Reset	Repair	I
5137807	K89142	10/01/2015	17:22	10/01/2015	17:57	95	3251	34	Animal related	Fuse	Replace - Same Size		III
5137813	HB6283	10/01/2015	17:35	10/01/2015	18:40	3	195	65	Animal related	Transformer Fuse	Replace - Same Size		VI
5137817	K01238	10/01/2015	18:04	10/01/2015	22:35	1	271	270	Underground equipment	Underground Service	Disconnect	Repair	VI
5137819	C76002	10/01/2015	18:29	10/01/2015	19:40	9	636	70	Unknown	Fuse	Replace - Same Size		I
5137823	J68402	10/01/2015	18:49	10/01/2015	19:40	1	50	50	Overhead equipment	Overhead Primary			III
5137829	U05595	10/01/2015	19:42	10/01/2015	21:10	1	87	87	Animal related	Transformer Fuse	Replace - Same Size	Replace - Same Size	II
5137835	K57211	10/01/2015	20:27	10/01/2015	22:00	1	92	92	Overhead equipment	Connector	Repair		VI
5137839	C76002	10/01/2015	20:37	10/02/2015	2:27	1	349	349	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
5137845	L16212	10/01/2015	22:03	10/01/2015	23:22	30	2355	78	Overhead equipment	Crossarm	Replace - Same Size		III
5137847	L16212	10/01/2015	22:06	10/02/2015	4:15	3	1106	368	Overhead equipment	Crossarm	Replace - Same Size		III
5137853	B53001	10/02/2015	0:00	10/02/2015	4:11	42	10528	250	Tree related-tree contact	Tree			III
5137855	B53001	10/02/2015	0:22	10/02/2015	4:28	1	245	245	Tree related-tree contact	Tree			III
5137857	B53001	10/02/2015	0:41	10/02/2015	4:17	1	215	215	Tree related-tree contact	Tree			III
5137859	B53001	10/02/2015	1:01	10/02/2015	4:45	1	223	223	Tree related-tree contact	Fuse			III
5137863	B53001	10/02/2015	2:53	10/02/2015	4:59	1	125	125	Tree related-tree contact	Fuse			III
5137865	X91510	10/02/2015	4:02	10/02/2015	11:50	1	467	467	Underground equipment	Underground Secondary	Repair		IV
5137867	B53001	10/02/2015	5:29	10/02/2015	5:32	1	2	2	Unknown				III
5137869	B53001	10/02/2015	5:55	10/02/2015	7:14	6	472	78	Overhead equipment	Fuse			III
5137875	V95586	10/02/2015	8:04	10/02/2015	10:10	1	125	125	Overhead equipment	Transformer Fuse	Replace - Same Size	Repair	II
5137881	U62521	10/02/2015	8:43	10/02/2015	9:45	1	61	61	Animal related	Transformer Fuse	Replace - Same Size		II
5137893	K52401	10/02/2015	8:53	10/02/2015	9:33	1	39	39	Other	Fuse	Replace - Same Size		V
5137895	Q82906	10/02/2015	8:58	10/02/2015	10:00	1	61	61	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	VI
5137899	V44504	10/02/2015	9:04	10/02/2015	9:36	1	32	31	Animal related	Fuse	Replace - Same Size		II
5137907	J80807	10/02/2015	10:05	10/02/2015	11:03	1	57	57	Animal related	Transformer Fuse	Replace - Same Size		V
5137921	HB6283	10/02/2015	10:33	10/02/2015	12:00	1	86	86	Animal related	Fuse			VI
5137929	HB6283	10/02/2015	10:55	10/02/2015	12:00	1	64	64	Animal related	Fuse	Replace - Same Size		VI
5137939	333001	10/02/2015	11:11	10/02/2015	12:00	1	48	48	Overhead equipment	Overhead Transformer	Switch/Reset		VI
5137941	D87001	10/02/2015	11:13	10/02/2015	14:00	1	166	166	Jurisdictional	Underground Secondary	Repair		I
5137977	K32915	10/02/2015	11:15	10/02/2015	13:10	2	231	115	Public	Pole	Replace - New Size		VI
5137951	J39392	10/02/2015	11:23	10/02/2015	14:17	1	173	173	Public	Pole		Repair	III
5137981	K32915	10/02/2015	11:30	10/02/2015	18:06	10	3967	396	Public	Pole	Replace - New Size	Repair	VI
5137943	K32915	10/02/2015	11:40	10/02/2015	13:10	1	90	90	Public	Pole	Replace - New Size	Repair	VI
5137971	K69116	10/02/2015	12:13	10/02/2015	13:18	51	3308	64	Animal related	Fuse	Repair		IV
5137973	J08207	10/02/2015	12:14	10/02/2015	13:02	5	238	47	Animal related	Fuse	Replace - Same Size		I
5137983	J08207	10/02/2015	12:16	10/02/2015	13:11	33	1815	55	Animal related				I
5137985	V22555	10/02/2015	12:41	10/02/2015	13:30	7	342	48	Animal related	Transformer Fuse	Replace - Same Size		II
5137989	N58144	10/02/2015	12:48	10/02/2015	18:08	1	319	319	Overhead equipment	Connector	Replace - Same Size		I
5137991	Q32170	10/02/2015	12:55	10/02/2015	15:07	6	788	131	Animal related	Fuse	Replace - Same Size	Patrol/Test/Inspect	I
5137995	J39392	10/02/2015	13:08	10/02/2015	15:41	1	152	152	Public	Pole	Repair		III
5138029	B93002	10/02/2015	14:20	10/02/2015	18:12	21	4863	231	Tree related-tree broken	Overhead Primary	Patrol/Test/Inspect	Repair	I
5138031	A50002	10/02/2015	14:28	10/02/2015	15:11	7	300	42	Unknown	Fuse	Replace - Same Size		I
5138033	J08207	10/02/2015	14:29	10/02/2015	16:33	3	371	123	Overhead equipment	Transformer Fuse	Replace - Same Size		I
5138035	K15205	10/02/2015	14:35	10/02/2015	19:28	12	3523	293	Tree related-tree broken	Overhead Service	Patrol/Test/Inspect	Replace - Same Size	VI
5138049	Z06537	10/02/2015	15:12	10/02/2015	16:15	10	621	62	Overhead equipment	Overhead Service	Patrol/Test/Inspect	Repair	IV
5138053	V84531	10/02/2015	15:32	10/02/2015	16:48	1	75	75	Animal related	Transformer Fuse	Replace - Same Size		II
5138057	U33586	10/02/2015	15:46	10/02/2015	16:22	1	35	35	Overhead equipment	Transformer Fuse	Replace - Same Size		II
5138063	H06135	10/02/2015	15:54	10/02/2015	20:49	1	294	294	Animal related	Fuse		Replace - Same Size	IV
5138065	N74242	10/02/2015	16:00	10/02/2015	16:45	16	708	44	Tree related-tree broken	Transformer Fuse	Repair	Repair	I

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5138067	S62520	10/02/2015	16:08	10/02/2015	16:51	1	42	42	Overhead equipment				VI
5138069	B80003	10/02/2015	16:10	10/02/2015	16:56	1	45	45	Animal related	Fuse	Patrol/Test/Inspect	Repair	I
5138075	P52305	10/02/2015	16:42	10/02/2015	17:30	8	377	47	Overhead equipment	Pole		Replace - Same Size	IV
5138077	L23145	10/02/2015	16:44	10/02/2015	17:09	45	1093	24	Animal related	Fuse	Replace - Same Size		III
5138079	J08207	10/02/2015	16:46	10/02/2015	17:47	3	181	60	Overhead equipment	Transformer Fuse	Replace - Same Size		I
5138083	K79213	10/02/2015	16:47	10/02/2015	17:51	86	5540	64	Overhead equipment	Connector	Replace - Same Size		IV
5138089	L23145	10/02/2015	17:06	10/02/2015	17:20	1	13	13	Animal related	Fuse	Replace - Same Size		III
5138095	L68113	10/02/2015	17:13	10/02/2015	19:40	10	1468	146	Overhead equipment	Overhead Primary	Replace - Same Size	Replace - Same Size	IV
5138105	B76002	10/02/2015	17:50	10/02/2015	19:10	38	3003	79	Overhead equipment	Fuse	Patrol/Test/Inspect	Repair	I
5138109	T08501	10/02/2015	17:56	10/02/2015	20:12	1	135	135	Tree related-tree broken	Overhead Primary	Patrol/Test/Inspect	Repair	VI
5138121	P17107	10/02/2015	17:56	10/02/2015	20:40	17	2771	163	Tree related-tree contact	Jumper	Repair		IV
5138115	T08501	10/02/2015	17:58	10/02/2015	20:12	4	533	133	Tree related-tree broken	Overhead Primary	Patrol/Test/Inspect	Repair	VI
5138119	T08501	10/02/2015	18:01	10/02/2015	20:00	1	118	118	Tree related-tree broken	Fuse	Repair	Repair	VI
5138149	Y86595	10/02/2015	19:40	10/02/2015	21:40	1	119	119	Animal related	Transformer Fuse	Repair	Patrol/Test/Inspect	IV
5138159	P69173	10/02/2015	20:58	10/02/2015	21:40	1	41	41	Overhead equipment	Lightning Arrestor	Replace - Same Size		III
5138161	D66001	10/02/2015	20:59	10/03/2015	0:01	1	182	182	Underground equipment	Underground Transformer	Replace - Same Size		IV
5138163	R20501	10/02/2015	21:02	10/02/2015	21:49	1	46	46	Overhead equipment	Overhead Secondary	Repair		IV
5138177	N54107	10/02/2015	21:24	10/03/2015	2:30	4	1221	305	Underground equipment	Underground Primary	Repair		II
5138169	S83533	10/02/2015	21:26	10/03/2015	3:58	3	1177	392	Overhead equipment	Tree			VI
5138171	S61531	10/02/2015	22:01	10/02/2015	22:55	9	485	53	Overhead equipment				VI
5138179	S49550	10/02/2015	22:44	10/02/2015	23:55	1	70	70	Overhead equipment	Fuse		Replace - Same Size	VI
5138193	S86582	10/02/2015	23:01	10/03/2015	3:02	7	1682	240	Tree related-tree broken	Overhead Primary	Replace - Same Size	Replace - Same Size	VI
5138183	T41556	10/02/2015	23:03	10/03/2015	1:39	1	155	155	Animal related	Transformer Fuse	Replace - Same Size		IV
5138189	Q04411	10/02/2015	23:16	10/03/2015	3:22	31	4558	246	Animal related	Underground Transformer			III
5138195	D31018	10/03/2015	4:18	10/03/2015	5:46	14	1235	88	Overhead equipment	Fuse	Replace - Same Size		III
5138199	K43383	10/03/2015	5:14	10/03/2015	6:44	1	89	89	Tree related-tree broken				V
5138201	Q18242	10/03/2015	5:37	10/03/2015	7:15	1	97	97	Animal related	Fuse	Replace - Same Size		VI
5138203	P26283	10/03/2015	5:53	10/03/2015	7:50	1	116	116	Unknown	Fuse	Repair		I
5138205	T02543	10/03/2015	5:55	10/03/2015	7:50	1	114	114	Tree related-tree broken	Overhead Service	Repair	Repair	VI
5138207	HB6283	10/03/2015	7:05	10/03/2015	8:19	1	73	73	Animal related	Fuse	Replace - Same Size		VI
5138209	L82187	10/03/2015	7:17	10/03/2015	7:56	1	38	38	Animal related	Transformer Fuse	Replace - Same Size		IV
5138211	U84566	10/03/2015	7:26	10/03/2015	8:51	3	253	84	Animal related	Fuse	Replace - Same Size		II
5138213	P26280	10/03/2015	7:38	10/03/2015	8:20	12	492	41	Animal related	Fuse	Repair		I
5138215	S55535	10/03/2015	7:42	10/03/2015	9:05	1	82	82	Animal related	Transformer Fuse	Replace - Same Size		VI
5138217	S55535	10/03/2015	7:51	10/03/2015	9:05	1	73	73	Animal related	Transformer Fuse	Replace - Same Size		VI
5138219	M45211	10/03/2015	8:16	10/03/2015	9:27	1	71	71	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
5138221	B53001	10/03/2015	8:25	10/03/2015	9:20	1	54	54	Animal related	Transformer Fuse	Replace - Same Size		III
5138223	M81402	10/03/2015	8:36	10/03/2015	9:21	1	44	44	Animal related	Fuse	Replace - Same Size		V
5138229	D81001	10/03/2015	8:55	10/03/2015	10:12	1	76	76	Overhead equipment	Connector	Replace - Same Size	Replace - Same Size	I
5138231	R71286	10/03/2015	9:00	10/03/2015	10:34	1	93	93	Overhead equipment	Fuse	Replace - Same Size		VI
5138283	S64506	10/03/2015	9:04	10/03/2015	10:40	170	16331	96	Underground equipment				VI
5138251	P18102	10/03/2015	9:16	10/03/2015	10:28	96	6833	71	Overhead equipment	Connector	Repair		IV
5138285	S64506	10/03/2015	9:16	10/03/2015	10:05	3	144	48	Underground equipment				VI
5138261	A85002	10/03/2015	9:25	10/03/2015	10:45	1	79	79	Animal related	Fuse	Patrol/Test/Inspect	Repair	I
5138263	P18102	10/03/2015	9:26	10/03/2015	10:30	9	567	63	Overhead equipment				IV
5138267	P69174	10/03/2015	9:31	10/03/2015	11:52	1	140	140	Overhead equipment	Fuse	Replace - Same Size		III
5138295	S43501	10/03/2015	10:09	10/03/2015	12:35	1	145	145	Overhead equipment	Overhead Service	Repair	Repair	VI
5138297	Y07576	10/03/2015	10:17	10/03/2015	11:30	1	72	72	Overhead equipment	Overhead Service	Repair		IV
5138299	P26284	10/03/2015	10:24	10/03/2015	11:20	11	623	56	Overhead equipment	Overhead Primary	Replace - Same Size		I
5138303	P69173	10/03/2015	10:31	10/03/2015	12:45	1	133	133	Unknown	Fuse	Replace - Same Size		III
5138305	Y73504	10/03/2015	10:33	10/03/2015	11:48	1	74	74	Animal related	Fuse	Replace - Same Size		IV
5138317	S31529	10/03/2015	10:54	10/03/2015	12:04	1	69	69	Other				VI
5217453	S64505	10/03/2015	10:54	10/03/2015	11:55	55	3362	61	Underground equipment				VI
5138327	U05595	10/03/2015	10:58	10/03/2015	12:31	18	1595	92	Tree related-tree broken	Overhead Primary	Replace - Same Size		II
5138343	S64506	10/03/2015	11:00	10/03/2015	13:46	170	16305	165	Underground equipment				VI
5138333	J84146	10/03/2015	11:27	10/03/2015	12:20	1	52	52	Animal related	Fuse	Replace - Same Size		VI

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5138337	J06168	10/03/2015	11:46	10/03/2015	13:43	1	117	117	Overhead equipment	Fuse	Replace - Same Size		I
5138345	U35511	10/03/2015	12:01	10/03/2015	13:10	1	68	68	Animal related	Transformer Fuse	Replace - Same Size		II
5138349	H32370	10/03/2015	12:18	10/03/2015	13:16	1	57	57	Animal related	Transformer Fuse	Replace - Same Size		V
5138353	Y82587	10/03/2015	12:50	10/03/2015	14:23	1	92	92	Animal related	Transformer Fuse	Replace - Same Size		IV
5138359	311002	10/03/2015	13:40	10/03/2015	15:16	7	665	95	Overhead equipment				VI
5138369	J87150	10/03/2015	14:45	10/03/2015	15:57	2	142	71	Tree related-tree broken	Tree	Remove		VI
5138371	Y97514	10/03/2015	14:50	10/03/2015	16:15	10	848	84	Overhead equipment	Overhead Secondary	Repair		IV
5138373	J86108	10/03/2015	14:56	10/03/2015	19:46	7	2028	289	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	VI
5138375	V65549	10/03/2015	15:11	10/03/2015	17:20	6	772	128	Tree related-tree contact	Fuse	Replace - Same Size		II
5138381	C00002	10/03/2015	15:21	10/03/2015	16:23	31	1896	61	Overhead equipment				I
5138389	K43382	10/03/2015	15:35	10/03/2015	15:56	1	20	20	Public				V
5138393	M36185	10/03/2015	16:34	10/03/2015	17:56	5	409	81	Overhead equipment	Fuse	Replace - Same Size		I
5138395	351002	10/03/2015	16:37	10/03/2015	17:48	1	70	70	Overhead equipment	Overhead Service	Repair		VI
5138399	Q64919	10/03/2015	16:48	10/03/2015	17:52	2	126	63	Animal related	Transformer Fuse	Repair		VI
5138401	Z05549	10/03/2015	17:07	10/03/2015	19:25	1	137	137	Overhead equipment	Fuse	Replace - Same Size		IV
5138403	T06503	10/03/2015	17:10	10/03/2015	18:15	1	64	64	Animal related	Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
5138407	J88163	10/03/2015	17:27	10/03/2015	18:50	1	82	82	Animal related	Fuse	Replace - Same Size		VI
5138409	Y37592	10/03/2015	17:31	10/03/2015	18:39	1	67	67	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
5138415	X64503	10/03/2015	17:41	10/03/2015	19:02	1	80	80	Tree related-tree contact	Overhead Service	Repair		IV
5138417	A45003	10/03/2015	18:20	10/04/2015	0:08	1	348	348	Public	Underground Transformer	Patrol/Test/Inspect	Repair	I
5138423	311001	10/03/2015	18:28	10/03/2015	19:14	39	1775	45	Public	Fuse	Replace - Same Size		VI
5138429	A45003	10/03/2015	18:34	10/04/2015	2:24	1	470	470	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
5138431	311001	10/03/2015	18:42	10/03/2015	19:15	1	32	32	Overhead equipment				VI
5138433	A45003	10/03/2015	19:07	10/03/2015	19:28	1	21	20	Public				I
5138439	X49570	10/03/2015	19:39	10/03/2015	23:00	1	200	200	Animal related	Transformer Fuse	Repair	Patrol/Test/Inspect	IV
5138443	U10547	10/03/2015	20:40	10/03/2015	22:20	1	99	99	Animal related	Transformer Fuse	Replace - Same Size	Patrol/Test/Inspect	II
5138449	L93133	10/03/2015	22:07	10/04/2015	0:45	18	2826	157	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	VI
5138451	L93133	10/03/2015	22:15	10/04/2015	0:45	8	1194	149	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	VI
5138453	X02549	10/04/2015	7:47	10/04/2015	8:30	1	42	42	Animal related	Fuse	Repair		IV
5138457	Q80353	10/04/2015	8:08	10/04/2015	8:35	1	26	26	Animal related	Transformer Fuse	Replace - Same Size	Replace - Same Size	V
5138459	X82576	10/04/2015	8:17	10/04/2015	11:18	1	180	180	Tree related-tree contact	Tree	Trim		IV
5138461	X34530	10/04/2015	8:28	10/04/2015	10:15	1	106	106	Animal related	Fuse	Repair		IV
5138465	P60170	10/04/2015	8:33	10/04/2015	14:20	1	346	346	Underground equipment	Underground Primary		Repair	VI
5138471	Q24311	10/04/2015	8:53	10/04/2015	11:09	1	135	135	Underground equipment	Underground Service	Repair		VI
5138477	D01001	10/04/2015	9:06	10/04/2015	10:17	1	70	70	Overhead equipment	Fuse	Replace - Same Size		I
5138481	M09143	10/04/2015	9:08	10/04/2015	12:15	1	186	186	Underground equipment	Underground Secondary	Replace - Same Size	Repair	VI
5138483	L00133	10/04/2015	9:14	10/04/2015	10:15	8	484	60	Animal related	Fuse	Replace - Same Size		III
5138489	S47537	10/04/2015	9:45	10/04/2015	9:50	5	24	4	Public				VI
5138493	X34530	10/04/2015	10:01	10/04/2015	10:30	1	28	28	Animal related	Fuse	Repair		IV
5138497	L63936	10/04/2015	10:37	10/04/2015	11:50	5	360	72	Animal related	Fuse	Replace - Same Size		VI
5138503	P26283	10/04/2015	11:28	10/04/2015	13:10	99	10105	102	Animal related	Fuse	Patrol/Test/Inspect		I
5138507	J18267	10/04/2015	11:35	10/04/2015	13:12	1	96	96	Overhead equipment	Overhead Service	Repair		VI
5138509	U06551	10/04/2015	11:38	10/04/2015	12:50	1	71	71	Overhead equipment	Transformer Fuse	Replace - Same Size		II
5138511	B93003	10/04/2015	11:57	10/04/2015	13:17	11	478	79	Unknown	Fuse	Replace - Same Size		I
5138513	B25001	10/04/2015	12:13	10/04/2015	13:29	1	75	75	Overhead equipment	Transformer Fuse	Replace - Same Size	Replace - Same Size	I
5138517	K52401	10/04/2015	12:31	10/04/2015	12:56	1	24	24	Animal related	Transformer Fuse	Replace - Same Size	Replace - Same Size	V
5138521	C70004	10/04/2015	12:58	10/04/2015	17:33	1	274	274	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	III
5138527	Y13042	10/04/2015	13:08	10/04/2015	14:40	1	91	91	Overhead equipment	Overhead Service	Repair		IV
5138529	M41111	10/04/2015	13:19	10/04/2015	15:00	1	100	100	Overhead equipment	Fuse	Replace - Same Size		I
5138533	346004	10/04/2015	13:30	10/04/2015	20:59	1	448	448	Public	Pole	Patrol/Test/Inspect	Replace - New Size	VI
5138535	346004	10/04/2015	13:38	10/04/2015	20:32	66	13049	414	Public	Pole	Patrol/Test/Inspect	Replace - New Size	VI
5138537	P18102	10/04/2015	13:51	10/04/2015	15:21	1	89	89	Animal related	Transformer Fuse	Replace - Same Size		IV
5138549	308004	10/04/2015	15:38	10/04/2015	16:18	1	39	39	Overhead equipment	Overhead Transformer	Switch/Reset		VI
5138559	R01153	10/04/2015	16:26	10/04/2015	17:45	1	78	78	Overhead equipment	Overhead Service			III
5138563	R49275	10/04/2015	16:50	10/04/2015	18:03	1	73	72	Animal related	Fuse	Replace - Same Size		VI
5138565	K31124	10/04/2015	17:08	10/04/2015	18:25	3	230	76	Animal related	Fuse	Repair		I

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5138567	K09863	10/04/2015	17:11	10/04/2015	18:23	9	640	71	Animal related	Fuse	Replace - Same Size	Repair	V
5138571	R49275	10/04/2015	17:25	10/04/2015	18:03	1	37	37	Animal related				VI
5138587	L79159	10/04/2015	17:43	10/04/2015	21:10	1	207	207	Animal related	Fuse	Replace - Same Size		IV
5138575	R49275	10/04/2015	17:49	10/04/2015	18:03	8	110	13	Animal related	Fuse	Replace - Same Size		VI
5138573	L79159	10/04/2015	17:55	10/04/2015	21:10	3	582	194	Animal related	Fuse	Replace - Same Size		IV
5138577	A56013	10/04/2015	18:18	10/04/2015	19:00	1	41	41	Overhead equipment	Overhead Service	Repair		I
5138579	M45212	10/04/2015	18:26	10/04/2015	20:20	1	113	113	Animal related	Transformer Fuse	Replace - Same Size		IV
5138583	H01192	10/04/2015	18:49	10/04/2015	20:00	1	70	70	Animal related	Fuse	Replace - Same Size	Replace - Same Size	III
5138585	P62138	10/04/2015	18:58	10/04/2015	21:30	1	151	151	Underground equipment	Underground Service		Repair	VI
5138593	A68001	10/04/2015	20:08	10/04/2015	21:25	1	76	76	Overhead equipment	Fuse	Replace - Same Size		I
5138595	A68001	10/04/2015	20:11	10/04/2015	21:29	1	77	77	Overhead equipment	Fuse	Replace - Same Size		I
5138609	R99180	10/04/2015	20:29	10/05/2015	8:50	42	17614	740	Public				IV
5138627	K95204	10/05/2015	3:05	10/05/2015	4:27	31	2539	81	Unknown	Fuse	Replace - Same Size		III
5138639	P17109	10/05/2015	4:09	10/05/2015	6:29	7	979	139	Underground equipment	Underground Primary	Switch/Reset	Switch/Reset	IV
5138635	K25164	10/05/2015	4:54	10/05/2015	5:54	1	59	59	Animal related	Transformer Fuse	Repair	Repair	VI
5138653	Y97513	10/05/2015	6:37	10/05/2015	8:35	1	117	117	Overhead equipment	Overhead Primary	Repair		IV
5138645	K69112	10/05/2015	7:02	10/05/2015	7:50	1	47	47	Animal related	Transformer Fuse	Replace - Same Size		IV
5138815	J12166	10/05/2015	7:51	10/05/2015	9:34	19	1951	102	Underground equipment	Underground Primary			III
5138689	J12166	10/05/2015	7:57	10/05/2015	9:13	1	75	75	Overhead equipment				III
5138667	V44504	10/05/2015	8:03	10/05/2015	9:07	1	63	63	Overhead equipment	Transformer Fuse	Repair		II
5138669	P39298	10/05/2015	8:04	10/05/2015	9:05	3	183	61	Overhead equipment				VI
5138671	C66001	10/05/2015	8:11	10/05/2015	8:55	1	43	43	Overhead equipment	Fuse	Replace - Same Size		III
5138673	Y98532	10/05/2015	8:18	10/05/2015	9:30	74	5276	71	Animal related	Fuse	Replace - Same Size	Repair	IV
5138681	T04512	10/05/2015	8:38	10/05/2015	14:43	3	1092	364	Public				VI
5138707	Y20522	10/05/2015	9:26	10/05/2015	16:02	12	4748	395	Underground equipment	Underground Primary	Repair	Repair	IV
5138717	T08502	10/05/2015	9:43	10/05/2015	10:25	1	41	41	Animal related	Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
5138723	T04512	10/05/2015	9:53	10/05/2015	14:39	2	571	285	Public	Pole	Repair		VI
5138725	Q21292	10/05/2015	9:57	10/05/2015	10:54	1	56	56	Animal related	Transformer Fuse	Replace - Same Size		VI
5138739	X77543	10/05/2015	10:11	10/05/2015	10:50	1	38	38	Overhead equipment	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	IV
5138747	P54828	10/05/2015	10:19	10/05/2015	12:23	1	123	123	Overhead equipment	Transformer Fuse	Replace - Same Size		V
5138749	H11340	10/05/2015	10:24	10/05/2015	11:15	728	30873	50	Animal related	Fuse	Replace - Same Size		V
5138751	M30301	10/05/2015	10:25	10/05/2015	11:48	1	82	82	Overhead equipment	Transformer Fuse			VI
5138753	R16510	10/05/2015	10:26	10/05/2015	11:35	4	272	68	Animal related	Transformer Fuse	Replace - Same Size		I
5138755	V10545	10/05/2015	10:27	10/05/2015	10:58	6	183	30	Animal related	Transformer Fuse	Replace - Same Size		II
5138791	Z57516	10/05/2015	10:56	10/05/2015	12:23	1	86	86	Overhead equipment	Fuse	Repair	Replace - Same Size	IV
5138795	U61001	10/05/2015	10:59	10/05/2015	13:25	1	145	145	Overhead equipment	Overhead Service	Repair		II
5138861	K74162	10/05/2015	12:29	10/05/2015	13:40	29	2045	70	Unknown	Fuse	Repair		IV
5138837	S47576	10/05/2015	12:30	10/05/2015	12:53	1	22	22	Other				VI
5138843	F03003	10/05/2015	12:42	10/05/2015	14:06	1	83	83	Animal related	Fuse	Replace - Same Size		III
5138855	U52516	10/05/2015	12:51	10/05/2015	14:47	1	115	115	Overhead equipment				II
5138857	Y82590	10/05/2015	12:52	10/05/2015	13:42	3	147	49	Animal related	Transformer Fuse	Replace - Same Size	Replace - Same Size	IV
5138863	P49183	10/05/2015	13:05	10/05/2015	15:00	1	114	114	Underground equipment	Underground Service	Repair	Replace - Same Size	I
5138865	N44217	10/05/2015	13:12	10/05/2015	15:47	39	6013	154	Overhead equipment	Fuse		Replace - Same Size	III
5138873	S43512	10/05/2015	13:34	10/05/2015	14:10	1	35	35	Animal related	Transformer Fuse	Replace - Same Size	Replace - Same Size	VI
5138885	Q18242	10/05/2015	13:54	10/05/2015	15:44	34	3741	110	Underground equipment	Underground Primary		Repair	VI
5138893	D16004	10/05/2015	14:00	10/05/2015	15:22	1	81	81	Unknown	Transformer Fuse	Replace - Same Size		I
5138921	Q18242	10/05/2015	14:01	10/05/2015	17:30	12	2514	209	Underground equipment	Underground Primary		Repair	VI
5138909	D41003	10/05/2015	15:06	10/05/2015	17:00	1	114	114	Public	Underground Secondary	Repair	Repair	I
5138911	U12540	10/05/2015	15:07	10/05/2015	16:36	1	88	88	Animal related	Transformer Fuse	Repair	Replace - Same Size	II
5138915	Q80352	10/05/2015	15:29	10/05/2015	17:13	1	103	103	Overhead equipment	Overhead Service	Repair		V
5138929	T22507	10/05/2015	16:07	10/05/2015	17:34	1	86	86	Other				VI
5138931	X92507	10/05/2015	16:08	10/05/2015	19:25	1	196	196	Overhead equipment	Overhead Transformer	Repair	Replace - Same Size	IV
5138935	D70006	10/05/2015	16:31	10/05/2015	20:47	1	255	255	Overhead equipment	Overhead Transformer		Repair	I
5138937	U31565	10/05/2015	16:37	10/05/2015	21:15	1	277	277	Underground equipment	Underground Primary	Repair	Repair	II
5138939	L17101	10/05/2015	16:45	10/05/2015	17:33	1	47	47	Animal related	Fuse	Replace - Same Size		III
5138953	D90004	10/05/2015	17:23	10/05/2015	18:13	129	6411	49	Overhead equipment	Jumper	Replace - Same Size		III

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5138965	K09864	10/05/2015	17:36	10/05/2015	19:05	1	88	88	Animal related	Fuse			V
5138967	D28123	10/05/2015	18:11	10/05/2015	19:35	1	83	83	Overhead equipment	Connector	Replace - Same Size		I
5138981	V69558	10/05/2015	19:15	10/05/2015	20:50	5	473	94	Overhead equipment	Overhead Transformer	Replace - Same Size		II
5138983	S04545	10/05/2015	19:32	10/05/2015	20:40	1	67	67	Jurisdictional				VI
5138987	D66002	10/05/2015	20:53	10/06/2015	1:00	1	246	246	Overhead equipment	Overhead Transformer	Replace - New Size		IV
5138989	Q82907	10/05/2015	21:12	10/05/2015	22:10	1	57	57	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	VI
5138991	P52305	10/05/2015	21:38	10/06/2015	2:17	1	278	278	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	IV
5138995	V17574	10/05/2015	22:36	10/06/2015	0:20	2	206	103	Unknown	Transformer Fuse	Replace - Same Size		II
5138997	B45003	10/06/2015	2:39	10/06/2015	4:24	50	5236	104	Overhead equipment	Lightning Arrestor	Replace - Same Size		I
5139001	C70001	10/06/2015	3:17	10/06/2015	4:40	1	82	82	Unknown	Fuse	Replace - Same Size		III
5139003	K07322	10/06/2015	5:42	10/06/2015	7:11	1	88	88	Unknown	Transformer Fuse	Replace - Same Size		I
5139005	M18130	10/06/2015	6:25	10/06/2015	8:27	1	121	121	Tree related-tree contact	Overhead Service			III
5139011	D69005	10/06/2015	7:50	10/06/2015	12:48	1	297	297	Underground equipment	Underground Secondary	Repair	Repair	I
5139013	J07135	10/06/2015	7:55	10/06/2015	10:18	1	142	142	Overhead equipment	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	I
5139017	S25552	10/06/2015	7:58	10/06/2015	9:11	1	72	72	Animal related	Transformer Fuse	Repair	Repair	VI
5139015	J20931	10/06/2015	7:58	10/06/2015	11:06	4	750	187	Overhead equipment	Overhead Primary	Repair	Repair	VI
5139019	S14511	10/06/2015	8:05	10/06/2015	9:10	1	64	64	Animal related	Transformer Fuse	Replace - Same Size		VI
5139043	F10003	10/06/2015	8:29	10/06/2015	10:25	108	12495	115	Overhead equipment	Overhead Primary	Replace - Same Size		III
5139035	K46388	10/06/2015	8:31	10/06/2015	9:30	1	58	58	Public	Overhead Service	Patrol/Test/Inspect	Repair	V
5139045	Y96564	10/06/2015	8:48	10/06/2015	10:15	1	86	86	Animal related	Transformer Fuse	Replace - Same Size		IV
5139047	U84566	10/06/2015	8:50	10/06/2015	9:33	1	42	42	Animal related	Fuse	Replace - Same Size		II
5139051	L23145	10/06/2015	8:54	10/06/2015	10:50	1	115	115	Overhead equipment	Overhead Service	Repair		III
5139057	V69558	10/06/2015	9:00	10/06/2015	10:26	1	85	85	Animal related	Transformer Fuse	Replace - Same Size		II
5139061	J99128	10/06/2015	9:08	10/06/2015	9:30	1	21	21	Animal related	Transformer Fuse			VI
5139065	H06135	10/06/2015	9:11	10/06/2015	10:13	1	61	61	Unknown	Transformer Fuse	Replace - Same Size		IV
5139091	K39153	10/06/2015	9:30	10/06/2015	12:35	215	39749	184	Animal related	Overhead Primary			III
5139093	K67924	10/06/2015	9:34	10/06/2015	10:21	1	46	46	Public	Guy Wire	Repair	Repair	VI
5139095	K31120	10/06/2015	9:35	10/06/2015	13:55	2	519	259	Public	Underground Transformer	Repair		I
5139109	J71129	10/06/2015	10:03	10/06/2015	11:33	1	89	89	Overhead equipment	Other	Replace - Same Size		I
5139119	M25144	10/06/2015	10:22	10/06/2015	11:41	1	78	78	Public	Fuse	Replace - Same Size		IV
5139129	K62102	10/06/2015	10:26	10/06/2015	11:50	28	2372	84	Overhead equipment	Overhead Primary	Switch/Reset		II
5139135	R71285	10/06/2015	10:38	10/06/2015	12:23	1	104	104	Overhead equipment	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
5139141	S93504	10/06/2015	10:51	10/06/2015	11:44	1	52	52	Overhead equipment	Overhead Primary	Repair		VI
5139149	B28006	10/06/2015	11:11	10/06/2015	12:45	1	93	93	Overhead equipment				I
5139159	S92559	10/06/2015	11:27	10/06/2015	12:21	1	53	53	Animal related	Transformer Fuse	Replace - Same Size		VI
5139165	S22593	10/06/2015	11:42	10/06/2015	13:00	1	77	77	Overhead equipment				VI
5139167	Y84534	10/06/2015	11:45	10/06/2015	13:05	1	79	79	Overhead equipment	Transformer Fuse	Replace - Same Size	Replace - Same Size	IV
5139169	HC9327	10/06/2015	11:52	10/06/2015	13:52	1	119	119	Weather	Fuse	Replace - Same Size		VI
5139173	A91002	10/06/2015	12:01	10/06/2015	19:44	1	463	463	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
5139175	V74513	10/06/2015	12:04	10/06/2015	12:32	7	195	27	Public	Transformer Fuse	Replace - Same Size		II
5139177	P60170	10/06/2015	12:11	10/06/2015	13:14	1	62	62	Overhead equipment				VI
5139179	K76546	10/06/2015	12:22	10/06/2015	13:10	1	47	47	Animal related				IV
5139187	J47178	10/06/2015	12:56	10/06/2015	13:11	1	14	14	Intentional				III
5139205	K89143	10/06/2015	13:43	10/06/2015	14:51	1	67	67	Overhead equipment	Jumper	Repair		III
5139213	V45574	10/06/2015	13:50	10/06/2015	17:02	2	385	192	Underground equipment	Underground Primary		Repair	II
5139229	302003	10/06/2015	14:18	10/06/2015	22:56	1	517	517	Overhead equipment	Disconnect Switch	Repair		VI
5139239	C70001	10/06/2015	14:43	10/06/2015	15:36	1	52	52	Overhead equipment	Fuse	Replace - Same Size		III
5139253	Q32170	10/06/2015	15:24	10/06/2015	16:45	1	80	80	Overhead equipment	Fuse	Replace - Same Size	Patrol/Test/Inspect	I
5139265	L93134	10/06/2015	15:33	10/06/2015	16:56	17	1405	82	Underground equipment				VI
5139261	K22173	10/06/2015	15:34	10/06/2015	16:51	4	307	76	Animal related	Transformer Fuse	Replace - Same Size		VI
5139263	A97003	10/06/2015	15:37	10/06/2015	17:06	1	88	88	Tree related-tree broken	Overhead Service	Reconnect		I
5139267	R33126	10/06/2015	15:48	10/06/2015	17:50	1	121	121	Overhead equipment	Transformer Fuse	Replace - Same Size	Repair	I
5139269	S28552	10/06/2015	15:58	10/06/2015	19:25	1	206	206	Overhead equipment	Overhead Transformer	Replace - Same Size	Replace - Same Size	VI
5139271	X78536	10/06/2015	16:41	10/06/2015	17:05	1	23	23	Animal related	Transformer Fuse	Replace - Same Size		IV
5139273	U84566	10/06/2015	16:51	10/06/2015	17:45	1	53	53	Overhead equipment	Transformer Fuse	Replace - Same Size		II
5139275	P60161	10/06/2015	16:52	10/06/2015	17:14	1	21	21	Other				VI

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5139279	P69174	10/06/2015	17:13	10/06/2015	18:46	1	92	92	Overhead equipment	Overhead Secondary	Repair		III
5139291	L81141	10/06/2015	18:58	10/07/2015	1:28	1	390	390	Underground equipment	Underground Primary		Repair	IV
5139301	Z17503	10/06/2015	20:33	10/06/2015	22:55	10	1418	141	Underground equipment				IV
5139303	S69516	10/06/2015	20:38	10/06/2015	22:45	1	126	126	Animal related	Transformer Fuse			VI
5139307	S09520	10/06/2015	20:49	10/06/2015	22:00	1	70	70	Overhead equipment				VI
5139313	A97002	10/06/2015	22:25	10/06/2015	22:36	8	91	11	Tree related-tree broken	Overhead Primary		Replace - Same Size	I
5139315	V95586	10/06/2015	23:17	10/07/2015	2:15	1	177	177	Animal related	Transformer Fuse	Replace - Same Size		II
5139319	H11340	10/07/2015	1:47	10/07/2015	7:39	1	351	351	Animal related	Transformer Fuse	Replace - New Size	Replace - New Size	V
5139329	J07173	10/07/2015	6:17	10/07/2015	7:51	1	93	93	Tree related-tree broken	Overhead Service	Patrol/Test/Inspect	Repair	I
5139337	T42525	10/07/2015	7:56	10/07/2015	8:27	1	30	30	Animal related	Transformer Fuse	Replace - Same Size		IV
5139341	R34921	10/07/2015	8:20	10/07/2015	9:23	1	62	62	Overhead equipment	Fuse	Replace - Same Size		VI
5139517	U06-XTR1	10/07/2015	8:28	10/07/2015	9:42	1556	116202	74	Jurisdictional				II
5139573	U62-XTR1	10/07/2015	8:28	10/07/2015	9:16	805	37971	47	Jurisdictional	Substation Relay	Repair	Replace - Same Size	II
5139597	332004	10/07/2015	8:41	10/07/2015	11:00	1	138	138	Overhead equipment	Overhead Service	Repair		VI
5139661	S62521	10/07/2015	9:08	10/07/2015	9:19	1	10	10	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	VI
5139671	M78325	10/07/2015	9:15	10/07/2015	10:21	32	2100	65	Animal related	Fuse	Replace - Same Size	Replace - Same Size	V
5139683	Q69926	10/07/2015	9:23	10/07/2015	10:40	1	76	76	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	VI
5139687	HB5890	10/07/2015	9:28	10/07/2015	10:10	1	41	41	Animal related	Transformer Fuse	Replace - Same Size		I
5139693	K52400	10/07/2015	9:34	10/07/2015	10:07	1	32	32	Animal related	Fuse	Replace - Same Size		V
5139711	D31016	10/07/2015	9:39	10/07/2015	11:10	976	63918	91	Overhead equipment	Overhead Primary	Replace - Same Size	Patrol/Test/Inspect	III
5139705	K74166	10/07/2015	9:40	10/07/2015	10:15	9	306	34	Animal related	Fuse	Repair		IV
5139721	Y36541	10/07/2015	9:54	10/07/2015	10:28	1	33	33	Overhead equipment	Fuse	Repair	Replace - Same Size	IV
5139727	Y07577	10/07/2015	10:01	10/07/2015	10:30	5	143	28	Animal related	Transformer Fuse	Replace - Same Size		IV
5139733	N18211	10/07/2015	10:06	10/07/2015	10:30	5	118	23	Unknown	Transformer Fuse	Replace - Same Size		III
5139739	K31120	10/07/2015	10:39	10/07/2015	13:06	1	146	146	Animal related	Fuse	Replace - Same Size		I
5139767	L73155	10/07/2015	11:22	10/07/2015	12:46	1	83	83	Overhead equipment	Overhead Service	Repair	Repair	IV
5139769	X78536	10/07/2015	11:31	10/07/2015	12:55	1	83	83	Animal related	Customer Equipment	Advise Customer		IV
5139775	M25144	10/07/2015	11:47	10/07/2015	12:52	1	64	64	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
5139777	X86546	10/07/2015	11:48	10/07/2015	12:20	1	31	31	Animal related	Transformer Fuse		Replace - Same Size	IV
5139781	Y97512	10/07/2015	12:01	10/07/2015	12:55	4	214	53	Animal related	Transformer Fuse	Replace - Same Size		IV
5139787	307003	10/07/2015	12:31	10/07/2015	14:15	36	3739	103	Public	Fuse	Replace - Same Size		VI
5139797	X88507	10/07/2015	12:59	10/07/2015	14:11	1	71	71	Animal related	Transformer Fuse	Replace - Same Size		IV
5139799	C65001	10/07/2015	13:00	10/07/2015	14:34	1	93	93	Unknown	Fuse	Replace - Same Size		III
5139853	H01190	10/07/2015	13:09	10/07/2015	14:46	82	7947	96	Public	Fuse			III
5139805	S19554	10/07/2015	13:14	10/07/2015	13:47	1	32	32	Unknown	Customer Equipment	Replace - Same Size		VI
5139807	R05114	10/07/2015	13:15	10/07/2015	13:42	1	26	26	Overhead equipment	Overhead Service			I
5139815	S49550	10/07/2015	13:20	10/07/2015	15:13	8	907	113	Underground equipment	Underground Primary	Repair	Repair	VI
5139823	B21004	10/07/2015	13:37	10/07/2015	15:20	1	102	102	Overhead equipment	Overhead Transformer	Replace - Same Size		I
5139829	301051	10/07/2015	13:50	10/07/2015	15:25	1	94	94	Animal related	Fuse	Replace - Same Size		VI
5139837	S24598	10/07/2015	13:59	10/07/2015	15:32	126	11702	92	Public	Overhead Primary	Repair	Repair	VI
5139847	Q16868	10/07/2015	14:28	10/07/2015	19:59	28	9255	330	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	V
5139865	Q11517	10/07/2015	14:44	10/07/2015	16:50	6	752	125	Overhead equipment	Overhead Transformer	Replace - Same Size		I
5139867	H01190	10/07/2015	14:48	10/07/2015	14:54	1	5	5	Public	Fuse			III
5139877	M19222	10/07/2015	14:55	10/07/2015	21:01	1	365	365	Underground equipment	Underground Service	Disconnect	Repair	VI
5139881	R48165	10/07/2015	14:58	10/07/2015	17:25	2	293	146	Overhead equipment	Fuse	Replace - Same Size		IV
5139883	D28123	10/07/2015	15:04	10/07/2015	16:17	1	72	72	Overhead equipment	Transformer Fuse	Replace - Same Size		I
5139885	D31016	10/07/2015	15:08	10/07/2015	17:35	5	732	146	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Patrol/Test/Inspect	III
5139891	N05172	10/07/2015	15:12	10/07/2015	17:04	1	111	111	Overhead equipment	Fuse		Replace - Same Size	I
5139895	S49550	10/07/2015	15:14	10/07/2015	15:20	1	5	5	Overhead equipment				VI
5139897	R48165	10/07/2015	15:17	10/07/2015	17:25	1	127	127	Overhead equipment	Fuse	Replace - Same Size		IV
5139905	L81142	10/07/2015	15:55	10/07/2015	18:30	1	154	154	Animal related	Fuse			IV
5139911	U86500	10/07/2015	16:00	10/07/2015	16:45	1	44	44	Overhead equipment	Overhead Service	Repair		II
5139913	K73361	10/07/2015	16:04	10/07/2015	22:45	1	401	401	Public	Underground Transformer	Patrol/Test/Inspect	Repair	IV
5139915	K36151	10/07/2015	16:04	10/07/2015	20:00	1	235	235	Underground equipment	Underground Service		Repair	III
5139919	B58001	10/07/2015	16:14	10/07/2015	20:46	1	272	272	Underground equipment	Underground Primary	Patrol/Test/Inspect	Replace - Same Size	I
5139921	342001	10/07/2015	16:22	10/07/2015	17:56	1	93	93	Overhead equipment	Connector	Repair		VI

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5139929	P62138	10/07/2015	16:45	10/07/2015	19:12	2	293	146	Overhead equipment	Overhead Transformer		Replace - Same Size	VI
5139933	U73583	10/07/2015	16:54	10/07/2015	19:44	16	2713	169	Public	Overhead Primary	Raise		II
5139937	Y66557	10/07/2015	17:28	10/07/2015	19:20	38	4230	111	Overhead equipment	Overhead Primary	Repair	Patrol/Test/Inspect	IV
5139941	K52401	10/07/2015	17:43	10/07/2015	19:16	3	277	92	Animal related	Transformer Fuse	Replace - Same Size		V
5139945	K31124	10/07/2015	18:02	10/07/2015	23:41	5	1692	338	Public	Overhead Primary	Repair	Replace - Same Size	I
5139947	S93504	10/07/2015	18:10	10/07/2015	19:59	1	108	108	Overhead equipment	Transformer Fuse	Repair	Replace - Same Size	VI
5139955	Q06132	10/07/2015	18:39	10/07/2015	20:05	1	85	85	Tree related-tree contact	Tree	Remove		IV
5139959	U97528	10/07/2015	18:42	10/07/2015	23:58	11	1429	315	Underground equipment	Underground Primary	Switch/Reset		II
5139963	K28180	10/07/2015	19:17	10/07/2015	21:10	1	112	112	Public	Other			III
5139967	B58001	10/07/2015	20:13	10/07/2015	21:23	1	69	69	Other	Fuse	Replace - Same Size		I
5139969	Q16868	10/07/2015	20:17	10/08/2015	0:09	21	3810	232	Underground equipment				V
5139973	R61241	10/07/2015	20:17	10/08/2015	1:25	1	307	307	Underground equipment				IV
5139977	J71128	10/07/2015	21:27	10/07/2015	23:25	43	5060	117	Overhead equipment	Fuse	Replace - Same Size		I
5139981	J71128	10/07/2015	21:30	10/07/2015	23:30	1	119	119	Overhead equipment	Fuse	Replace - Same Size		I
5139983	J14140	10/07/2015	21:31	10/07/2015	23:30	11	1304	118	Animal related	Fuse	Replace - Same Size		VI
5139985	J71128	10/07/2015	21:38	10/07/2015	23:32	1	113	113	Overhead equipment	Fuse	Replace - Same Size		I
5139989	R16510	10/07/2015	21:57	10/08/2015	0:40	1	162	162	Tree related-tree contact	Overhead Service	Replace - New Size	Replace - New Size	I
5139991	P49180	10/07/2015	22:09	10/07/2015	23:59	2	219	109	Overhead equipment	Overhead Service	Repair	Replace - Same Size	I
5139993	HB6283	10/07/2015	22:57	10/08/2015	0:23	1	85	85	Overhead equipment	Transformer Fuse	Replace - Same Size		VI
5139997	S49550	10/07/2015	23:46	10/08/2015	3:39	20	4674	233	Underground equipment	Underground Primary			VI
5139999	N35852	10/08/2015	0:03	10/08/2015	3:07	1	183	183	Overhead equipment	Overhead Service	Repair		V
5140001	S49550	10/08/2015	0:05	10/08/2015	3:39	8	1713	214	Underground equipment	Underground Primary	Repair	Repair	VI
5140003	J61117	10/08/2015	0:25	10/08/2015	1:44	1	78	78	Overhead equipment	Overhead Service			III
5140005	Y89540	10/08/2015	0:28	10/08/2015	9:09	18	9379	521	Underground equipment	Underground Primary	Repair	Replace - Same Size	IV
5140009	P49180	10/08/2015	1:21	10/08/2015	6:35	1	313	313	Overhead equipment	Overhead Transformer		Repair	I
5140013	B19002	10/08/2015	4:39	10/08/2015	9:04	2	529	264	Underground equipment	Fuse	Patrol/Test/Inspect	Replace - Same Size	I
5140019	S27598	10/08/2015	6:16	10/08/2015	9:25	1	188	188	Overhead equipment	Overhead Primary			VI
5140023	D69001	10/08/2015	7:15	10/08/2015	14:00	1	404	404	Underground equipment	Other	Patrol/Test/Inspect	Patrol/Test/Inspect	I
5140025	N60181	10/08/2015	7:18	10/08/2015	9:29	1	130	130	Unknown	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	I
5140029	S27598	10/08/2015	7:35	10/08/2015	9:27	1	112	112	Overhead equipment	Overhead Primary	Replace - Same Size		VI
5140033	Q11517	10/08/2015	7:44	10/08/2015	8:56	1	71	71	Overhead equipment	Overhead Service	Repair	Repair	I
5140037	341002	10/08/2015	8:17	10/08/2015	10:35	6	823	137	Tree related-tree contact	Tree	Trim	Trim	VI
5140041	T08502	10/08/2015	8:29	10/08/2015	11:10	1	160	160	Public	Underground Primary	Repair		VI
5140049	M09143	10/08/2015	8:58	10/08/2015	10:17	1	78	78	Animal related	Fuse	Replace - Same Size		VI
5140057	B19002	10/08/2015	9:12	10/08/2015	10:45	12	1112	92	Tree related-tree broken	Fuse	Replace - Same Size		I
5140061	M78323	10/08/2015	9:22	10/08/2015	10:30	1	67	67	Animal related	Transformer Fuse	Replace - Same Size		V
5140065	M81404	10/08/2015	9:28	10/08/2015	10:28	12	715	59	Overhead equipment	Fuse	Replace - Same Size		V
5140069	M81404	10/08/2015	9:29	10/08/2015	10:27	1	57	57	Overhead equipment	Fuse	Replace - Same Size		V
5140079	V18553	10/08/2015	9:48	10/08/2015	12:00	1	131	131	Public				II
5140081	W03570	10/08/2015	9:58	10/08/2015	11:10	1	71	71	Tree related-tree broken	Overhead Service	Replace - Same Size	Patrol/Test/Inspect	II
5140085	R28870	10/08/2015	10:00	10/08/2015	11:10	1	69	69	Animal related	Transformer Fuse	Replace - Same Size		V
5140099	R05186	10/08/2015	10:13	10/08/2015	13:51	19	4107	217	Underground equipment	Underground Primary	Repair	Replace - Same Size	I
5140105	L74193	10/08/2015	10:21	10/08/2015	11:13	7	363	51	Animal related	Fuse	Replace - Same Size		IV
5140107	E10002	10/08/2015	10:21	10/08/2015	12:37	210	28503	135	Public	Fuse	Replace - Same Size		III
5140109	T42525	10/08/2015	10:22	10/08/2015	11:14	92	4831	52	Animal related	Recloser	Replace - Same Size	Replace - Same Size	IV
5140125	Q37370	10/08/2015	10:54	10/08/2015	19:48	1	534	534	Underground equipment	Underground Primary	Repair	Repair	I
5140195	X92507	10/08/2015	11:12	10/08/2015	13:51	367	55421	159	Public	Overhead Primary			IV
5140161	K26136	10/08/2015	11:16	10/08/2015	12:21	1	65	65	Overhead equipment	Pole	Repair		VI
5140201	T15570	10/08/2015	11:31	10/08/2015	22:11	18	7537	640	Underground equipment	Underground Primary	Repair	Repair	VI
5140207	X69555	10/08/2015	11:43	10/08/2015	12:39	1	55	55	Overhead equipment				IV
5140209	N60181	10/08/2015	11:44	10/08/2015	12:35	1	50	50	Overhead equipment	Overhead Transformer	Repair	Replace - Same Size	I
5140213	R59415	10/08/2015	11:55	10/08/2015	13:01	1	65	65	Animal related	Fuse	Replace - Same Size		IV
5140317	P26280	10/08/2015	12:43	10/08/2015	14:38	220	25436	115	Overhead equipment	Connector	Repair		I
5140319	P26280	10/08/2015	12:43	10/08/2015	14:38	707	81481	115	Overhead equipment	Connector	Repair		I
5140321	P26280	10/08/2015	13:11	10/08/2015	14:38	1	86	86	Overhead equipment	Connector	Repair		I
5140295	N44215	10/08/2015	13:37	10/08/2015	15:00	1	82	82	Unknown	Transformer Fuse	Replace - Same Size		III

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5140323	IP9009	10/08/2015	14:07	10/08/2015	15:45	1	97	97	Overhead equipment	Fuse	Repair		VI
5140327	M45212	10/08/2015	14:08	10/08/2015	15:00	1	51	51	Animal related	Fuse	Replace - Same Size		IV
5140335	X49569	10/08/2015	14:16	10/08/2015	15:06	128	6455	50	Overhead equipment	Overhead Primary	Replace - Same Size	Replace - Same Size	IV
5140341	S78551	10/08/2015	14:28	10/08/2015	15:27	1	58	58	Overhead equipment	Fuse			VI
5140343	312113	10/08/2015	14:30	10/08/2015	17:20	1	169	169	Overhead equipment	Disconnect Switch	Patrol/Test/Inspect	Replace - New Size	V
5140349	Q91175	10/08/2015	14:35	10/08/2015	17:26	1	170	170	Overhead equipment	Disconnect Switch	Replace - Same Size		I
5140359	S13548	10/08/2015	15:22	10/08/2015	15:49	1	26	26	Unknown	Customer Equipment	Replace - Same Size		VI
5140361	P26284	10/08/2015	15:27	10/08/2015	16:20	1	52	52	Public	Transformer Fuse	Replace - Same Size	Repair	I
5140363	307001	10/08/2015	15:46	10/08/2015	16:15	83	2407	29	Tree related-tree broken				VI
5140365	307001	10/08/2015	16:07	10/08/2015	16:23	1	15	15	Tree related-tree broken				VI
5140367	N15849	10/08/2015	16:09	10/08/2015	16:48	1	38	38	Overhead equipment	Fuse	Replace - Same Size		V
5140369	J47176	10/08/2015	16:09	10/08/2015	21:20	1	310	310	Underground equipment	Underground Service			III
5140375	B73002	10/08/2015	16:23	10/08/2015	19:16	1	172	172	Overhead equipment	Overhead Service	Repair		I
5140377	R58961	10/08/2015	16:29	10/08/2015	17:33	5	320	63	Animal related	Transformer Fuse	Replace - Same Size		IV
5140379	N15849	10/08/2015	16:29	10/08/2015	16:50	6	125	20	Overhead equipment				V
5140381	T15570	10/08/2015	16:32	10/08/2015	20:41	16	3973	248	Underground equipment				VI
5140389	S27599	10/08/2015	17:09	10/09/2015	1:00	1	470	470	Underground equipment	Underground Secondary		Repair	VI
5140401	S50541	10/08/2015	17:20	10/08/2015	19:05	30	3151	105	Overhead equipment	Overhead Primary		Repair	VI
5140399	U10547	10/08/2015	17:24	10/08/2015	19:20	1	115	115	Overhead equipment	Transformer Fuse	Replace - Same Size	Patrol/Test/Inspect	II
5140403	M41112	10/08/2015	17:25	10/08/2015	19:00	12	1136	94	Animal related	Guy Wire		Repair	I
5140409	Z21564	10/08/2015	18:33	10/08/2015	19:40	1	66	66	Overhead equipment	Transformer Fuse	Repair	Replace - Same Size	IV
5140415	V92540	10/08/2015	18:58	10/08/2015	21:00	1	121	121	Overhead equipment	Pole	Cut in Clear	Patrol/Test/Inspect	II
5140419	S47575	10/08/2015	19:50	10/08/2015	20:25	1	34	34	Overhead equipment	Fuse		Replace - Same Size	VI
5140421	Y35515	10/08/2015	19:57	10/08/2015	21:00	1	62	62	Overhead equipment	Overhead Service			IV
5140429	Z11506	10/08/2015	20:49	10/08/2015	22:20	6	544	90	Overhead equipment	Transformer Fuse	Repair		IV
5140433	B38002	10/08/2015	21:19	10/08/2015	23:33	2	268	134	Overhead equipment	Overhead Primary	Replace - Same Size		I
5140461	B68003	10/08/2015	21:36	10/09/2015	0:50	142	27533	193	Overhead equipment				III
5140465	B68003	10/08/2015	22:05	10/09/2015	1:14	1	188	188	Weather				III
5140467	B38002	10/08/2015	22:28	10/08/2015	23:33	9	588	65	Overhead equipment	Overhead Primary	Replace - Same Size	Repair	I
5140475	K82202	10/08/2015	22:45	10/08/2015	23:29	1	43	43	Tree related-tree contact	Fuse			III
5140485	N90247	10/08/2015	22:51	10/09/2015	0:47	64	7398	115	Unknown	Fuse			III
5140483	N90247	10/08/2015	22:54	10/09/2015	0:48	4	454	113	Unknown	Fuse			III
5140491	M37192	10/08/2015	23:22	10/09/2015	0:36	1	73	73	Underground equipment				I
5140487	M37192	10/08/2015	23:22	10/09/2015	0:36	1	73	73	Overhead equipment				I
5140489	M37192	10/08/2015	23:22	10/09/2015	0:36	1	73	73	Underground equipment				I
5140493	M37192	10/08/2015	23:22	10/09/2015	0:36	1	73	73	Underground equipment				I
5140495	R05114	10/08/2015	23:23	10/09/2015	0:36	227	16598	73	Underground equipment	Underground Primary	Switch/Reset	Repair	I
5140499	M37192	10/08/2015	23:24	10/09/2015	0:36	1	71	71	Underground equipment				I
5140501	M37192	10/08/2015	23:24	10/09/2015	0:36	1	71	71	Underground equipment				I
5140505	M37192	10/08/2015	23:25	10/09/2015	0:36	1	70	70	Underground equipment				I
5140507	M37192	10/08/2015	23:26	10/09/2015	0:36	1	69	69	Underground equipment				I
5140511	R05186	10/08/2015	23:36	10/09/2015	0:36	1	59	59	Underground equipment				I
5140519	M41111	10/09/2015	5:10	10/09/2015	6:52	1	101	101	Animal related	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	I
5140521	N18211	10/09/2015	5:49	10/09/2015	7:58	5	642	128	Animal related	Transformer Fuse	Replace - Same Size		III
5140523	P26283	10/09/2015	6:18	10/09/2015	7:50	1	91	91	Animal related	Transformer Fuse	Repair		I
5140527	D69001	10/09/2015	6:58	10/09/2015	9:57	1	178	178	Underground equipment	Other	Patrol/Test/Inspect	Patrol/Test/Inspect	I
5140531	D69001	10/09/2015	7:11	10/09/2015	9:54	1	162	162	Underground equipment				I
5140535	R04412	10/09/2015	7:17	10/09/2015	8:25	1	67	67	Intentional				V
5140539	M54292	10/09/2015	7:22	10/09/2015	8:10	5	238	47	Animal related	Transformer Fuse	Replace - Same Size		V
5140541	L50217	10/09/2015	7:32	10/09/2015	8:13	13	530	40	Animal related	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
5140543	M47816	10/09/2015	7:42	10/09/2015	9:00	6	466	77	Animal related	Fuse	Repair	Repair	V
5140545	B62003	10/09/2015	7:48	10/09/2015	9:07	242	19246	79	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
5140547	B62003	10/09/2015	7:48	10/09/2015	9:07	402	31971	79	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
5140549	B62003	10/09/2015	7:49	10/09/2015	9:07	128	10086	78	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
5140601	D69001	10/09/2015	7:50	10/09/2015	13:48	2	716	358	Underground equipment				I
5140555	A17022	10/09/2015	7:59	10/09/2015	14:33	1	393	393	Overhead equipment	Other		Repair	I

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5154991	Z04520	10/09/2015	8:18	10/09/2015	9:15	4	225	56	Animal related				IV
5140567	N05172	10/09/2015	8:38	10/09/2015	9:44	1	65	65	Overhead equipment	Overhead Transformer	Replace - Same Size		I
5140583	S42579	10/09/2015	9:08	10/09/2015	10:02	1	53	53	Overhead equipment	Transformer Fuse	Repair	Replace - Same Size	VI
5140597	Z57516	10/09/2015	9:15	10/09/2015	10:13	7	402	57	Overhead equipment	Transformer Fuse			IV
5140599	X75573	10/09/2015	9:15	10/09/2015	10:35	1	79	79	Animal related	Transformer Fuse	Replace - Same Size	Replace - Same Size	IV
5140603	N18210	10/09/2015	9:18	10/09/2015	11:30	1	131	131	Animal related	Transformer Fuse	Replace - Same Size		III
5140605	D60002	10/09/2015	9:21	10/09/2015	11:22	1	120	120	Underground equipment	Underground Service	Repair		III
5140609	R60553	10/09/2015	9:23	10/09/2015	15:00	1	336	336	Underground equipment	Underground Transformer	Replace - Same Size		IV
5140619	D87001	10/09/2015	9:39	10/09/2015	10:54	1	74	74	Animal related	Fuse	Replace - Same Size		I
5140625	Q24312	10/09/2015	9:46	10/09/2015	10:54	1	67	67	Animal related	Fuse			VI
5140635	L93149	10/09/2015	10:08	10/09/2015	11:05	8	448	56	Animal related	Fuse	Replace - Same Size		VI
5140651	M21133	10/09/2015	10:18	10/09/2015	11:11	1	52	52	Overhead equipment	Transformer Fuse	Repair	Repair	VI
5140657	K58213	10/09/2015	10:26	10/09/2015	11:16	4	198	49	Animal related	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
5140667	R59415	10/09/2015	10:45	10/09/2015	12:16	1	90	90	Animal related	Fuse	Replace - Same Size		IV
5140669	S47576	10/09/2015	10:53	10/09/2015	11:34	1	40	40	Overhead equipment	Fuse		Replace - Same Size	VI
5140671	J18267	10/09/2015	11:18	10/09/2015	12:40	1	81	81	Overhead equipment	Transformer Fuse	Repair	Repair	VI
5140683	T06504	10/09/2015	11:47	10/09/2015	13:20	1	92	92	Overhead equipment	Connector	Patrol/Test/Inspect	Repair	VI
5140687	K89142	10/09/2015	11:54	10/09/2015	12:26	673	21953	32	Unknown	Substation Breaker			III
5140689	S22594	10/09/2015	11:57	10/09/2015	13:25	6	525	87	Animal related	Transformer Fuse	Replace - Same Size	Replace - Same Size	VI
5140691	K89142	10/09/2015	12:08	10/09/2015	12:23	1	14	14	Unknown	Substation Breaker			III
5140709	X75573	10/09/2015	12:56	10/09/2015	13:35	1	38	38	Overhead equipment	Transformer Fuse	Replace - Same Size	Replace - Same Size	IV
5140713	P54828	10/09/2015	13:00	10/09/2015	14:45	1	104	104	Animal related	Transformer Fuse	Replace - Same Size		V
5140717	D55001	10/09/2015	13:07	10/09/2015	13:54	30	1407	46	Unknown	Fuse	Replace - Same Size		I
5140723	A36002	10/09/2015	13:16	10/09/2015	14:08	1	51	51	Unknown	Fuse	Replace - Same Size		I
5140735	J30203	10/09/2015	13:33	10/09/2015	16:06	1	152	152	Overhead equipment	Overhead Service	Repair		VI
5140737	A85001	10/09/2015	13:42	10/09/2015	14:36	1	53	53	Animal related	Fuse	Replace - Same Size		I
5140741	Q01282	10/09/2015	13:50	10/09/2015	15:10	1	79	79	Animal related	Fuse			III
5140743	Y55505	10/09/2015	13:53	10/09/2015	15:31	1	97	97	Animal related	Transformer Fuse	Replace - Same Size	Repair	IV
5140745	R61241	10/09/2015	13:54	10/09/2015	15:10	9	682	75	Animal related	Transformer Fuse	Replace - Same Size		IV
5140747	T42525	10/09/2015	13:57	10/09/2015	15:28	1	90	90	Overhead equipment	Jumper	Repair		IV
5140749	R04412	10/09/2015	13:59	10/09/2015	16:03	1	123	123	Animal related	Transformer Fuse	Replace - Same Size		V
5140753	K07322	10/09/2015	14:14	10/09/2015	14:56	1	41	41	Animal related	Transformer Fuse	Replace - Same Size	Replace - Same Size	I
5140757	M47816	10/09/2015	14:26	10/09/2015	15:20	1	53	53	Overhead equipment	Overhead Service			V
5140759	B81003	10/09/2015	14:27	10/09/2015	15:17	1	49	49	Animal related	Transformer Fuse	Replace - Same Size		I
5140761	P07179	10/09/2015	14:36	10/09/2015	15:30	1	53	53	Unknown	Transformer Fuse	Replace - Same Size		I
5140767	K82202	10/09/2015	14:48	10/09/2015	15:16	5	135	27	Overhead equipment	Fuse		Replace - Same Size	III
5140769	307003	10/09/2015	14:56	10/09/2015	17:10	2	267	133	Public	Overhead Primary	Patrol/Test/Inspect	Repair	VI
5140771	D89002	10/09/2015	15:08	10/09/2015	16:50	63	6389	101	Animal related	Fuse	Replace - Same Size		I
5140775	T06504	10/09/2015	15:21	10/09/2015	16:52	1	90	90	Overhead equipment	Connector	Patrol/Test/Inspect	Repair	VI
5140777	Q06142	10/09/2015	15:21	10/09/2015	16:18	1	56	56	Animal related	Fuse	Replace - Same Size		IV
5140779	L71171	10/09/2015	15:26	10/09/2015	16:20	3	161	53	Animal related	Transformer Fuse	Replace - Same Size		IV
5140781	S02502	10/09/2015	15:30	10/09/2015	16:58	1	87	87	Animal related	Disconnect Switch		Replace - New Size	VI
5140783	M05360	10/09/2015	15:31	10/09/2015	16:44	1	72	72	Animal related	Fuse	Replace - Same Size		V
5140795	X83541	10/09/2015	15:57	10/09/2015	19:48	25	4489	230	Underground equipment	Underground Primary	Repair	Repair	IV
5140793	M09144	10/09/2015	16:01	10/09/2015	17:45	1	103	103	Animal related	Fuse			VI
5140803	L17102	10/09/2015	16:38	10/09/2015	17:09	20	614	30	Unknown	Fuse	Replace - Same Size		III
5140809	C10002	10/09/2015	16:46	10/09/2015	17:55	1	68	68	Overhead equipment	Connector	Replace - Same Size		III
5140813	P47169	10/09/2015	17:06	10/09/2015	18:45	1	98	98	Unknown	Transformer Fuse	Replace - Same Size		I
5140815	K30204	10/09/2015	17:09	10/09/2015	18:58	16	1736	108	Overhead equipment	Fuse			III
5140817	J67132	10/09/2015	17:18	10/09/2015	18:46	1	87	87	Tree related-tree contact	Other			III
5140823	H22346	10/09/2015	17:29	10/09/2015	19:10	1	100	100	Jurisdictional	Meter	Reconnect		V
5140827	J46180	10/09/2015	17:36	10/09/2015	18:03	19	510	26	Tree related-tree contact	Other			III
5140829	C70001	10/09/2015	17:42	10/09/2015	19:20	1	97	97	Animal related	Fuse	Replace - Same Size		III
5140837	M09143	10/09/2015	18:14	10/09/2015	20:00	32	3360	105	Overhead equipment	Fuse	Replace - Same Size		VI
5140843	M47802	10/09/2015	18:34	10/09/2015	19:40	1	65	65	Intentional	Customer Equipment			V
5140847	D90004	10/09/2015	18:57	10/09/2015	23:24	12	2189	267	Underground equipment	Underground Primary	Repair		III

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5140849	J82116	10/09/2015	18:58	10/09/2015	19:58	1	59	59	Underground equipment				VI
5140853	D96002	10/09/2015	19:32	10/09/2015	21:15	1	102	102	Animal related	Fuse	Replace - Same Size		I
5140855	R94269	10/09/2015	19:57	10/10/2015	15:00	16	2394	1143	Underground equipment	Underground Primary		Repair	VI
5140859	X83541	10/09/2015	20:01	10/09/2015	20:14	9	112	12	Underground equipment				IV
5140875	P77237	10/09/2015	21:00	10/09/2015	23:40	1	159	159	Animal related	Fuse	Replace - Same Size		VI
5140879	B38001	10/09/2015	22:31	10/10/2015	5:38	2	854	427	Underground equipment	Underground Primary	Repair		I
5140881	V21500	10/09/2015	22:38	10/10/2015	10:29	14	7806	710	Underground equipment	Underground Primary	Repair	Repair	II
5140885	V21548	10/09/2015	23:38	10/10/2015	0:23	1	44	44	Overhead equipment	Transformer Fuse	Replace - Same Size	Replace - Same Size	II
5140887	B28006	10/10/2015	1:31	10/10/2015	11:17	1274	144227	586	Public	Pole	Repair	Replace - Same Size	I
5140957	P60170	10/10/2015	2:37	10/10/2015	5:58	4	800	200	Animal related	Disconnect Switch	Replace - New Size	Replace - New Size	VI
5140961	K01240	10/10/2015	4:05	10/10/2015	5:06	1	60	60	Animal related	Transformer Fuse	Replace - Same Size		VI
5140965	T46001	10/10/2015	4:26	10/10/2015	7:50	1	203	203	Tree related-tree broken	Overhead Service	Patrol/Test/Inspect		VI
5140967	T59942	10/10/2015	5:07	10/10/2015	7:32	7	1011	144	Overhead equipment	Pole	Replace - Same Size		VI
5140973	324002	10/10/2015	5:55	10/10/2015	13:25	6	2696	449	Overhead equipment	Overhead Primary	Patrol/Test/Inspect		VI
5140979	R49275	10/10/2015	7:54	10/10/2015	9:18	36	2998	83	Overhead equipment	Overhead Primary	Repair		VI
5140983	D88001	10/10/2015	8:02	10/10/2015	10:05	1	122	122	Animal related	Transformer Fuse	Replace - Same Size		I
5140985	A50002	10/10/2015	8:03	10/10/2015	9:17	40	2960	74	Overhead equipment	Connector	Repair		I
5140999	S20554	10/10/2015	8:12	10/10/2015	9:24	4	285	71	Animal related	Transformer Fuse			VI
5141013	K69117	10/10/2015	8:30	10/10/2015	12:17	5	1135	226	Underground equipment	Underground Primary	Repair		IV
5141025	C50002	10/10/2015	9:21	10/10/2015	10:25	5	318	63	Animal related	Transformer Fuse	Replace - Same Size		III
5141027	V24583	10/10/2015	9:30	10/10/2015	11:23	1	112	112	Overhead equipment	Transformer Fuse	Replace - Same Size		II
5141071	Y68581	10/10/2015	9:36	10/10/2015	12:29	1	172	172	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
5141043	K89144	10/10/2015	10:06	10/10/2015	11:01	1	54	54	Animal related	Fuse	Replace - Same Size		III
5141045	K89144	10/10/2015	10:09	10/10/2015	11:01	2	103	51	Animal related	Fuse	Replace - Same Size		III
5141047	Q27185	10/10/2015	10:30	10/10/2015	12:19	22	2392	108	Animal related	Fuse	Replace - Same Size		VI
5141051	P25152	10/10/2015	10:37	10/10/2015	12:02	1	84	84	Animal related	Fuse	Replace - Same Size		III
5141063	HB0391	10/10/2015	11:54	10/10/2015	13:08	1	74	74	Overhead equipment	Fuse	Repair		IV
5141067	U44529	10/10/2015	12:00	10/10/2015	14:30	7	1049	149	Tree related-tree contact	Fuse	Replace - Same Size		II
5141069		10/10/2015	12:15	10/10/2015	13:08	1	53	53	Overhead equipment	Overhead Primary	Repair		V
5141083	N05172	10/10/2015	13:13	10/10/2015	14:01	1	47	47	Animal related	Transformer Fuse	Repair		I
5141095	X09557	10/10/2015	13:42	10/10/2015	15:41	15	1775	118	Animal related	Transformer Fuse	Repair	Repair	IV
5141135	Q34360	10/10/2015	13:46	10/10/2015	21:25	31	9746	459	Overhead equipment	Pole	Repair	Replace - Same Size	I
5141107	A50001	10/10/2015	13:52	10/10/2015	15:05	10	726	72	Animal related	Transformer Fuse	Replace - Same Size		I
5141137	Q34360	10/10/2015	14:01	10/10/2015	15:01	1	59	59	Public	Overhead Primary	Replace - Same Size		I
5141123	U94573	10/10/2015	15:05	10/10/2015	15:41	4	143	35	Animal related	Transformer Fuse	Replace - Same Size	Replace - Same Size	II
5141139	M09143	10/10/2015	15:12	10/10/2015	15:45	45	1493	33	Animal related	Fuse	Replace - Same Size		VI
5141129	P12290	10/10/2015	15:14	10/10/2015	16:45	12	1082	90	Animal related	Fuse	Replace - Same Size		V
5141133	N18211	10/10/2015	15:18	10/10/2015	17:24	9	1128	125	Animal related	Transformer Fuse	Replace - Same Size		III
5141143	E10001	10/10/2015	15:37	10/10/2015	16:35	1	57	57	Overhead equipment	Transformer Fuse	Replace - Same Size		III
5141167	N18211	10/10/2015	15:57	10/10/2015	17:35	7	682	97	Animal related	Fuse	Replace - Same Size		III
5141147	N18211	10/10/2015	16:04	10/10/2015	17:41	1	96	96	Animal related	Fuse			III
5141153	Q24313	10/10/2015	16:18	10/10/2015	17:32	1	73	73	Animal related	Fuse	Replace - Same Size		VI
5141155	H01194	10/10/2015	16:24	10/10/2015	18:23	1	118	118	Tree related-tree broken	Overhead Service	Repair		III
5141159	K30205	10/10/2015	17:07	10/10/2015	18:56	28	3049	108	Overhead equipment				III
5141175	K71821	10/10/2015	18:28	10/10/2015	19:41	4	290	72	Animal related	Transformer Fuse	Replace - Same Size		IV
5141177	K52401	10/10/2015	18:38	10/10/2015	19:22	1	43	43	Animal related	Fuse	Replace - Same Size		V
5141179	K30205	10/10/2015	19:08	10/10/2015	19:50	28	1175	41	Overhead equipment	Fuse			III
5141189	S93553	10/10/2015	20:19	10/10/2015	22:19	1	119	119	Overhead equipment	Transformer Fuse	Replace - Same Size		VI
5141193	L35283	10/10/2015	21:02	10/11/2015	0:40	7	1519	217	Overhead equipment	Overhead Transformer		Repair	III
5141201	Q91141	10/11/2015	2:10	10/11/2015	4:30	16	2238	139	Underground equipment	Underground Primary	Switch/Reset	Repair	I
5141205	A45003	10/11/2015	2:46	10/11/2015	8:19	1	332	332	Underground equipment	Fuse	Patrol/Test/Inspect	Replace - Same Size	I
5141209	R61242	10/11/2015	3:50	10/11/2015	5:42	36	3964	112	Underground equipment	Underground Primary	Switch/Reset	Repair	IV
5141211	N93260	10/11/2015	4:28	10/11/2015	6:40	1	131	131	Overhead equipment	Fuse			III
5141215	J98114	10/11/2015	7:07	10/11/2015	8:36	4	354	88	Overhead equipment	Transformer Fuse	Replace - Same Size		VI
5141217	V92542	10/11/2015	7:09	10/11/2015	11:44	5	1378	275	Underground equipment	Underground Transformer	Replace - New Size		II
5141223	M54292	10/11/2015	7:44	10/11/2015	8:52	45	3028	67	Animal related	Fuse	Replace - Same Size	Replace - Same Size	V

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5141229	S22594	10/11/2015	8:11	10/11/2015	8:45	3	100	33	Animal related	Fuse	Replace - Same Size		VI
5141239	S20555	10/11/2015	8:49	10/11/2015	9:51	1	61	61	Animal related	Fuse			VI
5141241	J06168	10/11/2015	8:53	10/11/2015	10:30	1	96	96	Animal related	Transformer Fuse	Replace - Same Size		I
5141253	R61242	10/11/2015	9:25	10/11/2015	10:27	148	9067	61	Overhead equipment	Fuse	Replace - Same Size		IV
5141257	S47585	10/11/2015	9:29	10/11/2015	10:10	1	40	40	Animal related	Overhead Secondary		Replace - Same Size	VI
5141259	D72003	10/11/2015	9:58	10/11/2015	10:53	12	654	54	Animal related	Transformer Fuse	Replace - Same Size	Replace - Same Size	I
5141265	B93001	10/11/2015	10:04	10/11/2015	13:00	28	4906	175	Animal related	Fuse	Replace - Same Size	Replace - Same Size	I
5141281	D37001	10/11/2015	10:14	10/11/2015	11:26	91	6600	72	Animal related	Fuse	Replace - Same Size		I
5141273	D37001	10/11/2015	10:15	10/11/2015	11:26	4	280	70	Animal related	Fuse	Replace - Same Size		I
5141275	J01118	10/11/2015	10:16	10/11/2015	12:00	8	828	103	Unknown	Fuse	Replace - Same Size		I
5141285	R49261	10/11/2015	10:19	10/11/2015	11:39	1	79	79	Animal related	Transformer Fuse	Replace - Same Size		VI
5141291	S19553	10/11/2015	10:43	10/11/2015	12:44	6	722	120	Animal related	Transformer Fuse	Repair	Replace - Same Size	VI
5141293	R10943	10/11/2015	10:46	10/11/2015	11:37	1	50	50	Animal related	Fuse	Replace - Same Size		VI
5141295	R10943	10/11/2015	10:46	10/11/2015	11:37	1	50	50	Animal related	Fuse	Replace - Same Size		VI
5141297	M36185	10/11/2015	10:51	10/11/2015	13:00	5	642	128	Unknown	Fuse	Replace - Same Size		I
5141299	D37001	10/11/2015	10:53	10/11/2015	11:37	1	43	43	Animal related				I
5141303	X75573	10/11/2015	11:15	10/11/2015	12:15	1	59	59	Animal related	Transformer Fuse	Replace - Same Size		IV
5141305	V92540	10/11/2015	11:21	10/11/2015	12:30	1	68	68	Animal related	Transformer Fuse	Replace - Same Size	Patrol/Test/Inspect	II
5141307	N60181	10/11/2015	11:27	10/11/2015	13:50	1	142	142	Animal related	Transformer Fuse	Replace - Same Size		I
5141309	T59925	10/11/2015	11:32	10/11/2015	11:58	1	25	25	Animal related	Fuse	Replace - Same Size		VI
5141315	R23332	10/11/2015	13:17	10/11/2015	14:28	22	1576	71	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	V
5141319	Q93522	10/11/2015	13:19	10/11/2015	15:55	1	155	155	Overhead equipment	Overhead Secondary	Repair		I
5141321	J83138	10/11/2015	13:29	10/11/2015	14:09	1	39	39	Overhead equipment	Fuse	Replace - Same Size		VI
5141325	Q14390	10/11/2015	14:04	10/11/2015	16:28	39	5523	143	Public	Underground Primary	Repair	Repair	I
5141341	A80002	10/11/2015	14:41	10/11/2015	15:54	1	72	72	Animal related	Transformer Fuse	Replace - Same Size	Replace - Same Size	I
5141363	P26284	10/11/2015	14:50	10/11/2015	18:49	2	477	238	Public	Fuse	Replace - Same Size		I
5154977		10/11/2015	15:10	10/11/2015	15:20	1	10	10	Public				IV
5154975		10/11/2015	15:10	10/11/2015	16:00	1	50	49	Public				IV
5141349		10/11/2015	15:10	10/11/2015	15:20	1338	13179	9	Public				IV
5141351		10/11/2015	15:10	10/11/2015	15:19	364	2959	8	Public				IV
5141357	K31124	10/11/2015	15:11	10/11/2015	16:21	1	69	69	Animal related	Transformer Fuse	Replace - Same Size		I
5141413	J14140	10/11/2015	15:17	10/11/2015	18:16	31	5555	179	Animal related	Overhead Primary	Repair	Repair	VI
5141447	R10943	10/11/2015	15:50	10/11/2015	16:37	1	46	46	Animal related				VI
5141451	R10943	10/11/2015	15:54	10/11/2015	17:15	16	1280	80	Animal related	Fuse	Replace - Same Size		VI
5141453	S93507	10/11/2015	16:45	10/11/2015	17:20	1	34	34	Animal related	Transformer Fuse	Replace - Same Size		VI
5141455	R04415	10/11/2015	16:47	10/11/2015	19:29	1	161	161	Underground equipment	Underground Transformer	Patrol/Test/Inspect	Replace - Same Size	V
5141459	R10943	10/11/2015	17:17	10/11/2015	18:51	2	186	93	Animal related	Disconnect Switch		Replace - New Size	VI
5141461	E05002	10/11/2015	17:20	10/11/2015	18:37	27	2070	76	Overhead equipment	Fuse	Repair		IV
5141463	U05001	10/11/2015	17:24	10/11/2015	18:30	1	65	65	Overhead equipment	Overhead Service	Repair		II
5141471	K71822	10/11/2015	17:25	10/11/2015	18:30	126	8079	64	Overhead equipment	Fuse	Replace - Same Size		IV
5141475	X88507	10/11/2015	17:34	10/11/2015	18:29	1	54	54	Animal related	Transformer Fuse	Replace - Same Size		IV
5141477	J89126	10/11/2015	17:38	10/11/2015	18:16	9	341	37	Animal related	Transformer Fuse	Replace - Same Size		VI
5141479	P47123	10/11/2015	17:48	10/11/2015	19:10	1	81	81	Animal related	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	I
5141481	K67911	10/11/2015	17:55	10/11/2015	18:35	30	1178	39	Animal related	Fuse	Replace - Same Size		VI
5141485	J14140	10/11/2015	17:59	10/11/2015	18:16	12	210	17	Overhead equipment	Overhead Primary		Replace - Same Size	VI
5141489	J99121	10/11/2015	18:18	10/11/2015	18:57	42	1597	38	Animal related	Fuse	Replace - Same Size		VI
5141491	L93133	10/11/2015	18:27	10/11/2015	19:24	12	678	56	Animal related	Transformer Fuse	Replace - Same Size		VI
5141493	J89126	10/11/2015	18:31	10/11/2015	19:24	1	52	52	Animal related	Fuse	Replace - Same Size		VI
5141495	K71822	10/11/2015	18:34	10/11/2015	18:54	1	19	19	Other				IV
5141511	HB0391	10/11/2015	19:21	10/11/2015	20:18	1	56	56	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
5141515	N18211	10/11/2015	20:00	10/11/2015	21:55	1	114	114	Overhead equipment	Fuse			III
5141517	U99515	10/11/2015	20:43	10/11/2015	22:15	1	91	91	Animal related	Disconnect Switch	Repair		II
5141523	B61001	10/11/2015	21:07	10/11/2015	21:38	1	31	30	Unknown	Fuse	Repair		I
5141525	B61001	10/11/2015	21:07	10/11/2015	21:38	9	270	30	Underground equipment	Underground Primary	Repair		I
5141535	D37001	10/11/2015	23:13	10/12/2015	7:15	9	1661	481	Underground equipment	Underground Primary	Patrol/Test/Inspect	Reconnect	I
5141543	K80382	10/11/2015	23:29	10/12/2015	1:55	46	6710	146	Underground equipment	Underground Primary	Switch/Reset	Repair	IV

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5141559	V21548	10/12/2015	1:25	10/12/2015	4:55	5	1045	209	Animal related	Transformer Fuse	Replace - Same Size		II
5141565	L79159	10/12/2015	2:26	10/12/2015	3:50	4	335	83	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
5141567	S25552	10/12/2015	3:21	10/12/2015	5:15	1	113	113	Animal related	Disconnect Switch		Repair	VI
5141569	S25552	10/12/2015	4:27	10/12/2015	5:15	1	47	47	Animal related				VI
5141571	S27598	10/12/2015	7:06	10/12/2015	8:50	1	103	103	Overhead equipment				VI
5141575	F03003	10/12/2015	7:10	10/12/2015	13:39	15	5832	388	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	III
5141577	R28871	10/12/2015	7:27	10/12/2015	8:21	1	53	53	Animal related	Transformer Fuse	Replace - Same Size		V
5141579	N54213	10/12/2015	7:33	10/12/2015	8:33	1	59	59	Unknown	Fuse	Replace - Same Size		II
5141581	J13108	10/12/2015	7:40	10/12/2015	8:20	1	39	39	Animal related	Transformer Fuse	Replace - Same Size		I
5141589	Q21292	10/12/2015	8:08	10/12/2015	10:09	3	360	120	Animal related	Transformer Fuse	Repair	Replace - Same Size	VI
5141591	L17102	10/12/2015	8:19	10/12/2015	9:59	4	397	99	Overhead equipment	Overhead Secondary	Raise		III
5141595	T12528	10/12/2015	8:25	10/12/2015	9:29	1	63	63	Overhead equipment	Overhead Service	Patrol/Test/Inspect	Repair	VI
5141597	V01002	10/12/2015	8:25	10/12/2015	11:10	1	164	164	Animal related	Transformer Fuse	Replace - Same Size	Replace - Same Size	II
5141599	R06212	10/12/2015	8:26	10/12/2015	9:03	1	36	36	Animal related	Transformer Fuse	Replace - Same Size		II
5141605	Z11536	10/12/2015	8:39	10/12/2015	9:47	1	67	67	Animal related	Transformer Fuse	Repair		IV
5141609	L14232	10/12/2015	8:41	10/12/2015	9:39	1	57	57	Tree related-tree contact	Overhead Service			III
5141617	R39934	10/12/2015	8:47	10/12/2015	9:33	1	45	45	Overhead equipment	Transformer Fuse	Replace - Same Size		VI
5141619	Z11536	10/12/2015	8:51	10/12/2015	9:47	1	55	55	Animal related	Transformer Fuse	Repair		IV
5141623	H07106	10/12/2015	9:05	10/12/2015	10:12	1	66	66	Animal related	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	IV
5141629	K11376	10/12/2015	9:14	10/12/2015	9:45	1	30	30	Animal related	Transformer Fuse	Replace - Same Size		V
5141637	K27150	10/12/2015	9:28	10/12/2015	11:00	1	91	91	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	VI
5141639	A50002	10/12/2015	9:29	10/12/2015	14:48	1	319	319	Underground equipment	Underground Primary	Patrol/Test/Inspect	Reconnect	I
5141657	K27150	10/12/2015	9:51	10/12/2015	11:01	2	139	69	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	VI
5141665	K52400	10/12/2015	9:57	10/12/2015	10:25	1	27	27	Animal related	Transformer Fuse	Replace - Same Size		V
5141667	V19001	10/12/2015	9:57	10/12/2015	11:32	1	94	94	Overhead equipment	Overhead Service	Repair		II
5141675	L63936	10/12/2015	10:08	10/12/2015	10:49	1	40	40	Animal related	Fuse	Replace - Same Size		VI
5141679	K69117	10/12/2015	10:11	10/12/2015	15:14	55	16515	302	Underground equipment	Underground Primary	Switch/Reset	Repair	IV
5141689	N05172	10/12/2015	10:28	10/12/2015	11:05	1	37	36	Animal related	Transformer Fuse	Replace - Same Size		I
5141701	B53001	10/12/2015	10:59	10/12/2015	12:00	1	60	60	Overhead equipment	Transformer Fuse	Replace - Same Size		III
5141709	S13546	10/12/2015	11:18	10/12/2015	11:32	1	13	13	Other				VI
5141717	V41527	10/12/2015	11:32	10/12/2015	12:47	1	75	74	Overhead equipment	Transformer Fuse	Repair		II
5141725	P49180	10/12/2015	12:16	10/12/2015	13:31	1	74	74	Animal related	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	I
5141729	X02548	10/12/2015	12:23	10/12/2015	12:59	4	145	36	Overhead equipment	Overhead Primary	Repair		IV
5141749	X64501	10/12/2015	13:02	10/12/2015	14:26	2	167	83	Tree related-tree contact	Tree			IV
5141803	D48001	10/12/2015	13:41	10/12/2015	17:03	23	4637	201	Overhead equipment	Guy Wire	Repair		I
5141773	P83710	10/12/2015	13:49	10/12/2015	15:45	1	115	115	Animal related	Transformer Fuse	Repair		I
5141779	J05140	10/12/2015	14:32	10/12/2015	21:45	3	1298	432	Overhead equipment	Overhead Secondary	Replace - Same Size	Repair	I
5141787	S78551	10/12/2015	14:44	10/12/2015	16:50	1	125	125	Overhead equipment	Overhead Service			VI
5141795	M40116	10/12/2015	15:13	10/12/2015	16:15	1	61	61	Overhead equipment	Overhead Service	Repair		I
5141831	D48001	10/12/2015	15:16	10/12/2015	17:03	3	321	107	Overhead equipment	Overhead Primary	Replace - Same Size		I
5141799	Y98561	10/12/2015	15:20	10/12/2015	16:25	1	64	64	Tree related-tree contact	Overhead Service	Repair	Repair	IV
5141805	V01001	10/12/2015	15:27	10/12/2015	16:29	1	61	61	Public	Overhead Secondary	Repair		II
5141807	K09863	10/12/2015	15:29	10/12/2015	17:15	3	315	105	Animal related	Underground Secondary			V
5141809	D37001	10/12/2015	15:37	10/12/2015	17:00	1	82	82	Overhead equipment	Overhead Service	Reconnect		I
5141813	U93563	10/12/2015	15:49	10/12/2015	17:36	1	106	106	Overhead equipment				II
5141815	S25552	10/12/2015	15:53	10/12/2015	17:33	5	495	99	Animal related	Disconnect Switch	Patrol/Test/Inspect	Replace - New Size	VI
5141817	P49180	10/12/2015	15:57	10/12/2015	17:15	1	77	77	Unknown	Fuse	Patrol/Test/Inspect	Replace - Same Size	I
5141821	P98192	10/12/2015	15:58	10/12/2015	22:27	134	27777	389	Underground equipment	Underground Primary	Repair	Replace - Same Size	III
5141823	F03003	10/12/2015	16:00	10/12/2015	19:25	1	205	205	Underground equipment	Underground Connector	Repair		III
5141825	J20931	10/12/2015	16:04	10/12/2015	17:38	1	93	93	Animal related	Transformer Fuse	Replace - Same Size		VI
5141833	L00133	10/12/2015	16:27	10/12/2015	17:33	5	325	65	Unknown	Fuse	Replace - Same Size		III
5141835	X16511	10/12/2015	16:28	10/12/2015	20:04	28	6030	215	Public	Overhead Primary		Replace - Same Size	IV
5141841	S15567	10/12/2015	16:53	10/12/2015	18:25	1	91	91	Overhead equipment	Transformer Fuse	Replace - Same Size		VI
5141843	S15567	10/12/2015	16:58	10/12/2015	18:29	1	90	90	Overhead equipment	Transformer Fuse	Replace - Same Size		VI
5141853	L63936	10/12/2015	17:22	10/12/2015	18:33	3	212	70	Animal related	Fuse	Replace - Same Size		VI
5141855	B73001	10/12/2015	17:31	10/12/2015	18:57	1	85	85	Overhead equipment	Disconnect Switch	Replace - Same Size		I

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5141857	R84148	10/12/2015	17:34	10/12/2015	19:57	1	142	142	Overhead equipment	Connector	Tie/Tighten	Reconnect	I
5141859	M36185	10/12/2015	17:39	10/12/2015	19:58	1	138	138	Underground equipment	Underground Service	Disconnect	Repair	I
5141865	L86175	10/12/2015	17:42	10/12/2015	19:58	58	7867	135	Animal related	Fuse	Replace - Same Size		IV
5141871	P98192	10/12/2015	17:59	10/12/2015	19:57	1	117	117	Underground equipment	Underground Primary			III
5141873	B44001	10/12/2015	18:13	10/12/2015	20:17	10	1232	123	Animal related	Fuse	Replace - Same Size		I
5141875	V82551	10/12/2015	18:31	10/12/2015	20:16	1	104	104	Animal related	Transformer Fuse	Replace - Same Size		II
5141877	T23528	10/12/2015	18:31	10/12/2015	19:56	1	84	84	Overhead equipment	Disconnect Switch	Replace - New Size		VI
5141879	J06168	10/12/2015	18:38	10/12/2015	20:58	1	139	139	Overhead equipment	Jumper	Repair		I
5141887	N94182	10/12/2015	18:58	10/12/2015	21:47	55	9307	169	Overhead equipment	Recloser			I
5141891	L86175	10/12/2015	19:03	10/12/2015	19:58	1	54	54	Animal related				IV
5141905	A68002	10/12/2015	19:38	10/12/2015	20:50	1	71	71	Overhead equipment	Connector	Replace - New Size		I
5141909	P98192	10/12/2015	20:10	10/12/2015	21:43	1	92	92	Underground equipment	Underground Primary			III
5141917	U84534	10/12/2015	20:41	10/12/2015	23:15	1	153	153	Underground equipment	Underground Service	Repair		II
5141919	U62510	10/12/2015	20:53	10/13/2015	1:05	1	251	251	Overhead equipment	Transformer Fuse	Replace - Same Size	Replace - Same Size	II
5141923	J06168	10/12/2015	21:09	10/12/2015	22:45	1	95	95	Overhead equipment	Jumper	Repair		I
5141925	S13546	10/12/2015	21:11	10/12/2015	22:42	15	1353	90	Overhead equipment	Disconnect Switch	Repair		VI
5141929	N94180	10/12/2015	21:31	10/12/2015	22:41	1	69	69	Overhead equipment				I
5141931	U31598	10/12/2015	21:35	10/13/2015	0:30	1	174	174	Overhead equipment	Transformer Fuse	Replace - Same Size	Replace - Same Size	II
5141933	D16002	10/12/2015	22:36	10/13/2015	0:25	1	108	108	Tree related-tree broken	Overhead Service		Repair	I
5141935	C36001	10/12/2015	23:06	10/13/2015	0:39	1	92	92	Animal related	Fuse	Replace - Same Size		III
5141937	T02534	10/12/2015	23:16	10/13/2015	5:58	1	401	401	Overhead equipment	Overhead Transformer		Replace - Same Size	VI
5141939	N67310	10/12/2015	23:32	10/13/2015	0:54	1	81	81	Overhead equipment	Other	Replace - Same Size	Replace - Same Size	I
5141941	A91001	10/13/2015	4:08	10/13/2015	6:35	2	293	146	Underground equipment	Underground Transformer	Replace - Same Size		I
5141943	L50214	10/13/2015	4:43	10/13/2015	6:17	1	93	93	Animal related	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
5141945	T08502	10/13/2015	7:11	10/13/2015	8:30	11	864	78	Animal related	Overhead Primary	Repair	Repair	VI
5141947	337003	10/13/2015	7:22	10/13/2015	8:30	1	67	67	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect		VI
5141985	Z10500	10/13/2015	7:24	10/13/2015	8:17	281	14817	52	Animal related	Recloser	Switch/Reset		IV
5141981	V80506	10/13/2015	7:34	10/13/2015	8:37	1	62	62	Overhead equipment	Transformer Fuse	Replace - New Size		II
5141995	R99180	10/13/2015	7:38	10/13/2015	11:28	1	229	229	Overhead equipment	Overhead Transformer		Replace - Same Size	IV
5142001	Q01282	10/13/2015	7:46	10/13/2015	8:30	12	524	43	Animal related	Transformer Fuse	Repair	Repair	III
5142009	M47802	10/13/2015	7:51	10/13/2015	8:30	22	841	38	Animal related	Fuse	Repair	Repair	V
5142013	T08502	10/13/2015	8:02	10/13/2015	8:36	1	33	33	Animal related	Overhead Primary	Repair	Repair	VI
5142015	U73583	10/13/2015	8:06	10/13/2015	9:53	3	318	106	Animal related	Transformer Fuse	Replace - Same Size		II
5142017	M47802	10/13/2015	8:07	10/13/2015	8:53	1	45	45	Animal related	Fuse	Repair	Repair	V
5142019	K71812	10/13/2015	8:22	10/13/2015	8:56	1	33	33	Animal related	Transformer Fuse	Replace - Same Size		IV
5142021	T08502	10/13/2015	8:24	10/13/2015	8:30	1	5	5	Animal related	Overhead Primary	Repair	Repair	VI
5142025	Z10500	10/13/2015	8:27	10/13/2015	8:34	1	7	7	Animal related	Transformer Fuse	Replace - Same Size		IV
5142027	K71812	10/13/2015	8:27	10/13/2015	8:56	6	169	28	Animal related	Transformer Fuse	Replace - Same Size		IV
5142031	M09175	10/13/2015	8:33	10/13/2015	9:00	1	26	26	Animal related	Fuse	Replace - Same Size		VI
5142029	K71812	10/13/2015	8:33	10/13/2015	12:26	1	232	232	Tree related-tree contact	Overhead Service			IV
5142033	U04589	10/13/2015	8:33	10/13/2015	10:27	4	454	113	Animal related	Transformer Fuse	Replace - Same Size		II
5142035	R08910	10/13/2015	8:35	10/13/2015	9:41	1	65	65	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	VI
5142037	R49261	10/13/2015	8:51	10/13/2015	10:10	1	78	78	Overhead equipment	Transformer Fuse	Repair	Repair	VI
5142045	R10903	10/13/2015	8:57	10/13/2015	9:53	12	669	55	Animal related	Fuse	Repair		VI
5142055	N67310	10/13/2015	9:01	10/13/2015	10:18	1	76	76	Overhead equipment	Overhead Secondary	Reconnect		I
5142063	B73003	10/13/2015	9:14	10/13/2015	10:56	1	101	101	Animal related	Transformer Fuse	Replace - Same Size		I
5142091	P57108	10/13/2015	9:26	10/13/2015	12:21	573	100148	174	Overhead equipment	Overhead Primary	Repair	Repair	VI
5142117	U39541	10/13/2015	9:40	10/13/2015	13:31	1	230	230	Unknown	Transformer Fuse	Repair	Replace - Same Size	II
5142119	P49187	10/13/2015	9:45	10/13/2015	10:31	1	45	45	Overhead equipment	Overhead Service	Patrol/Test/Inspect	Repair	I
5142123	341002	10/13/2015	9:46	10/13/2015	13:20	2	426	213	Tree related-tree broken	Overhead Secondary	Patrol/Test/Inspect	Repair	VI
5142125	H01190	10/13/2015	9:47	10/13/2015	11:29	31	3144	101	Unknown	Fuse	Replace - Same Size		III
5142129	P69175	10/13/2015	9:48	10/13/2015	10:45	7	397	56	Animal related	Overhead Transformer		Patrol/Test/Inspect	III
5142165	X96543	10/13/2015	10:16	10/13/2015	11:31	1	74	74	Overhead equipment	Transformer Fuse			IV
5142167	L79157	10/13/2015	10:18	10/13/2015	14:38	1	259	259	Underground equipment	Underground Service			IV
5142173	P82291	10/13/2015	10:24	10/13/2015	11:45	1	80	80	Animal related	Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
5142175	P82291	10/13/2015	10:24	10/13/2015	11:45	1	80	80	Animal related	Fuse	Patrol/Test/Inspect	Replace - Same Size	VI

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5142189	Z04520	10/13/2015	10:30	10/13/2015	11:15	1	44	44	Animal related	Transformer Fuse	Replace - Same Size		IV
5142195	Q14392	10/13/2015	10:34	10/13/2015	13:11	1	156	156	Overhead equipment	Overhead Service	Repair		I
5142201	X75573	10/13/2015	10:49	10/13/2015	12:00	1	70	70	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
5142209	U35511	10/13/2015	10:59	10/13/2015	12:31	21	1681	91	Animal related	Fuse	Replace - Same Size		II
5142219	U64521	10/13/2015	11:08	10/13/2015	12:33	1	84	84	Overhead equipment	Overhead Primary	Repair	Replace - Same Size	II
5142221	C70001	10/13/2015	11:11	10/13/2015	11:51	1	39	39	Animal related	Fuse	Replace - Same Size		III
5142241	H01190	10/13/2015	11:36	10/13/2015	13:54	63	8659	137	Overhead equipment	Overhead Primary	Repair		III
5142347	J07135	10/13/2015	12:16	10/13/2015	16:08	17	3951	232	Public	Pole	Repair		I
5142259	M40132	10/13/2015	12:19	10/13/2015	13:36	6	460	76	Animal related	Fuse	Repair	Replace - Same Size	I
5142261	J68402	10/13/2015	12:23	10/13/2015	13:04	1	40	40	Overhead equipment	Fuse		Replace - Same Size	III
5142267	J68402	10/13/2015	12:30	10/13/2015	13:05	1	34	34	Overhead equipment	Fuse		Replace - Same Size	III
5142313	D55001	10/13/2015	12:47	10/13/2015	14:10	181	15053	83	Animal related	Fuse	Repair	Repair	I
5142357	D55001	10/13/2015	12:51	10/13/2015	14:42	11	1217	110	Animal related	Fuse			I
5142315	P57108	10/13/2015	12:59	10/13/2015	13:28	1	28	28	Animal related				VI
5142319	H01192	10/13/2015	13:00	10/13/2015	17:42	5	1409	282	Underground equipment	Underground Primary	Repair		III
5142327	R02121	10/13/2015	13:15	10/13/2015	13:49	1	33	33	Animal related	Transformer Fuse	Repair	Repair	VI
5142329	Y73504	10/13/2015	13:19	10/13/2015	15:44	4	583	145	Public				IV
5142333	Z57516	10/13/2015	13:22	10/13/2015	14:32	1	69	69	Overhead equipment	Transformer Fuse			IV
5142337	HD0574	10/13/2015	13:26	10/13/2015	18:00	1	273	273	Underground equipment	Disconnect Switch	Replace - Same Size	Replace - Same Size	VI
5142345	H01190	10/13/2015	13:29	10/13/2015	15:12	42	4310	102	Animal related	Fuse	Replace - Same Size		III
5142343	X82585	10/13/2015	13:31	10/13/2015	14:23	5	258	51	Animal related	Disconnect Switch		Install	IV
5142351	N94180	10/13/2015	14:05	10/13/2015	16:00	1	114	114	Animal related	Transformer Fuse	Repair	Repair	I
5142355	H01192	10/13/2015	14:12	10/13/2015	14:50	1	37	37	Underground equipment	Underground Primary	Switch/Reset		III
5142359	Y11556	10/13/2015	14:15	10/13/2015	14:55	1	39	39	Tree related-tree contact	Meter	Disconnect		IV
5142361	P58155	10/13/2015	14:22	10/13/2015	14:48	1	25	25	Other				VI
5142363	T06503	10/13/2015	14:32	10/13/2015	15:10	1	37	37	Animal related	Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
5142365	L86175	10/13/2015	14:41	10/13/2015	17:49	1	187	187	Public	Pole	Repair	Replace - Same Size	IV
5142367	H01190	10/13/2015	15:05	10/13/2015	15:15	1	9	9	Animal related	Fuse	Replace - Same Size		III
5142369	Q15844	10/13/2015	15:08	10/13/2015	16:00	1	51	51	Tree related-tree broken	Overhead Service	Repair		V
5142375	V23522	10/13/2015	15:24	10/13/2015	15:51	8	210	26	Tree related-tree broken	Transformer Fuse	Replace - Same Size		II
5142381	A85001	10/13/2015	15:55	10/13/2015	17:37	1	101	101	Animal related	Other		Repair	I
5142383	V21500	10/13/2015	15:57	10/13/2015	18:22	1	144	144	Animal related	Transformer Fuse	Replace - Same Size		II
5142387	S19553	10/13/2015	16:14	10/13/2015	17:32	1	77	77	Unknown	Customer Equipment	Replace - Same Size		VI
5142389	T09558	10/13/2015	16:22	10/13/2015	17:50	1	87	87	Underground equipment	Underground Secondary	Patrol/Test/Inspect	Repair	VI
5142399	V45526	10/13/2015	16:50	10/13/2015	18:00	14	976	69	Animal related	Transformer Fuse	Replace - Same Size	Replace - Same Size	II
5142411	D72002	10/13/2015	17:09	10/14/2015	0:34	1	444	444	Public	Underground Primary	Patrol/Test/Inspect	Patrol/Test/Inspect	I
5142417	R65451	10/13/2015	17:33	10/13/2015	18:25	14	726	51	Unknown	Transformer Fuse			IV
5142419	R65451	10/13/2015	17:42	10/13/2015	18:28	1	45	45	Unknown	Transformer Fuse			IV
5142431	P47123	10/13/2015	19:07	10/13/2015	21:22	1	134	134	Overhead equipment	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	I
5142433	D72002	10/13/2015	19:17	10/14/2015	0:15	4	1195	298	Public	Underground Primary	Repair	Replace - Same Size	I
5142437	D35003	10/13/2015	19:19	10/13/2015	22:23	1	183	183	Overhead equipment	Fuse			I
5142439	Q74149	10/13/2015	19:21	10/13/2015	21:00	1	98	98	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
5142451	J84145	10/13/2015	20:29	10/13/2015	21:43	6	439	73	Underground equipment				VI
5142453	T22508	10/13/2015	20:54	10/13/2015	21:33	20	792	39	Public	Pole	Repair		VI
5142459	J84145	10/13/2015	21:45	10/14/2015	1:58	1	252	252	Underground equipment	Underground Service	Disconnect	Repair	VI
5142465	D72002	10/13/2015	22:38	10/14/2015	0:15	11	1074	97	Public	Underground Primary	Repair	Replace - Same Size	I
5142473	Q82907	10/14/2015	1:13	10/14/2015	5:27	1	253	253	Animal related	Overhead Transformer	Replace - Same Size	Replace - Same Size	VI
5142485	Q82906	10/14/2015	6:30	10/14/2015	7:14	20	865	43	Animal related	Fuse			VI
5142487	P98191	10/14/2015	7:10	10/14/2015	8:27	1	76	76	Overhead equipment	Jumper	Repair	Repair	III
5142489	V20502	10/14/2015	7:20	10/14/2015	9:27	1	126	126	Overhead equipment	Transformer Fuse	Replace - Same Size		II
5142497	U60518	10/14/2015	7:52	10/14/2015	10:00	1	127	127	Animal related	Transformer Fuse			II
5142499	U84534	10/14/2015	7:53	10/14/2015	9:52	1	118	118	Animal related	Fuse	Replace - Same Size		II
5142503	R93351	10/14/2015	8:07	10/14/2015	9:18	38	2681	70	Animal related	Fuse	Replace - Same Size		V
5142505	R93351	10/14/2015	8:10	10/14/2015	9:21	6	423	70	Animal related	Customer Equipment	Patrol/Test/Inspect	Advise Customer	V
5142507	U84534	10/14/2015	8:13	10/14/2015	9:52	1	98	98	Animal related	Fuse	Replace - Same Size		II
5142511	T41540	10/14/2015	8:22	10/14/2015	11:00	1	157	157	Animal related	Transformer Fuse	Replace - Same Size		IV

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5142513	N67309	10/14/2015	8:25	10/14/2015	10:40	1	134	134	Overhead equipment	Overhead Transformer	Replace - Same Size		I
5142517	Y97512	10/14/2015	8:31	10/14/2015	9:35	8	507	63	Animal related	Transformer Fuse	Replace - Same Size		IV
5142523	S14509	10/14/2015	8:40	10/14/2015	10:24	1	103	103	Unknown	Meter	Replace - Same Size		VI
5142525	S61529	10/14/2015	8:43	10/14/2015	9:20	1	36	36	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	VI
5142527	U68552	10/14/2015	8:52	10/14/2015	13:47	1	294	294	Underground equipment	Underground Primary		Repair	II
5142533	D48001	10/14/2015	8:59	10/14/2015	9:36	92	3397	36	Animal related	Fuse	Patrol/Test/Inspect	Replace - Same Size	I
5142543	M05362	10/14/2015	9:20	10/14/2015	10:21	42	2551	60	Animal related	Fuse	Replace - Same Size		V
5142547	M04364	10/14/2015	9:24	10/14/2015	10:59	27	2560	94	Animal related	Transformer Fuse	Replace - Same Size		V
5142701	D69001	10/14/2015	9:25	10/14/2015	17:04	6	2758	459	Underground equipment	Underground Primary	Repair	Repair	I
5142555	H14342	10/14/2015	9:36	10/14/2015	12:57	6	1200	200	Animal related	Transformer Fuse	Replace - Same Size		V
5142563	K28180	10/14/2015	9:46	10/14/2015	10:46	1	59	59	Animal related	Fuse	Replace - Same Size	Repair	III
5142565	L82187	10/14/2015	9:47	10/14/2015	16:28	15	6025	401	Public	Pole			IV
5142577	T08502	10/14/2015	9:54	10/14/2015	10:51	1	56	56	Overhead equipment	Fuse	Patrol/Test/Inspect	Repair	VI
5142591	J67132	10/14/2015	10:01	10/14/2015	10:18	1	16	16	Intentional				III
5142639	X16511	10/14/2015	10:05	10/14/2015	11:48	83	8524	102	Overhead equipment	Lightning Arrestor	Replace - Same Size		IV
5142595	J05139	10/14/2015	10:06	10/14/2015	11:55	1	108	108	Unknown	Transformer Fuse	Replace - Same Size		I
5142603	P57108	10/14/2015	10:09	10/14/2015	10:35	217	5592	25	Overhead equipment				VI
5142615	C15002	10/14/2015	10:12	10/14/2015	10:52	1	39	39	Animal related	Fuse	Replace - Same Size		III
5142545	D69001	10/14/2015	10:18	10/14/2015	12:05	8	856	107	Underground equipment	Other	Replace - Same Size	Replace - Same Size	I
5142633	V17574	10/14/2015	10:21	10/14/2015	12:33	4	527	131	Animal related				II
5142635	R60551	10/14/2015	10:22	10/14/2015	10:56	1	33	33	Animal related	Transformer Fuse	Repair		IV
5142645	S42579	10/14/2015	10:25	10/14/2015	11:10	56	1994	45	Animal related	Fuse	Replace - Same Size		VI
5142659	P62138	10/14/2015	10:38	10/14/2015	11:32	1	53	53	Animal related	Transformer Fuse	Replace - Same Size		VI
5142661	N50334	10/14/2015	10:39	10/14/2015	11:26	5	233	46	Animal related	Fuse	Replace - Same Size		II
5142669	J80807	10/14/2015	10:46	10/14/2015	11:51	1	64	64	Animal related	Fuse	Repair	Repair	V
5142675	H07106	10/14/2015	11:02	10/14/2015	13:00	1	117	117	Tree related-tree contact	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	IV
5142689	V33003	10/14/2015	11:31	10/14/2015	12:39	9	607	67	Overhead equipment	Overhead Secondary	Replace - Same Size		II
5142691	337001	10/14/2015	11:38	10/14/2015	12:56	2	156	78	Overhead equipment	Disconnect Switch	Patrol/Test/Inspect		VI
5142693	F10001	10/14/2015	11:48	10/14/2015	13:08	1	79	79	Animal related	Fuse	Replace - Same Size		III
5142695	N15849	10/14/2015	11:49	10/14/2015	12:41	18	945	52	Public				V
5142699	S88502	10/14/2015	12:00	10/14/2015	13:00	1	59	59	Animal related	Fuse	Replace - Same Size		VI
5142707	Q01282	10/14/2015	12:22	10/14/2015	18:40	47	17753	377	Underground equipment	Underground Primary	Repair		III
5142711	K32916	10/14/2015	12:27	10/14/2015	14:00	1	92	92	Animal related	Fuse			VI
5142713	Y45504	10/14/2015	12:28	10/14/2015	13:15	1	46	46	Overhead equipment	Transformer Fuse	Repair	Replace - Same Size	IV
5142719	A24001	10/14/2015	12:52	10/14/2015	13:36	1	43	43	Other	Connector	Replace - Same Size		I
5142729	M26161	10/14/2015	13:02	10/14/2015	14:49	1	106	106	Animal related	Transformer Fuse	Replace - Same Size	Repair	III
5142731	L08226	10/14/2015	13:02	10/14/2015	13:43	1	40	40	Other	Other			III
5142737	M25144	10/14/2015	13:09	10/14/2015	16:46	256	13474	216	Overhead equipment	Overhead Primary		Repair	IV
5142753	J34357	10/14/2015	13:20	10/14/2015	13:50	1	29	29	Animal related	Fuse	Replace - Same Size		V
5142755	J99151	10/14/2015	13:20	10/14/2015	14:15	1	54	54	Overhead equipment	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
5142769	M37191	10/14/2015	13:22	10/14/2015	14:13	62	3101	50	Overhead equipment	Fuse	Repair	Replace - Same Size	I
5142767	V22555	10/14/2015	13:26	10/14/2015	14:55	5	440	88	Animal related	Fuse	Replace - Same Size		II
5142783	L42158	10/14/2015	13:41	10/14/2015	14:55	11	812	73	Unknown	Transformer Fuse	Replace - Same Size		III
5142791	L24124	10/14/2015	13:48	10/14/2015	18:20	64	17404	271	Underground equipment	Underground Primary	Repair		III
5142803	310123	10/14/2015	14:07	10/14/2015	15:10	4	251	62	Animal related	Fuse	Replace - Same Size		V
5142807	L23145	10/14/2015	14:23	10/14/2015	15:26	4	249	62	Animal related	Fuse	Replace - Same Size		III
5142809	U44568	10/14/2015	14:36	10/14/2015	15:20	1	43	43	Overhead equipment	Transformer Fuse	Replace - Same Size		II
5142819	S16596	10/14/2015	15:05	10/14/2015	15:48	8	341	42	Animal related	Transformer Fuse	Replace - Same Size		VI
5142817	C52002	10/14/2015	15:07	10/14/2015	19:37	1	269	269	Other	Other			III
5142823	Z21564	10/14/2015	15:31	10/14/2015	17:00	1	88	88	Animal related	Transformer Fuse	Replace - Same Size		IV
5142827	Q16867	10/14/2015	15:39	10/14/2015	16:34	1	54	54	Weather	Transformer Fuse	Replace - Same Size	Replace - Same Size	V
5142829	V46552	10/14/2015	15:42	10/14/2015	19:28	2	451	225	Underground equipment	Underground Primary	Repair	Repair	II
5142831	H88109	10/14/2015	16:01	10/14/2015	17:27	1	85	85	Animal related	Fuse	Replace - Same Size		II
5142843	C15002	10/14/2015	16:39	10/14/2015	18:47	1	127	127	Animal related	Transformer Fuse	Repair	Replace - Same Size	III
5142845	R61241	10/14/2015	16:44	10/14/2015	17:32	9	426	47	Animal related	Transformer Fuse	Replace - Same Size		IV
5142849	D69003	10/14/2015	16:52	10/14/2015	17:07	98	1507	15	Underground equipment	Underground Primary	Repair		I

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5142851	K74166	10/14/2015	16:55	10/14/2015	17:33	10	377	37	Animal related	Transformer Fuse	Replace - Same Size		IV
5142853	A85001	10/14/2015	16:56	10/14/2015	18:33	1	96	96	Animal related	Fuse	Replace - Same Size		I
5142857	Y59519	10/14/2015	17:10	10/14/2015	18:40	1	89	89	Animal related	Transformer Fuse	Replace - Same Size	Replace - Same Size	IV
5142859	K74166	10/14/2015	17:29	10/14/2015	17:45	1	15	15	Animal related	Transformer Fuse	Replace - Same Size		IV
5142865	Y36541	10/14/2015	17:59	10/14/2015	18:35	1	35	35	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
5142867	T11508	10/14/2015	18:16	10/14/2015	19:30	1	73	73	Overhead equipment	Transformer Fuse			VI
5142869	C10002	10/14/2015	18:16	10/14/2015	20:24	48	6143	127	Public	Fuse	Replace - Same Size	Replace - Same Size	III
5142875	312112	10/14/2015	18:17	10/14/2015	21:00	1	162	162	Overhead equipment	Overhead Service	Patrol/Test/Inspect	Replace - Same Size	V
5142889	C10002	10/14/2015	18:19	10/14/2015	22:36	6	1540	256	Overhead equipment				III
5142883	B00003	10/14/2015	18:26	10/14/2015	21:28	10	1812	181	Unknown	Fuse			I
5142885	T06503	10/14/2015	18:39	10/14/2015	19:50	1	70	70	Other				VI
5142887	B93003	10/14/2015	19:05	10/14/2015	20:51	1	105	105	Animal related	Transformer Fuse	Replace - Same Size		I
5142899	U30005	10/14/2015	22:06	10/15/2015	0:01	1	114	114	Overhead equipment	Overhead Service	Repair		II
5142903	S25552	10/14/2015	22:25	10/14/2015	23:26	1	60	60	Overhead equipment	Pole	Repair	Repair	VI
5142911	R60552	10/15/2015	3:38	10/15/2015	7:23	14	3009	225	Underground equipment	Underground Primary	Switch/Reset	Repair	IV
5142913	N60181	10/15/2015	4:57	10/15/2015	8:32	33	7064	214	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
5142967	D87001	10/15/2015	7:24	10/15/2015	11:54	134	36086	269	Overhead equipment	Overhead Primary	Patrol/Test/Inspect	Repair	I
5142951	C36001	10/15/2015	8:07	10/15/2015	8:43	3	106	35	Animal related	Fuse	Replace - Same Size		III
5142955	D89002	10/15/2015	8:43	10/15/2015	10:00	1	76	76	Overhead equipment	Connector	Repair		I
5142957	T11509	10/15/2015	8:49	10/15/2015	10:19	1	89	89	Animal related	Transformer Fuse	Replace - Same Size	Replace - Same Size	VI
5142963	X92508	10/15/2015	8:51	10/15/2015	9:50	1	58	58	Overhead equipment	Transformer Fuse	Repair	Replace - Same Size	IV
5142961	K91117	10/15/2015	8:51	10/15/2015	9:20	1	28	28	Animal related	Fuse	Replace - Same Size		III
5142981	K11376	10/15/2015	9:12	10/15/2015	9:59	1	46	46	Animal related	Transformer Fuse	Replace - Same Size		V
5142985	T23528	10/15/2015	9:15	10/15/2015	10:35	1	80	79	Animal related	Fuse	Replace - New Size		VI
5142989	S04545	10/15/2015	9:19	10/15/2015	10:09	28	1381	49	Unknown	Disconnect Switch		Repair	VI
5142993	J99127	10/15/2015	9:21	10/15/2015	10:24	1	62	62	Overhead equipment	Transformer Fuse	Repair	Repair	VI
5143001	K28180	10/15/2015	9:26	10/15/2015	11:13	1	106	106	Underground equipment	Underground Service		Repair	III
5143209	K39154	10/15/2015	9:41	10/15/2015	15:29	1	347	347	Underground equipment	Underground Primary	Repair		III
5143015	Q11516	10/15/2015	9:47	10/15/2015	10:15	1	27	27	Overhead equipment	Overhead Secondary	Repair	Repair	I
5143207	K39154	10/15/2015	10:09	10/15/2015	15:02	6	1759	293	Underground equipment				III
5143029	N60181	10/15/2015	10:17	10/15/2015	11:45	1	87	87	Overhead equipment	Fuse	Replace - Same Size		I
5143031	V74513	10/15/2015	10:20	10/15/2015	13:43	1	202	202	Underground equipment	Underground Service		Repair	II
5143035	D60001	10/15/2015	10:26	10/15/2015	11:15	2	97	48	Animal related	Fuse	Replace - Same Size		III
5143037	N44216	10/15/2015	10:28	10/15/2015	11:43	1	74	74	Overhead equipment	Jumper		Repair	III
5143045	C10002	10/15/2015	10:41	10/15/2015	11:09	1	27	27	Animal related	Fuse	Replace - Same Size		III
5143059	K76546	10/15/2015	11:10	10/15/2015	11:51	11	445	40	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
5143085	T22508	10/15/2015	11:14	10/15/2015	11:54	45	1776	39	Overhead equipment	Overhead Primary	Repair		VI
5143071	T22508	10/15/2015	11:14	10/15/2015	11:53	29	1115	38	Overhead equipment	Overhead Primary	Repair		VI
5143073	T22508	10/15/2015	11:15	10/15/2015	11:55	6	237	39	Overhead equipment	Overhead Primary	Repair		VI
5143087	C10002	10/15/2015	11:16	10/15/2015	12:05	43	2105	48	Overhead equipment	Fuse	Replace - Same Size		III
5143077	T22508	10/15/2015	11:16	10/15/2015	11:57	1	40	40	Overhead equipment	Overhead Primary	Repair		VI
5143105	R49275	10/15/2015	11:29	10/15/2015	12:40	44	3096	70	Overhead equipment	Recloser	Switch/Reset		VI
5143123	Q75145	10/15/2015	11:48	10/15/2015	12:52	67	4252	63	Animal related	Recloser			VI
5143111	R16511	10/15/2015	12:07	10/15/2015	12:50	1	42	42	Animal related	Fuse	Repair	Repair	I
5143113	R16511	10/15/2015	12:10	10/15/2015	12:50	5	198	39	Animal related	Fuse	Repair	Repair	I
5143119	T22508	10/15/2015	12:17	10/15/2015	12:30	1	12	12	Other				VI
5143131	D90003	10/15/2015	12:35	10/15/2015	13:29	53	2852	53	Animal related	Fuse	Replace - Same Size	Patrol/Test/Inspect	III
5143135	J07135	10/15/2015	12:41	10/15/2015	14:35	1	113	113	Overhead equipment	Overhead Service	Tie/Tighten		I
5143145	R16510	10/15/2015	12:54	10/15/2015	13:54	1	59	59	Unknown	Transformer Fuse	Repair		I
5143147	D36003	10/15/2015	12:56	10/15/2015	13:57	39	2356	60	Unknown	Disconnect Switch	Replace - Same Size	Replace - Same Size	I
5143163	M36185	10/15/2015	13:34	10/15/2015	15:08	1	93	93	Animal related	Fuse	Replace - Same Size		I
5143185	P62138	10/15/2015	13:41	10/15/2015	15:26	63	6607	104	Public	Overhead Primary	Reconnect	Reconnect	VI
5143175	V18582	10/15/2015	13:41	10/15/2015	14:40	1	58	58	Animal related	Fuse	Replace - Same Size		II
5143195	D55003	10/15/2015	14:20	10/15/2015	15:17	1	56	56	Animal related	Transformer Fuse	Replace - Same Size		I
5143201	Y59519	10/15/2015	14:44	10/15/2015	16:25	1	100	100	Animal related	Transformer Fuse	Replace - Same Size		IV
5143203	T04512	10/15/2015	14:48	10/15/2015	16:47	2	238	119	Public	Pole	Repair		VI

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5143205	L17102	10/15/2015	14:53	10/15/2015	15:36	1	42	42	Animal related	Transformer Fuse	Replace - Same Size		III
5143211	D35002	10/15/2015	15:05	10/15/2015	16:30	1	84	84	Animal related	Fuse	Replace - Same Size		I
5143217	P77235	10/15/2015	15:21	10/15/2015	16:52	3	270	90	Animal related	Transformer Fuse	Replace - Same Size		VI
5143219	P62138	10/15/2015	15:29	10/15/2015	15:55	1	25	25	Public	Overhead Secondary	Replace - Same Size		VI
5143221	P62138	10/15/2015	15:30	10/15/2015	16:03	1	32	32	Public				VI
5143223	M09175	10/15/2015	15:39	10/15/2015	16:18	6	233	38	Overhead equipment	Overhead Transformer	Repair	Repair	VI
5143225	Q16867	10/15/2015	15:39	10/15/2015	17:05	1	85	85	Tree related-tree contact	Overhead Secondary	Trim	Trim	V
5143227	K32915	10/15/2015	15:40	10/15/2015	21:10	4	1318	329	Animal related	Overhead Transformer	Replace - Same Size		VI
5143237	R95520	10/15/2015	16:36	10/15/2015	19:19	1	162	162	Overhead equipment	Jumper	Repair	Repair	I
5143243	S24596	10/15/2015	16:58	10/15/2015	18:00	1	61	61	Overhead equipment	Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
5143245	P57104	10/15/2015	17:00	10/15/2015	17:31	4	124	31	Overhead equipment	Overhead Secondary	Replace - Same Size		VI
5143247	P18104	10/15/2015	17:34	10/15/2015	19:17	1	102	102	Unknown	Transformer Fuse			IV
5143275	H22347	10/15/2015	17:46	10/15/2015	19:42	11	1272	115	Animal related	Fuse	Replace - Same Size		V
5143253	K67924	10/15/2015	17:51	10/15/2015	18:43	1	51	51	Overhead equipment	Connector	Repair		VI
5143255	V18582	10/15/2015	18:11	10/15/2015	19:17	10	655	65	Animal related				II
5143261	B93003	10/15/2015	18:56	10/16/2015	4:05	1	549	549	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
5143265	D37001	10/15/2015	19:07	10/15/2015	19:58	1	50	50	Other				I
5143271	U44568	10/15/2015	19:23	10/15/2015	20:04	1	40	40	Overhead equipment	Transformer Fuse	Replace - Same Size		II
5143279	B93003	10/15/2015	20:36	10/15/2015	22:05	24	2121	88	Tree related-tree broken	Overhead Primary	Cut in Clear		I
5143285	D72003	10/15/2015	21:13	10/15/2015	22:03	1	49	49	Overhead equipment				I
5143289	U04538	10/15/2015	22:02	10/15/2015	23:05	1	62	62	Animal related	Transformer Fuse	Replace - Same Size	Repair	II
5143291	B93003	10/15/2015	22:04	10/16/2015	1:06	2	364	182	Tree related-tree broken	Overhead Primary	Patrol/Test/Inspect	Repair	I
5143293	P26280	10/15/2015	22:27	10/15/2015	23:55	1	87	87	Animal related	Transformer Fuse	Repair	Repair	I
5143299	J89125	10/15/2015	23:34	10/16/2015	1:42	54	6929	128	Underground equipment	Underground Primary		Repair	VI
5143307	303007	10/16/2015	1:43	10/16/2015	5:35	310	62100	232	Public	Pole	Repair	Replace - Same Size	VI
5143317	J89125	10/16/2015	1:54	10/16/2015	2:14	9	179	19	Underground equipment	Underground Primary	Switch/Reset		VI
5143319	U84587	10/16/2015	1:58	10/16/2015	3:40	2	203	101	Overhead equipment	Overhead Primary	Repair		II
5143321	U28510	10/16/2015	2:12	10/16/2015	3:50	1	97	97	Overhead equipment	Transformer Fuse	Replace - Same Size	Replace - Same Size	II
5143327	N54213	10/16/2015	3:55	10/16/2015	5:00	1	64	64	Animal related	Fuse	Replace - Same Size		II
5143329	N18211	10/16/2015	4:59	10/16/2015	6:21	1	81	81	Unknown	Transformer Fuse	Replace - Same Size		III
5143337	J18268	10/16/2015	6:03	10/16/2015	7:39	15	1429	95	Animal related	Fuse			VI
5143335	K74164	10/16/2015	6:05	10/16/2015	7:50	6	626	104	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
5143339	A73002	10/16/2015	6:48	10/16/2015	8:35	1	106	106	Tree related-tree broken	Fuse	Replace - Same Size		I
5143341	A24001	10/16/2015	7:05	10/16/2015	9:23	1	137	137	Tree related-tree broken	Tree	Trim		I
5143343	Q11517	10/16/2015	7:28	10/16/2015	17:44	2	1231	615	Overhead equipment	Pole	Replace - Same Size		I
5143361	N94182	10/16/2015	7:30	10/16/2015	8:55	18	1519	84	Overhead equipment	Connector	Repair		I
5143347	R10903	10/16/2015	7:31	10/16/2015	8:17	6	271	45	Animal related	Fuse	Replace - Same Size		VI
5143355	Y35515	10/16/2015	7:47	10/16/2015	8:25	1	37	37	Animal related	Fuse	Repair	Replace - Same Size	IV
5143359	N94182	10/16/2015	7:52	10/16/2015	8:55	1	62	62	Overhead equipment	Connector	Repair		I
5143363	Y35001	10/16/2015	8:03	10/16/2015	8:27	1	23	23	Animal related	Fuse	Repair	Replace - Same Size	IV
5143387	J76804	10/16/2015	8:05	10/16/2015	10:07	11	1339	121	Animal related	Fuse	Replace - Same Size	Replace - Same Size	V
5143423	Y66557	10/16/2015	8:08	10/16/2015	9:51	1	102	102	Animal related	Transformer Fuse			IV
5143369	H11340	10/16/2015	8:12	10/16/2015	9:42	91	8185	89	Animal related	Overhead Transformer			V
5143371	Q36410	10/16/2015	8:18	10/16/2015	8:51	5	163	32	Animal related	Transformer Fuse	Replace - Same Size		I
5143375	K57211	10/16/2015	8:20	10/16/2015	9:05	1	44	44	Animal related	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
5143377	T15570	10/16/2015	8:29	10/16/2015	9:30	1	60	60	Animal related	Overhead Primary	Repair	Repair	VI
5143379	L71171	10/16/2015	8:33	10/16/2015	9:50	1	76	76	Unknown	Fuse			IV
5143381	U97528	10/16/2015	8:35	10/16/2015	9:18	2	86	43	Animal related	Fuse	Replace - Same Size	Replace - Same Size	II
5143383	V74506	10/16/2015	8:36	10/16/2015	9:13	1	36	36	Animal related	Transformer Fuse			II
5143385	V17539	10/16/2015	8:37	10/16/2015	10:05	2	175	87	Animal related				II
5155151	P17107	10/16/2015	8:52	10/16/2015	9:32	1	40	40	Animal related				IV
5143407	R10903	10/16/2015	9:11	10/16/2015	10:28	1	76	76	Animal related	Fuse	Replace - Same Size		VI
5143419	Q80354	10/16/2015	9:16	10/16/2015	10:15	75	4362	58	Animal related	Overhead Transformer			V
5143421	K46388	10/16/2015	9:21	10/16/2015	10:13	1	51	51	Animal related				V
5143431	V42572	10/16/2015	9:32	10/16/2015	14:00	1	267	267	Overhead equipment	Overhead Service	Repair		II
5143443	S93553	10/16/2015	9:43	10/16/2015	10:46	1	62	62	Animal related	Transformer Fuse	Replace - Same Size	Replace - Same Size	VI

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5143449	P60170	10/16/2015	9:58	10/16/2015	12:13	1	134	134	Overhead equipment	Overhead Transformer		Replace - Same Size	VI
5143451	J79304	10/16/2015	10:01	10/16/2015	12:11	1	129	129	Overhead equipment	Overhead Primary	Repair		I
5143457	J79304	10/16/2015	10:08	10/16/2015	10:31	4	91	22	Overhead equipment				I
5143461	K80386	10/16/2015	10:08	10/16/2015	11:10	14	858	61	Animal related	Fuse	Replace - Same Size		IV
5143463	Q14390	10/16/2015	10:16	10/16/2015	12:29	58	7676	132	Animal related	Recloser	Replace - Same Size	Repair	I
5143467	D35003	10/16/2015	10:20	10/16/2015	11:32	1	71	71	Overhead equipment	Transformer Fuse	Replace - Same Size	Replace - Same Size	I
5143485	M25143	10/16/2015	10:49	10/16/2015	13:46	11	1944	176	Tree related-tree broken	Overhead Primary	Patrol/Test/Inspect	Repair	IV
5143491	K52401	10/16/2015	10:52	10/16/2015	12:11	1	78	78	Overhead equipment	Connector	Repair		V
5143493	B57002	10/16/2015	10:53	10/16/2015	11:40	18	837	46	Animal related	Fuse	Replace - Same Size		I
5143499	X34531	10/16/2015	10:55	10/16/2015	11:45	8	393	49	Animal related	Transformer Fuse	Replace - Same Size		IV
5143503	R01153	10/16/2015	10:57	10/16/2015	11:10	17	216	12	Overhead equipment	Transformer Fuse	Repair	Repair	III
5143505	U64518	10/16/2015	10:57	10/16/2015	11:18	8	162	20	Animal related	Overhead Secondary	Cover		II
5143601	Q27185	10/16/2015	11:04	10/16/2015	12:48	1140	118468	103	Transmission outage				VI
5143627	Q27186	10/16/2015	11:05	10/16/2015	12:48	168	17282	102	Transmission outage				VI
5143549	M45212	10/16/2015	11:08	10/16/2015	12:31	1	82	82	Unknown	Transformer Fuse	Replace - Same Size		IV
5143595	Q82906	10/16/2015	11:17	10/16/2015	12:11	1	53	53	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	VI
5143609	L35139	10/16/2015	11:23	10/16/2015	11:55	1	31	31	Animal related	Fuse	Replace - Same Size		III
5143623	X09534	10/16/2015	11:36	10/16/2015	12:02	11	286	26	Public				IV
5143631	X09534	10/16/2015	11:39	10/16/2015	12:02	35	814	23	Public				IV
5143633	M19222	10/16/2015	11:42	10/16/2015	13:20	1	97	97	Tree related-tree contact	Fuse	Replace - Same Size		VI
5143641	M78323	10/16/2015	11:44	10/16/2015	12:55	1	70	70	Overhead equipment	Fuse	Replace - Same Size		V
5143647	S09521	10/16/2015	11:48	10/17/2015	0:05	1	736	736	Underground equipment	Underground Secondary	Repair	Repair	VI
5143657	X72535	10/16/2015	12:00	10/16/2015	13:04	6	381	63	Animal related	Transformer Fuse	Replace - Same Size	Replace - Same Size	IV
5143659	F10003	10/16/2015	12:00	10/16/2015	12:43	1	42	42	Overhead equipment	Fuse	Replace - Same Size		III
5143665	B93002	10/16/2015	12:06	10/16/2015	12:51	4	178	44	Animal related	Transformer Fuse	Replace - Same Size		I
5143669	T23527	10/16/2015	12:07	10/16/2015	12:53	1	45	45	Animal related	Fuse	Replace - New Size		VI
5143679	Y23513	10/16/2015	12:18	10/16/2015	13:15	69	3890	56	Animal related	Fuse	Repair	Replace - Same Size	IV
5143683	J56341	10/16/2015	12:19	10/16/2015	12:58	9	342	38	Animal related	Transformer Fuse			III
5143687	T22507	10/16/2015	12:21	10/16/2015	13:25	1	63	63	Animal related	Transformer Fuse	Replace - Same Size		VI
5143689	R58961	10/16/2015	12:24	10/16/2015	13:12	1	47	47	Animal related	Transformer Fuse	Replace - Same Size		IV
5143697	Q14390	10/16/2015	12:37	10/16/2015	13:05	1	27	27	Overhead equipment	Recloser	Replace - Same Size		I
5143701	P73160	10/16/2015	12:59	10/16/2015	15:27	1	147	147	Overhead equipment	Overhead Primary		Replace - Same Size	VI
5143703	P73160	10/16/2015	12:59	10/16/2015	15:28	1	148	148	Overhead equipment	Overhead Primary		Replace - Same Size	VI
5143715	U10547	10/16/2015	13:23	10/16/2015	14:50	1	86	86	Tree related-tree contact	Tree	Trim	Patrol/Test/Inspect	II
5143721	P73160	10/16/2015	13:41	10/16/2015	15:51	1	129	129	Other				VI
5143735	B93002	10/16/2015	14:22	10/16/2015	15:18	3	167	55	Animal related	Transformer Fuse	Replace - Same Size		I
5143739	T08501	10/16/2015	14:26	10/16/2015	15:10	12	523	43	Tree related-tree broken	Overhead Primary	Patrol/Test/Inspect	Repair	VI
5143745	U19534	10/16/2015	15:03	10/16/2015	16:15	1	71	71	Public	Pole	Remove		II
5143751	K80386	10/16/2015	15:31	10/16/2015	16:12	7	285	40	Animal related	Transformer Fuse	Replace - Same Size		IV
5143755	337001	10/16/2015	15:35	10/16/2015	20:44	2	616	308	Overhead equipment	Disconnect Switch	Patrol/Test/Inspect	Replace - Same Size	VI
5143757	F22001	10/16/2015	15:42	10/16/2015	18:19	3	471	157	Underground equipment	Underground Primary	Disconnect	Repair	IV
5143765	R84148	10/16/2015	16:13	10/16/2015	17:50	1	96	96	Animal related	Transformer Fuse	Replace - Same Size		I
5143769	A56013	10/16/2015	16:21	10/16/2015	17:25	1	63	63	Overhead equipment	Overhead Service	Repair		I
5143771	R53391	10/16/2015	16:44	10/16/2015	17:50	36	2372	65	Overhead equipment	Fuse	Replace - Same Size		V
5143775	A91001	10/16/2015	16:53	10/16/2015	18:23	1	89	89	Other				I
5143777	C37002	10/16/2015	16:59	10/16/2015	18:36	4	384	96	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	III
5143779	M05368	10/16/2015	17:10	10/16/2015	19:17	1	126	126	Jurisdictional	Overhead Service	Reconnect		V
5143781	K30204	10/16/2015	17:13	10/16/2015	18:30	13	997	76	Overhead equipment	Jumper	Repair		III
5143783	Z20586	10/16/2015	17:15	10/16/2015	19:04	1	108	108	Animal related	Transformer Fuse	Replace - Same Size		IV
5143795	Y79500	10/16/2015	17:41	10/16/2015	19:55	7	934	133	Animal related	Transformer Fuse	Repair	Replace - Same Size	IV
5143799	A85001	10/16/2015	17:48	10/16/2015	19:50	1	121	121	Overhead equipment	Disconnect Switch	Replace - Same Size		I
5143801	N70332	10/16/2015	17:49	10/16/2015	19:08	1	78	78	Animal related	Transformer Fuse	Replace - Same Size	Replace - Same Size	I
5143807	R23332	10/16/2015	18:01	10/16/2015	19:19	2	154	77	Animal related	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	V
5143813	P17108	10/16/2015	18:05	10/17/2015	1:22	23	10036	436	Overhead equipment	Overhead Primary			IV
5143821	C37002	10/16/2015	18:40	10/16/2015	22:07	4	828	207	Underground equipment	Underground Primary	Repair		III
5143823	A48005	10/16/2015	19:05	10/16/2015	19:59	1	53	53	Other				I

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5143827	D01002	10/16/2015	19:21	10/17/2015	3:55	1	514	513	Underground equipment	Underground Primary	Repair	Repair	I
5143829	X66582	10/16/2015	19:38	10/16/2015	21:47	1	128	128	Animal related	Transformer Fuse	Replace - Same Size	Replace - Same Size	IV
5143837	N70332	10/16/2015	20:49	10/16/2015	23:55	1	185	185	Overhead equipment	Jumper	Replace - Same Size		I
5143845	N70332	10/16/2015	20:50	10/16/2015	23:55	15	2760	184	Overhead equipment	Jumper	Replace - Same Size		I
5143841	C36002	10/16/2015	20:51	10/16/2015	23:19	1	147	147	Animal related				III
5143847	C36002	10/16/2015	21:17	10/16/2015	23:15	1	117	117	Animal related	Fuse	Replace - Same Size		III
5143855	X91510	10/16/2015	22:02	10/16/2015	23:35	1	92	92	Animal related	Transformer Fuse	Repair	Replace - Same Size	IV
5143859	A97001	10/16/2015	22:18	10/17/2015	9:43	1	685	685	Underground equipment	Underground Primary			I
5143865	X24536	10/17/2015	0:53	10/17/2015	1:51	1	57	57	Animal related	Transformer Fuse			IV
5143867	B76003	10/17/2015	2:41	10/17/2015	9:21	2	499	399	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
5143869	P18104	10/17/2015	3:37	10/17/2015	6:32	18	3147	175	Underground equipment	Underground Primary	Repair	Repair	IV
5143871	N05172	10/17/2015	3:44	10/17/2015	6:50	1	185	185	Overhead equipment	Jumper	Repair		I
5143901	B81002	10/17/2015	7:29	10/17/2015	9:10	166	12892	101	Public	Pole	Cut in Clear	Repair	I
5143903	V22555	10/17/2015	7:54	10/17/2015	9:25	1	90	90	Animal related	Transformer Fuse	Replace - Same Size		II
5143905	R04412	10/17/2015	8:03	10/17/2015	8:48	1	44	44	Animal related	Transformer Fuse	Replace - Same Size	Replace - Same Size	V
5143909	J76804	10/17/2015	8:07	10/17/2015	9:00	58	3055	52	Animal related	Fuse	Replace - Same Size	Replace - Same Size	V
5143911	L93149	10/17/2015	8:09	10/17/2015	9:04	1	54	54	Overhead equipment	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
5143913	P77233	10/17/2015	8:11	10/17/2015	9:37	5	427	85	Animal related	Fuse			VI
5143917	P20913	10/17/2015	8:15	10/17/2015	9:34	4	315	78	Animal related	Fuse	Replace - Same Size		VI
5143919	S02501	10/17/2015	8:28	10/17/2015	10:42	1	133	133	Animal related	Transformer Fuse	Repair	Repair	VI
5143921	R05115	10/17/2015	8:31	10/17/2015	9:53	1	81	81	Overhead equipment	Recloser	Switch/Reset		I
5143943	R05115	10/17/2015	8:32	10/17/2015	9:53	290	23336	80	Overhead equipment	Recloser	Switch/Reset		I
5143933	J47178	10/17/2015	8:34	10/17/2015	12:30	1	235	235	Underground equipment	Underground Service			III
5143947	M21134	10/17/2015	8:40	10/17/2015	13:40	1	299	299	Underground equipment	Underground Service	Patrol/Test/Inspect	Repair	VI
5143951	R05115	10/17/2015	8:41	10/17/2015	9:53	1	71	71	Overhead equipment	Recloser	Switch/Reset		I
5143959	H11340	10/17/2015	8:46	10/17/2015	9:30	10	433	43	Animal related	Transformer Fuse	Replace - Same Size		V
5143961	R05115	10/17/2015	8:50	10/17/2015	9:53	10	621	62	Overhead equipment	Recloser	Switch/Reset		I
5143963	M19222	10/17/2015	8:52	10/17/2015	10:24	1	91	91	Animal related	Fuse	Replace - Same Size		VI
5143965	Y55505	10/17/2015	9:07	10/17/2015	10:15	6	404	67	Animal related	Transformer Fuse	Replace - Same Size		IV
5143973	X72535	10/17/2015	9:12	10/17/2015	10:27	11	816	74	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	IV
5144013	D72002	10/17/2015	9:23	10/17/2015	14:33	2	620	310	Tree related-tree broken	Overhead Secondary	Replace - Same Size		I
5143975	J15303	10/17/2015	9:23	10/17/2015	11:22	1	118	118	Overhead equipment	Fuse	Replace - Same Size		I
5143979	R48165	10/17/2015	9:32	10/17/2015	10:12	1	39	39	Animal related	Fuse			IV
5143981	R48165	10/17/2015	9:33	10/17/2015	10:12	13	502	38	Animal related	Fuse			IV
5143983	K30205	10/17/2015	9:41	10/17/2015	11:55	1	133	133	Animal related	Transformer Fuse	Replace - Same Size		III
5143985	J18268	10/17/2015	9:51	10/17/2015	10:52	1	60	60	Animal related	Transformer Fuse	Replace - Same Size		VI
5143987	Z21564	10/17/2015	9:53	10/17/2015	11:04	1	70	70	Animal related	Transformer Fuse	Repair	Replace - Same Size	IV
5143995	X60595	10/17/2015	10:06	10/17/2015	10:44	109	4060	37	Overhead equipment	Lightning Arrestor	Replace - Same Size		IV
5143997	Y45503	10/17/2015	10:08	10/17/2015	11:50	11	1113	101	Animal related	Transformer Fuse	Repair	Replace - Same Size	IV
5144009	X88510	10/17/2015	10:28	10/17/2015	11:46	5	388	77	Animal related	Transformer Fuse	Replace - Same Size		IV
5144011	R61241	10/17/2015	10:33	10/17/2015	11:23	9	445	49	Animal related	Transformer Fuse			IV
5144015	D53001	10/17/2015	10:42	10/17/2015	12:20	1	97	97	Overhead equipment	Jumper	Repair		I
5144017	S16502	10/17/2015	10:43	10/17/2015	12:44	1	120	120	Overhead equipment	Overhead Service	Repair		VI
5144021	R05186	10/17/2015	11:07	10/17/2015	12:47	56	5590	99	Underground equipment	Underground Primary	Switch/Reset		I
5144039	Y79500	10/17/2015	11:14	10/17/2015	14:20	167	30950	185	Overhead equipment	Disconnect Switch	Repair	Replace - Same Size	IV
5144055	Q83168	10/17/2015	11:34	10/17/2015	12:50	1	75	75	Animal related	Jumper	Repair		VI
5144057	A28001	10/17/2015	11:35	10/17/2015	13:55	1	139	139	Tree related-tree broken	Overhead Service	Raise		I
5144065	U04589	10/17/2015	12:12	10/17/2015	13:54	5	505	101	Animal related	Transformer Fuse	Replace - Same Size		II
5144067	D01002	10/17/2015	12:15	10/17/2015	15:56	2	442	221	Underground equipment	Underground Secondary	Repair	Replace - Same Size	I
5144071	K46388	10/17/2015	12:25	10/17/2015	22:13	4	2352	588	Underground equipment	Underground Primary		Advise Customer	V
5144075	N60181	10/17/2015	12:33	10/17/2015	15:07	1	153	153	Overhead equipment	Jumper	Repair		I
5144079	M37192	10/17/2015	12:49	10/17/2015	14:31	32	3253	101	Underground equipment	Underground Primary	Switch/Reset	Repair	I
5144081	T05539	10/17/2015	13:14	10/17/2015	15:02	1	107	107	Overhead equipment	Fuse	Repair	Replace - Same Size	VI
5144083	S43512	10/17/2015	13:34	10/17/2015	17:06	5	1061	212	Underground equipment	Underground Primary	Disconnect		VI
5144085	B62003	10/17/2015	13:39	10/17/2015	19:28	1	348	348	Underground equipment	Underground Primary	Patrol/Test/Inspect	Reconnect	I
5144089	Y51505	10/17/2015	13:44	10/17/2015	14:30	11	496	45	Unknown	Fuse	Replace - Same Size		IV

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5144095	T05539	10/17/2015	13:54	10/17/2015	15:01	1	66	66	Overhead equipment	Fuse	Repair	Replace - Same Size	VI
5144111	M37192	10/17/2015	14:05	10/17/2015	14:14	38	338	8	Underground equipment	Underground Primary	Repair		I
5144109	D37001	10/17/2015	14:07	10/17/2015	15:00	6	312	52	Animal related	Fuse	Replace - Same Size		I
5144135	Z17503	10/17/2015	14:55	10/17/2015	17:50	10	1747	174	Underground equipment	Underground Primary			IV
5144137	Y51505	10/17/2015	14:55	10/17/2015	15:29	1	33	33	Animal related	Transformer Fuse	Replace - Same Size		IV
5144141	Q11517	10/17/2015	15:10	10/17/2015	20:38	1	327	327	Public	Pole	Repair		I
5144179	Q64919	10/17/2015	15:17	10/17/2015	17:51	543	79523	154	Overhead equipment				VI
5144237	L79159	10/17/2015	15:39	10/17/2015	19:43	6	1462	243	Animal related	Fuse	Replace - Same Size		IV
5144239	N67315	10/17/2015	15:40	10/17/2015	17:25	1	104	104	Overhead equipment	Transformer Fuse	Replace - Same Size		I
5144255	H00163	10/17/2015	16:02	10/17/2015	17:26	1	83	83	Animal related	Transformer Fuse	Replace - Same Size		III
5144257	S60581	10/17/2015	16:03	10/17/2015	17:15	1	71	71	Animal related	Transformer Fuse	Replace - Same Size		VI
5144263	Y55555	10/17/2015	16:16	10/17/2015	16:58	3	124	41	Animal related	Transformer Fuse	Replace - Same Size		IV
5144271	J84146	10/17/2015	16:36	10/17/2015	17:45	1	68	68	Overhead equipment	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
5144293	K01239	10/17/2015	16:51	10/17/2015	19:17	21	3048	145	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	VI
5144285	V92542	10/17/2015	17:12	10/17/2015	18:30	1	77	77	Animal related	Transformer Fuse	Replace - Same Size	Patrol/Test/Inspect	II
5144287	U99578	10/17/2015	17:14	10/17/2015	18:30	1	75	75	Animal related	Transformer Fuse	Replace - Same Size		II
5144289	S04545	10/17/2015	17:14	10/17/2015	18:11	1	56	56	Animal related	Other	Repair	Repair	VI
5144297	L93135	10/17/2015	17:32	10/17/2015	20:10	4	630	157	Overhead equipment	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
5144301	A68001	10/17/2015	17:53	10/17/2015	19:22	1	88	88	Overhead equipment	Overhead Primary	Reconnect		I
5144333	A68001	10/17/2015	18:01	10/17/2015	19:22	1	80	80	Overhead equipment	Overhead Primary	Reconnect		I
5144343	S09520	10/17/2015	18:03	10/17/2015	20:00	8	930	116	Overhead equipment	Overhead Transformer	Repair		VI
5144363	K71822	10/17/2015	18:27	10/17/2015	20:06	17	1682	98	Animal related	Transformer Fuse			IV
5144365	L79159	10/17/2015	18:30	10/17/2015	20:05	1	94	94	Animal related	Fuse	Replace - Same Size		IV
5144373	Q64919	10/17/2015	19:29	10/17/2015	20:59	1	89	89	Animal related	Fuse	Replace - Same Size		VI
5144379	Q64919	10/17/2015	20:19	10/17/2015	22:22	2	245	122	Underground equipment	Underground Transformer		Replace - Same Size	VI
5144389	S83533	10/17/2015	21:30	10/17/2015	23:30	1	119	119	Overhead equipment	Fuse	Replace - Same Size		VI
5144391	T11509	10/17/2015	21:53	10/17/2015	23:15	1	81	81	Overhead equipment	Fuse			VI
5144393	S47589	10/17/2015	22:13	10/18/2015	1:36	1	203	203	Animal related				VI
5144399	J20931	10/18/2015	0:20	10/18/2015	4:30	33	4208	250	Overhead equipment	Overhead Primary	Repair		VI
5144405	U06524	10/18/2015	1:43	10/18/2015	5:30	17	3865	227	Underground equipment	Underground Primary	Switch/Reset	Repair	II
5144417	U02597	10/18/2015	1:45	10/18/2015	4:00	11	1477	134	Overhead equipment	Fuse	Replace - Same Size	Patrol/Test/Inspect	II
5144411	Y96564	10/18/2015	1:54	10/18/2015	4:01	1	127	127	Animal related	Transformer Fuse	Replace - Same Size	Replace - Same Size	IV
5144413	U06524	10/18/2015	2:09	10/18/2015	5:30	8	1608	200	Underground equipment	Underground Primary	Switch/Reset	Repair	II
5144415	J30201	10/18/2015	2:10	10/18/2015	4:35	1	144	144	Overhead equipment	Jumper	Patrol/Test/Inspect	Repair	VI
5144421	L93133	10/18/2015	3:22	10/18/2015	7:04	12	2653	221	Overhead equipment	Disconnect Switch	Patrol/Test/Inspect	Replace - Same Size	VI
5144423	D35003	10/18/2015	3:41	10/18/2015	6:04	13	1854	142	Animal related	Fuse	Replace - Same Size		I
5144425	M21133	10/18/2015	4:37	10/18/2015	11:47	16	6877	429	Public	Overhead Primary	Patrol/Test/Inspect	Repair	VI
5144427	B77001	10/18/2015	4:37	10/18/2015	11:04	5	1931	386	Public	Pole	Replace - Same Size		I
5144429	C70004	10/18/2015	4:40	10/18/2015	6:40	1	119	119	Overhead equipment	Disconnect Switch	Replace - Same Size		III
5144439	D72001	10/18/2015	5:11	10/18/2015	17:24	5	3664	732	Underground equipment	Fuse	Patrol/Test/Inspect	Replace - Same Size	I
5144443	D60001	10/18/2015	5:40	10/18/2015	11:17	26	6450	337	Underground equipment	Underground Primary			III
5144445	A81004	10/18/2015	6:14	10/18/2015	10:59	1	284	284	Underground equipment	Underground Primary			I
5144447	J20931	10/18/2015	6:15	10/18/2015	7:02	1	46	46	Overhead equipment				VI
5144451	P20930	10/18/2015	6:17	10/18/2015	9:44	41	8451	206	Overhead equipment	Overhead Primary	Repair		VI
5144455	P20930	10/18/2015	6:25	10/18/2015	9:44	15	2976	198	Overhead equipment				VI
5144469	K52401	10/18/2015	6:52	10/18/2015	8:36	392	40799	104	Public				V
5144467	K52401	10/18/2015	6:52	10/18/2015	8:36	329	34242	104	Public				V
5144471	K52401	10/18/2015	6:52	10/18/2015	8:36	412	42880	104	Public				V
5144475	K52-UNIT-1	10/18/2015	6:52	10/18/2015	8:36	1090	113447	104	Public				V
5144701	K55-UNIT-1	10/18/2015	6:52	10/18/2015	8:38	1064	112252	105	Public				V
5144731	K48-UNIT-2	10/18/2015	6:53	10/18/2015	8:36	1574	162751	103	Public	Insulator	Patrol/Test/Inspect	Replace - New Size	V
5144611	M15-UNIT-1	10/18/2015	6:53	10/18/2015	8:43	445	48972	110	Public				V
5144539	K48-UNIT-1	10/18/2015	6:53	10/18/2015	8:36	1084	111738	103	Overhead equipment				V
5144515	IP9009	10/18/2015	6:54	10/18/2015	8:41	476	51279	107	Public				VI
5144849	M17-UNIT-1	10/18/2015	6:56	10/18/2015	9:21	60	8680	144	Public				V
5144813	L93133	10/18/2015	7:17	10/18/2015	9:08	12	1323	110	Animal related	Disconnect Switch	Repair	Replace - Same Size	VI

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5144815	B21004	10/18/2015	7:17	10/18/2015	13:40	15	5736	382	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
5144911	B45005	10/18/2015	7:29	10/18/2015	8:55	117	10116	86	Animal related				I
5144827	R34920	10/18/2015	7:43	10/18/2015	9:44	2	241	120	Animal related	Fuse	Replace - Same Size		VI
5144835	D35003	10/18/2015	7:50	10/18/2015	10:30	1	159	159	Animal related	Fuse	Replace - Same Size		I
5144843	K51-UNIT-1	10/18/2015	7:55	10/18/2015	9:51	1	115	115	Public				V
5144845	HB5891	10/18/2015	7:57	10/18/2015	10:00	1	122	122	Animal related	Transformer Fuse	Repair		I
5144847	P20913	10/18/2015	7:58	10/18/2015	10:29	46	6921	150	Overhead equipment	Overhead Primary	Repair		VI
5144853	J20931	10/18/2015	8:06	10/18/2015	8:15	1	8	8	Animal related	Fuse	Replace - Same Size		VI
5144861	D66004	10/18/2015	8:21	10/18/2015	10:33	33	4374	132	Overhead equipment	Fuse	Replace - Same Size		IV
5144863	J84146	10/18/2015	8:27	10/18/2015	10:24	1	116	116	Overhead equipment	Disconnect Switch	Patrol/Test/Inspect	Replace - Same Size	VI
5144865	D70007	10/18/2015	8:31	10/18/2015	9:51	1	79	79	Overhead equipment				I
5144871	B68003	10/18/2015	8:35	10/18/2015	11:45	17	3218	189	Animal related	Other	Replace - Same Size	Patrol/Test/Inspect	III
5145199	M26161	10/18/2015	8:42	10/18/2015	13:52	4	1128	310	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	III
5144891	D36002	10/18/2015	8:43	10/18/2015	9:30	1	46	46	Overhead equipment	Fuse	Replace - Same Size		I
5144897	V42586	10/18/2015	8:48	10/18/2015	9:59	1	70	70	Animal related	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	II
5144899	Q54908	10/18/2015	8:50	10/18/2015	11:32	1	161	161	Tree related-tree broken	Overhead Service	Patrol/Test/Inspect	Replace - New Size	VI
5145155	J63172	10/18/2015	8:55	10/18/2015	15:15	51	19405	380	Public	Pole	Repair	Replace - Same Size	III
5144909	D90003	10/18/2015	8:59	10/18/2015	12:23	1	203	203	Animal related	Fuse	Replace - Same Size	Patrol/Test/Inspect	III
5144913	R07381	10/18/2015	9:04	10/18/2015	11:48	1	163	163	Animal related	Fuse	Replace - Same Size		I
5144915	M05360	10/18/2015	9:06	10/18/2015	10:12	12	785	65	Animal related	Transformer Fuse	Replace - Same Size	Replace - Same Size	V
5144921	D90003	10/18/2015	9:12	10/18/2015	12:21	1	188	188	Animal related	Fuse	Replace - Same Size	Patrol/Test/Inspect	III
5144923	S86581	10/18/2015	9:13	10/18/2015	11:17	1	123	123	Animal related	Transformer Fuse	Replace - Same Size		VI
5145141	L23146	10/18/2015	9:16	10/18/2015	11:12	224	26035	116	Animal related	Fuse	Repair		III
5144935	S86582	10/18/2015	9:17	10/18/2015	11:54	1	156	156	Animal related	Transformer Fuse	Replace - Same Size		VI
5145143	L23146	10/18/2015	9:17	10/18/2015	11:15	26	3068	118	Animal related				III
5145211	L23146	10/18/2015	9:21	10/18/2015	11:20	8	950	118	Animal related				III
5144949	B45005	10/18/2015	9:26	10/18/2015	11:04	1	98	98	Animal related				I
5144953	L23146	10/18/2015	9:29	10/18/2015	11:21	4	447	111	Animal related				III
5145207	L23146	10/18/2015	9:29	10/18/2015	11:20	4	442	110	Animal related	Fuse	Replace - Same Size		III
5144957	D60001	10/18/2015	9:34	10/18/2015	11:54	9	1256	139	Underground equipment	Underground Primary	Repair	Replace - Same Size	III
5144959	R07381	10/18/2015	9:35	10/18/2015	11:48	1	132	132	Animal related	Fuse	Replace - Same Size		I
5144967	J63173	10/18/2015	9:38	10/18/2015	11:50	6	789	131	Overhead equipment	Fuse			III
5144969	D01001	10/18/2015	9:41	10/18/2015	15:48	1	366	366	Underground equipment	Fuse	Patrol/Test/Inspect	Repair	I
5145175	N44-UNIT-2	10/18/2015	9:42	10/18/2015	12:59	1298	254641	196	Animal related	Lightning Arrestor	Replace - Same Size		III
5144905	J63172	10/18/2015	9:48	10/18/2015	10:13	461	11432	24	Public				III
5145065	P52305	10/18/2015	9:49	10/18/2015	10:50	40	2439	60	Animal related	Transformer Fuse			IV
5145209	L23146	10/18/2015	9:58	10/18/2015	11:20	4	331	82	Animal related				III
5145145	J63172	10/18/2015	10:07	10/18/2015	15:22	1	314	314	Overhead equipment				III
5145147	J56342	10/18/2015	10:10	10/18/2015	15:23	1	312	312	Overhead equipment				III
5145149	J63171	10/18/2015	10:12	10/18/2015	15:26	1	313	313	Overhead equipment				III
5145153	T08502	10/18/2015	10:12	10/18/2015	11:30	1	77	77	Animal related	Transformer Fuse	Replace - New Size		VI
5145157	J63172	10/18/2015	10:16	10/18/2015	15:27	1	310	310	Overhead equipment				III
5145159	Y54587	10/18/2015	10:17	10/18/2015	10:50	4	128	32	Animal related	Transformer Fuse	Replace - Same Size		IV
5145163	S07536	10/18/2015	10:19	10/18/2015	12:20	2	240	120	Animal related	Transformer Fuse		Replace - Same Size	VI
5145167	J15302	10/18/2015	10:21	10/18/2015	12:20	1	118	118	Animal related	Fuse	Replace - Same Size		I
5145169	X68506	10/18/2015	10:21	10/18/2015	11:32	6	420	70	Overhead equipment	Disconnect Switch	Repair		IV
5145173	Y31589	10/18/2015	10:22	10/18/2015	11:20	1	57	57	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
5145177	M18131	10/18/2015	10:23	10/18/2015	15:01	1	277	277	Animal related	Overhead Primary		Repair	III
5145179	B93003	10/18/2015	10:24	10/18/2015	11:55	1	90	90	Animal related	Fuse	Replace - Same Size		I
5145181	V84531	10/18/2015	10:27	10/18/2015	11:31	1	63	63	Overhead equipment	Connector	Replace - Same Size		II
5145183	M25144	10/18/2015	10:31	10/18/2015	11:53	1	81	81	Animal related	Fuse	Replace - Same Size		IV
5145185	J15302	10/18/2015	10:34	10/18/2015	12:13	5	494	98	Animal related	Fuse	Replace - Same Size		I
5145187	N05170	10/18/2015	10:38	10/18/2015	11:46	1	67	67	Animal related	Transformer Fuse	Repair		I
5145189	HC9325	10/18/2015	10:44	10/18/2015	12:05	5	403	80	Overhead equipment	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
5145193	T08502	10/18/2015	10:59	10/18/2015	11:32	1	32	32	Animal related	Transformer Fuse		Replace - New Size	VI
5145201	B00004	10/18/2015	11:12	10/18/2015	11:30	5	85	17	Overhead equipment	Other	Repair	Repair	I

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5145203	X88510	10/18/2015	11:18	10/18/2015	12:36	52	4005	77	Unknown	Fuse	Replace - Same Size		IV
5145221	A97006	10/18/2015	11:39	10/18/2015	13:15	1	95	95	Animal related	Transformer Fuse	Replace - Same Size		I
5145223	Y08552	10/18/2015	11:48	10/18/2015	14:30	12	1495	162	Underground equipment	Underground Primary	Repair	Replace - Same Size	IV
5145225	Z10500	10/18/2015	11:53	10/18/2015	13:15	1	81	81	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
5145227	K76543	10/18/2015	12:02	10/18/2015	13:49	1	106	106	Animal related	Transformer Fuse			IV
5145233	U68003	10/18/2015	12:26	10/18/2015	13:27	8	485	60	Animal related	Transformer Fuse	Replace - Same Size		II
5145235	X64503	10/18/2015	12:28	10/18/2015	14:09	9	907	100	Animal related	Transformer Fuse	Replace - Same Size	Replace - Same Size	IV
5145237	K69116	10/18/2015	12:33	10/18/2015	13:12	129	5009	38	Animal related	Transformer Fuse			IV
5145243	M45211	10/18/2015	12:47	10/18/2015	14:07	6	474	79	Overhead equipment	Fuse	Replace - Same Size		IV
5145245	L35139	10/18/2015	13:06	10/18/2015	14:00	27	1448	53	Animal related	Fuse	Repair		III
5145285	R60554	10/18/2015	13:36	10/18/2015	16:52	296	58075	196	Overhead equipment				IV
5145291	D93002	10/18/2015	13:48	10/18/2015	15:46	3	351	117	Animal related	Fuse	Patrol/Test/Inspect		IV
5145295	L81141	10/18/2015	13:57	10/18/2015	15:20	1	82	82	Jurisdictional	Other	Reconnect		IV
5145303	Q67948	10/18/2015	14:33	10/18/2015	18:54	3	782	260	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	VI
5145305	N44216	10/18/2015	14:38	10/18/2015	17:50	1	191	191	Animal related	Substation Transformer			III
5145307	Y08552	10/18/2015	14:42	10/18/2015	15:08	1	25	25	Underground equipment				IV
5145309	L35139	10/18/2015	14:50	10/18/2015	15:30	43	1715	39	Animal related	Fuse	Replace - Same Size		III
5145319	A36002	10/18/2015	15:01	10/18/2015	16:05	1	63	63	Animal related	Fuse	Replace - Same Size		I
5145321	X81555	10/18/2015	15:06	10/18/2015	16:25	1	78	78	Overhead equipment	Fuse	Replace - Same Size		IV
5145325	P26284	10/18/2015	15:15	10/18/2015	17:06	1	110	110	Animal related	Transformer Fuse	Replace - Same Size		I
5145331	X88507	10/18/2015	15:50	10/18/2015	17:12	1	81	81	Animal related	Fuse	Replace - Same Size		IV
5145333	P98192	10/18/2015	16:10	10/18/2015	17:14	10	639	63	Overhead equipment	Fuse			III
5145341	X91510	10/18/2015	16:33	10/18/2015	18:00	1	86	86	Animal related	Transformer Fuse	Repair	Replace - Same Size	IV
5145343	U33586	10/18/2015	16:34	10/18/2015	17:55	1	80	80	Overhead equipment	Transformer Fuse	Replace - Same Size		II
5145349	T02534	10/18/2015	16:42	10/18/2015	17:55	1	72	72	Tree related-tree broken	Overhead Service	Patrol/Test/Inspect	Repair	VI
5145353	P69174	10/18/2015	16:49	10/18/2015	17:25	1	35	35	Animal related	Fuse	Repair		III
5145355	M18131	10/18/2015	16:52	10/18/2015	20:30	1	217	217	Underground equipment	Underground Service		Repair	III
5145359	B38001	10/18/2015	17:05	10/18/2015	18:10	1	64	64	Overhead equipment	Fuse	Repair	Replace - Same Size	I
5145361	P12290	10/18/2015	17:11	10/18/2015	18:10	6	349	58	Animal related	Transformer Fuse	Replace - Same Size	Replace - Same Size	V
5145369	B35002	10/18/2015	17:28	10/18/2015	17:52	1	23	23	Overhead equipment	Fuse	Repair		I
5145373	HC9327	10/18/2015	17:35	10/18/2015	18:40	1	64	64	Overhead equipment	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
5145371	N05170	10/18/2015	17:35	10/18/2015	21:10	1	214	214	Overhead equipment	Overhead Transformer	Repair		I
5145377	J87120	10/18/2015	17:48	10/18/2015	23:44	8	2840	355	Underground equipment	Underground Secondary	Repair	Repair	VI
5145379	L95110	10/18/2015	18:01	10/18/2015	19:00	1	58	58	Overhead equipment	Overhead Secondary	Repair		III
5145381	N05170	10/18/2015	18:06	10/18/2015	21:10	1	183	183	Overhead equipment	Overhead Transformer	Repair		I
5145383	K76545	10/18/2015	18:08	10/18/2015	19:44	21	2005	95	Animal related	Transformer Fuse			IV
5145385	T08501	10/18/2015	19:29	10/18/2015	20:28	1	58	58	Overhead equipment	Connector	Patrol/Test/Inspect	Repair	VI
5145393	L12126	10/18/2015	20:52	10/19/2015	0:26	43	8433	213	Underground equipment	Underground Primary	Switch/Reset	Repair	III
5145403	A45003	10/18/2015	23:08	10/19/2015	4:34	2	420	325	Underground equipment	Underground Primary	Patrol/Test/Inspect	Patrol/Test/Inspect	I
5145405	R59422	10/18/2015	23:20	10/19/2015	0:33	16	1166	72	Animal related	Transformer Fuse	Replace - Same Size		IV
5145407	L72-UNIT-1	10/19/2015	3:49	10/19/2015	10:20	1	390	390	Animal related	Substation Misc.			IV
5145421	K80381	10/19/2015	5:58	10/19/2015	7:49	22	2429	110	Underground equipment	Underground Primary	Switch/Reset	Repair	IV
5145417	J76804	10/19/2015	6:08	10/19/2015	13:22	30	10136	434	Underground equipment	Underground Transformer	Replace - Same Size	Replace - Same Size	V
5145431	S66595	10/19/2015	7:53	10/19/2015	9:19	3	255	85	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	VI
5145433	N35851	10/19/2015	7:54	10/19/2015	9:30	1	95	95	Animal related	Transformer Fuse	Replace - Same Size		V
5145435	P77235	10/19/2015	7:56	10/19/2015	9:13	19	1459	76	Overhead equipment	Fuse	Repair	Repair	VI
5145439	Q25802	10/19/2015	8:03	10/19/2015	9:04	1	60	60	Animal related	Fuse	Replace - Same Size		I
5145443	Q25802	10/19/2015	8:03	10/19/2015	9:04	1	60	60	Animal related	Fuse	Replace - Same Size		I
5145445	Q34366	10/19/2015	8:10	10/19/2015	8:55	6	265	44	Animal related	Fuse	Replace - Same Size		I
5145505	L23146	10/19/2015	8:23	10/19/2015	11:05	26	2575	162	Animal related	Fuse			III
5145461	P05825	10/19/2015	8:25	10/19/2015	9:06	1	40	40	Animal related	Transformer Fuse	Replace - Same Size		V
5145463	L23146	10/19/2015	8:26	10/19/2015	9:41	8	597	74	Animal related	Fuse			III
5145465	L23146	10/19/2015	8:27	10/19/2015	9:41	4	293	73	Animal related	Fuse			III
5145471	D55002	10/19/2015	8:30	10/19/2015	9:34	1	63	63	Animal related	Transformer Fuse	Replace - Same Size		I
5145577	M37192	10/19/2015	8:42	10/19/2015	10:08	19	1626	85	Animal related	Fuse	Repair	Replace - Same Size	I
5145485	K74164	10/19/2015	8:45	10/19/2015	9:14	1	28	28	Animal related	Transformer Fuse	Replace - Same Size		IV

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5145487	Q74149	10/19/2015	8:49	10/19/2015	10:05	1	75	75	Overhead equipment	Fuse	Replace - Same Size		IV
5145489	S62523	10/19/2015	8:53	10/19/2015	9:37	1	43	43	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	VI
5145493	T01534	10/19/2015	8:54	10/19/2015	9:46	1	51	51	Overhead equipment	Overhead Service	Patrol/Test/Inspect	Repair	VI
5145495	S88502	10/19/2015	8:58	10/19/2015	10:01	1	62	62	Animal related	Fuse	Replace - Same Size		VI
5145497	M37192	10/19/2015	8:59	10/19/2015	9:50	1	50	50	Overhead equipment	Fuse	Repair	Replace - Same Size	I
5145611	J21-UNIT-1	10/19/2015	9:00	10/19/2015	10:08	1	67	67	Unknown				VI
5145609	J22-UNIT-1	10/19/2015	9:00	10/19/2015	10:08	1	67	67	Unknown				VI
5145619	J23-UNIT-1	10/19/2015	9:00	10/19/2015	10:08	3	203	67	Unknown				VI
5145605	J25-UNIT-1	10/19/2015	9:00	10/19/2015	10:08	1	67	67	Unknown				VI
5145607	J27-UNIT-1	10/19/2015	9:00	10/19/2015	10:08	2	135	67	Unknown				VI
5145621	J28-UNIT-1	10/19/2015	9:00	10/19/2015	10:08	1	67	67	Unknown				VI
5145615	J29-UNIT-1	10/19/2015	9:00	10/19/2015	10:08	1	67	67	Unknown				VI
5145613	Q72-UNIT-1	10/19/2015	9:00	10/19/2015	10:08	1	67	67	Unknown				VI
5145525	J20-UNIT-1	10/19/2015	9:02	10/19/2015	10:08	549	35888	65	Unknown				VI
5145557	P85146	10/19/2015	9:07	10/19/2015	10:44	1	96	96	Public	Meter	Repair	Repair	III
5145569	J19-UNIT-1	10/19/2015	9:08	10/19/2015	10:08	1	59	59	Unknown				VI
5145571	HB3-X1	10/19/2015	9:08	10/19/2015	10:00	1	51	51	Overhead equipment				VI
5145573	J24-UNIT-1	10/19/2015	9:08	10/19/2015	10:08	1	59	59	Unknown				VI
5145583	D96002	10/19/2015	9:20	10/19/2015	10:29	1	69	69	Other	Underground Transformer	Repair	Replace - Same Size	I
5145585	K36251	10/19/2015	9:22	10/19/2015	11:34	1	131	131	Overhead equipment	Overhead Primary			III
5145587	K36251	10/19/2015	9:22	10/19/2015	12:14	6	1028	171	Tree related-tree broken	Overhead Secondary	Repair		III
5145595	R16510	10/19/2015	9:36	10/19/2015	10:07	63	1903	30	Animal related	Fuse	Replace - Same Size		I
5145717	Z29579	10/19/2015	9:39	10/19/2015	14:02	1	262	262	Underground equipment	Underground Primary		Replace - Same Size	IV
5145599	309142	10/19/2015	9:40	10/19/2015	11:28	1	107	107	Overhead equipment	Overhead Secondary	Repair		V
5145601	N70330	10/19/2015	9:40	10/19/2015	10:54	2	146	73	Overhead equipment	Overhead Secondary	Reconnect		I
5145603	R16511	10/19/2015	9:44	10/19/2015	10:07	1	22	22	Animal related	Fuse	Replace - Same Size		I
5145633	P52305	10/19/2015	10:18	10/19/2015	11:22	4	255	63	Tree related-tree contact	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	IV
5145635	N91255	10/19/2015	10:18	10/19/2015	10:49	1	30	30	Tree related-tree broken	Overhead Secondary			III
5145637	D36001	10/19/2015	10:21	10/19/2015	11:12	14	709	50	Unknown	Fuse	Repair	Replace - Same Size	I
5145639	H06135	10/19/2015	10:23	10/19/2015	11:30	7	467	66	Animal related	Fuse	Replace - Same Size		IV
5145641	S30518	10/19/2015	10:23	10/19/2015	12:30	1	126	126	Animal related	Transformer Fuse	Repair	Replace - Same Size	VI
5145643	D36001	10/19/2015	10:24	10/19/2015	11:11	9	420	46	Unknown	Fuse	Repair		I
5145645	Z06537	10/19/2015	10:25	10/19/2015	10:49	1	23	23	Animal related	Transformer Fuse	Replace - Same Size		IV
5145647	S30518	10/19/2015	10:27	10/19/2015	12:30	1	122	122	Animal related	Transformer Fuse	Repair	Replace - Same Size	VI
5145679	K65221	10/19/2015	10:32	10/19/2015	11:24	1	51	51	Overhead equipment	Jumper			III
5145655	Y98532	10/19/2015	10:34	10/19/2015	11:48	1	74	74	Overhead equipment	Jumper	Patrol/Test/Inspect	Repair	IV
5145677	K65221	10/19/2015	10:35	10/19/2015	11:25	1	49	49	Overhead equipment	Jumper			III
5145663	B61001	10/19/2015	10:43	10/19/2015	11:57	1	73	73	Unknown	Transformer Fuse	Replace - Same Size		I
5145667	J05138	10/19/2015	10:47	10/19/2015	12:30	1	102	102	Overhead equipment	Jumper	Repair	Reconnect	I
5145683	X19561	10/19/2015	11:22	10/19/2015	15:55	1	272	272	Animal related	Overhead Service	Repair		IV
5145685	S95571	10/19/2015	11:24	10/19/2015	13:05	1	100	100	Overhead equipment	Disconnect Switch	Replace - Same Size		VI
5145689	K28183	10/19/2015	11:43	10/19/2015	12:24	34	1389	40	Other	Other			III
5145695	R16511	10/19/2015	11:56	10/19/2015	12:43	6	280	46	Animal related	Fuse	Replace - Same Size		I
5145697	X88510	10/19/2015	11:57	10/19/2015	12:55	1	57	57	Animal related	Transformer Fuse	Replace - Same Size		IV
5145703	V69558	10/19/2015	12:02	10/19/2015	12:55	1	52	52	Animal related	Transformer Fuse	Replace - Same Size		II
5145705	B62002	10/19/2015	12:07	10/19/2015	13:43	3	287	95	Public	Underground Secondary	Patrol/Test/Inspect	Repair	I
5145721	J76804	10/19/2015	12:23	10/19/2015	12:59	92	3305	35	Underground equipment	Overhead Primary	Repair	Repair	V
5145711	M19222	10/19/2015	12:23	10/19/2015	13:19	1	55	55	Animal related	Transformer Fuse	Repair	Replace - Same Size	VI
5145729	S36571	10/19/2015	12:45	10/19/2015	14:10	1	84	84	Overhead equipment	Overhead Secondary	Patrol/Test/Inspect	Repair	VI
5145741	S15560	10/19/2015	12:55	10/19/2015	13:50	7	384	54	Animal related	Transformer Fuse	Replace - Same Size		VI
5145751	K69116	10/19/2015	13:08	10/19/2015	16:45	1	216	216	Overhead equipment	Jumper	Repair		IV
5145779	N67309	10/19/2015	13:58	10/19/2015	15:22	1	83	83	Overhead equipment	Overhead Primary	Replace - Same Size	Replace - Same Size	I
5145795	E05002	10/19/2015	14:19	10/19/2015	18:29	90	22444	249	Tree related-tree broken	Overhead Primary	Repair		IV
5145789	335004	10/19/2015	14:24	10/19/2015	17:06	1	161	161	Tree related-tree broken	Overhead Primary	Patrol/Test/Inspect	Trim	VI
5145791	S47586	10/19/2015	14:28	10/19/2015	15:00	1	31	31	Other				VI
5145793	E05002	10/19/2015	14:29	10/19/2015	18:29	1	239	239	Overhead equipment				IV

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5145803	E05002	10/19/2015	14:34	10/19/2015	18:29	1	234	234	Overhead equipment	Tree	Trim		IV
5145815	L82187	10/19/2015	14:48	10/19/2015	16:55	1	126	126	Animal related	Fuse	Replace - Same Size		IV
5145817	A91003	10/19/2015	14:48	10/19/2015	15:55	1	66	66	Unknown	Underground Transformer			I
5145825	S88503	10/19/2015	15:06	10/19/2015	15:33	1	26	26	Animal related	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
5145827	P60161	10/19/2015	15:11	10/19/2015	15:55	1	43	43	Other				VI
5145829	R58961	10/19/2015	15:13	10/19/2015	16:03	14	692	49	Animal related	Fuse	Replace - Same Size		IV
5145835	C52001	10/19/2015	15:30	10/19/2015	16:23	92	4785	52	Overhead equipment	Disconnect Switch	Replace - Same Size		III
5145839	S62523	10/19/2015	15:40	10/19/2015	16:25	1	44	44	Animal related	Transformer Fuse			VI
5145845	P58155	10/19/2015	15:44	10/19/2015	16:42	14	803	57	Animal related	Disconnect Switch	Replace - Same Size		VI
5145859	K52401	10/19/2015	16:16	10/19/2015	17:04	1	47	47	Animal related	Transformer Fuse	Replace - Same Size		V
5145867	M36189	10/19/2015	16:26	10/19/2015	18:20	1	113	113	Animal related	Fuse	Replace - Same Size	Patrol/Test/Inspect	I
5145871	C52001	10/19/2015	16:28	10/19/2015	17:22	33	1769	53	Overhead equipment	Fuse	Replace - Same Size		III
5145875	P17107	10/19/2015	16:40	10/19/2015	17:32	1	51	51	Animal related	Transformer Fuse	Replace - Same Size		IV
5145881	S92559	10/19/2015	17:05	10/19/2015	17:55	1	49	49	Animal related	Transformer Fuse	Replace - Same Size		VI
5145883	B57001	10/19/2015	17:12	10/20/2015	2:37	44	8644	564	Animal related	Fuse	Replace - Same Size		I
5145887	J84124	10/19/2015	17:25	10/19/2015	18:17	7	358	51	Tree related-tree broken	Transformer Fuse	Replace - Same Size		VI
5145889	X39530	10/19/2015	17:36	10/19/2015	18:40	1	63	63	Tree related-tree broken	Overhead Service	Repair	Repair	IV
5145897	J56341	10/19/2015	18:08	10/19/2015	19:42	3	279	93	Animal related	Overhead Transformer			III
5145901	J18267	10/19/2015	18:21	10/19/2015	19:24	4	250	62	Animal related	Transformer Fuse	Replace - Same Size		VI
5145903	H11340	10/19/2015	18:22	10/19/2015	21:57	5	1074	214	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	V
5145905	Q85162	10/19/2015	18:31	10/19/2015	19:47	3	226	75	Animal related	Transformer Fuse	Replace - Same Size		VI
5145909	Q85162	10/19/2015	18:55	10/19/2015	19:53	1	57	57	Animal related	Transformer Fuse	Replace - Same Size		VI
5145911	C00001	10/19/2015	19:34	10/19/2015	23:09	1	214	214	Other	Overhead Service			I
5145927	X88507	10/19/2015	23:40	10/20/2015	0:36	1	55	55	Animal related	Transformer Fuse	Replace - Same Size		IV
5145935	P98190	10/20/2015	3:22	10/20/2015	4:52	5	445	89	Animal related	Transformer Fuse	Repair	Repair	III
5145941	J07135	10/20/2015	4:52	10/20/2015	6:26	1	93	93	Animal related	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	I
5145945	A81004	10/20/2015	5:41	10/20/2015	6:43	1	61	61	Animal related	Transformer Fuse	Replace - Same Size	Replace - Same Size	I
5145947	R60554	10/20/2015	5:45	10/20/2015	7:24	4	390	99	Underground equipment	Underground Primary	Switch/Reset	Repair	IV
5145949	P98191	10/20/2015	5:57	10/20/2015	10:00	1	242	242	Underground equipment	Underground Service	Repair	Repair	III
5145951	X69555	10/20/2015	6:14	10/20/2015	6:58	1	43	43	Animal related	Fuse	Repair	Replace - Same Size	IV
5145953	R60554	10/20/2015	6:53	10/20/2015	7:24	6	189	31	Underground equipment				IV
5145955	L73160	10/20/2015	7:06	10/20/2015	8:00	36	1922	53	Underground equipment				IV
5145957	M37192	10/20/2015	7:09	10/20/2015	8:05	1	55	55	Public				I
5145961	S93553	10/20/2015	7:18	10/20/2015	10:25	4	744	186	Animal related	Transformer Fuse	Replace - Same Size		VI
5145963	S78550	10/20/2015	7:21	10/20/2015	13:50	1	388	388	Underground equipment	Underground Primary			VI
5145969	H22347	10/20/2015	7:48	10/20/2015	10:00	5	659	131	Animal related	Fuse	Replace - Same Size		V
5145971	S47575	10/20/2015	7:49	10/20/2015	8:40	4	200	50	Animal related	Transformer Fuse			VI
5145975	J84146	10/20/2015	7:50	10/20/2015	8:29	13	502	38	Animal related	Fuse	Repair	Replace - Same Size	VI
5145977	B79005	10/20/2015	8:04	10/20/2015	9:50	1	105	105	Overhead equipment	Overhead Service	Patrol/Test/Inspect		I
5145983	K46389	10/20/2015	8:10	10/20/2015	9:04	1	53	53	Animal related	Recloser	Switch/Reset		V
5145985	K52401	10/20/2015	8:10	10/20/2015	8:52	404	16968	42	Animal related	Recloser	Switch/Reset		V
5145989	K52401	10/20/2015	8:12	10/20/2015	9:05	5	261	52	Animal related	Recloser	Switch/Reset		V
5146017	K52401	10/20/2015	8:16	10/20/2015	9:07	1	50	50	Animal related				V
5146015	K52401	10/20/2015	8:16	10/20/2015	9:08	1	51	51	Animal related				V
5145997	S43511	10/20/2015	8:29	10/20/2015	8:59	1	29	29	Animal related	Transformer Fuse	Replace - Same Size	Replace - Same Size	VI
5146003	M18131	10/20/2015	8:31	10/20/2015	9:30	50	2949	58	Animal related	Fuse	Replace - Same Size		III
5146009	Y45503	10/20/2015	8:39	10/20/2015	10:18	1	98	98	Overhead equipment	Transformer Fuse	Repair	Replace - Same Size	IV
5146013	D39001	10/20/2015	8:45	10/20/2015	9:28	1	42	42	Overhead equipment	Fuse	Repair		I
5146021	B80004	10/20/2015	8:53	10/20/2015	10:00	1	66	66	Public	Overhead Service	Cut in Clear	Repair	I
5146023	J20931	10/20/2015	8:55	10/20/2015	9:26	1	30	30	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	VI
5146027	Y60593	10/20/2015	8:58	10/20/2015	11:36	1	157	157	Animal related	Transformer Fuse	Replace - Same Size		IV
5146029	K52401	10/20/2015	9:00	10/20/2015	9:09	1	8	8	Animal related				V
5146031	Q36410	10/20/2015	9:01	10/20/2015	9:57	1	55	55	Animal related	Fuse	Replace - Same Size		I
5146033	Q06141	10/20/2015	9:02	10/20/2015	10:13	1	70	70	Animal related	Fuse	Repair		IV
5146035	D55003	10/20/2015	9:08	10/20/2015	9:46	7	260	37	Animal related	Transformer Fuse	Replace - Same Size		I
5146037	D66001	10/20/2015	9:17	10/20/2015	9:53	1	35	35	Overhead equipment	Transformer Fuse	Replace - Same Size		IV

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5146041	R10943	10/20/2015	9:27	10/20/2015	12:37	1	189	189	Overhead equipment	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	VI
5146047	N94180	10/20/2015	9:38	10/20/2015	11:30	1	111	111	Tree related-tree broken	Overhead Service	Repair		I
5146051	D55001	10/20/2015	9:39	10/20/2015	11:04	31	2629	84	Animal related	Fuse	Replace - Same Size		I
5146063	Z30584	10/20/2015	9:48	10/20/2015	10:45	1	56	56	Animal related	Fuse	Repair		IV
5146065	S42579	10/20/2015	9:49	10/20/2015	10:21	1	31	31	Animal related	Transformer Fuse	Replace - Same Size	Replace - Same Size	VI
5146079	K07322	10/20/2015	9:57	10/20/2015	11:33	17	1621	95	Animal related	Fuse	Replace - Same Size		I
5146077	D89003	10/20/2015	10:05	10/20/2015	10:55	2	99	49	Animal related	Fuse	Repair		I
5146081	A85001	10/20/2015	10:11	10/20/2015	10:52	1	40	40	Overhead equipment				I
5146085	T17581	10/20/2015	10:16	10/20/2015	10:45	1	28	28	Animal related	Transformer Fuse	Replace - Same Size		VI
5146089	S14511	10/20/2015	10:18	10/20/2015	10:48	1	29	29	Unknown	Customer Equipment	Replace - Same Size		VI
5146095	M48815	10/20/2015	10:19	10/20/2015	12:05	56	5896	105	Overhead equipment	Jumper	Repair	Repair	V
5146145	K52401	10/20/2015	10:22	10/20/2015	12:08	618	45141	105	Animal related	Recloser	Switch/Reset		V
5146099	L17101	10/20/2015	10:26	10/20/2015	11:15	1	48	48	Animal related	Fuse	Replace - Same Size		III
5146123	L12127	10/20/2015	10:28	10/20/2015	11:56	1	87	87	Animal related	Fuse	Replace - Same Size		III
5146147	P05825	10/20/2015	10:32	10/20/2015	11:02	1	29	29	Animal related	Transformer Fuse	Replace - Same Size		V
5146157	J99128	10/20/2015	10:42	10/20/2015	11:17	1	34	34	Overhead equipment	Transformer Fuse	Repair	Repair	VI
5146159	U68581	10/20/2015	10:50	10/20/2015	12:01	1	70	70	Other				II
5146161	B10001	10/20/2015	10:50	10/20/2015	11:50	1	59	59	Animal related	Fuse	Repair		I
5146163	K52401	10/20/2015	10:54	10/20/2015	12:17	1	82	82	Animal related	Recloser	Switch/Reset		V
5146165	J56341	10/20/2015	10:55	10/20/2015	12:57	10	1219	121	Animal related	Transformer Fuse	Repair	Repair	III
5146169	K52401	10/20/2015	11:02	10/20/2015	12:28	1	85	85	Animal related	Recloser	Switch/Reset		V
5146171	K52401	10/20/2015	11:02	10/20/2015	12:19	1	76	76	Animal related	Recloser	Switch/Reset		V
5146175	C36002	10/20/2015	11:05	10/20/2015	11:53	1	47	47	Animal related	Fuse	Replace - Same Size		III
5146183	K46388	10/20/2015	11:18	10/20/2015	12:23	1	64	64	Animal related				V
5146187	K43385	10/20/2015	11:20	10/20/2015	12:20	1	59	59	Animal related	Recloser	Switch/Reset		V
5146197	J14140	10/20/2015	11:34	10/20/2015	12:37	1	62	62	Animal related	Fuse	Replace - Same Size		VI
5146199	N94180	10/20/2015	11:36	10/20/2015	12:18	1	41	41	Animal related	Transformer Fuse	Replace - Same Size		I
5146201	F03003	10/20/2015	11:38	10/20/2015	12:40	1	61	61	Animal related	Fuse	Replace - Same Size		III
5146203	B71002	10/20/2015	11:40	10/20/2015	12:57	13	996	76	Unknown	Fuse	Replace - Same Size		I
5146205	P69173	10/20/2015	11:42	10/20/2015	12:39	1	56	56	Animal related	Fuse	Replace - Same Size	Repair	III
5146207	P62138	10/20/2015	11:44	10/20/2015	12:30	1	45	45	Overhead equipment	Fuse	Replace - Same Size		VI
5146213	U61572	10/20/2015	12:00	10/20/2015	13:17	1	76	76	Overhead equipment	Fuse	Replace - Same Size		II
5146217	K52401	10/20/2015	12:05	10/20/2015	12:24	1	18	18	Animal related				V
5146225	K28180	10/20/2015	12:08	10/20/2015	13:00	1	52	51	Animal related	Fuse	Replace - Same Size		III
5146229	K46388	10/20/2015	12:36	10/20/2015	13:00	1	23	23	Animal related				V
5146231	C36002	10/20/2015	12:41	10/20/2015	13:30	1	48	48	Animal related	Fuse	Replace - Same Size		III
5146237	J08207	10/20/2015	12:56	10/20/2015	13:55	42	2438	58	Animal related	Fuse	Replace - Same Size		I
5146251	N18210	10/20/2015	13:05	10/20/2015	14:21	28	2117	75	Animal related	Transformer Fuse	Replace - Same Size		III
5146269	J07173	10/20/2015	13:32	10/20/2015	16:28	3	526	175	Overhead equipment				I
5146283	R95520	10/20/2015	13:36	10/20/2015	14:41	1	64	64	Animal related	Transformer Fuse	Repair		I
5146289	308003	10/20/2015	13:47	10/20/2015	16:14	18	2633	146	Public	Other			VI
5146383	X88510	10/20/2015	14:10	10/20/2015	19:12	17	5128	301	Underground equipment	Fuse	Replace - Same Size		IV
5146307	F03003	10/20/2015	14:28	10/20/2015	15:32	1	63	63	Animal related	Fuse	Reconnect		III
5146309	J07173	10/20/2015	14:33	10/20/2015	16:28	30	3422	114	Overhead equipment				I
5146313	K46422	10/20/2015	14:34	10/20/2015	15:49	47	3517	74	Tree related-tree broken	Fuse	Replace - Same Size		V
5146315	K46422	10/20/2015	14:39	10/20/2015	15:54	1	74	74	Tree related-tree broken				V
5146319	K46422	10/20/2015	14:45	10/20/2015	15:54	1	68	68	Tree related-tree broken				V
5146321	X88510	10/20/2015	14:48	10/20/2015	15:53	9	583	64	Underground equipment	Underground Primary	Repair		IV
5146327	K46422	10/20/2015	14:52	10/20/2015	15:55	1	62	62	Tree related-tree broken				V
5146331	J79304	10/20/2015	15:18	10/20/2015	17:39	1	140	140	Overhead equipment	Transformer Fuse	Replace - Same Size	Replace - Same Size	I
5146333	U16001	10/20/2015	15:19	10/20/2015	16:40	1	80	80	Overhead equipment	Connector	Replace - New Size	Repair	II
5146339	M41112	10/20/2015	15:25	10/20/2015	16:07	1	41	41	Animal related	Transformer Fuse	Replace - Same Size		I
5146341	U01514	10/20/2015	15:26	10/20/2015	16:25	1	58	58	Animal related	Transformer Fuse	Replace - Same Size	Replace - Same Size	II
5146345	P26280	10/20/2015	15:34	10/20/2015	19:20	1	225	225	Tree related-tree contact	Overhead Secondary	Patrol/Test/Inspect	Repair	I
5146427	L59933	10/20/2015	15:35	10/20/2015	19:03	68	14163	208	Overhead equipment	Overhead Primary	Replace - Same Size	Replace - Same Size	VI
5146385	L59933	10/20/2015	15:35	10/20/2015	18:46	309	59250	191	Overhead equipment	Overhead Primary	Replace - Same Size	Replace - Same Size	VI

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5146397	R61241	10/20/2015	16:26	10/20/2015	18:29	1	122	122	Public	Underground Service	Patrol/Test/Inspect	Repair	IV
5146403	N05172	10/20/2015	16:35	10/20/2015	17:45	2	138	69	Animal related	Transformer Fuse	Repair	Repair	I
5146415	R48166	10/20/2015	17:22	10/20/2015	23:00	4	1350	337	Tree related-tree broken	Overhead Primary		Repair	IV
5146419	S62523	10/20/2015	17:31	10/20/2015	18:22	1	51	50	Animal related	Transformer Fuse	Repair	Replace - Same Size	VI
5146421	R84148	10/20/2015	17:38	10/20/2015	18:50	6	429	71	Weather	Fuse	Patrol/Test/Inspect	Replace - Same Size	I
5146429	M41112	10/20/2015	18:35	10/20/2015	20:50	1	134	134	Animal related	Fuse	Replace - Same Size		I
5146435	A36002	10/20/2015	19:53	10/20/2015	21:41	1	107	107	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
5146441	J79304	10/20/2015	19:56	10/20/2015	22:49	99	17176	173	Overhead equipment	Overhead Primary	Replace - Same Size	Replace - Same Size	I
5146455	A36002	10/20/2015	19:57	10/21/2015	3:32	4	1817	454	Underground equipment	Underground Primary	Repair		I
5146445	K08909	10/20/2015	20:42	10/20/2015	21:34	1	51	51	Animal related	Fuse	Replace - Same Size	Replace - Same Size	VI
5146447	A68002	10/20/2015	20:42	10/21/2015	5:33	1	530	530	Tree related-tree contact	Overhead Service	Patrol/Test/Inspect	Repair	I
5146449	V22555	10/20/2015	20:44	10/20/2015	22:20	1	95	95	Animal related	Fuse	Replace - Same Size		II
5146451	R53416	10/20/2015	21:27	10/20/2015	22:25	1	57	57	Animal related	Transformer Fuse	Replace - Same Size		V
5146457	A85002	10/20/2015	21:47	10/21/2015	1:25	5	1089	217	Overhead equipment				I
5146467	N54213	10/21/2015	0:20	10/21/2015	2:31	1	130	130	Unknown				II
5146477	K62102	10/21/2015	0:20	10/21/2015	3:44	40	8136	203	Unknown				II
5146471	T59942	10/21/2015	0:32	10/21/2015	2:09	6	554	96	Overhead equipment	Underground Primary	Repair	Replace - Same Size	VI
5146481	N54213	10/21/2015	0:46	10/21/2015	2:31	32	3351	104	Unknown				II
5146483	B65003	10/21/2015	1:16	10/21/2015	1:45	1	28	28	Public	Overhead Service	Disconnect		I
5146485	N54214	10/21/2015	1:32	10/21/2015	4:14	1	162	162	Overhead equipment	Fuse	Replace - Same Size		II
5146489	N50332	10/21/2015	1:55	10/21/2015	4:45	1	169	169	Overhead equipment	Fuse	Replace - Same Size		II
5146491	Y45503	10/21/2015	2:11	10/21/2015	3:19	1	67	67	Overhead equipment	Transformer Fuse	Repair	Replace - Same Size	IV
5146493	D53002	10/21/2015	2:49	10/21/2015	8:04	33	10407	315	Other	Pole	Repair		I
5146497	D53002	10/21/2015	2:52	10/21/2015	5:30	230	36420	158	Other	Pole	Repair		I
5146499	R49263	10/21/2015	6:13	10/21/2015	7:35	1	81	81	Animal related	Transformer Fuse	Replace - Same Size		VI
5146501	A80002	10/21/2015	6:15	10/21/2015	8:00	1	104	104	Overhead equipment	Fuse	Replace - Same Size		I
5146505	S47589	10/21/2015	7:10	10/21/2015	8:00	15	738	49	Animal related	Fuse			VI
5146509	N54213	10/21/2015	7:15	10/21/2015	8:10	1	54	54	Animal related	Fuse	Replace - Same Size		II
5146515	D32212	10/21/2015	7:54	10/21/2015	8:38	2	86	43	Unknown	Fuse	Repair	Replace - Same Size	I
5146517	310123	10/21/2015	7:55	10/21/2015	8:40	6	266	44	Animal related	Fuse	Replace - Same Size		V
5146519	J07173	10/21/2015	7:56	10/21/2015	8:52	1	55	55	Animal related	Fuse	Repair	Replace - Same Size	I
5146523	J56341	10/21/2015	8:09	10/21/2015	9:01	1	51	51	Tree related-tree broken	Overhead Service			III
5146525	R02121	10/21/2015	8:12	10/21/2015	8:40	1	27	27	Animal related	Transformer Fuse	Repair	Repair	VI
5146529	S15560	10/21/2015	8:21	10/21/2015	9:12	1	50	50	Animal related	Fuse	Replace - Same Size		VI
5146527	M49410	10/21/2015	8:21	10/21/2015	8:57	10	357	35	Animal related	Fuse	Replace - Same Size		V
5146531	R48165	10/21/2015	8:31	10/21/2015	9:15	1	43	43	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
5146539	R48165	10/21/2015	9:05	10/21/2015	9:18	1	12	12	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
5146545	M36185	10/21/2015	9:14	10/21/2015	10:33	1	78	78	Animal related	Overhead Primary	Patrol/Test/Inspect	Replace - Same Size	I
5146549	U02597	10/21/2015	9:21	10/21/2015	10:30	1	68	68	Animal related	Transformer Fuse	Replace - Same Size	Replace - Same Size	II
5146551	C70004	10/21/2015	9:23	10/21/2015	11:18	4	459	114	Overhead equipment	Overhead Primary	Patrol/Test/Inspect	Repair	III
5146553	C70004	10/21/2015	9:32	10/21/2015	11:18	1	105	105	Overhead equipment	Overhead Primary	Patrol/Test/Inspect	Repair	III
5146555	B27009	10/21/2015	9:33	10/21/2015	10:30	808	46152	57	Overhead equipment	Overhead Transformer	Repair		I
5146557	J89126	10/21/2015	9:33	10/21/2015	10:15	1	41	41	Animal related	Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
5146621	B27009	10/21/2015	9:35	10/21/2015	10:43	95	6422	67	Overhead equipment	Overhead Transformer	Repair		I
5146561	Y11556	10/21/2015	9:37	10/21/2015	10:15	1	37	37	Animal related	Transformer Fuse	Replace - Same Size		IV
5146563	D35002	10/21/2015	9:41	10/21/2015	10:33	7	364	52	Unknown	Fuse	Repair	Replace - Same Size	I
5146571	D35002	10/21/2015	9:46	10/21/2015	10:32	1	45	45	Underground equipment	Underground Primary	Patrol/Test/Inspect		I
5146581	K28183	10/21/2015	9:52	10/21/2015	10:40	23	1087	47	Animal related	Fuse	Repair		III
5146587	D35002	10/21/2015	9:56	10/21/2015	10:33	1	36	36	Overhead equipment	Fuse	Repair		I
5146593	J82106	10/21/2015	9:58	10/21/2015	11:02	20	1274	63	Overhead equipment	Overhead Secondary	Patrol/Test/Inspect	Replace - Same Size	VI
5146601	M81403	10/21/2015	10:03	10/21/2015	10:58	1	54	54	Animal related	Fuse	Replace - Same Size		V
5146603	M81403	10/21/2015	10:03	10/21/2015	10:58	1	54	54	Animal related	Fuse	Replace - Same Size		V
5146609	M36185	10/21/2015	10:06	10/21/2015	10:34	5	138	27	Animal related	Overhead Primary	Patrol/Test/Inspect	Replace - Same Size	I
5146615	J08205	10/21/2015	10:09	10/21/2015	11:29	1	79	79	Unknown	Fuse	Replace - Same Size		I
5146617	K30205	10/21/2015	10:10	10/21/2015	11:06	3	166	55	Overhead equipment				III
5146619	D35002	10/21/2015	10:21	10/21/2015	10:53	1	31	31	Overhead equipment	Fuse	Repair		I

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5146629	B27009	10/21/2015	10:30	10/21/2015	12:31	1	120	120	Overhead equipment	Overhead Transformer	Repair		I
5146637	B27009	10/21/2015	10:37	10/21/2015	10:51	1	13	13	Overhead equipment	Overhead Transformer	Repair		I
5146643	B27009	10/21/2015	10:46	10/21/2015	10:51	903	4876	5	Overhead equipment				I
5146645	U64521	10/21/2015	10:46	10/21/2015	11:39	1	52	52	Other				II
5146647	D35002	10/21/2015	10:46	10/21/2015	16:42	7	2489	355	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
5146649	B27009	10/21/2015	10:51	10/21/2015	11:20	1	28	28	Overhead equipment	Transformer Fuse	Replace - Same Size		I
5146651	B27009	10/21/2015	10:51	10/21/2015	11:19	4	108	27	Overhead equipment				I
5146655	B27009	10/21/2015	10:52	10/21/2015	12:39	1	106	106	Overhead equipment	Overhead Transformer	Repair		I
5146657	B27009	10/21/2015	10:53	10/21/2015	11:38	1	44	44	Overhead equipment	Overhead Transformer	Repair		I
5146661	B27009	10/21/2015	10:56	10/21/2015	11:20	1	24	24	Overhead equipment				I
5146665	C00002	10/21/2015	11:02	10/21/2015	12:30	1	87	87	Overhead equipment	Fuse	Repair		I
5146667	J82106	10/21/2015	11:02	10/21/2015	13:10	6	764	127	Overhead equipment	Overhead Secondary	Patrol/Test/Inspect	Repair	VI
5146669	B27009	10/21/2015	11:02	10/21/2015	11:20	1	17	17	Overhead equipment	Overhead Transformer	Repair		I
5146671	B27009	10/21/2015	11:05	10/21/2015	11:23	1	17	17	Overhead equipment				I
5146677	M09144	10/21/2015	11:10	10/21/2015	12:21	1	70	70	Animal related	Fuse	Replace - Same Size		VI
5146675	M09144	10/21/2015	11:10	10/21/2015	12:00	1	49	49	Animal related	Fuse	Replace - Same Size		VI
5146687	J08205	10/21/2015	11:17	10/21/2015	11:30	5	61	12	Unknown	Fuse	Replace - Same Size		I
5146689	Y36541	10/21/2015	11:22	10/21/2015	11:40	1	17	17	Animal related	Fuse	Repair		IV
5146695	B00002	10/21/2015	11:29	10/21/2015	13:43	128	17039	133	Underground equipment	Underground Primary	Repair	Repair	I
5156385	K71822	10/21/2015	11:32	10/21/2015	15:10	754	164409	218	Overhead equipment				IV
5146755	Y36559	10/21/2015	11:48	10/21/2015	12:40	1	51	51	Animal related	Fuse	Repair	Replace - Same Size	IV
5146789	U12540	10/21/2015	12:57	10/21/2015	14:14	7	533	76	Animal related	Transformer Fuse	Repair	Replace - Same Size	II
5146801	R10943	10/21/2015	13:19	10/21/2015	15:30	1	130	130	Animal related	Disconnect Switch	Patrol/Test/Inspect	Replace - Same Size	VI
5146805	E10001	10/21/2015	13:28	10/21/2015	19:25	4	1430	357	Public				III
5146815	M25143	10/21/2015	13:45	10/21/2015	17:04	1	198	198	Overhead equipment	Fuse	Replace - Same Size		IV
5146829	K71811	10/21/2015	14:27	10/21/2015	15:12	1	44	44	Overhead equipment	Overhead Primary	Patrol/Test/Inspect	Repair	IV
5146841	Q36410	10/21/2015	15:00	10/21/2015	16:08	1	67	67	Tree related-tree contact	Overhead Service	Repair		I
5146851	P17107	10/21/2015	15:19	10/21/2015	16:30	1	70	70	Animal related	Transformer Fuse		Replace - Same Size	IV
5146863	M40116	10/21/2015	15:40	10/21/2015	16:40	1	59	59	Weather	Fuse	Replace - Same Size		I
5146865	D92002	10/21/2015	15:51	10/21/2015	17:12	13	1045	80	Animal related	Fuse	Replace - Same Size		I
5146867	B68003	10/21/2015	15:56	10/21/2015	20:43	10	2874	287	Underground equipment	Underground Primary	Repair		III
5146869	N05172	10/21/2015	16:00	10/21/2015	16:40	1	39	39	Animal related	Transformer Fuse	Repair	Repair	I
5146877	D92002	10/21/2015	16:10	10/21/2015	17:10	1	59	59	Animal related	Fuse	Replace - Same Size		I
5146883	P20930	10/21/2015	16:19	10/21/2015	20:10	72	6685	231	Tree related-tree broken	Overhead Primary	Patrol/Test/Inspect	Repair	VI
5146881	U90566	10/21/2015	16:19	10/21/2015	18:02	1	102	102	Overhead equipment	Overhead Transformer	Repair	Repair	II
5146887	M21134	10/21/2015	16:32	10/21/2015	23:42	22	9460	430	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	VI
5146895	V04552	10/21/2015	16:51	10/21/2015	18:32	1	100	100	Animal related	Transformer Fuse	Replace - Same Size		II
5146897	K74164	10/21/2015	16:54	10/21/2015	17:47	1	52	52	Other				IV
5146901	V23592	10/21/2015	17:03	10/21/2015	18:30	1	86	86	Animal related	Transformer Fuse	Repair	Replace - Same Size	II
5146905	M21134	10/21/2015	17:16	10/21/2015	21:38	14	3660	261	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	VI
5146909	H00163	10/21/2015	17:38	10/21/2015	17:45	1	6	6	Animal related	Fuse			III
5146911	K71812	10/21/2015	17:42	10/21/2015	18:40	1	57	57	Overhead equipment	Connector	Repair		IV
5146917	K30205	10/21/2015	18:08	10/21/2015	19:38	3	267	89	Animal related	Transformer Fuse	Replace - Same Size		III
5146925	U16522	10/21/2015	19:19	10/21/2015	21:33	1	133	133	Overhead equipment	Transformer Fuse	Replace - Same Size	Repair	II
5146931	B82001	10/21/2015	20:38	10/21/2015	22:38	1	119	119	Animal related	Fuse			I
5146935	K67912	10/21/2015	21:42	10/22/2015	1:51	1	248	248	Animal related	Overhead Transformer	Patrol/Test/Inspect	Replace - Same Size	VI
5146937	S50544	10/21/2015	21:48	10/21/2015	23:00	1	71	71	Overhead equipment				VI
5147003	V24-XTR1	10/21/2015	23:26	10/22/2015	5:05	740	251022	339	Substation equipment	Lightning Arrestor	Replace - Same Size		II
5146997	K52400	10/21/2015	23:51	10/22/2015	3:57	30	6587	245	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	V
5147013	A91004	10/22/2015	1:27	10/22/2015	7:35	6	2206	367	Underground equipment	Fuse	Patrol/Test/Inspect	Replace - Same Size	I
5147015	R39934	10/22/2015	2:31	10/22/2015	4:11	1	99	99	Animal related	Transformer Fuse	Replace - Same Size		VI
5147019	U13551	10/22/2015	5:25	10/22/2015	7:19	1	113	113	Animal related	Transformer Fuse	Repair		II
5147025	Q54908	10/22/2015	7:24	10/22/2015	8:12	1	47	47	Animal related	Transformer Fuse	Replace - Same Size	Replace - Same Size	VI
5147027	S86597	10/22/2015	7:37	10/22/2015	9:32	7	801	114	Unknown	Fuse	Replace - Same Size		VI
5147029	J20931	10/22/2015	7:40	10/22/2015	8:35	11	600	54	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	VI
5147031	R65451	10/22/2015	7:41	10/22/2015	8:35	7	375	53	Animal related	Transformer Fuse	Replace - Same Size		IV

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5147033	V77543	10/22/2015	7:48	10/22/2015	10:25	21	3285	156	Underground equipment	Underground Primary		Repair	II
5147041	HA5432	10/22/2015	8:02	10/22/2015	9:16	3	221	73	Animal related	Fuse	Replace - Same Size		V
5147047	J18267	10/22/2015	8:19	10/22/2015	8:58	1	38	38	Animal related	Transformer Fuse	Replace - Same Size		VI
5147049	Y12559	10/22/2015	8:25	10/22/2015	9:45	1	79	79	Public	Meter	Replace - Same Size		IV
5147051	K39153	10/22/2015	8:30	10/22/2015	10:26	1	115	115	Animal related	Transformer Fuse	Repair		III
5147055	L43154	10/22/2015	8:42	10/22/2015	9:27	9	399	44	Animal related	Transformer Fuse	Replace - Same Size		I
5147063	J84123	10/22/2015	8:51	10/22/2015	9:19	1	27	27	Animal related	Fuse		Replace - Same Size	VI
5147065	S30518	10/22/2015	9:06	10/22/2015	9:50	1	43	43	Animal related	Transformer Fuse	Patrol/Test/Inspect	Patrol/Test/Inspect	VI
5147067	R61241	10/22/2015	9:13	10/22/2015	10:28	1	74	74	Animal related	Transformer Fuse	Replace - Same Size		IV
5147099	X02546	10/22/2015	9:29	10/22/2015	10:19	22	1085	49	Animal related	Fuse	Replace - Same Size		IV
5147085	308005	10/22/2015	9:35	10/22/2015	22:50	1	794	794	Intentional	Meter	Patrol/Test/Inspect		VI
5147109	P26283	10/22/2015	10:02	10/22/2015	11:11	1	68	68	Animal related	Fuse	Replace - Same Size		I
5147117	J80806	10/22/2015	10:12	10/22/2015	11:01	1	48	48	Animal related	Overhead Transformer	Repair	Repair	V
5147119	R49275	10/22/2015	10:14	10/22/2015	11:25	1	70	70	Animal related	Transformer Fuse	Replace - Same Size		VI
5147121	P69174	10/22/2015	10:16	10/22/2015	11:10	1	54	54	Animal related	Fuse	Replace - Same Size		III
5147129	V92540	10/22/2015	10:25	10/22/2015	11:05	1	39	39	Animal related	Transformer Fuse	Replace - Same Size		II
5147135	P26283	10/22/2015	10:38	10/22/2015	11:11	5	162	32	Animal related	Fuse	Replace - Same Size		I
5147139	R23332	10/22/2015	10:45	10/22/2015	12:50	1	124	124	Overhead equipment	Transformer Fuse	Replace - Same Size		V
5147145	V29001	10/22/2015	11:04	10/22/2015	11:24	2	40	20	Jurisdictional	Tree			II
5147147	Q82907	10/22/2015	11:14	10/22/2015	12:34	1	79	79	Overhead equipment	Jumper	Replace - Same Size	Replace - Same Size	VI
5147149	V42586	10/22/2015	11:20	10/22/2015	12:07	11	523	47	Jurisdictional	Tree	Trim	Trim	II
5147153	J47176	10/22/2015	11:21	10/22/2015	12:16	7	382	54	Animal related	Transformer Fuse	Repair	Repair	III
5147157	M09144	10/22/2015	11:31	10/22/2015	12:41	1	69	69	Overhead equipment	Overhead Service	Replace - Same Size		VI
5147159	L35137	10/22/2015	11:36	10/22/2015	13:12	6	570	95	Unknown	Transformer Fuse	Replace - Same Size		III
5147165	Q82907	10/22/2015	11:57	10/22/2015	12:37	1	39	39	Overhead equipment	Jumper	Replace - Same Size	Replace - Same Size	VI
5147167	M45212	10/22/2015	12:02	10/22/2015	13:20	1	77	77	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
5147175	T41540	10/22/2015	12:21	10/22/2015	13:07	1	45	45	Animal related	Transformer Fuse	Replace - Same Size	Replace - Same Size	IV
5147225	D16004	10/22/2015	12:39	10/22/2015	14:48	104	13449	129	Animal related	Fuse	Replace - Same Size	Replace - Same Size	I
5147209	P26281	10/22/2015	12:56	10/22/2015	13:49	4	208	52	Animal related	Fuse	Replace - Same Size		I
5147217	S14509	10/22/2015	13:16	10/22/2015	13:55	1	38	38	Unknown	Customer Equipment	Replace - Same Size		VI
5147221	S88503	10/22/2015	13:21	10/22/2015	14:35	1	73	73	Overhead equipment	Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
5147223	X92508	10/22/2015	13:22	10/22/2015	14:30	1	67	67	Overhead equipment	Transformer Fuse	Repair	Replace - Same Size	IV
5147237	D36001	10/22/2015	13:30	10/22/2015	14:26	1	55	55	Animal related	Disconnect Switch	Replace - Same Size	Replace - Same Size	I
5147243	L93132	10/22/2015	13:41	10/22/2015	14:35	1	53	53	Intentional	Meter	Patrol/Test/Inspect	Replace - Same Size	VI
5147245	K32916	10/22/2015	13:54	10/22/2015	17:00	4	740	185	Tree related-tree broken	Overhead Primary	Repair		VI
5147257	A26005	10/22/2015	14:08	10/22/2015	14:47	1	38	38	Overhead equipment	Connector	Replace - Same Size		I
5147263	R16511	10/22/2015	14:31	10/22/2015	15:30	8	471	58	Animal related	Transformer Fuse	Repair	Repair	I
5147281	Y39515	10/22/2015	14:49	10/22/2015	14:58	296	2746	9	Overhead equipment	Substation Breaker	Switch/Reset		IV
5147289	X02546	10/22/2015	14:55	10/22/2015	15:38	1	42	42	Animal related	Transformer Fuse	Replace - Same Size		IV
5147293	D32211	10/22/2015	15:05	10/22/2015	23:11	2	972	486	Underground equipment	Underground Primary		Repair	I
5147303	K31120	10/22/2015	15:24	10/22/2015	16:34	1	69	69	Unknown	Transformer Fuse	Replace - Same Size		I
5147311	J83138	10/22/2015	16:04	10/22/2015	17:30	1	85	85	Underground equipment				VI
5147315	M18131	10/22/2015	16:04	10/22/2015	16:49	49	2174	44	Unknown	Fuse	Replace - Same Size		III
5147341	J83138	10/22/2015	16:04	10/22/2015	19:28	4	815	203	Overhead equipment				VI
5147317	Y55003	10/22/2015	16:06	10/22/2015	17:25	1	78	78	Tree related-tree contact	Overhead Service	Repair	Repair	IV
5147313	J83138	10/22/2015	16:10	10/22/2015	17:29	6	478	79	Underground equipment	Underground Primary			VI
5147319	V42586	10/22/2015	16:13	10/22/2015	16:55	11	459	41	Jurisdictional	Overhead Secondary	Replace - Same Size	Replace - Same Size	II
5147325	M18131	10/22/2015	16:52	10/22/2015	17:00	1	7	7	Unknown	Fuse	Replace - Same Size		III
5147329	M18131	10/22/2015	17:05	10/22/2015	18:05	1	59	59	Tree related-tree contact	Overhead Transformer	Switch/Reset		III
5147335	K74166	10/22/2015	17:07	10/22/2015	18:16	48	3283	68	Unknown	Fuse	Replace - Same Size		IV
5147333	M18131	10/22/2015	17:08	10/22/2015	17:50	7	290	41	Overhead equipment	Jumper	Repair		III
5147337	K11373	10/22/2015	17:22	10/22/2015	18:35	1	72	72	Tree related-tree broken	Overhead Service	Repair		V
5147345	P58155	10/22/2015	17:42	10/22/2015	20:52	1	189	189	Public	Overhead Service	Reconnect	Reconnect	VI
152957106		10/22/2015	18:02	10/22/2015	18:16	1	14	14	Substation equipment				I
152957107		10/22/2015	18:02	10/22/2015	18:16	1	14	14	Substation equipment				I
5148115	V58-XTR1	10/22/2015	18:02	10/22/2015	18:17	665	9775	14	Transmission outage				II

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5147559	P47-X2	10/22/2015	18:03	10/22/2015	18:16	2611	33629	12	Transmission outage				I
5148885	Q91-UNIT-1	10/22/2015	18:03	10/22/2015	18:16	1597	20553	12	Transmission outage				I
5148995	P49-X1	10/22/2015	18:03	10/22/2015	20:33	887	132810	149	Transmission outage				I
5147747	P49-X2	10/22/2015	18:03	10/22/2015	18:16	1710	21768	12	Transmission outage				I
5148959	J05-UNIT-3	10/22/2015	18:03	10/22/2015	18:16	222	2823	12	Transmission outage				I
5148743	Q32-UNIT-1	10/22/2015	18:03	10/22/2015	18:16	1958	24240	12	Transmission outage	Substation Relay			I
5149249	R33-UNIT-1	10/22/2015	18:03	10/22/2015	18:16	1273	15568	12	Transmission outage				I
5147521	J01-UNIT-2	10/22/2015	18:04	10/22/2015	18:40	1351	48230	35	Transmission outage				I
5147881	R84-UNIT-1	10/22/2015	18:04	10/22/2015	18:16	1098	12703	11	Transmission outage				I
5148017	J01-UNIT-1	10/22/2015	18:04	10/22/2015	18:40	1425	50416	35	Transmission outage				I
5149197	P07-UNIT-1	10/22/2015	18:04	10/22/2015	18:16	661	7515	11	Transmission outage				I
5147689	N58-UNIT-1	10/22/2015	18:04	10/22/2015	20:34	718	107183	149	Transmission outage				I
5147715	J06-UNIT-1	10/22/2015	18:04	10/22/2015	18:16	995	11124	11	Transmission outage				I
5147579	P47-X1	10/22/2015	18:06	10/22/2015	18:16	928	8834	9	Transmission outage				I
5147859	J83138	10/22/2015	18:09	10/22/2015	19:21	6	436	72	Overhead equipment				VI
5149437	B25002	10/22/2015	18:19	10/22/2015	19:16	39	2214	56	Overhead equipment	Overhead Primary	Replace - Same Size	Replace - Same Size	I
5149423	B76003	10/22/2015	18:27	10/22/2015	21:47	1	199	199	Underground equipment	Underground Service	Patrol/Test/Inspect	Repair	I
5149433	D39001	10/22/2015	18:41	10/22/2015	21:53	1	191	191	Animal related	Fuse			I
5149443	D28124	10/22/2015	19:13	10/22/2015	20:15	1	61	61	Unknown	Transformer Fuse	Replace - Same Size		I
5149497	Z16-XTR1	10/22/2015	21:56	10/23/2015	1:32	544	117406	215	Substation equipment	Lightning Arrestor	Replace - Same Size		IV
5149481	Z37-XTR1	10/22/2015	21:56	10/22/2015	22:39	455	19237	42	Substation equipment				IV
5149493	Z37-XTR2	10/22/2015	21:56	10/22/2015	22:39	63	2663	42	Substation equipment	Lightning Arrestor	Replace - Same Size		IV
5149505	X56521	10/22/2015	22:13	10/23/2015	1:30	1	196	196	Substation equipment	Lightning Arrestor	Remove	Remove	IV
5149509	Y55505	10/22/2015	22:27	10/22/2015	23:30	6	377	62	Overhead equipment	Fuse	Replace - Same Size		IV
5149511	J86118	10/22/2015	22:56	10/23/2015	2:42	3	675	225	Overhead equipment	Overhead Primary		Repair	VI
5149521	Z37-XTR1	10/22/2015	23:59	10/23/2015	0:15	455	7293	16	Substation equipment				IV
5149529	K01240	10/23/2015	3:23	10/23/2015	6:40	26	5115	196	Underground equipment	Underground Primary			VI
5149533	B45005	10/23/2015	4:58	10/23/2015	13:05	1	486	486	Underground equipment	Fuse	Patrol/Test/Inspect	Repair	I
5149535	K01240	10/23/2015	6:01	10/23/2015	6:11	33	315	9	Underground equipment	Fuse	Replace - Same Size		VI
5149537	L24123	10/23/2015	6:54	10/23/2015	9:33	1	158	158	Underground equipment	Underground Service	Patrol/Test/Inspect	Repair	III
5149539	Q27185	10/23/2015	7:08	10/23/2015	9:54	1	165	165	Overhead equipment	Fuse		Replace - Same Size	VI
5149543	B45005	10/23/2015	7:10	10/23/2015	12:36	9	2519	326	Underground equipment	Fuse	Replace - Same Size	Replace - Same Size	I
5149545	T08502	10/23/2015	7:28	10/23/2015	8:40	6	429	71	Animal related	Transformer Fuse	Replace - Same Size	Patrol/Test/Inspect	VI
5149547	B28004	10/23/2015	7:36	10/23/2015	9:02	1	85	85	Unknown	Fuse	Replace - Same Size		I
5149587	Y31-XTR1	10/23/2015	7:47	10/23/2015	12:38	575	32145	290	Animal related	Fuse	Repair	Replace - Same Size	IV
5149573	M81402	10/23/2015	7:51	10/23/2015	8:35	1	43	43	Animal related	Transformer Fuse	Replace - Same Size		V
5149593	K19116	10/23/2015	8:29	10/23/2015	9:47	1	77	77	Public	Overhead Service	Replace - New Size	Replace - New Size	VI
5149597	B45005	10/23/2015	8:34	10/23/2015	11:12	25	3940	157	Underground equipment	Underground Secondary	Repair	Replace - Same Size	I
5149599	R60552	10/23/2015	8:37	10/23/2015	9:28	4	200	50	Animal related	Transformer Fuse	Replace - Same Size		IV
5149601	D36002	10/23/2015	8:41	10/23/2015	9:42	4	243	60	Animal related	Transformer Fuse	Replace - Same Size	Replace - Same Size	I
5149607	Y97513	10/23/2015	8:41	10/23/2015	10:30	1	108	108	Animal related	Overhead Transformer	Replace - Same Size	Replace - Same Size	IV
5149619	R07382	10/23/2015	9:13	10/23/2015	9:15	221	545	2	Unknown				I
5149623	T41540	10/23/2015	9:18	10/23/2015	15:14	1	355	355	Underground equipment	Underground Primary	Repair	Repair	IV
5149625	L93133	10/23/2015	9:23	10/23/2015	9:55	8	254	31	Animal related	Transformer Fuse			VI
5149629	C70002	10/23/2015	9:29	10/23/2015	10:13	1	43	43	Overhead equipment	Fuse	Replace - Same Size		III
5149633	M18131	10/23/2015	9:35	10/23/2015	10:55	28	2225	79	Unknown	Fuse	Replace - Same Size		III
5149659	U13551	10/23/2015	9:41	10/23/2015	11:00	88	6909	78	Unknown	Recloser			II
5149667	K73366	10/23/2015	10:14	10/23/2015	11:20	1	65	65	Public				IV
5149683	K76541	10/23/2015	10:52	10/23/2015	14:45	1	232	232	Tree related-tree contact	Overhead Service	Repair		IV
5149693	Z11536	10/23/2015	11:22	10/23/2015	12:00	4	149	37	Animal related	Transformer Fuse	Repair	Replace - Same Size	IV
5149697	D16004	10/23/2015	11:29	10/23/2015	13:29	18	2149	119	Animal related	Fuse	Replace - Same Size		I
5149699	D35003	10/23/2015	11:30	10/23/2015	12:55	1	84	84	Weather	Transformer Fuse	Replace - Same Size	Replace - Same Size	I
5149701	N60181	10/23/2015	11:32	10/23/2015	12:55	1	82	82	Animal related	Overhead Primary	Patrol/Test/Inspect	Replace - Same Size	I
5149709	R53391	10/23/2015	11:35	10/24/2015	1:10	1	814	814	Underground equipment	Overhead Service	Patrol/Test/Inspect	Repair	V
5149717	S47537	10/23/2015	11:42	10/23/2015	12:32	1	49	49	Overhead equipment				VI
5149723	R93351	10/23/2015	12:03	10/23/2015	13:14	1	70	70	Animal related	Transformer Fuse	Replace - Same Size		V

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5149725	U64518	10/23/2015	12:14	10/23/2015	13:35	10	807	80	Tree related-tree broken	Transformer Fuse	Replace - Same Size		II
5149729	U39541	10/23/2015	12:15	10/23/2015	12:54	1	38	38	Underground equipment	Underground Primary	Switch/Reset	Repair	II
5149733	D36002	10/23/2015	12:20	10/23/2015	14:06	1	105	105	Overhead equipment				I
5149741	A97003	10/23/2015	12:23	10/23/2015	17:48	56	13992	324	Underground equipment	Underground Primary	Patrol/Test/Inspect	Patrol/Test/Inspect	I
5149739	C36002	10/23/2015	12:26	10/23/2015	13:10	2	87	43	Animal related	Fuse	Replace - Same Size		III
5149747	J56341	10/23/2015	12:48	10/23/2015	13:19	1	30	30	Animal related	Transformer Fuse			III
5149749	D69006	10/23/2015	12:52	10/23/2015	13:30	1	37	37	Animal related	Transformer Fuse	Replace - Same Size		I
5149753	K80381	10/23/2015	12:58	10/23/2015	14:28	3	269	89	Animal related	Transformer Fuse	Repair		IV
5149757	E10002	10/23/2015	13:01	10/23/2015	13:17	9	140	15	Animal related	Transformer Fuse	Replace - Same Size		III
5149765	U10569	10/23/2015	13:06	10/23/2015	14:20	40	2928	73	Overhead equipment	Fuse	Replace - Same Size	Patrol/Test/Inspect	II
5149829	R16510	10/23/2015	13:15	10/23/2015	19:32	134	50524	377	Overhead equipment	Overhead Primary	Repair	Repair	I
5149771	U13551	10/23/2015	13:16	10/23/2015	13:50	1	33	33	Unknown	Transformer Fuse	Replace - Same Size	Replace - Same Size	II
5149779	R16510	10/23/2015	13:20	10/23/2015	14:15	4	218	54	Unknown	Fuse	Replace - Same Size		I
5149777	D39001	10/23/2015	13:24	10/23/2015	14:21	1	56	56	Unknown	Transformer Fuse	Replace - Same Size	Replace - Same Size	I
5149789	K31120	10/23/2015	13:39	10/23/2015	15:57	107	14762	137	Overhead equipment	Overhead Primary	Repair	Repair	I
5149795	K31120	10/23/2015	13:40	10/23/2015	15:57	87	11899	136	Overhead equipment	Connector	Repair		I
5149793	X29548	10/23/2015	13:43	10/23/2015	19:50	1	366	366	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	IV
5149799	M41112	10/23/2015	13:53	10/23/2015	14:20	10	268	26	Animal related	Fuse	Repair	Replace - Same Size	I
5149805	D69006	10/23/2015	14:13	10/23/2015	14:53	1	39	39	Unknown	Transformer Fuse	Replace - Same Size		I
5149815	M31201	10/23/2015	14:56	10/23/2015	15:53	1	56	56	Animal related	Transformer Fuse	Replace - Same Size	Replace - Same Size	I
5149827	U31565	10/23/2015	15:19	10/23/2015	16:15	58	3235	55	Underground equipment	Underground Primary	Repair	Repair	II
5149833	N18210	10/23/2015	15:31	10/23/2015	17:20	1	108	108	Overhead equipment				III
5149837	Y28598	10/23/2015	15:48	10/23/2015	18:00	1	131	131	Animal related	Fuse	Replace - Same Size	Repair	IV
5149839	K32915	10/23/2015	15:50	10/23/2015	17:58	1	127	127	Tree related-tree contact	Tree		Remove	VI
5149841	Y45503	10/23/2015	15:54	10/23/2015	16:34	1	39	39	Animal related	Transformer Fuse	Repair	Replace - Same Size	IV
5149849	R60552	10/23/2015	16:11	10/23/2015	16:45	1	33	33	Animal related	Transformer Fuse	Replace - Same Size		IV
5149855	R60554	10/23/2015	16:16	10/23/2015	17:39	1	82	82	Animal related	Transformer Fuse			IV
5149867	R60554	10/23/2015	16:29	10/23/2015	17:38	1	69	69	Animal related	Transformer Fuse			IV
5149871	U33509	10/23/2015	16:35	10/23/2015	17:48	1	72	72	Tree related-tree broken	Tree			II
5149875	D72002	10/23/2015	16:41	10/23/2015	19:06	1	144	144	Overhead equipment	Disconnect Switch	Replace - Same Size		I
5149883	B77003	10/23/2015	16:48	10/23/2015	21:07	32	8290	259	Overhead equipment	Jumper	Replace - Same Size	Repair	I
5149917	B73002	10/23/2015	16:53	10/23/2015	23:32	1	398	398	Underground equipment	Underground Primary	Patrol/Test/Inspect	Patrol/Test/Inspect	I
5149891	B77003	10/23/2015	16:55	10/23/2015	22:11	1	315	315	Overhead equipment				I
5149899	D87001	10/23/2015	17:04	10/23/2015	17:47	14	599	42	Overhead equipment	Disconnect Switch	Replace - Same Size		I
5149947	B77003	10/23/2015	17:06	10/23/2015	21:44	1	277	277	Overhead equipment	Fuse	Replace - Same Size	Replace - Same Size	I
5149901	F10001	10/23/2015	17:10	10/23/2015	20:07	1	176	176	Overhead equipment				III
5149903	Q11516	10/23/2015	17:12	10/23/2015	20:02	1	169	169	Weather	Transformer Fuse	Replace - Same Size		I
5149905	Q11516	10/23/2015	17:13	10/23/2015	20:00	9	1501	166	Weather	Transformer Fuse	Replace - Same Size		I
5149909	T04512	10/23/2015	17:22	10/23/2015	20:00	1	157	157	Overhead equipment	Disconnect Switch	Repair	Replace - Same Size	VI
5149911	351002	10/23/2015	17:25	10/23/2015	19:20	1	114	114	Tree related-tree broken	Overhead Service	Repair		VI
5149913	Q25801	10/23/2015	17:26	10/23/2015	20:47	1	200	200	Tree related-tree contact	Overhead Service	Replace - Same Size	Replace - Same Size	I
5149915	F10001	10/23/2015	17:35	10/23/2015	20:00	5	720	144	Overhead equipment	Disconnect Switch	Replace - Same Size		III
5149925	B81002	10/23/2015	17:43	10/24/2015	6:11	17	5253	747	Other	Fuse	Replace - Same Size		I
5149931	D39001	10/23/2015	17:51	10/24/2015	0:17	1	385	385	Overhead equipment	Crossarm	Replace - Same Size		I
5149939	A97003	10/23/2015	17:53	10/23/2015	18:15	24	542	22	Underground equipment				I
5149937	T15570	10/23/2015	17:59	10/23/2015	19:41	1	101	101	Animal related	Fuse	Patrol/Test/Inspect	Repair	VI
5149949	X92508	10/23/2015	18:19	10/23/2015	21:30	1	190	190	Tree related-tree broken	Overhead Service	Repair	Replace - Same Size	IV
5149953	Q21293	10/23/2015	18:57	10/24/2015	1:00	1	362	362	Tree related-tree broken	Overhead Transformer	Replace - Same Size		VI
5149957	U19567	10/23/2015	19:41	10/23/2015	21:50	1	128	128	Overhead equipment	Disconnect Switch	Replace - Same Size	Repair	II
5149965	Q80353	10/23/2015	19:50	10/23/2015	22:28	17	2686	158	Underground equipment	Underground Primary	Switch/Reset	Repair	V
5149967	N54214	10/23/2015	20:18	10/24/2015	0:13	26	6118	235	Underground equipment	Underground Primary	Switch/Reset	Repair	II
5149971	J18268	10/23/2015	20:33	10/23/2015	22:15	3	303	101	Overhead equipment	Transformer Fuse	Replace - Same Size		VI
5149975	Q80353	10/23/2015	21:26	10/23/2015	22:00	22	739	33	Overhead equipment				V
5149985	B76001	10/23/2015	21:45	10/23/2015	23:51	43	5399	125	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	I
5149991	D87001	10/23/2015	21:51	10/24/2015	0:35	6	978	163	Overhead equipment	Transformer Fuse	Replace - Same Size		I
5149995	Q23258	10/23/2015	23:10	10/24/2015	0:31	1	81	81	Animal related	Fuse	Replace - Same Size		VI

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5149997	B00008	10/24/2015	0:11	10/24/2015	2:10	1	118	118	Tree related-tree broken	Overhead Service	Reconnect	Repair	I
5149999	S47538	10/24/2015	1:05	10/24/2015	1:48	1	42	42	Overhead equipment				VI
5150001	S86580	10/24/2015	1:07	10/24/2015	8:40	1	452	452	Underground equipment	Underground Primary	Repair	Repair	VI
5150003	S86580	10/24/2015	1:36	10/24/2015	8:19	1	402	402	Underground equipment	Underground Primary	Repair	Repair	VI
5150009	N15850	10/24/2015	1:53	10/24/2015	4:39	100	15786	166	Public				V
5150023	N15850	10/24/2015	2:31	10/24/2015	7:38	1	306	306	Public	Pole	Replace - New Size	Replace - New Size	V
5150019	D35003	10/24/2015	2:57	10/24/2015	4:40	1	102	102	Overhead equipment	Fuse	Replace - Same Size		I
5150021	P26283	10/24/2015	3:16	10/24/2015	6:00	1	163	163	Tree related-tree broken	Overhead Primary	Repair	Repair	I
5150025	N15850	10/24/2015	4:31	10/24/2015	4:38	53	364	6	Public				V
5150029	S86580	10/24/2015	4:44	10/24/2015	8:19	1	214	214	Underground equipment	Underground Primary	Repair	Repair	VI
5150033	B21002	10/24/2015	4:52	10/24/2015	10:55	7	2536	362	Underground equipment	Underground Primary		Repair	I
5150035	307002	10/24/2015	6:07	10/24/2015	6:46	30	1186	39	Public	Transformer Fuse	Replace - Same Size		VI
5150041	H01192	10/24/2015	6:36	10/24/2015	7:21	1	44	44	Animal related	Transformer Fuse	Replace - Same Size		III
5150043	M36185	10/24/2015	6:49	10/24/2015	8:00	1	70	70	Tree related-tree broken	Overhead Service	Repair		I
5150047	S02502	10/24/2015	7:39	10/24/2015	9:46	1	126	126	Animal related	Transformer Fuse	Patrol/Test/Inspect	Repair	VI
5150083	C50001	10/24/2015	8:28	10/24/2015	13:41	6	1879	313	Underground equipment	Underground Transformer	Repair		III
5150059	J01119	10/24/2015	8:31	10/24/2015	9:37	1	65	65	Tree related-tree broken	Overhead Service	Repair		I
5150063	M05368	10/24/2015	8:38	10/24/2015	9:58	5	395	79	Animal related	Transformer Fuse	Replace - Same Size		V
5150067	V95586	10/24/2015	8:47	10/24/2015	10:27	1	99	99	Overhead equipment				II
5150069	C50001	10/24/2015	8:59	10/24/2015	10:29	2	178	89	Underground equipment	Underground Transformer	Switch/Reset		III
5150073	R16510	10/24/2015	9:21	10/24/2015	10:04	9	378	42	Animal related	Fuse	Replace - Same Size		I
5150075	S15560	10/24/2015	9:33	10/24/2015	11:38	1	124	124	Animal related	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
5150077	P52306	10/24/2015	9:39	10/24/2015	11:30	1	110	110	Tree related-tree contact	Overhead Service	Repair		IV
5150079	L81142	10/24/2015	9:41	10/24/2015	10:16	1	34	34	Animal related	Transformer Fuse	Replace - Same Size		IV
5150089	C50001	10/24/2015	11:01	10/24/2015	13:39	1	157	157	Underground equipment	Underground Transformer	Repair		III
5150091	R39934	10/24/2015	11:07	10/24/2015	12:49	1	101	101	Animal related	Transformer Fuse			VI
5150093	J06167	10/24/2015	11:09	10/24/2015	12:10	1	60	60	Animal related	Transformer Fuse	Replace - Same Size		I
5150097	J87111	10/24/2015	11:24	10/24/2015	12:11	1	46	46	Animal related	Fuse	Replace - Same Size		VI
5150101	D55001	10/24/2015	11:35	10/24/2015	12:31	1	55	55	Overhead equipment				I
5150103	J67132	10/24/2015	11:54	10/24/2015	12:21	1	26	26	Overhead equipment	Jumper			III
5150105	B53001	10/24/2015	12:02	10/24/2015	14:00	7	825	117	Animal related	Fuse	Replace - Same Size		III
5150107	J67132	10/24/2015	12:15	10/24/2015	12:22	1	6	6	Overhead equipment	Jumper			III
5150131	Z19538	10/24/2015	12:24	10/24/2015	13:41	84	6501	77	Tree related-tree broken	Recloser	Repair		IV
5150111	D36001	10/24/2015	12:26	10/24/2015	13:16	1	49	49	Animal related				I
5150113	S47575	10/24/2015	12:30	10/24/2015	13:10	1	39	39	Animal related	Transformer Fuse			VI
5150123	S20554	10/24/2015	12:51	10/24/2015	16:38	1	226	226	Underground equipment	Underground Service			VI
5150133	X66580	10/24/2015	13:13	10/24/2015	15:37	1	143	143	Animal related	Transformer Fuse	Replace - Same Size	Replace - Same Size	IV
5150135	M26161	10/24/2015	13:21	10/24/2015	18:40	1	318	318	Overhead equipment	Overhead Transformer		Repair	III
5150137	D60001	10/24/2015	13:22	10/24/2015	15:25	26	3179	122	Underground equipment	Underground Primary	Repair		III
5150147	L23146	10/24/2015	13:27	10/24/2015	16:15	46	7718	167	Tree related-tree broken	Overhead Primary	Repair		III
5150145	343006	10/24/2015	13:28	10/24/2015	22:53	1	564	564	Public	Meter	Disconnect		VI
5150151	H02256	10/24/2015	13:42	10/24/2015	14:41	1	58	58	Other	Other			III
5150159	Q75146	10/24/2015	13:54	10/24/2015	16:47	1	172	172	Overhead equipment	Fuse	Replace - Same Size		VI
5150161	B21003	10/24/2015	14:17	10/24/2015	15:03	3	136	45	Animal related	Transformer Fuse	Replace - Same Size		I
5150167	K71810	10/24/2015	14:22	10/24/2015	15:06	16	699	43	Unknown	Transformer Fuse			IV
5150169	E10002	10/24/2015	14:27	10/24/2015	15:30	1	62	62	Animal related	Other	Replace - Same Size	Patrol/Test/Inspect	III
5150175	Q85162	10/24/2015	15:21	10/24/2015	15:39	1	17	17	Overhead equipment	Transformer Fuse	Repair	Repair	VI
5150177	N54214	10/24/2015	15:30	10/24/2015	17:07	6	579	96	Overhead equipment	Fuse	Replace - Same Size		II
5150181	L99393	10/24/2015	15:34	10/24/2015	17:00	1	85	85	Animal related	Transformer Fuse	Repair		V
5150183	Y61007	10/24/2015	15:40	10/24/2015	16:14	1	33	33	Overhead equipment	Transformer Fuse	Replace - Same Size		IV
5150193	H07106	10/24/2015	16:13	10/24/2015	17:29	1	75	75	Overhead equipment	Overhead Primary			IV
5150195	R53391	10/24/2015	16:24	10/24/2015	17:52	1	87	87	Animal related	Transformer Fuse	Repair		V
5150197	L23146	10/24/2015	16:29	10/24/2015	17:08	3	115	38	Tree related-tree contact	Fuse	Replace - Same Size		III
5150311	M26161	10/24/2015	16:52	10/24/2015	17:46	996	53485	53	Overhead equipment	Overhead Transformer	Repair		III
5150209	M26161	10/24/2015	16:53	10/24/2015	16:55	42	98	2	Unknown				III
5150213	M26161	10/24/2015	16:53	10/24/2015	16:55	108	243	2	Unknown				III

Order Number	Circuit	Start Date	Start Time	Restore Date	Restore Time	CI	CMI	Duration	ICC cause code	Component	Restore Work	Permanent Repair	Division
5150207	M26161	10/24/2015	16:53	10/24/2015	16:55	175	393	2	Unknown				III
5150239	M26161	10/24/2015	16:55	10/24/2015	19:00	48	5956	124	Overhead equipment	Connector	Repair		III
5150343	M26164	10/24/2015	17:08	10/24/2015	17:50	1	41	41	Overhead equipment	Recloser	Switch/Reset		III
5150345	R01153	10/24/2015	17:22	10/24/2015	18:05	14	601	42	Overhead equipment	Fuse			III
5150347	S78551	10/24/2015	17:43	10/24/2015	20:30	3	500	166	Overhead equipment	Transformer Fuse	Replace - Same Size		VI
5150351	HB6283	10/24/2015	17:48	10/24/2015	19:02	1	73	73	Animal related	Fuse	Replace - Same Size		VI
5150353	N94180	10/24/2015	18:41	10/24/2015	21:30	1	168	168	Unknown	Other	Replace - Same Size	Replace - Same Size	I
5150361	Z43549	10/24/2015	19:10	10/24/2015	19:27	5	80	16	Overhead equipment	Fuse	Replace - Same Size		IV
5150363	S60581	10/24/2015	19:20	10/24/2015	21:38	1	137	137	Animal related	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
5150365	Y60593	10/24/2015	19:33	10/24/2015	23:53	1	259	259	Underground equipment	Underground Service	Repair	Repair	IV
5150369	Q74148	10/24/2015	21:18	10/25/2015	4:31	5	2162	432	Overhead equipment	Pole	Replace - Same Size		IV
5150389	M19222	10/24/2015	23:22	10/25/2015	4:45	132	23394	323	Overhead equipment	Overhead Primary	Patrol/Test/Inspect	Replace - Same Size	VI
5150409	K27150	10/24/2015	23:38	10/25/2015	2:58	1	199	199	Overhead equipment	Overhead Primary	Patrol/Test/Inspect	Repair	VI
5150415	P71830	10/24/2015	23:39	10/25/2015	3:14	18	3867	214	Public	Overhead Primary	Repair		V
5150421	R20502	10/25/2015	1:11	10/25/2015	6:29	11	997	317	Underground equipment	Underground Primary		Repair	IV
5150431	X30506	10/25/2015	2:32	10/25/2015	4:48	19	2591	136	Underground equipment	Other		Repair	IV
5150429	H06135	10/25/2015	2:32	10/25/2015	4:02	10	901	90	Underground equipment	Underground Primary		Repair	IV
5150435	U61568	10/25/2015	5:07	10/25/2015	8:35	1	207	207	Overhead equipment	Overhead Transformer	Replace - New Size		II
5150441	S86582	10/25/2015	7:20	10/25/2015	10:01	1	160	160	Unknown	Transformer Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
5150443	Y31589	10/25/2015	7:44	10/25/2015	8:40	1	55	55	Animal related	Fuse	Repair	Replace - Same Size	IV
5150447	B73003	10/25/2015	7:57	10/25/2015	9:11	1	73	73	Other				I
5150449	K27153	10/25/2015	7:57	10/25/2015	9:15	1	77	77	Overhead equipment	Transformer Fuse	Replace - Same Size	Repair	VI
5150451	P42229	10/25/2015	7:59	10/25/2015	8:39	1	39	39	Animal related	Fuse	Replace - Same Size		VI
5150453	Q36410	10/25/2015	8:02	10/25/2015	9:05	9	560	62	Public	Overhead Secondary	Replace - Same Size		I
5150455	X24536	10/25/2015	8:19	10/25/2015	10:40	1	140	140	Animal related	Transformer Fuse	Repair	Patrol/Test/Inspect	IV
5150457	X24536	10/25/2015	8:25	10/25/2015	10:40	1	134	134	Animal related	Transformer Fuse	Repair	Patrol/Test/Inspect	IV
5150459	L93132	10/25/2015	8:31	10/25/2015	9:50	6	472	78	Animal related	Fuse	Replace - Same Size		VI
5150461	L93132	10/25/2015	8:32	10/25/2015	9:50	38	2959	77	Animal related	Fuse	Replace - Same Size		VI
5150467	M42105	10/25/2015	8:43	10/25/2015	9:50	1	66	66	Animal related	Transformer Fuse	Replace - Same Size		I
5150473	B77002	10/25/2015	8:49	10/25/2015	12:54	37	9057	244	Overhead equipment	Crossarm	Tie/Tighten	Repair	I
5150475	M78323	10/25/2015	8:49	10/25/2015	10:45	53	6104	115	Overhead equipment	Disconnect Switch	Replace - Same Size		V
5150481	P47123	10/25/2015	8:52	10/25/2015	10:56	9	1107	123	Animal related	Transformer Fuse	Replace - Same Size		I
5150483	B80002	10/25/2015	8:58	10/25/2015	10:05	7	468	66	Animal related	Transformer Fuse	Replace - Same Size		I
5150485	Y68582	10/25/2015	8:59	10/25/2015	10:24	1	84	84	Animal related	Animal Guard		Install	IV
5150487	X65540	10/25/2015	9:03	10/25/2015	10:49	1	105	105	Animal related	Transformer Fuse	Replace - Same Size		IV
5150493	P17107	10/25/2015	9:12	10/25/2015	10:50	36	3496	97	Animal related	Fuse	Replace - Same Size		IV
5150507	B77003	10/25/2015	9:31	10/25/2015	12:15	14	2282	163	Overhead equipment	Underground Primary	Replace - Same Size	Replace - Same Size	I
5150505	K07320	10/25/2015	9:32	10/25/2015	10:21	1	48	48	Animal related	Transformer Fuse	Replace - Same Size	Replace - Same Size	I
5150509	T12528	10/25/2015	9:38	10/25/2015	10:40	1	61	61	Animal related	Fuse	Patrol/Test/Inspect	Replace - Same Size	VI
5150511	R02121	10/25/2015	9:39	10/25/2015	10:15	1	35	35	Overhead equipment	Transformer Fuse	Repair	Repair	VI
5150513	B73003	10/25/2015	9:39	10/25/2015	10:12	1	32	32	Other				I
5150517	Q23258	10/25/2015	9:45	10/25/2015	10:29	1	43	43	Animal related	Fuse	Replace - Same Size		VI
5150519	J76804	10/25/2015	9:46	10/25/2015	10:37	11	554	50	Animal related	Overhead Transformer	Repair	Repair	V
5150523	M36185	10/25/2015	10:02	10/25/2015	11:29	4	344	86	Animal related	Transformer Fuse	Replace - Same Size		I
5150531	M41111	10/25/2015	10:07	10/25/2015	11:50	15	1537	102	Animal related	Fuse	Replace - Same Size		I
5150551	M19222	10/25/2015	10:17	10/25/2015	16:16	4	1439	359	Underground equipment	Underground Primary	Patrol/Test/Inspect		VI
5150553	M19222	10/25/2015	10:25	10/25/2015	12:21	1	115	115	Underground equipment	Underground Primary	Patrol/Test/Inspect	Repair	VI
5150535	M36184	10/25/2015	10:47	10/25/2015	11:29	1	41	41	Animal related	Transformer Fuse	Replace - Same Size		I
5150539	J34377	10/25/2015	11:01	10/25/2015	13:23	3	425	141	Animal related	Transformer Fuse	Repair		V
5150541	X02547	10/25/2015	11:10	10/25/2015	12:40	1	89	89	Animal related	Fuse	Repair	Replace - Same Size	IV
5150547	B77002	10/25/2015	11:33	10/25/2015	12:57	1	83	83	Overhead equipment	Crossarm	Repair		I
5150549	X60596	10/25/2015	11:39	10/25/2015	12:39	5	295	59	Animal related	Transformer Fuse	Replace - Same Size	Replace - Same Size	IV
5150555	H22346	10/25/2015	11:59	10/25/2015	14:15	4	543	135	Animal related	Transformer Fuse	Repair		V
5150561	V92543	10/25/2015	13:29	10/25/2015	14:28	2	116	58	Animal related	Transformer Fuse	Replace - Same Size	Replace - Same Size	II
5150571	L74193	10/25/2015	15:16	10/25/2015	15:40	1	23	23	Overhead equipment	Overhead Service	Repair		IV
5150573	HE3304	10/25/2015	15:25	10/25/2015	16:57	6	551	91	Animal related	Fuse	Replace - Same Size		VI