

Hydrant Inspection Report

Docket No. 01-0489

ICC Staff Exh. 3.00

Schedule 3.01

pg. 1 of 2

System: Highland Shores Water Company

Hydrant #	Location	1997	2001	Comments
		Gals. per min.	Gals. per min.	
13	Wellhouse on Memory Trail		880	a) Relace - operated by Hydrant valve b) Hydrants requires painting.
				COMPLETED
18	Between Vine Ave & Oriole Trail on Pleasure Lane	340	340	Cl. - 0.5
17	Between Evergreen & Oriole Trail on Thompson	630	600	a) Increaser height of hydrant (18" to middle of cap.) b) Hydrants requires painting.
16	Between Evergreen & Pine on Meadow Lane	425	425	a) Hydrant hard to operate. b) Hydrants requires painting.
10	Memory & Meadow	935	900	a) Hydrants requires painting.
7	Between Shady & Sunset on Meadow Lane	770	770	a) Hydrants requires painting.
2	Between Acorn & Ramble on Meadow Lane	400	380	a) Hydrants requires painting.
1	Between Highland & Woody on Meadow Lane	340	380	a) Replace - upper barrel crack.
3	Thompson & Acorn	530	530	a) Hydrants requires painting.
5	Between Ramble & sunset on Thompson	770	790	a) Hydrants requires painting.
				COMPLETED

Note: No Change from last inspection

Hydrant Inspection Report

Docket No. 01-0489

ICC Staff Exh. 3.00

Schedule 3.01

pg. 2 of 2

System: Highland Shores Water Company

		1997	2001	
Hydrant #	Location	Gals.per min.	Gals.per min.	Comments
14	Westwood Dr. & Elm St.		660	a) Hard to operate (needed extension bar to provide assist).
				a) Hydrant requires painting.
11	Between Memory & Shady on Thompson	830	800	
15	Between Memory & Elm on Lake Vista	730	710	a) Replace - upper barrel crack
8	Westwood Dr.		No Flow test	a) Replace - cracked barrel
9	Between Sunset & Shady on Lake Vista	670	590	a) Hydrant requires painting; and b) Hydrant hard to operate (needed extension bar to provide assist.)
12	Between Memory & Shady on Lake Shore Drive	750	750	a) Hydrant requires painting.
6	Between Ramble & Sunset on Lake Shore Drive	750	750	a) Hydrant requires painting.
4	Between Acorn & Ramble on Lake Vista			a) Replace - Not operable
Flushing Valves				
39		340	340	a) Install flushing hydrants.
1	Highland	340	340	a) Install flushing hydrants.
2	Thompson	340	340	a) Install flushing hydrants.
3		370	370	
Note: No Change from last inspection				

011382


 **BOO2
 HIGHLAND SHORES WATER CO
 PO BOX 189
 WONDER LAKE, IL 60097

Residential Cust
1-800-Edi

Docket No. 01-0489
04. ICC Staff Exhibit 3.0
Schedule 3.02 (a)



Account Number
0429211003

Payment Amount


 ComEd
 PO Box 805376
 Chicago IL 60680-5376

00000741490005072766

042921100300000000020170000005

Return this portion with your check made payable to ComEd. Please write your account number on your check.

When paying in person, please bring the entire bill.

Page 1
 Name HIGHLAND SHORES WATER CO
 Service Location 9001 MEMORY TRAIL, GREENWOOD TWP
 Phone Number 815- 653-2961
 Account Number 0429211003
 Issue Date 11/30/2001

04292 1100 30002 0175



Meter Information	Read Date	Meter Number	Load Type	Reading Type	Meter Reading		Diff	Mult x	Usage
					Previous	Present			
	11/30	998125169	Pumping	On Pk kW	ACT	ACT			15.
	11/30	998125169	Pumping	Tot kWh	ACT	ACT			63
	11/30	998125171	Pumping	On Pk kW	ACT	ACT			11.
	11/30	998125171	Pumping	Tot kWh	ACT	ACT			30.

Current Period	Water and Sewage Pumping Service	Service from 10/30/2001 to 11/30/2001 - 31 Da:
	Customer charge	\$4.50
	Energy charge 9,362 kWh X	721.25
	Load factor discount	-21.64
	Decommissioning adjustment 9,362 kWh X	7.30
	Instrument Funding Charge Credit 9,362 kWh X	-37.07
	Instrument Funding Charge Debit 9,362 kWh X	37.07
	State tax	30.08
	Total current charges	\$741.49