

OFFICIAL FILE

I.C.C. DOCKET NO. 01-0668

EXHIBIT NO. 9

Witness Leap

Date 1-31-02 Reporter RF

**A REQUEST FOR SPECIAL INSPECTION TO SURVEY PREMISE**

**Date to Special Representative:** 06/18/01      **Date Requested:** 07/03/01

**Requested By:** Sally B Johnson

**Address:** 5007 S. King Dr      **Time:** 9:30

**Floor Location:** BD

**Name:** Jerome Malery      **Phone No:** (773) 935-4425

**What's needed & Access Info:** High bill complaint, states supplying hot water for 6 units only. Records indicate sure read device here registering on the average of 800 CCf's per month. Please verify. If there is no one in sight to admit you please call (773)935-4425 and Mrs. Houston will contact the Janitor who will be somewhere on the premises.

**What was found:** I found a unit heater improperly installed in the bse here. An old range was also found connected here. There was a pipe connected here that went upstairs into an apartment and another pipe ran back to the awh.

**Meter #-PGL records:** P1578462      **ERT # -PGL records:** 15944773

**Meter # verified:**      **ERT # verified:**

Earl Jerome Malry v. The Peoples Gas Light and Coke Company  
Ill.C.C. Docket No. 01-0668  
Respondent's Exhibit Number \_\_\_\_\_